

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 28.06.22 TO 04.07.2022

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|---------------------------------|---|-----------------------|-----------------------|----------|---------------------------------------|
| 1 | 28-Jun-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 2 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHVAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 3 | 28-Jun-2022 | BAGALKOT | 110 | AMBEWADI-NK2(KAVALWADA) | STATION NOT AFFECTED AMBEWADI_220 | 8:55 (23.05.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 4 | 28-Jun-2022 | BAGALKOT | 110 | HUBLI220- ANAND NAGAR | STATION NOT AFFECTED HUBLI_220 | 11:37 (14.06.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 5 | 28-Jun-2022 | BAGALKOT | 220 | NARENDRA- AMBEWADI1 | STATION NOT AFFECTED NARENDRA_220 | 10:05 (15.06.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 6 | 28-Jun-2022 | BAGALKOT | 220 | SIRSI220-HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 7 | 28-Jun-2022 | BAGALKOT | 220 | VAJRAMATTI-KUDAGI-I (KUDAGI-II) | STATION NOT AFFECTED VAJRAMATTI_220 | 23:04 (27.06.2022) | 16:44 (28.06.2022) | 17:40hrs | LINE CHARGED |
| 8 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | AINAPUR_110 | 17:00 | 17:02 | 0:02 | TRANSFORMER FAULT |
| 9 | 28-Jun-2022 | BAGALKOT | 110 | DAVALESHWAR-SAIDAPUR | STATION NOT AFFECTED DAVALESHWAR_110 | 11:00 | 16:38 | 5:38 | LINE FAULT |
| 10 | 28-Jun-2022 | BAGALKOT | 110 | BELGAUM-HUDLI | STATION NOT AFFECTED HUDLI_110 | 16:20 (28.06.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 11 | 28-Jun-2022 | BAGALKOT | 110 | HUKKERI-VISHWANATH SUGARS | STATION NOT AFFECTED HUKKERI_110 | 5:48 | 6:07 | 0:19 | LINE FAULT |
| 12 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV4 | HUKKERI_110 | 14:17 | 14:26 | 0:09 | TRANSFORMER FAULT |
| 13 | 28-Jun-2022 | BAGALKOT | 110 | MAHALINGAPUR-DAVALESHWAR | DAVALESHWAR_110 | 12:05 | 13:10 | 1:05 | LINE CLEAR AVOIDED |
| 14 | 28-Jun-2022 | BAGALKOT | 110 | NAREGAL-BETAGERI | STATION NOT AFFECTED NAREGAL_110 | 5:08 | 5:09 | 0:01 | HAND TRIPPED |
| 15 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | RAIBAG_110 | 5:28 | 5:35 | 0:07 | TRANSFORMER FAULT |
| 16 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | RAIBAG_110 | 15:28 | 15:35 | 0:07 | TRANSFORMER FAULT |
| 17 | 28-Jun-2022 | BAGALKOT | 110 | HUBLI-RAMANAKOPPA | STATION NOT AFFECTED RAMANAKOPPA_110 | 10:33 | 14:14 | 3:41 | LINE CLEAR AVOIDED |
| 18 | 28-Jun-2022 | BAGALKOT | 110 | RON-NAREGAL | STATION NOT AFFECTED RON_110 | 4:24 | 5:04 | 0:40 | LINE FAULT |
| 19 | 28-Jun-2022 | BAGALKOT | 110 | RON-HIREHAL | STATION NOT AFFECTED RON_110 | 4:24 | 5:08 | 0:44 | LINE FAULT |
| 20 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | TODALBAGI_110 | 12:24 | 12:35 | 0:11 | TRANSFORMER FAULT |
| 21 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | YADAWAD_110 | 12:19 | 13:10 | 0:51 | TRANSFORMER FAULT |
| 22 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | YADAWAD_110 | 13:10 | 13:15 | 0:05 | HAND TRIPPED |
| 23 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | YADAWAD_110 | 13:10 | 13:15 | 0:05 | HAND TRIPPED |
| 24 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | YELLAMANAWADI_110 | 15:02 | 15:34 | 0:32 | HAND TRIPPED |
| 25 | 28-Jun-2022 | BAGALKOT | 110 | KARWAR-ARGA | ARGA_110 | 4:15 | 4:39 | 0:24 | LINE FAULT |
| 26 | 28-Jun-2022 | BAGALKOT | 220 | VAJRAMATTI-KUDAGI-I | STATION NOT AFFECTED VAJRAMATTI_220 | 11:57 | 16:44 | 4:45 | LINE CLEAR AVOIDED |
| 27 | 28-Jun-2022 | BAGALKOT | 110 | 110/33KV, HV3 | YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 28 | 28-Jun-2022 | BAGALKOT | 220 | SIRSI220-HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|---------------------------------|---|-----------------------|-----------|----------|-------------------------------|
| 29 | 28-Jun-2022 | BAGALKOT | 110 | BELGAUM110-KANABARGI LAYOUT | STATION NOT AFFECTED BELGAUM_110 | 10:50 (26.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 30 | 28-Jun-2022 | BAGALKOT | 110 | RON-BELAVANKI | STATION NOT AFFECTED BELAVANKI_110 | 10:40 | 16:40 | 6:00 | LINE CLEAR AVAILED |
| 31 | 28-Jun-2022 | BAGALKOT | 110 | ANKOLA-ARGA | ANKOLA_110 | 4:15 | 6:01 | 1:46 | LINE FAULT |
| 32 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | STATION NOT AFFECTED ANKOLA_110 | 13:55 | 14:10 | 0:15 | TRANSFORMER FAULT |
| 33 | 28-Jun-2022 | BAGALKOT | 220 | 220/110KV,HV4,LV4 | GADAG_220 | 11:40 | 19:15 | 7:35 | LINE CLEAR AVAILED |
| 34 | 28-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MUDHOL_110 | 11:34 | 12:10 | 0:36 | LINE CLEAR AVAILED |
| 35 | 28-Jun-2022 | BAGALKOT | 110 | RAMANAKOPPA | STATION NOT AFFECTED HUBLI_220 | 10:35 | 13:36 | 3:01 | LINE CLEAR AVAILED |
| 36 | 28-Jun-2022 | BAGALKOT | 220 | KADRA -KARWAR2 | STATION NOT AFFECTED KARWAR_220 | 14:25 | 18:32 | 4:07 | LINE CLEAR AVAILED |
| 37 | 28-Jun-2022 | BENGALURU | 66 | BIDADI 220 - HEJJALA | BIDADI 220 | 10:15 | 10:50 | 0:35 | LINE FAULT |
| 38 | 28-Jun-2022 | BENGALURU | 66 | HV1 | BIDADI 220 | 10:15 | 10:50 | 0:35 | MAIN SUPPLY FAILURE |
| 39 | 28-Jun-2022 | BENGALURU | 66 | HV1 | BIDADI 220 | 10:15 | 10:50 | 0:35 | MAIN SUPPLY FAILURE |
| 40 | 28-Jun-2022 | BENGALURU | 66 | HV3 | BIDADI 220 | 10:15 | 10:50 | 0:35 | MAIN SUPPLY FAILURE |
| 41 | 28-Jun-2022 | BENGALURU | 66 | BIDADI 220 - BOSCH (EHT) | BOSCH (EHT) | 10:20 | 10:50 | 0:30 | MAIN SUPPLY FAILURE |
| 42 | 28-Jun-2022 | BENGALURU | 66 | BIDADI 220 - EPIPL (EHT) | EPIPL (EHT) | 10:20 | 10:50 | 0:30 | MAIN SUPPLY FAILURE |
| 43 | 28-Jun-2022 | BENGALURU | 66 | HV1 | BOODIGERE | 17:36 | 18:40 | 1:04 | LINE CLEAR AVAILED |
| 44 | 28-Jun-2022 | BENGALURU | 66 | HV1 | BRIGADE MEADOWS | 13:39 | 13:50 | 0:11 | LINE CLEAR AVAILED |
| 45 | 28-Jun-2022 | BENGALURU | 66 | HV2 | BRIGADE MEADOWS | 13:39 | 13:50 | 0:11 | LINE CLEAR AVAILED |
| 46 | 28-Jun-2022 | BENGALURU | 66 | HV1 | BRIGADE MEADOWS | 10:03 | 10:13 | 0:10 | LINE CLEAR AVAILED |
| 47 | 28-Jun-2022 | BENGALURU | 66 | HV2 | BRIGADE MEADOWS | 10:03 | 10:13 | 0:10 | LINE CLEAR AVAILED |
| 48 | 28-Jun-2022 | BENGALURU | 66 | HV1 | ELECTRONIC CITY P2 S1 | 12:41 | 12:43 | 0:02 | LINE CLEAR AVAILED |
| 49 | 28-Jun-2022 | BENGALURU | 66 | HV3 | ELECTRONIC CITY P2 S1 | 15:15 | 15:19 | 0:04 | LINE CLEAR AVAILED |
| 50 | 28-Jun-2022 | BENGALURU | 66 | HV1 | GURUVINAPURA | 17:05 | 17:23 | 0:18 | LINE CLEAR AVAILED |
| 51 | 28-Jun-2022 | BENGALURU | 66 | HV1 | KHB | 9:45 | 9:49 | 0:04 | LINE CLEAR AVAILED |
| 52 | 28-Jun-2022 | BENGALURU | 66 | HV1 | PRIMAL | 12:35 | 12:40 | 0:05 | LINE CLEAR AVAILED |
| 53 | 28-Jun-2022 | BENGALURU | 66 | HV1 | PRIMAL | 10:35 | 10:40 | 0:05 | LINE CLEAR AVAILED |
| 54 | 28-Jun-2022 | BENGALURU | 66 | HV2 | PRIMAL | 12:40 | 12:45 | 0:05 | LINE CLEAR AVAILED |
| 55 | 28-Jun-2022 | BENGALURU | 66 | HV2 | PRIMAL | 14:05 | 14:12 | 0:07 | LINE CLEAR AVAILED |
| 56 | 28-Jun-2022 | BENGALURU | 66 | HV2 | RMV | 13:41 | 13:44 | 0:03 | LINE CLEAR AVAILED |
| 57 | 28-Jun-2022 | BENGALURU | 66 | HV2 | RMV | 15:49 | 15:52 | 0:03 | LINE CLEAR AVAILED |
| 58 | 28-Jun-2022 | BENGALURU | 66 | HV2 | SHOBHA APARTMENT | 15:17 | 15:26 | 0:09 | LINE CLEAR AVAILED |
| 59 | 28-Jun-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - ANDERSONPETE | DODDAKARI, KYASAMBALLI, ANDERSONPETE | 5:18 | 5:34 | 0:16 | LINE FAULT |
| 60 | 28-Jun-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - ANDERSONPETE | DODDAKARI, KYASAMBALLI, ANDERSONPETE | 7:10 | 7:35 | 0:25 | LINE FAULT |
| 61 | 28-Jun-2022 | BENGALURU | 66 | TK HALLI 220 - SHIMSHA | NO STATION AFFECTED | 5:35 | 6:00 | 0:25 | LINE FAULT |
| 62 | 28-Jun-2022 | BENGALURU | 66 | HV1 | RBI | 12:00 | 12:05 | 0:05 | LINE CLEAR AVAILED |
| 63 | 28-Jun-2022 | BENGALURU | 66 | SUBRAMANYAPURA 220 - SARAKKI 1 | ISRO LAYOUT | 10:19 | 10:22 | 0:03 | LINE CLEAR AVAILED |
| 64 | 28-Jun-2022 | BENGALURU | 66 | SUBRAMANYAPURA 220 - SARAKKI 1 | ISRO LAYOUT | 15:54 | 15:58 | 0:04 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--|-------------------------------------|---------|-----------|----------|--------------------|
| 65 | 28-Jun-2022 | BENGALURU | 66 | SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 | SUBRAMANYAPURA 66 | 10:27 | 10:30 | 0:03 | LINE CLEAR AVAILED |
| 66 | 28-Jun-2022 | BENGALURU | 66 | SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 | SUBRAMANYAPURA 66 | 16:42 | 16:46 | 0:04 | LINE CLEAR AVAILED |
| 67 | 28-Jun-2022 | BENGALURU | 66 | HV2 | THAYALUR | 10:30 | 12:14 | 1:44 | LINE CLEAR AVAILED |
| 68 | 28-Jun-2022 | BENGALURU | 66 | HV2 | TYAMAGONDLU | 6:40 | 6:46 | 0:06 | TRANSFORMER FAULT |
| 69 | 28-Jun-2022 | BENGALURU | 66 | HV1 | TEKAL | 12:05 | 13:10 | 1:05 | LINE CLEAR AVAILED |
| 70 | 28-Jun-2022 | BENGALURU | 66 | HV2 | TEKAL | 10:55 | 11:59 | 1:04 | LINE CLEAR AVAILED |
| 71 | 28-Jun-2022 | BENGALURU | 66 | HV1 | SM MANGALA | 10:55 | 11:00 | 0:05 | LINE CLEAR AVAILED |
| 72 | 28-Jun-2022 | BENGALURU | 66 | HV2 | SM MANGALA | 12:25 | 12:30 | 0:05 | LINE CLEAR AVAILED |
| 73 | 28-Jun-2022 | BENGALURU | 66 | HV1 | SIDDALAGATTA | 16:36 | 16:40 | 0:03 | LINE CLEAR AVAILED |
| 74 | 28-Jun-2022 | BENGALURU | 66 | HV2 | SIDDALAGATTA | 11:18 | 11:23 | 0:05 | LINE CLEAR AVAILED |
| 75 | 28-Jun-2022 | BENGALURU | 66 | HV1 | N G HULKUR | 11:45 | 11:50 | 0:05 | LINE CLEAR AVAILED |
| 76 | 28-Jun-2022 | BENGALURU | 66 | HV2 | N G HULKUR | 14:30 | 14:35 | 0:05 | LINE CLEAR AVAILED |
| 77 | 28-Jun-2022 | BENGALURU | 66 | HV1 | MUDIYANUR | 16:07 | 16:10 | 0:02 | LINE CLEAR AVAILED |
| 78 | 28-Jun-2022 | BENGALURU | 66 | HV1 | MUDIYANUR | 17:55 | 18:31 | 0:36 | LINE CLEAR AVAILED |
| 79 | 28-Jun-2022 | BENGALURU | 66 | HV1 | MALLANAYAKANA HALLI | 15:32 | 15:38 | 0:05 | LINE CLEAR AVAILED |
| 80 | 28-Jun-2022 | BENGALURU | 66 | MANDIKAL - GOWRIBIDANUR 220 | MANDIKAL | 10:00 | 11:21 | 1:21 | LINE CLEAR AVAILED |
| 81 | 28-Jun-2022 | BENGALURU | 66 | HV2 | MAASTHI | 11:00 | 11:05 | 0:05 | LINE CLEAR AVAILED |
| 82 | 28-Jun-2022 | BENGALURU | 66 | HV2 | KOLAR 220 | 15:20 | 15:25 | 0:04 | LINE CLEAR AVAILED |
| 83 | 28-Jun-2022 | BENGALURU | 66 | HV2 | KODIHALLI HAROBELE | 9:25 | 9:39 | 0:14 | TRANSFORMER FAULT |
| 84 | 28-Jun-2022 | BENGALURU | 66 | HV1 | JULLUPALYA | 12:04 | 12:09 | 0:04 | LINE CLEAR AVAILED |
| 85 | 28-Jun-2022 | BENGALURU | 66 | HV2 | JULLUPALYA | 10:45 | 10:50 | 0:05 | LINE CLEAR AVAILED |
| 86 | 28-Jun-2022 | BENGALURU | 66 | HV1 | H GOLLAHALLI | 17:43 | 18:49 | 1:05 | LINE CLEAR AVAILED |
| 87 | 28-Jun-2022 | BENGALURU | 66 | HV2 | H GOLLAHALLI | 17:15 | 18:15 | 1:00 | LINE CLEAR AVAILED |
| 88 | 28-Jun-2022 | BENGALURU | 66 | HV1 | BANGARPET | 11:14 | 11:20 | 0:05 | LINE CLEAR AVAILED |
| 89 | 28-Jun-2022 | BENGALURU | 66 | HV2 | BANGARPET | 12:40 | 12:45 | 0:04 | LINE CLEAR AVAILED |
| 90 | 28-Jun-2022 | BENGALURU | 66 | CHANDAPURA - SARJAPURA 220 | CHANDAPURA | 6:30 | 6:38 | 0:08 | LOAD CHANGE OVER |
| 91 | 28-Jun-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2(DG3) | KONDASPURA | 10:07 | 10:33 | 0:26 | LINE FAULT |
| 92 | 28-Jun-2022 | BENGALURU | 66 | KONDASPURA - EPIP 220 | KONDASPURA | 11:58 | 12:00 | 0:02 | LOAD CHANGE OVER |
| 93 | 28-Jun-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2(DG3) | BELL CERAMICS (EHT) | 10:07 | 11:43 | 1:36 | LINE FAULT |
| 94 | 28-Jun-2022 | BENGALURU | 66 | T GOLAHALLI 220 - ANDERSONPET | ANDERSONPET, KYASAMBALLI, DODDAKARI | 5:18 | 5:34 | 0:16 | LINE FAULT |
| 95 | 28-Jun-2022 | BENGALURU | 66 | T GOLAHALLI 220 - ANDERSONPET | ANDERSONPET, KYASAMBALLI, DODDAKARI | 7:10 | 7:35 | 0:25 | LINE FAULT |
| 96 | 28-Jun-2022 | BENGALURU | 66 | HV1 | TORALAKKI | 10:00 | 11:00 | 1:00 | LINE CLEAR AVAILED |
| 97 | 28-Jun-2022 | BENGALURU | 66 | HV1 | MALUR 66 | 15:30 | 15:35 | 0:05 | LINE CLEAR AVAILED |
| 98 | 28-Jun-2022 | BENGALURU | 66 | HV2 | MALUR 66 | 10:15 | 10:20 | 0:05 | LINE CLEAR AVAILED |
| 99 | 28-Jun-2022 | BENGALURU | 66 | HV3 | MALUR 66 | 13:10 | 13:15 | 0:05 | LINE CLEAR AVAILED |
| 100 | 28-Jun-2022 | BENGALURU | 66 | HV1 | BUDIKOTE | 11:40 | 11:45 | 0:05 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|------------------------------|--------------------------|-----------------------|-------------------|----------|-------------------------------|
| 101 | 28-Jun-2022 | BENGALURU | 66 | HV2 | BUDIKOTE | 12:50 | 12:55 | 0:05 | LINE CLEAR AVAILED |
| 102 | 28-Jun-2022 | BENGALURU | 66 | HV2 | KAMASAMUDRA | 11:25 | 12:30 | 1:05 | LINE CLEAR AVAILED |
| 103 | 28-Jun-2022 | BENGALURU | 66 | HV1 | KGF | 14:10 | 14:15 | 0:05 | LINE CLEAR AVAILED |
| 104 | 28-Jun-2022 | BENGALURU | 66 | HV1 | LAKKUR | 13:25 | 13:30 | 0:05 | LINE CLEAR AVAILED |
| 105 | 28-Jun-2022 | BENGALURU | 66 | HV2 | LAKKUR | 11:30 | 11:35 | 0:05 | LINE CLEAR AVAILED |
| 106 | 28-Jun-2022 | BENGALURU | 66 | DB PURA 220 - DEVANAHALLI 1 | KUNDANA | 14:02 | 14:17 | 0:15 | LINE FAULT |
| 107 | 28-Jun-2022 | BENGALURU | 66 | DB PURA 220 - DEVANAHALLI 2 | DEVANAHALLI | 14:02 | 14:20 | 0:18 | LINE FAULT |
| 108 | 28-Jun-2022 | BENGALURU | 220 | HV1 | KUMBALAGODU | 10:15 | 10:35 | 0:20 | TRANSFORMER FAULT |
| 109 | 28-Jun-2022 | BENGALURU | 220 | HV1 | KUMBALAGODU | 10:35 | 17:04 | 6:29 | TRANSFORMER FAULT |
| 110 | 28-Jun-2022 | BENGALURU | 66 | KUMBALAGODU - HEJJALA | HEJJALA | 10:15 | 10:50 | 0:35 | MAIN SUPPLY FAILURE |
| 111 | 28-Jun-2022 | BENGALURU | 66 | HOODY 220 - BMRCL | NO STATION AFFECTED | 23:46:00(28/06/2022) | | | LINE OPEN,LINE FAULT |
| 112 | 28-Jun-2022 | BENGALURU | 66 | BIDADI 220 - COCO COLA (EHT) | COCO COLA (EHT) | 12:05(27/06/2022) | 23:41(28/06/2022) | 35:36HRS | LINE CHARGED |
| 113 | 28-Jun-2022 | GULBARGA | 400 | RTPS-MUNIRABAD | MUNIRABAD_400 | 10:04 (14.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 114 | 28-Jun-2022 | GULBARGA | 220 | HV1 | ITTAGI_220 | 18:36 | 18:45 | 0:09 | TRANSFORMER FAULT |
| 115 | 28-Jun-2022 | GULBARGA | 220 | LINGASUGUR-RTPS1 | RTPS1_220 | 1:05 | 1:16 | 0:11 | LINE FAULT |
| 116 | 28-Jun-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 23:28 | 23:48 | 0:20 | LINE FAULT |
| 117 | 28-Jun-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 118 | 28-Jun-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 119 | 28-Jun-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 11:30(23/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 120 | 28-Jun-2022 | GULBARGA | 110 | HV1 | MANVI_110 | 11:00 | 13:36 | 2:36 | LINE CLEAR AVAILED |
| 121 | 28-Jun-2022 | GULBARGA | 110 | HV2 | MANVI_110 | 14:43 | 16:29 | 1:46 | LINE CLEAR AVAILED |
| 122 | 28-Jun-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 16:59 | 17:05 | 0:06 | TRANSFORMER FAULT |
| 123 | 28-Jun-2022 | GULBARGA | 110 | HV2 | KUSHTAGI_220 | 3:00 | 3:05 | 0:05 | TRANSFORMER FAULT |
| 124 | 28-Jun-2022 | GULBARGA | 110 | HV2 | SIRIGERICROSS_110 | 21:25 | 21:50 | 0:25 | LINE CLEAR AVAILED |
| 125 | 28-Jun-2022 | GULBARGA | 110 | SEDAM-CHINCHOLI | CHINCHOLI_110 | 11:45 | 14:05 | 2:20 | LINE CLEAR AVAILED |
| 126 | 28-Jun-2022 | GULBARGA | 110 | KAPNOOR-MADIYAL | MADIYAL_110 | 5:42 | 5:46 | 0:04 | LINE FAULT |
| 127 | 28-Jun-2022 | GULBARGA | 110 | SEDAM-KURKUNTA | KURKUNTA_110 | 20:45 | 21:07 | 0:22 | LINE FAULT |
| 128 | 28-Jun-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 2:20 | 2:35 | 0:15 | LINE FAULT |
| 129 | 28-Jun-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 19:20 | 19:30 | 0:10 | LINE FAULT |
| 130 | 28-Jun-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 21:50 | 22:10 | 0:20 | LINE FAULT |
| 131 | 28-Jun-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110 | 2:43 | 2:47 | 0:04 | LINE FAULT |
| 132 | 28-Jun-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR2 | JEWARGI_110,NALWAR_110 | 5:21 | 5:30 | 0:09 | LINE FAULT |
| 133 | 28-Jun-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR2 | JEWARGI_110,NALWAR_110 | 5:55 | 6:06 | 0:11 | LINE FAULT |
| 134 | 28-Jun-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110 | 22:35 | 22:41 | 0:06 | LINE FAULT |
| 135 | 28-Jun-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 22:49 | 22:53 | 0:04 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-------------------------|---|-----------------------|-----------|----------|-------------------------------------|
| 136 | 28-Jun-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 23:40 | 23:48 | 0:08 | LINE FAULT |
| 137 | 28-Jun-2022 | GULBARGA | 110 | CHOWDAPUR-AFZALPUR | AFZALPUR_110 | 11:45 | 11:58 | 0:13 | LINE CLEAR AVAILED |
| 138 | 28-Jun-2022 | GULBARGA | 110 | KADAGANCHI-KBS SOLAR | KADAGANCHI_110 | 19:17 | 22:58 | 3:41 | LINE CLEAR AVAILED |
| 139 | 28-Jun-2022 | GULBARGA | 110 | KEREHALLI-TALAKUTAI_IPP | KEREHALLI_110 | 22:25(28.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 140 | 28-Jun-2022 | GULBARGA | 110 | HUMNABAD-MANEIKHELLI | MANAIKHELLI_110 | 5:30 | 5:38 | 0:08 | LINE FAULT |
| 141 | 28-Jun-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 0:56 | 6:17 | 5:21 | LINE FAULT |
| 142 | 28-Jun-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 10:31 | 14:53 | 4:22 | LINE CLEAR AVAILED |
| 143 | 28-Jun-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 22:18 | 22:28 | 0:10 | LINE FAULT |
| 144 | 28-Jun-2022 | GULBARGA | 110 | HALBARGA-KAMTHANA | KAMTHANA_110,HABSIKOTE_110 | 20:22 | 20:30 | 0:08 | LINE FAULT |
| 145 | 28-Jun-2022 | GULBARGA | 110 | YERADONA-BENUR | BENUR_110 | 8:00 | 17:45 | 9:45 | NFBC ISSUED |
| 146 | 28-Jun-2022 | GULBARGA | 110 | YERADONA-BENUR | BENUR_110 | 18:20 | 19:25 | 1:05 | LINE CLEAR AVAILED |
| 147 | 28-Jun-2022 | GULBARGA | 110 | ADAVI AMARESHWAR-MALLAT | ADAVI AMARESHWAR_110,JAWALGERA_110 | 0:08 | 0:12 | 0:04 | MAIN SUPPLY FAILURE |
| 148 | 28-Jun-2022 | GULBARGA | 66 | HV1,HV2 | UJJAINI_66 | 15:50 | 16:00 | 0:10 | LINE CLEAR AVAILED |
| 149 | 28-Jun-2022 | GULBARGA | 66 | HV1,HV2 | UJJAINI_66 | 16:10 | 16:30 | 0:20 | LINE CLEAR AVAILED |
| 150 | 28-Jun-2022 | GULBARGA | 66 | PUNABGHATA-NEELAGUNDA | PUNABGHATA_66,UCHANGIDURGA_66,BILCHOD_66,UJJAINI_66 | 5:55 | 6:00 | 0:05 | LINE FAULT |
| 151 | 28-Jun-2022 | GULBARGA | 66 | PUNABGHATA-NEELAGUNDA | PUNABGHATA_66,UCHANGIDURGA_66,BILCHOD_66,UJJAINI_66 | 15:40 | 15:45 | 0:05 | LINE FAULT |
| 152 | 28-Jun-2022 | GULBARGA | 66 | PUNABGHATA-NEELAGUNDA | PUNABGHATA_66,UCHANGIDURGA_66,BILCHOD_66,UJJAINI_66 | 15:50 | 15:55 | 0:05 | LINE FAULT |
| 153 | 28-Jun-2022 | GULBARGA | 66 | PUNABGHATA-NEELAGUNDA | PUNABGHATA_66,UCHANGIDURGA_66,BILCHOD_66,UJJAINI_66 | 16:10 | 16:15 | 0:05 | LINE FAULT |
| 154 | 28-Jun-2022 | GULBARGA | 66 | UJJANI-BREIPL | UJJAINI_66 | 12:42 | 12:55 | 0:13 | LINE FAULT |
| 155 | 28-Jun-2022 | GULBARGA | 66 | MUNIRABAD-MHD | VENKATAPURA_66,RRRSTEEL S_IPP, UPHALLI_66, HPHALLI_66 | 19:05 | 19:21 | 0:16 | LINE FAULT |
| 156 | 28-Jun-2022 | GULBARGA | 66 | HOSAHALLI-CJHALLI | HOSAHALLI_66 | 11:35 | 11:55 | 0:20 | MAIN SUPPLY FAILURE |
| 157 | 28-Jun-2022 | GULBARGA | 66 | UCCHANGIDURGA-BILCHOD | BILCHOD_110 | 14:15 | 15:15 | 1:00 | LINE CLEAR AVAILED |
| 158 | 28-Jun-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 159 | 28-Jun-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 160 | 28-Jun-2022 | HASSAN | 66 | HV2 | HASSAN_66 | 10:05 (6.06.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 161 | 28-Jun-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 13:12(18.06.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 162 | 28-Jun-2022 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 15:29(28.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|---------------------|---------------------|---------|-----------|----------|--------------------|
| 163 | 28-Jun-2022 | HASSAN | 220 | HV1 | HEGGUNJE_220 | 10:32 | 12:47 | 2:15 | LINE CLEAR AVAILED |
| 164 | 28-Jun-2022 | HASSAN | 220 | HV2 | HEGGUNJE_220 | 12:48 | 14:05 | 1:17 | LINE CLEAR AVAILED |
| 165 | 28-Jun-2022 | HASSAN | 110 | LV1 | HEGGUNJE_220 | 10:32 | 12:47 | 2:15 | LINE CLEAR AVAILED |
| 166 | 28-Jun-2022 | HASSAN | 110 | LV2 | HEGGUNJE_220 | 12:48 | 14:05 | 1:17 | LINE CLEAR AVAILED |
| 167 | 28-Jun-2022 | HASSAN | 220 | HV1 | KEMAR_220 | 10:27 | 11:44 | 1:17 | HAND TRIPPED |
| 168 | 28-Jun-2022 | HASSAN | 220 | HV1 | KEMAR_220 | 12:39 | 12:55 | 0:16 | HAND TRIPPED |
| 169 | 28-Jun-2022 | HASSAN | 220 | KEMAR-Varahi2 | KEMAR_220 | 10:28 | 11:43 | 1:15 | HAND TRIPPED |
| 170 | 28-Jun-2022 | HASSAN | 220 | KEMAR-Varahi2 | KEMAR_220 | 12:39 | 12:56 | 0:17 | HAND TRIPPED |
| 171 | 28-Jun-2022 | HASSAN | 110 | LV1 | KEMAR_220 | 10:27 | 11:44 | 1:17 | HAND TRIPPED |
| 172 | 28-Jun-2022 | HASSAN | 110 | LV1 | KEMAR_220 | 12:39 | 12:55 | 0:16 | HAND TRIPPED |
| 173 | 28-Jun-2022 | HASSAN | 110 | KEMAR-Manipal1 | KEMAR_220 | 10:26 | 11:44 | 1:18 | HAND TRIPPED |
| 174 | 28-Jun-2022 | HASSAN | 110 | KEMAR-Manipal1 | KEMAR_220 | 12:38 | 12:56 | 0:18 | HAND TRIPPED |
| 175 | 28-Jun-2022 | HASSAN | 110 | KEMAR-Manipal2 | KEMAR_220 | 10:26 | 12:26 | 2:00 | HAND TRIPPED |
| 176 | 28-Jun-2022 | HASSAN | 220 | MRSSHM-HONNALLI | MRSMG_220 | 10:15 | 17:45 | 7:30 | LINE CLEAR AVAILED |
| 177 | 28-Jun-2022 | HASSAN | 110 | MRSSHM-SS2 | MRSMG_220 | 10:30 | 12:49 | 2:19 | LINE CLEAR AVAILED |
| 178 | 28-Jun-2022 | HASSAN | 220 | SHRAVITY-TALAGUPPA1 | sharavathy_gen | 10:35 | 14:07 | 3:32 | LINE CLEAR AVAILED |
| 179 | 28-Jun-2022 | HASSAN | 220 | TALAGU-ST1 | TALAGUPPA_400 | 10:35 | 14:07 | 3:32 | LINE CLEAR AVAILED |
| 180 | 28-Jun-2022 | HASSAN | 220 | TALAGU-ST3 | TALAGUPPA_400 | 15:09 | 18:00 | 2:51 | LINE CLEAR AVAILED |
| 181 | 28-Jun-2022 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 10:28 | 11:43 | 1:15 | HAND TRIPPED |
| 182 | 28-Jun-2022 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 12:39 | 12:56 | 0:17 | HAND TRIPPED |
| 183 | 28-Jun-2022 | HASSAN | 110 | ANANDA-SHIMOGA | ANANDPURA_110 | 10:30 | 12:50 | 2:20 | LINE CLEAR AVAILED |
| 184 | 28-Jun-2022 | HASSAN | 110 | ANAVATI-BARNGI | ANAVATTI_110 | 16:30 | 16:50 | 0:20 | HAND TRIPPED |
| 185 | 28-Jun-2022 | HASSAN | 110 | HV2 | ANAVATTI_110 | 16:50 | 17:56 | 1:06 | TRANSFORMER FAULT |
| 186 | 28-Jun-2022 | HASSAN | 110 | BARANG-ANVATTI | BARANGI_110 | 16:25 | 16:45 | 0:20 | LINE CLEAR AVAILED |
| 187 | 28-Jun-2022 | HASSAN | 110 | HALADY1-HIRIYADKA | HALADY_110 | 19:00 | 19:22 | 0:22 | LINE FAULT |
| 188 | 28-Jun-2022 | HASSAN | 110 | HV1 | HIRENALLUR_110 | 17:10 | 17:25 | 0:15 | TRANSFORMER FAULT |
| 189 | 28-Jun-2022 | HASSAN | 110 | HV1 | HIRIYADKA_110 | 10:08 | 12:10 | 2:02 | LINE CLEAR AVAILED |
| 190 | 28-Jun-2022 | HASSAN | 110 | HV1 | KADUR_220 | 10:20 | 17:37 | 7:17 | LINE CLEAR AVAILED |
| 191 | 28-Jun-2022 | HASSAN | 110 | HV1 | KADUR_220 | 17:09 | 18:40 | 1:31 | TRANSFORMER FAULT |
| 192 | 28-Jun-2022 | HASSAN | 110 | HV1 | KADUR_220 | 18:47 | 18:53 | 0:06 | HAND TRIPPED |
| 193 | 28-Jun-2022 | HASSAN | 110 | HV2 | KADUR_220 | 17:03 | 17:09 | 0:06 | TRANSFORMER FAULT |
| 194 | 28-Jun-2022 | HASSAN | 110 | LV1 | KADUR_220 | 17:09 | 17:36 | 0:27 | TRANSFORMER FAULT |
| 195 | 28-Jun-2022 | HASSAN | 110 | LV2 | KADUR_220 | 17:09 | 17:37 | 0:28 | TRANSFORMER FAULT |
| 196 | 28-Jun-2022 | HASSAN | 110 | KADUR-NERELEKERE | KADUR_220 | 17:09 | 17:45 | 0:36 | LINE FAULT |
| 197 | 28-Jun-2022 | HASSAN | 110 | KADUR-NGNHL | KADUR_220 | 17:09 | 17:45 | 0:36 | LINE FAULT |
| 198 | 28-Jun-2022 | HASSAN | 110 | KADUR-TNGL | KADUR_220 | 17:09 | 17:45 | 0:36 | LINE FAULT |
| 199 | 28-Jun-2022 | HASSAN | 110 | KADUR-YGTI | KADUR_220 | 17:09 | 17:45 | 0:36 | LINE FAULT |
| 200 | 28-Jun-2022 | HASSAN | 110 | KAVOOR-KOCL | KAVOOR_220 | 10:00 | 12:17 | 2:17 | LINE CLEAR AVAILED |
| 201 | 28-Jun-2022 | HASSAN | 110 | MANIPAL-BRAMVR | MANIPAL_110 | 10:30 | 11:50 | 1:20 | HAND TRIPPED |
| 202 | 28-Jun-2022 | HASSAN | 110 | MANIPAL-BRAMVR | MANIPAL_110 | 12:42 | 13:02 | 0:20 | HAND TRIPPED |
| 203 | 28-Jun-2022 | HASSAN | 110 | MANIPAL-HIRIYADKA | MANIPAL_110 | 10:30 | 11:50 | 1:20 | HAND TRIPPED |
| 204 | 28-Jun-2022 | HASSAN | 110 | MANIPAL-HIRIYADKA | MANIPAL_110 | 12:42 | 13:02 | 0:20 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--------------------------|---|----------------------------|-----------|----------|-------------------------------|
| 205 | 28-Jun-2022 | HASSAN | 110 | HV3 | MANIPAL_110 | 10:30 | 11:50 | 1:20 | HAND TRIPPED |
| 206 | 28-Jun-2022 | HASSAN | 110 | HV3 | MANIPAL_110 | 12:42 | 13:02 | 0:20 | HAND TRIPPED |
| 207 | 28-Jun-2022 | HASSAN | 110 | MANIPAL-NITTUR | MANIPAL_110 | 10:30 | 11:50 | 1:20 | HAND TRIPPED |
| 208 | 28-Jun-2022 | HASSAN | 110 | MANIPAL-NITTUR | MANIPAL_110 | 12:42 | 13:02 | 0:20 | HAND TRIPPED |
| 209 | 28-Jun-2022 | HASSAN | 110 | MANIPAL-KEMAR1 | MANIPAL_110 | 10:30 | 11:50 | 1:20 | HAND TRIPPED |
| 210 | 28-Jun-2022 | HASSAN | 110 | MANIPAL-KEMAR1 | MANIPAL_110 | 12:42 | 13:02 | 0:20 | HAND TRIPPED |
| 211 | 28-Jun-2022 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPA_220 | 10:29 | 16:43 | 6:14 | LINE CLEAR AVOIDED |
| 212 | 28-Jun-2022 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 12:55 | 13:10 | 0:15 | MAIN SUPPLY FAILURE |
| 213 | 28-Jun-2022 | HASSAN | 66 | HV2 | BAGUR_66 | 13:47 | 14:05 | 0:18 | LINE CLEAR AVOIDED |
| 214 | 28-Jun-2022 | HASSAN | 66 | BELUR66-HASSAN | BELUR_66 | 12:21 | 15:11 | 2:50 | MAIN SUPPLY FAILURE |
| 215 | 28-Jun-2022 | HASSAN | 66 | HAGARE-HASSAN | HAGARE_66 | 14:30 | 14:40 | 0:10 | HAND TRIPPED |
| 216 | 28-Jun-2022 | HASSAN | 66 | HV2 | HIRISAVE_66 | 15:09 | 15:22 | 0:13 | LINE CLEAR AVOIDED |
| 217 | 28-Jun-2022 | HASSAN | 66 | HV1 | MALLAPURA_66 | 10:10 | 16:50 | 6:40 | LINE CLEAR AVOIDED |
| 218 | 28-Jun-2022 | HASSAN | 66 | HV2 | MALLAPURA_66 | 10:10 | 16:50 | 6:40 | LINE CLEAR AVOIDED |
| 219 | 28-Jun-2022 | HASSAN | 66 | MALLAPU-SHIMOGA | MALLAPURA_66 | 10:10 | 16:50 | 6:40 | LINE CLEAR AVOIDED |
| 220 | 28-Jun-2022 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESHUPURA_66 | 14:53 | 15:05 | 0:12 | LINE FAULT |
| 221 | 28-Jun-2022 | HASSAN | 66 | HV1 | SOMANAHALLI_66 | 14:18 | 16:10 | 1:52 | LINE CLEAR AVOIDED |
| 222 | 28-Jun-2022 | HASSAN | 66 | HV1 | UGANE_66 | 12:30 | 15:15 | 2:45 | NFBC ISSUED |
| 223 | 28-Jun-2022 | MYSURU | 66 | HV1 | HOOTAGALLY_220 | 13:15 | 13:33 | 0:18 | TRANSFORMER FAULT |
| 224 | 28-Jun-2022 | MYSURU | 66 | HOOTAGALLY-KHB | NO STATIONS EFFECTED | 10:08 | 11:13 | 1:05 | LINE CLEAR AVOIDED |
| 225 | 28-Jun-2022 | MYSURU | 66 | MADHUVANAHALLI-HEBBANI | NO STATIONS EFFECTED | 18:56 | 19:05 | 0:09 | LINE FAULT |
| 226 | 28-Jun-2022 | MYSURU | 66 | NAGAMANGALA-KOPPA | NO STATIONS EFFECTED | 13:30 | 15:55 | 2:25 | LINE CLEAR AVOIDED |
| 227 | 28-Jun-2022 | MYSURU | 66 | NAGAMANGALA-KOPPA | NO STATIONS EFFECTED | 16:35 | 18:58 | 2:23 | HAND TRIPPED |
| 228 | 28-Jun-2022 | MYSURU | 220 | TUBINAKERE-KOTIPURA 2 | NO STATIONS EFFECTED | 10:30 | 14:40 | 4:10 | LINE CLEAR AVOIDED |
| 229 | 28-Jun-2022 | MYSURU | 220 | TUBINAKERE-NAGAMANGALA 2 | HARADANAHALLI(JAK)_66 SHIVALLY_66 | 13:38 | 15:57 | 2:19 | HAND TRIPPED |
| 230 | 28-Jun-2022 | MYSURU | 220 | TUBINAKERE-ARAKERE | ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 | 14:53 | 15:10 | 0:17 | LINE CLEAR AVOIDED |
| 231 | 28-Jun-2022 | MYSURU | 66 | HV1 | AYRALLI_66 | 22:30 | 22:40 | 0:10 | TRANSFORMER FAULT |
| 232 | 28-Jun-2022 | MYSURU | 66 | HV2 | HONNALLY_MYS_66 | 11:00 | 15:50 | 4:50 | LINE CLEAR AVOIDED |
| 233 | 28-Jun-2022 | MYSURU | 66 | HV1 | KOPPA_66 | 12:15 | 13:35 | 1:20 | HAND TRIPPED |
| 234 | 28-Jun-2022 | MYSURU | 66 | HV2 | KOPPA_66 | 12:15 | 13:35 | 1:20 | HAND TRIPPED |
| 235 | 28-Jun-2022 | MYSURU | 66 | HARDANAHALLY-H N PURA | HARADANAHALLI_66 | 10:35 | 11:05 | 0:30 | HAND TRIPPED |
| 236 | 28-Jun-2022 | MYSURU | 66 | HV1 | HARADANAHALLI_66 | 10:35 | 17:30 | 6:55 | HAND TRIPPED |
| 237 | 28-Jun-2022 | MYSURU | 66 | HV2 | HARADANAHALLI_66 | 13:00 | 13:20 | 0:20 | TRANSFORMER FAULT |
| 238 | 28-Jun-2022 | MYSURU | 66 | HV2 | HARADANAHALLI_66 | 17:10 | 17:30 | 0:20 | HAND TRIPPED |
| 239 | 28-Jun-2022 | MYSURU | 66 | HV1 | CHANDALLI_66 | 17:38 | 17:43 | 0:05 | TRANSFORMER FAULT |
| 240 | 28-Jun-2022 | MYSURU | 66 | SUNTIKOPPA-MADIKERI | NO STATIONS EFFECTED | 8:55 | 13:55 | 5:00 | HAND TRIPPED |
| 241 | 28-Jun-2022 | MYSURU | 66 | SATHEGALA-KOLLEGALA | NO STATIONS EFFECTED | 18:30 | 18:45 | 0:15 | LINE FAULT |
| 242 | 28-Jun-2022 | MYSURU | 66 | MADIKERI-KUSHALANAGARA | MADIKERI_66 | 13:36 | 14:00 | 0:24 | HAND TRIPPED |
| 243 | 28-Jun-2022 | MYSURU | 220 | TUBINKERE-BASTIPURA | NO STATIONS EFFECTED | 7:01:00 AM (26.06.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|------------------------------------|---|----------------------------|-----------|----------|---------------------------------------|
| 244 | 28-Jun-2022 | MYSURU | 66 | KUNTHUR-BANNARI IPP | NO STATIONS EFFECTED | 15:25:08 | | | LINE OPEN, LINE CLEAR AVAILED |
| 245 | 28-Jun-2022 | MYSURU | 66 | DEVANUR NANJANGUDU-BAS1 | NO STATIONS EFFECTED | 6:10:00 PM (03/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 246 | 28-Jun-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 247 | 28-Jun-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 248 | 28-Jun-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN, LINE CLEAR AVAILED |
| 249 | 28-Jun-2022 | MYSURU | 66 | MUGUR-THAYURU | NO STATIONS EFFECTED | 9:40:00 (20.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 250 | 28-Jun-2022 | TUMKUR | 220 | ANCHEPALYA 220kV- NAGAMANGALA-1 | ANCHEPALYA_220 | 10:04 | 10:10 | 0:06 | LINE FAULT |
| 251 | 28-Jun-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 4:38 | 4:48 | 0:10 | LINE FAULT |
| 252 | 28-Jun-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 9:00 | 9:14 | 0:14 | LINE FAULT |
| 253 | 28-Jun-2022 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 9:00 | 9:14 | 0:14 | LINE FAULT |
| 254 | 28-Jun-2022 | TUMKUR | 66 | HIRIYUR220-MATHOD 1 | MATHOD_66,HINDASGHATTA_66,KANCHIPURA_66,GARAG A_66,PANCHANAHALLI_66,H OSADURGA_66 | 22:30 | 22:45 | 1:14 | HAND TRIPPED |
| 255 | 28-Jun-2022 | TUMKUR | 66 | HIRIYUR220-BEVINAHALLI66 | BEVINAHALLI_66,JAVAGONDA NAHALLI_66,DASUDI_66 | 7:30 | 7:42 | 0:12 | LINE FAULT |
| 256 | 28-Jun-2022 | TUMKUR | 66 | TUMKUR-ANTHRASANAHALI | TUMKUR_66 | 14:02 | 14:25 | 0:23 | LINE CLEAR AVAILED |
| 257 | 28-Jun-2022 | TUMKUR | 66 | DAVANGERE SRS- DAVANGERE | DAVANAGERE_66,KADAJJI_66 ,MELEKATTE_66 | 12:06 | 13:43 | 1:37 | LINE CLEAR AVAILED |
| 258 | 28-Jun-2022 | TUMKUR | 66 | TR1 | AMRUTHUR_66 | 18:55 | 19:00 | 0:05 | TRANSFORMER FAULT |
| 259 | 28-Jun-2022 | TUMKUR | 66 | HAALURAMESWARA66- MATHOD | HALURAMESHWARA_66 | 15:40 | 16:30 | 0:50 | MAIN SUPPLY FAILURE |
| 260 | 28-Jun-2022 | TUMKUR | 66 | HAALURAMESWARA66- MATHOD | HALURAMESHWARA_66 | 22:30 | 22:40 | 0:10 | MAIN SUPPLY FAILURE |
| 261 | 28-Jun-2022 | TUMKUR | 66 | TR1 | HONNALI_66 | 12:25 | 12:55 | 0:30 | LINE CLEAR AVAILED |
| 262 | 28-Jun-2022 | TUMKUR | 66 | TR3 | HOLALKERE_66 | 11:20 | 12:30 | 1:10 | LINE CLEAR AVAILED |
| 263 | 28-Jun-2022 | TUMKUR | 66 | TR1 | MALEBENNUR_66 | 11:00 | 14:30 | 3:30 | LINE CLEAR AVAILED |
| 264 | 28-Jun-2022 | TUMKUR | 66 | TR2 | MALEBENNUR_66 | 15:50 | 19:20 | 3:30 | LINE CLEAR AVAILED |
| 265 | 28-Jun-2022 | TUMKUR | 66 | TR1 | MATHOD_66 | 13:35 | 13:40 | 0:05 | TRANSFORMER FAULT |
| 266 | 28-Jun-2022 | TUMKUR | 66 | MATHOD- HOSADURGA | HOSADURGA_66,BAGUR_66, MADADAKERE_66,HALURAM ESHWARA_66,NEERAGUNDA6 6 | 15:40 | 16:30 | 0:50 | HAND TRIPPED |
| 267 | 28-Jun-2022 | TUMKUR | 66 | HIRIYUR220-MATHOD 1 | MATHOD_66,HINDASGHATTA_66,KANCHIPURA_66,GARAG A_66,PANCHANAHALLI_66,H OSADURGA_66 | 22:55 | 23:00 | 0:10 | HAND TRIPPED |
| 268 | 28-Jun-2022 | TUMKUR | 66 | MATHOD- HIRIYUR220KV SRS 1 | MATHOD_66 | 22:15 | 22:55 | 0:40 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------------|--|-------------------------|-----------|----------|------------------------------------|
| 269 | 28-Jun-2022 | TUMKUR | 66 | MATHOD- HIRIYUR220KV SRS 1 | MATHOD_66 | 22:55 | 23:00 | 0:05 | MAIN SUPPLY FAILURE |
| 270 | 28-Jun-2022 | TUMKUR | 66 | TR2 | PAVAGADA_66 | 14:10 | 14:20 | 0:10 | LINE CLEAR AVAILED |
| 271 | 28-Jun-2022 | TUMKUR | 66 | HARIYABBE-PD KOTE | PKOTE_66 | 12:25 | 15:45 | 3:20 | NFBC ISSUED |
| 272 | 28-Jun-2022 | TUMKUR | 66 | TR2 | PKOTE_66 | 16:50 | 18:15 | 1:25 | LINE CLEAR AVAILED |
| 273 | 28-Jun-2022 | TUMKUR | 66 | HARIYABBE-PD KOTE | HARIYABBE_66 | 12:38 | 15:42 | 3:04 | LINE CLEAR AVAILED |
| 274 | 28-Jun-2022 | TUMKUR | 66 | TR3 | HARIYABBE_66 | 7:10 | 7:15 | 0:05 | HAND TRIPPED |
| 275 | 28-Jun-2022 | TUMKUR | 66 | PKOTE_66-CLEAR SOLAR | PKOTE_66 | 12:18 | 12:23 | 0:05 | LINE FAULT |
| 276 | 28-Jun-2022 | TUMKUR | 66 | UCHANGIDURGA-PALLAGATTE | PALLAGATTA_66,BILCHODU_66, SOKKE_66 | 15:40 | 15:45 | 0:05 | HAND TRIPPED |
| 277 | 28-Jun-2022 | TUMKUR | 66 | UCHANGIDURGA-PALLAGATTE | PALLAGATTA_66,BILCHODU_66, SOKKE_66 | 22:20 | 23:30 | 1:10 | LINE FAULT |
| 278 | 28-Jun-2022 | TUMKUR | 66 | TR1 AND TR2 | BILCHODU_66 | 9:55 | 13:10 | 3:15 | LINE CLEAR AVAILED |
| 279 | 28-Jun-2022 | TUMKUR | 66 | TR1 AND TR2 | BILCHODU_66 | 5:05 | 16:05 | 11:00 | MAIN SUPPLY FAILURE |
| 280 | 28-Jun-2022 | TUMKUR | 66 | TR1 AND TR2 | BILCHODU_66 | 15:50 | 15:55 | 0:05 | MAIN SUPPLY FAILURE |
| 281 | 28-Jun-2022 | TUMKUR | 66 | TR1 AND TR2 | BILCHODU_66 | 16:05 | 16:20 | 0:15 | MAIN SUPPLY FAILURE |
| 282 | 28-Jun-2022 | TUMKUR | 66 | TR1 | SASALUHALLA_66 | 13:00:00 PM(28.06.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 283 | 28-Jun-2022 | TUMKUR | 66 | TR2 | PULLAMGHATTA_66 | 11:50 | 12:05 | 0:15 | LINE CLEAR AVAILED |
| 284 | 28-Jun-2022 | TUMKUR | 66 | TR1 | PULLAMGHATTA_66 | 12:15 | 12:35 | 0:20 | LINE CLEAR AVAILED |
| 285 | 28-Jun-2022 | TUMKUR | 66 | PULAMGHATTA-MADHUGIRI | PULAMGHATTA_66 | 12:15 | 12:35 | 0:20 | LINE CLEAR AVAILED |
| 286 | 29-Jun-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 287 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHWAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 288 | 29-Jun-2022 | BAGALKOT | 110 | AMBEWADI-NK2(KAVALWADA) | STATION NOT AFFECTED AMBEWADI_220 | 8:55 (23.05.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 289 | 29-Jun-2022 | BAGALKOT | 110 | HUBLI220- ANAND NAGAR | STATION NOT AFFECTED HUBLI_220 | 11:37 (14.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 290 | 29-Jun-2022 | BAGALKOT | 220 | NARENDRA- AMBEWADI1 | STATION NOT AFFECTED NARENDRA_220 | 10:05 (15.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 291 | 29-Jun-2022 | BAGALKOT | 220 | SIRSI220-HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 292 | 29-Jun-2022 | BAGALKOT | 110 | BELGAUM-HUDLI | STATION NOT AFFECTED HUDLI_110 | 16:20 (28.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 293 | 29-Jun-2022 | BAGALKOT | 110 | KIADB BIJAPUR-BHUTNAL | STATION NOT AFFECTED KIADB BIJAPUR_110 | 9:22 | 18:32 | 9:10 | LINE CLEAR AVAILED |
| 294 | 29-Jun-2022 | BAGALKOT | 110 | KIADB BIJAPUR-BHUTNAL | STATION NOT AFFECTED KIADB BIJAPUR_110 | 18:44 | 19:39 | 0:55 | LINE CLEAR AVAILED |
| 295 | 29-Jun-2022 | BAGALKOT | 110 | THORVI-BHUTNAL | STATION NOT AFFECTED THORVI_110 | 9:32 | 19:42 | 10:10 | LINE CLEAR AVAILED |
| 296 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | THORVI_110 | 10:41 | 10:48 | 0:07 | TRANSFORMER FAULT |
| 297 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HIREMASALI_110 | 20:52 | 20:56 | 0:04 | TRANSFORMER FAULT |
| 298 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV4 | HUKKERI_110 | 12:25 | 12:42 | 0:17 | TRANSFORMER FAULT |
| 299 | 29-Jun-2022 | BAGALKOT | 110 | 110/33KV,HV1 | HIPPARAGI_33 JAMAKHANDI_110 | 14:11 | 18:49 | 4:38 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|----------------------------------|--|-----------------------|-----------|----------|---------------------------------------|
| 300 | 29-Jun-2022 | BAGALKOT | 110 | 110/33KV,HV2 | HIPPARAGI_33 JAMAKHANDI_110 | 14:15 | 18:48 | 4:33 | LINE CLEAR AVAILED |
| 301 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KADAKLAT_110 | 11:18 | 12:44 | 1:26 | LINE CLEAR AVAILED |
| 302 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | KADAKLAT_110 | 10:40 | 12:46 | 2:06 | LINE CLEAR AVAILED |
| 303 | 29-Jun-2022 | BAGALKOT | 110 | 110/33KV,HV3(HV4) | ARALIMATTI_33,TIGADI_33 KULIGOD_110 | 16:00 | 17:11 | 1:11 | LINE CLEAR AVAILED |
| 304 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV4(HV3) | ARALIMATTI_33,TIGADI_33 KULIGOD_110 | 16:00 | 17:54 | 1:54 | LINE CLEAR AVAILED |
| 305 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KULIGOD_110 | 17:10 | 17:11 | 0:01 | LINE CLEAR AVAILED |
| 306 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1(HV2) | MACHE_110 | 13:00 | 14:18 | 1:18 | LINE CLEAR AVAILED |
| 307 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV3(HV2) | MUNDUGANUR_110 | 11:57 | 13:40 | 1:43 | TRANSFORMER FAULT |
| 308 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | RAIBAG_110 | 12:34 | 13:37 | 1:03 | HAND TRIPPED |
| 309 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1(HV2) | SAVALAGI_110 | 11:52 | 12:54 | 1:02 | LINE CLEAR AVAILED |
| 310 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | SIRSI_110 | 17:52 | 18:08 | 0:16 | TRANSFORMER FAULT |
| 311 | 29-Jun-2022 | BAGALKOT | 110 | TAKKALAKI-THORVI | STATION NOT AFFECTED TAKKALAKI_110 | 19:42 | 19:43 | 0:01 | HAND TRIPPED |
| 312 | 29-Jun-2022 | BAGALKOT | 110 | TAKKALAKI-TIKOTA | STATION NOT AFFECTED TAKKALAKI_110 | 19:43 | 19:44 | 0:01 | HAND TRIPPED |
| 313 | 29-Jun-2022 | BAGALKOT | 110 | ZALKI-CHADACHAN | CHADACHAN_110 | 9:10 | 9:25 | 0:15 | LINE FAULT |
| 314 | 29-Jun-2022 | BAGALKOT | 220 | NARENDRA-HUBLI-2 | STATION NOT AFFECTED NARENDRA_220. | 10:01 | 18:18 | 8:17 | NFBC ISSUED |
| 315 | 29-Jun-2022 | BAGALKOT | 220 | HUBLI-NARENDRA-2 | STATION NOT AFFECTED HUBLI_220 | 10:01 | 18:18 | 8:17 | LINE CLEAR AVAILED |
| 316 | 29-Jun-2022 | BAGALKOT | 220 | 220/110KV, HV1,LV1 | STATION NOT AFFECTED HUBLI_220 | 15:07 | 15:22 | 0:15 | LINE CLEAR AVAILED |
| 317 | 29-Jun-2022 | BAGALKOT | 110 | KARWAR220-ARGA | STATION NOT AFFECTED ARGA_110 | 10:55 | 14:30 | 3:35 | LINE CLEAR AVAILED |
| 318 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED TILUVALLI_110 | 16:26 | 17:29 | 1:03 | LINE CLEAR AVAILED |
| 319 | 29-Jun-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 320 | 29-Jun-2022 | BAGALKOT | 220 | SIRSI220-HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 321 | 29-Jun-2022 | BAGALKOT | 110 | BELGAUM110-KANABARGI LAYOUT | STATION NOT AFFECTED BELGAUM_110 | 10:50 (26.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 322 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KAMBAGI_110 | 9:28 | 9:33 | 0:05 | TRANSFORMER FAULT |
| 323 | 29-Jun-2022 | BAGALKOT | 110 | KUMTA-HONNAVAR(KRCL RAILWAY) | STATION NOT AFFECTED KUMTA_110 | 12:11 | 15:53 | 3:42 | LINE CLEAR AVAILED |
| 324 | 29-Jun-2022 | BAGALKOT | 220 | BELAGAVI-AEQUS-1 | STATION NOT AFFECTED BELAGAVI_220 | 14:12 | 14:16 | 0:04 | HAND TRIPPED |
| 325 | 29-Jun-2022 | BAGALKOT | 220 | BELAGAVI-AEQUS-2 | STATION NOT AFFECTED BELAGAVI_220 | 14:17 | 14:23 | 0:06 | HAND TRIPPED |
| 326 | 29-Jun-2022 | BAGALKOT | 110 | BELAGAUM220-KANABARGI LAYOUT | KANABARGI LAYOUT_110 | 13:30 | 13:40 | 0:10 | MAIN SUPPLY FAILURE |
| 327 | 29-Jun-2022 | BAGALKOT | 110 | MUGALKHOD220-KULIGOD | STATION NOT AFFECTED MUGALKHOD_220 | 12:17 | 15:51 | 3:34 | LINE CLEAR AVAILED |
| 328 | 29-Jun-2022 | BAGALKOT | 110 | MUGALKHOD220-SAIDAPUR | SAIDAPUR_110 | 18:12 | 18:25 | 0:13 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--------------------------------------|---|---------|-----------|----------|--------------------|
| 329 | 29-Jun-2022 | BAGALKOT | 110 | HAVERI220-GM SUARS | GM SUGARS_110 STATION NOT AFFECTED HAVERI 220 | 15:37 | 17:04 | 1:27 | LINE FAULT |
| 330 | 29-Jun-2022 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED GUTTAL 110 | 11:05 | 13:00 | 1:55 | LINE CLEAR AVOIDED |
| 331 | 29-Jun-2022 | BAGALKOT | 220 | AMBEWADI-NARENDRA-1 | STATION NOT AFFECTED AMBEWADI 220 | 13:56 | 18:24 | 4:28 | LINE CLEAR AVOIDED |
| 332 | 29-Jun-2022 | BAGALKOT | 220 | AEQUS-BELAGAVI-1 | STATION NOT AFFECTED AEQUS 220 | 14:12 | 14:16 | 0:04 | HAND TRIPPED |
| 333 | 29-Jun-2022 | BAGALKOT | 220 | AEQUS-BELAGAVI-2 | STATION NOT AFFECTED AEQUS 220 | 14:17 | 14:23 | 0:06 | HAND TRIPPED |
| 334 | 29-Jun-2022 | BENGALURU | 66 | BANASHANKARI - VRISHABHAVATHI 220 | BANASHANKARI | 15:40 | 15:44 | 0:04 | LOAD CHANGE OVER |
| 335 | 29-Jun-2022 | BENGALURU | 66 | BANASHANKARI - SUBRAMANYAPURA 220 | BANASHANKARI | 18:35 | 18:40 | 0:05 | LOAD CHANGE OVER |
| 336 | 29-Jun-2022 | BENGALURU | 66 | HV2 | DEVARABISANAHALLI | 11:10 | 11:18 | 0:08 | LINE CLEAR AVOIDED |
| 337 | 29-Jun-2022 | BENGALURU | 66 | HV1 | DEVARABISANAHALLI | 12:45 | 12:53 | 0:08 | LINE CLEAR AVOIDED |
| 338 | 29-Jun-2022 | BENGALURU | 66 | HV2 | ELECTRONIC CITY P2 S1 | 9:57 | 10:35 | 0:38 | TRANSFORMER FAULT |
| 339 | 29-Jun-2022 | BENGALURU | 66 | HV1 | GURUVINAPURA | 10:04 | 14:25 | 4:21 | LINE CLEAR AVOIDED |
| 340 | 29-Jun-2022 | BENGALURU | 66 | HV1 | KHODAYS 220 | 10:52 | 10:56 | 0:04 | LINE CLEAR AVOIDED |
| 341 | 29-Jun-2022 | BENGALURU | 66 | HV2 | KHODAYS 220 | 10:52 | 10:56 | 0:04 | LINE CLEAR AVOIDED |
| 342 | 29-Jun-2022 | BENGALURU | 66 | KHODAYS 220 - ANJANAPURA | ANJANAPURA | 10:52 | 10:56 | 0:04 | LINE CLEAR AVOIDED |
| 343 | 29-Jun-2022 | BENGALURU | 66 | KHODAYS 220 - ANJANAPURA | ANJANAPURA | 13:33 | 13:40 | 0:07 | LINE CLEAR AVOIDED |
| 344 | 29-Jun-2022 | BENGALURU | 66 | HV1 | KHODAYS 220 | 13:33 | 13:40 | 0:07 | LINE CLEAR AVOIDED |
| 345 | 29-Jun-2022 | BENGALURU | 66 | HV2 | KHODAYS 220 | 13:33 | 13:40 | 0:07 | LINE CLEAR AVOIDED |
| 346 | 29-Jun-2022 | BENGALURU | 66 | KHODAYS 220 - SOUTH CITY | NO STATION AFFECTED | 10:52 | 10:56 | 0:04 | LINE CLEAR AVOIDED |
| 347 | 29-Jun-2022 | BENGALURU | 66 | KOTHIPURA 220 - MELLAHALLI | KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI | 14:03 | 14:17 | 0:14 | LINE CLEAR AVOIDED |
| 348 | 29-Jun-2022 | BENGALURU | 66 | HV2 | RMV | 13:31 | 13:36 | 0:05 | LINE CLEAR AVOIDED |
| 349 | 29-Jun-2022 | BENGALURU | 66 | HV2 | RMV | 14:24 | 14:30 | 0:06 | LOAD CHANGE OVER |
| 350 | 29-Jun-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 1 | SURYANAGAR | 5:55 | 6:39 | 0:44 | LINE FAULT |
| 351 | 29-Jun-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 2 | ANEKAL, SAMANDURU, ATTIBELE(HV1) | 5:55 | 6:39 | 0:44 | LINE FAULT |
| 352 | 29-Jun-2022 | BENGALURU | 66 | HV2 | TELECOM LAYOUT | 12:10 | 12:15 | 0:05 | LINE CLEAR AVOIDED |
| 353 | 29-Jun-2022 | BENGALURU | 66 | HV2 | YEDUMADU | 16:31 | 17:00 | 0:29 | TRANSFORMER FAULT |
| 354 | 29-Jun-2022 | BENGALURU | 66 | HV2 | THAYALUR | 15:16 | 15:25 | 0:08 | LINE CLEAR AVOIDED |
| 355 | 29-Jun-2022 | BENGALURU | 66 | HV1 | MALLASANDRA | 11:01 | 11:06 | 0:04 | LINE CLEAR AVOIDED |
| 356 | 29-Jun-2022 | BENGALURU | 66 | HV1 | MALLASANDRA | 19:01 | 19:50 | 0:48 | TRANSFORMER FAULT |
| 357 | 29-Jun-2022 | BENGALURU | 66 | HV2 | MALLASANDRA | 13:29 | 13:35 | 0:05 | LINE CLEAR AVOIDED |
| 358 | 29-Jun-2022 | BENGALURU | 66 | HV1 | KUNDANA | 13:53 | 15:27 | 1:33 | LINE CLEAR AVOIDED |
| 359 | 29-Jun-2022 | BENGALURU | 66 | HV1 | KEMBODI | 10:31 | 13:06 | 2:34 | LINE CLEAR AVOIDED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|---------------------------------|---|-----------------------|-------------------|----------|-------------------------------|
| 360 | 29-Jun-2022 | BENGALURU | 66 | HV2 | KEMBODI | 12:00 | 13:00 | 1:00 | LINE CLEAR AVAILED |
| 361 | 29-Jun-2022 | BENGALURU | 66 | HV2 | KANAKAPURA 66 | 12:34 | 12:38 | 0:03 | LINE CLEAR AVAILED |
| 362 | 29-Jun-2022 | BENGALURU | 66 | HV1 | AVANI | 14:30 | 14:35 | 0:05 | LINE CLEAR AVAILED |
| 363 | 29-Jun-2022 | BENGALURU | 66 | HV1 | AVANI | 12:36 | 12:40 | 0:04 | LINE CLEAR AVAILED |
| 364 | 29-Jun-2022 | BENGALURU | 66 | VIDYANAGAR - HENNUR CROSS | NO STATION AFFECTED | 10:18 | 12:18 | 1:59 | LINE FAULT |
| 365 | 29-Jun-2022 | BENGALURU | 66 | SURYANAGAR - YERANDANAHALLI 220 | SURYANAGAR | 5:54 | 6:41 | 0:47 | LINE FAULT |
| 366 | 29-Jun-2022 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 1 | VATADOSANAHALLI | 12:26 | 12:33 | 0:06 | LINE FAULT |
| 367 | 29-Jun-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NO STATION AFFECTED | 6:44 | 7:00 | 0:15 | LINE FAULT |
| 368 | 29-Jun-2022 | BENGALURU | 66 | PATHPALYA - MITTEMARI 220 | PATHPALYA, THIMMAMPALLI | 8:55 | 9:05 | 0:10 | LINE CLEAR AVAILED |
| 369 | 29-Jun-2022 | BENGALURU | 66 | HOODY 220 - BMRCL | NO STATION AFFECTED | 23:46:00(28/06/2022) | 00:35(29/06/2022) | 0:49HRS | LINE CHARGED |
| 370 | 29-Jun-2022 | GULBARGA | 400 | RTPS-MUNIRABAD | MUNIRABAD_400 | 10:04 (14.06.2022) | | | LOAD CURTAILMENT |
| 371 | 29-Jun-2022 | GULBARGA | 220 | HV1 | KUSHTAGI_220 | 12:32 | 14:37 | 2:05 | LINE CLEAR AVAILED |
| 372 | 29-Jun-2022 | GULBARGA | 220 | HV2 | SINDHNOOR_220 | 10:20 | 12:00 | 1:40 | LINE CLEAR AVAILED |
| 373 | 29-Jun-2022 | GULBARGA | 220 | HV1 | ITTAGI_220 | 5:57 | 6:19 | 0:22 | TRANSFORMER FAULT |
| 374 | 29-Jun-2022 | GULBARGA | 220 | HV2 & LV2 | HALBARGA_220 | 14:32 | 15:39 | 1:07 | LINE CLEAR AVAILED |
| 375 | 29-Jun-2022 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 5:04 | 5:21 | 0:17 | LINE FAULT |
| 376 | 29-Jun-2022 | GULBARGA | 220 | LINGAPUR-JVSL1 | LINGAPUR_220 | 8:07 | 19:39 | 11:32 | LINE CLEAR AVAILED |
| 377 | 29-Jun-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 378 | 29-Jun-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 379 | 29-Jun-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 11:30(23/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 380 | 29-Jun-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 21:10(29.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 381 | 29-Jun-2022 | GULBARGA | 110 | NALWAR-WARAD SOLAR_IPP | NALWAR_110 | 21:10(29.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 382 | 29-Jun-2022 | GULBARGA | 110 | HV2 | LINGASUGUR | 10:04 | 14:36 | 4:32 | LINE CLEAR AVAILED |
| 383 | 29-Jun-2022 | GULBARGA | 110 | HV2 | SREERAMANAGAR_110 | 6:20 | 6:27 | 0:07 | TRANSFORMER FAULT |
| 384 | 29-Jun-2022 | GULBARGA | 110 | HV2 | MUDGAL_110 | 17:50 | 19:35 | 1:45 | TRANSFORMER FAULT |
| 385 | 29-Jun-2022 | GULBARGA | 110 | KEREHALLI-TALAKUTAI_IPP | KEREHALLI_110 | 22:25(28.06.2022) | 6:42(29.06.2022) | 8:17HRS | LINE CHARGED |
| 386 | 29-Jun-2022 | GULBARGA | 110 | LINGASUGUR-GURGUNTA | GURGUNRA_110,KHEL_IPP,LJVL_IPP | 9:51 | 16:52 | 7:01 | LINE CLEAR AVAILED |
| 387 | 29-Jun-2022 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110 | 3:35 | 3:42 | 0:07 | LINE FAULT |
| 388 | 29-Jun-2022 | GULBARGA | 110 | SINDHNOOR-NIRLOOTI_IPP | SINDHNOOR_220 | 10:20 | 12:05 | 1:45 | LINE CLEAR AVAILED |
| 389 | 29-Jun-2022 | GULBARGA | 110 | SINDHNOOR-MUNIRABAD2 | MUKHUNDA_110,YARADONA_110,BENNUR_110,BTPS_WATERWORKS,KAMPLI_110 | 13:45 | 13:55 | 0:10 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|----------------------------|---|---------|-----------|----------|---------------------|
| 390 | 29-Jun-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 0:03 | 0:18 | 0:15 | LINE FAULT |
| 391 | 29-Jun-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110 | 0:43 | 0:50 | 0:07 | LINE FAULT |
| 392 | 29-Jun-2022 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 1:11 | 8:42 | 7:31 | LINE FAULT |
| 393 | 29-Jun-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110 | 4:15 | 4:23 | 0:08 | LINE FAULT |
| 394 | 29-Jun-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110 | 5:09 | 5:19 | 0:10 | LINE FAULT |
| 395 | 29-Jun-2022 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI,KBJNL | KEMBHAVI_110,KBJNL_110 | 11:33 | 11:52 | 0:19 | LINE CLEAR AVAILED |
| 396 | 29-Jun-2022 | GULBARGA | 110 | SHAHAPUR-RAICHUR1 | DEODURGA_110 | 14:09 | 18:05 | 3:56 | LINE CLEAR AVAILED |
| 397 | 29-Jun-2022 | GULBARGA | 110 | NALWAR-SHAHAPUR1 | NALWAR_110,JEWARGI_110 | 21:10 | 23:00 | 1:50 | LINE FAULT |
| 398 | 29-Jun-2022 | GULBARGA | 110 | NALWAR-SHAHABAD(SHAHAPUR)2 | JEWARGI_110 | 21:10 | 22:50 | 1:40 | LINE CLEAR AVAILED |
| 399 | 29-Jun-2022 | GULBARGA | 110 | NALWAR-SHAHABAD(SHAHAPUR)2 | JEWARGI_110 | 22:50 | 23:05 | 0:15 | LINE CLEAR AVAILED |
| 400 | 29-Jun-2022 | GULBARGA | 110 | NALWAR-SHAHAPUR1 | NALWAR_110,JEWARGI_110 | 23:35 | 23:40 | 0:05 | LINE FAULT |
| 401 | 29-Jun-2022 | GULBARGA | 110 | MADIYAL-CHOWDAPUR | CHOWDAPUR_110,AFZALPUR_110,KPR_FACTORY | 10:43 | 10:48 | 0:05 | LINE FAULT |
| 402 | 29-Jun-2022 | GULBARGA | 110 | AURADA-SANTHAPUR | AURADA_110 | 3:40 | 3:50 | 0:10 | MAIN SUPPLY FAILURE |
| 403 | 29-Jun-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI2 | YADRAMI_110,MORATAGI_110 | 10:43 | 10:50 | 0:07 | LINE FAULT |
| 404 | 29-Jun-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI2 | YADRAMI_110,MORATAGI_110 | 20:41 | 20:50 | 0:09 | LINE FAULT |
| 405 | 29-Jun-2022 | GULBARGA | 110 | SHAHABAD-BAGEWADI1 | MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110 | 10:45 | 11:40 | 0:55 | LINE CLEAR AVAILED |
| 406 | 29-Jun-2022 | GULBARGA | 110 | HALBARGA-SANTAPUR | SANTAPUR_110,DONGARGOAN_110,DIGGI_110 | 3:37 | 3:45 | 0:08 | LINE FAULT |
| 407 | 29-Jun-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 3:31 | 3:38 | 0:07 | LINE FAULT |
| 408 | 29-Jun-2022 | GULBARGA | 110 | HUMNABAD-SASTHAPUR | RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110 | 11:30 | 13:28 | 1:58 | LINE CLEAR AVAILED |
| 409 | 29-Jun-2022 | GULBARGA | 110 | HUNASAGI-KEMBHAVI | HUNASAGI_110 | 12:40 | 12:50 | 0:10 | MAIN SUPPLY FAILURE |
| 410 | 29-Jun-2022 | GULBARGA | 110 | HUNASAGI-KEMBHAVI | HUNASAGI_110 | 4:15 | 4:25 | 0:10 | MAIN SUPPLY FAILURE |
| 411 | 29-Jun-2022 | GULBARGA | 110 | HUNASAGI-KEMBHAVI | HUNASAGI_110 | 5:10 | 5:20 | 0:10 | MAIN SUPPLY FAILURE |
| 412 | 29-Jun-2022 | GULBARGA | 110 | HUNASAGI-KEMBHAVI | HUNASAGI_110 | 11:35 | 11:50 | 0:15 | MAIN SUPPLY FAILURE |
| 413 | 29-Jun-2022 | GULBARGA | 110 | YERADONA-SINDHANOOR | YERADONA_110 | 13:50 | 13:55 | 0:05 | MAIN SUPPLY FAILURE |
| 414 | 29-Jun-2022 | GULBARGA | 110 | RAJESHWAR-HUMNABAD | RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110 | 11:45 | 12:05 | 0:20 | NFBC ISSUED |
| 415 | 29-Jun-2022 | GULBARGA | 110 | YELBURGA-TALAKUTAI_IPP | YELBURGA_110 | 13:21 | 13:31 | 0:10 | LOAD CURTAILMENT |
| 416 | 29-Jun-2022 | GULBARGA | 66 | HV2 | TAMBRAHALLI_66 | 13:30 | 13:45 | 0:15 | TRANSFORMER FAULT |
| 417 | 29-Jun-2022 | GULBARGA | 66 | HUVINAHADAGALI-ITTAGI | HUVINAHADAGALI_66,HOLAGUNDI_66 | 5:57 | 6:45 | 0:48 | LINE FAULT |
| 418 | 29-Jun-2022 | GULBARGA | 66 | HANASI-KUDLIGI | HANASI_66 | 16:05 | 16:15 | 0:10 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-----------------------|---|-----------------------|-----------|----------|--|
| 419 | 29-Jun-2022 | GULBARGA | 66 | PUNABGHATA-NEELAGUNDA | PUNABGHATA_66,UCHANGID URGA_66,BILCHOD_66, UJJAINI_66 | 20:20 | 20:25 | 0:05 | LINE FAULT |
| 420 | 29-Jun-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 421 | 29-Jun-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.20 22) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 422 | 29-Jun-2022 | HASSAN | 66 | HV2 | HASSAN_66 | 10:05 (6.06.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 423 | 29-Jun-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 13:12(18.06.20 22) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 424 | 29-Jun-2022 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 15:29(28.06.20 22) | | | LINE OPEN, LINE CLEAR AVAILED |
| 425 | 29-Jun-2022 | HASSAN | 220 | SHRAVITY-TALAGUPPA 2 | sharavathy_gen | 20:11 (29.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 426 | 29-Jun-2022 | HASSAN | 220 | HV1 | CRAPATNA_220 | 11:27 | 12:18 | 0:51 | LINE CLEAR AVAILED |
| 427 | 29-Jun-2022 | HASSAN | 220 | LV1 | CRAPATNA_220 | 11:27 | 12:18 | 0:51 | LINE CLEAR AVAILED |
| 428 | 29-Jun-2022 | HASSAN | 220 | GERSOPA-TALGUPA1 | gerusoppa_gen | 12:36 | 13:05 | 0:29 | LINE FAULT |
| 429 | 29-Jun-2022 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 10:48 | 17:05 | 6:17 | NFBC ISSUED |
| 430 | 29-Jun-2022 | HASSAN | 220 | HGUNJE-VARAH1 | HEGGUNJE_220 | 11:20 | 13:43 | 2:23 | LINE CLEAR AVAILED |
| 431 | 29-Jun-2022 | HASSAN | 220 | HV2 | KADUR_220 | 10:32 | 12:50 | 2:18 | LINE CLEAR AVAILED |
| 432 | 29-Jun-2022 | HASSAN | 110 | HV1 | KADUR_220 | 11:40 | 11:45 | 0:05 | TRANSFORMER FAULT |
| 433 | 29-Jun-2022 | HASSAN | 110 | LV1 | KADUR_220 | 11:40 | 11:45 | 0:05 | TRANSFORMER FAULT |
| 434 | 29-Jun-2022 | HASSAN | 110 | LV2 | KADUR_220 | 10:32 | 12:50 | 2:18 | LINE CLEAR AVAILED |
| 435 | 29-Jun-2022 | HASSAN | 110 | KADUR-NERELEKERE | KADUR_220 | 11:40 | 11:52 | 0:12 | MAIN SUPPLY FAILURE |
| 436 | 29-Jun-2022 | HASSAN | 110 | KADUR-TNGL | KADUR_220 | 11:40 | 11:50 | 0:10 | MAIN SUPPLY FAILURE |
| 437 | 29-Jun-2022 | HASSAN | 110 | KADUR-YGTI | KADUR_220 | 11:40 | 11:52 | 0:12 | MAIN SUPPLY FAILURE |
| 438 | 29-Jun-2022 | HASSAN | 220 | KEMAR-Kavoor1 | KEMAR_220 | 11:13 | 12:50 | 1:37 | LINE CLEAR AVAILED |
| 439 | 29-Jun-2022 | HASSAN | 220 | HV3 | MRSMG_220 | 10:12 | 16:13 | 6:01 | LINE CLEAR AVAILED |
| 440 | 29-Jun-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMG_220 | 12:37 | 13:05 | 0:28 | LINE FAULT |
| 441 | 29-Jun-2022 | HASSAN | 110 | LV3 | MRSMG_220 | 10:12 | 16:13 | 6:01 | LINE CLEAR AVAILED |
| 442 | 29-Jun-2022 | HASSAN | 220 | MSEZ-KEMAR1 | MSEZ_220 | 11:13 | 12:50 | 1:37 | NFBC ISSUED |
| 443 | 29-Jun-2022 | HASSAN | 110 | MSEZ-GSS31 | MSEZ_220 | 10:22 | 13:45 | 3:23 | LINE CLEAR AVAILED |
| 444 | 29-Jun-2022 | HASSAN | 220 | TALAGU-STRP2 | TALAGUPPA_400 | 10:48 | 17:07 | 6:19 | LINE CLEAR AVAILED |
| 445 | 29-Jun-2022 | HASSAN | 220 | VARAH1-KEMAR3 | varahi_gen | 11:22 | 13:43 | 2:21 | NFBC ISSUED |
| 446 | 29-Jun-2022 | HASSAN | 110 | ARSK2-GERUMARA | ARASIKERE_220 | 5:40 | 5:43 | 0:03 | LINE FAULT |
| 447 | 29-Jun-2022 | HASSAN | 110 | HV1 | GAJNUR_110 | 9:58 | 14:32 | 4:34 | LINE CLEAR AVAILED |
| 448 | 29-Jun-2022 | HASSAN | 110 | HV1 | HIENALLUR_110 | 11:45 | 13:50 | 2:05 | TRANSFORMER FAULT |
| 449 | 29-Jun-2022 | HASSAN | 110 | HV2 | MANIPAL_110 | 10:15 | 10:45 | 0:30 | HAND TRIPPED |
| 450 | 29-Jun-2022 | HASSAN | 110 | HV2 | NAVUNDA_110 | 9:30 | 10:05 | 0:35 | LINE CLEAR AVAILED |
| 451 | 29-Jun-2022 | HASSAN | 110 | HV2 | NAVUNDA_110 | 10:18 | 10:28 | 0:10 | LINE CLEAR AVAILED |
| 452 | 29-Jun-2022 | HASSAN | 110 | HV2 | NAVUNDA_110 | 11:02 | 12:18 | 1:16 | LINE CLEAR AVAILED |
| 453 | 29-Jun-2022 | HASSAN | 110 | NERALA-TEREKERE | NERALAKERE_110 | 15:10 | 16:35 | 1:25 | LINE CLEAR AVAILED |
| 454 | 29-Jun-2022 | HASSAN | 110 | HV3 | PUTTUR_110 | 1:40 | 1:50 | 0:10 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|----------------------------|----------------------|----------------------------|-----------|----------|------------------------------------|
| 455 | 29-Jun-2022 | HASSAN | 110 | HV3 | PUTTUR_110 | 9:08 | 13:52 | 4:44 | LINE CLEAR AVAIED |
| 456 | 29-Jun-2022 | HASSAN | 110 | SHIVAPUR-BIRUR | SHIVAPURA_110 | 15:07 | 16:05 | 0:58 | LINE CLEAR AVAIED |
| 457 | 29-Jun-2022 | HASSAN | 110 | SHIVAPUR-NERLEKERE | SHIVAPURA_110 | 15:07 | 16:05 | 0:58 | LINE CLEAR AVAIED |
| 458 | 29-Jun-2022 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 11:33 | 12:20 | 0:47 | NFBC ISSUED |
| 459 | 29-Jun-2022 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 12:22 | 12:25 | 0:03 | HAND TRIPPED |
| 460 | 29-Jun-2022 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 12:27 | 12:38 | 0:11 | HAND TRIPPED |
| 461 | 29-Jun-2022 | HASSAN | 66 | AREHALI-SAKLESPUR | AREHALLI_66 | 11:50 | 14:35 | 2:45 | NFBC ISSUED |
| 462 | 29-Jun-2022 | HASSAN | 66 | BAGUR-UDAYAPUR | BAGUR_66 | 11:34 | 12:15 | 0:41 | NFBC ISSUED |
| 463 | 29-Jun-2022 | HASSAN | 66 | HV1 | BALLUPETE_66 | 14:45 | 15:20 | 0:35 | LINE CLEAR AVAIED |
| 464 | 29-Jun-2022 | HASSAN | 66 | CHANNARA-HIRESAVE | CHANNARAYAPATNA_66 | 15:35 | 17:01 | 1:26 | LINE CLEAR AVAIED |
| 465 | 29-Jun-2022 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 12:15 | 12:49 | 0:34 | LINE CLEAR AVAIED |
| 466 | 29-Jun-2022 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 12:50 | 14:10 | 1:20 | LINE CLEAR AVAIED |
| 467 | 29-Jun-2022 | HASSAN | 66 | SAKALE-HANBAL | SAKLESH PURA_66 | 11:50 | 14:35 | 2:45 | LINE CLEAR AVAIED |
| 468 | 29-Jun-2022 | HASSAN | 66 | UDAYAP-BAGUR | UDAYAPURA_66 | 11:20 | 12:14 | 0:54 | LINE CLEAR AVAIED |
| 469 | 29-Jun-2022 | MYSURU | 66 | HV1 | CHIKKA_MANDYA_66 | 14:40 | 16:15 | 1:35 | LINE CLEAR AVAIED |
| 470 | 29-Jun-2022 | MYSURU | 66 | HV2 | CHIKKA_MANDYA_66 | 8:14 | 8:42 | 0:28 | LINE CLEAR AVAIED |
| 471 | 29-Jun-2022 | MYSURU | 66 | HV2 | CHIKKA_MANDYA_66 | 12:02 | 14:25 | 2:23 | LINE CLEAR AVAIED |
| 472 | 29-Jun-2022 | MYSURU | 66 | HV1 | BOGADHI_66 | 14:50 | 16:55 | 2:04 | LINE CLEAR AVAIED |
| 473 | 29-Jun-2022 | MYSURU | 66 | HV2 | BOGADHI_66 | 11:21 | 14:32 | 3:11 | LINE CLEAR AVAIED |
| 474 | 29-Jun-2022 | MYSURU | 66 | HV2 | BOOKANAKERE_66 | 8:29 | 8:39 | 0:10 | TRANSFORMER FAULT |
| 475 | 29-Jun-2022 | MYSURU | 66 | DODDARAYAPETE-C R NAGARA 2 | NO STATIONS EFFECTED | 12:12 | 13:55 | 1:43 | LINE CLEAR AVAIED |
| 476 | 29-Jun-2022 | MYSURU | 66 | HV2 | HULLAHALLI_66 | 11:50 | 13:30 | 1:40 | LINE CLEAR AVAIED |
| 477 | 29-Jun-2022 | MYSURU | 66 | HV1 | KOLLEGALA_66 | 13:38 | 15:23 | 1:45 | LINE CLEAR AVAIED |
| 478 | 29-Jun-2022 | MYSURU | 220 | TUBINKERE-BASTIPURA | NO STATIONS EFFECTED | 7:01:00 AM (26.06.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 479 | 29-Jun-2022 | MYSURU | 66 | KUNTHUR-BANNARI IPP | NO STATIONS EFFECTED | 15:25(24.6.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 480 | 29-Jun-2022 | MYSURU | 66 | DEVANUR NANJANGUDU-BAS1 | NO STATIONS EFFECTED | 6:10:00 PM (03/06/2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 481 | 29-Jun-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 482 | 29-Jun-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 6:26:00 PM (22/04/2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 483 | 29-Jun-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN, LINE CLEAR AVAIED |
| 484 | 29-Jun-2022 | MYSURU | 66 | MUGUR-THAYURU | NO STATIONS EFFECTED | 9:40:00 (20.06.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 485 | 29-Jun-2022 | TUMKUR | 66 | TR1 | SASALUHALLA_66 | 13:00(28.06.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAIED |
| 486 | 29-Jun-2022 | TUMKUR | 220 | TR-3(HV SIDE) | CHITRADURGA_220 | 18:53 | 19:02 | 0:09 | TRANSFORMER FAULT |
| 487 | 29-Jun-2022 | TUMKUR | 220 | TR-3(HV SIDE) | THALLAK_220 | 15:25 | 18:31 | 3:06 | LINE CLEAR AVAIED |
| 488 | 29-Jun-2022 | TUMKUR | 220 | TR-1(HV SIDE) | KIADB_220 | 12:12 | 15:14 | 3:01 | LINE CLEAR AVAIED |
| 489 | 29-Jun-2022 | TUMKUR | 66 | TR-1(LV SIDE) | ANTHARASANAHALLI_220 | 11:03 | 11:54 | 0:50 | LINE CLEAR AVAIED |
| 490 | 29-Jun-2022 | TUMKUR | 66 | TR-2 | ANTHARASANAHALLI_220 | 11:04 | 11:54 | 0:50 | LINE CLEAR AVAIED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|------------------------------------|--|-----------------------|-----------------------|-----------|---------------------------------------|
| 491 | 29-Jun-2022 | TUMKUR | 66 | THALLAK 220kv- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 15:25 | 15:47 | 0:22 | HAND TRIPPED |
| 492 | 29-Jun-2022 | TUMKUR | 66 | THALLAK 220kv- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 15:25 | 15:47 | 0:22 | HAND TRIPPED |
| 493 | 29-Jun-2022 | TUMKUR | 66 | THALLAK 220-PR PURA | THALLAK_220 | 15:25 | 15:47 | 0:22 | HAND TRIPPED |
| 494 | 29-Jun-2022 | TUMKUR | 66 | BHARAMAGIRI66-SRS 220KV HIRIYUR | BHARAMAGIRI_66 | 8:00 | 9:10 | 1:10 | MAIN SUPPLY FAILURE |
| 495 | 29-Jun-2022 | TUMKUR | 66 | TR-1 | CHANNAGIRI_66 | 13:26 | 14:42 | 1:15 | LINE CLEAR AVAIED |
| 496 | 29-Jun-2022 | TUMKUR | 66 | TR-3(HV SIDE) | CHITRADURGA_220 | 18:45 | 19:05 | 0:20 | TRANSFORMER FAULT |
| 497 | 29-Jun-2022 | TUMKUR | 66 | CHITRADURGA 220kv-SUZLON 1 &2 | SUZLON2_IPP_66 | 18:45 | 19:05 | 0:20 | LINE CLEAR AVAIED |
| 498 | 29-Jun-2022 | TUMKUR | 66 | TR-1 | HIREHALLI_66 | 17:30 | 18:09 | 0:39 | LINE CLEAR AVAIED |
| 499 | 29-Jun-2022 | TUMKUR | 66 | TR-2 | HIREHALLI_66 | 17:30 | 18:10 | 0:39 | LINE CLEAR AVAIED |
| 500 | 29-Jun-2022 | TUMKUR | 66 | HONNALLI 220kv-CHANNAGIRI(NALLUR) | DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66 | 9:35 | 9:45 | 0:10 | LINE FAULT |
| 501 | 29-Jun-2022 | TUMKUR | 66 | TR-1(HV SIDE) | KIADB_220 | 12:12 | 15:14 | 3:01 | LINE CLEAR AVAIED |
| 502 | 29-Jun-2022 | TUMKUR | 66 | TR-1 | KORA_66 | 12:35 | 18:20 | 5:45 | LINE CLEAR AVAIED |
| 503 | 30-Jun-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 504 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHWAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 505 | 30-Jun-2022 | BAGALKOT | 110 | AMBEWADI-NK2(KAVALWADA) | STATION NOT AFFECTED AMBEWADI_220 | 8:55 (23.05.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 506 | 30-Jun-2022 | BAGALKOT | 110 | HUBLI220- ANAND NAGAR | STATION NOT AFFECTED HUBLI_220 | 11:37 (14.06.2022) | 11:53 (30.06.2022) | 384:16HRS | LINE CHARGED |
| 507 | 30-Jun-2022 | BAGALKOT | 220 | NARENDRA- AMBEWADI1 | STATION NOT AFFECTED NARENDRA_220 | 10:05 (15.06.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 508 | 30-Jun-2022 | BAGALKOT | 220 | SIRSI220-HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 509 | 30-Jun-2022 | BAGALKOT | 110 | BELGAUM-HUDLI | STATION NOT AFFECTED HUDLI_110 | 16:20 (28.06.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 510 | 30-Jun-2022 | BAGALKOT | 220 | 220/110KV, HV2 | STATION NOT AFFECTED NARENDRA_220 | 11:31 | 16:59 | 5:28 | LINE CLEAR AVAIED |
| 511 | 30-Jun-2022 | BAGALKOT | 110 | 220/110KV, LV2 | STATION NOT AFFECTED NARENDRA_220 | 11:31 | 17:17 | 5:46 | LINE CLEAR AVAIED |
| 512 | 30-Jun-2022 | BAGALKOT | 110 | 220/110KV, LV1 | STATION NOT AFFECTED BELGAUM_220 | 13:13 | 17:40 | 4:27 | LINE CLEAR AVAIED |
| 513 | 30-Jun-2022 | BAGALKOT | 220 | BAGEWADI-MASUTI LIS | STATION NOT AFFECTED BAGEWADI_220 | 11:30 | 18:25 | 6:55 | LINE CLEAR AVAIED |
| 514 | 30-Jun-2022 | BAGALKOT | 110 | KIADB BIJAPUR-BHUTNAL | STATION NOT AFFECTED KIADB BIJAPUR_110 | 8:17 | 9:52 | 1:35 | LINE CLEAR AVAIED |
| 515 | 30-Jun-2022 | BAGALKOT | 110 | THORVI-TIKOTA(TAKKALAKI) | THORVI_110 | 4:37 | 4:38 | 0:01 | HAND TRIPPED |
| 516 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | DEVARA GENNUR_110 | 16:35 | 17:02 | 0:27 | TRANSFORMER FAULT |
| 517 | 30-Jun-2022 | BAGALKOT | 110 | 110/33KV,HV2 | KAMATAGI_33,SHIRUR_33,AC ME SOLAR_33 GULEDAGUDDA_110 | 11:19 | 11:24 | 0:05 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--|---|---------|-----------|----------|--------------------|
| 518 | 30-Jun-2022 | BAGALKOT | 110 | 110/33KV,HV2 | GULEDAGUDDA_110 | 12:01 | 12:08 | 0:07 | TRANSFORMER FAULT |
| 519 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | HIEMASALI_110 | 17:25 | 17:33 | 0:08 | TRANSFORMER FAULT |
| 520 | 30-Jun-2022 | BAGALKOT | 110 | HUKKERI-KOTABAGI LIS | STATION NOT AFFECTED HUKKERI_110 | 20:27 | 20:50 | 0:23 | LINE FAULT |
| 521 | 30-Jun-2022 | BAGALKOT | 110 | 110/33KV,HV2 | HIPPARAGI_33 JAMAKHANDI_110 | 14:18 | 16:37 | 2:19 | LINE CLEAR AVAILED |
| 522 | 30-Jun-2022 | BAGALKOT | 110 | 110/33KV,HV1 | HIPPARAGI_33 JAMAKHANDI_110 | 14:18 | 16:35 | 2:17 | LINE CLEAR AVAILED |
| 523 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | KANABARGI LAYOUT_110 | 13:51 | 14:04 | 0:13 | HAND TRIPPED |
| 524 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | KANABARGI LAYOUT_110 | 13:51 | 13:59 | 0:08 | HAND TRIPPED |
| 525 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV3(HV1) | KANABARGI LAYOUT_110 | 13:51 | 14:06 | 0:15 | HAND TRIPPED |
| 526 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV4(HV2) | KANABARGI LAYOUT_110 | 13:52 | 14:06 | 0:14 | HAND TRIPPED |
| 527 | 30-Jun-2022 | BAGALKOT | 110 | BELGAUM220-KANABARGI LAYOUT | KANABARGI LAYOUT_110 | 13:38 | 13:39 | 0:01 | HAND TRIPPED |
| 528 | 30-Jun-2022 | BAGALKOT | 110 | KERUR-KONNUR | KONNUR_110 | 10:49 | 13:35 | 2:46 | LINE CLEAR AVAILED |
| 529 | 30-Jun-2022 | BAGALKOT | 110 | NARENDRA-KUD DHARWAD | STATION NOT AFFECTED KUD DHARWAD_110 | 11:26 | 17:35 | 6:09 | LINE CLEAR AVAILED |
| 530 | 30-Jun-2022 | BAGALKOT | 110 | KUD DHARWAD- LAKAMANAHALLI | STATION NOT AFFECTED KUD DHARWAD_110 | 17:35 | 17:37 | 0:02 | HAND TRIPPED |
| 531 | 30-Jun-2022 | BAGALKOT | 110 | KULIGERI SUGARS-MRN SUGARS | KULAGERI CROSS_110 | 10:41 | 13:15 | 2:34 | LINE CLEAR AVAILED |
| 532 | 30-Jun-2022 | BAGALKOT | 110 | KONNUR-KULIGERI SUGARS | KULIGERI CROSS_110 | 10:35 | 13:13 | 2:38 | LINE CLEAR AVAILED |
| 533 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | MANTUR(GHP_110 | 12:48 | 12:57 | 0:09 | TRANSFORMER FAULT |
| 534 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | MANTUR(GHP_110 | 13:29 | 14:15 | 0:46 | LINE CLEAR AVAILED |
| 535 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | MANTUR(GHP_110 | 13:29 | 14:15 | 0:46 | LINE CLEAR AVAILED |
| 536 | 30-Jun-2022 | BAGALKOT | 110 | 110/33KV,HV2(HV3) | MATTIHAL_110 | 10:59 | 14:46 | 3:47 | LINE CLEAR AVAILED |
| 537 | 30-Jun-2022 | BAGALKOT | 110 | NEERBUDIHAL-KATARAKI | STATION NOT AFFECTED NEERBUDIHAL_110 | 8:55 | 12:28 | 3:33 | LINE CLEAR AVAILED |
| 538 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | RAIBAG_110 | 10:56 | 12:22 | 1:26 | HAND TRIPPED |
| 539 | 30-Jun-2022 | BAGALKOT | 110 | RANEENNUR220-RATTIHALI (TUMMINAKATTI) | STATION NOT AFFECTED RANEENNUR_220 | 11:10 | 20:21 | 9:11 | LINE CLEAR AVAILED |
| 540 | 30-Jun-2022 | BAGALKOT | 110 | TAKKALAKI-TIKOTA | STATION NOT AFFECTED TAKKALAKI_110 | 10:08 | 10:11 | 0:03 | HAND TRIPPED |
| 541 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | TAKKALAKI_110 | 18:46 | 18:50 | 0:04 | TRANSFORMER FAULT |
| 542 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | TUMMINAKATTI_110 | 10:10 | 17:50 | 7:40 | LINE CLEAR AVAILED |
| 543 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | TUMMINAKATTI_110 | 10:10 | 17:51 | 7:41 | LINE CLEAR AVAILED |
| 544 | 30-Jun-2022 | BAGALKOT | 110 | RANEENNUR220- TUMMINAKATTI | TUMMINAKATTI_110 | 11:15 | 17:48 | 6:33 | LINE CLEAR AVAILED |
| 545 | 30-Jun-2022 | BAGALKOT | 110 | TUMMINAKATTI-RATTIHALI | TUMMINAKATTI_110 | 11:15 | 18:05 | 6:50 | LINE CLEAR AVAILED |
| 546 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | TODALBAGI_110 | 2:36 | 4:47 | 2:11 | TRANSFORMER FAULT |
| 547 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV1 | UCHAGOAN_110 | 13:08 | 14:02 | 0:54 | LINE CLEAR AVAILED |
| 548 | 30-Jun-2022 | BAGALKOT | 110 | VAJRAMATTI-KATARAKI | KATARAKI_110 | 8:42 | 11:35 | 2:53 | LINE CLEAR AVAILED |
| 549 | 30-Jun-2022 | BAGALKOT | 220 | HUBLI-NAGJHARI 1 | STATION NOT AFFECTED HUBLI_220 | 12:25 | 16:49 | 4:24 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|-----------|---------|--------------------------------|--|-----------------------|-----------|----------|---------------------------------------|
| 550 | 30-Jun-2022 | BAGALKOT | 220 | HUBLI-NAGJHARI 2 | STATION NOT AFFECTED HUBLI 220 | 12:26 | 16:49 | 4:23 | LINE CLEAR AVAILED |
| 551 | 30-Jun-2022 | BAGALKOT | 220 | GADAG-DHONI-1&2 | STATION NOT AFFECTED GADAG 220 | 8:34 | 10:56 | 2:22 | LINE CLEAR AVAILED |
| 552 | 30-Jun-2022 | BAGALKOT | 220 | DHONI-GADAG-1&2 | STATION NOT AFFECTED DHONI 400 | 8:33 | 10:56 | 2:23 | LINE CLEAR AVAILED |
| 553 | 30-Jun-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI 110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 554 | 30-Jun-2022 | BAGALKOT | 220 | SIRSI220-HUBLI2 | STATION NOT AFFECTED SIRSI 220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 555 | 30-Jun-2022 | BAGALKOT | 110 | BELGAUM110-KANABARGI LAYOUT | STATION NOT AFFECTED BELGAUM 110 | 10:50 (26.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 556 | 30-Jun-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED BELGAUM 220 | 13:13 | 13:35 | 0:22 | LINE CLEAR AVAILED |
| 557 | 30-Jun-2022 | BAGALKOT | 110 | SAVANUR-ASIAN FEBTECH SOLAR | ASIAN FEBTECH SOLAR_110 STATION NOT AFFECTED SAVANUR 110 | 13:55 | 14:10 | 0:15 | LINE FAULT |
| 558 | 30-Jun-2022 | BAGALKOT | 220 | ATHANI220-KAKAMARI-1 | STATION NOT AFFECTED ATHANI 220 | 15:28 | 18:03 | 2:35 | HAND TRIPPED |
| 559 | 30-Jun-2022 | BAGALKOT | 110 | 110/11KV,HV2 | MATTIHAL_110 | 14:10 | 14:30 | 0:20 | LINE CLEAR AVAILED |
| 560 | 30-Jun-2022 | BAGALKOT | 110 | TUMMINAKATTI-KNNL | TUMMINAKATTI_110 | 10:00 | 18:10 | 8:10 | LINE CLEAR AVAILED |
| 561 | 30-Jun-2022 | BENGALURU | 66 | ELITE PROMENENDE - RBI | ELITE PROMENENDE | 12:25 | 12:30 | 0:05 | LOAD CHANGE OVER |
| 562 | 30-Jun-2022 | BENGALURU | 66 | HV2 | HEBBALA 220 | 16:07 | 16:21 | 0:14 | LINE CLEAR AVAILED |
| 563 | 30-Jun-2022 | BENGALURU | 66 | HV1 | HULIMANGALA | 11:54 | 12:07 | 0:13 | LINE CLEAR AVAILED |
| 564 | 30-Jun-2022 | BENGALURU | 66 | HV2 | HULIMANGALA | 12:40 | 13:09 | 0:29 | LINE CLEAR AVAILED |
| 565 | 30-Jun-2022 | BENGALURU | 66 | HV1 | MAHALAKSHMI LAYOUT | 13:18 | 13:20 | 0:02 | LINE CLEAR AVAILED |
| 566 | 30-Jun-2022 | BENGALURU | 66 | HV1 | NGEF | 11:54 | 12:05 | 0:11 | LINE CLEAR AVAILED |
| 567 | 30-Jun-2022 | BENGALURU | 66 | T GOLLAHALLI 220 - NANGLI | NANGLI, BAIRKURU | 19:02 | 19:22 | 0:20 | LINE FAULT |
| 568 | 30-Jun-2022 | BENGALURU | 66 | BANGARPETE - MALUR 220 | BANGARPETE | 9:15 | 9:25 | 0:10 | LOAD CHANGE OVER |
| 569 | 30-Jun-2022 | BENGALURU | 66 | BANGARPETE - KOLAR 220 | BANGARPETE | 18:45 | 18:55 | 0:10 | LOAD CHANGE OVER |
| 570 | 30-Jun-2022 | BENGALURU | 66 | HV1 | DABUSPETE 220 | 13:38 | 13:40 | 0:02 | LINE CLEAR AVAILED |
| 571 | 30-Jun-2022 | BENGALURU | 66 | HV2 | DABUSPETE 220 | 9:52 | 9:54 | 0:02 | LINE CLEAR AVAILED |
| 572 | 30-Jun-2022 | BENGALURU | 66 | HV2 | DODDABELAVANGALA | 11:44 | 11:50 | 0:06 | LINE CLEAR AVAILED |
| 573 | 30-Jun-2022 | BENGALURU | 66 | HV1 | DEVANAHALLI | 14:17 | 14:25 | 0:08 | TRANSFORMER FAULT |
| 574 | 30-Jun-2022 | BENGALURU | 66 | MALLASANDRA - DRDO | MALLASANDRA | 12:02 | 12:30 | 0:28 | MAIN SUPPLY FAILURE |
| 575 | 30-Jun-2022 | BENGALURU | 66 | MALUR 220 - MAASTHI | MAASTHI, DEVANGONDHI, LAKKUR | 9:26 | 9:29 | 0:03 | LOAD CHANGE OVER |
| 576 | 30-Jun-2022 | BENGALURU | 66 | MALUR 220 - HOSKOTE 1 | MALUR I/A, STAR PANEL (EHT) | 9:26 | 9:29 | 0:03 | LOAD CHANGE OVER |
| 577 | 30-Jun-2022 | BENGALURU | 66 | MALUR 220 - MAASTHI | MAASTHI, DEVANGONDHI, LAKKUR | 18:36 | 18:37 | 0:01 | LOAD CHANGE OVER |
| 578 | 30-Jun-2022 | BENGALURU | 66 | MALUR 220 - HOSKOTE 1 | MALUR I/A, STAR PANEL (EHT) | 18:36 | 18:37 | 0:01 | LOAD CHANGE OVER |
| 579 | 30-Jun-2022 | BENGALURU | 66 | TK HALLI 220 - IGGALUR | IGGALUR,K HONALGERE, YATHAMBADI | 6:10 | 6:23 | 0:13 | LINE FAULT |
| 580 | 30-Jun-2022 | GULBARGA | 400 | RTPS-MUNIRABAD | MUNIRABAD_400 | 10:04 (14.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------|--|-------------------|-------------------|----------|-------------------------------|
| 581 | 30-Jun-2022 | GULBARGA | 220 | HV1 | SHAHAPUR_220 | 15:00 | 18:55 | 3:55 | LINE CLEAR AVAILED |
| 582 | 30-Jun-2022 | GULBARGA | 220 | HV2 | SEDAM_220 | 11:30 | 12:25 | 0:55 | LINE CLEAR AVAILED |
| 583 | 30-Jun-2022 | GULBARGA | 220 | LINGAPUR-JINDAL1 | LINGAPUR_220 | 8:36 | 18:33 | 9:57 | LINE CLEAR AVAILED |
| 584 | 30-Jun-2022 | GULBARGA | 220 | LINGAPUR-JINDAL2 | LINGAPUR_220 | 10:53 | 11:43 | 0:50 | LINE FAULT |
| 585 | 30-Jun-2022 | GULBARGA | 220 | LINGSUGUR-RTPS2 | LINGSUGUR_220 | 11:54 | 12:09 | 0:15 | LINE FAULT |
| 586 | 30-Jun-2022 | GULBARGA | 220 | ITTAGI-HARAKNAL & VESTAS | ITTAGI_220 | 11:10 | 15:50 | 4:40 | LINE CLEAR AVAILED |
| 587 | 30-Jun-2022 | GULBARGA | 220 | ITTAGI-EMBASSY | ITTAGI_220 | 17:38 | 18:15 | 0:37 | LINE CLEAR AVAILED |
| 588 | 30-Jun-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 589 | 30-Jun-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 590 | 30-Jun-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 11:30(23/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 591 | 30-Jun-2022 | GULBARGA | 110 | HV1 | CHIDRI_110 | 16:15 | 17:00 | 0:45 | LINE CLEAR AVAILED |
| 592 | 30-Jun-2022 | GULBARGA | 110 | HV2 | CHIDRI_110 | 11:20 | 12:05 | 0:45 | LINE CLEAR AVAILED |
| 593 | 30-Jun-2022 | GULBARGA | 110 | HV3 | CHIDRI_110 | 12:20 | 16:15 | 3:55 | LINE CLEAR AVAILED |
| 594 | 30-Jun-2022 | GULBARGA | 110 | HV1 | METRI_110 | 10:30 | 18:30 | 8:00 | LINE CLEAR AVAILED |
| 595 | 30-Jun-2022 | GULBARGA | 110 | HV2 | MATAMARI_110 | 10:15 | 15:20 | 5:05 | LINE CLEAR AVAILED |
| 596 | 30-Jun-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 12:25 | 12:30 | 0:05 | TRANSFORMER FAULT |
| 597 | 30-Jun-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 21:10(29.06.2022) | 01:45(30.06.2022) | 04:35HRS | LINE CHARGED |
| 598 | 30-Jun-2022 | GULBARGA | 110 | NALWAR-WARAD SOLAR_IPP | NALWAR_110 | 21:10(29.06.2022) | 01:45(30.06.2022) | 04:35HRS | LINE CHARGED |
| 599 | 30-Jun-2022 | GULBARGA | 110 | STAR METALLIC -MUNIRABAD | MUNIRABAD_220 | 10:53 | 11:00 | 0:07 | LINE FAULT |
| 600 | 30-Jun-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 5:18 | 5:24 | 0:06 | LINE FAULT |
| 601 | 30-Jun-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 5:41 | 5:51 | 0:10 | LINE FAULT |
| 602 | 30-Jun-2022 | GULBARGA | 110 | HALBARGA-SANTAPUR | SANTAPUR_110,AURAD_110,DONGARGOAN_110,DIGGI_110 | 2:09 | 2:16 | 0:07 | LINE FAULT |
| 603 | 30-Jun-2022 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,MGS SK_IPP,BHALKI SUGAR_IPP | 10:50 | 13:25 | 2:35 | LINE CLEAR AVAILED |
| 604 | 30-Jun-2022 | GULBARGA | 110 | RAICHUR-SHAHAPUR2 | GOOGAL_110 | 21:10 | 21:15 | 0:05 | LINE FAULT |
| 605 | 30-Jun-2022 | GULBARGA | 110 | SHAHAPUR-WARDHASOLAR_IPP | SHAHAPUR_220 | 19:56 | 23:49 | 3:53 | LINE CLEAR AVAILED |
| 606 | 30-Jun-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110 | 20:32 | 20:39 | 0:07 | LINE FAULT |
| 607 | 30-Jun-2022 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 5:25 | 5:35 | 0:10 | LINE FAULT |
| 608 | 30-Jun-2022 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 8:25 | 8:35 | 0:10 | LINE FAULT |
| 609 | 30-Jun-2022 | GULBARGA | 110 | MUDDAPUR-MASKI | MUDDAPUR_110 | 2:08 | 2:16 | 0:08 | LINE FAULT |
| 610 | 30-Jun-2022 | GULBARGA | 110 | MUDDAPUR-MASKI | MUDDAPUR_110 | 4:10 | 4:25 | 0:15 | LINE FAULT |
| 611 | 30-Jun-2022 | GULBARGA | 110 | MUDDAPUR-MASKI | MUDDAPUR_110 | 23:50 | 23:55 | 0:05 | LINE FAULT |
| 612 | 30-Jun-2022 | GULBARGA | 66 | HV1 | CHORNOOR_110 | 22:35 | 22:40 | 0:05 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|-----------------------------|--|-----------------------|-----------------------|---------------|--|
| 613 | 30-Jun-2022 | GULBARGA | 66 | HV1,HV2 | UJJAINI_66 | 11:40 | 13:25 | 1:45 | LINE CLEAR AVAILED |
| 614 | 30-Jun-2022 | GULBARGA | 66 | HV1 | UJJAINI_66 | 13:40 | 14:50 | 1:10 | LINE CLEAR AVAILED |
| 615 | 30-Jun-2022 | GULBARGA | 66 | HV1 | UJJAINI_66 | 15:00 | 15:05 | 0:05 | TRANSFORMER FAULT |
| 616 | 30-Jun-2022 | GULBARGA | 66 | UJJAINI-BREIPL | UJJAINI_66 | 11:40 | 13:05 | 1:25 | LINE CLEAR AVAILED |
| 617 | 30-Jun-2022 | GULBARGA | 66 | KUDLIGI-KUDLIGI | KUDLIGI_66 | 7:10 | 8:10 | 1:00 | LINE FAULT |
| 618 | 30-Jun-2022 | GULBARGA | 66 | PUNABGHATA- UCHANGIDURGA | UCHANGIDURGA_66,BILCHO D_66,UJJAINI_66 | 6:50 | 7:00 | 0:10 | LINE FAULT |
| 619 | 30-Jun-2022 | GULBARGA | 66 | PUNABGHATA- UCHANGIDURGA | UCHANGIDURGA_66,BILCHO D_66,UJJAINI_66 | 7:02 | 7:20 | 0:18 | LINE FAULT |
| 620 | 30-Jun-2022 | GULBARGA | 66 | CHORANOR-KUDLIGI | CHORNOOR_110 | 11:05 | 11:10 | 0:05 | MAIN SUPPLY FAILURE |
| 621 | 30-Jun-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI1 | HIREHADAGALI_66 | 10:18 | 18:00 | 7:42 | LINE CLEAR AVAILED |
| 622 | 30-Jun-2022 | GULBARGA | 66 | ITTAGI-HIREHADAGALI2 | HIREHADAGALI_66,GIRIYAPU R_66,MAGALA_66,SOVENHAL LI_66,TUNGABHADRA_IPP | 10:18 | 17:27 | 7:09 | LINE CLEAR AVAILED |
| 623 | 30-Jun-2022 | GULBARGA | 66 | ITTAGI-SUZLON1&2 | ITTAGI_220 | 11:25 | 16:35 | 5:10 | LINE CLEAR AVAILED |
| 624 | 30-Jun-2022 | GULBARGA | 66 | ITTAGI-KUDLIGI1&2 | KUDLIGI_66 | 11:55 | 14:41 | 2:46 | LINE CLEAR AVAILED |
| 625 | 30-Jun-2022 | GULBARGA | 66 | ITTAGI-CLEANMAX1&2 | ITTAGI_220 | 16:00 | 17:50 | 1:50 | LINE CLEAR AVAILED |
| 626 | 30-Jun-2022 | GULBARGA | 66 | ITTAGI-RENEWSOLAR2 | ITTAGI_220 | 18:16 | 18:57 | 0:41 | LINE CLEAR AVAILED |
| 627 | 30-Jun-2022 | GULBARGA | 66 | ITTAGI-RENEWSOLAR1 | ITTAGI_220 | 18:57 | 20:02 | 1:05 | LINE CLEAR AVAILED |
| 628 | 30-Jun-2022 | GULBARGA | 66 | NEELGUNDA-PUNABGATTA | PUNABGATTA_66, UCHCHANGIDURGA_66,BILCH OD_66,UJJAINI_66 | 9:10 | 9:21 | 0:11 | LINE FAULT |
| 629 | 30-Jun-2022 | HASSAN | 400kv | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 630 | 30-Jun-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.20 22) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 631 | 30-Jun-2022 | HASSAN | 66 | HV2 | HASSAN_66 | 10:05 (6.06.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 632 | 30-Jun-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 13:12(18.06.20 22) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 633 | 30-Jun-2022 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 15:29(28.06.20 22) | 15:11 (30.06.2022) | 47:41 hrs | LINE CHARGED |
| 634 | 30-Jun-2022 | HASSAN | 220 | SHRAVITY-TALAGUPPA 2 | sharavathy_gen | 20:11 (29.06.2022) | 15:13(30.06.202 2) | 43:021 hrs | LINE CHARGED |
| 635 | 30-Jun-2022 | HASSAN | 220 | HGUNJE-KMR | HEGGUNJE_220 | 13:51 | 17:09 | 3:18 | LINE FAULT |
| 636 | 30-Jun-2022 | HASSAN | 220 | KEMAR-Varahi2 | KEMAR_220 | 11:02 | 13:59 | 2:57 | NFBC ISSUED |
| 637 | 30-Jun-2022 | HASSAN | 220 | KEMAR-HEGNJE | KEMAR_220 | 13:51 | 17:10 | 3:19 | LINE FAULT |
| 638 | 30-Jun-2022 | HASSAN | 220 | VARAHI-KEMAR2 | gen_varahi | 11:02 | 14:00 | 2:58 | LINE CLEAR AVAILED |
| 639 | 30-Jun-2022 | HASSAN | 220 | VARAHI-KEMAR3 | gen_varahi | 13:02 | 13:41 | 0:39 | LINE FAULT |
| 640 | 30-Jun-2022 | HASSAN | 110 | GURUVA-SLVPWR | GURUVAYANKERE_110 | 12:26 | 13:11 | 0:45 | LINE CLEAR AVAILED |
| 641 | 30-Jun-2022 | HASSAN | 110 | HV3 | HIRIYADKA_110 | 10:30 | 12:10 | 1:40 | LINE CLEAR AVAILED |
| 642 | 30-Jun-2022 | HASSAN | 110 | HV2 | JOG_110 | 11:20 | 13:00 | 1:40 | LINE CLEAR AVAILED |
| 643 | 30-Jun-2022 | HASSAN | 110 | KADUR-AJAMPURA | KADUR_220 | 12:16 | 12:30 | 0:14 | MAIN SUPPLY FAILURE |
| 644 | 30-Jun-2022 | HASSAN | 110 | HV2 | KADUR_220 | 10:26 | 17:15 | 6:49 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--------------------------------|---|---------|-----------|----------|---------------------|
| 645 | 30-Jun-2022 | HASSAN | 110 | LV1 | KADUR_220 | 12:16 | 12:30 | 0:14 | TRANSFORMER FAULT |
| 646 | 30-Jun-2022 | HASSAN | 110 | LV2 | KADUR_220 | 10:26 | 17:15 | 6:49 | LINE CLEAR AVOIDED |
| 647 | 30-Jun-2022 | HASSAN | 110 | KADUR-NERELEKERE | KADUR_220 | 12:16 | 12:30 | 0:14 | MAIN SUPPLY FAILURE |
| 648 | 30-Jun-2022 | HASSAN | 110 | KADUR-NGNHL | KADUR_220 | 12:16 | 12:30 | 0:14 | MAIN SUPPLY FAILURE |
| 649 | 30-Jun-2022 | HASSAN | 110 | KADUR-TNGL | KADUR_220 | 12:16 | 12:30 | 0:14 | MAIN SUPPLY FAILURE |
| 650 | 30-Jun-2022 | HASSAN | 110 | KADUR-YGTI | KADUR_220 | 12:16 | 12:30 | 0:14 | MAIN SUPPLY FAILURE |
| 651 | 30-Jun-2022 | HASSAN | 110 | HV2 | NERALEKERE_110 | 16:06 | 17:40 | 1:34 | HAND TRIPPED |
| 652 | 30-Jun-2022 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 9:16 | 9:20 | 0:04 | MAIN SUPPLY FAILURE |
| 653 | 30-Jun-2022 | HASSAN | 66 | BHADRA-SHMGA 1 | BHADRA | 16:16 | 17:02 | 0:46 | LINE CLEAR AVOIDED |
| 654 | 30-Jun-2022 | HASSAN | 66 | BHADRA-SHMGA 2 | BHADRA | 15:00 | 16:14 | 1:14 | LINE CLEAR AVOIDED |
| 655 | 30-Jun-2022 | HASSAN | 66 | HNPR2-MYSOR1 | HOLENARASIPURA_220 | 0:00 | 0:13 | 0:13 | LINE FAULT |
| 656 | 30-Jun-2022 | HASSAN | 66 | HV2 | HOLEHONNUR_66 | 10:05 | 18:45 | 8:40 | LINE CLEAR AVOIDED |
| 657 | 30-Jun-2022 | HASSAN | 66 | HV1 | KUDLIGERE_66 | 13:20 | 13:35 | 0:15 | MAIN SUPPLY FAILURE |
| 658 | 30-Jun-2022 | HASSAN | 66 | SIGEBAG-KDLGRE | SIGEBAGE_66 | 12:55 | 13:20 | 0:25 | LINE FAULT |
| 659 | 30-Jun-2022 | MYSURU | 66 | HV1 | DODDABYADARAHALLI_66 | 6:50 | 7:25 | 0:35 | LINE CLEAR AVOIDED |
| 660 | 30-Jun-2022 | MYSURU | 66 | HAMPAPURA-BASARALU | NO STATIONS EFFECTED | 12:14 | 14:22 | 2:08 | LINE CLEAR AVOIDED |
| 661 | 30-Jun-2022 | MYSURU | 66 | HUNSUR-ILAWALA | GAVADAGERE_66 | 18:48 | 19:05 | 0:17 | LINE FAULT |
| 662 | 30-Jun-2022 | MYSURU | 66 | NAGAMANGALA 220 - KASALGERE | NO STATIONS EFFECTED | 6:23 | 6:53 | 0:30 | LINE FAULT |
| 663 | 30-Jun-2022 | MYSURU | 220 | NAGAMANGALA 220 - ANCHEPALYA 1 | BOGADHI MANDYA_66 GUDDENAHALLI_66 | 14:25 | 16:43 | 2:18 | NFBC ISSUED |
| 664 | 30-Jun-2022 | MYSURU | 220 | NAGAMANGALA 220 - ANCHEPALYA 2 | NO STATIONS EFFECTED | 14:25 | 16:43 | 2:18 | NFBC ISSUED |
| 665 | 30-Jun-2022 | MYSURU | 220 | KUSHALANAGARA-BASTHIPURA 2 | KUSHALNAGARA_220 BYLUKUPPE_66 KAMPALAPURA_66 PERIYAPATNA_66 PONNAMPET_66, VIRAJPET_66, HANAGODU_66 MADIKERI_66 SUNTIKOPPA_66 BETTADHAPURA_66 KITTUR_66 MIRLE_66 RAVANDUR_66 CHUNCHUNKATTE_66 KRNAGARA_66 KANAGAL_66 ALUR SIDDAPURA_66 BHERYA_66 BILIKERE_66 DMG_HALLI_66 GVGUDI_66 | 14:47 | 15:38 | 0:51 | LINE FAULT |
| 666 | 30-Jun-2022 | MYSURU | 66 | HV2 | SANTHEBACHALLI_66 | 18:05 | 18:10 | 0:05 | TRANSFORMER FAULT |
| 667 | 30-Jun-2022 | MYSURU | 66 | DOORA-CHANDRAVADI | CHANDRAVADI_66 HURA_66 HULLAHALLI_66 | 6:45 | 7:00 | 0:15 | LINE FAULT |
| 668 | 30-Jun-2022 | MYSURU | 66 | HV1 | BILIKERE_66 | 15:47 | 17:35 | 1:48 | TRANSFORMER FAULT |
| 669 | 30-Jun-2022 | MYSURU | 66 | HV1 | BILIKERE_66 | 17:51 | 18:14 | 0:23 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|---------|---------|--|-------------------------------------|----------------------------|-----------------------------|----------|---------------------------------------|
| 670 | 30-Jun-2022 | MYSURU | 66 | DEVANUR NANJANGUDU-BAS1 | NO STATIONS EFFECTED | 18:10 (03/06/2022) | 12:15:00 PM (30.06.2022) | 18:05HRS | LINE CHARGED |
| 671 | 30-Jun-2022 | MYSURU | 66 | HV2 | KOPPA_66 | 22:45 (30.06.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 672 | 30-Jun-2022 | MYSURU | 220 | TUBINKERE-BASTIPURA | NO STATIONS EFFECTED | 7:01:00 AM (26.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 673 | 30-Jun-2022 | MYSURU | 66 | KUNTHUR-BANNARI IPP | NO STATIONS EFFECTED | 15:25(24.6.22) | | | LINE OPEN, LINE CLEAR AVAILED |
| 674 | 30-Jun-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 675 | 30-Jun-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26:00 | | | LINE OPEN, LINE CLEAR AVAILED |
| 676 | 30-Jun-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN, LINE CLEAR AVAILED |
| 677 | 30-Jun-2022 | TUMKUR | 220 | HONNALLI 220kV- DAVANAGERE SRS | HONNALLI_220 | 13:25 | 13:56 | 0:31 | LINE FAULT |
| 678 | 30-Jun-2022 | TUMKUR | 220 | HONNALLI 220kV-SYSLONE LINE-1 | HONNALLI_220 | 13:26 | 14:06 | 0:40 | MAIN SUPPLY FAILURE |
| 679 | 30-Jun-2022 | TUMKUR | 220 | HONNALLI 220kV-SYSLONE LINE-2 | HONNALLI_220 | 13:26 | 14:06 | 0:40 | MAIN SUPPLY FAILURE |
| 680 | 30-Jun-2022 | TUMKUR | 220 | TR1 AND TR2 | HONNALLI_220 | 13:26 | 14:06 | 0:40 | MAIN SUPPLY FAILURE |
| 681 | 30-Jun-2022 | TUMKUR | 220 | HONNALLI 220kV-BENKIKERE - 1 | HONNALLI_220 | 13:27 | 14:06 | 0:39 | MAIN SUPPLY FAILURE |
| 682 | 30-Jun-2022 | TUMKUR | 220 | HONNALLI 220kV-BENKIKERE - 2 | HONNALLI_220 | 13:27 | 14:06 | 0:39 | MAIN SUPPLY FAILURE |
| 683 | 30-Jun-2022 | TUMKUR | 220 | TR1 | PAVAGADA_220 | 14:20 | 14:30 | 0:10 | TRANSFORMER FAULT |
| 684 | 30-Jun-2022 | TUMKUR | 220 | TR2 | PAVAGADA_220 | 14:20 | 14:35 | 0:15 | TRANSFORMER FAULT |
| 685 | 30-Jun-2022 | TUMKUR | 66 | ANCHEPALYA 220kV- ANCHEPALYA1 | ANCHEPALYA_66, BHAKTHARAHALLI_66 | 11:45 | 11:47 | 0:02 | LINE CLEAR AVAILED |
| 686 | 30-Jun-2022 | TUMKUR | 66 | KEMPANAHALLI 66- ANCHEPALYA220 | KEMPANAHALL66 | 0:10 | 0:25 | 0:15 | LINE FAULT |
| 687 | 30-Jun-2022 | TUMKUR | 66 | YEDIYUR- ANCHEPALYA220KV | BGNAGARA_66 | 10:14 | 16:29 | 6:15 | LINE CLEAR AVAILED |
| 688 | 30-Jun-2022 | TUMKUR | 66 | ANCHEPALYA220KV- NAGAMANGALA LINE 1 | ANCHEPALYA_220 | 14:24 | 16:46 | 2:22 | LINE CLEAR AVAILED |
| 689 | 30-Jun-2022 | TUMKUR | 66 | ANCHEPALYA220KV- NAGAMANGALA LINE 2 | ANCHEPALYA_220 | 14:24 | 16:46 | 2:22 | LINE CLEAR AVAILED |
| 690 | 30-Jun-2022 | TUMKUR | 66 | PAVAGADA220- NAGALAMADIKE66 | PAVAGADA_220 | 6:50 | 7:22 | 0:32 | LINE FAULT |
| 691 | 30-Jun-2022 | TUMKUR | 66 | PAVAGADA220-PAVAGADA2 | PAVAGADA_220 | 14:20 | 14:40 | 0:20 | LINE FAULT |
| 692 | 30-Jun-2022 | TUMKUR | 66 | TR1 AND TR2 | BILCHODU_66 | 6:50 | 7:20 | 0:30 | MAIN SUPPLY FAILURE |
| 693 | 30-Jun-2022 | TUMKUR | 66 | TR1 AND TR2 | BILCHODU_66 | 9:10 | 9:20 | 0:10 | MAIN SUPPLY FAILURE |
| 694 | 30-Jun-2022 | TUMKUR | 66 | TR3 | HARIYABBE_66 | 9:05 | 9:10 | 0:05 | TRANSFORMER FAULT |
| 695 | 30-Jun-2022 | TUMKUR | 66 | TR3 | HARIYABBE_66 | 9:10 | 9:40 | 0:30 | LINE CLEAR AVAILED |
| 696 | 30-Jun-2022 | TUMKUR | 66 | HARIYABBE-PD KOTE | HARIYABBE_66 | 11:00 | 18:35 | 7:35 | LINE CLEAR AVAILED |
| 697 | 30-Jun-2022 | TUMKUR | 66 | HANAGAL-THALLAK 1 | HANAGAL_66 | 19:05 | 19:35 | 0:30 | LINE FAULT |
| 698 | 30-Jun-2022 | TUMKUR | 66 | HANAGAL-THALLAK2 | HANAGAL_66 | 19:05 | 19:25 | 0:20 | LINE FAULT |
| 699 | 30-Jun-2022 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 14:50 | 15:05 | 0:15 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|-------------|----------|---------|--------------------------------|--|--------------------|--------------------|----------|-------------------------------------|
| 700 | 30-Jun-2022 | TUMKUR | 66 | HOLALKERE-CHIKAJAJUR1 | HOLALKERE_66 | 17:40 | 18:00 | 0:20 | MAIN SUPPLY FAILURE |
| 701 | 30-Jun-2022 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 15:15 | 15:30 | 0:15 | MAIN SUPPLY FAILURE |
| 702 | 30-Jun-2022 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 16:50 | 17:25 | 0:35 | MAIN SUPPLY FAILURE |
| 703 | 30-Jun-2022 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 17:30 | 17:35 | 0:05 | MAIN SUPPLY FAILURE |
| 704 | 30-Jun-2022 | TUMKUR | 66 | HOLALKERE-CHIKAJAJUR1 | HOLALKERE_66 | 18:15 | 18:30 | 0:15 | MAIN SUPPLY FAILURE |
| 705 | 30-Jun-2022 | TUMKUR | 66 | HOLALKERE-CHIKAJAJUR1 | HOLALKERE_66 | 19:10 | 19:15 | 0:05 | MAIN SUPPLY FAILURE |
| 706 | 30-Jun-2022 | TUMKUR | 66 | TR1,TR2 AND TR3 | HONNALI_66 | 13:25 | 14:15 | 0:50 | MAIN SUPPLY FAILURE |
| 707 | 30-Jun-2022 | TUMKUR | 66 | KADDAJI_66-SRS_DAVANGERE | KADDAJI_66 | 6:50 | 7:00 | 0:10 | MAIN SUPPLY FAILURE |
| 708 | 30-Jun-2022 | TUMKUR | 66 | KADDAJI_66-SRS_DAVANGERE | KADDAJI_66 | 7:00 | 7:20 | 0:20 | MAIN SUPPLY FAILURE |
| 709 | 30-Jun-2022 | TUMKUR | 66 | TR1 | JIDDIGERE_66 | 10:15 | 16:30 | 6:15 | MAIN SUPPLY FAILURE |
| 710 | 30-Jun-2022 | TUMKUR | 66 | TR1 AND TR2 | MALEBENNUR_66 | 13:25 | 14:15 | 0:50 | TRANSFORMER FAULT |
| 711 | 30-Jun-2022 | TUMKUR | 66 | MATHOD- PANCHANAHALLI | GARAGA_66,PANCHANAHALLI_66 | 5:55 | 6:00 | 0:05 | LINE FAULT |
| 712 | 30-Jun-2022 | TUMKUR | 66 | TR1 | SASALUHALLA_66 | 13:00(28.06.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 713 | 1-Jul-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 714 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHWAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 715 | 1-Jul-2022 | BAGALKOT | 110 | AMBEWADI-NK2(KAVALWADA) | STATION NOT AFFECTED AMBEWADI_220 | 8:55 (23.05.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 716 | 1-Jul-2022 | BAGALKOT | 220 | NARENDRA- AMBEWADI1 | STATION NOT AFFECTED NARENDRA_220 | 10:05 (15.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 717 | 1-Jul-2022 | BAGALKOT | 220 | SIRSI220-HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 718 | 1-Jul-2022 | BAGALKOT | 110 | BELGAUM-HUDLI | STATION NOT AFFECTED HUDLI_110 | 16:20 (28.06.2022) | 13:23 (01.07.2022) | 69:03HRS | LINE CHARGED |
| 719 | 1-Jul-2022 | BAGALKOT | 110 | VAJJRAMATTI220-MELLIGERI | MELLIGERI_110 | 15:42 | 15:45 | 0:03 | HAND TRIPPED |
| 720 | 1-Jul-2022 | BAGALKOT | 110 | VAJJRAMATTI220-MANTUR-I | MANTUR_110 MUNDAGNUR_110 MAREGUDDI_110 SHIROL_110 NIRANI SUGARS_110 PRABHU SUGARS_110 | 15:52 | 15:55 | 0:03 | HAND TRIPPED |
| 721 | 1-Jul-2022 | BAGALKOT | 110 | VAJJRAMATTI220-MANTUR-II | MANTUR_110 MUNDAGNUR_110 MAREGUDDI_110 SHIROL_110 NIRANI SUGARS_110 PRABHU SUGARS_110 | 15:52 | 15:56 | 0:04 | HAND TRIPPED |
| 722 | 1-Jul-2022 | BAGALKOT | 220 | VAJJRAMATTI-ENERGON(VENA)SOLAR | ENERGON(VENA)SOLAR_220 VAJJRAMATTI_220 | 15:56 | 16:02 | 0:06 | HAND TRIPPED |
| 723 | 1-Jul-2022 | BAGALKOT | 220 | VAJJRAMATTI-KAWATAGI LIS | KAWATAGI LIS_220 VAJJRAMATTI_220 | 15:55 | 16:03 | 0:08 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|----------------------------------|--|-----------------------|-----------|----------|--|
| 724 | 1-Jul-2022 | BAGALKOT | 220 | HUBLI-BIDNAL-1 | STATION NOT AFFECTED HUBLI 220 | 10:18 | 16:53 | 6:35 | LINE CLEAR AVAILED |
| 725 | 1-Jul-2022 | BAGALKOT | 110 | GHATAPRABHA220- GHATAPRABHA-2 | STATION NOT AFFECTED GHATAPRABHA 220 | 13:44 | 18:38 | 4:54 | LINE CLEAR AVAILED |
| 726 | 1-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV1 | STATION NOT AFFECTED BAGALKOT 220 | 11:56 | 11:59 | 0:03 | HAND TRIPPED |
| 727 | 1-Jul-2022 | BAGALKOT | 110 | RANEENNUR220- TUMMINAKATTI | STATION NOT AFFECTED RANEENNUR 220 | 11:06 | 18:04 | 6:58 | LINE CLEAR AVAILED |
| 728 | 1-Jul-2022 | BAGALKOT | 220 | NARENDRA-HUBLI-1 | STATION NOT AFFECTED NARENDRA 220 | 5:59 | 6:18 | 0:19 | LINE FAULT |
| 729 | 1-Jul-2022 | BAGALKOT | 110 | KARWAR220-BINAGA (SOLARIS) | SOLARIS_110 STATION NOT AFFECTED KARWAR 220 | 16:40 | 17:47 | 1:07 | LINE FAULT |
| 730 | 1-Jul-2022 | BAGALKOT | 110 | GHATAPRABHA220-HIDIKAL DAM | STATION NOT AFFECTED HIDIKAL DAM 110 | 13:32 | 18:55 | 5:23 | HAND TRIPPED |
| 731 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | STATION NOT AFFECTED JAMAKHANDI 110 | 6:04 | 10:19 | 4:15 | LINE CLEAR AVAILED |
| 732 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED KUDUCHI 220 | 6:19 | 6:25 | 0:06 | TRANSFORMER FAULT |
| 733 | 1-Jul-2022 | BAGALKOT | 220 | BIDNAL-HUBLI-1 | STATION NOT AFFECTED BIDNAL 220 | 10:18 | 16:10 | 5:52 | LINE CLEAR AVAILED |
| 734 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED MANTUR(GHP) 110 | 17:46 | 17:59 | 0:13 | TRANSFORMER FAULT |
| 735 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | STATION NOT AFFECTED RAIBAG 110 | 10:18 | 16:15 | 5:57 | LINE CLEAR AVAILED |
| 736 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV3(HV1) | STATION NOT AFFECTED SAVALAGI 110 | 10:56 | 13:50 | 2:54 | LINE CLEAR AVAILED |
| 737 | 1-Jul-2022 | BAGALKOT | 110 | 110/33KV,HV2(HV1) | LIS_33,KALBILAGI_33,TUNGAL LIS_33 STATION NOT AFFECTED HIREPADASALAGI 110 | 15:59 | 16:25 | 0:26 | LINE CLEAR AVAILED |
| 738 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED SHIRBUR 110 | 17:05 | 17:36 | 0:31 | LINE CLEAR AVAILED |
| 739 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | STATION NOT AFFECTED SIRSI 110 | 21:50 | 22:22 | 0:32 | TRANSFORMER FAULT |
| 740 | 1-Jul-2022 | BAGALKOT | 110 | RANEENNUR220- TUMMINAKATTI | STATION NOT AFFECTED TUMMINAKATTI 110 | 11:10 | 18:01 | 6:51 | LINE CLEAR AVAILED |
| 741 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | STATION NOT AFFECTED UKKALI 110 | 17:35 | 17:54 | 0:19 | LINE CLEAR AVAILED |
| 742 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV4(HV2) | STATION NOT AFFECTED VADAGOAN 110 | 14:20 | 14:34 | 0:14 | LINE CLEAR AVAILED |
| 743 | 1-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI 110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 744 | 1-Jul-2022 | BAGALKOT | 220 | SIRSI220-HUBLI2 | STATION NOT AFFECTED SIRSI 220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 745 | 1-Jul-2022 | BAGALKOT | 110 | BELGAUM110-KANABARGI LAYOUT | STATION NOT AFFECTED BELGAUM 110 | 10:50 (26.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 746 | 1-Jul-2022 | BAGALKOT | 110 | VAJJRAMATTI220-LOKAPUR | STATION NOT AFFECTED VAJJRAMATTI 220 | 15:36 | 15:41 | 0:05 | HAND TRIPPED |
| 747 | 1-Jul-2022 | BAGALKOT | 110 | BELAGAVI220-HUDLI | HUDLI 110 | 13:18 | 13:20 | 0:02 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|-----------|---------|--|--|---------|-----------|----------|---------------------|
| 748 | 1-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-NAVANAGAR-2 | STATION NOT AFFECTED BAGALKOT_220 | 12:40 | 12:55 | 0:15 | HAND TRIPPED |
| 749 | 1-Jul-2022 | BAGALKOT | 110 | BAGALKOT220- NEERABUDIHAL | STATION NOT AFFECTED BAGALKOT_220 | 11:56 | 12:04 | 0:08 | HAND TRIPPED |
| 750 | 1-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-KALADAGI | STATION NOT AFFECTED BAGALKOT_220 | 11:55 | 12:04 | 0:09 | HAND TRIPPED |
| 751 | 1-Jul-2022 | BAGALKOT | 110 | CHIKKODI220-RAIBAG-2 | STATION NOT AFFECTED CHIKKODI_220 | 23:13 | 23:21 | 0:08 | LINE FAULT |
| 752 | 1-Jul-2022 | BAGALKOT | 220 | HUBLI-NARENDRA-1 | STATION NOT AFFECTED HUBLI_220 | 6:00 | 6:00 | 0:00 | LINE FAULT |
| 753 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED KAMBAGI_110 | 13:30 | 13:40 | 0:10 | TRANSFORMER FAULT |
| 754 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED SAVALAGI_110 | 16:25 | 16:30 | 0:05 | LINE CLEAR AVAILED |
| 755 | 1-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV3(HV1) | STATION NOT AFFECTED SAVALAGI_110 | 16:30 | 16:35 | 0:05 | LINE CLEAR AVAILED |
| 756 | 1-Jul-2022 | BENGALURU | 66 | ADUGODI - HSR LAYOUT 220 | ADUGODI, BOSCH (EHT), JAKKASANDRA | 7:59 | 8:04 | 0:05 | LOAD CHANGE OVER |
| 757 | 1-Jul-2022 | BENGALURU | 66 | HV1 | CHANDRA LAYOUT | 17:59 | 18:17 | 0:18 | TRANSFORMER FAULT |
| 758 | 1-Jul-2022 | BENGALURU | 66 | PADMANABHANAGARA - NATIONAL COLLEGE | PADMANABHANAGARA | 6:29 | 6:33 | 0:04 | LOAD CHANGE OVER |
| 759 | 1-Jul-2022 | BENGALURU | 66 | HV2 | ANEKAL | 14:45 | 14:47 | 0:02 | LINE CLEAR AVAILED |
| 760 | 1-Jul-2022 | BENGALURU | 66 | HV2 | ANEKAL | 16:10 | 16:13 | 0:03 | LOAD CHANGE OVER |
| 761 | 1-Jul-2022 | BENGALURU | 66 | HV1 | BANGARPETE | 22:06 | 22:30 | 0:24 | TRANSFORMER FAULT |
| 762 | 1-Jul-2022 | BENGALURU | 66 | DALASNUR - MALLASANDRA | DALASNUR, YELDUR | 11:20 | 11:45 | 0:25 | MAIN SUPPLY FAILURE |
| 763 | 1-Jul-2022 | BENGALURU | 66 | DALASNUR - CHINTAMANI 220 | DALASNUR | 13:40 | 13:50 | 0:10 | LOAD CHANGE OVER |
| 764 | 1-Jul-2022 | BENGALURU | 66 | HV2 | HUKUNDA | 11:15 | 11:20 | 0:05 | TRANSFORMER FAULT |
| 765 | 1-Jul-2022 | BENGALURU | 66 | HV2 | HUKUNDA | 12:25 | 12:30 | 0:05 | TRANSFORMER FAULT |
| 766 | 1-Jul-2022 | BENGALURU | 66 | MALLASANDRA - DRDO | MALLASANDRA | 11:25 | 13:25 | 2:00 | MAIN SUPPLY FAILURE |
| 767 | 1-Jul-2022 | BENGALURU | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 9:24 | 9:34 | 0:10 | LINE FAULT |
| 768 | 1-Jul-2022 | BENGALURU | 66 | HV1 | MITTEMARI 220 | 14:58 | 15:13 | 0:15 | LINE CLEAR AVAILED |
| 769 | 1-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - SOMANATHPURA | SOMANATHPURA, CHAKAVELU, CHELUR | 16:29 | 18:12 | 1:43 | LINE CLEAR AVAILED |
| 770 | 1-Jul-2022 | BENGALURU | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE | 15:03 | 15:17 | 0:14 | LINE FAULT |
| 771 | 1-Jul-2022 | GULBARGA | 110 | SHAKTINAGAR- RAICHURBIOMASS | SHAKTINAGAR_110 | 13:49 | 15:59 | 2:10 | LINE FAULT |
| 772 | 1-Jul-2022 | GULBARGA | 110 | SHAKTINAGAR- RAICHURBIOMASS | SHAKTINAGAR_110 | 15:38 | 15:58 | 0:20 | LINE CLEAR AVAILED |
| 773 | 1-Jul-2022 | GULBARGA | 110 | MUDDAPUR-MASKI | MASKI_110,KAVITAL_110 | 23:21 | 23:27 | 0:06 | LINE FAULT |
| 774 | 1-Jul-2022 | GULBARGA | 110 | ADAVI AMARESHWAR- MALLAT | ADAVI AMRESHWAR_110,JAWALGER A_110 | 4:05 | 4:13 | 0:08 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|------------------------------|--|---------|-----------|----------|---------------------|
| 775 | 1-Jul-2022 | GULBARGA | 110 | NALWAR-SHAHABAD(SHAHAPUR)1&2 | NALWAR_110,JEWARGI_110,CLEAN SOLAR_IPP,WARAD SOLAR_IPP | 4:10 | 4:30 | 0:20 | LINE FAULT |
| 776 | 1-Jul-2022 | GULBARGA | 110 | NALWAR-SHAHABAD(SHAHAPUR)2 | JEWARGI_110 | 5:40 | 5:50 | 0:10 | LINE FAULT |
| 777 | 1-Jul-2022 | GULBARGA | 110 | NALWAR-SHAHABAD(SHAHAPUR)2 | JEWARGI_110 | 17:20 | 19:55 | 2:35 | LINE FAULT |
| 778 | 1-Jul-2022 | GULBARGA | 110 | NALWAR-SHAHABAD(SHAHAPUR)2 | JEWARGI_110 | 22:20 | 22:25 | 0:05 | LINE FAULT |
| 779 | 1-Jul-2022 | GULBARGA | 110 | JAWALAGERA-ADVIAMARESHWAR | JAWALAGERA_110 | 0:00 | 0:10 | 0:10 | MAIN SUPPLY FAILURE |
| 780 | 1-Jul-2022 | GULBARGA | 110 | JAWALAGERA-ADVIAMARESHWAR | JAWALAGERA_110 | 4:00 | 4:10 | 0:10 | MAIN SUPPLY FAILURE |
| 781 | 1-Jul-2022 | GULBARGA | 110 | YEREDONA-SINDHANOOR | YERADONA_110 | 2:10 | 2:35 | 0:25 | MAIN SUPPLY FAILURE |
| 782 | 1-Jul-2022 | GULBARGA | 110 | YEREDONA-SINDHANOOR | YERADONA_110 | 2:50 | 3:10 | 0:20 | MAIN SUPPLY FAILURE |
| 783 | 1-Jul-2022 | GULBARGA | 110 | YEREDONA-SINDHANOOR | YERADONA_110 | 4:50 | 5:15 | 0:25 | MAIN SUPPLY FAILURE |
| 784 | 1-Jul-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR1 | SHAHAPUR_110 | 4:06 | 4:11 | 0:05 | LINE FAULT |
| 785 | 1-Jul-2022 | GULBARGA | 110 | SEDAM-KURKUNTA | KURKUNTA_110 | 12:15 | 15:45 | 3:30 | LINE CLEAR AVAILED |
| 786 | 1-Jul-2022 | GULBARGA | 110 | SEDAM-VICATSAGAR_IPP | SEDAM_220 | 19:03 | 19:17 | 0:14 | LINE FAULT |
| 787 | 1-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 0:04 | 0:10 | 0:06 | LINE FAULT |
| 788 | 1-Jul-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 10:19 | 10:40 | 0:21 | LINE FAULT |
| 789 | 1-Jul-2022 | GULBARGA | 110 | KAPNOOR-ALAND | ALAND_110,KADAGANCHI_110 | 10:22 | 10:42 | 0:20 | LINE FAULT |
| 790 | 1-Jul-2022 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD2 | MUKUNDA_110,YERDONA_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110 | 2:12 | 2:27 | 0:15 | LINE FAULT |
| 791 | 1-Jul-2022 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD2 | MUKUNDA_110,YERDONA_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110 | 2:55 | 3:10 | 0:15 | LINE FAULT |
| 792 | 1-Jul-2022 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD2 | MUKUNDA_110,YERDONA_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110 | 5:04 | 5:14 | 0:10 | LINE FAULT |
| 793 | 1-Jul-2022 | GULBARGA | 66 | HV1 | HARAPANAHALLI_66 | 20:35 | 20:45 | 0:10 | TRANSFORMER FAULT |
| 794 | 1-Jul-2022 | GULBARGA | 66 | HV1 | BENNEHALLI_66 | 14:30 | 14:50 | 0:20 | TRANSFORMER FAULT |
| 795 | 1-Jul-2022 | GULBARGA | 66 | HV1,HV2 | BENNEHALLI_66 | 18:45 | 18:50 | 0:05 | TRANSFORMER FAULT |
| 796 | 1-Jul-2022 | GULBARGA | 66 | HV3 | TELAGI_66 | 11:00 | 11:20 | 0:20 | LINE CLEAR AVAILED |
| 797 | 1-Jul-2022 | GULBARGA | 66 | HV1 | HANSI_66 | 6:30 | 6:50 | 0:20 | TRANSFORMER FAULT |
| 798 | 1-Jul-2022 | GULBARGA | 66 | HV1 | HANSI_66 | 8:10 | 9:10 | 1:00 | LINE CLEAR AVAILED |
| 799 | 1-Jul-2022 | GULBARGA | 66 | BENNEHALLI-KOTTUR | KOTTUR_66 | 18:45 | 18:55 | 0:10 | LINE FAULT |
| 800 | 1-Jul-2022 | GULBARGA | 66 | BENNEHALLI-ITTAGGI | BENNEHALLI_66 | 18:45 | 18:50 | 0:05 | LINE FAULT |
| 801 | 1-Jul-2022 | GULBARGA | 66 | ITTAGI-RENEWSOLAR2_IPP | ITTAGI_220 | 14:12 | 14:15 | 0:03 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|-------------------------|--|-----------------------|-----------|----------|--------------------------------------|
| 802 | 1-Jul-2022 | GULBARGA | 66 | ITTAGI-BENNEHALLI | BENNEHALLI_66, KOTTUR_66, UJJAINI_66 | 14:25 | 14:45 | 0:20 | LINE FAULT |
| 803 | 1-Jul-2022 | GULBARGA | 66 | HANSI-KUDALIGI 220KV | HANSI_66 | 9:00 | 9:10 | 0:10 | LINE CLEAR AVAILED |
| 804 | 1-Jul-2022 | GULBARGA | 66 | HANSI-KUDALIGI 220KV | HANSI_66 | 19:10 | 19:20 | 0:10 | MAIN SUPPLY FAILURE |
| 805 | 1-Jul-2022 | GULBARGA | 66 | PUNABGATTA-NEELGUNDA | PUNABGATTA_66, UCHCHANGIDURGA_66, BILCHOD_66, UJJAINI_66 | 7:00 | 7:05 | 0:05 | LINE FAULT |
| 806 | 1-Jul-2022 | GULBARGA | 66 | PUNABGHATA-UCHANGIDURGA | UCHANGIDURGA_66, BILCHOD_66, UJJAINI_66 | 15:00 | 15:55 | 0:55 | LINE FAULT |
| 807 | 1-Jul-2022 | HASSAN | 400kV | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 808 | 1-Jul-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN, LINE CLEAR AVAILED |
| 809 | 1-Jul-2022 | HASSAN | 66 | HV2 | HASSAN_66 | 10:05 (6.06.2022) | | | TRANSFORMER OPEN, LINE CLEAR AVAILED |
| 810 | 1-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 13:12(18.06.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 811 | 1-Jul-2022 | HASSAN | 66 | BHADRA-SHMG 2 | gen_bhadra | 16:40(01.07.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 812 | 1-Jul-2022 | HASSAN | 220 | SHRAVITY-SHIMOGA1 | gen_sharavthy | 9:27 | 16:49 | 7:22 | LINE CLEAR AVAILED |
| 813 | 1-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY2 | MRS MG_220 | 9:27 | 16:49 | 7:22 | LINE CLEAR AVAILED |
| 814 | 1-Jul-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 12:14 | 13:50 | 1:36 | LINE CLEAR AVAILED |
| 815 | 1-Jul-2022 | HASSAN | 110 | KAVOOR-KONAJE | KAVOOR_220 | 9:24 | 13:02 | 3:38 | LINE CLEAR AVAILED |
| 816 | 1-Jul-2022 | HASSAN | 110 | HV1 | SHIRALKOPPA_220 | 16:54 | 17:25 | 0:31 | LINE CLEAR AVAILED |
| 817 | 1-Jul-2022 | HASSAN | 66 | HV1 | BYACHANAHALLI_66 | 8:15 | 10:30 | 2:15 | LINE CLEAR AVAILED |
| 818 | 1-Jul-2022 | HASSAN | 66 | HV1 | HASSAN_66 | 16:59 | 17:10 | 0:11 | HAND TRIPPED |
| 819 | 1-Jul-2022 | HASSAN | 66 | HV2 | RAMNAHPURA_66T | 14:09 | 14:50 | 0:41 | LINE CLEAR AVAILED |
| 820 | 1-Jul-2022 | HASSAN | 400kV | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 821 | 1-Jul-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN, LINE CLEAR AVAILED |
| 822 | 1-Jul-2022 | HASSAN | 66 | HV2 | HASSAN_66 | 10:05 (6.06.2022) | | | TRANSFORMER OPEN, LINE CLEAR AVAILED |
| 823 | 1-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 13:12(18.06.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 824 | 1-Jul-2022 | HASSAN | 66 | BHADRA-SHMG 2 | gen_bhadra | 16:40(01.07.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 825 | 1-Jul-2022 | HASSAN | 220 | SHRAVITY-SHIMOGA1 | gen_sharavthy | 9:27 | 16:49 | 7:22 | LINE CLEAR AVAILED |
| 826 | 1-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY2 | MRS MG_220 | 9:27 | 16:49 | 7:22 | LINE CLEAR AVAILED |
| 827 | 1-Jul-2022 | HASSAN | 110 | HV2 | BARANGI_110 | 12:14 | 13:50 | 1:36 | LINE CLEAR AVAILED |
| 828 | 1-Jul-2022 | HASSAN | 110 | KAVOOR-KONAJE | KAVOOR_220 | 9:24 | 13:02 | 3:38 | LINE CLEAR AVAILED |
| 829 | 1-Jul-2022 | HASSAN | 110 | HV1 | SHIRALKOPPA_220 | 16:54 | 17:25 | 0:31 | LINE CLEAR AVAILED |
| 830 | 1-Jul-2022 | HASSAN | 66 | HV1 | BYACHANAHALLI_66 | 8:15 | 10:30 | 2:15 | LINE CLEAR AVAILED |
| 831 | 1-Jul-2022 | HASSAN | 66 | HV1 | HASSAN_66 | 16:59 | 17:10 | 0:11 | HAND TRIPPED |
| 832 | 1-Jul-2022 | HASSAN | 66 | HV2 | RAMNAHPURA_66T | 14:09 | 14:50 | 0:41 | LINE CLEAR AVAILED |
| 833 | 1-Jul-2022 | MYSURU | 66 | HV1 | KADKOTHANAHALLI_66 | 14:00 | 14:05 | 0:05 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|---------|---------|----------------------------------|--|----------------------------|----------------------------|-----------|------------------------------------|
| 834 | 1-Jul-2022 | MYSURU | 66 | HV2 | KADKOTHANAHALLI_66 | 14:00 | 14:05 | 0:05 | HAND TRIPPED |
| 835 | 1-Jul-2022 | MYSURU | 66 | HV2 | KOPPA_66 | 22:45 (30.06.2022) | 2:20:00 PM (01.07.2022) | 15:35HRS | TRANSFORMER CHARGED |
| 836 | 1-Jul-2022 | MYSURU | 220 | TUBINKERE-BASTIPURA | NO STATIONS EFFECTED | 7:01:00 AM (26.06.2022) | 17:30:00 (01.07.2022) | 10:29HRS | LINE CHARGED |
| 837 | 1-Jul-2022 | MYSURU | 66 | KUNTHUR-BANNARI IPP | NO STATIONS EFFECTED | 15:25 (24.07.2022) | 9:04:05 AM (01.07.2022) | 161:38HRS | LINE CHARGED |
| 838 | 1-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 839 | 1-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26 (22/04/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 840 | 1-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHALLI | NO STATIONS EFFECTED | 15:16(08/12/2021) | | | LINE OPEN, LINE CLEAR AVAILED |
| 841 | 1-Jul-2022 | TUMKUR | 220 | TR3 | CHITRADURGA_220 | 16:34 | 16:46 | 0:12 | TRANSFORMER FAULT |
| 842 | 1-Jul-2022 | TUMKUR | 220 | TR3 | HIRIYUR_220 | 18:40 | 19:06 | 0:26 | TRANSFORMER FAULT |
| 843 | 1-Jul-2022 | TUMKUR | 66 | CHITRADURGA 220kV-CHALLAKERE | BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66 | 5:28 | 5:42 | 0:14 | LINE FAULT |
| 844 | 1-Jul-2022 | TUMKUR | 66 | CHITRADURGA 220kV-TURUVANUR | MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66 | 16:35 | 16:47 | 0:12 | HAND TRIPPED |
| 845 | 1-Jul-2022 | TUMKUR | 66 | CHITRADURGA 220kV-CHALLAKERE | BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66 | 16:35 | 16:47 | 0:12 | HAND TRIPPED |
| 846 | 1-Jul-2022 | TUMKUR | 66 | CHITRADURGA 66kV-CHITRADURGA 4 | CHITRADURGA_66 | 19:04 | 19:15 | 0:11 | LINE FAULT |
| 847 | 1-Jul-2022 | TUMKUR | 66 | CHITRADURGA 220kV-PANDARAHALLI 2 | PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66 | 19:04 | 19:15 | 0:11 | LINE FAULT |
| 848 | 1-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- SOKKE | MELLEKATTE_66, SOKKE_66 | 10:50 | 10:58 | 0:08 | LINE FAULT |
| 849 | 1-Jul-2022 | TUMKUR | 66 | HIRIYUR 220KV-ENERCON1 IPP_66 | ENERCON1_IPP_66 | 18:50 | 19:10 | 0:20 | HAND TRIPPED |
| 850 | 1-Jul-2022 | TUMKUR | 66 | HIRIYURKV 220kV- SUZLON 2 | SUZLON2_IPP_66 | 18:50 | 19:10 | 0:20 | HAND TRIPPED |
| 851 | 1-Jul-2022 | TUMKUR | 66 | HIRIYURKV 220kV-THALLAK_66 | HIRIYUR_220 | 18:50 | 19:20 | 0:30 | HAND TRIPPED |
| 852 | 1-Jul-2022 | TUMKUR | 66 | HIRIYUR220-MATHOD 1 | MATHOD_66,HINDASGHATTA_66,KANCHIPURA_66,GARAG A_66,PANCHANAHALLI_66,HOSADURGA_66 | 18:45 | 19:10 | 0:25 | HAND TRIPPED |
| 853 | 1-Jul-2022 | TUMKUR | 66 | HIRIYUR220-MATHOD 2&1 LINE CLUB | MATHOD_66,HINDASGHATTA_66,KANCHIPURA_66,GARAG A_66,PANCHANAHALLI_66,HOSADURGA_66 | 18:45 | 19:10 | 0:25 | HAND TRIPPED |
| 854 | 1-Jul-2022 | TUMKUR | 66 | TR2 | BILCHODU_66 | 13:10 | 13:25 | 0:15 | TRANSFORMER FAULT |
| 855 | 1-Jul-2022 | TUMKUR | 66 | TR2 | BILCHODU_66 | 14:00 | 14:50 | 0:50 | TRANSFORMER FAULT |
| 856 | 1-Jul-2022 | TUMKUR | 66 | TR1 AND TR2 | BILCHODU_66 | 7:00 | 7:05 | 0:05 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|--------------------------------|---|--------------------|--------------------|-----------|-------------------------------------|
| 857 | 1-Jul-2022 | TUMKUR | 66 | TR1 AND TR2 | BILCHODU_66 | 15:00 | 15:55 | 0:55 | MAIN SUPPLY FAILURE |
| 858 | 1-Jul-2022 | TUMKUR | 66 | TR1 AND TR2 | BILCHODU_66 | 16:35 | 16:50 | 0:15 | MAIN SUPPLY FAILURE |
| 859 | 1-Jul-2022 | TUMKUR | 66 | TR1 | CHANNAGIRI_66 | 13:29 | 13:33 | 0:04 | TRANSFORMER FAULT |
| 860 | 1-Jul-2022 | TUMKUR | 66 | TR1 AND TR2 | DASUDI_66 | 12:40 | 12:50 | 0:10 | MAIN SUPPLY FAILURE |
| 861 | 1-Jul-2022 | TUMKUR | 66 | HARIYABBE-PD KOTE | HARIYABBE_66 | 11:50 | 20:30 | 8:40 | LINE CLEAR AVAILED |
| 862 | 1-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 16:30 | 16:35 | 0:05 | LINE FAULT |
| 863 | 1-Jul-2022 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 19:05 | 19:15 | 0:10 | MAIN SUPPLY FAILURE |
| 864 | 1-Jul-2022 | TUMKUR | 66 | BEVINAHALLI_66-AFTL SOLAR | BEVINAHALLI_66 | 5:55 | 7:05 | 1:10 | LINE FAULT |
| 865 | 1-Jul-2022 | TUMKUR | 66 | TR1 | NIDSALE | 10:00 | 11:00 | 1:00 | TRANSFORMER FAULT |
| 866 | 1-Jul-2022 | TUMKUR | 66 | TR1 | NIDSALE | 14:30 | 15:15 | 0:45 | TRANSFORMER FAULT |
| 867 | 1-Jul-2022 | TUMKUR | 66 | TR1 | JAVAGONDANAHALLI_66 | 12:00 | 12:50 | 0:50 | MAIN SUPPLY FAILURE |
| 868 | 1-Jul-2022 | TUMKUR | 66 | TR1 | SASALUHALLA_66 | 13:00(28.06.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 869 | 2-Jul-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 870 | 2-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHWAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 871 | 2-Jul-2022 | BAGALKOT | 110 | AMBEWADI-NK2(KAVALWADA) | STATION NOT AFFECTED AMBEWADI_220 | 8:55 (23.05.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 872 | 2-Jul-2022 | BAGALKOT | 220 | NARENDRA- AMBEWADI1 | STATION NOT AFFECTED NARENDRA_220 | 10:05 (15.06.2022) | 18:49 (02.07.2022) | 416:44HRS | LINE CHARGED |
| 873 | 2-Jul-2022 | BAGALKOT | 220 | SIRSI220-HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 874 | 2-Jul-2022 | BAGALKOT | 220 | AEQUS-CHIKKODI-1 | STATION NOT AFFECTED AEQUS_220 | 18:25 | 19:06 | 0:41 | LINE FAULT |
| 875 | 2-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 & LV1 | STATION NOT AFFECTED CHIKKODI_220 | 18:25 | 18:54 | 0:29 | HAND TRIPPED |
| 876 | 2-Jul-2022 | BAGALKOT | 110 | CHIKKODI220-NIPPANI(KADAKALAT) | KADAKALAT_110 NIPPANI_110 | 5:17 | 5:35 | 0:18 | LINE FAULT |
| 877 | 2-Jul-2022 | BAGALKOT | 110 | HIDKAL DAM-ANKALAGI(ISLAMPUR) | ISLAMPUR_110 | 10:00 | 10:12 | 0:12 | LINE FAULT |
| 878 | 2-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV1 | HIPPARGI_33 STATION NOT AFFECTED JAMAKHANDI_110 | 14:09 | 18:47 | 4:38 | LINE CLEAR AVAILED |
| 879 | 2-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV2 | HIPPARGI_33 STATION NOT AFFECTED JAMAKHANDI_110 | 14:14 | 18:42 | 4:28 | LINE CLEAR AVAILED |
| 880 | 2-Jul-2022 | BAGALKOT | 110 | CHIKKODI220-KADAKALAT | KADAKALAT_110 | 5:16 | 5:38 | 0:22 | LINE FAULT |
| 881 | 2-Jul-2022 | BAGALKOT | 110 | KADAKALAT-NIPPANI | NIPPANI_110 | 5:38 | 5:39 | 0:01 | HAND TRIPPED |
| 882 | 2-Jul-2022 | BAGALKOT | 110 | KADAKALAT-NIPPANI | NIPPANI_110 | 18:33 | 18:51 | 0:18 | HAND TRIPPED |
| 883 | 2-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-KERUR | STATION NOT AFFECTED KERUR_110 | 16:44 | 18:06 | 1:22 | LINE CLEAR AVAILED |
| 884 | 2-Jul-2022 | BAGALKOT | 220 | MUGALKHOD-CHIKKODI-1 | STATION NOT AFFECTED MUGALKHOD_220 | 11:30 | 16:13 | 4:43 | NFBC ISSUED |
| 885 | 2-Jul-2022 | BAGALKOT | 220 | MUGALKHOD-CHIKKODI-2 | STATION NOT AFFECTED MUGALKHOD_220 | 16:29 (02.07.2022) | | | LINE OPEN, LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|--------------------------------|--|-----------------------|-----------|----------|--|
| 886 | 2-Jul-2022 | BAGALKOT | 220 | MUGALKHOD-GHATAPRABHA-2 | STATION NOT AFFECTED MUGALKHOD_220 | 18:25 | 18:48 | 0:23 | LINE FAULT |
| 887 | 2-Jul-2022 | BAGALKOT | 220 | MUGALKHOD-CHIKKODI-1 | STATION NOT AFFECTED MUGALKHOD_220 | 18:25 | 18:49 | 0:24 | LINE FAULT |
| 888 | 2-Jul-2022 | BAGALKOT | 220 | SIRSI-SHARAVATY-1 | STATION NOT AFFECTED SIRSI_220 | 10:27 | 16:52 | 6:25 | HAND TRIPPED |
| 889 | 2-Jul-2022 | BAGALKOT | 110 | KARWAR220-ARGA | STATION NOT AFFECTED KARWAR_220 | 12:06 | 15:22 | 3:16 | LINE CLEAR AVAILED |
| 890 | 2-Jul-2022 | BAGALKOT | 220 | KUDACHI-CHIKKODI-1 | STATION NOT AFFECTED KUDACHI_220 | 18:25 | 18:51 | 0:26 | LINE FAULT |
| 891 | 2-Jul-2022 | BAGALKOT | 220 | KUDACHI-CHIKKODI-2 | STATION NOT AFFECTED KUDACHI_220 | 18:25 | 18:54 | 0:29 | LINE FAULT |
| 892 | 2-Jul-2022 | BAGALKOT | 220 | HUBLI-NAGAZARI-1 | STATION NOT AFFECTED HUBLI_220 | 9:19 | 18:52 | 9:33 | LINE CLEAR AVAILED |
| 893 | 2-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-KERUR | STATION NOT AFFECTED BAGALKOT_220 | 15:31 | 15:34 | 0:03 | HAND TRIPPED |
| 894 | 2-Jul-2022 | BAGALKOT | 110 | BAGALKOT-KERUR | STATION NOT AFFECTED BAGALKOT_220 | 17:42 | 17:49 | 0:07 | HAND TRIPPED |
| 895 | 2-Jul-2022 | BAGALKOT | 220 | VAJRAMATT220- MELLIGERI | MELLIGERI_110 | 18:25 | 19:05 | 0:40 | LINE FAULT |
| 896 | 2-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV3 | STATION NOT AFFECTED BAGALKOT_220 | 15:28 | 17:35 | 2:07 | LINE CLEAR AVAILED |
| 897 | 2-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV3 | STATION NOT AFFECTED BAGALKOT_220 | 15:28 | 17:35 | 2:07 | LINE CLEAR AVAILED |
| 898 | 2-Jul-2022 | BAGALKOT | 220 | VAJRAMATTI-MAHALINGAPUR-2 | STATION NOT AFFECTED VAJARAMATTI_220 | 18:25 | 19:05 | 0:40 | LINE FAULT |
| 899 | 2-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | SIRSI_110 | 4:54 | 5:10 | 0:16 | TRANSFORMER FAULT |
| 900 | 2-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | SIRSI_110 | 8:37 | 8:45 | 0:08 | TRANSFORMER FAULT |
| 901 | 2-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | SIRSI_110 | 13:44 | 13:57 | 0:13 | LINE CLEAR AVAILED |
| 902 | 2-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | SIDDAPUR_110 | 13:36 | 14:19 | 0:43 | LINE CLEAR AVAILED |
| 903 | 2-Jul-2022 | BAGALKOT | 110 | RON-HIREHAL | RON_110 | 15:11 | 15:19 | 0:08 | HAND TRIPPED |
| 904 | 2-Jul-2022 | BAGALKOT | 110 | 220/110, LV2 | STATION NOT AFFECTED RANEBENNUR_220 | 17:45 | 17:58 | 0:13 | HAND TRIPPED |
| 905 | 2-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN, TRANSFORMER FAULT |
| 906 | 2-Jul-2022 | BAGALKOT | 220 | SIRSI220-HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 907 | 2-Jul-2022 | BAGALKOT | 110 | BELGAUM110-KANABARGI LAYOUT | STATION NOT AFFECTED BELGAUM_110 | 10:50 (26.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 908 | 2-Jul-2022 | BAGALKOT | 220 | BELGAUM- CHIKKODI 2(AEQU2) | STATION NOT AFFECTED BELGAUM_220 | 18:25 | 18:54 | 0:29 | LINE FAULT |
| 909 | 2-Jul-2022 | BAGALKOT | 110 | KARWAR-ARGA | STATION NOT AFFECTED ARGA_110 | 12:06 | 15:22 | 3:16 | NFBC ISSUED |
| 910 | 2-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-RAMDURG | STATION NOT AFFECTED BAGALKOT_220 | 6:40 | 6:50 | 0:10 | LINE FAULT |
| 911 | 2-Jul-2022 | BAGALKOT | 220 | HUBLI-NARENDRA 1 | HUBLI_220 | 5:56 | 5:56 | 0:00 | LINE FAULT |
| 912 | 2-Jul-2022 | BAGALKOT | 220 | RANEBENNUR-BALLIGAVI | BALLIGAVI_110 | 16:15 | 18:05 | 1:50 | LINE CLEAR AVAILED |
| 913 | 2-Jul-2022 | BAGALKOT | 220 | CHIKKODI-KUDACHI-1 | STATION NOT AFFECTED CHIKKODI_220 | 18:27 | 18:50 | 0:23 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|-----------|---------|---|--|-----------------------|-----------|----------|-------------------------------|
| 914 | 2-Jul-2022 | BAGALKOT | 110 | HIREHAL-MYTRA SOLAR | MYTRA SOLAR_110 HIREHAL_110 | 15:05 | 15:24 | 0:19 | HAND TRIPPED |
| 915 | 2-Jul-2022 | BAGALKOT | 110 | HIREHAL-BADAMI | BADAMI_110 | 15:05 | 15:24 | 0:19 | HAND TRIPPED |
| 916 | 2-Jul-2022 | BENGALURU | 66 | BIDADI 220 - COCO COLA (EHT) | COCO COLA (EHT) | 14:49 | 15:32 | 0:43 | LINE FAULT |
| 917 | 2-Jul-2022 | BENGALURU | 66 | BIDADI 220 - COCO COLA (EHT) | COCO COLA (EHT) | 17:52 | 19:00 | 1:08 | LINE FAULT |
| 918 | 2-Jul-2022 | BENGALURU | 66 | HAL 220 - HOODY 2 | BAGMANE TECH PARK, GTRE (EHT) | 11:00 | 12:45 | 1:45 | LINE CLEAR AVAILED |
| 919 | 2-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ELECTRONIC CITY 2 | BIOCON (EHT), BOMMASANDRA I/A | 9:32 | 9:50 | 0:18 | LINE CLEAR AVAILED |
| 920 | 2-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ELECTRONIC CITY 1 | ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA | 9:36 | 9:51 | 0:15 | LINE CLEAR AVAILED |
| 921 | 2-Jul-2022 | BENGALURU | 220 | HV1 | YARANDANAHALLI 220 | 9:36 | 9:50 | 0:14 | LINE CLEAR AVAILED |
| 922 | 2-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 1 | SURYANAGAR | 17:10 | 17:20 | 0:10 | LINE CLEAR AVAILED |
| 923 | 2-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ANEKAL 2 | ANEKAL, SAMANDURU | 17:10 | 17:20 | 0:10 | LINE CLEAR AVAILED |
| 924 | 2-Jul-2022 | BENGALURU | 66 | HV1 | YARANDANAHALLI 220 | 17:11 | 17:19 | 0:08 | LINE CLEAR AVAILED |
| 925 | 2-Jul-2022 | BENGALURU | 66 | HV3 | YARANDANAHALLI 220 | 17:11 | 17:19 | 0:08 | LINE CLEAR AVAILED |
| 926 | 2-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ELECTRONIC CITY 1 | ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA | 17:12 | 17:27 | 0:15 | LINE CLEAR AVAILED |
| 927 | 2-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - ELECTRONIC CITY 2 | BIOCON (EHT), BOMMASANDRA I/A | 17:12 | 17:27 | 0:15 | LINE CLEAR AVAILED |
| 928 | 2-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - CHANDAPURA | CHANDAPURA | 17:14 | 17:20 | 0:06 | LINE CLEAR AVAILED |
| 929 | 2-Jul-2022 | BENGALURU | 66 | YARANDANAHALLI 220 - TIMES OF INDIA (EHT) | TIMES OF INDIA (EHT) | 17:14 | 17:20 | 0:06 | LINE CLEAR AVAILED |
| 930 | 2-Jul-2022 | BENGALURU | 220 | HV1 | YARANDANAHALLI 220 | 17:15 | 17:26 | 0:11 | LINE CLEAR AVAILED |
| 931 | 2-Jul-2022 | BENGALURU | 66 | VIDYANAGAR - HOSKOTE 220 | NO STATION AFFECTED | 17:46 | 20:08 | 2:21 | LINE FAULT |
| 932 | 2-Jul-2022 | BENGALURU | 66 | VIDHURASHWATHA - GUNDLU KOTTUR | GUNDLU KOTTUR | 7:29 | 7:33 | 0:04 | LINE FAULT |
| 933 | 2-Jul-2022 | BENGALURU | 66 | HV2 | SADALI | 13:55 | 14:15 | 0:20 | LINE CLEAR AVAILED |
| 934 | 2-Jul-2022 | BENGALURU | 66 | HV1 | MULBAGLU | 16:36 | 16:58 | 0:21 | LINE CLEAR AVAILED |
| 935 | 2-Jul-2022 | BENGALURU | 66 | HV1 | GODURU | 13:31 | 14:27 | 0:55 | LINE CLEAR AVAILED |
| 936 | 2-Jul-2022 | BENGALURU | 66 | HOSKOTE 220 - BIAL BEGUR | NO STATION AFFECTED | 18:52 | 18:59 | 0:07 | LINE FAULT |
| 937 | 2-Jul-2022 | BENGALURU | 66 | TADIGOLU CROSS - CHINTAMANI 220 | TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU | 17:45 | 18:15 | 0:30 | LINE FAULT |
| 938 | 2-Jul-2022 | GULBARGA | 400 | RTPS-MUNIRABAD | MUNIRABAD_400 | 10:04 (14.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 939 | 2-Jul-2022 | GULBARGA | 110 | HV1 | BENUR_110 | 5:00 | 5:18 | 0:18 | TRANSFORMER FAULT |
| 940 | 2-Jul-2022 | GULBARGA | 110 | HV2 | SREERAMANAGAR_110 | 17:56 | 18:25 | 0:29 | TRANSFORMER FAULT |
| 941 | 2-Jul-2022 | GULBARGA | 110 | HV1 | HALKUNDI_110 | 9:00 | 17:20 | 8:20 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|-------------------------|--|--------------------|-----------|----------|-------------------------------------|
| 942 | 2-Jul-2022 | GULBARGA | 110 | ADAVI AMARESHWAR-MALLAT | ADAVI AMRESHWAR_110,JAWALGERA_110 | 17:14 | 17:19 | 0:05 | MAIN SUPPLY FAILURE |
| 943 | 2-Jul-2022 | GULBARGA | 110 | GURMITKAL-SEDAM | GURMITKAL_110 | 11:15 | 14:40 | 3:25 | NFBC ISSUED |
| 944 | 2-Jul-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 0:00 | 0:10 | 0:10 | LINE FAULT |
| 945 | 2-Jul-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 0:40 | 1:20 | 0:40 | LINE FAULT |
| 946 | 2-Jul-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 5:17 | 5:55 | 0:38 | LINE FAULT |
| 947 | 2-Jul-2022 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 18:50 | 20:15 | 1:25 | LINE CLEAR AVOIDED |
| 948 | 2-Jul-2022 | GULBARGA | 110 | HALBARGA-KOLHAR1 | KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY | 19:05 | 19:13 | 0:08 | LINE FAULT |
| 949 | 2-Jul-2022 | GULBARGA | 110 | HALBARGA-KOLHAR2 | KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY | 19:05 | 19:13 | 0:08 | LINE FAULT |
| 950 | 2-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 951 | 2-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 952 | 2-Jul-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 11:30(23/06/2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 953 | 2-Jul-2022 | GULBARGA | 110 | LINGASUGUR-KAREPOWER | CHAYADEVI_IPP,KAREPOWER_IPP | 19:49 | 19:56 | 0:07 | LINE FAULT |
| 954 | 2-Jul-2022 | GULBARGA | 110 | LINGASUGUR-KAREPOWER | CHAYADEVI_IPP,KAREPOWER_IPP | 20:55 | 21:16 | 0:21 | LINE FAULT |
| 955 | 2-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110 | 2:33 | 2:38 | 0:05 | LINE FAULT |
| 956 | 2-Jul-2022 | GULBARGA | 110 | SHAHAPUR-SHORAPUR | SHORAPUR_110 | 4:09 | 4:15 | 0:06 | LINE FAULT |
| 957 | 2-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110 | 23:35 | 23:39 | 0:04 | LINE FAULT |
| 958 | 2-Jul-2022 | GULBARGA | 110 | SEDAM-GURUMITKAL | GURUMITKAL_110,KONKAL_110 | 11:12 | 14:45 | 3:33 | LINE CLEAR AVOIDED |
| 959 | 2-Jul-2022 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD_2 | MUKUNDA_110,YARADONA_110,BENNUR_110,BTPAS WATER WORKS | 4:40 | 4:50 | 0:10 | LINE FAULT |
| 960 | 2-Jul-2022 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD_1 | KARATAGI_110, SRERAMNAGAR_110, GANGAVATHI_110, VENKATAGIRI_110 | 22:40 | 22:50 | 0:10 | LINE FAULT |
| 961 | 2-Jul-2022 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110,GALAG_110 | 1:08 | 1:12 | 0:04 | LINE FAULT |
| 962 | 2-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 17:15 | 17:19 | 0:04 | LINE CLEAR AVOIDED |
| 963 | 2-Jul-2022 | GULBARGA | 66 | HANASI-KUDALIGI | HANASI_66 | 21:35 | 21:50 | 0:15 | MAIN SUPPLY FAILURE |
| 964 | 2-Jul-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 965 | 2-Jul-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVOIDED |
| 966 | 2-Jul-2022 | HASSAN | 66 | HV2 | HASSAN_66 | 10:05 (6.06.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVOIDED |
| 967 | 2-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 13:12(18.06.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 968 | 2-Jul-2022 | HASSAN | 66 | BHADRA-SHMG 2 | gen_bhadra | 16:40(01.07.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|---------|---------|--------------------------------|------------------------------|---------------------------|----------------------|-----------|-------------------------------|
| 969 | 2-Jul-2022 | HASSAN | 110 | MOODAB-SOHAM2 | MOODABIDRE_110 | 1:02(02.07.2022) | | | LINE OPEN,LINE FAULT |
| 970 | 2-Jul-2022 | HASSAN | 66 | BHADRA-SHMG2 | bhadra_gen | 16:40(01.07.2022) | 15:25 (2.07.2022) | 22:44 hrs | LINE CHARGED |
| 971 | 2-Jul-2022 | HASSAN | 400 | HASSAN4-UPCL2 | HASSAN_400 | 1:17 | 7:13 | 5:56 | HAND TRIPPED |
| 972 | 2-Jul-2022 | HASSAN | 400 | UPCL-HASSAN2 | upcl_gen | 1:17 | 7:13 | 5:56 | HAND TRIPPED |
| 973 | 2-Jul-2022 | HASSAN | 220 | TALAGU-ST2 | TALAGUPPA_400 | 9:36 | 11:55 | 2:19 | HAND TRIPPED |
| 974 | 2-Jul-2022 | HASSAN | 110 | ANAVATI-BARNGI | ANAVATTI_110 | 10:50 | 11:55 | 1:05 | HAND TRIPPED |
| 975 | 2-Jul-2022 | HASSAN | 110 | HV2 | ANAVATTI_110 | 11:55 | 12:08 | 0:13 | TRANSFORMER FAULT |
| 976 | 2-Jul-2022 | HASSAN | 110 | BARANG-ANVATTI | BARANGI_110 | 11:20 | 12:00 | 0:40 | LINE CLEAR AVAILED |
| 977 | 2-Jul-2022 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPPA_220 | 11:22 | 18:48 | 7:26 | LINE CLEAR AVAILED |
| 978 | 2-Jul-2022 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 12:04 | 16:20 | 4:16 | LINE FAULT |
| 979 | 2-Jul-2022 | HASSAN | 66 | HV2 | ARAKALGUD_66 | 17:25 | 17:40 | 0:15 | TRANSFORMER FAULT |
| 980 | 2-Jul-2022 | HASSAN | 66 | HV | CHIKABOMMENAHALLI_66 | 11:40 | 11:50 | 0:10 | TRANSFORMER FAULT |
| 981 | 2-Jul-2022 | HASSAN | 66 | HV | CHIKABOMMENAHALLI_66 | 11:52 | 12:00 | 0:08 | TRANSFORMER FAULT |
| 982 | 2-Jul-2022 | HASSAN | 66 | CRPATNA-MATTANAVILE | CHANNRAYAPATNA_66 | 11:20 | 12:25 | 1:05 | LINE CLEAR AVAILED |
| 983 | 2-Jul-2022 | HASSAN | 66 | HNPR2-HASS2 | HOLENARASIPURA_220 | 12:25 | 12:35 | 0:10 | LINE FAULT |
| 984 | 2-Jul-2022 | HASSAN | 66 | HV1 | HOLALUR_66 | 10:20 | 14:40 | 4:20 | MAIN SUPPLY FAILURE |
| 985 | 2-Jul-2022 | HASSAN | 66 | HV2 | HOLALUR_66 | 10:20 | 14:40 | 4:20 | MAIN SUPPLY FAILURE |
| 986 | 2-Jul-2022 | HASSAN | 66 | HV1 | HOLEHONNUR_66 | 10:20 | 18:05 | 7:45 | LINE CLEAR AVAILED |
| 987 | 2-Jul-2022 | HASSAN | 66 | HV2 | HOLEHONNUR_66 | 10:20 | 18:05 | 7:45 | LINE CLEAR AVAILED |
| 988 | 2-Jul-2022 | HASSAN | 66 | KUDLIGE-SIGEBAGI | KUDLIGERE_66 | 10:10 | 12:30 | 2:20 | MAIN SUPPLY FAILURE |
| 989 | 2-Jul-2022 | HASSAN | 66 | MATTNAV-DIDGTHL | MATTANNAVILE_66 | 11:25 | 12:25 | 1:00 | LINE CLEAR AVAILED |
| 990 | 2-Jul-2022 | HASSAN | 66 | MRSSHM-DVG2 | MRSMSG_220 | 10:56 | 12:58 | 2:02 | LINE CLEAR AVAILED |
| 991 | 2-Jul-2022 | HASSAN | 66 | MRSSHM-HOLUR | MRSMSG_220 | 10:21 | 14:20 | 3:59 | LINE CLEAR AVAILED |
| 992 | 2-Jul-2022 | HASSAN | 66 | HV1 | SIGEBAGE_66 | 10:10 | 13:00 | 2:50 | LINE CLEAR AVAILED |
| 993 | 2-Jul-2022 | HASSAN | 66 | SIGEBEG-KDLGRE | SIGEBAGE_66 | 10:10 | 13:00 | 2:50 | LINE CLEAR AVAILED |
| 994 | 2-Jul-2022 | HASSAN | 66 | SIGEBEG-SMG-DVG2 | SIGEBAGE_66 | 10:10 | 13:00 | 2:50 | LINE CLEAR AVAILED |
| 995 | 2-Jul-2022 | MYSURU | 66 | HV1 | BANNIMANTAP_66 | 9:32 | 10:48 | 1:16 | LINE CLEAR AVAILED |
| 996 | 2-Jul-2022 | MYSURU | 66 | HV1 | BANNIMANTAP_66 | 11:52 | 11:58 | 0:05 | TRANSFORMER FAULT |
| 997 | 2-Jul-2022 | MYSURU | 66 | HV2 | BANNIMANTAP_66 | 10:54 | 12:20 | 1:25 | LINE CLEAR AVAILED |
| 998 | 2-Jul-2022 | MYSURU | 66 | HV2 | HAMPAPURA_66 | 0:00 | 0:12 | 0:12 | TRANSFORMER FAULT |
| 999 | 2-Jul-2022 | MYSURU | 66 | KRPETE 220-SB HALLI | NO STATIONS EFFECTED | 16:11 | 16:18 | 0:07 | LINE FAULT |
| 1000 | 2-Jul-2022 | MYSURU | 220 | KRPETE 220-TUBINAKERE | NO STATIONS EFFECTED | 5:32:51 AM (02.7.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1001 | 2-Jul-2022 | MYSURU | 66 | HV2 | SANTHEBACHALLI_66 | 3:14 | 3:19 | 0:04 | TRANSFORMER FAULT |
| 1002 | 2-Jul-2022 | MYSURU | 66 | HV2 | SANTHEBACHALLI_66 | 13:45 | 13:52 | 0:07 | TRANSFORMER FAULT |
| 1003 | 2-Jul-2022 | MYSURU | 220 | TUBINAKERE-KR PETE 220 | NO STATIONS EFFECTED | 5:31:38 (02.7.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1004 | 2-Jul-2022 | MYSURU | 66 | VAJAMANGALA-KADAKOLA1 | AYRALLI_66 MARADIHUNDI_66 | 5:25 | 5:31 | 0:06 | LINE FAULT |
| 1005 | 2-Jul-2022 | MYSURU | 66 | KUSHALNAGARA 220-PERIYAPATNA 2 | NO STATIONS EFFECTED | 11:29 | 11:38 | 0:09 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|---|--|--------------------------|-----------|----------|---------------------------------------|
| 1006 | 2-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1007 | 2-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26 (22/04/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1008 | 2-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1009 | 2-Jul-2022 | TUMKUR | 66 | TR1 | SASALUHALLA_66 | 13:00(28.06.20 22 | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1010 | 2-Jul-2022 | TUMKUR | 220 | BENKIKERE 220kV-HONNALLI LINE 2 | BENKIKERE_220 | 1:06 | 1:45 | 0:39 | LINE FAULT |
| 1011 | 2-Jul-2022 | TUMKUR | 220 | HONNALLI 220k-BENKIKERE-2 | BENKIKERE_220 | 0:48 | 1:00 | 0:11 | LINE FAULT |
| 1012 | 2-Jul-2022 | TUMKUR | 110 | TR-1 | HONNAVALLI_110 | 17:17 | 18:52 | 1:34 | LINE CLEAR AVAILED |
| 1013 | 2-Jul-2022 | TUMKUR | 66 | TR-2 | BEVINAHALLI_66 | 11:45 | 13:45 | 2:00 | LINE CLEAR AVAILED |
| 1014 | 2-Jul-2022 | TUMKUR | 66 | TR-1 & 2 | BHARAMAGIRI_66 | 8:15 | 8:45 | 0:30 | LINE CLEAR AVAILED |
| 1015 | 2-Jul-2022 | TUMKUR | 66 | BILCHODU-PALLAGATTE | PALLAGATTE_66 | 12:20 | 12:50 | 0:30 | MAIN SUPPLY FAILURE |
| 1016 | 2-Jul-2022 | TUMKUR | 66 | TR-1 | DASUDI_66 | 16:35 | 18:01 | 1:26 | LINE CLEAR AVAILED |
| 1017 | 2-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA(YARAGUNTA) | HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 11:22 | 11:34 | 0:12 | LINE FAULT |
| 1018 | 2-Jul-2022 | TUMKUR | 66 | DAVANGERE SRS- YARAGUNTA(HARIHARA) | YARAGUNTA_66, OBAJJIHALLI_66 | 19:26 | 19:41 | 0:14 | LINE FAULT |
| 1019 | 2-Jul-2022 | TUMKUR | 66 | HARIYABBE- CHIKKABANAGERE(P D KOTE) | HARIYABBE_66 | 10:52 | 17:40 | 6:48 | LINE CLEAR AVAILED |
| 1020 | 2-Jul-2022 | TUMKUR | 66 | HIRIYUR 220KV- MATHOD | MATHOD_66 | 5:48 | 5:56 | 0:08 | LINE FAULT |
| 1021 | 2-Jul-2022 | TUMKUR | 66 | TR-2 | HOLALKERE_66 | 11:10 | 11:13 | 0:03 | TRANSFORMER FAULT |
| 1022 | 2-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 9:35 | 9:40 | 0:04 | LINE FAULT |
| 1023 | 2-Jul-2022 | TUMKUR | 66 | HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR) | DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66 | 0:48 | 0:58 | 0:09 | LINE FAULT |
| 1024 | 2-Jul-2022 | TUMKUR | 66 | TR-2 | KOLALA_66 | 15:31 | 15:50 | 0:18 | LINE CLEAR AVAILED |
| 1025 | 2-Jul-2022 | TUMKUR | 66 | PDKOTE-AZURE SOLAR | AZURE SOLAR_66 | 10:49 | 17:46 | 6:56 | LINE CLEAR AVAILED |
| 1026 | 2-Jul-2022 | TUMKUR | 66 | PDKOTE-AZURE SOLAR | AZURE SOLAR_66 | 18:52 | 19:07 | 0:14 | LINE FAULT |
| 1027 | 2-Jul-2022 | TUMKUR | 66 | PDKOTE-CLEAR SOLAR | CLEAR SOLAR | 10:49 | 17:44 | 6:55 | LINE CLEAR AVAILED |
| 1028 | 2-Jul-2022 | TUMKUR | 66 | PDKOTE-CLEAR SOLAR | CLEAR SOLAR | 18:49 | 19:06 | 0:16 | LINE FAULT |
| 1029 | 2-Jul-2022 | TUMKUR | 66 | TR-1 | PDKOTE_66 | 10:49 | 17:41 | 6:51 | LINE CLEAR AVAILED |
| 1030 | 2-Jul-2022 | TUMKUR | 66 | TR-2 | PDKOTE_66 | 10:49 | 17:41 | 6:51 | LINE CLEAR AVAILED |
| 1031 | 2-Jul-2022 | TUMKUR | 66 | PDKOTE-HARIYABBE | PDKOTE_66 | 10:53 | 17:38 | 6:44 | LINE CLEAR AVAILED |
| 1032 | 2-Jul-2022 | TUMKUR | 66 | PDKOTE-HARIYABBE | PDKOTE_66 | 18:46 | 19:00 | 0:14 | LINE FAULT |
| 1033 | 2-Jul-2022 | TUMKUR | 66 | PDKOTE-SALOTOR SOLAR | SOLITAIRE SOLAR | 10:49 | 17:46 | 6:56 | LINE CLEAR AVAILED |
| 1034 | 2-Jul-2022 | TUMKUR | 66 | PDKOTE-SALOTOR SOLAR | SOLITAIRE SOLAR | 18:46 | 19:27 | 0:40 | LINE FAULT |
| 1035 | 3-Jul-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL_110 | 16:13 (04.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|-----------------------------|--|-----------------------|-----------------------|----------|---------------------------------------|
| 1036 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHVAR_110 | 17:55 (28.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1037 | 3-Jul-2022 | BAGALKOT | 110 | AMBEWADI- NK2(KAVALWADA) | STATION NOT AFFECTED AMBEWADI_220 | 8:55 (23.05.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 1038 | 3-Jul-2022 | BAGALKOT | 220 | SIRSI220-HUBLI1 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 1039 | 3-Jul-2022 | BAGALKOT | 220 | MUGALKHOD-CHIKKODI-2 | STATION NOT AFFECTED MUGALKHOD_220 | 16:29 (02.07.2022) | 14:18 (03.07.2022) | 21:49HRS | LINE CHARGED |
| 1040 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED BIJAPUR KIADB_110 | 17:34 | 17:46 | 0:12 | TRANSFORMER FAULT |
| 1041 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED BJCTY(THORVI)_110 | 12:10 | 12:11 | 0:01 | TRANSFORMER FAULT |
| 1042 | 3-Jul-2022 | BAGALKOT | 110 | DAMBAL-SUZLON-1 | SUZALON_110 STATION NOT AFFECTED DAMBAL_110 | 11:38 | 14:14 | 2:36 | LINE FAULT |
| 1043 | 3-Jul-2022 | BAGALKOT | 110 | MAHALINGAPUR220-HIDKAL | STATION NOT AFFECTED HIDKAL_110 | 6:40 | 15:17 | 8:37 | HAND TRIPPED |
| 1044 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED HIREMASALI_110 | 2:19 | 2:23 | 0:04 | TRANSFORMER FAULT |
| 1045 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED HIREMASALI_110 | 2:25 | 2:35 | 0:10 | TRANSFORMER FAULT |
| 1046 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED HIREMASALI_110 | 6:03 | 6:08 | 0:05 | TRANSFORMER FAULT |
| 1047 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV4 | STATION NOT AFFECTED HUKKERI_110 | 13:03 | 13:09 | 0:06 | TRANSFORMER FAULT |
| 1048 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED ITNAL_110 | 11:00 | 11:08 | 0:08 | TRANSFORMER FAULT |
| 1049 | 3-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV2 | STATION NOT AFFECTED JAMAKHANDI_110 | 14:22 | 19:10 | 4:48 | LINE CLEAR AVOIDED |
| 1050 | 3-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV1 | STATION NOT AFFECTED VAJARAMATTI_220 | 13:50 | 15:12 | 1:22 | TRANSFORMER FAULT |
| 1051 | 3-Jul-2022 | BAGALKOT | 220 | 220/110KV, HV2 | STATION NOT AFFECTED VAJARAMATTI_220 | 13:50 | 14:13 | 0:23 | TRANSFORMER FAULT |
| 1052 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV ,HV2 | TAKKALAKI_110 | 13:19 | 13:24 | 0:05 | TRANSFORMER FAULT |
| 1053 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV3 | SAVALAGI_110 | 10:01 | 13:39 | 3:38 | LINE CLEAR AVOIDED |
| 1054 | 3-Jul-2022 | BAGALKOT | 110 | RON-HIREHAL | RON_110 | 10:20 | 10:57 | 0:37 | HAND TRIPPED |
| 1055 | 3-Jul-2022 | BAGALKOT | 110 | MUNDARGI-VIJAY SUGARS | VIJAY SUGARS_IPP STATION NOT AFFECTED MUNDARGI_110 | 11:39 | 12:09 | 0:30 | LINE FAULT |
| 1056 | 3-Jul-2022 | BAGALKOT | 110 | MANTUR-NIRANI SUGARS | NIRANI SGARS_IPP_110 MANTUR(M)_110 | 15:09 | 15:18 | 0:09 | MAIN SUPPLY FAILURE |
| 1057 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | MALGHAN(B)_110 | 6:40 | 6:52 | 0:12 | TRANSFORMER FAULT |
| 1058 | 3-Jul-2022 | BAGALKOT | 110 | MAHALINGPUR220-HIDIKAL | STATION NOT AFFECTED HIDIKAL_110 | 6:09 | 14:43 | 8:34 | LINE FAULT |
| 1059 | 3-Jul-2022 | BAGALKOT | 110 | MAHALINGPUR220-HIDIKAL | STATION NOT AFFECTED HIDIKAL_110 | 14:43 | 15:14 | 0:31 | LINE CLEAR AVOIDED |
| 1060 | 3-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|-----------|---------|----------------------------------|--|-----------------------|-----------|----------|-------------------------------|
| 1061 | 3-Jul-2022 | BAGALKOT | 220 | SIRSI220-HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 1062 | 3-Jul-2022 | BAGALKOT | 110 | BELGAUM110-KANABARGI LAYOUT | STATION NOT AFFECTED BELGAUM_110 | 10:50 (26.03.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 1063 | 3-Jul-2022 | BAGALKOT | 110 | MANTUR-VAJRAMATTI 1& 2 | MANTUR_110 | 15:09 | 15:18 | 0:09 | MAIN SUPPLY FAILURE |
| 1064 | 3-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | MALGHAN(B)_110 | 13:00 | 13:05 | 0:05 | TRANSFORMER FAULT |
| 1065 | 3-Jul-2022 | BENGALURU | 66 | HV1 | BRINDAVANA 220 | 10:20 | 10:25 | 0:05 | LINE CLEAR AVOIDED |
| 1066 | 3-Jul-2022 | BENGALURU | 66 | HV2 | HULIMANGALA | 11:34 | 11:36 | 0:02 | LINE CLEAR AVOIDED |
| 1067 | 3-Jul-2022 | BENGALURU | 66 | SRS PEENYA 220 - BRINDAVANA | NO STATION AFFECTED | 17:20 | 18:45 | 1:25 | LINE FAULT |
| 1068 | 3-Jul-2022 | BENGALURU | 66 | CHINTAMANI 220 - SRINIVASPURA | KODIHALLI, SRINIVASPURA, YELDUR | 12:38 | 12:46 | 0:08 | LINE FAULT |
| 1069 | 3-Jul-2022 | BENGALURU | 220 | NELMANGALA 400 - DB PURA 2 | NO STATION AFFECTED | 17:36 | 20:23 | 2:47 | LINE FAULT |
| 1070 | 3-Jul-2022 | BENGALURU | 220 | NELMANGALA 400 - DB PURA 2 | NO STATION AFFECTED | 20:23 | 21:37 | 1:14 | LINE CLEAR AVOIDED |
| 1071 | 3-Jul-2022 | BENGALURU | 66 | WELCASTE STEEL - BMRCL(EHT) | BMRCL | 0:07 | 1:16 | 1:08 | LINE CLEAR AVOIDED |
| 1072 | 3-Jul-2022 | BENGALURU | 66 | VIDYANANGAR - HENNUR CROSS | NO STATION AFFECTED | 17:46 | 20:08 | 2:21 | LINE FAULT |
| 1073 | 3-Jul-2022 | BENGALURU | 66 | HV2 | MULBAGLU | 10:10 | 12:07 | 1:57 | LINE CLEAR AVOIDED |
| 1074 | 3-Jul-2022 | BENGALURU | 66 | HV2 | MULBAGLU | 12:07 | 12:25 | 0:18 | TRANSFORMER FAULT |
| 1075 | 3-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 1 | VATADOSANAHALLI | 18:51 | 19:02 | 0:11 | LINE FAULT |
| 1076 | 3-Jul-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2(DG3) | BELL CERAMICS (EHT), KONDASPURA | 16:39 | 16:53 | 0:14 | LINE FAULT |
| 1077 | 3-Jul-2022 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALNUR | 16:46 | 16:53 | 0:06 | LINE FAULT |
| 1078 | 3-Jul-2022 | BENGALURU | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 12:01 | 12:12 | 0:10 | LINE FAULT |
| 1079 | 3-Jul-2022 | BENGALURU | 66 | HV1 | GOWRIBIDANUR 220 | 15:47 | 16:01 | 0:14 | TRANSFORMER FAULT |
| 1080 | 3-Jul-2022 | GULBARGA | 400 | RTPS-MUNIRABAD | MUNIRABAD_400 | 10:04 (14.06.2022) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 1081 | 3-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/20 22) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 1082 | 3-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/20 22) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 1083 | 3-Jul-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR_11 0 | 11:30(23/06/20 22) | | | LINE OPEN, LINE CLEAR AVOIDED |
| 1084 | 3-Jul-2022 | GULBARGA | 110 | KADAGANCHI-KAPNOOR | KADAGANCHI_110,KBS_SOLA R_IPP | 15:39 | 15:56 | 0:17 | LINE CLEAR AVOIDED |
| 1085 | 3-Jul-2022 | GULBARGA | 110 | ADAVI AMARESHWAR- MALLAT | ADAVI AMRESHWAR_110,JAWALGER A_110 | 23:30 | 23:40 | 0:10 | MAIN SUPPLY FAILURE |
| 1086 | 3-Jul-2022 | GULBARGA | 110 | GURMITKAL-KONKAL | KONKAL_110 | 19:15 | 19:25 | 0:10 | LINE FAULT |
| 1087 | 3-Jul-2022 | GULBARGA | 110 | HANASI_66 | HANASI_66 | 7:05 | 7:10 | 0:05 | LINE CLEAR AVOIDED |
| 1088 | 3-Jul-2022 | GULBARGA | 110 | MALLAT-KONDAPURAM SOLAR_IPP | MALLAT_220 | 18:57 | 22:21 | 3:24 | LINE CLEAR AVOIDED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|----------------------------|--|-----------------------|-------------------|-----------|-------------------------------------|
| 1089 | 3-Jul-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 21:25 | 21:35 | 0:10 | LINE FAULT |
| 1090 | 3-Jul-2022 | GULBARGA | 110 | MALLAT-MADLAPUR | ADAVI AMARESHWAR_110 | 23:30 | 23:40 | 0:10 | LINE FAULT |
| 1091 | 3-Jul-2022 | GULBARGA | 110 | HALBARGA-KOLHAR1 | KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY | 18:52 | 19:01 | 0:09 | LINE FAULT |
| 1092 | 3-Jul-2022 | GULBARGA | 110 | HALBARGA-KOLHAR1 | KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY | 18:52 | 19:01 | 0:09 | LINE FAULT |
| 1093 | 3-Jul-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 15:42 | 15:56 | 0:14 | LINE CLEAR AVAILED |
| 1094 | 3-Jul-2022 | GULBARGA | 110 | RAICHUR-MALIYABAD | MALIYABAD_110,YERAGERA_110,VADAVATTI_110,YAPALDI_NNI_110 | 21:55 | 22:40 | 0:45 | LINE FAULT |
| 1095 | 3-Jul-2022 | GULBARGA | 110 | SEDAM-VICTSAGAR_IPP | VICATSAGARCEMNETS | 21:15 | 21:30 | 0:15 | LINE FAULT |
| 1096 | 3-Jul-2022 | GULBARGA | 110 | SEDAM-VICTSAGAR_IPP | VICATSAGARCEMNETS | 23:05 | 23:20 | 0:15 | LINE FAULT |
| 1097 | 3-Jul-2022 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 12:15 (29.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1098 | 3-Jul-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1099 | 3-Jul-2022 | HASSAN | 66 | HV2 | HASSAN_66 | 10:05 (6.06.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1100 | 3-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 13:12(18.06.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1101 | 3-Jul-2022 | HASSAN | 66 | BHADRA-SHMG2 | gen_bhadra | 16:40(01.07.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1102 | 3-Jul-2022 | HASSAN | 400 | HASSAN4-UPCL2 | HASSAN_400 | 23:59(03.07.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1103 | 3-Jul-2022 | HASSAN | 400 | UPCL-HASSAN2 | upcl_gen | 23:59(03.07.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1104 | 3-Jul-2022 | HASSAN | 110 | MOODAB-SOHAM2 | MOODABIDRE_110 | 1:02(02.07.2022) | 12:45(03.07.2022) | 35:42 hrs | LINE CHARGED |
| 1105 | 3-Jul-2022 | HASSAN | 220 | KEMAR-PUTUR2 | KEMAR_220 | 8:00 | 8:16 | 0:16 | LINE FAULT |
| 1106 | 3-Jul-2022 | HASSAN | 110 | MOODAB-SOHAM1 | MOODABIDRE_110 | 11:02 | 12:45 | 1:43 | LINE CLEAR AVAILED |
| 1107 | 3-Jul-2022 | HASSAN | 110 | HV1 | SHIKARIPURA_110 | 11:36 | 12:03 | 0:27 | LINE CLEAR AVAILED |
| 1108 | 3-Jul-2022 | HASSAN | 110 | HV2 | SHIKARIPURA_110 | 12:12 | 12:56 | 0:44 | LINE CLEAR AVAILED |
| 1109 | 3-Jul-2022 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPPA_220 | 9:35 | 18:31 | 8:56 | LINE CLEAR AVAILED |
| 1110 | 3-Jul-2022 | HASSAN | 66 | BELUR66-CKMGLR | BELUR_66 | 5:30 | 6:50 | 1:20 | MAIN SUPPLY FAILURE |
| 1111 | 3-Jul-2022 | HASSAN | 66 | HV2 | BELUR_66 | 5:30 | 6:50 | 1:20 | MAIN SUPPLY FAILURE |
| 1112 | 3-Jul-2022 | HASSAN | 66 | BELUR66-MUDIGERE | BELUR_66 | 5:30 | 6:50 | 1:20 | MAIN SUPPLY FAILURE |
| 1113 | 3-Jul-2022 | HASSAN | 66 | HV | CHIKABOMMENAHALLI_66 | 0:03 | 9:28 | 9:25 | TRANSFORMER FAULT |
| 1114 | 3-Jul-2022 | HASSAN | 66 | HNPR2-RNPR2 | HOLENARASIPURA_220 | 19:00 | 19:10 | 0:10 | LINE FAULT |
| 1115 | 3-Jul-2022 | MYSURU | 66 | VAJMANGALA-KADAKOLA 2 | NO STATIONS EFFECTED | 5:25 | 5:31 | 0:06 | LINE FAULT |
| 1116 | 3-Jul-2022 | MYSURU | 66 | HOOTGALLY-BEML | NO STATIONS EFFECTED | 10:27 | 17:11 | 6:44 | LINE CLEAR AVAILED |
| 1117 | 3-Jul-2022 | MYSURU | 66 | HOOTGALLY-HEBBAL | HEBBAL_66METAGALLY_66 | 11:15 | 16:15 | 5:00 | LINE CLEAR AVAILED |
| 1118 | 3-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-PERIYAPATNA 2 | BYLUKUPPE_66 | 11:28 | 11:37 | 0:09 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|---------|---------|------------------------------------|--|--------------------------|-----------|----------|---------------------------------------|
| 1119 | 3-Jul-2022 | MYSURU | 66 | HEBBANI-MEGHALAPURA | CHIDRAVALLI_66THUMBLA_6 66GARGESHWARI_66BGPURA_66 66VYSARAJAPURA_66BGPUR A_66PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66TNARASIPURA 66 | 6:11 | 6:25 | 0:14 | LINE FAULT |
| 1120 | 3-Jul-2022 | MYSURU | 66 | HV1 | BEGUR_66 | 11:04 | 11:15 | 0:11 | TRANSFORMER FAULT |
| 1121 | 3-Jul-2022 | MYSURU | 66 | 220 BEGUR-SINDHUVALLI | SINDHUVALLI_66 | 11:20 | 18:16 | 6:56 | LINE CLEAR AVAILED |
| 1122 | 3-Jul-2022 | MYSURU | 66 | NANJANGUDU-SINDHUVALLI | NO STATIONS EFFECTED | 10:51 | 15:28 | 4:36 | LINE CLEAR AVAILED |
| 1123 | 3-Jul-2022 | MYSURU | 66 | HV1 | KOLLEGALA_66 | 10:00 | 13:54 | 3:53 | LINE CLEAR AVAILED |
| 1124 | 3-Jul-2022 | MYSURU | 66 | HV2 | KOLLEGALA_66 | 14:02 | 17:05 | 3:02 | LINE CLEAR AVAILED |
| 1125 | 3-Jul-2022 | MYSURU | 66 | HV1 | NAGAMANGALA_66 | 14:10 | 14:25 | 0:15 | LINE CLEAR AVAILED |
| 1126 | 3-Jul-2022 | MYSURU | 66 | PERIYAPATNA-KUSHALNAGARA 1 | PERIYAPATNA_66KAMPLAPU RA_66HANAGODU_66PONNA MPET 66VIRAJPET 66 | 11:28 | 11:42 | 0:14 | LINE FAULT |
| 1127 | 3-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57 (31.5.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1128 | 3-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26 (22/04/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1129 | 3-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16:00 (08/12/2021) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1130 | 3-Jul-2022 | MYSURU | 220 | TUBINAKERE-KR PETE 220 | NO STATIONS EFFECTED | 5:31:38 (02.7.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1131 | 3-Jul-2022 | TUMKUR | 66 | TR1 | SASALUHALLA_66 | 13:00(28.06.20 22) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1132 | 3-Jul-2022 | TUMKUR | 220 | TR-2 | HIRIYUR_220 | 5:45 | 5:55 | 0:10 | TRANSFORMER FAULT |
| 1133 | 3-Jul-2022 | TUMKUR | 66 | TR-2 | BEVINAHALLI_66 | 11:33 | 12:29 | 0:55 | LINE CLEAR AVAILED |
| 1134 | 3-Jul-2022 | TUMKUR | 66 | TR-1 | BHARAMAGIRI_66 | 17:45 | 17:51 | 0:05 | LINE CLEAR AVAILED |
| 1135 | 3-Jul-2022 | TUMKUR | 66 | TR-2 | BHARAMAGIRI_66 | 17:46 | 17:51 | 0:05 | LINE CLEAR AVAILED |
| 1136 | 3-Jul-2022 | TUMKUR | 66 | TR-2 | BHARAMAGIRI_66 | 18:45 | 18:47 | 0:01 | TRANSFORMER FAULT |
| 1137 | 3-Jul-2022 | TUMKUR | 66 | BRAHMASANDRA-THOVINKERE | THOVINAKERE_66, KORA_66 | 10:49 | 11:34 | 0:44 | LINE CLEAR AVAILED |
| 1138 | 3-Jul-2022 | TUMKUR | 66 | BRAHMASANDRA-THOVINKERE | THOVINAKERE_66, KORA_66 | 13:09 | 14:57 | 1:48 | LINE CLEAR AVAILED |
| 1139 | 3-Jul-2022 | TUMKUR | 66 | HARIYABBE-CHIKKABANAGERE(P D KOTE) | HARIYABBE_66 | 10:06 | 19:00 | 8:53 | LINE CLEAR AVAILED |
| 1140 | 3-Jul-2022 | TUMKUR | 66 | TR-2 | HIRIYUR_220 | 5:45 | 5:58 | 0:13 | TRANSFORMER FAULT |
| 1141 | 3-Jul-2022 | TUMKUR | 66 | TR-2 | HIRIYUR_220 | 5:58 | 6:20 | 0:22 | TRANSFORMER FAULT |
| 1142 | 3-Jul-2022 | TUMKUR | 66 | HIRIYUR 220KV-RANGANATHPURA | RANGANATHAPURA_66 | 5:45 | 6:38 | 0:53 | LINE FAULT |
| 1143 | 3-Jul-2022 | TUMKUR | 66 | HIRIYUR 220KV-CHALLAKERE | CHALLAKERE_66, SANIKERE_66 | 5:45 | 6:38 | 0:53 | HAND TRIPPED |
| 1144 | 3-Jul-2022 | TUMKUR | 66 | HIRIYUR220kV-BEVINAHALLI | JAVAGONDANAHALLI_66, BEVINAHALLI 66 | 5:45 | 6:30 | 0:45 | HAND TRIPPED |
| 1145 | 3-Jul-2022 | TUMKUR | 66 | HIRIYUR 220KV- RKP2 | RKP2_IPP_66 | 5:45 | 6:38 | 0:53 | HAND TRIPPED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|--------------------------------|---|-----------------------|-----------------------|----------|------------------------------|
| 1146 | 3-Jul-2022 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | PANDRAHALLI2 | 4:20 | 4:25 | 0:04 | LINE FAULT |
| 1147 | 3-Jul-2022 | TUMKUR | 66 | TR-1 | KORA_66 | 15:20 | 17:35 | 2:14 | LINE CLEAR AVAIED |
| 1148 | 3-Jul-2022 | TUMKUR | 66 | TR-1 & 2 | KORA_66 | 11:10 | 15:20 | 4:10 | LINE CLEAR AVAIED |
| 1149 | 3-Jul-2022 | TUMKUR | 66 | KORA- ANTHRASANAHALLI | KORA_66 | 11:20 | 13:15 | 1:55 | LINE CLEAR AVAIED |
| 1150 | 3-Jul-2022 | TUMKUR | 66 | TR-2 | NAYAKANAHATTE_66 | 9:59 | 10:18 | 0:19 | TRANSFORMER FAULT |
| 1151 | 3-Jul-2022 | TUMKUR | 66 | PDKOTE-AZURE SOLAR | AZURE SOLAR_66 | 10:02 | 19:48 | 9:46 | LINE CLEAR AVAIED |
| 1152 | 3-Jul-2022 | TUMKUR | 66 | PDKOTE-CLEAR SOLAR | CLEAR SOLAR | 10:02 | 19:48 | 9:46 | LINE CLEAR AVAIED |
| 1153 | 3-Jul-2022 | TUMKUR | 66 | TR-1 | PDKOTE_66 | 10:02 | 19:02 | 8:59 | LINE CLEAR AVAIED |
| 1154 | 3-Jul-2022 | TUMKUR | 66 | TR-2 | PDKOTE_66 | 10:02 | 19:02 | 8:59 | LINE CLEAR AVAIED |
| 1155 | 3-Jul-2022 | TUMKUR | 66 | PDKOTE-HARIYABBE | PDKOTE_66 | 10:06 | 18:58 | 8:51 | LINE CLEAR AVAIED |
| 1156 | 3-Jul-2022 | TUMKUR | 66 | PDKOTE-SALOTOR SOLAR | SOLITAIRE SOLAR | 10:02 | 19:48 | 9:46 | LINE CLEAR AVAIED |
| 1157 | 3-Jul-2022 | TUMKUR | 66 | SIRA- MADHUGIRI 1 | BUKKAPATNA_66, KALLAMBELLA 66 | 12:10 | 12:18 | 0:07 | LOAD CURTAILMENT |
| 1158 | 3-Jul-2022 | TUMKUR | 66 | THALLAK 220KV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 9:43 | 9:56 | 0:13 | LINE FAULT |
| 1159 | 3-Jul-2022 | TUMKUR | 66 | THALLAK 220KV- WELSPUN SOLAR2 | WELSPUN SOLAR2 | 9:44 | 9:56 | 0:12 | LINE FAULT |
| 1160 | 4-Jul-2022 | BAGALKOT | 110 | PG HUNSHYAL-MUDALAGI (NAGANUR) | STATION NOT AFFECTED PG HUNSHYAL 110 | 16:13 (04.03.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 1161 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV2 | STATION NOT AFFECTED LAXMESHWAR 110 | 17:55 (28.04.2022) | 16:55 (04.07.2022) | 1607HRS | TRANSFORMER CHARGED |
| 1162 | 4-Jul-2022 | BAGALKOT | 110 | AMBEWADI- NK2(KAVALWADA) | STATION NOT AFFECTED AMBEWADI 220 | 8:55 (23.05.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 1163 | 4-Jul-2022 | BAGALKOT | 220 | SIRSI220-HUBLI1 | STATION NOT AFFECTED SIRSI 220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 1164 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | UAS DHARWAD_110 | 14:37 | 14:45 | 0:08 | TRANSFORMER FAULT |
| 1165 | 4-Jul-2022 | BAGALKOT | 110 | STPR-F2 (KABBUR) | SULTANPUR 110 | 11:04 | 11:27 | 0:23 | LINE CLEAR AVAIED |
| 1166 | 4-Jul-2022 | BAGALKOT | 110 | SIRSI-KUMATA2 | KUMATA_110 | 5:32 | 14:19 | 8:47 | LINE FAULT |
| 1167 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV,HV1 | SIRSI_110 | 18:15 | 18:27 | 0:12 | TRANSFORMER FAULT |
| 1168 | 4-Jul-2022 | BAGALKOT | 110 | RANEBENNUR-HIREKERUR | HIREKERUR_110 | 5:58 | 6:04 | 0:06 | LINE FAULT |
| 1169 | 4-Jul-2022 | BAGALKOT | 110 | MUNDARGI-VIJAYA SUGARS | MUNDARGI_110,VIJAYA SUGARS IPP | 12:30 | 12:45 | 0:15 | MAIN SUPPLY FAILURE |
| 1170 | 4-Jul-2022 | BAGALKOT | 110 | MUGLD-LN5(ITANAL) | ITANAL_110 | 18:22 | 18:59 | 0:37 | LINE FAULT |
| 1171 | 4-Jul-2022 | BAGALKOT | 110 | MLGHAN-MANALI SUGARS | MALGHAN(S) | 16:26 | 16:32 | 0:06 | LINE CLEAR AVAIED |
| 1172 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | MANTUR_110 | 14:40 | 14:53 | 0:13 | TRANSFORMER FAULT |
| 1173 | 4-Jul-2022 | BAGALKOT | 220 | 220/110/KV, HV2 | STATION NOT AFFECTED ATHANI 220 | 10:59 | 11:06 | 0:07 | TRANSFORMER FAULT |
| 1174 | 4-Jul-2022 | BAGALKOT | 110 | 220/110/KV, LV | STATION NOT AFFECTED ATHANI 220 | 10:59 | 11:07 | 0:08 | TRANSFORMER FAULT |
| 1175 | 4-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV1 | STATION NOT AFFECTED ATHANI 220 | 10:59 | 11:07 | 0:08 | TRANSFORMER FAULT |
| 1176 | 4-Jul-2022 | BAGALKOT | 110 | ATHANI220-AIGALI | AIGALI_110 | 10:59 | 11:08 | 0:09 | LINE FAULT |
| 1177 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED ATHANI 220 | 10:59 | 11:10 | 0:11 | TRANSFORMER FAULT |
| 1178 | 4-Jul-2022 | BAGALKOT | 110 | ATHANI220-SATTI | SATTI_110 | 10:59 | 11:09 | 0:10 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|-----------------------------------|--|-----------------------|-----------|----------|---------------------------------------|
| 1179 | 4-Jul-2022 | BAGALKOT | 110 | BAGALKOT220-KATARKI(NEERABUDIHAI) | NEERABUDIHAI_110 | 13:30 | 13:36 | 0:06 | HAND TRIPPED |
| 1180 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED BIJAPUR KIADB_110 | 18:22 | 18:28 | 0:06 | TRANSFORMER FAULT |
| 1181 | 4-Jul-2022 | BAGALKOT | 110 | GADAG220-DAMBAL | DAMBAL_110 | 12:22 | 12:23 | 0:01 | LINE FAULT |
| 1182 | 4-Jul-2022 | BAGALKOT | 110 | DAMBAL-ENERCON IPP | ENERCON IPP_110 DAMBAL_110 | 12:22 | 12:33 | 0:11 | HAND TRIPPED |
| 1183 | 4-Jul-2022 | BAGALKOT | 110 | DAMBAL-MUNDARGI-1&2 | MUNDARGI_110 | 12:22 | 12:25 | 0:03 | HAND TRIPPED |
| 1184 | 4-Jul-2022 | BAGALKOT | 110 | DAMBAL-SUZLON-1&2 | SUZLON_110 DAMBAL_110 | 12:22 | 12:25 | 0:03 | HAND TRIPPED |
| 1185 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV. HV2 | STATION NOT AFFECTED GOKAK_110 | 15:18 | 15:37 | 0:19 | TRANSFORMER FAULT |
| 1186 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV. HV1 | STATION NOT AFFECTED HATTARGI_110 | 6:24 | 6:45 | 0:21 | TRANSFORMER FAULT |
| 1187 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV. HV1 | STATION NOT AFFECTED HIREMASALI_110 | 15:49 | 15:53 | 0:04 | TRANSFORMER FAULT |
| 1188 | 4-Jul-2022 | BAGALKOT | 110 | ITNAL-HIDKAL(KABBUR3) | STATION NOT AFFECTED ITNAL_110 | 6:02 | 7:09 | 1:07 | LINE FAULT |
| 1189 | 4-Jul-2022 | BAGALKOT | 220 | CHIKKODI- KUDACHI-1 | STATION NOT AFFECTED CHIKKODI_220 | 10:22 | 20:05 | 9:43 | LINE CLEAR AVAILED |
| 1190 | 4-Jul-2022 | BAGALKOT | 220 | KUDUCHI-CHIKKODI-1 | STATION NOT AFFECTED KUDUCHI_220 | 10:22 | 20:05 | 9:43 | NFBC ISSUED |
| 1191 | 4-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV1 | STATION NOT AFFECTED KARWAR_220 | 12:10 | 12:53 | 0:43 | HAND TRIPPED |
| 1192 | 4-Jul-2022 | BAGALKOT | 110 | 220/110KV, LV2 | STATION NOT AFFECTED KARWAR_220 | 12:10 | 12:53 | 0:43 | HAND TRIPPED |
| 1193 | 4-Jul-2022 | BAGALKOT | 110 | KARWAR220-SOLARIS(BINAGA) | BINAGA_110 STATION NOT AFFECTED KARWAR_220 | 12:10 | 12:54 | 0:44 | HAND TRIPPED |
| 1194 | 4-Jul-2022 | BAGALKOT | 220 | NAGJHARI-AMBEWADI2 | STATION NOT AFFECTED AMBEWADI_220 | 12:04 | 13:07 | 1:03 | LINE FAULT |
| 1195 | 4-Jul-2022 | BAGALKOT | 110 | 110/33KV, HV3 | STATION NOT AFFECTED YELPARAHATTI_110 | 18:20 (21.04.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1196 | 4-Jul-2022 | BAGALKOT | 220 | SIRSI220-HUBLI2 | STATION NOT AFFECTED SIRSI_220 | 15:54 (23.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1197 | 4-Jul-2022 | BAGALKOT | 110 | BELGAUM110-KANABARGI LAYOUT | STATION NOT AFFECTED BELGAUM_110 | 10:50 (26.03.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1198 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED YARAGATTI_110 | 13:38 | 13:41 | 0:03 | LINE CLEAR AVAILED |
| 1199 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED YARAGATTI_110 | 14:00 | 14:12 | 0:12 | LINE CLEAR AVAILED |
| 1200 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED KATAKOL_110 | 15:06 | 16:19 | 1:13 | LINE CLEAR AVAILED |
| 1201 | 4-Jul-2022 | BAGALKOT | 110 | KARWAR220-ARGA | ARGA_110 | 12:04 | 12:15 | 0:11 | MAIN SUPPLY FAILURE |
| 1202 | 4-Jul-2022 | BAGALKOT | 110 | ARGA-ANKOLA | ANKOLA_110 | 12:04 | 12:15 | 0:11 | MAIN SUPPLY FAILURE |
| 1203 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | SINGATALUR_110 | 12:00 | 12:35:00 | 0:35:00 | MAIN SUPPLY FAILURE |
| 1204 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | SINGATALUR_110 | 12:00 | 12:35:00 | 0:35:00 | MAIN SUPPLY FAILURE |
| 1205 | 4-Jul-2022 | BAGALKOT | 110 | MUGALKHOD-ITNAL-3 | STATION NOT AFFECTED MUGALKHOD_220 | 18:22 | 19:00 | 0:38 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|-----------|---------|----------------------------------|---|-----------------------|-----------|----------|---------------------------------------|
| 1206 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED HALIYAL_110 | 11:30 (04.07.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1207 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV4 | STATION NOT AFFECTED HANGAL_110 | 17:00 | 17:05 | 0:05 | TRANSFORMER FAULT |
| 1208 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED UMMACHAGI_110 | 17:10 | 17:40 | 0:30 | LINE CLEAR AVAILED |
| 1209 | 4-Jul-2022 | BAGALKOT | 110 | ATHANI220- ATHANI | ATHANI_110 | 10:59 | 11:07 | 0:08 | MAIN SUPPLY FAILURE |
| 1210 | 4-Jul-2022 | BAGALKOT | 110 | ATHANI220- BALIGERI | BALIGERI_110 | 10:59 | 11:07 | 0:08 | MAIN SUPPLY FAILURE |
| 1211 | 4-Jul-2022 | BAGALKOT | 110 | ATHANI220- KARIMASUTI | KARIMASUTI_110 STATION NOT AFFECTED ATHANI_220 | 10:59 | 11:07 | 0:08 | MAIN SUPPLY FAILURE |
| 1212 | 4-Jul-2022 | BAGALKOT | 110 | ATHANI220-HALIYAL | HALIYAL_110 | 10:59 | 11:07 | 0:08 | MAIN SUPPLY FAILURE |
| 1213 | 4-Jul-2022 | BAGALKOT | 110 | ATHANI220-KSSKN | KSSKN_110 STATION NOT AFFECTED ATHANI_220 | 10:59 | 11:07 | 0:08 | MAIN SUPPLY FAILURE |
| 1214 | 4-Jul-2022 | BAGALKOT | 110 | DAMBAL-AKHILAGYA SOLAR | AKHILAGYA SOLAR_110 DAMBAL_110 | 12:22 | 12:25 | 0:03 | HAND TRIPPED |
| 1215 | 4-Jul-2022 | BAGALKOT | 110 | SAMBAPUR-DAMBAL | DAMBAL_110 | 12:22 | 12:23 | 0:01 | LINE FAULT |
| 1216 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED KALADGI_110 | 11:45 | 16:55 | 5:10 | LINE CLEAR AVAILED |
| 1217 | 4-Jul-2022 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED KALADGI_110 | 11:45 | 14:10 | 2:25 | LINE CLEAR AVAILED |
| 1218 | 4-Jul-2022 | BENGALURU | 66 | HV5 | NRS 220 | 10:15 | 14:08 | 3:53 | LINE CLEAR AVAILED |
| 1219 | 4-Jul-2022 | BENGALURU | 66 | HV4 | NRS 220 | 12:10 | 12:14 | 0:04 | LOAD CHANGE OVER |
| 1220 | 4-Jul-2022 | BENGALURU | 66 | HV4 | NRS 220 | 22:12 | 22:22 | 0:10 | LOAD CHANGE OVER |
| 1221 | 4-Jul-2022 | BENGALURU | 66 | RR NAGAR - VRISHABHAVATHI 220 | RR NAGAR | 11:30 | 11:35 | 0:05 | LOAD CHANGE OVER |
| 1222 | 4-Jul-2022 | BENGALURU | 66 | RR NAGAR - SUBRAMANYAPURA | RR NAGAR | 22:18 | 22:22 | 0:04 | LOAD CHANGE OVER |
| 1223 | 4-Jul-2022 | BENGALURU | 66 | HV2 | VIJAYANAGARA | 12:05 | 12:08 | 0:03 | LOAD CHANGE OVER |
| 1224 | 4-Jul-2022 | BENGALURU | 66 | HV2 | VIJAYANAGARA | 22:06 | 22:11 | 0:05 | LOAD CHANGE OVER |
| 1225 | 4-Jul-2022 | BENGALURU | 66 | HV1 | VIJAYANAGARA | 12:05 | 12:08 | 0:03 | LOAD CHANGE OVER |
| 1226 | 4-Jul-2022 | BENGALURU | 66 | HV1 | VIJAYANAGARA | 22:06 | 22:11 | 0:05 | LOAD CHANGE OVER |
| 1227 | 4-Jul-2022 | BENGALURU | 66 | HV3 | YARANDANAHALLI 220 | 16:59 | 17:07 | 0:08 | TRANSFORMER FAULT |
| 1228 | 4-Jul-2022 | BENGALURU | 66 | HV2 | BANGARPETE | 16:08 | 16:44 | 0:36 | LINE CLEAR AVAILED |
| 1229 | 4-Jul-2022 | BENGALURU | 66 | HV2 | CHANDAPURA | 17:19 | 20:38 | 3:19 | LINE CLEAR AVAILED |
| 1230 | 4-Jul-2022 | BENGALURU | 66 | HV3 | CHIKKABALLAPURA IND AREA | 16:28 | 16:49 | 0:21 | LINE CLEAR AVAILED |
| 1231 | 4-Jul-2022 | BENGALURU | 66 | HV2 | MANCHENAHALLI | 16:01 | 16:47 | 0:45 | LINE CLEAR AVAILED |
| 1232 | 4-Jul-2022 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2(DG3) | BELL CERAMICS (EHT), KONDASPURA | 11:30 | 11:46 | 0:16 | LINE FAULT |
| 1233 | 4-Jul-2022 | BENGALURU | 66 | KOLAR 220 - SRINIVASAPURA | MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR | 11:14 | 11:57 | 0:43 | LINE CLEAR AVAILED |
| 1234 | 4-Jul-2022 | BENGALURU | 220 | DB PURA 220 - NELAMANGALA 1 | NO STATION AFFECTED | 12:20 | 14:55 | 2:35 | LINE CLEAR AVAILED |
| 1235 | 4-Jul-2022 | BENGALURU | 66 | YELAHANKA 220 - LINE6 | SOLDEVANAHALLI | 7:58 | 8:17 | 0:18 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|-----------|---------|------------------------------------|---|-----------------------|-----------|----------|-------------------------------|
| 1236 | 4-Jul-2022 | BENGALURU | 66 | SOMENAHALLI - AFTL (IPP) | NO STATION AFFECTED | 16:11 | 16:15 | 0:03 | LINE FAULT |
| 1237 | 4-Jul-2022 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 2 | BAGEPALLI | 16:11 | 16:18 | 0:07 | LINE FAULT |
| 1238 | 4-Jul-2022 | BENGALURU | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 11:47 | 12:13 | 0:26 | LINE CLEAR AVAILED |
| 1239 | 4-Jul-2022 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NO STATION AFFECTED | 19:01 | 19:11 | 0:09 | LINE FAULT |
| 1240 | 4-Jul-2022 | BENGALURU | 66 | HV2 | MULABAGALU | 15:43 | 16:00 | 0:17 | LINE CLEAR AVAILED |
| 1241 | 4-Jul-2022 | BENGALURU | 66 | KIADB HARDWARE PARK 220 - BPH(EHT) | BPH(EHT) | 12:09 | 14:05 | 1:55 | LINE CLEAR AVAILED |
| 1242 | 4-Jul-2022 | BENGALURU | 66 | MAGADI 220 - MAGADI 66 | MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE | 10:58 | 12:26 | 1:28 | LINE CLEAR AVAILED |
| 1243 | 4-Jul-2022 | GULBARGA | 400 | RTPS-MUNIRABAD | MUNIRABAD_400 | 10:04 (14.06.2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1244 | 4-Jul-2022 | GULBARGA | 220 | HV1 | ITTAGI_220 | 11:30 | 17:50 | 6:20 | LINE CLEAR AVAILED |
| 1245 | 4-Jul-2022 | GULBARGA | 220 | MALLAT-RTPS3 | MALLAT_220 | 0:05 | 0:18 | 0:13 | LINE FAULT |
| 1246 | 4-Jul-2022 | GULBARGA | 220 | SHAHABAD-KAPNOOR | KAPNOOR_220 | 0:27 | 0:48 | 0:21 | LINE FAULT |
| 1247 | 4-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR1 | JEWARGI_110 | 12:15(15/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1248 | 4-Jul-2022 | GULBARGA | 110 | SHAHABAD-RAICHUR2 | NALWAR_110 | 15:10(14/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1249 | 4-Jul-2022 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR_110 | 11:30(23/06/2022) | | | LINE OPEN, LINE CLEAR AVAILED |
| 1250 | 4-Jul-2022 | GULBARGA | 110 | HV1 | YERAGERA_110 | 9:20 | 16:35 | 7:15 | LINE CLEAR AVAILED |
| 1251 | 4-Jul-2022 | GULBARGA | 110 | HV2 | YERAGERA_110 | 12:40 | 16:35 | 3:55 | LINE CLEAR AVAILED |
| 1252 | 4-Jul-2022 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 15:20 | 15:27 | 0:07 | TRANSFORMER FAULT |
| 1253 | 4-Jul-2022 | GULBARGA | 110 | HV2 | SREERAMANAGAR_110 | 17:45 | 17:55 | 0:10 | TRANSFORMER FAULT |
| 1254 | 4-Jul-2022 | GULBARGA | 110 | AURAD-SANTHAPUR | AURAD_110,DONGARGOA_110 | 3:40 | 6:00 | 2:20 | MAIN SUPPLY FAILURE |
| 1255 | 4-Jul-2022 | GULBARGA | 110 | AURAD-SANTHAPUR | AURAD_110,DONGARGOA_110 | 12:25 | 12:45 | 0:20 | LINE CLEAR AVAILED |
| 1256 | 4-Jul-2022 | GULBARGA | 110 | LADHA-SASTHAPUR | LADHA_110 | 13:15 | 13:25 | 0:10 | MAIN SUPPLY FAILURE |
| 1257 | 4-Jul-2022 | GULBARGA | 110 | NALWAR-SHAHABAD(SHAHAPUR)2 | JEWARAGI_110 | 4:50 | 6:35 | 1:45 | LINE FAULT |
| 1258 | 4-Jul-2022 | GULBARGA | 110 | ADAVI AMARESHWAR-JAWALGERA | ADAVI AMRESHWAR_110 | 13:17 | 13:28 | 0:11 | LINE FAULT |
| 1259 | 4-Jul-2022 | GULBARGA | 110 | YAKATAPUR-KAMTHANA | YAKATAPUR_110 | 1:15 | 1:20 | 0:05 | MAIN SUPPLY FAILURE |
| 1260 | 4-Jul-2022 | GULBARGA | 110 | GURMITKAL-SEDAM | GURMITKAL_110 | 17:45 | 17:55 | 0:10 | LINE FAULT |
| 1261 | 4-Jul-2022 | GULBARGA | 110 | TEKKALAKOTE-RNWSLR | TEKKALAKOTE_110 | 18:25 | 21:40 | 3:15 | LINE CLEAR AVAILED |
| 1262 | 4-Jul-2022 | GULBARGA | 110 | HALBARGA-HALLIKHED | HALLIKHED_110 | 6:52 | 7:01 | 0:09 | LINE FAULT |
| 1263 | 4-Jul-2022 | GULBARGA | 110 | SEDAM-CHINCHOLI | CHINCHOLI_110 | 2:45 | 3:00 | 0:15 | LINE FAULT |
| 1264 | 4-Jul-2022 | GULBARGA | 110 | HUMNABAD-HALBARGA | HALBARGA_110 | 1:06 | 1:13 | 0:07 | LINE FAULT |
| 1265 | 4-Jul-2022 | GULBARGA | 110 | HUMNABAD-ALAND | ALAND_110,KADAGANCHI_110 | 18:45 | 19:05 | 0:20 | LINE FAULT |
| 1266 | 4-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110 | 4:48 | 4:53 | 0:05 | LINE FAULT |
| 1267 | 4-Jul-2022 | GULBARGA | 110 | SHAHAPUR-YADGIR | YADGIR_110 | 21:49 | 21:58 | 0:09 | LINE FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|----------|---------|---------------------|---|-------------------|-------------------|-----------|-------------------------------------|
| 1268 | 4-Jul-2022 | GULBARGA | 110 | SHAHAPUR-SHAHAPUR2 | SHAHAPUR_110 | 14:44 | 17:58 | 3:14 | LINE CLEAR AVAILED |
| 1269 | 4-Jul-2022 | GULBARGA | 110 | KAPNOOR-ALAND | ALAND_110,KADGANCHI_110 | 18:48 | 18:56 | 0:08 | LINE FAULT |
| 1270 | 4-Jul-2022 | GULBARGA | 110 | KUSTAGI-TAVARGERA | TAVARGERA_110 | 9:56 | 13:03 | 3:07 | LINE CLEAR AVAILED |
| 1271 | 4-Jul-2022 | GULBARGA | 110 | RAICHUR-SHAHAPUR2 | SHAHAPUR2_110 | 0:02 | 0:05 | 0:03 | LINE FAULT |
| 1272 | 4-Jul-2022 | GULBARGA | 110 | MALLAT-SIRWAR | SIRWAR_110 | 23:51 | 0:00 | 0:09 | LINE FAULT |
| 1273 | 4-Jul-2022 | GULBARGA | 66 | LV1 | ITTAGI_220 | 5:30 | 5:36 | 0:06 | TRANSFORMER FAULT |
| 1274 | 4-Jul-2022 | GULBARGA | 66 | HALVAGALU-HARVI | HARVI_66 | 12:40 | 12:45 | 0:05 | LINE CLEAR AVAILED |
| 1275 | 4-Jul-2022 | GULBARGA | 66 | ITTAGI-TAMBRAHALLI | HAMPASAGAR_66,MORGERE_66,TAMBRAHALLI_66 | 5:08 | 5:13 | 0:05 | LINE FAULT |
| 1276 | 4-Jul-2022 | GULBARGA | 66 | BENNEHALLI-KOTTUR | KOTTUR_66 | 12:45 | 12:50 | 0:05 | LINE CLEAR AVAILED |
| 1277 | 4-Jul-2022 | HASSAN | 110 | HV3 | JOG_110 | 10:55(05.04.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1278 | 4-Jul-2022 | HASSAN | 66 | HV2 | HASSAN_66 | 10:05(6.06.2022) | | | TRANSFORMER OPEN,LINE CLEAR AVAILED |
| 1279 | 4-Jul-2022 | HASSAN | 110 | HV2 | KARAYA_110 | 13:12(18.06.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1280 | 4-Jul-2022 | HASSAN | 400 | HASSAN4-UPCL2 | HASSAN_400 | 23:59(03.07.2022) | 6:18(4.07.2022) | 6:18 hrs | LINE CHARGED |
| 1281 | 4-Jul-2022 | HASSAN | 66 | BHADRA-SHMG A 1 | gen_bhadra | 16:40(01.07.2022) | 13:14(04.07.2022) | 20:33 hrs | LINE CHARGED |
| 1282 | 4-Jul-2022 | HASSAN | 400 | UPCL-HASSAN2 | gen_upcl | 23:59(03.07.2022) | 6:18(4.07.2022) | 6:18 hrs | LINE CHARGED |
| 1283 | 4-Jul-2022 | HASSAN | 220 | MRSSHM-SHARAVATHY3 | MRSMSG_220 | 10:21 | 10:45 | 0:24 | LINE FAULT |
| 1284 | 4-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIMOGA3 | gen_sharavaty | 10:21 | 10:46 | 0:25 | LINE FAULT |
| 1285 | 4-Jul-2022 | HASSAN | 220 | SHRAVTY-SHIRALKOPPA | gen_sharavaty | 10:47 | 16:51 | 6:04 | LINE CLEAR AVAILED |
| 1286 | 4-Jul-2022 | HASSAN | 220 | SHRLKP-SGS | SHIRALKOPPA_220 | 10:43 | 16:52 | 6:09 | LINE CLEAR AVAILED |
| 1287 | 4-Jul-2022 | HASSAN | 110 | BAIKAMP-KAVOOR | BAIKAMPADY_110 | 13:35 | 16:15 | 2:40 | MAIN SUPPLY FAILURE |
| 1288 | 4-Jul-2022 | HASSAN | 110 | KAVOOR-BAIKAMPADI | KAVOOR_220 | 13:35 | 16:15 | 2:40 | LINE FAULT |
| 1289 | 4-Jul-2022 | HASSAN | 110 | HV2 | NAVUNDA_110 | 23:18 | 23:45 | 0:27 | TRANSFORMER FAULT |
| 1290 | 4-Jul-2022 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPA_220 | 13:17 | 13:35 | 0:18 | LINE FAULT |
| 1291 | 4-Jul-2022 | HASSAN | 66 | HV4 | BALEHONNUR_66 | 23:06 | 23:43 | 0:37 | TRANSFORMER FAULT |
| 1292 | 4-Jul-2022 | HASSAN | 66 | HV1 | gen_bhadra | 16:20 | 21:13 | 4:53 | MAIN SUPPLY FAILURE |
| 1293 | 4-Jul-2022 | HASSAN | 66 | DODDAKAD-HNPURA | DODDAKADNUR_66 | 16:20 | 21:10 | 4:50 | MAIN SUPPLY FAILURE |
| 1294 | 4-Jul-2022 | HASSAN | 66 | HV1 | DODDAKADNUR_66 | 16:20 | 21:10 | 4:50 | MAIN SUPPLY FAILURE |
| 1295 | 4-Jul-2022 | HASSAN | 66 | DODDAKAD-KRNAGARA | DODDAKADNUR_66 | 16:20 | 21:11 | 4:51 | MAIN SUPPLY FAILURE |
| 1296 | 4-Jul-2022 | HASSAN | 66 | HNPR2-MYSOR1 | HNPURA_220 | 16:02 | 21:01 | 4:59 | LINE CLEAR AVAILED |
| 1297 | 4-Jul-2022 | HASSAN | 66 | HNPR2-MYSOR2 | HNPURA_220 | 16:02 | 21:01 | 4:59 | LINE CLEAR AVAILED |
| 1298 | 4-Jul-2022 | HASSAN | 66 | HV2 | KANDDLI_66 | 12:15 | 12:50 | 0:35 | LINE CLEAR AVAILED |
| 1299 | 4-Jul-2022 | HASSAN | 66 | HV1 CB | NAGARTHI_66 | 16:39 | 21:11 | 4:32 | MAIN SUPPLY FAILURE |
| 1300 | 4-Jul-2022 | HASSAN | 66 | NGRTHI-L1 | NAGARTHI_66 | 16:39 | 21:10 | 4:31 | MAIN SUPPLY FAILURE |
| 1301 | 4-Jul-2022 | HASSAN | 66 | NGRTHI-L2 | NAGARTHI_66 | 16:40 | 21:24 | 4:44 | MAIN SUPPLY FAILURE |
| 1302 | 4-Jul-2022 | HASSAN | 66 | HV1 | SAKALESHPURA_66 | 1:20 | 1:32 | 0:12 | TRANSFORMER FAULT |
| 1303 | 4-Jul-2022 | HASSAN | 66 | HV1 | SAKALESHPURA_66 | 1:45 | 1:58 | 0:13 | TRANSFORMER FAULT |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|---------|---------|-----------------------------|--|---------|-----------|----------|---------------------|
| 1304 | 4-Jul-2022 | HASSAN | 66 | HV2 | SAKALESH PURA_66 | 4:37 | 4:50 | 0:13 | TRANSFORMER FAULT |
| 1305 | 4-Jul-2022 | MYSURU | 66 | HOOTGALLY-ELAWALA | NO STATIONS EFFECTED | 10:13 | 18:11 | 7:58 | NFBC ISSUED |
| 1306 | 4-Jul-2022 | MYSURU | 66 | HOOTGALLY-DATTGALLY | NO STATIONS EFFECTED | 14:45 | 17:05 | 2:20 | NFBC ISSUED |
| 1307 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-PERİYAPATNA1 | PONNAMPET_66VIRAJPET_66 KAMPLAPURA_66HANAGODU 66PERİYAPATNA 66 | 6:10 | 6:25 | 0:15 | LINE FAULT |
| 1308 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-PERİYAPATNA2 | BYLUKUPPE_66 | 6:10 | 6:25 | 0:15 | LINE FAULT |
| 1309 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-PERİYAPATNA 1 | NO STATIONS EFFECTED | 9:16 | 12:06 | 2:50 | LINE CLEAR AVAILED |
| 1310 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-PERİYAPATNA2 | BYLUKUPPE_66 | 6:58 | 7:22 | 0:24 | LINE FAULT |
| 1311 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-PERİYAPATNA2 | BYLUKUPPE_66 | 7:24 | 12:06 | 4:42 | LINE FAULT |
| 1312 | 4-Jul-2022 | MYSURU | 66 | PERİYAPATNA-KUSHANAGARA 1 | PONNAMPET_66VIRAJPET_66 KAMPLAPURA_66HANAGODU 66PERİYAPATNA 66 | 6:57 | 7:34 | 0:37 | LINE FAULT |
| 1313 | 4-Jul-2022 | MYSURU | 66 | PERİYAPATNA-HANGUDU | HANAGODU_66PONNAMPET 66VIRAJPET 66 | 0:09 | 0:28 | 0:19 | LINE FAULT |
| 1314 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-RAMANATHAPURA1 | KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA 66 | 6:25 | 6:34 | 0:09 | LINE FAULT |
| 1315 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-RAMANATHAPURA1 | KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA 66 | 19:30 | 19:36 | 0:06 | LINE FAULT |
| 1316 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-MERCERA | NO STATIONS EFFECTED | 20:10 | 20:15 | 0:05 | LINE FAULT |
| 1317 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-MERCERA | NO STATIONS EFFECTED | 20:15 | 20:42 | 0:27 | LINE FAULT |
| 1318 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-MERCERA | NO STATIONS EFFECTED | 20:44 | 21:15 | 0:31 | HAND TRIPPED |
| 1319 | 4-Jul-2022 | MYSURU | 66 | SUNTIKOPPA-MADIKERI | MADIKERI_66 | 20:05 | 20:22 | 0:17 | LINE FAULT |
| 1320 | 4-Jul-2022 | MYSURU | 66 | SUNTIKOPPA-MADIKERI | MADIKERI_66 | 20:23 | 22:13 | 1:50 | LINE FAULT |
| 1321 | 4-Jul-2022 | MYSURU | 66 | SUNTIKOPPA-MADIKERI | MADIKERI_66 | 22:14 | 23:00 | 0:46 | LINE FAULT |
| 1322 | 4-Jul-2022 | MYSURU | 66 | SUNTIKOPPA-MADIKERI | MADIKERI_66 | 23:28 | 23:54 | 0:26 | HAND TRIPPED |
| 1323 | 4-Jul-2022 | MYSURU | 66 | KR PETE 220-KR PETE1 | NO STATIONS EFFECTED | 11:04 | 11:17 | 0:12 | LINE FAULT |
| 1324 | 4-Jul-2022 | MYSURU | 66 | KR PETE 66-HUYGONAHALLI 2 | KRPET_66 AKKIHEBBAL_66 KIKKERI 66 | 11:04 | 11:16 | 0:12 | LINE FAULT |
| 1325 | 4-Jul-2022 | MYSURU | 66 | AKKIHEBBAL-HV2 | AKKIHEBBAL_66 | 14:47 | 16:39 | 1:52 | LINE CLEAR AVAILED |
| 1326 | 4-Jul-2022 | MYSURU | 66 | HV1 | HAMPAPURA_66 | 11:04 | 13:00 | 1:55 | LINE CLEAR AVAILED |
| 1327 | 4-Jul-2022 | MYSURU | 66 | HV2 | HAMPAPURA_66 | 12:54 | 14:44 | 1:50 | LINE CLEAR AVAILED |
| 1328 | 4-Jul-2022 | MYSURU | 66 | HV1 | HAMPAPURA_66 | 13:36 | 13:38 | 0:02 | TRANSFORMER FAULT |
| 1329 | 4-Jul-2022 | MYSURU | 66 | KIRUGAVALU-MALIYUR | NO STATIONS EFFECTED | 6:56 | 7:06 | 0:10 | LINE FAULT |
| 1330 | 4-Jul-2022 | MYSURU | 66 | HV1 | MADIKERI_66 | 10:50 | 16:30 | 5:40 | LINE CLEAR AVAILED |
| 1331 | 4-Jul-2022 | MYSURU | 66 | HV1 | MANDGERE_66 | 16:05 | 21:27 | 5:22 | MAIN SUPPLY FAILURE |
| 1332 | 4-Jul-2022 | MYSURU | 66 | RK NAGARA-DATTAGALLI | DATAGALLI_66 | 10:28 | 16:08 | 5:39 | NFBC ISSUED |
| 1333 | 4-Jul-2022 | MYSURU | 66 | RK NAGARA-DATTAGALLI | DATAGALLI_66 | 16:30 | 17:29 | 0:59 | NFBC ISSUED |
| 1334 | 4-Jul-2022 | MYSURU | 66 | HV2 | THALAKADU_66 | 11:43 | 13:17 | 1:34 | LINE CLEAR AVAILED |
| 1335 | 4-Jul-2022 | MYSURU | 66 | HV1 | THALAKADU_66 | 13:20 | 16:00 | 2:40 | LINE CLEAR AVAILED |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|---------|---------|--|--|-------------------------|------------------------|----------|---------------------------------------|
| 1336 | 4-Jul-2022 | MYSURU | 66 | VAJMANGALA-HEBBANI | NO STATIONS EFFECTED | 23:33 | 23:38 | 0:05 | LINE FAULT |
| 1337 | 4-Jul-2022 | MYSURU | 220 | BEGUR 220 -HV 2 | NO STATIONS EFFECTED | 15:40 | 16:54 | 1:14 | LINE CLEAR AVAIED |
| 1338 | 4-Jul-2022 | MYSURU | 66 | HV2 | DMG_HALLI_66 | 11:45 | 13:20 | 1:35 | LINE CLEAR AVAIED |
| 1339 | 4-Jul-2022 | MYSURU | 220 | HV2 | MADHUVANAHALLI_220 | 18:57:18 (31.5.2022) | | | TRANSFORMER OPEN,TRANSFORMER FAULT |
| 1340 | 4-Jul-2022 | MYSURU | 66 | HEBBANI-VAJAMANGALA | NO STATIONS EFFECTED | 18:26 (22/04/2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 1341 | 4-Jul-2022 | MYSURU | 66 | HEBBANI-MADHUVANAHLLI | NO STATIONS EFFECTED | 15:16(08/12/20 21) | | | LINE OPEN, LINE CLEAR AVAIED |
| 1342 | 4-Jul-2022 | MYSURU | 220 | TUBINAKERE-KR PETE 220 | NO STATIONS EFFECTED | 5:31:38 (02.7.2022) | 15:24:04 (4.7.2022) | 57:26HRS | LINE CHARGED |
| 1343 | 4-Jul-2022 | MYSURU | 66 | KUSHALNAGARA-MERCERA | NO STATIONS EFFECTED | 22:09:00 (4.7.2022) | | | LINE OPEN, LINE CLEAR AVAIED |
| 1344 | 4-Jul-2022 | TUMKUR | 66 | TR1 | SASALUHALLA_66 | 13:00(28.06.20 22) | | | TRANSFORMER OPEN,LINE CLEAR AVAIED |
| 1345 | 4-Jul-2022 | TUMKUR | 220 | TR1 | KIADB V N PURA_220 | 10:57 | 14:05 | 3:08 | LINE CLEAR AVAIED |
| 1346 | 4-Jul-2022 | TUMKUR | 220 | TR1 | PAVAGADA_220 | 6:09 | 6:18 | 0:08 | TRANSFORMER FAULT |
| 1347 | 4-Jul-2022 | TUMKUR | 220 | TR-2 | PAVAGADA_220 | 6:09 | 6:19 | 0:10 | TRANSFORMER FAULT |
| 1348 | 4-Jul-2022 | TUMKUR | 110 | TR-1 | HONNAVALLI_110 | 13:40 | 17:22 | 3:42 | LINE CLEAR AVAIED |
| 1349 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | BHARAMAGIRI_66 | 7:17 | 7:25 | 0:07 | TRANSFORMER FAULT |
| 1350 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | BHARAMAGIRI_66 | 17:21 | 17:26 | 0:05 | TRANSFORMER FAULT |
| 1351 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | BHARAMAGIRI_66 | 23:18 | 23:38 | 0:19 | TRANSFORMER FAULT |
| 1352 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | BHARAMAGIRI_66 | 23:38 | 23:50 | 0:11 | TRANSFORMER FAULT |
| 1353 | 4-Jul-2022 | TUMKUR | 66 | TR-2 | BILCHODU_66 | 11:30 | 11:40 | 0:10 | TRANSFORMER FAULT |
| 1354 | 4-Jul-2022 | TUMKUR | 66 | BRAHMASANDRA- THOVINKERE | THOVINAKERE_66, KORA_66 | 14:08 | 14:10 | 0:01 | HAND TRIPPED |
| 1355 | 4-Jul-2022 | TUMKUR | 66 | TR-2 | BUKKAPATNA_66 | 12:15 | 12:40 | 0:25 | LINE CLEAR AVAIED |
| 1356 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | BUKKAPATNA_66 | 11:50 | 12:15 | 0:25 | LINE CLEAR AVAIED |
| 1357 | 4-Jul-2022 | TUMKUR | 66 | BUKKAPATNA-GOLDEN HATCHERIES IPP_66 | GOLDEN HATCHERIES_IPP_66 | 11:00 | 12:15 | 1:15 | LINE CLEAR AVAIED |
| 1358 | 4-Jul-2022 | TUMKUR | 66 | TR-2 | CHANNAGIRI_66 | 13:39 | 13:48 | 0:09 | LINE CLEAR AVAIED |
| 1359 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | CHITRADURGA_66 | 21:41 | 21:57 | 0:15 | TRANSFORMER FAULT |
| 1360 | 4-Jul-2022 | TUMKUR | 66 | TR-2 | HALURAMESWARA_66 | 12:33 | 17:43 | 5:10 | LINE CLEAR AVAIED |
| 1361 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | HALURAMESWARA_66 | 12:33 | 13:12 | 0:39 | LINE CLEAR AVAIED |
| 1362 | 4-Jul-2022 | TUMKUR | 66 | HARIYABBE- CHIKKABANAGERE(P D KOTE) | HARIYABBE_66 | 10:13 | 18:38 | 8:25 | LINE CLEAR AVAIED |
| 1363 | 4-Jul-2022 | TUMKUR | 66 | TR-2 | HIREHALLI_66 | 8:26 | 8:32 | 0:06 | LINE CLEAR AVAIED |
| 1364 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | HIREHALLI_66 | 8:26 | 8:32 | 0:06 | LINE CLEAR AVAIED |
| 1365 | 4-Jul-2022 | TUMKUR | 66 | TR-2 | HOLALKERE_66 | 18:20 | 18:27 | 0:06 | TRANSFORMER FAULT |
| 1366 | 4-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 6:08 | 6:16 | 0:07 | LINE FAULT |
| 1367 | 4-Jul-2022 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 11:42 | 12:02 | 0:20 | LINE FAULT |
| 1368 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | KDBVNP_220 | 10:56 | 14:08 | 3:11 | LINE CLEAR AVAIED |
| 1369 | 4-Jul-2022 | TUMKUR | 66 | KORA- BRAHMASANDRA | KORA_66, BRAHMASANDRA_66, THOVINAKERE_66 | 13:57 | 14:11 | 0:14 | MAIN SUPPLY FAILURE |

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_at | Duration | REASON |
|-------|------------|---------|---------|------------------|---------------------|---------|-----------|----------|--------------------|
| 1370 | 4-Jul-2022 | TUMKUR | 66 | TR-1(LV-1) | PAVAGADA_220 | 6:09 | 6:16 | 0:07 | TRANSFORMER FAULT |
| 1371 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | SANTEMAVATTUR_66 | 11:35 | 16:06 | 4:30 | LINE CLEAR AVAILED |
| 1372 | 4-Jul-2022 | TUMKUR | 66 | TR-2 | THIMMASANDTA_66 | 12:00 | 12:09 | 0:08 | HAND TRIPPED |
| 1373 | 4-Jul-2022 | TUMKUR | 66 | TR-1 | VENKATAPURA_66 | 10:56 | 14:10 | 3:13 | LINE CLEAR AVAILED |
| 1374 | 4-Jul-2022 | TUMKUR | 66 | TR-2 | VENKATAPURA_66 | 14:05 | 15:45 | 1:40 | LINE CLEAR AVAILED |