

**400/220/110/66 kV TRANSMISSION OUTAGES FROM : 28.9.21 TO 4.10.21**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	28-Sep-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
2	28-Sep-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
3	28-Sep-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVOIDED
4	28-Sep-21	BAGALKOT	110	110/11KV,HV1	DEVAGOAN_110	14:15	15:15	1:00	LINE CLEAR AVOIDED
5	28-Sep-21	BAGALKOT	110	110/11KV,HV1	RAMDURGA_110	13:00	13:50	0:50	LINE CLEAR AVOIDED
6	28-Sep-21	BAGALKOT	110	110/11KV,HV2	DHAVALESHWAR_110	8:31	11:23	2:52	LINE CLEAR AVOIDED
7	28-Sep-21	BAGALKOT	110	110/11KV,HV2	MALGHAN(S)	10:59	11:45	0:46	TRANSFORMER FAULT
8	28-Sep-21	BAGALKOT	110	110/11KV,HV2	SAVALAGI_110	18:50	18:57	0:07	HAND TRIPPED
9	28-Sep-21	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
10	28-Sep-21	BAGALKOT	110	110/33KV,HV3	IE_33,DUMAWAD_33 TARIHAKL_110	16:26	19:02	2:36	LINE CLEAR AVOIDED
11	28-Sep-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED RANEENNUR_220	14:18	14:24	0:06	HAND TRIPPED
12	28-Sep-21	BAGALKOT	110	ALABAL-REV SOLAR	ALABAL_110	15:52	19:07	3:15	LINE CLEAR AVOIDED
13	28-Sep-21	BAGALKOT	110	ALABAL-SAI PRIYA SUGARS	ALABAL_110	15:52	19:06	3:14	LINE CLEAR AVOIDED
14	28-Sep-21	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGER_110	10:31	17:15	6:44	LINE CLEAR AVOIDED
15	28-Sep-21	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
16	28-Sep-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
17	28-Sep-21	BAGALKOT	110	HALIYAL-ALNAVAR	HALIYAL_110	6:04	6:18	0:14	LINE CLEAR AVOIDED
18	28-Sep-21	BAGALKOT	110	HAVERI-BYADAGI	STATION NOT AFFECTED HAVERI_220	18:20 (27.09.2021)	13:31 (28.09.2021)	19:11	LINE CHARGED
19	28-Sep-21	BAGALKOT	110	HAVERI-KNNL	HAVERI_220	4:45	11:30	6:45	LINE FAULT
20	28-Sep-21	BAGALKOT	110	HAVERI-TILUVALLI (HANAGALL)	TILUVALLI_110	11:45	15:05	3:20	LINE CLEAR AVOIDED
21	28-Sep-21	BAGALKOT	110	HIREHAL-MFR SOLAR	HIREHAL_110	16:05	16:26	0:21	HAND TRIPPED
22	28-Sep-21	BAGALKOT	110	INDI-ZALKI2	STATION NOT AFFECTED INDI_220	3:02	3:10	0:08	LINE FAULT
23	28-Sep-21	BAGALKOT	110	ITNAL-SULTANPUR(HIDKAL)	STATION NOT AFFECTED ITANAL_110	11:32 (25.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
24	28-Sep-21	BAGALKOT	110	MK HUBLI-KITTUR	KITTUR_110	14:24	14:44	0:20	HAND TRIPPED
25	28-Sep-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)	14:50 (28.09.2021)	1:34	LINE CHARGED
26	28-Sep-21	BAGALKOT	110	RANEENNUR-BYADAGI	STATION NOT AFFECTED BYADAGI_110	13:52	14:47	0:55	LINE CLEAR AVOIDED
27	28-Sep-21	BAGALKOT	110	RANEENNUR-HIREKERURI	STATION NOT AFFECTED HIREKERUR_110	14:18	15:10	0:52	LINE CLEAR AVOIDED
28	28-Sep-21	BAGALKOT	110	SAVALAGI-TODALBAGI	STATION NOT AFFECTED TODALBAGI_110	12:44	18:59	6:15	HAND TRIPPED
29	28-Sep-21	BAGALKOT	110	SAVALAGI-YELLAMANAWADI	YELLAMANAWADI_110	12:35	18:50	6:15	LINE CLEAR AVOIDED
30	28-Sep-21	BAGALKOT	110	SAVANUR-ASF(ASIAN FEB TECH)	STATION NOT AFFECTED SAVANUR_110	4:45	4:49	0:04	LINE FAULT
31	28-Sep-21	BAGALKOT	110	SAVANUR-ASF(ASIAN FEB TECH)	STATION NOT AFFECTED SAVANUR_110	4:56	5:01	0:05	LINE FAULT
32	28-Sep-21	BAGALKOT	110	SAVANUR-ASF(ASIAN FEB TECH)	STATION NOT AFFECTED SAVANUR_110	5:01	5:05	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
33	28-Sep-21	BAGALKOT	110	SAVANUR-ASF(ASIAN FEB TECH)	STATION NOT AFFECTED SAVANUR_110	5:05	6:20	1:15	LINE FAULT
34	28-Sep-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
35	28-Sep-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVAILED
36	28-Sep-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)			LINE OPEN:LINE CLEAR AVAILED
37	28-Sep-21	BAGALKOT	110	TODALBAGI-MAMADAPUR	TODALBAGI_110	12:45	13:05	0:20	HAND TRIPPED
38	28-Sep-21	BAGALKOT	110	TODALBAGI-MAMADAPUR	TODALBAGI_110	18:59	19:10	0:11	HAND TRIPPED
39	28-Sep-21	BAGALKOT	110	YELLAMANAVADI-ALBAL	YELLAMANAWADI_110	7:05	10:30	3:25	LINE CLEAR AVAILED
40	28-Sep-21	BAGALKOT	110	YELLAMANAVADI-ALBAL	YELLAMANAWADI_110	15:55	19:00	3:05	LINE CLEAR AVAILED
41	28-Sep-21	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED MUGALKHOD_220	11:45	14:24	2:39	LINE CLEAR AVAILED
42	28-Sep-21	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED MK HUBLI_220	15:14	18:59	3:45	LINE CLEAR AVAILED
43	28-Sep-21	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED MUGALKHOD_220	9:20	11:41	2:21	LINE CLEAR AVAILED
44	28-Sep-21	BAGALKOT	220	AMBEWADI-PONDA1	STATION NOT AFFECTED AMBEWADI_220	19:42 (27.09.2021)	14:42 (28.09.2021)	19:00	LINE CHARGED
45	28-Sep-21	BAGALKOT	220	ATHANI220-KAKAMARI2	STATION NOT AFFECTED ATHANI_220	16:45	17:16	0:31	LINE FAULT
46	28-Sep-21	BAGALKOT	220	ATHANI220-KAKAMARI2	STATION NOT AFFECTED ATHANI_220	17:16	18:05	0:49	LINE FAULT
47	28-Sep-21	BAGALKOT	220	ATHANI220-KAKAMARI2	STATION NOT AFFECTED ATHANI_220	18:05	21:28	3:23	LINE CLEAR AVAILED
48	28-Sep-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:22 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
49	28-Sep-21	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	13:29	15:18	1:49	LINE CLEAR AVAILED
50	28-Sep-21	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	12:21	15:20	2:59	LINE CLEAR AVAILED
51	28-Sep-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	12:55 (19.09.2021)			LINE OPEN:LINE FAULT
52	28-Sep-21	BAGALKOT	220	MAHALINGAPUR-ATHANI	STATION NOT AFFECTED ATHANI_220	16:28	18:59	2:31	LINE CLEAR AVAILED
53	28-Sep-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
54	28-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
55	28-Sep-21	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	13:29	15:17	1:48	LINE CLEAR AVAILED
56	28-Sep-21	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	12:21	15:20	2:59	LINE CLEAR AVAILED
57	28-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:06 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
58	28-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:07 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
59	28-Sep-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
60	28-Sep-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
61	28-Sep-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	15:02	15:06	0:04	LOAD CHANGE OVER
62	28-Sep-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	9:23	9:28	0:05	LOAD CHANGE OVER
63	28-Sep-21	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	5:55	6:00	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
64	28-Sep-21	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT, BELL CERAMICS (EHT)	13:29	13:33	0:04	LOAD CHANGE OVER
65	28-Sep-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	12:47	13:20	0:32	LINE CLEAR AVAILED
66	28-Sep-21	BENGALURU	66	HV1	AMAR JYOTHI	11:30	11:44	0:14	TRANSFORMER FAULT
67	28-Sep-21	BENGALURU	66	HV1	BG ROAD	11:08	11:14	0:06	TRANSFORMER FAULT
68	28-Sep-21	BENGALURU	66	HV1	VIJAYANAGARA	7:18	7:30	0:12	MAIN SUPPLY FAILURE
69	28-Sep-21	BENGALURU	66	HV1	VIJAYANAGARA	11:02	11:05	0:03	LOAD CHANGE OVER
70	28-Sep-21	BENGALURU	66	HV1	SURYANAGAR	13:20	14:10	0:50	LINE CLEAR AVAILED
71	28-Sep-21	BENGALURU	66	HV1	MULBAGLU	10:56	11:02	0:05	TRANSFORMER FAULT
72	28-Sep-21	BENGALURU	66	HV1	MITTEMARI 220	15:50	16:58	1:08	LINE CLEAR AVAILED
73	28-Sep-21	BENGALURU	66	HV1	MELUR	12:58	13:20	0:21	TRANSFORMER FAULT
74	28-Sep-21	BENGALURU	66	HV1	MELUR	15:25	15:40	0:15	TRANSFORMER FAULT
75	28-Sep-21	BENGALURU	66	HV1	MELUR	22:01	22:15	0:14	TRANSFORMER FAULT
76	28-Sep-21	BENGALURU	66	HV1	MELUR	22:16	22:35	0:18	TRANSFORMER FAULT
77	28-Sep-21	BENGALURU	66	HV1	KYALANUR	18:30	18:38	0:08	TRANSFORMER FAULT
78	28-Sep-21	BENGALURU	66	HV1	KGF	13:44	15:51	2:07	LINE CLEAR AVAILED
79	28-Sep-21	BENGALURU	66	HV1	KACHMARANAHALLI	9:28	9:35	0:06	TRANSFORMER FAULT
80	28-Sep-21	BENGALURU	66	HV2	NIMHANS	12:13	12:18	0:05	LINE CLEAR AVAILED
81	28-Sep-21	BENGALURU	66	HV2	KGF	15:52	18:09	2:17	LINE CLEAR AVAILED
82	28-Sep-21	BENGALURU	66	HV3	KGF	12:15	14:32	2:16	LINE CLEAR AVAILED
83	28-Sep-21	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	5:55	6:00	0:05	LINE FAULT
84	28-Sep-21	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	5:54	6:00	0:06	LOAD CHANGE OVER
85	28-Sep-21	BENGALURU	66	KHW PARK 220 - SHELL(EHT)	SHELL(EHT)	14:10	18:58	4:48	LINE CLEAR AVAILED
86	28-Sep-21	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	16:57(25/09/2021)			LINE OPEN:LINE FAULT
87	28-Sep-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:54	21:23	4:29	LINE FAULT
88	28-Sep-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	15:18	15:31	0:12	LINE FAULT
89	28-Sep-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	6:02	6:12	0:09	LINE FAULT
90	28-Sep-21	BENGALURU	66	NRS 220 - VIJAYANAGARA MY 1	VIJAYANAGARA	7:19	7:30	0:11	LINE FAULT
91	28-Sep-21	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	10:00	16:30	6:30	LINE CLEAR AVAILED
92	28-Sep-21	BENGALURU	66	REMCO - SUBRAMANYAPURA 220	REMCO	8:21	9:02	0:41	MAIN SUPPLY FAILURE
93	28-Sep-21	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	11:35	11:56	0:21	LINE FAULT
94	28-Sep-21	BENGALURU	66	SIDLAGATTA - MELUR	MELUR	11:35	11:56	0:21	LINE FAULT
95	28-Sep-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	REMCO, GLOBAL VILLAGE (EHT)	8:21	9:02	0:41	LINE FAULT
96	28-Sep-21	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	9:03	9:07	0:04	LOAD CHANGE OVER
97	28-Sep-21	BENGALURU	66	YELAHANKA 220 - LINE5	KHB	10:04	14:11	4:06	LINE CLEAR AVAILED
98	28-Sep-21	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	10:04	16:00	5:55	LINE CLEAR AVAILED
99	28-Sep-21	GULBARGA	66	HV1	KUDLIGI_220	10:20	10:30	0:10	TRANSFORMER FAULT
100	28-Sep-21	GULBARGA	66	NEELAGUNDA-TENGLI	TENGLI_66,KURBNAHALLI_66	4:21	8:30	4:09	LINE FAULT
101	28-Sep-21	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BH ALKI SUGAR IPP	21:11	21:17	0:06	LINE FAULT
102	28-Sep-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110, DIGGI_110	6:45	6:50	0:05	LINE FAULT
103	28-Sep-21	GULBARGA	110	HATTI-LINGSUGUR	HATTI_110	6:20	6:27	0:07	MAIN SUPPLY FAILURE
104	28-Sep-21	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	16:35(28.09.2021)			LINE OPEN:LINE CLEAR AVAILED
105	28-Sep-21	GULBARGA	110	HUMNABAD-MANEKHELI	MANEKHALI_110	16:34	16:58	0:24	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
106	28-Sep-21	GULBARGA	110	HV2	HATTI_110	1:50	1:58	0:08	TRANSFORMER FAULT
107	28-Sep-21	GULBARGA	110	HV2	MUNIRABAD_220	10:23	12:48	2:25	LINE CLEAR AVAIED
108	28-Sep-21	GULBARGA	110	HV2	TEKKALKOTE_110	23:13	23:18	0:05	TRANSFORMER FAULT
109	28-Sep-21	GULBARGA	110	HV2	TEKKALKOTE_110	23:24	23:30	0:06	TRANSFORMER FAULT
110	28-Sep-21	GULBARGA	110	HV2	TEKKALKOTE_110	11:05	11:10	0:05	TRANSFORMER FAULT
111	28-Sep-21	GULBARGA	110	HV2	YEDRAMI_110	14:45	15:15	0:30	LINE CLEAR AVAIED
112	28-Sep-21	GULBARGA	110	JANAWADA-SANTAPUR	JANAWADA_110	18:10	18:19	0:09	LINE FAULT
113	28-Sep-21	GULBARGA	110	MUNIRABAD-SANKALAPUR	SANKALAPUR_110,HAGARI_110,RBSNN, KAMALAPUR_110	8:55	13:32	4:37	LINE CLEAR AVAIED
114	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	1:00	1:25	0:25	LINE FAULT
115	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	5:47	5:55	0:08	LINE FAULT
116	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	18:34	18:50	0:16	LINE FAULT
117	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	18:52	19:09	0:17	LINE FAULT
118	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	20:21	20:43	0:22	LINE FAULT
119	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	1:00	1:25	0:25	LINE FAULT
120	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:47	5:55	0:08	LINE FAULT
121	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	18:34	18:50	0:16	LINE FAULT
122	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	18:52	19:09	0:17	LINE FAULT
123	28-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:21	20:43	0:22	LINE FAULT
124	28-Sep-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	12:20	18:52	6:32	LINE CLEAR AVAIED
125	28-Sep-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	3:45	3:50	0:05	LINE FAULT
126	28-Sep-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	6:55	7:16	0:21	LINE FAULT
127	28-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAIED
128	28-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAIED
129	28-Sep-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	3:26	3:34	0:08	LINE FAULT
130	28-Sep-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA _110,SRNAGAR_110,MALLAPURA_110	6:20	6:40	0:20	LINE FAULT
131	28-Sep-21	GULBARGA	110	TEKKALKOTE-ABMN_SLR	TEKKALKOTE_110	15:23	19:22	3:59	LINE CLEAR AVAIED
132	28-Sep-21	GULBARGA	110	TEKKALKOTE-RERNEW SOLAR	TEKKALKOTE_110	15:23	19:23	4:00	LINE CLEAR AVAIED
133	28-Sep-21	GULBARGA	110	YELBURGA-PRP/SLR	YELBURGA_110	20:02	21:25	1:23	LINE CLEAR AVAIED
134	28-Sep-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
135	28-Sep-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	11:41	18:23	6:42	LINE FAULT
136	28-Sep-21	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	19:37	19:56	0:19	LINE FAULT
137	28-Sep-21	HASSAN	66	CRPATNA--KIKKERI	CRPATNA_220	12:16	12:41	0:25	LINE CLEAR AVAIED
138	28-Sep-21	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	12:43	14:27	1:44	LINE CLEAR AVAIED
139	28-Sep-21	HASSAN	66	HIREMAN-CKM220	HIREMANGALUR_66	12:43	14:29	1:46	LINE CLEAR AVAIED
140	28-Sep-21	HASSAN	66	HIREMAN-RDL	HIREMANGALUR_66	12:43	14:38	1:55	LINE CLEAR AVAIED
141	28-Sep-21	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	11:03	15:07	4:04	LINE CLEAR AVAIED
142	28-Sep-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	9:09	9:11	0:02	LOAD CHANGE OVER
143	28-Sep-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	18:27	18:28	0:01	LOAD CHANGE OVER
144	28-Sep-21	HASSAN	66	HV1	CHIKMAGALUR_66	12:43	14:30	1:47	LINE CLEAR AVAIED
145	28-Sep-21	HASSAN	66	HV1	HIREMANGALUR_66	9:48	14:30	4:42	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
146	28-Sep-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	9:17	9:23	0:06	LOAD CHANGE OVER
147	28-Sep-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	18:24	18:30	0:06	LOAD CHANGE OVER
148	28-Sep-21	HASSAN	66	HV2	RAMNATHPURA_66	9:12	9:17	0:05	HAND TRIPPED
149	28-Sep-21	HASSAN	66	HV2	RAMNATHPURA_66	18:25	18:29	0:04	HAND TRIPPED
150	28-Sep-21	HASSAN	66	HV2	CHIKMAGALUR_66	12:43	14:30	1:47	LINE CLEAR AVAILED
151	28-Sep-21	HASSAN	66	LV1	CRPATNA_220	14:12	17:44	3:32	LINE CLEAR AVAILED
152	28-Sep-21	HASSAN	66	Lv1	HOLENARASIPURA_220	13:35	18:35	5:00	LINE CLEAR AVAILED
153	28-Sep-21	HASSAN	66	LV2	CRPATNA_220	9:16	14:09	4:53	LINE CLEAR AVAILED
154	28-Sep-21	HASSAN	66	Lv2	HOLENARASIPURA_220	9:23	13:30	4:07	LINE CLEAR AVAILED
155	28-Sep-21	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	9:17	18:30	9:13	LINE CLEAR AVAILED
156	28-Sep-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	9:12	9:17	0:05	HAND TRIPPED
157	28-Sep-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	18:25	18:29	0:04	HAND TRIPPED
158	28-Sep-21	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	9:29	18:27	8:58	LINE CLEAR AVAILED
159	28-Sep-21	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:09	14:15	4:06	LINE CLEAR AVAILED
160	28-Sep-21	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	23:58(28.09.2021)			LINE OPEN:LINE CLEAR AVAILED
161	28-Sep-21	HASSAN	110	HV1	ESSUR_110	10:09	17:53	7:44	LINE CLEAR AVAILED
162	28-Sep-21	HASSAN	110	HV1	HOSANGADI_110	11:02	16:39	5:37	LINE CLEAR AVAILED
163	28-Sep-21	HASSAN	110	HV1	NANDIKUR_110	10:37	12:27	1:50	LINE CLEAR AVAILED
164	28-Sep-21	HASSAN	110	HV1	NAVUNDA_110	10:08	14:24	4:16	MAIN SUPPLY FAILURE
165	28-Sep-21	HASSAN	110	HV1	SHIVAPURA_110	13:03	14:19	1:16	LINE CLEAR AVAILED
166	28-Sep-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
167	28-Sep-21	HASSAN	110	HV2	ESSUR_110	10:09	17:53	7:44	LINE CLEAR AVAILED
168	28-Sep-21	HASSAN	110	HV2	GURUPURA_110	10:31	15:53	5:22	LINE CLEAR AVAILED
169	28-Sep-21	HASSAN	110	HV2	KADUR_220	9:17	10:34	1:17	LINE CLEAR AVAILED
170	28-Sep-21	HASSAN	110	HV2	KONAJE_110	10:09	15:59	5:50	LINE CLEAR AVAILED
171	28-Sep-21	HASSAN	110	HV2	MANIPAL_110	11:05	15:34	4:29	LINE CLEAR AVAILED
172	28-Sep-21	HASSAN	110	HV2	NANDIKUR_110	10:37	12:27	1:50	LINE CLEAR AVAILED
173	28-Sep-21	HASSAN	110	HV2	NANDIKUR_110	12:27	13:06	0:39	LINE CLEAR AVAILED
174	28-Sep-21	HASSAN	110	HV2	SAGARA_110	12:58	16:20	3:22	LINE CLEAR AVAILED
175	28-Sep-21	HASSAN	110	JOG110-LPH	JOG_110	9:53(8.09.2021)			LINE OPEN:LINE CLEAR AVAILED
176	28-Sep-21	HASSAN	110	Lv1	HEGGUNJE_220	12:41	13:44	1:03	LINE CLEAR AVAILED
177	28-Sep-21	HASSAN	110	Lv2	HEGGUNJE_220	11:18	12:38	1:20	LINE CLEAR AVAILED
178	28-Sep-21	HASSAN	110	LV2	PUTTUR_220	9:02	13:31	4:29	LINE CLEAR AVAILED
179	28-Sep-21	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	10:10	14:27	4:17	NFBC ISSUED
180	28-Sep-21	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	10:09	14:27	4:18	NFBC ISSUED
181	28-Sep-21	HASSAN	110	NANDIKU-ISTRIL	NANDIKUR_110	10:37	12:27	1:50	LINE CLEAR AVAILED
182	28-Sep-21	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	10:37	12:27	1:50	LINE CLEAR AVAILED
183	28-Sep-21	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	10:37	12:27	1:50	LINE CLEAR AVAILED
184	28-Sep-21	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	10:37	12:27	1:50	LINE CLEAR AVAILED
185	28-Sep-21	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	11:16	14:22	3:06	NFBC ISSUED
186	28-Sep-21	HASSAN	110	VITTAL-PUTR_SLTUR	VITTAL_110	11:15	14:22	3:07	LINE CLEAR AVAILED
187	28-Sep-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	23:15 (27.09.2021)			LINE OPEN:LINE FAULT
188	28-Sep-21	HASSAN	220	HV1	CRPATNA_220	14:12	17:43	3:31	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
189	28-Sep-21	HASSAN	220	HV1	HEGGUNJE_220	12:41	13:44	1:03	LINE CLEAR AVAIED
190	28-Sep-21	HASSAN	220	HV1	HOLENARASIPURA_220	13:35	18:33	4:58	LINE CLEAR AVAIED
191	28-Sep-21	HASSAN	220	HV2	CRPATNA_220	9:17	14:02	4:45	LINE CLEAR AVAIED
192	28-Sep-21	HASSAN	220	HV2	HEGGUNJE_220	11:18	12:38	1:20	LINE CLEAR AVAIED
193	28-Sep-21	HASSAN	220	HV2	HOLENARASIPURA_220	9:23	13:28	4:05	LINE CLEAR AVAIED
194	28-Sep-21	HASSAN	220	HV2	KEMAR_220	10:53	12:04	1:11	LINE CLEAR AVAIED
195	28-Sep-21	HASSAN	220	HV2	PUTTUR_220	9:02	13:31	4:29	LINE CLEAR AVAIED
196	28-Sep-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	13:19	18:09	4:50	NFBC ISSUED
197	28-Sep-21	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	8:32 (24.09.2021)			LINE OPEN:LINE CLEAR AVAIED
198	28-Sep-21	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	8:32 (24.09.2021)			LINE OPEN:LINE CLEAR AVAIED
199	28-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	23:15 (27.09.2021)	7:39(28.09.2021)	8:33 hrs	LINE CHARGED
200	28-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	7:39(28.09.2021)			LINE OPEN:LINE FAULT
201	28-Sep-21	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	15:41	17:54	2:13	LINE CLEAR AVAIED
202	28-Sep-21	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	15:41	17:56	2:15	LINE CLEAR AVAIED
203	28-Sep-21	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	11:05(28.09.2021)			LINE OPEN:LINE CLEAR AVAIED
204	28-Sep-21	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	15:40	17:54	2:14	LINE CLEAR AVAIED
205	28-Sep-21	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	15:40	17:55	2:15	LINE CLEAR AVAIED
206	28-Sep-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
207	28-Sep-21	MYSURU	66	GUNDLUPETE-BEGUR-2	NO STATIONS EFFECTED	17:53	21:45	3:51	LINE CLEAR AVAIED
208	28-Sep-21	MYSURU	66	GUNDLUPETE-CR NAGAR 2	NO STATIONS EFFECTED	17:53	21:45	3:51	LINE CLEAR AVAIED
209	28-Sep-21	MYSURU	66	GUNDLUPETE-KABBALLI	NO STATIONS EFFECTED	17:53	21:45	3:51	LINE CLEAR AVAIED
210	28-Sep-21	MYSURU	66	HV1	NAGAMANGALA_66	14:00	14:10	0:10	HAND TRIPPED
211	28-Sep-21	MYSURU	66	HV1	SANTHESARGUR_66	11:20	11:40	0:20	LINE CLEAR AVAIED
212	28-Sep-21	MYSURU	66	HV1	SANTHESARGUR_66	16:47 (23.09.2021)	11:40:00 (28.09.2021)	114:53 hrs	TRANSFORMER CHARGED
213	28-Sep-21	MYSURU	66	HV2	AKKIHEBBAL_66	13:47	14:06	0:19	LINE CLEAR AVAIED
214	28-Sep-21	MYSURU	66	HV2	DEVNUR(N'GUD)_66	11:12	11:19	0:07	TRANSFORMER FAULT
215	28-Sep-21	MYSURU	66	HV2	DUNDANAHALLI_66	11:46	17:27	5:40	LINE CLEAR AVAIED
216	28-Sep-21	MYSURU	66	HV2	KOLLEGALA_66	16:31	16:48	0:16	LINE CLEAR AVAIED
217	28-Sep-21	MYSURU	66	HV2	KOPPA_66	10:20	11:59	1:39	LINE CLEAR AVAIED
218	28-Sep-21	MYSURU	66	HV2	MADDUR_66	10:47	12:04	1:17	LINE CLEAR AVAIED
219	28-Sep-21	MYSURU	66	HV2	NAGAMANGALA_66	14:01	14:10	0:08	HAND TRIPPED
220	28-Sep-21	MYSURU	66	HV2	DK MAIDANA _66	10:38	16:36	5:58	LINE CLEAR AVAIED
221	28-Sep-21	MYSURU	66	HV3	AKKIHEBBAL_66	13:47	14:06	0:19	LINE CLEAR AVAIED
222	28-Sep-21	MYSURU	66	KADAKOLA-MANTAGALLI	NO STATIONS EFFECTED	8:23	14:39	6:16	LINE CLEAR AVAIED
223	28-Sep-21	MYSURU	66	NANJANGUDU-THANDYA	NO STATIONS EFFECTED	12:17	12:20	0:03	HAND TRIPPED
224	28-Sep-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN:LINE CLEAR AVAIED
225	28-Sep-21	MYSURU	66	PERIYAPATNA-HANGODU	HANGODU_66 VIRAJPETE _66 PONNAMPETE _66	2:01	2:08	0:06	LINE FAULT
226	28-Sep-21	MYSURU	66	RAVANDUR-ADANI	NO STATIONS EFFECTED	15:24	16:38	1:14	LINE CLEAR AVAIED
227	28-Sep-21	MYSURU	66	RAVANDUR-ADANI	NO STATIONS EFFECTED	19:38	19:52	0:13	HAND TRIPPED
228	28-Sep-21	MYSURU	66	THANDYA-NANJANGUDU	NO STATIONS EFFECTED	11:04	12:19	1:15	HAND TRIPPED
229	28-Sep-21	MYSURU	66	TUBINKERE-MC-2	MANDYA_66 CHIKKAMANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGRALLI_66 KK HALLI _66	10:38	10:48	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
230	28-Sep-21	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 CHIKKAMANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGRALLI_66 KK HALLI_66	10:38	10:48	0:09	LINE FAULT
231	28-Sep-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18(23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
232	28-Sep-21	MYSURU	220	HEBBANITK HALLI-1	NO STATIONS EFFECTED	11:37	15:08	3:31	LINE CLEAR AVAILED
233	28-Sep-21	MYSURU	220	HEBBANI-TK HALLI-2	NO STATIONS EFFECTED	9:46	11:37	1:51	LINE CLEAR AVAILED
234	28-Sep-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
235	28-Sep-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:44	16:12	0:27	LINE FAULT
236	28-Sep-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:44	16:12	0:27	LINE FAULT
237	28-Sep-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:53	11:06	0:13	LINE FAULT
238	28-Sep-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:53	11:06	0:13	LINE FAULT
239	28-Sep-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:38	9:49	0:10	LINE FAULT
240	28-Sep-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:57	15:05	0:08	LINE FAULT
241	28-Sep-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:38	9:49	0:10	LINE FAULT
242	28-Sep-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:57	15:05	0:08	LINE FAULT
243	28-Sep-21	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66,SAS ALUHALLA_66	12:54	13:34	0:39	LINE FAULT
244	28-Sep-21	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66,SAS ALUHALLA_66	12:54	13:34	0:39	LINE FAULT
245	28-Sep-21	TUMKUR	66	TR-1	BRAHMASANDRA_66	16:08	17:20	1:12	LINE CLEAR AVAILED
246	28-Sep-21	TUMKUR	66	TR-1	P D KOTE_66	5:36	5:43	0:07	TRANSFORMER FAULT
247	28-Sep-21	TUMKUR	66	TR-1	P D KOTE_66	13:15	13:32	0:16	TRANSFORMER FAULT
248	28-Sep-21	TUMKUR	66	TR-1	PAVAGADA_220	16:35	16:40	0:05	TRANSFORMER FAULT
249	28-Sep-21	TUMKUR	66	TR-1	PAVAGADA_220	16:54	16:56	0:01	TRANSFORMER FAULT
250	28-Sep-21	TUMKUR	66	TR-1	BRAHMASANDRA_66	16:08	17:20	1:12	LINE CLEAR AVAILED
251	28-Sep-21	TUMKUR	66	TR-1	P D KOTE_66	5:36	5:43	0:07	TRANSFORMER FAULT
252	28-Sep-21	TUMKUR	66	TR-1	P D KOTE_66	13:15	13:32	0:16	TRANSFORMER FAULT
253	28-Sep-21	TUMKUR	66	TR-1	PAVAGADA_220	16:35	16:40	0:05	TRANSFORMER FAULT
254	28-Sep-21	TUMKUR	66	TR-1	PAVAGADA_220	16:54	16:56	0:01	TRANSFORMER FAULT
255	28-Sep-21	TUMKUR	66	TR-2	DAVANGERE_66	13:14	14:01	0:47	HAND TRIPPED
256	28-Sep-21	TUMKUR	66	TR-2	DAVANGERE_66	13:14	14:01	0:47	HAND TRIPPED
257	29-Sep-21	BAGALKOT	66	66/11KV, HV1	STATION NOT AFFECTED HARIHAR-HOSPET_66	12:33	18:24	5:51	LINE CLEAR AVAILED
258	29-Sep-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
259	29-Sep-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
260	29-Sep-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
261	29-Sep-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIRBUR_110	17:31	18:00	0:29	LINE CLEAR AVAILED
262	29-Sep-21	BAGALKOT	110	110/11KV,HV1	KUD DHARWAD_110	14:49	14:50	0:01	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
263	29-Sep-21	BAGALKOT	110	110/11KV,HV1	MANTUR(GHP)_110	13:00	18:13	5:13	LINE CLEAR AVAIED
264	29-Sep-21	BAGALKOT	110	110/11KV,HV1	MORATAGI_110	15:54	15:58	0:04	TRANSFORMER FAULT
265	29-Sep-21	BAGALKOT	110	110/11KV,HV1	RANNABELAGALI_110	9:01	11:15	2:14	LINE CLEAR AVAIED
266	29-Sep-21	BAGALKOT	110	110/11KV,HV1	GANESHGUDI_110	11:12	13:06	1:54	LINE CLEAR AVAIED
267	29-Sep-21	BAGALKOT	110	110/11KV,HV1	KATARAKI_110	20:30	21:10	0:40	LINE CLEAR AVAIED
268	29-Sep-21	BAGALKOT	110	110/11KV,HV1	SHIROL_110	12:20	14:50	2:30	LINE CLEAR AVAIED
269	29-Sep-21	BAGALKOT	110	110/11KV,HV1	ITNAL_110	7:35	7:45	0:10	TRANSFORMER FAULT
270	29-Sep-21	BAGALKOT	110	110/11KV,HV1	ITNAL_110	7:50	7:55	0:05	TRANSFORMER FAULT
271	29-Sep-21	BAGALKOT	110	110/11KV,HV1	ITNAL_110	8:50	8:55	0:05	TRANSFORMER FAULT
272	29-Sep-21	BAGALKOT	110	110/11KV,HV2	MANTUR(GHP)_110	12:59	18:13	5:14	LINE CLEAR AVAIED
273	29-Sep-21	BAGALKOT	110	110/11KV,HV2	RANNABELAGALI_110	9:01	11:15	2:14	LINE CLEAR AVAIED
274	29-Sep-21	BAGALKOT	110	110/11KV,HV2	RON_110	8:17	8:45	0:28	TRANSFORMER FAULT
275	29-Sep-21	BAGALKOT	110	110/11KV,HV2	RAIBAG_110	8:23	8:27	0:04	HAND TRIPPED
276	29-Sep-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	9:54	10:10	0:16	TRANSFORMER FAULT
277	29-Sep-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	10:40	11:37	0:57	TRANSFORMER FAULT
278	29-Sep-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:37	12:45	1:08	TRANSFORMER FAULT
279	29-Sep-21	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
280	29-Sep-21	BAGALKOT	110	110/33KV,HV3	MUSHIGERI_33 RON_110	8:17	8:45	0:28	TRANSFORMER FAULT
281	29-Sep-21	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	4:08	6:50	2:42	HAND TRIPPED
282	29-Sep-21	BAGALKOT	110	ALBAL-RAY SOLAR	ALBAL_110	8:23	9:42	1:19	LINE CLEAR AVAIED
283	29-Sep-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGAR-	ALBAL_110	8:25	9:41	1:16	LINE CLEAR AVAIED
284	29-Sep-21	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVAIED
285	29-Sep-21	BAGALKOT	110	GHATAPRABHA220-MANTUR	MANTUR(GHP)_110	14:35	18:15	3:40	LINE CLEAR AVAIED
286	29-Sep-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAIED
287	29-Sep-21	BAGALKOT	110	HAVERI-HANAGAL(TILUVALI)	HAVERI_220	6:21	6:33	0:12	LINE FAULT
288	29-Sep-21	BAGALKOT	110	HAVERI-TILUVALI(HANAGAL)	HAVERI_220	11:10	11:24	0:14	LINE CLEAR AVAIED
289	29-Sep-21	BAGALKOT	110	ITNAL-SULTANPUR(HIDKAL)	STATION NOT AFFECTED ITANAL_110	11:32 (25.09.2021)			LINE OPEN:LINE CLEAR AVAIED
290	29-Sep-21	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	14:30 (15.09.2021)	14:01 (29.09.2021)	23:31	LINE CHARGED
291	29-Sep-21	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	9:59	11:05	1:06	LINE CLEAR AVAIED
292	29-Sep-21	BAGALKOT	110	MK HUBLI-KITTUR(NARENDRA)	KITTUR_110	8:06	12:36	4:30	LINE FAULT
293	29-Sep-21	BAGALKOT	110	RANEENNUR-RATTIHALLI	RATTIHALLI_110	7:35	8:20	0:45	HAND TRIPPED
294	29-Sep-21	BAGALKOT	110	RANEENNUR-TUMMINAKATTI(RATTIHALLI)	RANEENNUR_220	7:38	8:35	0:57	LINE FAULT
295	29-Sep-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAIED
296	29-Sep-21	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAIED
297	29-Sep-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVAIED
298	29-Sep-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)			LINE OPEN:LINE CLEAR AVAIED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
299	29-Sep-21	BAGALKOT	110	UTTUR-RANNABELAGALI	RANNABELAGALI_110	9:59	11:09	1:10	LINE CLEAR AVAILED
300	29-Sep-21	BAGALKOT	110	VAJRAMATTI-LOKAPUR	LOKAPUR_110	12:37	16:25	3:48	LINE CLEAR AVAILED
301	29-Sep-21	BAGALKOT	110	VAJRAMATTI-MALLIGERI	MALLIGERI_110	11:03	18:03	7:00	LINE CLEAR AVAILED
302	29-Sep-21	BAGALKOT	220	220/110KV,HV2.LV2	KARWAR_220	15:40	17:25	1:45	LINE CLEAR AVAILED
303	29-Sep-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:22 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
304	29-Sep-21	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	12:51	15:38	2:47	HAND TRIPPED
305	29-Sep-21	BAGALKOT	220	BELGAUM-KANABARGI2	BELGAUM_220	12:57	15:38	2:41	LINE CLEAR AVAILED
306	29-Sep-21	BAGALKOT	220	BIJAPUR-INDI2	BIJAPUR_220	12:01	19:00	6:59	LINE CLEAR AVAILED
307	29-Sep-21	BAGALKOT	220	INDI-BIJAPUR2	INDI_220	12:10	19:07	6:57	LINE CLEAR AVAILED
308	29-Sep-21	BAGALKOT	220	KARWAR-KADRA2	KARWAR_220	10:30	16:04	5:34	LINE CLEAR AVAILED
309	29-Sep-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	12:55 (19.09.2021)			LINE OPEN:LINE FAULT
310	29-Sep-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
311	29-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
312	29-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:06 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
313	29-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:07 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
314	29-Sep-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
315	29-Sep-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
316	29-Sep-21	BENGALURU	66	ADUGODI - HSR LAYOUT 2	ST.JOHN WOOD	16:17	16:28	0:11	LINE FAULT
317	29-Sep-21	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	14:50	14:58	0:08	LINE CLEAR AVAILED
318	29-Sep-21	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:01	12:29	1:28	LINE CLEAR AVAILED
319	29-Sep-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:13	16:15	1:01	LINE CLEAR AVAILED
320	29-Sep-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	10:20	15:35	5:15	LINE CLEAR AVAILED
321	29-Sep-21	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HALAGUR	17:49	18:06	0:17	LINE FAULT
322	29-Sep-21	BENGALURU	66	HV1	HOODY 220	11:26	11:56	0:30	LINE CLEAR AVAILED
323	29-Sep-21	BENGALURU	66	HV1	ST.JOHN WOOD	10:34	10:37	0:03	LINE CLEAR AVAILED
324	29-Sep-21	BENGALURU	66	HV1	MAGADI 66	6:53	7:18	0:24	TRANSFORMER FAULT
325	29-Sep-21	BENGALURU	66	HV1	KODIHALLI CHINTAMANI	15:50	15:55	0:05	TRANSFORMER FAULT
326	29-Sep-21	BENGALURU	66	HV1	HUKUNDA	12:25	14:48	2:23	LINE CLEAR AVAILED
327	29-Sep-21	BENGALURU	66	HV1	DALASNUR	13:20	14:35	1:15	LINE CLEAR AVAILED
328	29-Sep-21	BENGALURU	66	HV1	MELUR	8:58	9:23	0:24	TRANSFORMER FAULT
329	29-Sep-21	BENGALURU	66	HV1	MELUR	9:25	9:45	0:20	TRANSFORMER FAULT
330	29-Sep-21	BENGALURU	66	HV1	MELUR	17:25	18:13	0:47	TRANSFORMER FAULT
331	29-Sep-21	BENGALURU	66	HV1	MELUR	18:15	19:01	0:46	TRANSFORMER FAULT
332	29-Sep-21	BENGALURU	66	HV1	MELUR	20:12	20:15	0:03	TRANSFORMER FAULT
333	29-Sep-21	BENGALURU	66	HV2	ST.JOHN WOOD	12:45	12:47	0:02	LINE CLEAR AVAILED
334	29-Sep-21	BENGALURU	66	HV2	SIDDALAGATTA	15:38	15:42	0:03	TRANSFORMER FAULT
335	29-Sep-21	BENGALURU	66	HV2	M GOLLAHALLI	8:15	8:57	0:41	LINE CLEAR AVAILED
336	29-Sep-21	BENGALURU	66	HV2	MALLASANDRA	10:56	11:35	0:38	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
337	29-Sep-21	BENGALURU	66	HV2	HUKUNDA	12:31	13:16	0:45	LINE CLEAR AVAILED
338	29-Sep-21	BENGALURU	66	IRGAMPALLI - CHINTAMANI 220	IRGAMPALLI	5:58	6:08	0:10	LINE FAULT
339	29-Sep-21	BENGALURU	66	IRGAMPALLI - DIBBURALLI	NO STATION AFFECTED	5:58	6:08	0:10	LINE FAULT
340	29-Sep-21	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	16:57(25/09/2021)	8:36(29/09/2021)	87:39HRS	LINE CHARGED
341	29-Sep-21	BENGALURU	66	LV2	MALUR 220	13:34	13:38	0:04	LINE CLEAR AVAILED
342	29-Sep-21	BENGALURU	66	LV2	MALUR 220	13:40	13:44	0:04	LINE CLEAR AVAILED
343	29-Sep-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	13:35	13:47	0:12	MAIN SUPPLY FAILURE
344	29-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	13:35	13:47	0:11	MAIN SUPPLY FAILURE
345	29-Sep-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	13:34	13:44	0:10	MAIN SUPPLY FAILURE
346	29-Sep-21	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	13:35	13:47	0:11	MAIN SUPPLY FAILURE
347	29-Sep-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	21:23	22:37	1:14	LINE CLEAR AVAILED
348	29-Sep-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	16:57	17:01	0:04	LINE FAULT
349	29-Sep-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	17:01:54(29-9-2021)			LINE OPEN:LINE FAULT
350	29-Sep-21	BENGALURU	66	ST.JOHN WOOD - ADUGODI	ST.JOHN WOOD	16:17	16:28	0:11	MAIN SUPPLY FAILURE
351	29-Sep-21	BENGALURU	66	ST.JOHN WOOD - HSR LAYOUT 220	ST.JOHN WOOD	15:24	15:26	0:02	LOAD CHANGE OVER
352	29-Sep-21	BENGALURU	66	T GOLLAHALLI 220 -TAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:20	14:42	3:22	LINE CLEAR AVAILED
353	29-Sep-21	BENGALURU	66	VIDHURASHRAWATHA - BAGEPALLI	BAGEPALLI, GUNDLU KOTTURU	18:20	18:40	0:20	MAIN SUPPLY FAILURE
354	29-Sep-21	BENGALURU	66	VIDHURASHRAWATHA - GOWRIBIDANUR 220	VIDHURASHRAWATHA	18:20	18:35	0:15	LINE FAULT
355	29-Sep-21	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	10:24	15:18	4:53	LINE CLEAR AVAILED
356	29-Sep-21	GULBARGA	66	HV1	KOTTUR_66	13:11	13:16	0:05	TRANSFORMER FAULT
357	29-Sep-21	GULBARGA	66	KOTTUR-KUDLIGI	UJJAINI_66	16:27	16:35	0:08	LINE CLEAR AVAILED
358	29-Sep-21	GULBARGA	66	MUNIRABAD-MHD	VENKATAPURA_66,RR STEELS_FACTORY,UPHALLI_66	11:42	14:50	3:08	NFBC ISSUED
359	29-Sep-21	GULBARGA	66	TUNGABHADRAIPP-ITTAGGI	ITTAGGI_220	6:00	6:05	0:05	MAIN SUPPLY FAILURE
360	29-Sep-21	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLAU_110,KUDITINI_110,KURUGOD_110,SHATHAVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_IPP,MATRI_110,RBNS FACTORY	11:41	11:48	0:07	LINE FAULT
361	29-Sep-21	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	3:50	3:58	0:08	LINE FAULT
362	29-Sep-21	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	23:49	23:55	0:06	LINE FAULT
363	29-Sep-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITAPUR_110,KORAWAR TEMPLE_110	11:24	11:34	0:10	LINE FAULT
364	29-Sep-21	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	16:35(28.09.2021)			LINE OPEN:LINE CLEAR AVAILED
365	29-Sep-21	GULBARGA	110	HV1	PDHALLI_110	7:00	15:50	8:50	LINE CLEAR AVAILED
366	29-Sep-21	GULBARGA	110	HV1	TEKKALKOTE_110	7:05	8:40	1:35	LINE CLEAR AVAILED
367	29-Sep-21	GULBARGA	110	HV1	NIRNA_110	15:10	15:17	0:07	TRANSFORMER FAULT
368	29-Sep-21	GULBARGA	110	HV2	TEKKALKOTE_110	4:07	4:12	0:05	TRANSFORMER FAULT
369	29-Sep-21	GULBARGA	110	HV2	TEKKALKOTE_110	4:30	4:45	0:15	TRANSFORMER FAULT
370	29-Sep-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:02	19:12	0:10	LINE FAULT
371	29-Sep-21	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	20:07	20:10	0:03	LINE FAULT
372	29-Sep-21	GULBARGA	110	PDHALLI-ALIPUR	PDHALLI_110	18:55	19:05	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
373	29-Sep-21	GULBARGA	110	PDHALLI-BASAI_IPP	PDHALLI_110	10:50	13:30	2:40	LINE CLEAR AVAILED
374	29-Sep-21	GULBARGA	110	PDHALLI-CLNMAX,CLNSLR_IPP	PDHALLI_110	11:00	11:30	0:30	LINE CLEAR AVAILED
375	29-Sep-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	22:38	22:47	0:09	LINE FAULT
376	29-Sep-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	22:32(29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
377	29-Sep-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	3:45	3:50	0:05	LINE FAULT
378	29-Sep-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	6:55	7:16	0:21	LINE FAULT
379	29-Sep-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	17:05	17:20	0:15	LINE FAULT
380	29-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
381	29-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
382	29-Sep-21	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	20:06	20:11	0:05	LINE FAULT
383	29-Sep-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADA GERA_110,SANNATHI_IPP,COREGREEN_ IPP	18:17	18:30	0:13	LINE FAULT
384	29-Sep-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADA GERA_110,SANNATHI_IPP,COREGREEN_ IPP	18:34	18:43	0:09	LINE FAULT
385	29-Sep-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	3:26	3:34	0:08	LINE FAULT
386	29-Sep-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR220	8:40	8:50	0:10	LINE FAULT
387	29-Sep-21	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDHINAGAR_110	22:35	22:45	0:10	LINE FAULT
388	29-Sep-21	GULBARGA	110	TEKKALKOTE-ABMN_SLR	TEKKALKOTE_110	15:20	19:45	4:25	LINE CLEAR AVAILED
389	29-Sep-21	GULBARGA	110	TEKKALKOTE-RERNEW SOLAR	TEKKALKOTE_110	15:20	19:45	4:25	LINE CLEAR AVAILED
390	29-Sep-21	GULBARGA	220	HV1	RAICHUR_220	11:17	12:55	1:38	LINE CLEAR AVAILED
391	29-Sep-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
392	29-Sep-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	9:35	12:08	2:33	LINE CLEAR AVAILED
393	29-Sep-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	21:43	22:17	0:34	LINE FAULT
394	29-Sep-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	23:09	23:25	0:16	LINE FAULT
395	29-Sep-21	GULBARGA	220	SHAHAPUR-RTPS1&2	RTPS_220	12:12	13:26	1:14	LINE CLEAR AVAILED
396	29-Sep-21	HASSAN	66	HV1	MAGGE_66	23:24(29.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
397	29-Sep-21	HASSAN	66	HV1	KANDLI_66	11:45	12:20	0:35	LINE CLEAR AVAILED
398	29-Sep-21	HASSAN	66	HV1	MAGGE_66	10:26	16:05	5:39	LINE CLEAR AVAILED
399	29-Sep-21	HASSAN	66	HV2	HOLEHONNUR_66	11:00	11:30	0:30	LINE CLEAR AVAILED
400	29-Sep-21	HASSAN	66	HV2	MAGGE_66	10:59	16:05	5:06	LINE CLEAR AVAILED
401	29-Sep-21	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	10:28	10:38	0:10	LINE CLEAR AVAILED
402	29-Sep-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	7:45	8:10	0:25	LINE FAULT
403	29-Sep-21	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	23:58(28.09.2021)	12:12 (29.09.2021)	12:13 hrs	LINE CHARGED
404	29-Sep-21	HASSAN	110	HV1	PUTTUR_110	10:56	12:15	1:19	LINE CLEAR AVAILED
405	29-Sep-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
406	29-Sep-21	HASSAN	110	HV2	PUTTUR_110	12:16	13:12	0:56	LINE CLEAR AVAILED
407	29-Sep-21	HASSAN	110	HV3	PUTTUR_110	13:16	15:09	1:53	LINE CLEAR AVAILED
408	29-Sep-21	HASSAN	110	HV4	PUTTUR_110	15:09	17:45	2:36	LINE CLEAR AVAILED
409	29-Sep-21	HASSAN	110	JOG110-LPH	JOG_110	9:53(8.09.2021)	17:30(29.09.2021)	511:36 hrs	NFBC ISSUED
410	29-Sep-21	HASSAN	110	JOG110-LPH	JOG_110	18:35(29.09.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
411	29-Sep-21	HASSAN	110	KAVOOR-KVR-AMR	KAVOOR_220	1:15	13:38	12:23	LINE FAULT
412	29-Sep-21	HASSAN	110	LPH-MGHE 2	lph_gen	14:15(29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
413	29-Sep-21	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	11:05	16:05	5:00	NFBC ISSUED
414	29-Sep-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	23:15(28.09.2021)	16:12(29.09.2021)	16:56 hrs	LINE CHARGED
415	29-Sep-21	HASSAN	220	HBUNJE-KEMAR	HEGGUNJE_220	11:33	14:31	2:58	LINE CLEAR AVAILED
416	29-Sep-21	HASSAN	220	KEMAR-HEGUNJE	KEMAR_220	11:33	14:31	2:58	NFBC ISSUED
417	29-Sep-21	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	8:32 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
418	29-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	23:15 (27.09.2021)	16:12(29.09.2021)	16:56 hrs	LINE CHARGED
419	29-Sep-21	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	7:27	9:00	1:33	NFBC ISSUED
420	29-Sep-21	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	11:05(28.09.2021)	14:34 (29.09.2021)	27:28 hrs	LINE CHARGED
421	29-Sep-21	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	12:26	14:35	2:09	LINE CLEAR AVAILED
422	29-Sep-21	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	14:12	17:16	3:04	LINE CLEAR AVAILED
423	29-Sep-21	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	14:12	17:16	3:04	HAND TRIPPED
424	29-Sep-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
425	29-Sep-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:11	13:19	1:08	LINE FAULT
426	29-Sep-21	MYSURU	66	BESAGARALLI-DUDDENHALLY	NO STATIONS EFFECTED	8:47	9:44	0:57	LINE CLEAR AVAILED
427	29-Sep-21	MYSURU	66	CR NAGAR-YALANDUR	NO STATIONS EFFECTED	10:18	10:25	0:07	LINE FAULT
428	29-Sep-21	MYSURU	66	DK MAIDANA-VAJAMANGALA	NO STATIONS EFFECTED	18:32	22:14	3:41	LOAD CHANGE OVER
429	29-Sep-21	MYSURU	66	FTS-HOOTGALLY 1	NO STATIONS EFFECTED	6:31:29 (29/09/2021)			LINE OPEN:LINE CLEAR AVAILED
430	29-Sep-21	MYSURU	66	FTS-HOOTGALLY 1	NO STATIONS EFFECTED	6:31:24 (29/09/2021)			LINE OPEN:LINE CLEAR AVAILED
431	29-Sep-21	MYSURU	66	G UKKADA-SR PATNA	NO STATIONS EFFECTED	6:33	18:02	11:28	LINE CLEAR AVAILED
432	29-Sep-21	MYSURU	66	HV1	GUNDULPET_66	13:13	14:35	1:22	LINE CLEAR AVAILED
433	29-Sep-21	MYSURU	66	HV2	KIKKERI_66	11:47	18:00	6:12	LINE CLEAR AVAILED
434	29-Sep-21	MYSURU	66	HV2	KIRUGAVALU_66	15:51	16:33	0:41	LINE CLEAR AVAILED
435	29-Sep-21	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	11:48	16:38	4:50	HAND TRIPPED
436	29-Sep-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
437	29-Sep-21	MYSURU	66	SFC SHIVA-HEBBANI 1	NO STATIONS EFFECTED	9:26	13:47	4:21	NFBC ISSUED
438	29-Sep-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18(23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
439	29-Sep-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
440	29-Sep-21	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	11:19	15:41	4:22	NFBC ISSUED
441	29-Sep-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	2:32	2:38	0:05	LINE FAULT
442	29-Sep-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:23	9:33	0:10	LINE FAULT
443	29-Sep-21	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	10:40	10:48	0:07	HAND TRIPPED
444	29-Sep-21	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	10:39	10:45	0:06	LINE FAULT
445	29-Sep-21	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	16:23	16:41	0:17	HAND TRIPPED
446	29-Sep-21	TUMKUR	66	TR-1	BHARAMGIRI_66	13:28	13:33	0:05	TRANSFORMER FAULT
447	29-Sep-21	TUMKUR	66	TR-1	GOWRASAMUDRA_66	9:59	10:44	0:45	LINE CLEAR AVAILED
448	29-Sep-21	TUMKUR	66	TR-1	KORA_66	12:29	13:17	0:47	LINE CLEAR AVAILED
449	29-Sep-21	TUMKUR	66	TR-1	PAVAGADA_220	14:40	14:46	0:06	TRANSFORMER FAULT
450	29-Sep-21	TUMKUR	66	TR-1	PAVAGADA_220	15:23	15:36	0:13	TRANSFORMER FAULT
451	29-Sep-21	TUMKUR	66	TR-1	SOKKE_66	16:23	16:28	0:05	HAND TRIPPED
452	29-Sep-21	TUMKUR	66	TR-1	SOKKE_66	16:38	16:41	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
453	29-Sep-21	TUMKUR	66	TR-2	BHARAMGIRI_66	12:37	12:41	0:03	TRANSFORMER FAULT
454	29-Sep-21	TUMKUR	66	TR-2	KORA_66	11:16	14:39	3:22	LINE CLEAR AVAIED
455	29-Sep-21	TUMKUR	66	TR-2	KORATAGERE_66	1:37	17:03	15:25	TRANSFORMER FAULT
456	29-Sep-21	TUMKUR	110	TR-1	BIDAREGERE_110	13:04	14:02	0:58	LINE CLEAR AVAIED
457	29-Sep-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	15:45	17:58	2:13	LINE CLEAR AVAIED
458	29-Sep-21	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	15:45	17:57	2:12	LINE CLEAR AVAIED
459	29-Sep-21	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	11:33	18:56	7:23	LINE CLEAR AVAIED
460	30-Sep-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAIED
461	30-Sep-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAIED
462	30-Sep-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAIED
463	30-Sep-21	BAGALKOT	110	110/11KV, HV1	MAMADAPUR(B)_110	16:14	19:12	2:58	LINE CLEAR AVAIED
464	30-Sep-21	BAGALKOT	110	110/11KV, HV1	GADAG_110	10:06	17:42	7:36	LINE CLEAR AVAIED
465	30-Sep-21	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	13:34	13:56	0:22	TRANSFORMER FAULT
466	30-Sep-21	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	16:00	16:14	0:14	HAND TRIPPED
467	30-Sep-21	BAGALKOT	110	110/11KV, HV2	KANABARGI LAYOUT_110	11:29	14:30	3:01	LINE CLEAR AVAIED
468	30-Sep-21	BAGALKOT	110	110/11KV, HV2	KIADB BIJAPUR_110	15:30	16:00	0:30	LINE CLEAR AVAIED
469	30-Sep-21	BAGALKOT	110	110/11KV,HV1	ANMOD_110	11:30	12:20	0:50	LINE CLEAR AVAIED
470	30-Sep-21	BAGALKOT	110	110/11KV,HV1	GANESHGUDI_110	11:20	14:35	3:15	LINE CLEAR AVAIED
471	30-Sep-21	BAGALKOT	110	110/11KV,HV1	MANTUR_110	19:50	19:55	0:05	TRANSFORMER FAULT
472	30-Sep-21	BAGALKOT	110	110/11KV,HV1	INDI_220	9:00	18:55	9:55	LINE CLEAR AVAIED
473	30-Sep-21	BAGALKOT	110	110/11KV,HV2	GANESHGUDI_110	11:22	14:37	3:15	LINE CLEAR AVAIED
474	30-Sep-21	BAGALKOT	110	110/11KV,HV2	INDI_220	9:00	19:30	10:30	LINE CLEAR AVAIED
475	30-Sep-21	BAGALKOT	110	110/33KV, HV1	YARAGATTI_110, SHIVAPUR_33, SINCHANUR_33	10:20	10:44	0:24	HAND TRIPPED
476	30-Sep-21	BAGALKOT	110	110/33KV, HV2	HIREKERUR_110, KODA_33, CHIKKERUR_33	13:23	14:04	0:41	LINE CLEAR AVAIED
477	30-Sep-21	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	19:29	20:58	1:29	TRANSFORMER FAULT
478	30-Sep-21	BAGALKOT	110	110/33KV, HV3	KIADB BIJAPUR_110, NAGTHAN_33, HONNATAGI_33	16:01	16:27	0:26	LINE CLEAR AVAIED
479	30-Sep-21	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
480	30-Sep-21	BAGALKOT	110	220/110KV,LV1	STATION NOT AFFECTED BIJAPUR_220	15:03	15:12	0:09	LINE CLEAR AVAIED
481	30-Sep-21	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED BIJAPUR_220	15:26	15:32	0:06	LINE CLEAR AVAIED
482	30-Sep-21	BAGALKOT	110	ALMEL-CHANDAKAVATE	CHANDAKAVATE	16:45	16:50	0:05	LINE FAULT
483	30-Sep-21	BAGALKOT	110	AMBEWADI-GANESHGUDI	GANESHGUDI_110	11:16	14:18	3:02	LINE CLEAR AVAIED
484	30-Sep-21	BAGALKOT	110	AMBEWADI-SUPA1	STATION NOT AFFECTED AMBEWADI_220	11:16	14:20	3:04	LINE CLEAR AVAIED
485	30-Sep-21	BAGALKOT	110	AMBEWADI-SUPA2	STATION NOT AFFECTED AMBEWADI_220	11:16	14:20	3:04	LINE CLEAR AVAIED
486	30-Sep-21	BAGALKOT	110	ATHANI-MAHALINGAPUR	MAHALINGAPUR_220	9:05	22:43	13:38	LINE CLEAR AVAIED
487	30-Sep-21	BAGALKOT	110	BIJAPUR-BIJAPUR CITY	STATION NOT AFFECTED BIJAPUR_220	15:15	15:17	0:02	LINE CLEAR AVAIED
488	30-Sep-21	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	STATION NOT AFFECTED BIJAPUR_220	15:19	15:23	0:04	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
489	30-Sep-21	BAGALKOT	110	BIJAPUR-KAIDB BIJAPUR1	STATION NOT AFFECTED BIJAPUR_220	15:17	15:18	0:01	LINE CLEAR AVOIDED
490	30-Sep-21	BAGALKOT	110	BIJAPUR-KAIDB BIJAPUR2	STATION NOT AFFECTED BIJAPUR_220	15:13	15:15	0:02	LINE CLEAR AVOIDED
491	30-Sep-21	BAGALKOT	110	CHIKKODI-ANKALI	STATION NOT AFFECTED CHIKKODI_220	22:30	22:50	0:20	LINE FAULT
492	30-Sep-21	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
493	30-Sep-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
494	30-Sep-21	BAGALKOT	110	INDI220-INDI	INDI_110	9:27	18:55	9:28	LINE CLEAR AVOIDED
495	30-Sep-21	BAGALKOT	110	INDI220-LACHYAN	LACHYAN_110,HIREBEVANUR_110,ROD AGI_110	9:24	19:20	9:56	LINE CLEAR AVOIDED
496	30-Sep-21	BAGALKOT	110	INDI220-ZALKI1&2	ZALKI_110,CHADCHAN_110,INCHIGERI_ 110	9:20	19:20	10:00	LINE CLEAR AVOIDED
497	30-Sep-21	BAGALKOT	110	INDI-DEVARAHIPPARAGI	DEVARAHIPPARAGI_110,ATHARGA_110, HIREMASALI_110	9:17	19:13	9:56	LINE CLEAR AVOIDED
498	30-Sep-21	BAGALKOT	110	ITNAL-SULTANPUR(HIDKAL)	STATION NOT AFFECTED ITANAL_110	11:32 (25.09.2021)	13:15 (30.09.2021)	1:43	LINE CHARGED
499	30-Sep-21	BAGALKOT	110	JAMKHANDI- MAHALINGAPUR(NAVALAGI)	JAMKHANDI_110	9:17	9:20	0:03	HAND TRIPPED
500	30-Sep-21	BAGALKOT	110	MAHALINGAPUR220- DAVALESHWAR	DAVALESHWAR_110	9:55	20:47	10:52	LINE CLEAR AVOIDED
501	30-Sep-21	BAGALKOT	110	MAHALINGAPUR220- RANNABELAGALI	RANNABELAGALI_110	20:08	20:37	0:29	HAND TRIPPED
502	30-Sep-21	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	STATION NOT AFFECTED BANAHATTI_110	9:00	22:13	13:13	LINE CLEAR AVOIDED
503	30-Sep-21	BAGALKOT	110	MAHALINGAPUR-ITNAL	STATION NOT AFFECTED ITNAL_110	9:00	10:14	1:14	HAND TRIPPED
504	30-Sep-21	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	STATION NOT AFFECTED RANNABELAGALI	8:59	10:05	1:06	HAND TRIPPED
505	30-Sep-21	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	STATION NOT AFFECTED RANNABELAGALI	20:10	20:45	0:35	HAND TRIPPED
506	30-Sep-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
507	30-Sep-21	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
508	30-Sep-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
509	30-Sep-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
510	30-Sep-21	BAGALKOT	110	SUPA-ANMOD	ANMOD_110	11:16	14:25	3:09	MAIN SUPPLY FAILURE
511	30-Sep-21	BAGALKOT	220	220/110KV,HV1	INDI_220	9:00	18:52	9:52	LINE CLEAR AVOIDED
512	30-Sep-21	BAGALKOT	220	220/110KV,HV2	INDI_220	9:00	19:14	10:14	LINE CLEAR AVOIDED
513	30-Sep-21	BAGALKOT	220	220/110KV,HV2,LV2,HV1,LV1	MAHALINGAPUR_220,BANAHATTI_110, DAVALESHWAR_110,GSML2	9:15	20:48	11:33	LINE CLEAR AVOIDED
514	30-Sep-21	BAGALKOT	220	220/110KV,HV3,LV3	MAHALIONGAPUR_220,RABAKAVI_110	9:25	20:45	11:20	LINE CLEAR AVOIDED
515	30-Sep-21	BAGALKOT	220	ATHANI-MAHALINGAPUR	STATION NOT AFFECTED ATHANI_220	9:07	22:43	13:36	NFBC ISSUED
516	30-Sep-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:22 (20.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
517	30-Sep-21	BAGALKOT	220	BIJAPUR-INDI1	STATION NOT AFFECTED BIJAPUR_220	9:22	18:44	9:22	LINE CLEAR AVOIDED
518	30-Sep-21	BAGALKOT	220	BIJAPUR-INDI2	STATION NOT AFFECTED BIJAPUR_220	9:21	18:45	9:24	LINE CLEAR AVOIDED
519	30-Sep-21	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	15:51	16:02	0:11	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
520	30-Sep-21	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	9:50 (30.09.2021)			LINE OPEN:LINE CLEAR AVAILED
521	30-Sep-21	BAGALKOT	220	INDI-SAVALSANG	INDI_220	9:04	18:55	9:51	LINE CLEAR AVAILED
522	30-Sep-21	BAGALKOT	220	INDI-VIJAYAPUR1	INDI_220	9:04	18:50	9:46	LINE CLEAR AVAILED
523	30-Sep-21	BAGALKOT	220	INDI-VIJAYAPUR2	INDI_220	9:04	18:50	9:46	LINE CLEAR AVAILED
524	30-Sep-21	BAGALKOT	220	KARWAR-KADRA2	STATION NOT AFFECTED KARWAR_220	9:00	16:48	7:48	NFBC ISSUED
525	30-Sep-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	12:55 (19.09.2021)			LINE OPEN:LINE FAULT
526	30-Sep-21	BAGALKOT	220	MAHALINGAPUR -NARENDRA1	MAHALINGAPUR_220	9:00	20:03	11:03	LINE CLEAR AVAILED
527	30-Sep-21	BAGALKOT	220	MAHALINGAPUR -SOUDATTI	MAHALINGAPUR_220	9:15	20:34	11:19	LINE CLEAR AVAILED
528	30-Sep-21	BAGALKOT	220	MAHALINGAPUR-KUDUCHI	MAHALINGAPUR_220	9:05 (30.09.2021)			LINE OPEN:LINE CLEAR AVAILED
529	30-Sep-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
530	30-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
531	30-Sep-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	9:49 (30.09.2021)			LINE OPEN:LINE CLEAR AVAILED
532	30-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:06 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
533	30-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:07 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
534	30-Sep-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	9:15	20:48	11:33	NFBC ISSUED
535	30-Sep-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
536	30-Sep-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
537	30-Sep-21	BENGALURU	66	ABBIGERE - YELAHANKA 220	ABBIGERE	11:31	11:52	0:21	LOAD CURTAILMENT
538	30-Sep-21	BENGALURU	66	ATTUR YELAHANKA - YELAHANKA 220	ATTUR YELAHANKA	11:31	11:44	0:13	LINE FAULT
539	30-Sep-21	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	19:38	19:44	0:06	LOAD CHANGE OVER
540	30-Sep-21	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE, SOMENAHALLI	19:12	19:42	0:30	LOAD CURTAILMENT
541	30-Sep-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI	9:05	9:35	0:30	LINE FAULT
542	30-Sep-21	BENGALURU	66	HV1	EPIP 220	8:23	8:28	0:05	TRANSFORMER FAULT
543	30-Sep-21	BENGALURU	66	HV1	REMCO	20:42	20:45	0:03	LOAD CHANGE OVER
544	30-Sep-21	BENGALURU	66	HV1	SADALI	14:01	14:15	0:14	LINE CLEAR AVAILED
545	30-Sep-21	BENGALURU	66	HV1	TEMAGONDLU	14:43	15:30	0:47	LINE CLEAR AVAILED
546	30-Sep-21	BENGALURU	66	HV1	TAYALUR	12:27	13:40	1:13	LINE CLEAR AVAILED
547	30-Sep-21	BENGALURU	66	HV1	KODIHALLI	8:45	8:55	0:10	TRANSFORMER FAULT
548	30-Sep-21	BENGALURU	66	HV2	PRESTIGE SHANTINIKETHAN	10:01	10:05	0:04	LINE CLEAR AVAILED
549	30-Sep-21	BENGALURU	66	HV2	GANJIGUNTE	16:45	17:23	0:38	LINE CLEAR AVAILED
550	30-Sep-21	BENGALURU	66	HV2	GOWRIBIDANUR 220	16:12	16:22	0:10	TRANSFORMER FAULT
551	30-Sep-21	BENGALURU	66	HV2	MALLASANDRA	12:00	12:05	0:05	LINE CLEAR AVAILED
552	30-Sep-21	BENGALURU	66	HV2	TAYALUR	13:40	14:39	0:59	LINE CLEAR AVAILED
553	30-Sep-21	BENGALURU	66	HV2	TALAGAWARA	13:51	14:28	0:37	TRANSFORMER FAULT
554	30-Sep-21	BENGALURU	66	HV3	HOSKOTE 66	11:00	11:15	0:15	LINE CLEAR AVAILED
555	30-Sep-21	BENGALURU	66	HV3	HOSKOTE 66	21:21	21:40	0:19	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
556	30-Sep-21	BENGALURU	66	KADUBISANAHALLI - CESSNA	ISRO (EHT), KADUBISANAHALLI	10:08	10:26	0:18	LOAD CHANGE OVER
557	30-Sep-21	BENGALURU	66	KHW PARK 220 - SHELL(EHT)	SHELL(EHT)	9:57	15:55	5:58	LINE CLEAR AVAILED
558	30-Sep-21	BENGALURU	66	KODIGEHALLI - BYDRAHALLI	KODIGEHALLI	8:57	9:02	0:05	LINE FAULT
559	30-Sep-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	18:45	18:55	0:10	LOAD CURTAILMENT
560	30-Sep-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:33	18:45	0:12	LOAD CURTAILMENT
561	30-Sep-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:33	19:05	0:32	LOAD CURTAILMENT
562	30-Sep-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	14:36	14:54	0:18	LINE CLEAR AVAILED
563	30-Sep-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	17:12	17:18	0:06	LINE CLEAR AVAILED
564	30-Sep-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	18:50	19:10	0:20	LINE FAULT
565	30-Sep-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	17:01:54(29-9-2021)	17:08(30-9-2021)	0:06	LINE CHARGED
566	30-Sep-21	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	18:55	19:44	0:49	LINE FAULT
567	30-Sep-21	BENGALURU	66	TALAGAWARA - CHINTAMANI 220	TALAGAWARA	13:51	14:09	0:18	LINE FAULT
568	30-Sep-21	BENGALURU	66	TALAGAWARA - Y HUNSENAHALLI	Y HUNSENAHALLI, CHEEMANGLA, VEMGAL	13:51	14:10	0:19	LINE CLEAR AVAILED
569	30-Sep-21	BENGALURU	66	TAYALUR - T GOLLAHALLI 220	TAYALUR, N G HULKUR	12:00	12:35	0:35	LINE CLEAR AVAILED
570	30-Sep-21	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	17:10	17:13	0:03	LOAD CHANGE OVER
571	30-Sep-21	BENGALURU	66	WELCAST STEEL - YELAHANKA 220	WELCAST STEEL	11:31	11:41	0:10	LOAD CURTAILMENT
572	30-Sep-21	BENGALURU	66	YENNIGADALE - CHAKAVELU	CHELUR, CHAKAVELU, SOMANATHPURA	15:35	17:02	1:27	LINE CLEAR AVAILED
573	30-Sep-21	BENGALURU	66	YENNIGADALE - CHINTAMANI 220	YENNIGADALE, CHELUR, CHAKAVELU	10:00	10:15	0:15	LINE CLEAR AVAILED
574	30-Sep-21	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	10:35	11:56	1:21	LINE FAULT
575	30-Sep-21	GULBARGA	66	HV2,HV3	TELAGI_66	8:30	9:10	0:40	LINE CLEAR AVAILED
576	30-Sep-21	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLAU_110,KUDITINI_110,KUR UGOD_110,SHATHAVAHANA_IPP,AGAR WAL_IPP,SUZLON_IPP,KAMALAPUR_IPP ,MATRI_110,RBNS FACTORY	17:51	19:43	1:52	LINE FAULT
577	30-Sep-21	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLAU_110,KUDITINI_110,KUR UGOD_110,SHATHAVAHANA_IPP,AGAR WAL_IPP,SUZLON_IPP,KAMALAPUR_IPP ,MATRI_110,RBNS FACTORY	20:08	20:17	0:09	LINE CLEAR AVAILED
578	30-Sep-21	GULBARGA	110	BISIHALLI-ALLIPUR	BISIHALLI_110	18:00	18:17	0:17	MAIN SUPPLY FAILURE
579	30-Sep-21	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	1:05	1:15	0:10	LINE FAULT
580	30-Sep-21	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	4:38	4:47	0:09	LINE FAULT
581	30-Sep-21	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	5:30	5:40	0:10	MAIN SUPPLY FAILURE
582	30-Sep-21	GULBARGA	110	GURMITKAL-KONKAL	GURUMITKAL_110	0:45	0:55	0:10	LINE CLEAR AVAILED
583	30-Sep-21	GULBARGA	110	HALAKUNDI-ALLIPUR	ALAKUNDI_110	18:00	18:18	0:18	MAIN SUPPLY FAILURE
584	30-Sep-21	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	3:33	3:47	0:14	LINE FAULT
585	30-Sep-21	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	6:40(30.09.21)			LINE OPEN:LINE FAULT
586	30-Sep-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110, DIGGI_110	19:14	19:21	0:07	LINE FAULT
587	30-Sep-21	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	16:35(28.09.2021)			LINE OPEN:LINE CLEAR AVAILED
588	30-Sep-21	GULBARGA	110	HUNSAGI-KEMBHAVI	HUNSAGI_110	19:35	19:50	0:15	MAIN SUPPLY FAILURE
589	30-Sep-21	GULBARGA	110	HV1	RAJESHWAR_110	18:15	18:36	0:21	LOAD CURTAILMENT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
590	30-Sep-21	GULBARGA	110	HV1	RAJESHWAR_110	18:44	18:54	0:10	LOAD CURTAILMENT
591	30-Sep-21	GULBARGA	110	HV1	CHINCHOLLI_110	15:26	16:20	0:54	LINE CLEAR AVAILED
592	30-Sep-21	GULBARGA	110	HV1	GABBUR_110	6:05	6:10	0:05	TRANSFORMER FAULT
593	30-Sep-21	GULBARGA	110	HV1	GABBUR_110	9:05	9:10	0:05	TRANSFORMER FAULT
594	30-Sep-21	GULBARGA	110	HV1	GULBARGA WEST_110	7:19	7:25	0:06	TRANSFORMER FAULT
595	30-Sep-21	GULBARGA	110	HV1	BAYYAPURA_110	11:45	15:25	3:40	LINE CLEAR AVAILED
596	30-Sep-21	GULBARGA	110	HV1	BAYYAPURA_110	13:55	15:30	1:35	LINE CLEAR AVAILED
597	30-Sep-21	GULBARGA	110	HV2	RAJESHWAR_110	18:14	18:30	0:16	LOAD CURTAILMENT
598	30-Sep-21	GULBARGA	110	HV2	SANKLAPUR_110	18:25	18:30	0:05	TRANSFORMER FAULT
599	30-Sep-21	GULBARGA	110	HV2	SHAHAPUR_220	12:25	15:24	2:59	LINE CLEAR AVAILED
600	30-Sep-21	GULBARGA	110	HV2	CHINCHOLLI_110	18:15	18:30	0:15	TRANSFORMER FAULT
601	30-Sep-21	GULBARGA	110	HV2	CHINCHOLLI_110	18:45	19:07	0:22	TRANSFORMER FAULT
602	30-Sep-21	GULBARGA	110	HV2	KAPNOOR_110	11:00	14:30	3:30	LINE CLEAR AVAILED
603	30-Sep-21	GULBARGA	110	HV2	BAYYAPURA_110	11:45	13:25	1:40	LINE CLEAR AVAILED
604	30-Sep-21	GULBARGA	110	HV3	VALKAMDINNI_110	7:47	7:55	0:08	TRANSFORMER FAULT
605	30-Sep-21	GULBARGA	110	HV3	CHINCHOLLI_110	15:26	16:40	1:14	LINE CLEAR AVAILED
606	30-Sep-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	16:40	16:50	0:10	LINE FAULT
607	30-Sep-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	23:50	23:55	0:05	LINE FAULT
608	30-Sep-21	GULBARGA	110	JEAWARI-SHAHPUR	JEWARGI_110	4:30	4:40	0:10	MAIN SUPPLY FAILURE
609	30-Sep-21	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	9:33	10:49	1:16	LINE FAULT
610	30-Sep-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	0:02	0:16	0:14	LINE FAULT
611	30-Sep-21	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110,DEODURGA_110	5:20	5:29	0:09	LINE FAULT
612	30-Sep-21	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110,DEODURGA_110	20:43	20:50	0:07	LINE FAULT
613	30-Sep-21	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	5:20	5:29	0:09	LINE FAULT
614	30-Sep-21	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	20:43	20:50	0:07	LINE FAULT
615	30-Sep-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110	21:25	21:37	0:12	LINE FAULT
616	30-Sep-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	22:32(29.09.2021)	7:30(30.09.2021)	8:58	LINE CHARGED
617	30-Sep-21	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	3:38	3:45	0:07	LINE FAULT
618	30-Sep-21	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	4:08	4:15	0:07	LINE FAULT
619	30-Sep-21	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	4:37	4:42	0:05	LINE FAULT
620	30-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
621	30-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
622	30-Sep-21	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	5:30	5:40	0:10	MAIN SUPPLY FAILURE
623	30-Sep-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	4:02	4:16	0:14	LINE FAULT
624	30-Sep-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	5:45	6:01	0:16	LINE FAULT
625	30-Sep-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	13:28	14:37	1:09	LINE CLEAR AVAILED
626	30-Sep-21	GULBARGA	110	SHAHAPUR-NALWAR	NALWAR_110	20:05	20:10	0:05	LINE FAULT
627	30-Sep-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1 (IDLE LINE)	SHAHAPUR1_110	11:50(30.09.2021)			LINE OPEN:LINE CLEAR AVAILED
628	30-Sep-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	12:44	12:47	0:03	LINE CLEAR AVAILED
629	30-Sep-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	12:42	15:12	2:30	LINE CLEAR AVAILED
630	30-Sep-21	GULBARGA	110	SINDANOOR-TURVIHAL	GANDHINAGAR_110,TURVIHAL_110	20:58	21:08	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
631	30-Sep-21	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	17:50	18:50	1:00	MAIN SUPPLY FAILURE
632	30-Sep-21	GULBARGA	110	TEKKALKOTE-ABMN_SLR	TEKKALKOTE_110	15:50	19:33	3:43	LINE CLEAR AVAILED
633	30-Sep-21	GULBARGA	110	TEKKALKOTE-RERNEW SOLAR	TEKKALKOTE_110	15:50	19:32	3:42	LINE CLEAR AVAILED
634	30-Sep-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	0:25	0:30	0:05	MAIN SUPPLY FAILURE
635	30-Sep-21	GULBARGA	110	YAKATPURA-KAMTHANA	YAKATPURA_110	6:30	6:50	0:20	MAIN SUPPLY FAILURE
636	30-Sep-21	GULBARGA	220	HV1	ALIPUR_220	17:51	18:07	0:16	TRANSFORMER FAULT
637	30-Sep-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
638	30-Sep-21	GULBARGA	220	HV2	ALIPUR_220	17:51	18:28	0:37	TRANSFORMER FAULT
639	30-Sep-21	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	5:31	5:49	0:18	LINE FAULT
640	30-Sep-21	GULBARGA	220	LV2	KAPNOOR_220	9:14	9:17	0:03	LINE CLEAR AVAILED
641	30-Sep-21	GULBARGA	220	LV2	KAPNOOR_220	9:24	10:09	0:45	LINE CLEAR AVAILED
642	30-Sep-21	GULBARGA	220	MALLAT-RTPS	RTPS_220	7:55	15:41	7:46	LINE FAULT
643	30-Sep-21	GULBARGA	220	MALLAT-RTPS	RTPS_220	19:42	20:05	0:23	LINE FAULT
644	30-Sep-21	GULBARGA	220	MALLAT-RTPS	RTPS_220	19:42	20:05	0:23	LINE FAULT
645	30-Sep-21	GULBARGA	220	SEDAM-SHAHAPUR_220	SEDAM_220	22:38	22:54	0:16	LINE FAULT
646	30-Sep-21	GULBARGA	400	RTPS-BTPS	BTPS_400	10:26(30.09.2021)			LINE OPEN:LINE CLEAR AVAILED
647	30-Sep-21	HASSAN	66	HV1	MAGGE_66	23:24(29.09.2021)	0:01(30.9.2021)'0:36	10:42 hrs	TRANSFORMER CHARGED
648	30-Sep-21	HASSAN	66	HV1	HANGARAHALLY_66	18:14	18:25	0:11	LOAD CURTAILMENT
649	30-Sep-21	HASSAN	66	HV1	HOLENARSIPURA_220	13:10	14:06	0:56	LINE CLEAR AVAILED
650	30-Sep-21	HASSAN	66	HV1	MALLAPURA_66	12:02	16:09	4:07	MAIN SUPPLY FAILURE
651	30-Sep-21	HASSAN	66	HV2	BASAVAGATA_66	18:14	18:28	0:14	LOAD CURTAILMENT
652	30-Sep-21	HASSAN	66	HV2	BASAVAGATA_66	18:44	18:56	0:12	LOAD CURTAILMENT
653	30-Sep-21	HASSAN	66	HV2	HOLALUR_66	12:47	16:41	3:54	LINE CLEAR AVAILED
654	30-Sep-21	HASSAN	66	HV2	MALLAPURA_66	12:02	16:09	4:07	MAIN SUPPLY FAILURE
655	30-Sep-21	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	12:02	16:09	4:07	MAIN SUPPLY FAILURE
656	30-Sep-21	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	11:44	15:47	4:03	LINE CLEAR AVAILED
657	30-Sep-21	HASSAN	110	HEGUNJE-HALADY	HEGUNJE_220	11:45	15:39	3:54	NFBC ISSUED
658	30-Sep-21	HASSAN	110	HOSNGD-HULIKAL	HOSANGADI_110	15:47	17:25	1:38	LINE CLEAR AVAILED
659	30-Sep-21	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	14:27	15:31	1:04	LINE CLEAR AVAILED
660	30-Sep-21	HASSAN	110	HV1	DMKURKE_110	18:14	18:25	0:11	LOAD CURTAILMENT
661	30-Sep-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
662	30-Sep-21	HASSAN	110	HV2	GERUMAR	18:15	18:46	0:31	LOAD CURTAILMENT
663	30-Sep-21	HASSAN	110	JOG110-LPH	JOG_110	18:35(29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
664	30-Sep-21	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	10:37	11:07	0:30	LINE FAULT
665	30-Sep-21	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	10:37	11:05	0:28	LINE FAULT
666	30-Sep-21	HASSAN	110	LPH-MGHE 2	lph_gen	14:15(29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
667	30-Sep-21	HASSAN	110	LV2	KAVOOR_220	10:37	11:01	0:24	TRANSFORMER FAULT
668	30-Sep-21	HASSAN	110	MSEZ-GSS31	MSEZ_220	9:55	14:09	4:14	LINE CLEAR AVAILED
669	30-Sep-21	HASSAN	110	MSEZ-GSS32	MSEZ_220	9:55	14:09	4:14	LINE CLEAR AVAILED
670	30-Sep-21	HASSAN	220	HV2	KAVOOR_220	10:37	11:01	0:24	TRANSFORMER FAULT
671	30-Sep-21	HASSAN	220	KAVOOR-KB1	KAVOOR_220	22:50(30.09.2021)			LINE OPEN:LINE CLEAR AVAILED
672	30-Sep-21	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	10:37(30.09.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
673	30-Sep-21	HASSAN	220	MRSSH-M-KBCRS	MRSMSG_220	8:32 (24.09.2021)			LINE OPEN:LINE CLEAR AVAIED
674	30-Sep-21	HASSAN	220	MRSSH-M-SHARAVATHY4	MRSMSG_220	11:19	12:04	0:45	LINE FAULT
675	30-Sep-21	HASSAN	220	MRSSH-M-VARAH3	MRSMSG_220	10:39	11:01	0:22	LINE CLEAR AVAIED
676	30-Sep-21	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	10:36	11:32	0:56	LINE FAULT
677	30-Sep-21	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	10:36(30.09.2021)			LINE OPEN:LINE FAULT
678	30-Sep-21	HASSAN	220	SHRVATY-SHIMOGA4	gen_sharavaty	11:19	12:04	0:45	LINE FAULT
679	30-Sep-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
680	30-Sep-21	MYSURU	66	HV1	NAGAMANGALA_66	18:15	18:24	0:08	LINE CLEAR AVAIED
681	30-Sep-21	MYSURU	66	AKKIHEBBAL-KAVERI HYDRO	NO STATIONS EFFECTED	19:39	21:16	1:37	LINE FAULT
682	30-Sep-21	MYSURU	66	BG NAGARA-NAGMANGLA	HARADANAHALLI_66 BG NAGARA_66 AC GIRI_66 VADERALLI_66	11:35	13:12	1:36	NFBC ISSUED
683	30-Sep-21	MYSURU	66	FTS-HOOTGALLY 1	NO STATIONS EFFECTED	6:31:29 (29/09/2021)			LINE OPEN:LINE CLEAR AVAIED
684	30-Sep-21	MYSURU	66	FTS-HOOTGALLY 2	NO STATIONS EFFECTED	6:31:24 (29/09/2021)			LINE OPEN:LINE CLEAR AVAIED
685	30-Sep-21	MYSURU	66	HV1	BILIKERE_66	18:14	18:31	0:17	LINE CLEAR AVAIED
686	30-Sep-21	MYSURU	66	HV1	DODDINADUWADI_66	18:14	18:25	0:10	LINE CLEAR AVAIED
687	30-Sep-21	MYSURU	66	HV1	HONNALLY_66	15:14	15:17	0:03	HAND TRIPPED
688	30-Sep-21	MYSURU	66	HV1	MADIKERI_66	10:55	12:36	1:41	LINE CLEAR AVAIED
689	30-Sep-21	MYSURU	66	HV1	MYSORE SOUTH_66	19:57	21:12	1:14	LINE CLEAR AVAIED
690	30-Sep-21	MYSURU	66	HV1	GV GUDI_66	11:10:00 (30.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAIED
691	30-Sep-21	MYSURU	66	HV2	ADDIHALLI_66	18:44	18:49	0:05	LINE CLEAR AVAIED
692	30-Sep-21	MYSURU	66	HV2	AKKIHEBBAL_66	18:45	18:55	0:10	LINE CLEAR AVAIED
693	30-Sep-21	MYSURU	66	HV2	BOOKANAKERE_66	18:44	18:49	0:05	LINE CLEAR AVAIED
694	30-Sep-21	MYSURU	66	HV2	HANNUR_66	15:01	15:08	0:07	TRANSFORMER FAULT
695	30-Sep-21	MYSURU	66	HV2	HDKOTE_66	18:14	18:25	0:10	LINE CLEAR AVAIED
696	30-Sep-21	MYSURU	66	HV2	HULLAHALLI_66	16:55	17:45	0:50	LINE CLEAR AVAIED
697	30-Sep-21	MYSURU	66	HV2	JAIPURA_66	18:16	18:24	0:08	LINE CLEAR AVAIED
698	30-Sep-21	MYSURU	66	HV2	KM DODDI_66	18:15	18:24	0:09	LINE CLEAR AVAIED
699	30-Sep-21	MYSURU	66	HV2	KM DODDI_66	18:44	18:59	0:15	LINE CLEAR AVAIED
700	30-Sep-21	MYSURU	66	HV2	KOLLEGALA_66	18:15	18:17	0:02	LINE CLEAR AVAIED
701	30-Sep-21	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	10:21	10:46	0:24	HAND TRIPPED
702	30-Sep-21	MYSURU	66	KR PETE 220-CRPATNA	ANEGOLA_66 KRISHNAPURA_66	19:39	19:48	0:09	LINE FAULT
703	30-Sep-21	MYSURU	66	KR PETE 220-KR PETE1	NO STATIONS EFFECTED	19:39	19:49	0:09	LINE FAULT
704	30-Sep-21	MYSURU	66	KR PETE 220-KR PETE1	KR PETE_66 KIKKERI_66 AKKIHEBBAL_66	20:19	20:25	0:05	LINE FAULT
705	30-Sep-21	MYSURU	66	KR PETE 220-KR PETE2	NO STATIONS EFFECTED	20:19	20:31	0:11	LINE FAULT
706	30-Sep-21	MYSURU	66	KR PETE-HUYGONALLY 2	KR PETE_66 KIKKERI_66 AKKIHEBBAL_66	19:39	20:00	0:20	LINE FAULT
707	30-Sep-21	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	ALURSIDDAPURA_66 KANGAL_66 CB HALLI_66 RUDRAPATNA_66	5:41	5:46	0:04	LINE FAULT
708	30-Sep-21	MYSURU	66	MADHUVANAHALLIHEBBANI	NO STATIONS EFFECTED	16:44	16:50	0:05	LINE FAULT
709	30-Sep-21	MYSURU	66	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	12:04	12:44	0:39	LINE CLEAR AVAIED
710	30-Sep-21	MYSURU	66	NAGAMANGALA -JAKKANAHALLI	G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI_66 NAGAMANGALA_66 .	11:37	13:25	1:47	NFBC ISSUED
711	30-Sep-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
712	30-Sep-21	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	16:43	16:46	0:03	LINE FAULT
713	30-Sep-21	MYSURU	66	SFC SIVA-5MW	NO STATIONS EFFECTED	16:43	16:45	0:02	LINE FAULT
714	30-Sep-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	11:50	12:50	1:00	NFBC ISSUED
715	30-Sep-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
716	30-Sep-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
717	30-Sep-21	MYSURU	220	HV2	KR PETE_220	21:32:00 (30.09.2021)	0:22:00 (1.10.2021)	2:50	TRANSFORMER CHARGED
718	30-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	9:47	10:28	0:40	LINE FAULT
719	30-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	11:10	12:44	1:34	LINE FAULT
720	30-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	18:57	19:30	0:33	LOAD CURTAILMENT
721	30-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA	KOLALA_66, URDIGERE_66	18:57	19:30	0:33	LOAD CURTAILMENT
722	30-Sep-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	18:51	19:18	0:27	LOAD CURTAILMENT
723	30-Sep-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	1:37	1:45	0:08	LINE FAULT
724	30-Sep-21	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	NIDSALE_66,DUNDANAHALLI_66	14:39	15:38	0:59	LINE CLEAR AVAILED
725	30-Sep-21	TUMKUR	66	KATTIGE- RENEW WIND ENERGY_IPP_66	RENEW WIND ENERGY_IPP_66	12:22	16:02	3:40	MAIN SUPPLY FAILURE
726	30-Sep-21	TUMKUR	66	KATTIGE66-HONNALLI220	KATTIGE_66	12:20	16:01	3:41	MAIN SUPPLY FAILURE
727	30-Sep-21	TUMKUR	66	KORATAGERE66-MADHUGIRI	KORATAGERE_66	10:21	14:41	4:19	LINE CLEAR AVAILED
728	30-Sep-21	TUMKUR	66	KORATAGERE-HOLAVANHALLI	KORATAGERE_66	10:21	14:48	4:27	LINE CLEAR AVAILED
729	30-Sep-21	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE	KORATAGERE_66,HOLAVINAHALLY_66	9:45	14:36	4:51	LINE CLEAR AVAILED
730	30-Sep-21	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66,PANCHANAHALLI_66	13:02	13:04	0:02	LINE FAULT
731	30-Sep-21	TUMKUR	66	TR-1	BELLAVI_66	9:42	9:43	0:01	LINE CLEAR AVAILED
732	30-Sep-21	TUMKUR	66	TR-1	HONNALLI_66	14:19	15:32	1:12	LINE CLEAR AVAILED
733	30-Sep-21	TUMKUR	66	TR-1	KATTIGE_66	12:16	16:02	3:45	MAIN SUPPLY FAILURE
734	30-Sep-21	TUMKUR	66	TR-1	MELEKOTE_66	16:15	18:50	2:35	LINE CLEAR AVAILED
735	30-Sep-21	TUMKUR	66	TR-1	NIDSALE_66	15:43	15:44	0:01	LINE CLEAR AVAILED
736	30-Sep-21	TUMKUR	66	TR-2	BHARAMGIRI_66	12:47	12:57	0:10	TRANSFORMER FAULT
737	30-Sep-21	TUMKUR	66	TR-2	BHARAMGIRI_66	14:14	14:17	0:02	TRANSFORMER FAULT
738	30-Sep-21	TUMKUR	66	TR-2	HONNALLI_66	14:19	15:32	1:12	LINE CLEAR AVAILED
739	30-Sep-21	TUMKUR	66	TR-2	HOSAKERE_66	11:11	12:37	1:26	MAIN SUPPLY FAILURE
740	30-Sep-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	16:39	19:38	2:59	LINE CLEAR AVAILED
741	30-Sep-21	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	16:41	19:38	2:57	HAND TRIPPED
742	1-Oct-21	BAGALKOT	66	66/11KV, HV1	STATION NOT AFFECTED HARIHAR HOSPET_66	12:54	17:30	4:36	LINE CLEAR AVAILED
743	1-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
744	1-Oct-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
745	1-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
746	1-Oct-21	BAGALKOT	110	110/11KV, HV1	SOUDATTI_220	17:42	18:35	0:53	HAND TRIPPED
747	1-Oct-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED YARAGATTI_110	17:42	18:54	1:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
748	1-Oct-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YARAGATTI_110	16:57	17:41	0:44	LINE CLEAR AVOIDED
749	1-Oct-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RANNABELAGALI_110	13:57	14:20	0:23	TRANSFORMER FAULT
750	1-Oct-21	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	14:48	15:10	0:22	TRANSFORMER FAULT
751	1-Oct-21	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	23:40 (01.10.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
752	1-Oct-21	BAGALKOT	110	110/11KV, HV1	LKMANAHALLI_110	14:55	15:23	0:28	LINE CLEAR AVOIDED
753	1-Oct-21	BAGALKOT	110	110/11KV, HV1	LAKKMANAHALLI_110	17:48	17:52	0:04	LINE CLEAR AVOIDED
754	1-Oct-21	BAGALKOT	110	110/11KV, HV2	ALMEL_110	9:58	10:19	0:21	LINE CLEAR AVOIDED
755	1-Oct-21	BAGALKOT	110	110/11KV, HV2	LAKKMANAHALLI_110	16:15	17:09	0:54	LINE CLEAR AVOIDED
756	1-Oct-21	BAGALKOT	110	110/11KV, HV2(HV4)	GAJENDRAGAD_110	10:06	15:00	4:54	LINE CLEAR AVOIDED
757	1-Oct-21	BAGALKOT	110	110/33KV, HV2	SODATTI_110	10:05	16:25	6:20	LINE CLEAR AVOIDED
758	1-Oct-21	BAGALKOT	110	110/33KV, HV1(HV5)	WIND1&WIND2 GAJENDRAGAD_110	16:05	16:45	0:40	TRANSFORMER FAULT
759	1-Oct-21	BAGALKOT	110	110/33KV, HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
760	1-Oct-21	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED BIJAPUR_220	10:33	10:34	0:01	HAND TRIPPED
761	1-Oct-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED BIJAPUR_220	10:46	10:50	0:04	HAND TRIPPED
762	1-Oct-21	BAGALKOT	110	ATHARGA-KNLSLR	ATHARGA_110	9:08	17:20	8:12	LINE FAULT
763	1-Oct-21	BAGALKOT	110	BELGAUM220- ANKALAGI(HUDLI)	HUDLI_110	11:58	18:04	6:06	HAND TRIPPED
764	1-Oct-21	BAGALKOT	110	BELGAUM220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	11:55	12:52	0:57	LINE FAULT
765	1-Oct-21	BAGALKOT	110	BIJAPUR220-BIJAPUR CITY	STATION NOT AFFECTED BIJAPUR_220	10:39	10:40	0:01	HAND TRIPPED
766	1-Oct-21	BAGALKOT	110	BIJAPUR220-ENERCON(BAGEWADI)	STATION NOT AFFECTED BIJAPUR_220	10:37	10:38	0:01	HAND TRIPPED
767	1-Oct-21	BAGALKOT	110	BIJAPUR-KIADB1	STATION NOT AFFECTED BIJAPUR_220	10:35	0:00	13:25	HAND TRIPPED
768	1-Oct-21	BAGALKOT	110	BIJAPUR-KIADB2	STATION NOT AFFECTED BIJAPUR_220	10:40	10:41	0:01	HAND TRIPPED
769	1-Oct-21	BAGALKOT	110	BILAGI-BISANAL	BISANAL_110	3:45	3:50	0:05	MAIN SUPPLY FAILURE
770	1-Oct-21	BAGALKOT	110	BILAGI-GIRISAGARA	GIRISAGARA_110	4:15	4:20	0:05	MAIN SUPPLY FAILURE
771	1-Oct-21	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	20:40	20:50	0:10	LINE FAULT
772	1-Oct-21	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
773	1-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
774	1-Oct-21	BAGALKOT	110	HATTARAGI-DADDI(BELGAUM)	DADDI_110	20:40	21:35	0:55	HAND TRIPPED
775	1-Oct-21	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110	21:32	21:35	0:03	LINE FAULT
776	1-Oct-21	BAGALKOT	110	JAMAKHANDI(NAVALAGI)-BANAHATTI	NAVALAGI_110,BANAHATTI_110	17:43	18:45	1:02	LINE FAULT
777	1-Oct-21	BAGALKOT	110	KERUR-KONNUR	KERUR_110	17:25	18:22	0:57	LINE CLEAR AVOIDED
778	1-Oct-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	JAMAKHANDI_110	18:07 (01.10.2021)			LINE OPEN:LINE CLEAR AVOIDED
779	1-Oct-21	BAGALKOT	110	MAHALINGAPUR-DAVALESHWAR	DAVALESHWAR_110	17:43	18:30	0:47	HAND TRIPPED
780	1-Oct-21	BAGALKOT	110	MUGALKHOD-(LN2)RAIBAG	MUGALKHOD_110	20:0 (01.10.2021)			LINE OPEN:LINE FAULT
781	1-Oct-21	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	20:55	21:01	0:06	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
782	1-Oct-21	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH IPP_110 STATION NOT AFFECTED SAVANUR_110	18:39	18:45	0:06	LINE FAULT
783	1-Oct-21	BAGALKOT	110	SHIRAGUPPI-BILAGI	SHIRAGUPPI_110	3:45	3:55	0:10	LINE FAULT
784	1-Oct-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
785	1-Oct-21	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
786	1-Oct-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVOIDED
787	1-Oct-21	BAGALKOT	110	SOUDATTI220- ARATAGAL	ARATAGAL_110	17:45	18:40	0:55	MAIN SUPPLY FAILURE
788	1-Oct-21	BAGALKOT	110	SOUDATTI220- BENAKATTI	BENAKATTI_110	17:42	18:47	1:05	HAND TRIPPED
789	1-Oct-21	BAGALKOT	110	SOUDATTI220- BENAKATTI	BENAKATTI_110	17:45	18:50	1:05	MAIN SUPPLY FAILURE
790	1-Oct-21	BAGALKOT	110	SOUDATTI220- KADAKOL	KADAKOL_110	17:45	18:50	1:05	MAIN SUPPLY FAILURE
791	1-Oct-21	BAGALKOT	110	SOUDATTI220- MMCL1	SOUDATTI_220	17:42	19:17	1:35	MAIN SUPPLY FAILURE
792	1-Oct-21	BAGALKOT	110	SOUDATTI220- MMCL2	SOUDATTI_220	17:45	19:25	1:40	MAIN SUPPLY FAILURE
793	1-Oct-21	BAGALKOT	110	SOUDATTI220- MUNAVALLI	MUNAVALLI_110	17:42	18:40	0:58	HAND TRIPPED
794	1-Oct-21	BAGALKOT	110	SOUDATTI220- MUNAVALLI	MUNAVALLI_110	17:40	18:40	1:00	MAIN SUPPLY FAILURE
795	1-Oct-21	BAGALKOT	110	SOUDATTI220- RAMDURGA1	RAMDURGA_110	17:42	18:59	1:17	HAND TRIPPED
796	1-Oct-21	BAGALKOT	110	SOUDATTI220- RAMDURGA2	RAMDURGA_110	17:42	18:59	1:17	HAND TRIPPED
797	1-Oct-21	BAGALKOT	110	SOUDATTI220- SOUDATTI1	SOUDATTI_110	17:42	18:38	0:56	HAND TRIPPED
798	1-Oct-21	BAGALKOT	110	SOUDATTI220- SOUDATTI1	SOUDATTI_110	17:45	18:40	0:55	MAIN SUPPLY FAILURE
799	1-Oct-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)	16:57 (01.10.2021)	8:22	NFBC ISSUED
800	1-Oct-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	17:42	19:16	1:34	HAND TRIPPED
801	1-Oct-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	10:05	10:15	0:10	LINE CLEAR AVOIDED
802	1-Oct-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	110KV SAUNDATTI	17:45	19:16	1:31	MAIN SUPPLY FAILURE
803	1-Oct-21	BAGALKOT	110	SOUDATTI220- UDAKERI	UDAKERI_110	17:42	18:51	1:09	HAND TRIPPED
804	1-Oct-21	BAGALKOT	110	VAJRAMATTI-SHIRAGUPPI	SHIRAGUPPI_110	3:45	3:50	0:05	LINE FAULT
805	1-Oct-21	BAGALKOT	220	220/110KV, HV1	CHIKKODI_220	11:32 (01.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
806	1-Oct-21	BAGALKOT	220	220/110KV, HV1&LV1	SOUDATTI_220	17:42	18:33	0:51	MAIN SUPPLY FAILURE
807	1-Oct-21	BAGALKOT	220	220/110KV, HV2&LV2	SOUDATTI_220	17:42	18:33	0:51	MAIN SUPPLY FAILURE
808	1-Oct-21	BAGALKOT	220	ATHANI- MAHALINGAPUR	ATHANI_220	13:48	14:18	0:30	LINE FAULT
809	1-Oct-21	BAGALKOT	220	ATHANI- MAHALINGAPUR	ATHANI_220	17:06 (01.10.2021)			LINE OPEN:LINE CLEAR AVOIDED
810	1-Oct-21	BAGALKOT	220	BAGALKOT- GADAG1	BAGALKOT_220	12:03	12:59	0:56	LINE FAULT
811	1-Oct-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:22 (20.09.2021)	12:22 (01.10.2021)	2:00	LINE CHARGED
812	1-Oct-21	BAGALKOT	220	BELGAUM- CHIKKODI1	BELGAUM_220	14:00	15:08	1:08	HAND TRIPPED
813	1-Oct-21	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	17:01	22:03	5:02	LINE FAULT
814	1-Oct-21	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	22:03 (01.10.2021)			LINE OPEN:LINE FAULT
815	1-Oct-21	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	16:12	20:25	4:13	LINE FAULT
816	1-Oct-21	BAGALKOT	220	BIJAPUR220-INDI2	STATION NOT AFFECTED BIJAPUR_220	12:07	20:47	8:40	LINE CLEAR AVOIDED
817	1-Oct-21	BAGALKOT	220	GUTTUR- RANEBENNUR	RANEBENNUR_220	21:58	22:26	0:28	LINE FAULT
818	1-Oct-21	BAGALKOT	220	HAVERI- GUTTUR1	HAVERI_220	18:39 (01.10.2021)			LINE OPEN:LINE FAULT
819	1-Oct-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	11:31	14:08	2:37	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
820	1-Oct-21	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	9:50 (30.09.2021)	16:40 (01.10.2021)	6:50	LINE CHARGED
821	1-Oct-21	BAGALKOT	220	KUDACHI- CHIKKODI1	KUDACHI_220	16:26	18:01	1:35	HAND TRIPPED
822	1-Oct-21	BAGALKOT	220	KUDACHI- CHIKKODI2	KUDACHI_220	16:25	18:04	1:39	HAND TRIPPED
823	1-Oct-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	12:55 (19.09.2021)	16:02 (01.10.2021)	3:07	LINE CHARGED
824	1-Oct-21	BAGALKOT	220	MAHALINGAPUR-KUDUCHI	STATION NOT AFFECTED MAHALINGAPUR_220	9:05 (30.09.2021)	16:00 (01.10.2021)	6:55	LINE CHARGED
825	1-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
826	1-Oct-21	BAGALKOT	220	NARENDA220- SHEDBAL	SHEDBAL_110	16:42	18:17	1:35	LINE CLEAR AVAILED
827	1-Oct-21	BAGALKOT	220	NARENDRA- BELGAUM1	NARENDRA_220	11:57	14:06	2:09	LINE FAULT
828	1-Oct-21	BAGALKOT	220	NARENDRA- BELGAUM2	NARENDRA_220	11:26	17:46	6:20	LINE FAULT
829	1-Oct-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	11:31	14:09	2:38	LINE FAULT
830	1-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
831	1-Oct-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	9:49 (30.09.2021)	16:39 (01.10.2021)	6:50	LINE CHARGED
832	1-Oct-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:06 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
833	1-Oct-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:07 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
834	1-Oct-21	BAGALKOT	220	SOUDATTI- BIDNAL	SOUDATTI_220	16:11	20:25	4:14	LINE FAULT
835	1-Oct-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	13:47	14:39	0:52	LINE FAULT
836	1-Oct-21	BAGALKOT	220	VAJRAMATTI- KUDAGI1	VAJRAMATTI_220	11:54	13:19	1:25	LINE FAULT
837	1-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
838	1-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
839	1-Oct-21	BENGALURU	66	BAGHMANE TECH PARK - HAL 220	BAGHMANE TECH PARK	10:10	15:45	5:35	LINE CLEAR AVAILED
840	1-Oct-21	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	8:56	9:33	0:37	MAIN SUPPLY FAILURE
841	1-Oct-21	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	14:38	14:43	0:05	LINE FAULT
842	1-Oct-21	BENGALURU	66	DODALAHALLI - AACHALU	DODALAHALLI	5:51	6:16	0:24	LINE FAULT
843	1-Oct-21	BENGALURU	66	DODALAHALLI - AACHALU	DODALAHALLI	16:02	16:35	0:32	LINE CLEAR AVAILED
844	1-Oct-21	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	8:13	8:18	0:05	LOAD CHANGE OVER
845	1-Oct-21	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	10:00	10:07	0:07	LOAD CHANGE OVER
846	1-Oct-21	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	17:33	17:40	0:07	LOAD CHANGE OVER
847	1-Oct-21	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	10:16	10:17	0:01	LINE CLEAR AVAILED
848	1-Oct-21	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	15:25	15:27	0:02	LINE CLEAR AVAILED
849	1-Oct-21	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT, BELL CERAMICS (EHT)	13:03	13:07	0:04	LOAD CHANGE OVER
850	1-Oct-21	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	12:12	12:31	0:19	LINE FAULT
851	1-Oct-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	11:53	12:00	0:06	LINE FAULT
852	1-Oct-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	19:05	19:14	0:09	LINE FAULT
853	1-Oct-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	NO STATION AFFECTED	20:57	23:37	2:40	LINE FAULT
854	1-Oct-21	BENGALURU	66	HV1	AMAR JYOTHI	10:00	16:34	6:34	LINE CLEAR AVAILED
855	1-Oct-21	BENGALURU	66	HV1	BANASAWADI	12:12	12:31	0:19	MAIN SUPPLY FAILURE
856	1-Oct-21	BENGALURU	66	HV1	BANASAWADI	12:52	12:58	0:06	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
857	1-Oct-21	BENGALURU	66	HV1	BANASAWADI	13:44	13:48	0:04	LOAD CHANGE OVER
858	1-Oct-21	BENGALURU	66	HV1	REMC0	8:56	9:38	0:42	MAIN SUPPLY FAILURE
859	1-Oct-21	BENGALURU	66	HV1	VIJAYANAGARA	5:45	5:52	0:07	MAIN SUPPLY FAILURE
860	1-Oct-21	BENGALURU	66	HV1	VIJAYANAGARA	8:58	9:22	0:24	LOAD CHANGE OVER
861	1-Oct-21	BENGALURU	66	HV1	VIJAYANAGARA	22:18	22:24	0:06	LOAD CHANGE OVER
862	1-Oct-21	BENGALURU	66	HV1	MELUR	17:00	17:30	0:30	TRANSFORMER FAULT
863	1-Oct-21	BENGALURU	66	HV1	MELUR	17:35	17:50	0:15	TRANSFORMER FAULT
864	1-Oct-21	BENGALURU	66	HV1	SARJAPURA 220	12:13	12:26	0:13	MAIN SUPPLY FAILURE
865	1-Oct-21	BENGALURU	66	HV2	AMAR JYOTHI	10:00	10:10	0:10	LINE CLEAR AVAILED
866	1-Oct-21	BENGALURU	66	HV2	BANASAWADI	12:52	12:58	0:06	MAIN SUPPLY FAILURE
867	1-Oct-21	BENGALURU	66	HV2	BANASAWADI	13:35	13:40	0:05	LOAD CHANGE OVER
868	1-Oct-21	BENGALURU	66	HV2	MELLAHALLI	15:34	15:50	0:16	LINE CLEAR AVAILED
869	1-Oct-21	BENGALURU	66	HV2	SARJAPURA 220	12:13	12:26	0:13	MAIN SUPPLY FAILURE
870	1-Oct-21	BENGALURU	66	HV2	KIADB DB PURA 220	12:32	12:43	0:10	TRANSFORMER FAULT
871	1-Oct-21	BENGALURU	66	HV3	BANASAWADI	12:12	12:31	0:19	MAIN SUPPLY FAILURE
872	1-Oct-21	BENGALURU	66	HV3	BANASAWADI	12:52	12:58	0:06	MAIN SUPPLY FAILURE
873	1-Oct-21	BENGALURU	66	HV3	BANASAWADI	13:44	13:48	0:04	LOAD CHANGE OVER
874	1-Oct-21	BENGALURU	66	ITI 220 - BANASAWADI	BANASAWADI	12:52	12:58	0:06	LINE FAULT
875	1-Oct-21	BENGALURU	66	KENGERI SATELLITE TOWN - VRISHABHAVATHI 220	KENGERI SATELLITE TOWN	8:56	9:35	0:39	MAIN SUPPLY FAILURE
876	1-Oct-21	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	5:16	5:26	0:10	LOAD CHANGE OVER
877	1-Oct-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:13	12:28	0:15	MAIN SUPPLY FAILURE
878	1-Oct-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:13	12:28	0:15	MAIN SUPPLY FAILURE
879	1-Oct-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:13	12:29	0:16	MAIN SUPPLY FAILURE
880	1-Oct-21	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	10:55	13:12	2:17	LINE CLEAR AVAILED
881	1-Oct-21	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	10:44	12:45	2:01	LINE FAULT
882	1-Oct-21	BENGALURU	220	HV1	SARJAPURA 220	12:13	12:26	0:13	MAIN SUPPLY FAILURE
883	1-Oct-21	BENGALURU	220	HV2	SARJAPURA 220	12:13	12:26	0:13	MAIN SUPPLY FAILURE
884	1-Oct-21	BENGALURU	220	MALUR 220 - HOODY 220	NO STATION AFFECTED	10:45	12:45	2:00	LINE FAULT
885	1-Oct-21	BENGALURU	220	MALUR 220 - SOMANAHALLI 1	SARJAPURA 220, VIKAS TEC PARK 220	12:13	12:22	0:09	LINE FAULT
886	1-Oct-21	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI (EHT)	TATAGUNI (EHT), VRISHABHAVATHI 220	8:56	9:14	0:18	LINE FAULT
887	1-Oct-21	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHABHAVATHI 220	8:56	9:26	0:30	LINE FAULT
888	1-Oct-21	GULBARGA	66	GUDDEKOTE-KUDALIGI	GUDDEKOTE_66	9:30	9:55	0:25	MAIN SUPPLY FAILURE
889	1-Oct-21	GULBARGA	66	GUDDEKOTE-KUDLIGI	GUDDEKOTE_66	9:55	17:15	7:20	NFBC ISSUED
890	1-Oct-21	GULBARGA	66	HALAVAGALU-NEELAGUNDA	HALAVAGALU_66	13:10	14:35	1:25	MAIN SUPPLY FAILURE
891	1-Oct-21	GULBARGA	66	HV1	TELAGI_66	10:30	10:35	0:05	TRANSFORMER FAULT
892	1-Oct-21	GULBARGA	66	HV1	PUNAB GHATA_66	20:45	21:05	0:20	TRANSFORMER FAULT
893	1-Oct-21	GULBARGA	66	HV1	PUNAB GHATA_66	21:55(01.10.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
894	1-Oct-21	GULBARGA	66	HV1	KUDLIGI_220	14:25	14:30	0:05	TRANSFORMER FAULT
895	1-Oct-21	GULBARGA	66	HV2	HALAVAGALU_66	7:35	7:40	0:05	TRANSFORMER FAULT
896	1-Oct-21	GULBARGA	66	HV3	TELAGI_66	8:30(30.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
897	1-Oct-21	GULBARGA	66	PUNAB GHATA-NEELAGUNDA	PUNAB GHATA_66	13:10	13:35	0:25	MAIN SUPPLY FAILURE
898	1-Oct-21	GULBARGA	66	PUNAB GHATA-NEELAGUNDA	PUNAB GHATA_66	22:25	22:35	0:10	LINE FAULT
899	1-Oct-21	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI_66	13:15	13:35	0:20	MAIN SUPPLY FAILURE
900	1-Oct-21	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI_66	22:35	22:50	0:15	MAIN SUPPLY FAILURE
901	1-Oct-21	GULBARGA	66	TELAGI-VESTA_IPP	TELAGI_66	23:25	23:35	0:10	LINE FAULT
902	1-Oct-21	GULBARGA	110	ALAND-KAPNOOR	ALAND_110,KADAGANCHI_110	5:45	5:50	0:05	MAIN SUPPLY FAILURE
903	1-Oct-21	GULBARGA	110	BISIHALLI-BELLARY NORTH	BISIHALLI_110	14:32	14:40	0:08	MAIN SUPPLY FAILURE
904	1-Oct-21	GULBARGA	110	BISIHALLI-BELLARY NORTH	BISIHALLI_110	15:18	16:28	1:10	MAIN SUPPLY FAILURE
905	1-Oct-21	GULBARGA	110	BISIHALLI-BELLARY NORTH	BISIHALLI_110	18:24	18:32	0:08	MAIN SUPPLY FAILURE
906	1-Oct-21	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	18:15	19:07	0:52	MAIN SUPPLY FAILURE
907	1-Oct-21	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA_110,GABBUR_110,GOOGLE_110	10:10	10:40	0:30	MAIN SUPPLY FAILURE
908	1-Oct-21	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA_110,GABBUR_110,GOOGLE_110	11:50	12:20	0:30	MAIN SUPPLY FAILURE
909	1-Oct-21	GULBARGA	110	GABBUR-RAICHUR1	GABBUR_110,DEODURGA_110,GOOGLE_110	10:15	10:45	0:30	MAIN SUPPLY FAILURE
910	1-Oct-21	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	0:45	0:55	0:10	LINE CLEAR AVAILED
911	1-Oct-21	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	12:05	12:15	0:10	LINE CLEAR AVAILED
912	1-Oct-21	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	16:35(28.09.2021)			LINE OPEN:LINE CLEAR AVAILED
913	1-Oct-21	GULBARGA	110	HV1	CHOWDAPUR_110	17:10	17:50	0:40	LINE CLEAR AVAILED
914	1-Oct-21	GULBARGA	110	HV1	VALKAMDINNI_110	20:50	21:00	0:10	LINE CLEAR AVAILED
915	1-Oct-21	GULBARGA	110	HV2	DEODURGA_110	15:35	14:45	0:50	TRANSFORMER FAULT
916	1-Oct-21	GULBARGA	110	HV2	GULBARGASOUTH_110	19:10	19:20	0:10	TRANSFORMER FAULT
917	1-Oct-21	GULBARGA	110	HV2	GULBARGASOUTH_110	20:50	20:55	0:05	TRANSFORMER FAULT
918	1-Oct-21	GULBARGA	110	HV2	GULBARGASOUTH_110	21:15	21:20	0:05	TRANSFORMER FAULT
919	1-Oct-21	GULBARGA	110	HV2	VALKAMDINNI_110	20:00	21:00	1:00	LINE CLEAR AVAILED
920	1-Oct-21	GULBARGA	110	HV2	VALKAMDINNI_110	21:45	21:55	0:10	TRANSFORMER FAULT
921	1-Oct-21	GULBARGA	110	HV2	VALKAMDINNI_110	22:05	22:20	0:15	TRANSFORMER FAULT
922	1-Oct-21	GULBARGA	110	HV2	SREERAMANAGAR_110	10:01	12:14	2:13	LINE CLEAR AVAILED
923	1-Oct-21	GULBARGA	110	HV3	VALKAMDINNI_110	4:06	4:14	0:08	TRANSFORMER FAULT
924	1-Oct-21	GULBARGA	110	HV3	VALKAMDINNI_110	23:50	0:00	0:10	TRANSFORMER FAULT
925	1-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMARESHWAR_110	1:15	1:25	0:10	LINE FAULT
926	1-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMARESHWAR_110	5:25	5:35	0:10	LINE FAULT
927	1-Oct-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	5:45	5:51	0:06	LINE FAULT
928	1-Oct-21	GULBARGA	110	KAPNOOR-KAPNNOR	KAPNOOR_110	22:41	23:58	1:17	LINE CLEAR AVAILED
929	1-Oct-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	5:59	6:16	0:17	LINE FAULT
930	1-Oct-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADVIAMR ESHWAR_110	0:45	0:55	0:10	LINE FAULT
931	1-Oct-21	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	22:48	22:56	0:08	LINE FAULT
932	1-Oct-21	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPURA_110	22:49	22:55	0:06	MAIN SUPPLY FAILURE
933	1-Oct-21	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110	5:58	6:06	0:08	LINE FAULT
934	1-Oct-21	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110	16:23	18:01	1:38	LINE CLEAR AVAILED
935	1-Oct-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
936	1-Oct-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
937	1-Oct-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1 (IDLE LINE)	SHAHAPUR1_110	11:50(30.09.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
938	1-Oct-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	3:28	3:38	0:10	LINE FAULT
939	1-Oct-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	5:46	5:53	0:07	LINE FAULT
940	1-Oct-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:38(01.10.21)	7:45(2.10.2021)	10:45 hrs	LINE CHARGED
941	1-Oct-21	GULBARGA	110	SINDANOR-SIRIGUPPA	DHADESUGUR_110,SIRIGUPPA_110,TEK KALKOTE_110	10:15	12:50	2:35	LINE CLEAR AVAILED
942	1-Oct-21	GULBARGA	110	SINDANOR-SIRIGUPPA	DHADESUGUR_110,SIRIGUPPA_110,TEK KALKOTE_110	20:04	20:14	0:10	LINE FAULT
943	1-Oct-21	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	14:23	14:32	0:09	LINE FAULT
944	1-Oct-21	GULBARGA	220	HUMNABAD-SEDAM1&2	SEDAM_220	10:59	11:14	0:15	LINE FAULT
945	1-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
946	1-Oct-21	GULBARGA	220	LINGAPUR-GADAG1	LINGAPUR_220	14:24	20:48	6:24	LINE FAULT
947	1-Oct-21	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	0:12	22:10	21:58	LINE FAULT
948	1-Oct-21	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	21:28	22:12	0:44	LINE FAULT
949	1-Oct-21	GULBARGA	220	SEDAM-SHAHAPUR_220	SEDAM_220	4:42	13:55	9:13	LINE FAULT
950	1-Oct-21	GULBARGA	400	BTPSG-GUTTUR	BTPS_400	11:11	19:36	8:25	LINE FAULT
951	1-Oct-21	GULBARGA	400	BTPSG-RTPS	RTPS_400	5:03	9:25	4:22	LINE FAULT
952	1-Oct-21	GULBARGA	400	RTPS-BTPS	BTPS_400	10:26(30.09.2021)	15:03(01.10.2021)	28:37 HRS	LINE CHARGED
953	1-Oct-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	7:55	8:03	0:08	LINE FAULT
954	1-Oct-21	HASSAN	66	HASSN22-SKPURA2	HASSAN_220	6:23	6:35	0:12	LINE FAULT
955	1-Oct-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	19:23	19:52	0:29	LINE FAULT
956	1-Oct-21	HASSAN	66	HV1	MALALI_66	19:25	20:00	0:35	MAIN SUPPLY FAILURE
957	1-Oct-21	HASSAN	66	HV1	RAMESHWANAGAR_66	19:25	19:40	0:15	MAIN SUPPLY FAILURE
958	1-Oct-21	HASSAN	66	HV1	MALLAPURA_66	16:10	17:35	1:25	LINE CLEAR AVAILED
959	1-Oct-21	HASSAN	66	HV2	RAMESHWANAGAR_66	19:25	19:40	0:15	MAIN SUPPLY FAILURE
960	1-Oct-21	HASSAN	66	MALAI-CRPATNA	MALALI_66	19:25	20:00	0:35	MAIN SUPPLY FAILURE
961	1-Oct-21	HASSAN	66	RMWNGR-HASSAN	RAMESHWANAGAR_66	19:25	19:35	0:10	LINE FAULT
962	1-Oct-21	HASSAN	66	RMWNGR-SHANTI	RAMESHWANAGAR_66	19:35 (1.10.2021)			LINE OPEN:LINE CLEAR AVAILED
963	1-Oct-21	HASSAN	66	TAVAREC-HONNALI	TAVARECHATNAHALLI_66	10:46	11:00	0:14	HAND TRIPPED
964	1-Oct-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	21:10	21:32	0:22	LINE FAULT
965	1-Oct-21	HASSAN	110	HV	KITTADAHALLI_110	14:19	16:05	1:46	LINE CLEAR AVAILED
966	1-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
967	1-Oct-21	HASSAN	110	HV2	ANAVATTI_110	19:56	20:20	0:24	TRANSFORMER FAULT
968	1-Oct-21	HASSAN	110	JOG-JLT4	JOG_110	18:35(29.09.2021)	18:40 (1.10.2021)	48:04 hrs	NFBC ISSUED
969	1-Oct-21	HASSAN	110	KAVOOR-AMR	KAVOOR_220	17:16	20:40	3:24	LINE FAULT
970	1-Oct-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	21:10	21:31	0:21	LINE FAULT
971	1-Oct-21	HASSAN	110	LPH-MGHE 2	lph_gen	14:15(29.09.2021)	18:40 (1.10.2021)	52:24 hrs	LINE CHARGED
972	1-Oct-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	19:30	19:50	0:20	LINE FAULT
973	1-Oct-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:04	14:09	3:05	LINE FAULT
974	1-Oct-21	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	22:50 (30.09.2021)	00:56(01.10.2021)	2:5 hrs	NFBC ISSUED
975	1-Oct-21	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	10:37 (30.09.2021)	15:00(01.10.2021)	28:22 hrs	LINE CHARGED
976	1-Oct-21	HASSAN	220	MRSSHM-HSN4001	MRSMG_220	20:39(01.10.2021)			LINE OPEN:LINE FAULT
977	1-Oct-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	11:40	14:08	2:28	LINE FAULT
978	1-Oct-21	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	10:36(30.09.2021)	00:56(1.10.2021)	14:19 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
979	1-Oct-21	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	9:46	15:00	5:14	LINE CLEAR AVAILED
980	1-Oct-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	11:40	14:08	2:28	LINE FAULT
981	1-Oct-21	HASSAN	220	SMRESSHM-HARAVATHY1	MRSMSG_220	11:04	14:09	3:05	LINE FAULT
982	1-Oct-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
983	1-Oct-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	19:06(01.10.2021)			LINE OPEN:LINE FAULT
984	1-Oct-21	MYSURU	66	FTS-HOOTGALLY 1	NO STATIONS EFFECTED	6:31:29 (29/09/2021)			LINE OPEN:LINE CLEAR AVAILED
985	1-Oct-21	MYSURU	66	FTS-HOOTGALLY 2	NO STATIONS EFFECTED	6:31:24 (29/09/2021)			LINE OPEN:LINE CLEAR AVAILED
986	1-Oct-21	MYSURU	66	HV1	FTS_66	9:51	11:50	1:58	LINE CLEAR AVAILED
987	1-Oct-21	MYSURU	66	HV1	HONNALLY_MYS_66	10:56	13:44	2:48	LINE CLEAR AVAILED
988	1-Oct-21	MYSURU	66	HV1	MADIKERI_66	10:25	11:05	0:40	LINE CLEAR AVAILED
989	1-Oct-21	MYSURU	66	HV2	KIKKERI_66	11:28	11:43	0:14	TRANSFORMER FAULT
990	1-Oct-21	MYSURU	66	HV2	KIKKERI_66	19:18	18:31	0:06	TRANSFORMER FAULT
991	1-Oct-21	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	10:58	18:49	7:51	LINE FAULT
992	1-Oct-21	MYSURU	66	KR PETE 220-SB HALLI	SANTHEBACHALLI_66 ADDIHALLI_66 NAGAMANGALA_66 AHARIYALDAMMATAMPLE_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	6:44	6:57	0:13	LINE FAULT
993	1-Oct-21	MYSURU	66	KR PETE 220-SB HALLI	SANTHEBACHALLI_66 ADDIHALLI_66 NAGAMANGALA_66 AHARIYALDAMMATAMPLE_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	7:07	7:20	0:13	LINE FAULT
994	1-Oct-21	MYSURU	66	KR PETE 220-SB HALLI	SANTHEBACHALLI_66 ADDIHALLI_66 NAGAMANGALA_66 AHARIYALDAMMATAMPLE_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	18:08	18:19	0:11	LINE FAULT
995	1-Oct-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
996	1-Oct-21	MYSURU	66	SANTESARGUR-KADAKOLA 1	HDKOTE_66 YEREHALLI_66 ANTHRASANTHE_66	5:44	5:50	0:06	LINE FAULT
997	1-Oct-21	MYSURU	66	SB HALLI-HUYONAHALLI	SANTHEBACHALLI_66 ADDIHALLI_66 NAGAMANGALA_66 AHARIYALDAMMATAMPLE_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	15:11	16:32	1:21	NFBC ISSUED
998	1-Oct-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
999	1-Oct-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1000	1-Oct-21	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	7:22	7:48	0:25	LINE FAULT
1001	1-Oct-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:00	6:21	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1002	1-Oct-21	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	19:57	20:57	1:00	LINE FAULT
1003	1-Oct-21	TUMKUR	66	CHITRADURGA 220kV-BALENAHALLI-66	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	20:01	21:35	1:33	LINE FAULT
1004	1-Oct-21	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA4	CHITRADURGA_220	20:04	21:44	1:40	LINE FAULT
1005	1-Oct-21	TUMKUR	66	HANAGAL-THALLAK 1	HANAGAL_66	9:12	9:54	0:42	LINE CLEAR AVAILED
1006	1-Oct-21	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	11:18	11:44	0:25	HAND TRIPPED
1007	1-Oct-21	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	10:15	10:21	0:06	HAND TRIPPED
1008	1-Oct-21	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	8:58	9:59	1:00	LINE FAULT
1009	1-Oct-21	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	21:49	22:47	0:58	LINE FAULT
1010	1-Oct-21	TUMKUR	66	MADHUGIRI 220KV- SIRA 1	SIRA_66,GULIGENAHALLI_66	14:57	15:06	0:09	LINE FAULT
1011	1-Oct-21	TUMKUR	66	TR-1	GULIGENAHALLI_66	7:59	8:31	0:31	LINE CLEAR AVAILED
1012	1-Oct-21	TUMKUR	66	TR-1	HANAGAL_66	13:30	13:36	0:06	LINE CLEAR AVAILED
1013	1-Oct-21	TUMKUR	66	TR-2	BHARAMAGIRI_66	15:29	15:33	0:04	TRANSFORMER FAULT
1014	1-Oct-21	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	14:16	14:30	0:13	HAND TRIPPED
1015	1-Oct-21	TUMKUR	110	TR-1	TURUVEKERE_110	8:15	8:54	0:38	TRANSFORMER FAULT
1016	1-Oct-21	TUMKUR	110	TR-1	TURUVEKERE_110	18:44	19:34	0:49	TRANSFORMER FAULT
1017	1-Oct-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	14:03	15:00	0:57	LINE FAULT
1018	1-Oct-21	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	14:03	14:54	0:51	LINE FAULT
1019	1-Oct-21	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	13:11	14:21	1:09	LINE FAULT
1020	2-Oct-21	BAGALKOT	66	66/11KV, HV2	STATION NOT AFFECTED HARIHAR HOSPET_66	14:08	14:44	0:36	LINE CLEAR AVAILED
1021	2-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1022	2-Oct-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1023	2-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
1024	2-Oct-21	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	23:40 (01.10.2021)	0:09 (02.10.2021)	0:29	TRANSFORMER CHARGED
1025	2-Oct-21	BAGALKOT	110	110/11KV,HV1	THORVI_110	19:10	20:45	1:35	TRANSFORMER FAULT
1026	2-Oct-21	BAGALKOT	110	110/11KV,HV2	AMENAGAD_33,KARADI_33,MYTRA SOLAR_33 HUNGUND_110	21:18	21:24	0:06	TRANSFORMER FAULT
1027	2-Oct-21	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1028	2-Oct-21	BAGALKOT	110	110/33KV,HV4	ALAGAWADI_33 HIDIKAL_110	19:55	21:18	1:23	TRANSFORMER FAULT
1029	2-Oct-21	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1030	2-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1031	2-Oct-21	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	10:40	11:16	0:36	HAND TRIPPED
1032	2-Oct-21	BAGALKOT	110	INDI- DEVAR HIPPARAGI	DEVAR HIPPARAGI_110, ATHARGA_110, HIREMASALI_110	17:35	17:40	0:05	LINE FAULT
1033	2-Oct-21	BAGALKOT	110	ITNAL-HIDIKAL(RAIBAG)	HIDIKAL_110	19:52	20:15	0:23	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1034	2-Oct-21	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	10:25	12:36	2:11	LINE CLEAR AVAILED
1035	2-Oct-21	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMAKHANDI	JAMAKHANDI_110	18:07 (01.10.2021)	9:32 (02.10.2021)	15:25	LINE CHARGED
1036	2-Oct-21	BAGALKOT	110	MUGALKHOD-(LN2)RAIBAG	MUGALKHOD_110	20:00 (01.10.2021)	18:47 (02.10.2021)	22:47	LINE CHARGED
1037	2-Oct-21	BAGALKOT	110	RAMANAKOPPA-HUBLI220	STATION NOT AFFECTED RAMANAKOPPA_110	11:07	14:05	2:58	HAND TRIPPED
1038	2-Oct-21	BAGALKOT	110	RANEENNUR220- GUTTAL	GUTTAL_110	20:04	20:15	0:11	LINE FAULT
1039	2-Oct-21	BAGALKOT	110	RANNABELAGALI-MHALINGAPUR220	STATION NOT AFFECTED RANNABELAGALI_110	11:40	16:15	4:35	HAND TRIPPED
1040	2-Oct-21	BAGALKOT	110	RAY SOLAR-ALBAL	ALBAL_110	15:49	18:17	2:28	LINE CLEAR AVAILED
1041	2-Oct-21	BAGALKOT	110	SAIPRIYA SOLAR -ALBAL	ALBAL_110	10:45	11:05	0:20	LINE CLEAR AVAILED
1042	2-Oct-21	BAGALKOT	110	SAIPRIYA SOLAR -ALBAL	ALBAL_110	15:49	18:17	2:28	LINE CLEAR AVAILED
1043	2-Oct-21	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH IPP_110 STATION NOT AFFECTED SAVANUR_110	16:05	16:12	0:07	LINE FAULT
1044	2-Oct-21	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH IPP_110 STATION NOT AFFECTED SAVANUR_110	16:12	16:33	0:21	LINE FAULT
1045	2-Oct-21	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH IPP_110 STATION NOT AFFECTED SAVANUR_110	16:38	17:19	0:41	LINE FAULT
1046	2-Oct-21	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH IPP_110 STATION NOT AFFECTED SAVANUR_110	17:29	18:11	0:42	LINE FAULT
1047	2-Oct-21	BAGALKOT	110	SHIRAHATTI-BPCL2	BPCL IPP_110 STATION NOT AFFECTED SHIRHATTI_110	4:15	17:50	13:35	LINE FAULT
1048	2-Oct-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1049	2-Oct-21	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1050	2-Oct-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1051	2-Oct-21	BAGALKOT	110	TARIHAL-HUBLI220-2	STATION NOT AFFECTED TARIHAL	11:06	14:41	3:35	HAND TRIPPED
1052	2-Oct-21	BAGALKOT	110	TODALBAGI-MAMADAPUR	STATION NOT AFFECTED TODALBAGI_110	13:34	15:15	1:41	HAND TRIPPED
1053	2-Oct-21	BAGALKOT	110	VAJJRAMATTI220-JK CEMENT	JK CEMENT_110 STATION NOT AFFECTED VAJJRAMATTI_220	1:48	2:23	0:35	LINE FAULT
1054	2-Oct-21	BAGALKOT	110	VAJJRAMATTI220- J.K CEMENT	VAJJRAMATTI_220	1:48	2:23	1:27	LINE FAULT
1055	2-Oct-21	BAGALKOT	220	220/110KV, HV1	CHIKKODI_220	11:32 (01.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1056	2-Oct-21	BAGALKOT	220	220/110KV, HV2	VAJJRAMATTI_220	1:48	2:09	0:21	TRANSFORMER FAULT
1057	2-Oct-21	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	11:40	18:23	6:43	LINE FAULT
1058	2-Oct-21	BAGALKOT	220	ATHANI- MAHALINGAPUR	ATHANI_220	17:06 (01.10.2021)	11:20 (02.10.2021)	18:14	LINE CHARGED
1059	2-Oct-21	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	22:03 (01.10.2021)	14:49 (02.10.2021)	16:46	LINE CHARGED
1060	2-Oct-21	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	11:58	14:47	2:49	LINE CLEAR AVAILED
1061	2-Oct-21	BAGALKOT	220	CHIKKODI220- BELGAUM1	CHIKKODI_220	7:32 (02.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1062	2-Oct-21	BAGALKOT	220	HAVERI- GUTTUR1	HAVERI_220	18:39 (01.10.2021)	10:20 (02.10.2021)	15:41	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1063	2-Oct-21	BAGALKOT	220	HAVERI- GUTTUR1	HAVERI_220	12:41	16:05	3:24	LINE FAULT
1064	2-Oct-21	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	13:23	16:04	2:41	HAND TRIPPED
1065	2-Oct-21	BAGALKOT	220	HUBLI- NAGJHARI3	HUBLI_220	10:39	19:54	9:15	LINE FAULT
1066	2-Oct-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	10:39	13:17	2:38	LINE FAULT
1067	2-Oct-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	12:02	20:22	8:20	LINE FAULT
1068	2-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAIED
1069	2-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1070	2-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	12:08 (02.10.2021)			LINE OPEN:LINE CLEAR AVAIED
1071	2-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	12:08 (02.10.2021)			LINE OPEN:LINE CLEAR AVAIED
1072	2-Oct-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:06 (24.09.2021)	12:09 (02.10.2021)	20:03	LINE CHARGED
1073	2-Oct-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:07 (24.09.2021)	12:08 (02.10.2021)	20:01	LINE CHARGED
1074	2-Oct-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	2:20 (02.10.2021)			LINE OPEN:LINE FAULT
1075	2-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1076	2-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAIED
1077	2-Oct-21	BAGALKOT	400	DHONI- GUTTUR	DHONI_400	10:55 (02.10.2021)			LINE OPEN:LINE FAULT
1078	2-Oct-21	BENGALURU	66	ATTUR YELAHANKA - DG4	PLATINUM CITY, SAHAKARNAGAR	12:26	13:02	0:36	MAIN SUPPLY FAILURE
1079	2-Oct-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	5:46	5:52	0:06	LINE FAULT
1080	2-Oct-21	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT, BELL CERAMICS (EHT)	12:10	12:13	0:03	LOAD CHANGE OVER
1081	2-Oct-21	BENGALURU	66	HOODY 220 - HP(EHT)	HP(EHT)	11:02	13:45	2:43	LINE CLEAR AVAIED
1082	2-Oct-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	NO STATION AFFECTED	10:27	11:25	0:57	LINE FAULT
1083	2-Oct-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	NO STATION AFFECTED	0:52	9:47	8:55	LINE FAULT
1084	2-Oct-21	BENGALURU	66	HV1	HSR LAYOUT 220	4:13	5:00	0:47	TRANSFORMER FAULT
1085	2-Oct-21	BENGALURU	66	HV1	YELAHANKA 220	12:26	13:04	0:38	MAIN SUPPLY FAILURE
1086	2-Oct-21	BENGALURU	66	HV1	KYALANUR	16:47	16:57	0:09	TRANSFORMER FAULT
1087	2-Oct-21	BENGALURU	66	HV1	SM MANGALA	13:15	13:34	0:19	LINE CLEAR AVAIED
1088	2-Oct-21	BENGALURU	66	HV2	YELAHANKA 220	12:26	12:42	0:16	MAIN SUPPLY FAILURE
1089	2-Oct-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT)	22:02	22:06	0:03	LOAD CHANGE OVER
1090	2-Oct-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	14:25	14:30	0:05	LOAD CHANGE OVER
1091	2-Oct-21	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	12:26	12:45	0:19	MAIN SUPPLY FAILURE
1092	2-Oct-21	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	12:25	12:40	0:15	MAIN SUPPLY FAILURE
1093	2-Oct-21	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	5:45	5:50	0:05	LINE FAULT
1094	2-Oct-21	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	12:26	12:40	0:14	MAIN SUPPLY FAILURE
1095	2-Oct-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	7:25	7:41	0:15	LINE FAULT
1096	2-Oct-21	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	12:26	12:40	0:14	MAIN SUPPLY FAILURE
1097	2-Oct-21	BENGALURU	220	HV1	YELAHANKA 220	12:26	19:00	6:34	TRANSFORMER FAULT
1098	2-Oct-21	GULBARGA	66	HV1	PUNAB GHATA_66	21:55(01.10.2021)	6:30(02.10.2021)	8:35 HRS	TRANSFORMER CHARGED
1099	2-Oct-21	GULBARGA	66	HV2	TELAGI_66	0:20	0:25	0:05	TRANSFORMER FAULT
1100	2-Oct-21	GULBARGA	66	HV2	HALAVAGALU_66	3:30	3:35	0:05	TRANSFORMER FAULT
1101	2-Oct-21	GULBARGA	66	HV2	HALAVAGALU_66	7:00	7:05	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1102	2-Oct-21	GULBARGA	66	HV2	HALAVAGALU_66	17:50	18:15	0:25	LINE CLEAR AVAIED
1103	2-Oct-21	GULBARGA	66	HV2	HALAVAGALU_66	22:05	22:25	0:20	LINE CLEAR AVAIED
1104	2-Oct-21	GULBARGA	66	HV3	TELAGI_66	8:30(30.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAIED
1105	2-Oct-21	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	13:47	17:30	3:43	LINE CLEAR AVAIED
1106	2-Oct-21	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	17:31(2.10.2021)			LINE OPEN:LINE CLEAR AVAIED
1107	2-Oct-21	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADVIAMRESHWAR_110	0:45	0:55	0:10	MAIN SUPPLY FAILURE
1108	2-Oct-21	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADVIAMRESHWAR_110	2:30	2:40	0:10	MAIN SUPPLY FAILURE
1109	2-Oct-21	GULBARGA	110	BISIHALLI-BELLARY NORTH	BISIHALLI_110	6:05	6:11	0:06	MAIN SUPPLY FAILURE
1110	2-Oct-21	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	3:24	3:40	0:16	LINE FAULT
1111	2-Oct-21	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA_110,GABBUR_110,GOOGLE_110	1:10	1:15	0:05	MAIN SUPPLY FAILURE
1112	2-Oct-21	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA_110,GABBUR_110,GOOGLE_110	2:10	2:20	0:10	MAIN SUPPLY FAILURE
1113	2-Oct-21	GULBARGA	110	GALAG_ALKOD	GALAG_110	1:35	1:45	0:10	MAIN SUPPLY FAILURE
1114	2-Oct-21	GULBARGA	110	GALAG_ALKOD	GALAG_110	2:05	2:10	0:05	MAIN SUPPLY FAILURE
1115	2-Oct-21	GULBARGA	110	GALAG_ALKOD	GALAG_110	6:00	6:20	0:20	MAIN SUPPLY FAILURE
1116	2-Oct-21	GULBARGA	110	GANDHINAGAR-SINDHANOOR	GANDHINAGAR_110	1:45	1:50	0:05	MAIN SUPPLY FAILURE
1117	2-Oct-21	GULBARGA	110	HUMNABAD-HUMNABAD1	MANEKAHALLI_110	3:38	3:55	0:17	LINE FAULT
1118	2-Oct-21	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	16:35(28.09.2021)			LINE OPEN:LINE CLEAR AVAIED
1119	2-Oct-21	GULBARGA	110	HV1	MUDDAPURA_110	2:10	2:28	0:18	TRANSFORMER FAULT
1120	2-Oct-21	GULBARGA	110	HV1	MUDDAPURA_110	2:40	2:50	0:10	TRANSFORMER FAULT
1121	2-Oct-21	GULBARGA	110	HV1	BAYYAPURA_110	11:30	13:05	1:35	TRANSFORMER FAULT
1122	2-Oct-21	GULBARGA	110	HV2	HATTI_110	3:40	3:45	0:05	MAIN SUPPLY FAILURE
1123	2-Oct-21	GULBARGA	110	HV3	GULBARGASOUTH_110	12:50	13:50	1:00	LINE CLEAR AVAIED
1124	2-Oct-21	GULBARGA	110	HV3	CHINCHOLI_110	3:24	3:45	0:21	TRANSFORMER FAULT
1125	2-Oct-21	GULBARGA	110	HV3	VALKAMDINNI_110	6:05	6:15	0:10	TRANSFORMER FAULT
1126	2-Oct-21	GULBARGA	110	HV3	TEKKALKOTE_110	11:28	14:28	3:00	TRANSFORMER FAULT
1127	2-Oct-21	GULBARGA	110	HV3	TEKKALKOTE_110	14:37	15:09	0:32	TRANSFORMER FAULT
1128	2-Oct-21	GULBARGA	110	JANAWADA-SANTAPUR	JANAWADA_110	19:55	22:02	2:07	LINE FAULT
1129	2-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMARESHWAR_110	0:55	1:05	0:10	LINE FAULT
1130	2-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMARESHWAR_110	4:00	4:05	0:05	LINE FAULT
1131	2-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMARESHWAR_110	7:20	7:35	0:15	LINE FAULT
1132	2-Oct-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMARESHWAR_110	21:45	21:55	0:10	LINE FAULT
1133	2-Oct-21	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	1:45	1:50	0:05	MAIN SUPPLY FAILURE
1134	2-Oct-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	3:30	3:40	0:10	LINE FAULT
1135	2-Oct-21	GULBARGA	110	SEDAM-VASAVADATTHA_IPP	SEDAM_220	19:30	19:43	0:13	LINE FAULT
1136	2-Oct-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAIED
1137	2-Oct-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAIED
1138	2-Oct-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	2:47	2:58	0:11	LINE FAULT
1139	2-Oct-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1 (IDLE LINE)	SHAHAPUR1_110	11:50(30.09.2021)	10:31(02.10.2021)	46:40 HRS	LINE CHARGED
1140	2-Oct-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:04	23:08	0:04	LINE FAULT
1141	2-Oct-21	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	18:20	18:35	0:15	LINE FAULT
1142	2-Oct-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	1:30	1:45	0:15	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1143	2-Oct-21	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	5:00	5:20	0:20	MAIN SUPPLY FAILURE
1144	2-Oct-21	GULBARGA	220	HV1	KUSTAGI_220	0:09	1:00	0:51	TRANSFORMER FAULT
1145	2-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1146	2-Oct-21	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	2:09	22:10	20:01	LINE FAULT
1147	2-Oct-21	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	12:24(01.10.2021)	14:20(02.10.2021)	25:56HRS	LINE CHARGED
1148	2-Oct-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	23:45(2.10.2021)			LINE OPEN:LINE FAULT
1149	2-Oct-21	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	5:55	6:05	0:10	LINE FAULT
1150	2-Oct-21	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	13:40	17:03	3:23	LINE CLEAR AVAILED
1151	2-Oct-21	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	7:20	17:02	9:42	LINE FAULT
1152	2-Oct-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:40	17:03	3:23	LINE CLEAR AVAILED
1153	2-Oct-21	HASSAN	66	CHANNAR-SHETTIHALLY	CHANNARAYAPATNA_66	8:15	17:00	8:45	LINE CLEAR AVAILED
1154	2-Oct-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	13:40	17:03	3:23	LINE CLEAR AVAILED
1155	2-Oct-21	HASSAN	66	CRPATNA-CRPTNA1	CHANNARAYAPATNA_66	7:16	13:22	6:06	LINE FAULT
1156	2-Oct-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	6:12	6:20	0:08	LINE FAULT
1157	2-Oct-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	7:50	8:01	0:11	LINE FAULT
1158	2-Oct-21	HASSAN	66	HV1	ARKD_66	7:57	8:15	0:18	LINE CLEAR AVAILED
1159	2-Oct-21	HASSAN	66	HV1	HALEBEEDU_66	18:02	18:11	0:09	TRANSFORMER FAULT
1160	2-Oct-21	HASSAN	66	HV1	CHANNARAYAPATNA_66	13:40	17:03	3:23	LINE CLEAR AVAILED
1161	2-Oct-21	HASSAN	66	HV1	MALLAPURA_66	11:51	14:29	2:38	LINE CLEAR AVAILED
1162	2-Oct-21	HASSAN	66	HV2	CHANNARAYAPATNA_66	13:40	17:03	3:23	LINE CLEAR AVAILED
1163	2-Oct-21	HASSAN	66	HV2	MALLAPURA_66	11:51	14:18	2:27	LINE CLEAR AVAILED
1164	2-Oct-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	6:00	6:15	0:15	LINE FAULT
1165	2-Oct-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMANATHPURA_66	7:50	8:05	0:15	LINE FAULT
1166	2-Oct-21	HASSAN	66	RMWNGR-SHANTI	RAMESHWANAGAR_66	19:35 (1.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1167	2-Oct-21	HASSAN	66	RMWNGR-SHANTI	RAMESHWANAGAR_66	19:35 (1.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1168	2-Oct-21	HASSAN	110	HV	PUTTUR_220	17:25	17:48	0:23	TRANSFORMER FAULT
1169	2-Oct-21	HASSAN	110	HV1	KARAYA_110	17:25	18:23	0:58	TRANSFORMER FAULT
1170	2-Oct-21	HASSAN	110	HV1	SHIKARIPURA_110	1:30	1:57	0:27	TRANSFORMER FAULT
1171	2-Oct-21	HASSAN	110	HV1	SORABA_110	8:10	8:15	0:05	HAND TRIPPED
1172	2-Oct-21	HASSAN	110	HV1	SORABA_110	8:25	8:30	0:05	HAND TRIPPED
1173	2-Oct-21	HASSAN	110	HV1	SORABA_110	9:45	14:10	4:25	TRANSFORMER FAULT
1174	2-Oct-21	HASSAN	110	HV1	SORABA_110	14:20	16:00	1:40	LINE CLEAR AVAILED
1175	2-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1176	2-Oct-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1177	2-Oct-21	HASSAN	110	KAVOOR-BAIKAMPADY	KAVOOR_220	9:58	12:10	2:12	LINE FAULT
1178	2-Oct-21	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	17:30	17:42	0:12	LINE FAULT
1179	2-Oct-21	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	17:25	17:37	0:12	HAND TRIPPED
1180	2-Oct-21	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	17:30	17:40	0:10	HAND TRIPPED
1181	2-Oct-21	HASSAN	110	VITTAL-PUTR_SLTUR	VITTAL_110	17:25	17:43	0:18	MAIN SUPPLY FAILURE
1182	2-Oct-21	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	20:39(01.10.2021)	18:27 (2.10.2021)	21:47 hrs	LINE CHARGED
1183	2-Oct-21	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	8:32 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1184	2-Oct-21	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	17:25	17:34	0:09	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1185	2-Oct-21	HASSAN	220	PUTTURKEMAR2	PUTTUR_220	17:25	17:45	0:20	LINE FAULT
1186	2-Oct-21	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	19:33 (2.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1187	2-Oct-21	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	19:33 (2.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1188	2-Oct-21	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	19:27	19:32	0:05	HAND TRIPPED
1189	2-Oct-21	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	15:01(02.10.2021			LINE OPEN:LINE FAULT
1190	2-Oct-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
1191	2-Oct-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
1192	2-Oct-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	19:06(01.10.2021)	18:50(2.10.2021)	23:43 hrs	LINE CHARGED
1193	2-Oct-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	19:25 (2.10.2021)			LINE OPEN:LINE FAULT
1194	2-Oct-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	19:25 (2.10.2021)	16:22(03.10.2021)	20:56 hrs	LINE CHARGED
1195	2-Oct-21	MYSURU	66	BESAGRALLI-KOPPA	NO STATIONS EFFECTED	10:44	12:53	2:09	LINE CLEAR AVAILED
1196	2-Oct-21	MYSURU	66	FTS-HOOTGALLY 1	NO STATIONS EFFECTED	6:31:29 (29/09/2021)			LINE OPEN:LINE CLEAR AVAILED
1197	2-Oct-21	MYSURU	66	FTS-HOOTGALLY 2	NO STATIONS EFFECTED	6:31:24 (29/09/2021)			LINE OPEN:LINE CLEAR AVAILED
1198	2-Oct-21	MYSURU	66	HOOTAGALLI-FTS -1	NO STATIONS EFFECTED	7:00	7:34	0:34	LINE FAULT
1199	2-Oct-21	MYSURU	66	HV1	GVGUDI_66	9:48	10:43	0:55	LINE CLEAR AVAILED
1200	2-Oct-21	MYSURU	66	HV2	AKKIHEBBAL_66	2:39	3:00	0:21	LINE CLEAR AVAILED
1201	2-Oct-21	MYSURU	66	HV2	KIKKERI_66	11:38	18:49	7:11	TRANSFORMER FAULT
1202	2-Oct-21	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLALLI _66	18:31	18:31	0:10	LINE FAULT
1203	2-Oct-21	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	11:12	11:17	0:05	LINE FAULT
1204	2-Oct-21	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PG PALYA _66	3:21	3:26	0:05	LINE FAULT
1205	2-Oct-21	MYSURU	66	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	3:14	3:28	0:14	LINE FAULT
1206	2-Oct-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1207	2-Oct-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1208	2-Oct-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1209	2-Oct-21	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR _66	YEDIYUR_66,THIPPUR_66,JIDDEGERE_66	15:14	15:22	0:08	LINE FAULT
1210	2-Oct-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	5:56	6:10	0:13	LINE FAULT
1211	2-Oct-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:19	10:32	0:12	LINE FAULT
1212	2-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:15	9:25	0:10	LINE FAULT
1213	2-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:33	9:52	0:19	LINE FAULT
1214	2-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:19	10:32	0:12	LINE FAULT
1215	2-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:09	11:14	0:05	LINE FAULT
1216	2-Oct-21	TUMKUR	66	HINDASGHATTA66-HIRIYUR220KV	HINDASGHATTA_66	16:36	18:17	1:41	LINE CLEAR AVAILED
1217	2-Oct-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	7:28	7:39	0:11	MAIN SUPPLY FAILURE
1218	2-Oct-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	3:48	3:53	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1219	2-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	0:43	2:02	1:18	LINE CLEAR AVAILED
1220	2-Oct-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	9:13	9:23	0:09	LINE FAULT
1221	2-Oct-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:16	10:31	0:15	LINE FAULT
1222	2-Oct-21	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	SIRA_66,GULIGENAHALLI_66	16:08	16:16	0:08	LINE FAULT
1223	2-Oct-21	TUMKUR	66	TR-1	HOLALKERE_66	7:28	7:41	0:13	MAIN SUPPLY FAILURE
1224	2-Oct-21	TUMKUR	66	TR-1	MADADKERE_66	6:52	7:03	0:11	TRANSFORMER FAULT
1225	2-Oct-21	TUMKUR	66	TR-2	HINDASGHATTA_66	6:43	7:55	1:11	LINE CLEAR AVAILED
1226	2-Oct-21	TUMKUR	66	TR-2	HINDASGHATTA_66	16:26	18:17	1:51	LINE CLEAR AVAILED
1227	2-Oct-21	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	5:56	6:17	0:20	LINE FAULT
1228	2-Oct-21	TUMKUR	110	KEREKODI-HONNAVALLI 110	KEREKODI_110	17:00	17:02	0:01	HAND TRIPPED
1229	2-Oct-21	TUMKUR	110	TR-1	KEREKODI_66	8:38	8:57	0:18	HAND TRIPPED
1230	2-Oct-21	TUMKUR	110	TR-1	KEREKODI_66	17:02	17:55	0:53	HAND TRIPPED
1231	3-Oct-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1232	3-Oct-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1233	3-Oct-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
1234	3-Oct-21	BAGALKOT	110	110/11KV,HV1	BELGAUM_110	9:25	17:03	7:38	LINE CLEAR AVAILED
1235	3-Oct-21	BAGALKOT	110	110/11KV,HV1	BELGAUM_110	17:05	18:05	1:00	HAND TRIPPED
1236	3-Oct-21	BAGALKOT	110	110/11KV,HV1	GOKAK_110	14:04	18:11	4:07	HAND TRIPPED
1237	3-Oct-21	BAGALKOT	110	110/11KV,HV1	KULIGERE CROSS_110	10:22	10:40	0:18	LINE CLEAR AVAILED
1238	3-Oct-21	BAGALKOT	110	110/11KV,HV2	BELGAUM_110	9:25	17:04	7:39	LINE CLEAR AVAILED
1239	3-Oct-21	BAGALKOT	110	110/11KV,HV2	BELGAUM_110	17:05	18:05	1:00	HAND TRIPPED
1240	3-Oct-21	BAGALKOT	110	110/11KV,HV2	KULIGERE CROSS_110	10:22	10:40	0:18	LINE CLEAR AVAILED
1241	3-Oct-21	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	18:07	18:18	0:11	TRANSFORMER FAULT
1242	3-Oct-21	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	21:17	21:27	0:10	TRANSFORMER FAULT
1243	3-Oct-21	BAGALKOT	110	110/11KV,HV3&HV4(HV1&HV2)	FORT_33,RM2_33,SADASHIVANAGAR_33,KLE_33,GIS SHRINAGAR_33 BELGAUM_110	10:05	17:51	7:46	LINE CLEAR AVAILED
1244	3-Oct-21	BAGALKOT	110	110/11KV,HV3(HV2)&HV1	MUDHOL_110	10:08	15:37	5:29	LINE CLEAR AVAILED
1245	3-Oct-21	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1246	3-Oct-21	BAGALKOT	110	110/33KV,HV3	RIDDI SIDDI_33,KOLAVI SUGARS_33 GOKAK_110	14:04	18:12	4:08	HAND TRIPPED
1247	3-Oct-21	BAGALKOT	110	BELGAUM220-BELGAUM	BELGAUM_110	10:00	17:03	7:03	LINE CLEAR AVAILED
1248	3-Oct-21	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	13:05	13:15	0:10	LINE FAULT
1249	3-Oct-21	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	16:57	17:15	0:18	LINE FAULT
1250	3-Oct-21	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	17:23	17:45	0:22	LINE FAULT
1251	3-Oct-21	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1252	3-Oct-21	BAGALKOT	110	GHATAPRABHA220- GOKAK	GOKAK_110	13:58	18:07	4:09	LINE CLEAR AVAILED
1253	3-Oct-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1254	3-Oct-21	BAGALKOT	110	HATTARAGI-DADDI(BELGAUM)	DADDI_110	18:01	18:02	0:01	HAND TRIPPED
1255	3-Oct-21	BAGALKOT	110	HATTARAGI-DADDI(BELGAUM)	DADDI_110	13:20	13:25	0:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1256	3-Oct-21	BAGALKOT	110	HATTARAGI-HUKKERI	HATTARAGI_110	18:01 (03.10.2021)			LINE OPEN:LINE FAULT
1257	3-Oct-21	BAGALKOT	110	HUKKERI-HATTARAGI	HUKKERI_110	13:20	13:21	0:01	HAND TRIPPED
1258	3-Oct-21	BAGALKOT	110	HUKKERI-HATTARAGI	HUKKERI_110	16:55	17:21	0:26	HAND TRIPPED
1259	3-Oct-21	BAGALKOT	110	HUKKERI-HATTARAGI	HUKKERI_110	17:21 (03.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1260	3-Oct-21	BAGALKOT	110	ITNAL-HIDIKAL(RAIBAG)	HIDIKAL_110	15:27	16:37	1:10	LINE CLEAR AVAILED
1261	3-Oct-21	BAGALKOT	110	JAMBAGI-MUDHOL	MUDHOL_110	10:37	15:33	4:56	NFBC ISSUED
1262	3-Oct-21	BAGALKOT	110	KUMTA-KRCL	KUMTA_110	3:10	3:36	0:26	LINE FAULT
1263	3-Oct-21	BAGALKOT	110	MAMADAPUR-SOUBAGYA LAXMI	MAMADAPUR(GHP)_110	18:35	18:46	0:11	LINE CLEAR AVAILED
1264	3-Oct-21	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	12:28	14:59	2:31	LINE FAULT
1265	3-Oct-21	BAGALKOT	110	RAY SOLAR-ALBAL	ALBAL_110	6:25	11:33	5:08	LINE CLEAR AVAILED
1266	3-Oct-21	BAGALKOT	110	RAY SOLAR-ALBAL	ALBAL_110	16:10	19:01	2:51	LINE CLEAR AVAILED
1267	3-Oct-21	BAGALKOT	110	SAIPRIYA SOLAR -ALBAL	ALBAL_110	6:24	11:33	5:09	LINE CLEAR AVAILED
1268	3-Oct-21	BAGALKOT	110	SAIPRIYA SOLAR -ALBAL	ALBAL_110	16:10	19:00	2:50	LINE CLEAR AVAILED
1269	3-Oct-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1270	3-Oct-21	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1271	3-Oct-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1272	3-Oct-21	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	17:22	20:29	3:07	HAND TRIPPED
1273	3-Oct-21	BAGALKOT	110	SIRSI-SIDDAPUR(JOG1)	STATION NOT AFFECTED SIRSI_110	17:22	20:29	3:07	HAND TRIPPED
1274	3-Oct-21	BAGALKOT	220	220/110KV, HV1	CHIKKODI_220	11:32 (01.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1275	3-Oct-21	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	13:41	14:34	0:53	LINE FAULT
1276	3-Oct-21	BAGALKOT	220	CHIKKODI- BELGAUM2	CHIKKODI_220	16:52	19:21	2:29	LINE CLEAR AVAILED
1277	3-Oct-21	BAGALKOT	220	CHIKKODI220- BELGAUM1	CHIKKODI_220	7:32 (02.10.2021)	19:21 (03.10.2021)	11:49	LINE CHARGED
1278	3-Oct-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	13:48	20:19	6:31	LINE FAULT
1279	3-Oct-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1280	3-Oct-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1281	3-Oct-21	BAGALKOT	220	RANEENNUR- BELLIGAVI	RANEENNUR_220	12:18	12:54	0:36	LINE FAULT
1282	3-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	12:08 (02.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1283	3-Oct-21	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	12:08 (02.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1284	3-Oct-21	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	16:37 (03.10.2021)			LINE OPEN:LINE FAULT
1285	3-Oct-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	2:20 (02.10.2021)	1:30 (03.10.2021)	23:10	LINE CHARGED
1286	3-Oct-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1287	3-Oct-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1288	3-Oct-21	BAGALKOT	400	400/220KV, ICT2	DHONI_400	13:02	15:54	2:52	TRANSFORMER FAULT
1289	3-Oct-21	BAGALKOT	400	DHONI- GUTTUR	DHONI_400	10:55 (02.10.2021)	17:12 (03.10.2021)	6:17	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1290	3-Oct-21	BENGALURU	66	A STATION 66 - A STATION 220	A STATION 66	14:51	14:58	0:07	LOAD CHANGE OVER
1291	3-Oct-21	BENGALURU	66	A STATION 66 - A STATION 220	A STATION 66	15:18	15:31	0:13	LOAD CHANGE OVER
1292	3-Oct-21	BENGALURU	66	A STATION 66 - A STATION 220	A STATION 66	16:36	17:11	0:35	MAIN SUPPLY FAILURE
1293	3-Oct-21	BENGALURU	66	A STATION 66 - A STATION 220	A STATION 66	21:50	21:53	0:03	LOAD CHANGE OVER
1294	3-Oct-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	12:30	12:33	0:03	LOAD CHANGE OVER
1295	3-Oct-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	11:10	11:17	0:07	MAIN SUPPLY FAILURE
1296	3-Oct-21	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	11:11	11:37	0:26	MAIN SUPPLY FAILURE
1297	3-Oct-21	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	15:11	15:16	0:04	LINE FAULT
1298	3-Oct-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:35	17:45	0:09	LINE FAULT
1299	3-Oct-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:46	17:53	0:07	LINE FAULT
1300	3-Oct-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	9:08	9:29	0:20	LINE FAULT
1301	3-Oct-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	16:54	17:00	0:05	LINE FAULT
1302	3-Oct-21	BENGALURU	66	HV1	BIDADI 220	10:00	18:00	8:00	LINE CLEAR AVAIED
1303	3-Oct-21	BENGALURU	66	HV1	REMCO	11:10	11:37	0:27	MAIN SUPPLY FAILURE
1304	3-Oct-21	BENGALURU	66	HV1	KONDASPURA	11:30	14:40	3:10	LINE CLEAR AVAIED
1305	3-Oct-21	BENGALURU	66	HV1	TEMAGONDALU	18:05	19:24	1:19	LINE CLEAR AVAIED
1306	3-Oct-21	BENGALURU	66	HV1	DODDABELAVANGALA	16:16	16:45	0:29	LINE CLEAR AVAIED
1307	3-Oct-21	BENGALURU	66	HV1	KOLAR 220	10:37	12:36	1:59	LINE CLEAR AVAIED
1308	3-Oct-21	BENGALURU	66	HV1	JIGANI 220	10:35	10:46	0:11	LINE CLEAR AVAIED
1309	3-Oct-21	BENGALURU	66	HV2	BIDADI 220	10:00	18:00	8:00	LINE CLEAR AVAIED
1310	3-Oct-21	BENGALURU	66	HV2	KONDASPURA	12:06	14:51	2:45	LINE CLEAR AVAIED
1311	3-Oct-21	BENGALURU	66	HV2	DODDABELAVANGALA	2:01	2:10	0:08	TRANSFORMER FAULT
1312	3-Oct-21	BENGALURU	66	HV2	KOLAR 220	10:37	11:00	0:23	LOAD CHANGE OVER
1313	3-Oct-21	BENGALURU	66	HV2	KOLAR 220	14:04	14:16	0:12	LOAD CHANGE OVER
1314	3-Oct-21	BENGALURU	66	HV2	JIGANI 220	10:36	10:46	0:10	LOAD CHANGE OVER
1315	3-Oct-21	BENGALURU	66	HV3	BIDADI 220	10:00	18:00	8:00	LINE CLEAR AVAIED
1316	3-Oct-21	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	10:34	10:40	0:06	LOAD CHANGE OVER
1317	3-Oct-21	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	17:49	17:54	0:05	LOAD CHANGE OVER
1318	3-Oct-21	BENGALURU	66	JIGANI LINK ROAD - B G ROAD	JIGANI LINK ROAD	17:49	17:54	0:05	LOAD CHANGE OVER
1319	3-Oct-21	BENGALURU	66	JIGANI LINK ROAD - JIGANI 220	JIGANI LINK ROAD	10:34	10:40	0:06	LOAD CHANGE OVER
1320	3-Oct-21	BENGALURU	66	KADUGODI - ARMY WELFARE	ARMY WELFARE	12:08	12:10	0:02	LINE CLEAR AVAIED
1321	3-Oct-21	BENGALURU	66	KANTEERAVA - A STATION 220	KANTEERAVA	16:36	17:35	0:59	MAIN SUPPLY FAILURE
1322	3-Oct-21	BENGALURU	66	KENGERI SATELLITE TOWN - VRISHABHAVATHI 220	KENGERI SATELLITE TOWN	11:10	11:40	0:30	MAIN SUPPLY FAILURE
1323	3-Oct-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT)	14:04	14:16	0:12	LOAD CHANGE OVER
1324	3-Oct-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:37	11:00	0:23	LOAD CHANGE OVER
1325	3-Oct-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	14:04	14:16	0:12	LOAD CHANGE OVER
1326	3-Oct-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:30	17:36	0:06	LINE FAULT
1327	3-Oct-21	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	19:46	20:28	0:42	LINE CLEAR AVAIED
1328	3-Oct-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:27	12:23	0:56	LINE CLEAR AVAIED
1329	3-Oct-21	BENGALURU	66	SHOBHA INDRAPRASTA - A STATION 220	SHOBHA INDRAPRASTA	16:36	17:32	0:56	MAIN SUPPLY FAILURE
1330	3-Oct-21	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	17:35	17:54	0:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1331	3-Oct-21	BENGALURU	66	T G HALLI - BYDARAHALLI	BWSSB (EHT)	16:39	17:40	1:00	LINE CLEAR AVAIED
1332	3-Oct-21	BENGALURU	220	HV1	A STATION 220	16:36	17:32	0:56	TRANSFORMER FAULT
1333	3-Oct-21	BENGALURU	220	HV2	JIGANI 220	10:50	17:52	7:02	LINE CLEAR AVAIED
1334	3-Oct-21	BENGALURU	220	LV1	JIGANI 220	10:37	10:47	0:10	LOAD CHANGE OVER
1335	3-Oct-21	BENGALURU	220	LV1	JIGANI 220	17:30	22:38	5:08	LOAD CHANGE OVER
1336	3-Oct-21	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	0:14	4:02	3:48	LINE FAULT
1337	3-Oct-21	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHABHAVATHI 220	11:11	11:31	0:20	LINE FAULT
1338	3-Oct-21	GULBARGA	66	HV3	TELAGI_66	8:30(30.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAIED
1339	3-Oct-21	GULBARGA	66	MUNIRABAD-MSDLIN	HANASI_66	17:31(2.10.2021)	9:01(03.10.2021)	15:30 HRS	LINE CHARGED
1340	3-Oct-21	GULBARGA	110	DEODURGA-RAICHUR	DEODURGA_110,GABBUR_110,GOOGLE_110	10:05	10:10	0:05	MAIN SUPPLY FAILURE
1341	3-Oct-21	GULBARGA	110	GALAG_ALKOD	GALAG_110	5:20	5:30	0:10	MAIN SUPPLY FAILURE
1342	3-Oct-21	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANWADA_110,NSSK FACTORY	11:40	11:45	0:05	MAIN SUPPLY FAILURE
1343	3-Oct-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110, DIGGI_110	6:14	6:25	0:11	MAIN SUPPLY FAILURE
1344	3-Oct-21	GULBARGA	110	HATTI-SOMANAMARADI_IPP	HATTI_110	22:23	22:31	0:08	MAIN SUPPLY FAILURE
1345	3-Oct-21	GULBARGA	110	HUMNABAD-HUMNABAD1	MANEKAHALLI_110	3:49	4:02	0:13	LINE FAULT
1346	3-Oct-21	GULBARGA	110	HUMNABAD-HUMNABAD1	MANEKAHALLI_110	5:46	5:52	0:06	LINE FAULT
1347	3-Oct-21	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	16:35(28.09.2021)			LINE OPEN:LINE CLEAR AVAIED
1348	3-Oct-21	GULBARGA	110	HV1	JEWARGI_110	14:00	14:10	0:10	MAIN SUPPLY FAILURE
1349	3-Oct-21	GULBARGA	110	HV1	GANDHINAGAR_110	4:23	4:30	0:07	LINE CLEAR AVAIED
1350	3-Oct-21	GULBARGA	110	HV2	YELBURGA_110	6:24	6:52	0:28	LINE CLEAR AVAIED
1351	3-Oct-21	GULBARGA	110	HV3	VALKAMDINNI_110	15:25	15:30	0:05	TRANSFORMER FAULT
1352	3-Oct-21	GULBARGA	110	HV3	VALKAMDINNI_110	15:35	15:40	0:05	TRANSFORMER FAULT
1353	3-Oct-21	GULBARGA	110	HV3	VALKAMDINNI_110	18:00	18:05	0:05	TRANSFORMER FAULT
1354	3-Oct-21	GULBARGA	110	HV3	TEKKALKOTE_110	7:40	7:52	0:12	TRANSFORMER FAULT
1355	3-Oct-21	GULBARGA	110	HV3	TEKKALKOTE_110	8:50	9:15	0:25	TRANSFORMER FAULT
1356	3-Oct-21	GULBARGA	110	HV3	TEKKALKOTE_110	11:03	11:20	0:17	TRANSFORMER FAULT
1357	3-Oct-21	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110,KUKUNOOR_110	0:56	1:28	0:32	LINE FAULT
1358	3-Oct-21	GULBARGA	110	MANGALURU-BEVOOR	MANGALURU_110	0:55	1:35	0:40	MAIN SUPPLY FAILURE
1359	3-Oct-21	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPURA_110	22:40	22:50	0:10	MAIN SUPPLY FAILURE
1360	3-Oct-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	14:00	14:05	0:05	MAIN SUPPLY FAILURE
1361	3-Oct-21	GULBARGA	110	PUNAB GHATA-NEELAGUNDA	PUNAB GHATA_66	9:20	9:30	0:10	LINE FAULT
1362	3-Oct-21	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110	12:39	15:40	3:01	LINE CLEAR AVAIED
1363	3-Oct-21	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	12:40	15:48	3:08	LINE CLEAR AVAIED
1364	3-Oct-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAIED
1365	3-Oct-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAIED
1366	3-Oct-21	GULBARGA	110	SINDANOOR-NIRLOOPI	NIRLOOPI_IPP	21:05	21:20	0:15	LINE FAULT
1367	3-Oct-21	GULBARGA	110	SINDANOOR-SIRIGUPPA	NSLSUGAR_IPP	3:40	3:55	0:15	LINE FAULT
1368	3-Oct-21	GULBARGA	110	SINDANOOR-SUZLON-1	SINDANOOR_110	1:30	1:45	0:15	LINE FAULT
1369	3-Oct-21	GULBARGA	110	TEKKALKOTE-ABMN_SLR	TEKKALKOTE_110	18:40	20:50	2:10	LINE CLEAR AVAIED
1370	3-Oct-21	GULBARGA	110	TEKKALKOTE-RENEW SOLAR	TEKKALKOTE_110	15:10	15:20	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1371	3-Oct-21	GULBARGA	110	TEKKALKOTE-SINDHANOOR	TEKKALKOTE_110	3:40	3:55	0:15	MAIN SUPPLY FAILURE
1372	3-Oct-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	0:54	1:21	0:27	MAIN SUPPLY FAILURE
1373	3-Oct-21	GULBARGA	220	HV1	KUSTAGI_220	0:56	1:31	0:35	TRANSFORMER FAULT
1374	3-Oct-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1375	3-Oct-21	GULBARGA	220	HV2	KUSTAGI_220	0:56	1:15	0:19	TRANSFORMER FAULT
1376	3-Oct-21	GULBARGA	220	HV2,LV2	HALBARGA_220	5:40	5:47	0:07	MAIN SUPPLY FAILURE
1377	3-Oct-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	23:45(2.10.2021)	00:21(3.10.2021)	0:36	LINE CHARGED
1378	3-Oct-21	GULBARGA	400	BTPSG-GUTTUR	BTPS_400	12:36	19:40	7:04	LINE FAULT
1379	3-Oct-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	6:09	6:12	0:03	LINE FAULT
1380	3-Oct-21	HASSAN	66	HV1	MALALI_66	6:00	6:10	0:10	MAIN SUPPLY FAILURE
1381	3-Oct-21	HASSAN	66	MALALI-CRPATNA	MALALI_66	6:00	6:10	0:10	MAIN SUPPLY FAILURE
1382	3-Oct-21	HASSAN	66	MATTNAV-CRPATNA	MATTNAVILE_66	6:18	6:28	0:10	LINE FAULT
1383	3-Oct-21	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	6:18	6:28	0:10	LINE FAULT
1384	3-Oct-21	HASSAN	110	HV1	SHIKARIPURA_110	10:05	18:00	7:55	LINE CLEAR AVAILED
1385	3-Oct-21	HASSAN	110	HV2	KUNDAPURA_110	1:40	1:52	0:12	TRANSFORMER FAULT
1386	3-Oct-21	HASSAN	110	HV2	SHIKARIPURA_110	10:05	18:00	7:55	LINE CLEAR AVAILED
1387	3-Oct-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	10:17	16:53	6:36	LINE CLEAR AVAILED
1388	3-Oct-21	HASSAN	220	MRSSH-M-VAHAH1	MRSMG_220	15:01(02.10.2021)	15:14(03.10.2021)	24:12 hrs	LINE CHARGED
1389	3-Oct-21	HASSAN	220	MRSSH-M-VAHAH2	MRSMG_220	1:42	15:15	13:33	LINE FAULT
1390	3-Oct-21	HASSAN	220	SHRAVATY-SHIMOGA4	sharavathy_gen	12:45	13:03	0:18	LINE FAULT
1391	3-Oct-21	HASSAN	220	SHRVATY-SIRISI 1	sharavathy_gen	16:37 (3.10.2021)			LINE OPEN:LINE FAULT
1392	3-Oct-21	HASSAN	220	SHRVATY-ST1	sharavathy_gen	16:59(03.10.2021)			LINE OPEN:LINE FAULT
1393	3-Oct-21	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	16:59(03.10.2021)			LINE OPEN:LINE FAULT
1394	3-Oct-21	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	15:01(02.10.2021)	15:14(03.10.2021)	24:12 hrs	LINE CHARGED
1395	3-Oct-21	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	1:42	15:15	13:33	LINE FAULT
1396	3-Oct-21	MYSURU	66	DUNDANAHALLI-HULIYUR DURGA	DUNDANAHALLI_66	13:13	15:35	2:21	LOAD CHANGE OVER
1397	3-Oct-21	MYSURU	66	FTS-HOOTGALLY 1	NO STATIONS EFFECTED	6:31:29 (29/09/2021)			LINE OPEN:LINE CLEAR AVAILED
1398	3-Oct-21	MYSURU	66	FTS-HOOTGALLY 2	NO STATIONS EFFECTED	6:31:24 (29/09/2021)			LINE OPEN:LINE CLEAR AVAILED
1399	3-Oct-21	MYSURU	66	G UKKADA-SR PATNA	NO STATIONS EFFECTED	11:23	18:02	6:39	NFBC ISSUED
1400	3-Oct-21	MYSURU	66	HOOTAGALLI-FTS-1	NO STATIONS EFFECTED	2:05	2:19	0:14	LINE FAULT
1401	3-Oct-21	MYSURU	66	HOOTAGALLI-FTS-1	NO STATIONS EFFECTED	11:40	12:36	0:56	LINE CLEAR AVAILED
1402	3-Oct-21	MYSURU	66	HOOTAGALLI-FTS-2	NO STATIONS EFFECTED	11:40	12:36	0:56	LINE CLEAR AVAILED
1403	3-Oct-21	MYSURU	66	HOOTAGALLI-MCF	BELAGOLA_66	18:13	18:24	0:11	LINE FAULT
1404	3-Oct-21	MYSURU	66	HV1	SINDHUVALI_66	10:03	18:10	8:06	LINE CLEAR AVAILED
1405	3-Oct-21	MYSURU	66	HV2	SINDHUVALI_66	9:45	18:05	8:20	LINE CLEAR AVAILED
1406	3-Oct-21	MYSURU	66	KADAKOLA-NANJANGUDU	NANJANGUDU_66	10:38	17:38	7:00	NFBC ISSUED
1407	3-Oct-21	MYSURU	66	KADAKOLA-SARGUR-2	DOORA_66 HULLAHALLI_66 HURA_66	6:24	6:32	0:08	LINE FAULT
1408	3-Oct-21	MYSURU	66	KADAKOLA-THANDYA	THANDYA_66	10:07	18:49	8:42	NFBC ISSUED
1409	3-Oct-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	16:38	16:45	0:06	LINE FAULT
1410	3-Oct-21	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	18:28	18:45	0:17	LINE FAULT
1411	3-Oct-21	MYSURU	66	NANJANGUDU-BEGUR	NO STATIONS EFFECTED	10:07	18:31	8:24	NFBC ISSUED
1412	3-Oct-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1413	3-Oct-21	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	0:58	1:07	0:08	LINE FAULT
1414	3-Oct-21	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	9:32	9:41	0:08	LINE FAULT
1415	3-Oct-21	MYSURU	66	SINDHUVALLI-BEGUR	SINDHUVALLI_66	10:05	12:35	2:30	LINE CLEAR AVAILED
1416	3-Oct-21	MYSURU	66	SINDHUVALLI-NANJANGUDU	SINDHUVALLI_66	10:05	12:35	2:30	LINE CLEAR AVAILED
1417	3-Oct-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1418	3-Oct-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1419	3-Oct-21	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_66,KADAJ JI_66	12:59	13:12	0:12	LINE FAULT
1420	3-Oct-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:04	12:17	0:13	LINE FAULT
1421	3-Oct-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	12:04	12:17	0:12	LINE FAULT
1422	3-Oct-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	16:53	17:28	0:35	MAIN SUPPLY FAILURE
1423	3-Oct-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:04	6:10	0:05	LINE FAULT
1424	3-Oct-21	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	NIDSALE_66,DUNDANAHALLI_66	14:33	15:31	0:58	LINE CLEAR AVAILED
1425	3-Oct-21	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	NIDSALE_66,DUNDANAHALLI_66	22:36	23:08	0:31	LINE FAULT
1426	3-Oct-21	TUMKUR	66	MADHUGIRI 66KV- MADHUGIRI	MADHUGIRI_66	3:53	3:57	0:04	HAND TRIPPED
1427	3-Oct-21	TUMKUR	66	MADHUGIRI 66KV- MADHUGIRI	MADHUGIRI_66	6:49	7:51	1:01	LINE CLEAR AVAILED
1428	3-Oct-21	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	16:47	17:37	0:50	MAIN SUPPLY FAILURE
1429	3-Oct-21	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	16:47	17:32	0:44	MAIN SUPPLY FAILURE
1430	3-Oct-21	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	16:47	17:32	0:44	MAIN SUPPLY FAILURE
1431	3-Oct-21	TUMKUR	66	SOKKE 66-JAGLUR66	SOKKE_66	9:22	9:53	0:31	LINE FAULT
1432	3-Oct-21	TUMKUR	66	TR-1	BALENAHALLI_66	9:54	16:24	6:29	LINE CLEAR AVAILED
1433	3-Oct-21	TUMKUR	66	TR-1	BALENAHALLI_66	9:54	16:24	6:29	LINE CLEAR AVAILED
1434	3-Oct-21	TUMKUR	66	TR-1	NIDISALE_66	11:44	12:03	0:18	HAND TRIPPED
1435	3-Oct-21	TUMKUR	66	TR-1	NIDISALE_66	13:11	13:12	0:01	MAIN SUPPLY FAILURE
1436	3-Oct-21	TUMKUR	66	TR-1	NIDISALE_66	22:35	23:55	1:20	MAIN SUPPLY FAILURE
1437	3-Oct-21	TUMKUR	66	TR-2	HINDASGHATTA_66	12:20	12:58	0:37	LINE CLEAR AVAILED
1438	3-Oct-21	TUMKUR	110	TR-1	TURUVEKERE_110	9:58	10:24	0:26	TRANSFORMER FAULT
1439	3-Oct-21	TUMKUR	220	TR-3	HIRIYUR_220	23:38	23:59	0:20	TRANSFORMER FAULT
1440	4-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
1441	4-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1442	4-Oct-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1443	4-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1444	4-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1445	4-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1446	4-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1447	4-Oct-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1448	4-Oct-2021	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1449	4-Oct-2021	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110 & KHAROSHI & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1450	4-Oct-2021	BAGALKOT	220	220/110KV, HV1	CHIKKODI_220	11:32 (01.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1451	4-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	12:08 (02.10.2021)	16:56 (04.10.2021)	28:47hrs	LINE CHARGED
1452	4-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	12:08 (02.10.2021)	16:56 (04.10.2021)	28:48hrs	LINE CHARGED
1453	4-Oct-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	16:37 (03.10.2021)	18:02 (04.10.2021)	25:25hrs	LINE CHARGED
1454	4-Oct-2021	BAGALKOT	110	HATTARAGI-HUKKERI	HATTARAGI_110	18:01 (03.10.2021)	11:20 (04.10.2021)	17:19hrs	LINE CHARGED
1455	4-Oct-2021	BAGALKOT	110	HUKKERI-HATTARAGI	HUKKERI_110	17:21 (03.10.2021)	11:19 (04.10.2021)	17:59hrs	LINE CHARGED
1456	4-Oct-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED AINAPUR_110	18:40	18:45	0:05	LOAD CURTAILMENT
1457	4-Oct-2021	BAGALKOT	110	AMBEWADI220-SUPA1	STATION NOT AFFECTED AMBEWADI_220	8:38	8:48	0:10	LINE FAULT
1458	4-Oct-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ATHARGA_110	18:40	18:45	0:05	LOAD CURTAILMENT
1459	4-Oct-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:26	11:02	0:36	HAND TRIPPED
1460	4-Oct-2021	BAGALKOT	220	BELGAUM-KANBARGI1	STATION NOT AFFECTED BELGAUM_220	10:29	11:00	0:31	HAND TRIPPED
1461	4-Oct-2021	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	23:15	23:22	0:07	HAND TRIPPED
1462	4-Oct-2021	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	18:42	18:52	0:10	LOAD CURTAILMENT
1463	4-Oct-2021	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	19:36	19:44	0:08	HAND TRIPPED
1464	4-Oct-2021	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	20:00	20:04	0:04	TRANSFORMER FAULT
1465	4-Oct-2021	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, IE_33, DHUMMAWAD_33	15:30	20:15	4:45	LINE CLEAR AVAILED
1466	4-Oct-2021	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	8:19	17:18	8:59	LINE CLEAR AVAILED
1467	4-Oct-2021	BAGALKOT	110	110/11KV, HV2	SAVALAGI_110	18:42	18:48	0:06	LOAD CURTAILMENT
1468	4-Oct-2021	BAGALKOT	110	SANKESHWAR- HUKKERI	HUKKERI_110	13:02	13:15	0:13	HAND TRIPPED
1469	4-Oct-2021	BAGALKOT	110	MAHALINGAPUR- RANNABELAGALI	RANNABELAGALI_110	8:26	14:10	5:44	HAND TRIPPED
1470	4-Oct-2021	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	18:42	18:53	0:11	LOAD CURTAILMENT
1471	4-Oct-2021	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	14:10	14:20	0:10	HAND TRIPPED
1472	4-Oct-2021	BAGALKOT	110	110/11KV, HV2	MATTIHAL_110	11:59	12:06	0:07	TRANSFORMER FAULT
1473	4-Oct-2021	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	18:41	18:49	0:08	LOAD CURTAILMENT
1474	4-Oct-2021	BAGALKOT	110	110/11KV, HV1	KUDAL SANGAM_110	18:41	18:45	0:04	LOAD CURTAILMENT
1475	4-Oct-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	9:09	11:08	1:59	HAND TRIPPED
1476	4-Oct-2021	BAGALKOT	110	KUDACHI220- KUDACHI (AINAPUR)	AINAPUR_110	10:32	11:27	0:55	HAND TRIPPED
1477	4-Oct-2021	BAGALKOT	110	KUDACHI220-TERDAL (MORAB)	MORAB_110	10:32	12:07	1:35	HAND TRIPPED
1478	4-Oct-2021	BAGALKOT	110	KUDACHI220- AINAPUR( YELPARAHATTI)	YELPARAHATTI_110	10:32	11:50	1:18	HAND TRIPPED
1479	4-Oct-2021	BAGALKOT	110	KUDACHI220- UGARKHUD (KUDACHI)	KUDACHI_110	10:03	12:09	2:06	HAND TRIPPED
1480	4-Oct-2021	BAGALKOT	110	KIRUVATTI- UMMACHAGI	KIRUVATTI_110	9:38	9:44	0:06	HAND TRIPPED
1481	4-Oct-2021	BAGALKOT	110	KIRUVATTI- UMMACHAGI	KIRUVATTI_110	10:00	13:52	3:52	LINE CLEAR AVAILED
1482	4-Oct-2021	BAGALKOT	110	JAMKHANDI- MAHALINGAPUR(NAVALAGI)	NAVALAGI_110	9:18	9:21	0:03	HAND TRIPPED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1483	4-Oct-2021	BAGALKOT	110	110/33KV, HV3	HIDIKAL_110, KOLIGUDDA_33, MYTRA SOLAR_33	18:42	18:47	0:05	LOAD CURTAILMENT
1484	4-Oct-2021	BAGALKOT	110	HUKKERI- HATTARGI	HATTARGI_110	17:15	17:22	0:07	LINE FAULT
1485	4-Oct-2021	BAGALKOT	110	110/33KV, HV1	HANGAL_110	18:42	19:17	0:35	LOAD CURTAILMENT
1486	4-Oct-2021	BAGALKOT	110	110/11KV, HV1	GOKAK_110	10:18	13:42	3:24	LINE CLEAR AVAILED
1487	4-Oct-2021	BAGALKOT	110	110/11KV, HV2	GOKAK_110	13:58	18:33	4:35	LINE CLEAR AVAILED
1488	4-Oct-2021	BAGALKOT	110	110/11KV, HV4	GAJENDRAGAD_110	18:41	18:53	0:12	LOAD CURTAILMENT
1489	4-Oct-2021	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_110	8:10	8:29	0:19	LINE FAULT
1490	4-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	17:40 (04.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1491	4-Oct-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	14:18	14:22	0:04	HAND TRIPPED
1492	4-Oct-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	16:03	17:43	1:40	HAND TRIPPED
1493	4-Oct-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	18:21	18:33	0:12	HAND TRIPPED
1494	4-Oct-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	SIRSI_220	14:19	14:23	0:04	HAND TRIPPED
1495	4-Oct-2021	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	10:10	15:09	5:00	LINE CLEAR AVAILED
1496	4-Oct-2021	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	13:45	16:24	2:39	LINE CLEAR AVAILED
1497	4-Oct-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	14:26	16:10	1:44	LINE CLEAR AVAILED
1498	4-Oct-2021	BAGALKOT	110	HAVERI220-HAVERI	HAVERI_220	10:04	17:20	7:17	LINE CLEAR AVAILED
1499	4-Oct-2021	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	13:45	16:26	8:17	LINE FAULT
1500	4-Oct-2021	BAGALKOT	110	110/33KV,HV3	ALNAVAR LAKKAMANAHALLI_110	15:25	15:30	9:17	TRANSFORMER FAULT
1501	4-Oct-2021	BAGALKOT	110	110/33KV,HV3	ALNAVAR LAKKAMANAHALLI_110	15:35	15:40	10:17	TRANSFORMER FAULT
1502	4-Oct-2021	BAGALKOT	110	HIDIKAL-GHATAPRABHA2	HIDKALDAM_110KV, ISLAMPUR_110	8:10	8:29	0:19	LINE FAULT
1503	4-Oct-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	8:26	10:48	12:17	LINE FAULT
1504	4-Oct-2021	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	19:39 (04.10.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1505	4-Oct-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	CHIKKODI_220	13:02	13:12	0:10	LINE FAULT
1506	4-Oct-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	CHIKKODI_220	13:30	13:38	0:08	LINE FAULT
1507	4-Oct-2021	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_220	14:12	14:50	0:38	LINE FAULT
1508	4-Oct-2021	BAGALKOT	110	CHIKKODI-HUKKERI	HUKKERI_110	13:18	13:30	0:12	HAND TRIPPED
1509	4-Oct-2021	BAGALKOT	110	CHIKKODI-HUKKERI	HUKKERI_110	13:42	17:22	3:40	HAND TRIPPED
1510	4-Oct-2021	BAGALKOT	220	220/110 HV1,LV1	KARWAR_220	12:36	13:47	1:15	LINE CLEAR AVAILED
1511	4-Oct-2021	BAGALKOT	110	KARWAR - ARG(AARGA)	KARWAR_220	11:30	12:18	0:48	LINE FAULT
1512	4-Oct-2021	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	11:06	17:50	1:48	LINE FAULT
1513	4-Oct-2021	BAGALKOT	220	BIJAPUR-INDI1	BIJAPUR_220	11:05	15:05	2:48	LINE CLEAR AVAILED
1514	4-Oct-2021	BAGALKOT	220	BIJAPUR-INDI2	BIJAPUR_220	16:05	16:39	3:48	LINE CLEAR AVAILED
1515	4-Oct-2021	BAGALKOT	220	220/110KV,HV2	BIJAPUR_220	18:13	18:25	4:48	LINE CLEAR AVAILED
1516	4-Oct-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1517	4-Oct-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1518	4-Oct-2021	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_220	13:57 (29.09.2021)			LINE OPEN:LINE CLEAR AVAILED
1519	4-Oct-2021	BAGALKOT	110	INDI-ZALKI2	ZALKI_110,INDI_110	19:05	21:15	2:10	LINE FAULT
1520	4-Oct-2021	BAGALKOT	220	INDI-BIJAPUR2	INDI_220	15:20	16:42	1:22	LINE CLEAR AVAILED
1521	4-Oct-2021	BAGALKOT	110	MANTUR-VAJRAMATTI2	MANTUR_110	7:27	7:35	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1522	4-Oct-2021	BAGALKOT	110	MANTUR-SHIROL	MANTUR_110	7:27	7:37	0:10	LINE FAULT
1523	4-Oct-2021	BAGALKOT	110	SHIROL-MANTUR	SHIROL_110	7:41	8:42	1:01	HAND TRIPPED
1524	4-Oct-2021	BAGALKOT	110	110/11KV,HV2	MUDHOL_110	7:40	9:10	1:30	HAND TRIPPED
1525	4-Oct-2021	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	1:13	8:51	7:38	HAND TRIPPED
1526	4-Oct-2021	BAGALKOT	110	MK HUBLI-BAILHONGAL	BAILHONGAL_110	6:16	7:32	1:16	LINE FAULT
1527	4-Oct-2021	BAGALKOT	110	UMMACHAGI-KIRUVATTI	UMMACHAGI_110	10:00	13:50	3:50	LINE CLEAR AVAIED
1528	4-Oct-2021	BAGALKOT	220	MAHALINGAPUR-ATHANI	ATHANI_220	8:26	12:32	4:06	LINE FAULT
1529	4-Oct-2021	BAGALKOT	220	ATHANI-KUDACHI	ATHANI_220	8:30	9:17	0:47	LOAD CURTAILMENT
1530	4-Oct-2021	BAGALKOT	220	KAKAMARI1- ATHANI	ATHANI_220	8:30	9:17	0:47	MAIN SUPPLY FAILURE
1531	4-Oct-2021	BAGALKOT	220	KAKAMARI2- ATHANI	ATHANI_220	8:30	9:17	0:47	MAIN SUPPLY FAILURE
1532	4-Oct-2021	BAGALKOT	220	220/110KV,HV1,LV1	ATHANI_220	8:30	9:17	0:47	MAIN SUPPLY FAILURE
1533	4-Oct-2021	BAGALKOT	110	220/110KV,HV2,LV2	ATHANI_220	8:30	9:17	0:47	MAIN SUPPLY FAILURE
1534	4-Oct-2021	BAGALKOT	110	110/11KV,HV1	ATHANI_220	8:26	9:22	0:56	TRANSFORMER FAULT
1535	4-Oct-2021	BAGALKOT	110	ATHANI220-ATHANI	ATHANI_110	8:30	9:17	0:47	MAIN SUPPLY FAILURE
1536	4-Oct-2021	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	8:30	9:17	0:47	MAIN SUPPLY FAILURE
1537	4-Oct-2021	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	8:26	9:20	0:54	LINE FAULT
1538	4-Oct-2021	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	8:26	9:22	0:56	LINE FAULT
1539	4-Oct-2021	BAGALKOT	110	ATHANI220-HALIYAL	HALIYAL_110	8:30	9:17	0:47	MAIN SUPPLY FAILURE
1540	4-Oct-2021	BAGALKOT	110	ATHANI220-KSSKN	ATHANI_220	8:30	9:17	0:47	MAIN SUPPLY FAILURE
1541	4-Oct-2021	BENGALURU	66	BMTC - EAST DIVISION COMPOUND 220	BMTC	14:52	15:15	0:23	MAIN SUPPLY FAILURE
1542	4-Oct-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - AUSTIN TOWN	AUSTIN TOWN	14:52	15:02	0:10	LINE CLEAR AVAIED
1543	4-Oct-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	BMTC	14:52	15:15	0:23	LINE FAULT
1544	4-Oct-2021	BENGALURU	220	HV1	EAST DIVISION COMPOUND 220	14:52	15:01	0:09	TRANSFORMER FAULT
1545	4-Oct-2021	BENGALURU	220	HV2	EAST DIVISION COMPOUND 220	14:52	15:01	0:09	TRANSFORMER FAULT
1546	4-Oct-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - B STATION	B STATION	14:52	15:03	0:11	LINE CLEAR AVAIED
1547	4-Oct-2021	BENGALURU	66	HV1	EAST DIVISION COMPOUND 220	14:52	15:24	0:32	LINE CLEAR AVAIED
1548	4-Oct-2021	BENGALURU	66	HV2	EAST DIVISION COMPOUND 220	14:52	15:03	0:11	LINE CLEAR AVAIED
1549	4-Oct-2021	BENGALURU	66	HV2	EPIP 220	14:08	14:12	0:04	TRANSFORMER FAULT
1550	4-Oct-2021	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	11:51	11:59	0:08	LINE FAULT
1551	4-Oct-2021	BENGALURU	66	HV2	BANASAWADI	12:38	12:55	0:17	LOAD CURTAILMENT
1552	4-Oct-2021	BENGALURU	66	HV2	BANASAWADI	13:50	14:03	0:13	LOAD CURTAILMENT
1553	4-Oct-2021	BENGALURU	66	HV2	BANASAWADI	16:58	17:05	0:07	LOAD CHANGE OVER
1554	4-Oct-2021	BENGALURU	66	IIsc - HEBBAL 220	IIsc	10:18	10:24	0:06	LOAD CHANGE OVER
1555	4-Oct-2021	BENGALURU	66	ITI 220 - BANASAWADI	BANASAWADI	12:38	12:55	0:17	LINE FAULT
1556	4-Oct-2021	BENGALURU	66	ITI 220 - BANASAWADI	BANASAWADI	13:50	14:03	0:13	LINE FAULT
1557	4-Oct-2021	BENGALURU	66	POTTERY ROAD - ITI 220	POTTERY ROAD	15:40	15:55	0:15	LOAD CHANGE OVER
1558	4-Oct-2021	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	17:01	17:05	0:04	LOAD CHANGE OVER
1559	4-Oct-2021	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K&C VALLEY	3:28	4:06	0:38	LINE FAULT
1560	4-Oct-2021	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K&C VALLEY	6:36	8:00	1:24	LINE CLEAR AVAIED
1561	4-Oct-2021	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K&C VALLEY	8:08	8:35	0:27	LINE FAULT
1562	4-Oct-2021	BENGALURU	220	MANYATHA TECH PARK 220 - HOODY 220	MANYATHA TECH PARK 220	13:32	14:03	0:31	LINE FAULT
1563	4-Oct-2021	BENGALURU	220	MANYATHA TECH PARK 220 - ITI 220	MANYATHA TECH PARK 220	13:32	13:55	0:23	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1564	4-Oct-2021	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 1	MANYATHA 66	13:32	14:05	0:33	LINE CLEAR AVAIED
1565	4-Oct-2021	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 2	SHOBHA CITY	13:32	14:05	0:33	LINE CLEAR AVAIED
1566	4-Oct-2021	BENGALURU	66	MANYATHA TECH PARK 220 - PEENYA 2	SAHAKARINAGAR	13:32	14:05	0:33	LINE CLEAR AVAIED
1567	4-Oct-2021	BENGALURU	66	HV1	MANYATHA TECH PARK 220	13:32	14:05	0:33	LINE CLEAR AVAIED
1568	4-Oct-2021	BENGALURU	66	HV2	MANYATHA TECH PARK 220	13:32	14:05	0:33	LINE CLEAR AVAIED
1569	4-Oct-2021	BENGALURU	66	HV3	MANYATHA TECH PARK 220	13:32	14:05	0:33	LINE CLEAR AVAIED
1570	4-Oct-2021	BENGALURU	66	HV4	MANYATHA TECH PARK 220	13:32	14:05	0:33	LINE CLEAR AVAIED
1571	4-Oct-2021	BENGALURU	66	HV1	RR NAGAR	0:10	0:40	0:30	TRANSFORMER FAULT
1572	4-Oct-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	14:53	15:02	0:09	LINE FAULT
1573	4-Oct-2021	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:48	16:58	0:10	LINE FAULT
1574	4-Oct-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	10:00	17:35	7:35	LINE FAULT
1575	4-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	10:00	17:35	7:35	LINE FAULT
1576	4-Oct-2021	BENGALURU	66	HV1	VIDHURASTRAVATA	9:15	9:20	0:04	TRANSFORMER FAULT
1577	4-Oct-2021	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	19:26	22:45	3:19	LINE FAULT
1578	4-Oct-2021	BENGALURU	66	HV1	TEMGONDALU	9:46	9:50	0:04	TRANSFORMER FAULT
1579	4-Oct-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	11:13	13:58	2:45	LINE CLEAR AVAIED
1580	4-Oct-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:05	17:34	7:29	LINE CLEAR AVAIED
1581	4-Oct-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA,KYALANUR	11:11	11:19	0:07	LINE FAULT
1582	4-Oct-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA,KYALANUR	11:19	15:05	3:46	LINE FAULT
1583	4-Oct-2021	BENGALURU	66	HV1	TEKAL	15:31	15:54	0:23	LINE CLEAR AVAIED
1584	4-Oct-2021	BENGALURU	66	HV1	KONDASPURA	0:29	0:45	0:16	TRANSFORMER FAULT
1585	4-Oct-2021	BENGALURU	220	HV1	GOWRIBIDANUR 220	18:23	19:17	0:53	LINE CLEAR AVAIED
1586	4-Oct-2021	BENGALURU	66	HV1	GOWRIBIDANUR 220	19:59	20:10	0:11	TRANSFORMER FAULT
1587	4-Oct-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	NO STATION AFFECTED	23:20	23:26	0:06	LINE FAULT
1588	4-Oct-2021	BENGALURU	66	JIGANI LINK ROAD - B G ROAD	JIGANI LINK ROAD	12:51	21:16	8:25	LOAD CHANGE OVER
1589	4-Oct-2021	BENGALURU	66	HV2	SIDDLAGHATTA	11:00:12	11:05	0:04	LINE CLEAR AVAIED
1590	4-Oct-2021	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	11:35:00	11:40	0:05	LOAD CHANGE OVER
1591	4-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1592	4-Oct-2021	GULBARGA	220	ITTAGI-BMMISPAT	ITTAGI_220	12:50	14:52	2:02	LINE CLEAR AVAIED
1593	4-Oct-2021	GULBARGA	220	ITTAGI-NEELAGUNDA	ITTAGI_220	14:14(04.10.2021)			LINE OPEN:LINE FAULT
1594	4-Oct-2021	GULBARGA	220	HV2	ITTAGI_220	14:56	17:12	2:16	LINE CLEAR AVAIED
1595	4-Oct-2021	GULBARGA	220	NEELGUNDA-HALAVAGALU	NEELGUNDA_220	13:30	13:40	0:10	LINE CLEAR AVAIED
1596	4-Oct-2021	GULBARGA	220	NEELGUNDA-ITTAGI	NEELGUNDA_220	14:15	14:27	0:12	LINE FAULT
1597	4-Oct-2021	GULBARGA	220	NEELGUNDA-GUTTUR	NEELGUNDA_220	14:27	16:19	1:52	LINE FAULT
1598	4-Oct-2021	GULBARGA	220	NEELGUNDA-GUTTUR	NEELGUNDA_220	16:30	20:46	4:16	LINE CLEAR AVAIED
1599	4-Oct-2021	GULBARGA	220	HV1	ITTAGI_220	10:00	14:10	4:10	HAND TRIPPED
1600	4-Oct-2021	GULBARGA	220	HV2	ITTAGI_220	10:00	11:20	1:20	HAND TRIPPED
1601	4-Oct-2021	GULBARGA	220	LINGAPUR-DURVADESH	LINGAPUR_220	11:20	11:28	0:08	MAIN SUPPLY FAILURE
1602	4-Oct-2021	GULBARGA	220	LINGAPUR-DURVADESH	GDHALLI_220	11:22	16:24	5:02	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1603	4-Oct-2021	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	23:07(04.10.2021)			MAIN SUPPLY FAILURE
1604	4-Oct-2021	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	11:15	11:42	0:27	MAIN SUPPLY FAILURE
1605	4-Oct-2021	GULBARGA	220	RTPS-SHAHAPUR1	SHAHAPUR_220	3:16	6:18	3:02	MAIN SUPPLY FAILURE
1606	4-Oct-2021	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	23:07	23:22	0:15	MAIN SUPPLY FAILURE
1607	4-Oct-2021	GULBARGA	220	HV2	HALBARGA_220	18:29	18:44	0:15	MAIN SUPPLY FAILURE
1608	4-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:23(04.10.2021)			LINE OPEN:LINE FAULT
1609	4-Oct-2021	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	16:30	17:30	1:00	LINE FAULT
1610	4-Oct-2021	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	16:35(28.09.2021)	18:55(04.10.2021)	146:20HRS	LINE CHARGED
1611	4-Oct-2021	GULBARGA	110	HATTI-SOMANAMARADI_IPP	HATTI_110	2:46	2:52	0:06	MAIN SUPPLY FAILURE
1612	4-Oct-2021	GULBARGA	110	HATTI-SOMANAMARADI_IPP	HATTI_110	5:29	5:49	0:20	MAIN SUPPLY FAILURE
1613	4-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1614	4-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN:LINE CLEAR AVAILED
1615	4-Oct-2021	GULBARGA	110	HV2	HATTI_110	5:04	5:07	0:03	MAIN SUPPLY FAILURE
1616	4-Oct-2021	GULBARGA	110	HV2	HATTI_110	7:00	7:33	0:33	MAIN SUPPLY FAILURE
1617	4-Oct-2021	GULBARGA	110	GALAG_ALKOD	GALAG_110	1:15	1:25	0:10	MAIN SUPPLY FAILURE
1618	4-Oct-2021	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPURA_110	1:12	1:20	0:08	MAIN SUPPLY FAILURE
1619	4-Oct-2021	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPURA_110	2:45	2:50	0:05	MAIN SUPPLY FAILURE
1620	4-Oct-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	11:35	11:40	0:05	LINE FAULT
1621	4-Oct-2021	GULBARGA	110	JANAWADA-SANTAPUR	JANAWADA_110	1:45	3:10	1:25	LINE FAULT
1622	4-Oct-2021	GULBARGA	110	JANAWADA-SANTAPUR	JANAWADA_110	3:19	3:24	0:05	LINE FAULT
1623	4-Oct-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADVAMRESHWAR_110	0:55	1:00	0:05	MAIN SUPPLY FAILURE
1624	4-Oct-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADVAMRESHWAR_110	5:10	5:18	0:08	MAIN SUPPLY FAILURE
1625	4-Oct-2021	GULBARGA	110	MALLAT-BYGWAT-2	MADLAPUR_110,MANVI_110,ADVI AMARESHWAR	0:29	0:39	0:10	LINE FAULT
1626	4-Oct-2021	GULBARGA	110	MALLAT-BYGWAT-1	BYGWAT_110,VALKAMDINI_110	19:21	19:31	0:10	LINE FAULT
1627	4-Oct-2021	GULBARGA	110	MALLAT-BYGWAT-1	BYGWAT_110,VALKAMDINI_110	20:14	20:24	0:10	LINE FAULT
1628	4-Oct-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	23:30(4.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1629	4-Oct-2021	GULBARGA	110	MUNIRABAD-SINDANOOR1	BPCL_IPP,VENKATAPUR_110,GANGAVA TI_110	22:40	22:52	0:12	LINE FAULT
1630	4-Oct-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	22:41	22:52	0:11	LINE FAULT
1631	4-Oct-2021	GULBARGA	110	HV1	GANDHINAGAR_110	1:05	3:57	2:52	LINE CLEAR AVAILED
1632	4-Oct-2021	GULBARGA	110	HV1	GANDHINAGAR_110	17:45	17:55	0:10	LINE CLEAR AVAILED
1633	4-Oct-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADVAMRESHWAR_110	0:55	1:00	0:05	MAIN SUPPLY FAILURE
1634	4-Oct-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADVAMRESHWAR_110	5:10	5:18	0:08	MAIN SUPPLY FAILURE
1635	4-Oct-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADVAMRESHWAR_110	18:42	18:50	0:08	MAIN SUPPLY FAILURE
1636	4-Oct-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADVAMRESHWAR_110	22:43	22:54	0:11	MAIN SUPPLY FAILURE
1637	4-Oct-2021	GULBARGA	110	HUMNABAD-HUMNABAD1	MANEKAHALLI_110	18:29	20:39	2:10	MAIN SUPPLY FAILURE
1638	4-Oct-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	0:53	1:08	0:15	LINE FAULT
1639	4-Oct-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	20:52	21:12	0:20	LINE FAULT
1640	4-Oct-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	23:07	23:18	0:11	LINE FAULT
1641	4-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAID HAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP	0:03	0:21	0:18	LINE FAULT
1642	4-Oct-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:13	23:24	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1643	4-Oct-2021	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110	4:27	4:31	0:04	LINE FAULT
1644	4-Oct-2021	GULBARGA	110	SEADM-VICAT SAGAR_IPP	SEDAM_220	22:10	22:25	0:15	LINE FAULT
1645	4-Oct-2021	GULBARGA	110	SEADM-VICAT SAGAR_IPP	SEDAM_220	23:15	23:25	0:10	LINE FAULT
1646	4-Oct-2021	GULBARGA	110	TEKKALKOTE-RENEWSOLAR_IPP	TEKKALKOTE_110	20:53(04.10.2021)			LINE OPEN:LINE FAULT
1647	4-Oct-2021	GULBARGA	110	TEKKALKOTE-SHAHISOLAR_IPP	TEKKALKOTE_110	21:30	22:32	1:02	LINE FAULT
1648	4-Oct-2021	GULBARGA	110	HV1	MADIYAL_110	20:50	20:55	0:05	TRANSFORMER FAULT
1649	4-Oct-2021	GULBARGA	110	HV1	MADIYAL_110	21:28	21:33	0:05	TRANSFORMER FAULT
1650	4-Oct-2021	GULBARGA	110	HV1	MADIYAL_110	23:24	23:34	0:10	TRANSFORMER FAULT
1651	4-Oct-2021	GULBARGA	110	SINDANOOR-MUNIRABAD2	MUKUNDA_1210,YERADONA_110,BEN NUR_110	8:14	8:24	0:10	LINE FAULT
1652	4-Oct-2021	GULBARGA	110	SINDANOOR-MUNIRABAD1	KARATAGI_110,SRNAGAR_110,GANGAVATI_110	21:45	21:55	0:10	LINE FAULT
1653	4-Oct-2021	GULBARGA	66	HV3	TELAGI_66	8:30(30.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1654	4-Oct-2021	GULBARGA	66	ITTAGI-KUDLIGI 1	ITTAGI_220	11:05	11:22	0:17	LINE FAULT
1655	4-Oct-2021	GULBARGA	66	ITTAGI-HIREHADGALI 2	HIREHADGALI_66,GIRIYAPUR_66,MAGLA_66,SOVENAHALLI_66,TB_IPP	12:35	12:45	0:10	LINE FAULT
1656	4-Oct-2021	GULBARGA	66	ITTAGI-RENEW1_IPP	ITTAGI_220	18:15	18:30	0:15	LINE FAULT
1657	4-Oct-2021	GULBARGA	66	ITTAGI-RENEW2_IPP	ITTAGI_220	18:15	19:10	0:55	LINE FAULT
1658	4-Oct-2021	GULBARGA	66	ITTAGI-KOGALI	KOGALI_66,KUDLIGI_66,HANASI_66	8:15	8:25	0:10	MAIN SUPPLY FAILURE
1659	4-Oct-2021	GULBARGA	66	ITTAGI-KOGALI	KOGALI_66,KUDLIGI_66,HANASI_66	10:00	10:30	0:30	MAIN SUPPLY FAILURE
1660	4-Oct-2021	GULBARGA	66	ITTAGI-KOGALI	KOGALI_66,KUDLIGI_66,HANASI_66	11:15	18:10	6:55	LINE CLEAR AVAILED
1661	4-Oct-2021	GULBARGA	66	KOGALI-KUDLIGI	KUDLIGI_66	11:05	11:20	0:15	LINE FAULT
1662	4-Oct-2021	GULBARGA	66	KOGALI-KUDLIGI	KUDLIGI_66	12:20	12:30	0:10	LINE FAULT
1663	4-Oct-2021	GULBARGA	66	KOGALI-KUDLIGI	KUDLIGI_66	13:00	13:10	0:10	LINE FAULT
1664	4-Oct-2021	GULBARGA	66	KOGALI-KUDLIGI	KUDLIGI_66	14:10	14:20	0:10	LINE FAULT
1665	4-Oct-2021	GULBARGA	66	KOGALI-ATRSOLAR_IPP	KOGALI_66	10:00	11:35	1:35	LINE CLEAR AVAILED
1666	4-Oct-2021	GULBARGA	66	HV1	HALAVAGALU_66	10:30	21:05	10:35	LINE CLEAR AVAILED
1667	4-Oct-2021	GULBARGA	66	HV2	HALAVAGALU_66	11:10	21:05	9:55	LINE CLEAR AVAILED
1668	4-Oct-2021	GULBARGA	66	UCHANAGIDURGA-NEELAGUNDA	UCHANAGIDURGA_66	14:25	21:45	7:20	MAIN SUPPLY FAILURE
1669	4-Oct-2021	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66	14:30	19:00	4:30	MAIN SUPPLY FAILURE
1670	4-Oct-2021	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI_66	14:30	21:20	6:50	MAIN SUPPLY FAILURE
1671	4-Oct-2021	GULBARGA	66	PUNAB GHATA-NEELAGUNDA	PUNAB GHATA_66	14:30	19:10	4:40	MAIN SUPPLY FAILURE
1672	4-Oct-2021	GULBARGA	66	PUNAB GHATA-NEELAGUNDA	PUNAB GHATA_66	20:55	21:05	0:10	MAIN SUPPLY FAILURE
1673	4-Oct-2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWANAGAR_66	19:35 (1.10.2021)	14:12 (4.10.2021)	42:36 hrs	LINE CHARGED
1674	4-Oct-2021	HASSAN	220	SHRVATY-SIRISI 1	sharavathy_gen	16:37 (3.10.2021)	17:46 (4.10.2021)	25:8 hrs	LINE CHARGED
1675	4-Oct-2021	HASSAN	220	SHRVATY-ST1	sharavathy_gen	16:59(03.10.2021)	14:26 (4.10.2021)	21:26hrs	LINE CHARGED
1676	4-Oct-2021	HASSAN	220	SHRVATY-TALAGUPPA 2	sharavathy_gen	19:33 (2.10.2021)	12:38 (4.10.2021)	41:64	LINE CHARGED
1677	4-Oct-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	16:59(03.10.2021)	14:26 (4.10.2021)	21:26hrs	LINE CHARGED
1678	4-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1679	4-Oct-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN:LINE FAULT
1680	4-Oct-2021	HASSAN	220	SHRVATY-TALAGUPPA 2	sharavathy_gen	13:05 (4.10.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1681	4-Oct-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	13:05 (4.10.2021)			LINE OPEN:LINE FAULT
1682	4-Oct-2021	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	9:01(4.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1683	4-Oct-2021	HASSAN	110	LV3	MRSMSG_220	9:40(4.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1684	4-Oct-2021	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	9:01(4.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1685	4-Oct-2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:20 (4.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1686	4-Oct-2021	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	9:26(4.10.2021)			LINE OPEN:LINE CLEAR AVAILED
1687	4-Oct-2021	HASSAN	66	LV1	MRSMSG_220	9:39(4.10.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1688	4-Oct-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_220	13:21	14:17	0:56	HAND TRIPPED
1689	4-Oct-2021	HASSAN	110	HV4	BEJAI_110	13:15	13:28	0:13	TRANSFORMER FAULT
1690	4-Oct-2021	HASSAN	110	HV3	BEJAI_110	13:15	13:26	0:11	TRANSFORMER FAULT
1691	4-Oct-2021	HASSAN	110	JOG-JLT4	mghejog_gen	9:18	18:36	9:18	NFBC ISSUED
1692	4-Oct-2021	HASSAN	110	JOG-JST1	mghejog_gen	17:39	18:19	0:40	LINE FAULT
1693	4-Oct-2021	HASSAN	110	KAEKLA-HIRIYADKA	KARKLA_110	10:54	12:41	1:47	NFBC ISSUED
1694	4-Oct-2021	HASSAN	220	HV1	KAVOOR_220	9:47	15:24	5:37	LINE CLEAR AVAILED
1695	4-Oct-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:31	12:28	1:57	LINE CLEAR AVAILED
1696	4-Oct-2021	HASSAN	220	KEMAR-VARAH	KEMAR_220	11:02	13:48	2:46	LINE CLEAR AVAILED
1697	4-Oct-2021	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	10:35	14:02	3:27	LINE CLEAR AVAILED
1698	4-Oct-2021	HASSAN	220	HV3	MRSMSG_220	9:41	21:07	11:26	LINE CLEAR AVAILED
1699	4-Oct-2021	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	9:01	11:34	2:33	HAND TRIPPED
1700	4-Oct-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	10:32	12:37	2:05	NFBC ISSUED
1701	4-Oct-2021	HASSAN	110	HV1	SAGARA_110	12:30	13:30	1:00	LINE CLEAR AVAILED
1702	4-Oct-2021	HASSAN	110	SAGARA-JSTI	SAGARA_110	17:40	18:15	0:35	LINE FAULT
1703	4-Oct-2021	HASSAN	110	HV4	SHIRALKOPPA_2110	10:19	17:42	7:23	LINE CLEAR AVAILED
1704	4-Oct-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:20	15:19	4:59	NFBC ISSUED
1705	4-Oct-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:18	15:20	4:02	LINE FAULT
1706	4-Oct-2021	HASSAN	110	HV2	SORABA_110	8:15	11:20	3:05	LINE CLEAR AVAILED
1707	4-Oct-2021	HASSAN	110	HV2	SORABA_110	16:55	18:30	1:35	LINE CLEAR AVAILED
1708	4-Oct-2021	HASSAN	110	HV2	SORABA_110	18:30	18:35	0:05	HAND TRIPPED
1709	4-Oct-2021	HASSAN	66	BALEHN-MUGULVALLY	BALEHONNUR_66	21:16	21:25	0:09	LINE FAULT
1710	4-Oct-2021	HASSAN	66	HV1	BELUR_66	12:41	17:21	4:40	LINE CLEAR AVAILED
1711	4-Oct-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:03	9:25	0:22	HAND TRIPPED
1712	4-Oct-2021	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	9:01	11:34	2:33	HAND TRIPPED
1713	4-Oct-2021	HASSAN	66	HV1	BYACHANAHALLI_66	12:25	13:40	1:15	LINE CLEAR AVAILED
1714	4-Oct-2021	HASSAN	66	HV2	BYACHANAHALLI_66	11:15	12:35	1:20	LINE CLEAR AVAILED
1715	4-Oct-2021	HASSAN	66	HV2	HALLYMYSORE_66	15:45	16:40	0:55	LINE CLEAR AVAILED
1716	4-Oct-2021	HASSAN	66	HV1	MATNAVILE_66	11:29	12:45	1:16	LINE CLEAR AVAILED
1717	4-Oct-2021	HASSAN	66	HV1	SALAGAME_66	16:25	17:00	0:35	LINE CLEAR AVAILED
1718	4-Oct-2021	HASSAN	66	HV1	SIGEBAGE_66	9:20	11:40	2:20	MAIN SUPPLY FAILURE
1719	4-Oct-2021	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	9:20	11:40	2:20	MAIN SUPPLY FAILURE
1720	4-Oct-2021	MYSURU	66	HV2	AKKIHEBBAL_66	11:05	12:33	22:44	LINE CLEAR AVAILED
1721	4-Oct-2021	MYSURU	66	BESAGRALLI-DUNDANAHALLI	NO STATIONS EFFECTED	18:24	18:29	0:05	LINE FAULT
1722	4-Oct-2021	MYSURU	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	16:42	16:53	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1723	4-Oct-2021	MYSURU	66	HV1	DATTAGALLY_66	14:58	18:31	3:32	LINE CLEAR AVAIED
1724	4-Oct-2021	MYSURU	66	HV2	DATTAGALLY_66	14:26	18:49	4:22	LINE CLEAR AVAIED
1725	4-Oct-2021	MYSURU	66	VAJMANGALA-DEVNUR(MYS)	RAJEEVNAGARA_66 DEVANOORMYS_66 FTS_66	17:32	21:25	3:53	LINE FAULT
1726	4-Oct-2021	MYSURU	66	G UKKADA-SR PATNA	NO STATIONS EFFECTED	5:49	18:46	12:56	LINE CLEAR AVAIED
1727	4-Oct-2021	MYSURU	66	VAJMANGALA-JYOTHINAGARA	DKMAIDANA_66 JYOTHINAGARA_66	17:32	21:31	3:59	LINE FAULT
1728	4-Oct-2021	MYSURU	220	KADAKOLA-BASTIPURA1	NO STATIONS EFFECTED	11:02	13:43	2:41	LINE CLEAR AVAIED
1729	4-Oct-2021	MYSURU	220	KADAKOLA-BASTIPURA2	NO STATIONS EFFECTED	13:59	16:44	2:44	LINE CLEAR AVAIED
1730	4-Oct-2021	MYSURU	66	HV2	KIKKERI_66	11:33	11:38	0:04	TRANSFORMER FAULT
1731	4-Oct-2021	MYSURU	66	HV2	KIKKERI_66	13:21	18:08	4:47	LINE CLEAR AVAIED
1732	4-Oct-2021	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	6:30	6:36	0:06	LINE FAULT
1733	4-Oct-2021	MYSURU	66	KM DODDI-TK HALLI	NO STATIONS EFFECTED	16:48	17:03	0:14	LINE FAULT
1734	4-Oct-2021	MYSURU	66	HV1	KUSHALANAGARA_66	6:15	21:35	15:20	LINE CLEAR AVAIED
1735	4-Oct-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	5:45	5:53	0:07	LINE FAULT
1736	4-Oct-2021	MYSURU	66	HV1	NAGAMANGALA_66	10:31	12:36	2:04	LINE CLEAR AVAIED
1737	4-Oct-2021	MYSURU	66	HV2	NAGAMANGALA_66	12:32	14:30	1:57	LINE CLEAR AVAIED
1738	4-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	18:03	22:08	4:05	LOAD CHANGE OVER
1739	4-Oct-2021	MYSURU	66	HV1	RKNAGARA_66	9:54	12:16	2:22	LINE CLEAR AVAIED
1740	4-Oct-2021	MYSURU	66	HV2	RKNAGARA_66	12:16	12:34	0:17	LINE CLEAR AVAIED
1741	4-Oct-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	15:50	16:05	0:14	LINE CLEAR AVAIED
1742	4-Oct-2021	MYSURU	66	HV2	SRIRANGAPATNA_66	15:50	16:05	0:14	LINE CLEAR AVAIED
1743	4-Oct-2021	MYSURU	66	TALAKADU-PARINAMIPURA	CHANDALLI_66 THALAKADU_66	6:58	7:17	0:19	LINE FAULT
1744	4-Oct-2021	MYSURU	66	VAJMANGALAMEGALAPURA	NO STATIONS EFFECTED	16:01	16:07	0:06	LINE FAULT
1745	4-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18 (23.09.2021)			LINE OPEN:LINE CLEAR AVAIED
1746	4-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN:LINE CLEAR AVAIED
1747	4-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN:LINE CLEAR AVAIED
1748	4-Oct-2021	MYSURU	66	FTS-HOOTGALLY 1	NO STATIONS EFFECTED	6:31:29 (29/09/2021)	17:50:13' (4/10/2021)	131:18hrs	LINE CHARGED
1749	4-Oct-2021	MYSURU	66	FTS-HOOTGALLY 2	NO STATIONS EFFECTED	6:31:24 (29/09/2021)	17:50:13' (4/10/2021)	131:18hrs	LINE CHARGED
1750	4-Oct-2021	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	14:27	16:02	1:35	LINE FAULT
1751	4-Oct-2021	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	16:34	20:45	4:11	LINE CLEAR AVAIED
1752	4-Oct-2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	12:26	13:43	1:16	LINE FAULT
1753	4-Oct-2021	TUMKUR	220	TR-2	DAVANGERE_SRS_220	15:05	15:17	0:12	TRANSFORMER FAULT
1754	4-Oct-2021	TUMKUR	110	TR-1	TURUVEKERE_110	13:14	14:10	0:55	TRANSFORMER FAULT
1755	4-Oct-2021	TUMKUR	110	TR-2	BANDIHALLI_110	12:25	13:19	0:54	LINE CLEAR AVAIED
1756	4-Oct-2021	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	1:36	2:25	0:49	LINE FAULT
1757	4-Oct-2021	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110	1:36	2:19	0:43	LINE FAULT
1758	4-Oct-2021	TUMKUR	110	TR-1	KALLUR_110	14:49	16:32	1:43	LINE CLEAR AVAIED
1759	4-Oct-2021	TUMKUR	110	TR-2	NITTUR_220	1:11	11:24	10:13	TRANSFORMER FAULT
1760	4-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR_66	YEDIYUR_66,THIPPUR_66,JIDDEGERE_66	10:58	13:58	3:00	LINE CLEAR AVAIED
1761	4-Oct-2021	TUMKUR	66	TR-1	BHARAMAGIRI_66	0:00	0:12	0:12	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1762	4-Oct-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66,MELEKAT TE_66	15:15	15:24	0:08	HAND TRIPPED
1763	4-Oct-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	17:10	22:36	5:26	HAND TRIPPED
1764	4-Oct-2021	TUMKUR	66	TR-1	DAVANGERE_SRS_220	15:16	15:18	0:02	TRANSFORMER FAULT
1765	4-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	4:07	4:20	0:12	LINE FAULT
1766	4-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:00	6:10	0:10	LINE FAULT
1767	4-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:59	11:37	1:38	LINE CLEAR AVAILED
1768	4-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:27	15:42	1:14	LINE FAULT
1769	4-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:51	18:15	2:23	HAND TRIPPED
1770	4-Oct-2021	TUMKUR	66	TR-1	GULIGENAHALLI_66	13:03	17:30	4:27	LINE CLEAR AVAILED
1771	4-Oct-2021	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66,GUDEKOTE_66	6:38	6:40	0:02	HAND TRIPPED
1772	4-Oct-2021	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	6:26	6:38	0:12	HAND TRIPPED
1773	4-Oct-2021	TUMKUR	66	TR-1	HANAGAL_66	19:09	19:17	0:08	LINE CLEAR AVAILED
1774	4-Oct-2021	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMUDRA_66	6:38	6:40	0:02	HAND TRIPPED
1775	4-Oct-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:18	18:24	0:05	HAND TRIPPED
1776	4-Oct-2021	TUMKUR	66	TR-1	HONNALLI_66	15:02	15:55	0:52	LINE CLEAR AVAILED
1777	4-Oct-2021	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI66	MADHUGIRI_66, BADAVANAHALLI_66	12:10	13:02	0:51	HAND TRIPPED
1778	4-Oct-2021	TUMKUR	66	MADHUGIRI 220kv- MEDIGESHI 2	NAGALMADIKE_66,SHYLAPURA_6,MAN GALWADA_66,YNHOSKOTE_66	12:10	13:00	0:50	HAND TRIPPED
1779	4-Oct-2021	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	12:28	12:59	0:31	HAND TRIPPED
1780	4-Oct-2021	TUMKUR	66	TR-2	RAMAPURA_66	10:43	16:36	5:52	LINE CLEAR AVAILED
1781	4-Oct-2021	TUMKUR	66	TR-2	RAMAPURA_66	21:16	21:28	0:11	TRANSFORMER FAULT
1782	4-Oct-2021	TUMKUR	66	YEDIYUR- BG NAGARA66	BGNAGARA_66	11:24	14:05	2:40	HAND TRIPPED
1783	4-Oct-2021	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	6:26	6:35	0:09	LINE FAULT











































































































