

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM : 05.04.2022 TO 11.4.2022**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	5-Apr-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN, LINE CLEAR AVOIDED
2	5-Apr-2022	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56(26.11.2021)			LINE OPEN, LINE CLEAR AVOIDED
3	5-Apr-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13(03.03.2022)			LINE OPEN, LINE CLEAR AVOIDED
4	5-Apr-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVOIDED
5	5-Apr-2022	BAGALKOT	110	GOPANKOPPA-MRUTYUNJAYNAGAR	STATION NOT AFFECTED GOPANKOPPA_110	12:46(26.03.2022)			LINE OPEN, LINE CLEAR AVOIDED
6	5-Apr-2022	BAGALKOT	110	110/11KV,HV4	BELGAUM_110	5:00 (31.03.2022)			TRANSFORMER OPEN ,TRANSFORMER FAULT
7	5-Apr-2022	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59(31.03.2022)			LINE OPEN, LINE CLEAR AVOIDED
8	5-Apr-2022	BAGALKOT	110	ILKAL1&2-HUNGUND	HUNGUND_110	22:36 (02.04.2022)	12 (05.04.2022)	67:36HRS	LINE CHARGED
9	5-Apr-2022	BAGALKOT	110	110/11KV HV2	ALAMEL_110	6:49	6:52	0:03	HAND TRIPPED
10	5-Apr-2022	BAGALKOT	110	110/11KV HV2	BABALESHWAR_110	6:38	8:50	2:12	TRANSFORMER FAULT
11	5-Apr-2022	BAGALKOT	110	110/11KV HV2	BABALESHWAR_110	9:04	9:27	0:23	TRANSFORMER FAULT
12	5-Apr-2022	BAGALKOT	110	110/11KV HV2	BABALESHWAR_110	9:49	9:55	0:06	TRANSFORMER FAULT
13	5-Apr-2022	BAGALKOT	110	110/11KV HV2	BABALESHWAR_110	14:21	14:31	0:10	TRANSFORMER FAULT
14	5-Apr-2022	BAGALKOT	110	110/11KV HV2	BABALESHWAR_110	18:12	18:24	0:12	TRANSFORMER FAULT
15	5-Apr-2022	BAGALKOT	110	110/11KV HV2	BEDI_110	11:14	12:17	1:03	LINE CLEAR AVOIDED
16	5-Apr-2022	BAGALKOT	220	BIDNAL-SOUNDATTI	BIDNAL_220	16:38	19:49	3:11	LINE FAULT
17	5-Apr-2022	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	17:11	19:24	2:13	LINE FAULT
18	5-Apr-2022	BAGALKOT	110	HIDIKALDAM-ANKALAGI	HIDIKDAM_110	3:45	4:40	0:55	LINE FAULT
19	5-Apr-2022	BAGALKOT	110	ILKAL-AVAADA SOLAR	AVADA SOLAR_110 ILKAL_110	10:49	13:30	2:41	LINE FAULT
20	5-Apr-2022	BAGALKOT	110	KUSTAGI220-ILKAL	ILKAL_110	10:49	12:13	1:24	LINE FAULT
21	5-Apr-2022	BAGALKOT	110	KUSTAGI220-ILKAL	ILKAL_110	12:58	13:29	0:31	LINE FAULT
22	5-Apr-2022	BAGALKOT	110	ISLAMPUR_HIDICAL DAM	ISLAMPUR_110	4:44	4:50	0:06	LINE FAULT
23	5-Apr-2022	BAGALKOT	110	KUDACHI_UGARKHUD	KUDACHI_110	10:21	10:51	0:30	LINE FAULT
24	5-Apr-2022	BAGALKOT	110	KULAGIRI CROSS - MRN SUGERS	KULAGIRI CROSS	16:05	16:13	0:08	LINE FAULT
25	5-Apr-2022	BAGALKOT	110	110/11KV,HV2	MALAGHAN(B)_110	6:37	7:16	0:39	HAND TRIPPED
26	5-Apr-2022	BAGALKOT	110	110/11KV,HV2	MALAGHAN(B)_110	3:02	3:13	0:11	TRANSFORMER FAULT
27	5-Apr-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MAMADAPUR(B)_110	14:51	18:11	3:20	LINE CLEAR AVOIDED
28	5-Apr-2022	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED MAMADAPUR(B)_110	8:12	9:09	0:57	HAND TRIPPED
29	5-Apr-2022	BAGALKOT	110	MAMADAPUR(B)-BELGAUM SOLAR	BELGAUM SOLAR_110 STATION NOT AFFECTED MAMADAPUR(B)_110	8:11	8:13	0:02	HAND TRIPPED
30	5-Apr-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MAMADAPUR(B)_110	8:11	13:21	5:10	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
31	5-Apr-2022	BAGALKOT	110	MAMADAPUR(B)-BELGAUM SOLAR	BELGAUM SOLAR_110 STATION NOT AFFECTED MAMADAPUR(B)_110	2:10	2:29	0:19	LINE FAULT
32	5-Apr-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MKHUBLI_110	17:58	18:31	0:33	TRANSFORMER FAULT
33	5-Apr-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUNAVALLI_110	10:31	11:07	0:36	TRANSFORMER FAULT
34	5-Apr-2022	BAGALKOT	110	SAVALAGI-AIGALI	STATION NOT AFFECTED SAVALAGI_110	8:29	18:42	10:13	LINE CLEAR AVAILED
35	5-Apr-2022	BAGALKOT	110	TARIHAL-KIADB GAMANAGATTI	STATION NOT AFFECTED TARIHAL_110	10:27	11:37	1:10	LINE FAULT
36	5-Apr-2022	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	19:13	22:30	3:17	LINE FAULT
37	5-Apr-2022	BAGALKOT	110	HAVERI-BYADAGI	STATION NOT AFFECTED HAVERI_220	19:13	20:34	1:21	LINE FAULT
38	5-Apr-2022	BAGALKOT	110	HAVERI-HANAGAL(TILUVALI)	TILUVALI_110	19:13	20:40	1:27	LINE FAULT
39	5-Apr-2022	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	MAHALINGAPUR_220	17:20	18:25	1:05	LINE FAULT
40	5-Apr-2022	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	17:19	21:00	3:41	LINE FAULT
41	5-Apr-2022	BAGALKOT	220	SOUDATTI- BIDNAL	SOUDATTI_220	16:41	19:50	3:09	LINE FAULT
42	5-Apr-2022	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	17:16	18:26	1:10	LINE FAULT
43	5-Apr-2022	BAGALKOT	110	SOUDATTI220- SOUDATTI1&2	SOUDATTI_110	17:16	18:26	1:10	MAIN SUPPLY FAILURE
44	5-Apr-2022	BAGALKOT	110	SOUDATTI220- MMCL	SOUDATTI_220	17:16	18:26	1:10	MAIN SUPPLY FAILURE
45	5-Apr-2022	BAGALKOT	110	KARWAR- ARGA(KUMATA)	KARWAR_220	20:05	20:11	0:06	LINE FAULT
46	5-Apr-2022	BAGALKOT	220	CHIKKODI- MUGHALKOD2	CHIKKODI_220	18:40	20:16	1:36	LINE FAULT
47	5-Apr-2022	BAGALKOT	220	CHIKKODI- BELAGAVI2	CHIKKODI_220	19:01	19:17	0:16	HAND TRIPPED
48	5-Apr-2022	BAGALKOT	220	CHIKKODI- BELAGAVI2	CHIKKODI_220	19:18 (05.04.2022)			LINE OPEN,LINE FAULT
49	5-Apr-2022	BAGALKOT	110	CHIKKODI220- SADALAGA	CHIKKODI_220	18:45	20:08	1:23	LINE FAULT
50	5-Apr-2022	BAGALKOT	110	BAGALKOT220- BAGALKOT2	BAGALKOT_220	14:35	14:46	0:11	LINE FAULT
51	5-Apr-2022	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	18:38	19:17	0:39	LINE FAULT
52	5-Apr-2022	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	19:18 (05.04.2022)			LINE OPEN,LINE FAULT
53	5-Apr-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	17:30 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
54	5-Apr-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	9:40 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
55	5-Apr-2022	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	23:40(05.04.2022)			LINE OPEN,LINE FAULT
56	5-Apr-2022	BAGALKOT	110	MAHALINGAPUR- DAVALESHWAR	DAVALESHWAR_110	23:55(05.04.2022)			LINE OPEN,LINE FAULT
57	5-Apr-2022	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABKAVI_110	23:41(05.04.2022)			LINE OPEN,LINE FAULT
58	5-Apr-2022	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MAHALINGAPUR_220	23:58(05.04.2022)			TRANSFORMER OPEN ,TRANSFORMER FAULT
59	5-Apr-2022	BAGALKOT	110	SOUDATTI220- MUNAVALLI	MUNAVALLI_110	17:16	18:38	1:22	MAIN SUPPLY FAILURE
60	5-Apr-2022	BAGALKOT	110	SOUDATTI220- YARAGATTI	YARAGATTI_110	17:16	18:40	1:24	MAIN SUPPLY FAILURE
61	5-Apr-2022	BAGALKOT	110	SOUDATTI220- KATAKOL	KATAKOL_110	17:16	18:40	1:24	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
62	5-Apr-2022	BAGALKOT	110	SOUDATTI220- ARATAGAL	ARATAGAL_110	17:16	18:40	1:24	MAIN SUPPLY FAILURE
63	5-Apr-2022	BAGALKOT	110	SOUDATTI220- RAMDURGA1&2	RAMDURGA_110	17:16	18:26	1:10	MAIN SUPPLY FAILURE
64	5-Apr-2022	BAGALKOT	110	SOUDATTI220- BENAKATTI	BENAKATTI_110	17:16	18:26	1:10	MAIN SUPPLY FAILURE
65	5-Apr-2022	BAGALKOT	110	SOUDATTI220- UDAKERI	UDAKERI_110	17:16	18:26	1:10	MAIN SUPPLY FAILURE
66	5-Apr-2022	BAGALKOT	110	ATHANI220-SATTI	ATHANI_220	23:37 (05.04.2022)			LINE OPEN,LINE FAULT
67	5-Apr-2022	BAGALKOT	110	ATHANI220-HALYAL110	ATHANI_220	23:10 (05.04.2022)			LINE OPEN,LINE FAULT
68	5-Apr-2022	BAGALKOT	110	BAGALKOT220- RAMDURGA	BAGALKOT_220	16:05	16:15	0:10	LINE FAULT
69	5-Apr-2022	BAGALKOT	110	110/33KV, HV3	LAKAMANAHALLI_110, ALNAVAR_33	18:32	19:10	0:38	TRANSFORMER FAULT
70	5-Apr-2022	BAGALKOT	110	110/33KV, HV3	LAKAMANAHALLI_110, ALNAVAR_33	19:12	19:20	0:08	TRANSFORMER FAULT
71	5-Apr-2022	BAGALKOT	110	110/33KV, HV3	LAKAMANAHALLI_110, ALNAVAR_33	19:20	20:19	0:59	TRANSFORMER FAULT
72	5-Apr-2022	BENGALURU	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	SHANTHINIKETHAN	20:14	20:50	0:36	LINE FAULT
73	5-Apr-2022	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 4 220	NO STATION AFFECTED	19:55	20:35	0:40	LINE FAULT
74	5-Apr-2022	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	20:14	22:47	2:33	LINE CLEAR AVOIDED
75	5-Apr-2022	BENGALURU	66	HV2	YEDUMADU	12:41	13:00	0:19	LINE CLEAR AVOIDED
76	5-Apr-2022	BENGALURU	66	HV1	N G HULKUR	9:34	9:40	0:05	LINE CLEAR AVOIDED
77	5-Apr-2022	BENGALURU	66	HV1	KONDASPURA	9:43	11:39	1:55	LINE CLEAR AVOIDED
78	5-Apr-2022	BENGALURU	66	HV1	GODURU	12:05	15:51	3:46	LINE CLEAR AVOIDED
79	5-Apr-2022	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	10:50	18:38	7:48	LOAD CURTAILMENT
80	5-Apr-2022	BENGALURU	66	HV2	BANGARPETE	20:15	20:40	0:25	TRANSFORMER FAULT
81	5-Apr-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL(EHT), HOSKOTE 66	23:52:04(5-4-2022)			LINE OPEN,LINE FAULT
82	5-Apr-2022	BENGALURU	66	HV2	PRESTIGE SHANTINIKETHAN	20:14(5/4/2022)			TRANSFORMER OPEN ,TRANSFORMER FAULT
83	5-Apr-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN ,TRANSFORMER FAULT
84	5-Apr-2022	GULBARGA	220	HALBARGA-HUMNABAD 1	HALBARGA_220	11:01	11:08	0:07	LINE FAULT
85	5-Apr-2022	GULBARGA	220	RAICHUR-JURAL1_IPP	RAICHUR_220	6:00	6:12	0:12	LINE FAULT
86	5-Apr-2022	GULBARGA	110	HV2	SHAHABAD_220	20:28(4.4.2022)			TRANSFORMER OPEN ,TRANSFORMER FAULT
87	5-Apr-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	9:24 (27.03.2022)			LINE OPEN, LINE CLEAR AVOIDED
88	5-Apr-2022	GULBARGA	110	HV3	HATTI_100	4:23(05.03.2022)			TRANSFORMER OPEN ,TRANSFORMER FAULT
89	5-Apr-2022	GULBARGA	110	HV1	KADAGANCHI_110	12:40	13:45	1:05	LINE CLEAR AVOIDED
90	5-Apr-2022	GULBARGA	110	HV3	VALKAMDINNI_110	8:22	8:31	0:09	TRANSFORMER FAULT
91	5-Apr-2022	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR_110	19:15	20:10	0:55	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
92	5-Apr-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	14:56(05.04.2022)			LINE OPEN, LINE CLEAR AVAILED
93	5-Apr-2022	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	9:10	9:20	0:10	MAIN SUPPLY FAILURE
94	5-Apr-2022	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	11:48	11:50	0:02	LINE FAULT
95	5-Apr-2022	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	20:10	21:18	1:08	LINE FAULT
96	5-Apr-2022	GULBARGA	110	NALWAR-SHAHBAD	NALWAR_110	11:45	12:05	0:20	LINE FAULT
97	5-Apr-2022	GULBARGA	110	NALWAR-SHAHBAD	NALWAR_110	14:10	15:10	1:00	LINE CLEAR AVAILED
98	5-Apr-2022	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	18:47	18:57	0:10	LINE FAULT
99	5-Apr-2022	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	18:57	19:50	0:53	LINE FAULT
100	5-Apr-2022	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	19:50(05.04.2022)			LINE OPEN, LINE CLEAR AVAILED
101	5-Apr-2022	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	15:58	16:05	0:07	LINE FAULT
102	5-Apr-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	5:25	5:30	0:05	LINE FAULT
103	5-Apr-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERDONA_110,SRNAGAR_110, MALLAPURA_110	6:02	6:12	0:10	LINE FAULT
104	5-Apr-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR2	NALWAR_110	11:45	12:02	0:17	LINE FAULT
105	5-Apr-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR2	NALWAR_110	14:16	15:04	0:48	LINE CLEAR AVAILED
106	5-Apr-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	14:16	15:04	0:48	LINE CLEAR AVAILED
107	5-Apr-2022	GULBARGA	66	HV1	HOLAGUNDI_66	18:20	18:40	0:20	LINE CLEAR AVAILED
108	5-Apr-2022	GULBARGA	66	HV1	HOLAGUNDI_66	19:35	20:10	0:35	LINE CLEAR AVAILED
109	5-Apr-2022	GULBARGA	66	HV1	TELAGI_66	8:15	8:20	0:05	LINE CLEAR AVAILED
110	5-Apr-2022	GULBARGA	66	HV2	HALVAGALU_66	4:00	4:10	0:10	TRANSFORMER FAULT
111	5-Apr-2022	GULBARGA	66	HV2	HALVAGALU_66	7:00	7:10	0:10	TRANSFORMER FAULT
112	5-Apr-2022	GULBARGA	66	HV2	HALVAGALU_66	12:30	12:35	0:05	TRANSFORMER FAULT
113	5-Apr-2022	GULBARGA	66	HARAPANAHALLI- NEELAGUNDA	HARAPANAHALLI_66	17:45	18:05	0:20	LINE FAULT
114	5-Apr-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN,LINE FAULT
115	5-Apr-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	10:54 (24.03.2022)			LINE OPEN, LINE CLEAR AVAILED
116	5-Apr-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN,LINE FAULT
117	5-Apr-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
118	5-Apr-2022	HASSAN	220	SHIMOGA1	VARAHI_GEN	18:47(03.04.2022)			LINE OPEN,LINE FAULT
119	5-Apr-2022	HASSAN	220	SHIMOGA2	VARAHI_GEN	18:47(03.04.2022)			LINE OPEN,LINE FAULT
120	5-Apr-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
121	5-Apr-2022	HASSAN	220	SHRAVATHY-SHIMOGA3	gen_shravty	17:03	19:03	2:00	LINE FAULT
122	5-Apr-2022	HASSAN	220	SHRAVATHY-SHIMOGA4	gen_shravty	17:19	17:43	0:24	LINE FAULT
123	5-Apr-2022	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:25	13:46	3:21	LINE CLEAR AVAILED
124	5-Apr-2022	HASSAN	110	HV2	HALADY_110	9:29	19:10	9:41	LINE CLEAR AVAILED
125	5-Apr-2022	HASSAN	110	KADUR-NERELEKERE	KADUR_220	11:11	12:00	0:49	LINE CLEAR AVAILED
126	5-Apr-2022	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:25	13:46	3:21	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
127	5-Apr-2022	HASSAN	110	HV2	KITTADAHALLI_110	0:10	0:27	0:17	TRANSFORMER FAULT
128	5-Apr-2022	HASSAN	110	HV3	MANIPAL_110	10:00	13:07	3:07	LINE CLEAR AVAILED
129	5-Apr-2022	HASSAN	110	HV2	MSEZ_220	10:02	18:15	8:13	LINE CLEAR AVAILED
130	5-Apr-2022	HASSAN	110	HV2	NERALAKERE_110	11:15	12:10	0:55	LINE CLEAR AVAILED
131	5-Apr-2022	HASSAN	110	HV2	SAGARA_110	19:30	20:20	0:50	TRANSFORMER FAULT
132	5-Apr-2022	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	13:20	13:35	0:15	HAND TRIPPED
133	5-Apr-2022	HASSAN	66	HV1	MALLAPURA_66	21:30	22:20	0:50	MAIN SUPPLY FAILURE
134	5-Apr-2022	MYSURU	66	HV1	BGPURA_66	0:00	0:15	0:14	TRANSFORMER FAULT
135	5-Apr-2022	MYSURU	66	HV2	DEVANOORNGUDU_66	16:20	17:14	0:54	LINE CLEAR AVAILED
136	5-Apr-2022	MYSURU	66	HV1	DEVANOORMYS_66	13:48	15:32	1:44	LINE CLEAR AVAILED
137	5-Apr-2022	MYSURU	66	HV2	DEVANOORMYS_66	10:33	12:58	2:25	LINE CLEAR AVAILED
138	5-Apr-2022	MYSURU	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	11:56	18:11	6:15	LINE CLEAR AVAILED
139	5-Apr-2022	MYSURU	66	HV1	JYOTHINAGARA_66	11:31	13:09	1:38	LINE CLEAR AVAILED
140	5-Apr-2022	MYSURU	66	HV2	SANTHEBACHALLI_66	16:31	18:10	1:39	LINE CLEAR AVAILED
141	5-Apr-2022	MYSURU	66	HV1	THANDYA_66	11:17	12:02	0:45	HAND TRIPPED
142	5-Apr-2022	MYSURU	66	HV2	THANDYA_66	12:02	12:14	0:12	TRANSFORMER FAULT
143	5-Apr-2022	MYSURU	66	HV2	THANDYA_66	12:14	12:31	0:17	HAND TRIPPED
144	5-Apr-2022	MYSURU	66	KUSHALNAGARA-PERİYAPATNA 2	BYLUKUPPE_66	6:17	6:23	0:06	LINE FAULT
145	5-Apr-2022	MYSURU	66	KOPPA-BESAGRAHALLI	BESAGRAHALLI_66 KOPPA_66	18:00	18:10	0:10	HAND TRIPPED
146	5-Apr-2022	MYSURU	66	KOPPA-HAMPAPURA	NO STATIONS EFFECTED	12:00	17:55	5:55	NFBC ISSUED
147	5-Apr-2022	MYSURU	66	BEGUR-NANJANGUDU	NO STATIONS EFFECTED	21:05	21:15	0:10	LINE FAULT
148	5-Apr-2022	MYSURU	66	HV2	MANDYA_66	11:11	12:50	1:39	LINE CLEAR AVAILED
149	5-Apr-2022	MYSURU	66	MANDYA-MC-2	NO STATIONS EFFECTED	12:39	13:35	0:56	LINE CLEAR AVAILED
150	5-Apr-2022	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	8:57	13:30	4:33	LINE CLEAR AVAILED
151	5-Apr-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN, LINE CLEAR AVAILED
152	5-Apr-2022	MYSURU	66	HEBBANI-MADHUVANALLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN, LINE CLEAR AVAILED
153	5-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
154	5-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
155	5-Apr-2022	TUMKUR	220	BENKIKERE 220kV-HONNALLI LINE	BENKIKERE_220	21:30	21:58	0:28	MAIN SUPPLY FAILURE
156	5-Apr-2022	TUMKUR	220	TR-1	HONNALLI_220	13:15	14:37	1:22	LINE CLEAR AVAILED
157	5-Apr-2022	TUMKUR	220	TR-1	HONNALLI_220	21:39	22:00	0:20	MAIN SUPPLY FAILURE
158	5-Apr-2022	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	21:32	22:00	0:28	MAIN SUPPLY FAILURE
159	5-Apr-2022	TUMKUR	220	TR-1 & 2	KBCROSS_220	21:32	22:02	0:30	MAIN SUPPLY FAILURE
160	5-Apr-2022	TUMKUR	110	TR-1 (LV-SIDE)	KBCROSS_220	21:32	22:02	0:30	MAIN SUPPLY FAILURE
161	5-Apr-2022	TUMKUR	110	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	21:32	22:02	0:30	MAIN SUPPLY FAILURE
162	5-Apr-2022	TUMKUR	110	K G TEMPLE-NITTUR220	KGTEMPLE_110	9:37	9:54	0:17	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
163	5-Apr-2022	TUMKUR	110	NITTUR 220kV-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	21:51	22:17	0:26	LOAD CURTAILMENT
164	5-Apr-2022	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	21:33	21:47	0:14	LOAD CURTAILMENT
165	5-Apr-2022	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	21:36	21:53	0:16	LOAD CURTAILMENT
166	5-Apr-2022	TUMKUR	110	TR-2	NITTUR_220	22:28	22:39	0:10	TRANSFORMER FAULT
167	5-Apr-2022	TUMKUR	110	NITTUR 220kV- SOMALAPURA	SOMALAPURA_66	22:28	22:51	0:23	LINE FAULT
168	5-Apr-2022	TUMKUR	66	TR-1	BADAVANAHALLI	13:20	13:25	0:05	TRANSFORMER FAULT
169	5-Apr-2022	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	21:30	21:58	0:28	MAIN SUPPLY FAILURE
170	5-Apr-2022	TUMKUR	66	BENKIKERE 220kV-HOSADURGA LINE 1 & 2	HOSADURGA_66	21:30	21:58	0:28	MAIN SUPPLY FAILURE
171	5-Apr-2022	TUMKUR	66	CHANNAGIRI-LINGADAHALLI	CHANNAGIRI_66	7:16	8:22	1:05	MAIN SUPPLY FAILURE
172	5-Apr-2022	TUMKUR	66	CHANNAGIRI-LINGADAHALLI	CHANNAGIRI_66	21:57	22:18	0:21	MAIN SUPPLY FAILURE
173	5-Apr-2022	TUMKUR	66	CHANNAGIRI-LINGADAHALLI	CHANNAGIRI_66	10:48	14:44	3:56	LINE CLEAR AVAILED
174	5-Apr-2022	TUMKUR	66	CHANNAGIRI-LINGADAHALLI	CHANNAGIRI_66	18:54	19:44	0:49	LINE CLEAR AVAILED
175	5-Apr-2022	TUMKUR	66	TR-1	CHITRAHALLI_66	10:05	10:11	0:06	TRANSFORMER FAULT
176	5-Apr-2022	TUMKUR	66	TR-1	CHITRAHALLI_66	14:07	14:24	0:17	MAIN SUPPLY FAILURE
177	5-Apr-2022	TUMKUR	66	TR-1	CHITRAHALLI_66	18:05	19:54	1:48	MAIN SUPPLY FAILURE
178	5-Apr-2022	TUMKUR	66	TR-1	CHITRAHALLI_66	20:52	21:00	0:07	TRANSFORMER FAULT
179	5-Apr-2022	TUMKUR	66	TR-1	CHITRAHALLI_66	23:31	23:33	0:02	TRANSFORMER FAULT
180	5-Apr-2022	TUMKUR	66	TR-2	CHITRAHALLI_66	18:55	19:54	0:59	MAIN SUPPLY FAILURE
181	5-Apr-2022	TUMKUR	66	CHITRAHALLI-CHITRADURGA	CHITRAHALLI_66	6:17	18:50	12:32	MAIN SUPPLY FAILURE
182	5-Apr-2022	TUMKUR	66	CHITRAHALLI-CHITRADURGA	CHITRAHALLI_66	18:54	19:54	1:00	MAIN SUPPLY FAILURE
183	5-Apr-2022	TUMKUR	66	DEVARAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66	14:55	14:57	0:02	LINE FAULT
184	5-Apr-2022	TUMKUR	66	DEVARAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66	16:08	16:10	0:02	LINE FAULT
185	5-Apr-2022	TUMKUR	66	DAVANGERE220kV-DAVANGERE	DAVANAGERE_66	14:16	14:28	0:11	LINE FAULT
186	5-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:08	14:23	0:14	LINE FAULT
187	5-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:39	20:48	0:09	LINE FAULT
188	5-Apr-2022	TUMKUR	66	TR-1	HALURAMESWARA_66	12:52	13:05	0:13	TRANSFORMER FAULT
189	5-Apr-2022	TUMKUR	66	TR-1	HANGAL_66	11:48	12:10	0:21	LINE CLEAR AVAILED
190	5-Apr-2022	TUMKUR	66	TR-1 & 2	HONNALLI_220	13:15	14:39	1:24	LINE CLEAR AVAILED
191	5-Apr-2022	TUMKUR	66	TR-1 & 2	HONNALLI_220	21:31	22:07	0:36	MAIN SUPPLY FAILURE
192	5-Apr-2022	TUMKUR	66	HONNALLI 220kV-LINGADAHALLI-CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:46	14:51	4:05	LINE CLEAR AVAILED
193	5-Apr-2022	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,	21:31	22:02	0:30	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
194	5-Apr-2022	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,	7:05	14:49	7:44	LINE FAULT
195	5-Apr-2022	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,	15:25	15:35	0:10	LINE FAULT
196	5-Apr-2022	TUMKUR	66	TR-2	LINGADAHALLI_66	13:12	13:20	0:07	TRANSFORMER FAULT
197	5-Apr-2022	TUMKUR	66	TR-1	LOKEKERE_66	8:26	8:35	0:08	TRANSFORMER FAULT
198	5-Apr-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:14	19:52	13:37	LINE CLEAR AVAIED
199	5-Apr-2022	TUMKUR	66	TR-2	PAVAGADA_66	6:03	6:09	0:05	TRANSFORMER FAULT
200	5-Apr-2022	TUMKUR	66	TR-2	PAVAGADA_66	6:40	7:10	0:30	TRANSFORMER FAULT
201	5-Apr-2022	TUMKUR	66	TR-1	SASALUHALLA_66	13:15	13:50	0:35	LINE CLEAR AVAIED
202	5-Apr-2022	TUMKUR	66	TR-2	SASALUHALLA_66	15:40	15:45	0:05	TRANSFORMER FAULT
203	5-Apr-2022	TUMKUR	66	TR-2 &1	SASALUHALLA_66	11:15	14:50	3:35	LINE CLEAR AVAIED
204	5-Apr-2022	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR2	WELSPUN SOLAR2	19:07	19:11	0:04	LINE FAULT
205	5-Apr-2022	TUMKUR	66	TR-2	THOVINAKERE_66	7:33	8:05	0:31	LINE CLEAR AVAIED
206	5-Apr-2022	TUMKUR	66	TR-1	THOVINAKERE_66	7:15	7:30	0:15	LINE CLEAR AVAIED
207	6-Apr-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN, LINE CLEAR AVAIED
208	6-Apr-2022	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56(26.11.2021)			LINE OPEN, LINE CLEAR AVAIED
209	6-Apr-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13(03.03.2022)			LINE OPEN, LINE CLEAR AVAIED
210	6-Apr-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAIED
211	6-Apr-2022	BAGALKOT	110	GOPANKOPPA-MRUTYUNJAYNAGAR	STATION NOT AFFECTED GOPANKOPPA_110	12:46(26.03.2022)			LINE OPEN, LINE CLEAR AVAIED
212	6-Apr-2022	BAGALKOT	110	110/11KV,HV4	BELGAUM_110	5:00 (31.03.2022)			TRANSFORMER OPEN ,TRANSFORMER FAULT
213	6-Apr-2022	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59(31.03.2022)			LINE OPEN, LINE CLEAR AVAIED
214	6-Apr-2022	BAGALKOT	220	CHIKKODI- BELAGAVI2	CHIKKODI_220	19:18 (05.04.2022)	25 (06.04.2022)	13:07HRS	LINE CHARGED
215	6-Apr-2022	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	19:18 (05.04.2022)	27 (06.04.2022)	13:09HRS	LINE CHARGED
216	6-Apr-2022	BAGALKOT	220	BIDNAL-SOUDATTI	STATION NOT AFFECTED BIDNAL_220	11:36	12:57	1:21	LINE FAULT
217	6-Apr-2022	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED BIDNAL_220	9:44	13:33	3:49	LINE CLEAR AVAIED
218	6-Apr-2022	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	8:45	8:47	0:02	TRANSFORMER FAULT
219	6-Apr-2022	BAGALKOT	110	ATHARGA-KN SOLAR	ATHARGA_110	18:36	21:03	2:27	LINE CLEAR AVAIED
220	6-Apr-2022	BAGALKOT	110	110/11KV,HV2	BABLESHWAR_110	12:08	12:24	0:16	LINE CLEAR AVAIED
221	6-Apr-2022	BAGALKOT	110	110/11KV,HV2	BABLESHWAR_110	18:03	19:11	1:08	LINE CLEAR AVAIED
222	6-Apr-2022	BAGALKOT	110	110/11KV,HV2	BABLESHWAR_110	23:43	23:55	0:12	TRANSFORMER FAULT
223	6-Apr-2022	BAGALKOT	110	110/11KV,HV1	THORVI_110	6:09	12:45	6:36	LINE CLEAR AVAIED
224	6-Apr-2022	BAGALKOT	110	DAMBAL-MUNDARGI1	STATION NOT AFFECTED DAMBAL_110	18:57	22:44	3:47	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
225	6-Apr-2022	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	23:11	23:20	0:09	TRANSFORMER FAULT
226	6-Apr-2022	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	11:11	13:55	2:44	LINE CLEAR AVAILED
227	6-Apr-2022	BAGALKOT	110	110/11KV,HV3	HIDIKAL_110	23:11	23:16	0:05	TRANSFORMER FAULT
228	6-Apr-2022	BAGALKOT	110	HUKKERI-V S	HUKKERI_110	19:57	19:59	0:02	LINE FAULT
229	6-Apr-2022	BAGALKOT	110	ITNAL-KABBUR(HIDIKAL)	ITNAL_110	10:04	12:55	2:51	LINE CLEAR AVAILED
230	6-Apr-2022	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	23:10	23:15	0:05	LOAD CURTAILMENT
231	6-Apr-2022	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	TODALBAGI_110	17:27	17:28	0:01	LINE FAULT
232	6-Apr-2022	BAGALKOT	110	YELLAMANAWADI-SAVALAGI	SAVALAGI_110	17:14	17:24	0:10	LINE FAULT
233	6-Apr-2022	BAGALKOT	110	ATHANI-TODALBAGI	TODALBAGI_110	17:15	17:25	0:10	LINE FAULT
234	6-Apr-2022	BAGALKOT	110	110/33KV,HV1	BIJJARAGI_33 TIKOTA_110	16:05	16:10	0:05	TRANSFORMER FAULT
235	6-Apr-2022	BAGALKOT	110	TARIHAL-TARIHAL1&2	STATION NOT AFFECTED TARIHAL_110	10:19	13:51	3:32	LINE CLEAR AVAILED
236	6-Apr-2022	BAGALKOT	110	SOUDATTI-ENERCON2	SOUDATTI_110	5:39	8:20	2:41	LINE FAULT
237	6-Apr-2022	BAGALKOT	110	110/33KV,HV2	KALBILAGI_33,HIREPADASALA GI_33,TUNGAL LIS SAVALAGI_110	17:56	21:00	3:04	TRANSFORMER FAULT
238	6-Apr-2022	BAGALKOT	110	MALGHAN-MANALI SUGARS	MALGHAN(S)_110	2:51	2:57	0:06	LINE FAULT
239	6-Apr-2022	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	23:45	23:55	0:10	LINE CLEAR AVAILED
240	6-Apr-2022	BAGALKOT	220	220/110KV, HV1	AQUES_220	19:20	19:47	0:27	TRANSFORMER FAULT
241	6-Apr-2022	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	19:20	19:55	0:35	LINE FAULT
242	6-Apr-2022	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	19:20	19:55	0:35	LINE FAULT
243	6-Apr-2022	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	11:33	13:05	1:32	LINE FAULT
244	6-Apr-2022	BAGALKOT	110	KARWAR220- ARGA(KUMTA)	STATION NOT AFFECTED KARWAR_220	9:37	9:42	0:05	LINE FAULT
245	6-Apr-2022	BAGALKOT	220	CHIKKODI- BELGAUM1(AQUES)	STATION NOT AFFECTED CHIKKODI_220	11:17(06.04.2022)			LINE OPEN, LINE CLEAR AVAILED
246	6-Apr-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	17:30 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
247	6-Apr-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	9:40 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
248	6-Apr-2022	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	23:40(05.04.2022)	39 (06.04.2022)	5:59HRS	LINE CHARGED
249	6-Apr-2022	BAGALKOT	110	MAHALINGAPUR- DAVALESHWAR	DAVALESHWAR_110	23:55(05.04.2022)	45 (06.04.2022)	0:50HRS	LINE CHARGED
250	6-Apr-2022	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABKAVI_110	23:41(05.04.2022)	39 (06.04.2022)	0:58HRS	LINE CHARGED
251	6-Apr-2022	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MAHALINGAPUR_220	23:58(05.04.2022)	38 (06.04.2022)	0:40HRS	TRANSFORMER CHARGED
252	6-Apr-2022	BAGALKOT	110	ATHANI220-SATTI	ATHANI_220	23:37 (05.04.2022)	30 (06.04.2022)	0:53HRS	LINE CHARGED
253	6-Apr-2022	BAGALKOT	110	ATHANI220-HALYAL110	ATHANI_220	23:10 (05.04.2022)	07 (6.4.2022)	11:57HRS	LINE CHARGED
254	6-Apr-2022	BAGALKOT	110	110/33KV, HV3	MANTUR(B)_110	12:40	14:00	1:20	LINE CLEAR AVAILED
255	6-Apr-2022	BAGALKOT	110	110/11KV, HV1	MAREGUDDI_110	11:50	12:35	0:45	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
256	6-Apr-2022	BAGALKOT	110	110/11KV, HV2	MAREGUDDI_110	10:15	12:35	2:20	LINE CLEAR AVAILED
257	6-Apr-2022	BAGALKOT	110	BAGALKOT220-RAMDURG	STATION NOT AFFECTED BAGALKOT_220	16:05	16:15	0:10	LINE FAULT
258	6-Apr-2022	BAGALKOT	110	MUGALKHOD- ITANAL3	STATION NOT AFFECTED MUGALKHOD_220	10:04	12:54	2:50	NFBC ISSUED
259	6-Apr-2022	BAGALKOT	110	HUBLI220- TARIHAL2	STATION NOT AFFECTED HUBLI_220	10:21	13:37	3:16	NFBC ISSUED
260	6-Apr-2022	BAGALKOT	110	INDI220- ZALKI1	STATION NOT AFFECTED INDI_220	16:49	16:58	0:09	LINE FAULT
261	6-Apr-2022	BAGALKOT	110	110/11KV, HV1	UMMACHAGI_110	1:05	1:15	0:10	TRANSFORMER FAULT
262	6-Apr-2022	BAGALKOT	110	110/11KV, HV1	UMMACHAGI_110	3:45	4:00	0:15	TRANSFORMER FAULT
263	6-Apr-2022	BAGALKOT	220	AQUES- BELGAUM1	STATION NOT AFFECTED AQUES_220	19:20	19:50	0:30	LINE FAULT
264	6-Apr-2022	BENGALURU	66	HV1	ADUGODI	1:55	2:15	0:20	TRANSFORMER FAULT
265	6-Apr-2022	BENGALURU	66	ADUGODI - HSR LAYOUT 1 220	ADUGODI	5:50	5:58	0:08	LOAD CHANGE OVER
266	6-Apr-2022	BENGALURU	66	HV1	AMAR JYOTHI	1:03	1:28	0:25	TRANSFORMER FAULT
267	6-Apr-2022	BENGALURU	66	HV1	AMAR JYOTHI	5:08	5:45	0:37	TRANSFORMER FAULT
268	6-Apr-2022	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	11:50	11:55	0:05	LOAD CHANGE OVER
269	6-Apr-2022	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	14:08	14:13	0:05	LOAD CHANGE OVER
270	6-Apr-2022	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	5:54	6:28	0:34	LINE FAULT
271	6-Apr-2022	BENGALURU	66	LEELA VENTURE - HAL 2 220	LEELA VENTURE	7:15	7:40	0:25	LOAD CHANGE OVER
272	6-Apr-2022	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:35	11:45	0:10	LOAD CHANGE OVER
273	6-Apr-2022	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	14:17	14:24	0:07	LOAD CHANGE OVER
274	6-Apr-2022	BENGALURU	66	HV1	PATHPALYA	16:03	16:57	0:54	LINE CLEAR AVAILED
275	6-Apr-2022	BENGALURU	66	BAGMANE WTP - HOODY 2	BAGMANE WTP	23:05	23:10	0:05	LOAD CHANGE OVER
276	6-Apr-2022	BENGALURU	66	HV2	DODDALAHALLI	14:02	15:29	1:27	LINE CLEAR AVAILED
277	6-Apr-2022	BENGALURU	66	HV1	DODDALAHALLI	14:02	15:29	1:27	LINE CLEAR AVAILED
278	6-Apr-2022	BENGALURU	66	HV1	BANGARPET	19:23	20:30	1:06	LINE CLEAR AVAILED
279	6-Apr-2022	BENGALURU	66	HV1	BANGARPET	7:50	11:50	4:00	LINE CLEAR AVAILED
280	6-Apr-2022	BENGALURU	66	HV2	BANGARPET	0:00	0:05	0:05	LINE CLEAR AVAILED
281	6-Apr-2022	BENGALURU	66	HV2	BANGARPET	7:50	11:59	4:09	MAIN SUPPLY FAILURE
282	6-Apr-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	13:13	13:18	0:04	LINE FAULT
283	6-Apr-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	18:19	18:27	0:08	LINE FAULT
284	6-Apr-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	17:50	17:58	0:08	LINE FAULT
285	6-Apr-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), HOSKOTE 66	23:52:04(5-4-2022)	0:16(6-4-2022)	0:23HRS	LINE CHARGED
286	6-Apr-2022	BENGALURU	66	HV2	PRESTIGE SHANTINIKETHAN	20:14(5/4/2022)	15(06/04/2022)	5:01HRS	TRANSFORMER CHARGED
287	6-Apr-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	9:32(04.04.2022)	1:33(06.04.2022)	60:01HRS	LINE CHARGED
288	6-Apr-2022	GULBARGA	400	BPS-JSWL3	BPS_400	13:38	15:46	2:08	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
289	6-Apr-2022	GULBARGA	220	SEDAM-TANDUR	TANDUR_220	14:10(06.04.2022)			LINE OPEN, LINE CLEAR AVAILED
290	6-Apr-2022	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	15:40	16:08	0:28	LINE CLEAR AVAILED
291	6-Apr-2022	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	14:56(05.04.2022)			LINE OPEN, LINE CLEAR AVAILED
292	6-Apr-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	11:15(06.04.2022)			LINE OPEN, LINE FAULT
293	6-Apr-2022	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	12:05(06.04.2022)			LINE OPEN, LINE CLEAR AVAILED
294	6-Apr-2022	GULBARGA	110	HV3	YELBURGA_110	23:11	23:24	0:13	LOAD CURTAILMENT
295	6-Apr-2022	GULBARGA	110	HV4	KOLHAR_110	16:50	17:15	0:25	LINE CLEAR AVAILED
296	6-Apr-2022	GULBARGA	110	HV1	TEKKALKOTE_110	23:10	23:21	0:11	LOAD CURTAILMENT
297	6-Apr-2022	GULBARGA	110	HV1	GANDHINAGAR_110	9:51	10:51	1:00	LINE CLEAR AVAILED
298	6-Apr-2022	GULBARGA	110	HV1	ALAND_110	15:40	16:00	0:20	LINE CLEAR AVAILED
299	6-Apr-2022	GULBARGA	110	HV3	CHIDRI_110	16:35	17:35	1:00	LINE CLEAR AVAILED
300	6-Apr-2022	GULBARGA	110	HV2	CHINCHOLI_110	23:10	23:35	0:25	LOAD CURTAILMENT
301	6-Apr-2022	GULBARGA	110	HV2	HATTI_110	23:10	23:15	0:05	TRANSFORMER FAULT
302	6-Apr-2022	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	19:50(05.04.2022)	19:43(06.04.2022)	05:53HRS	LINE CHARGED
303	6-Apr-2022	GULBARGA	110	KUSTAGI-KUSTAGI SOLAR	KUSTAGI_220	19:00	23:50	4:50	LINE CLEAR AVAILED
304	6-Apr-2022	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	1:26	1:32	0:06	LINE FAULT
305	6-Apr-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_110,CORE GREEN SUGAR IPP	9:17	18:21	9:04	LINE CLEAR AVAILED
306	6-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:47	19:52	0:05	LINE FAULT
307	6-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:10	20:16	0:06	LINE FAULT
308	6-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:15	22:19	0:04	LINE FAULT
309	6-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	23:49	0:05	0:16	LINE FAULT
310	6-Apr-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	21:59	22:09	0:10	LINE FAULT
311	6-Apr-2022	GULBARGA	66	HV1,HV2	TAMBRAHALI_66	16:10	17:10	1:00	LINE CLEAR AVAILED
312	6-Apr-2022	GULBARGA	66	HV2	HARAPANAHALLI_66	4:00	4:05	0:05	LOAD CURTAILMENT
313	6-Apr-2022	GULBARGA	66	HV2	HARAPANAHALLI_66	8:30	8:40	0:10	LOAD CURTAILMENT
314	6-Apr-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN, LINE FAULT
315	6-Apr-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	10:54 (24.03.2022)			LINE OPEN, LINE CLEAR AVAILED
316	6-Apr-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN, LINE FAULT
317	6-Apr-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
318	6-Apr-2022	HASSAN	220	SHIMOGA1	VARAHI_GEN	18:47(03.04.2022)			LINE OPEN, LINE FAULT
319	6-Apr-2022	HASSAN	220	SHIMOGA2	VARAHI_GEN	18:47(03.04.2022)			LINE OPEN, LINE FAULT
320	6-Apr-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
321	6-Apr-2022	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	17:03(06/04/2022)			LINE OPEN, LINE FAULT
322	6-Apr-2022	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	16:36	19:40	3:04	LINE FAULT
323	6-Apr-2022	HASSAN	220	VARAHI-SHIMOGA2	VARAHI	16:36	19:40	3:04	LINE FAULT
324	6-Apr-2022	HASSAN	110	HV2	HALADY_110	12:40	12:50	0:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
325	6-Apr-2022	HASSAN	110	HV2	KADUR_220	16:36	17:12	0:36	TRANSFORMER FAULT
326	6-Apr-2022	HASSAN	110	KADUR-TNGL	KADUR_220	16:36	17:12	0:36	LINE FAULT
327	6-Apr-2022	HASSAN	110	KADUR-YGTI	KADUR_220	16:36	17:12	0:36	LINE FAULT
328	6-Apr-2022	HASSAN	110	HV2	MSEZ_220	10:04	16:12	6:08	LINE CLEAR AVAILED
329	6-Apr-2022	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	9:58	10:50	0:52	NFBC ISSUED
330	6-Apr-2022	HASSAN	66	HV1	ARAKALGUD_66	9:45	13:00	3:15	MAIN SUPPLY FAILURE
331	6-Apr-2022	HASSAN	66	HV2	ARAKALGUD_66	9:45	13:00	3:15	MAIN SUPPLY FAILURE
332	6-Apr-2022	HASSAN	66	ARAKLGD-MALLIPATNA	ARAKALGUD_66	9:50	13:00	3:10	MAIN SUPPLY FAILURE
333	6-Apr-2022	HASSAN	66	HV1	DODDAHALLI_66	15:20	16:10	0:50	LINE CLEAR AVAILED
334	6-Apr-2022	HASSAN	66	HASSN-ARAKALGUD	HASSAN_220	9:44	12:48	3:04	LINE FAULT
335	6-Apr-2022	HASSAN	66	MRSSMG-HOLUR	MRSMSG_220	12:58	16:49	3:51	LOAD CHANGE OVER
336	6-Apr-2022	HASSAN	66	HV2	RAMESHWARNAGAR_66	23:10	23:25	0:15	TRANSFORMER FAULT
337	6-Apr-2022	HASSAN	66	HV1	SALAGAME_66	12:00	13:10	1:10	LINE CLEAR AVAILED
338	6-Apr-2022	HASSAN	66	HV2	SALAGAME_66	12:00	13:10	1:10	LINE CLEAR AVAILED
339	6-Apr-2022	HASSAN	66	HV1	SHRAVANABELAGOLA_66	22:10	22:17	0:07	TRANSFORMER FAULT
340	6-Apr-2022	HASSAN	66	TAVARC-HONNALLI	TAVARECHATNAHALLI_66	21:40	21:45	0:05	LINE FAULT
341	6-Apr-2022	HASSAN	66	HV1	YESLUR_66	9:45	12:55	3:10	MAIN SUPPLY FAILURE
342	6-Apr-2022	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	BASARALU_66 HARADANAHALLI_66 KESLAGERE_66 SHIVALLY_66	2:45	2:50	0:05	LINE FAULT
343	6-Apr-2022	MYSURU	66	TUBINAKERE-PANDAVAPURA	BANANGADI_66 BELAGOLA_66 DODDABYADARAHALLI_66 PANDAVAPURA_66	11:47	11:58	0:11	LINE FAULT
344	6-Apr-2022	MYSURU	66	VAJAMANGALA-DEVANUR MYSORE	DEVANOORMYS_66	10:37	11:00	0:23	HAND TRIPPED
345	6-Apr-2022	MYSURU	66	VAJAMANGALA-DEVANUR MYSORE	NO STATIONS EFFECTED	12:50	18:05	5:15	LINE CLEAR AVAILED
346	6-Apr-2022	MYSURU	66	ADDIHALLY-TUBINAKERE	ADICHUNCHANAGIRI_66 BGNAGARA_66 KADABALLY_66 VADERALLI_66	6:05	6:15	0:10	LINE FAULT
347	6-Apr-2022	MYSURU	66	KOPPA-HAMPAURA - BASARALU	BESAGARAHALLI_66 KOPPA_66	11:45	18:20	6:35	LINE CLEAR AVAILED
348	6-Apr-2022	MYSURU	66	HV1	HONNALLY_MYS_66	16:00	17:30	1:30	LINE CLEAR AVAILED
349	6-Apr-2022	MYSURU	66	CHUNCHANKATTE-RAVANDUR	CHUNCHUNKATTE_66	18:18	19:15	0:56	LINE FAULT
350	6-Apr-2022	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	10:37	18:09	7:32	LINE CLEAR AVAILED
351	6-Apr-2022	MYSURU	66	HV1	HADLI_66	14:00	15:52	1:51	LINE CLEAR AVAILED
352	6-Apr-2022	MYSURU	66	HV2	K_HONNALGERE_66	10:24	11:05	0:40	LINE CLEAR AVAILED
353	6-Apr-2022	MYSURU	66	SFCSIVA-PPCL	NO STATIONS EFFECTED	6:20	13:02	6:41	LINE CLEAR AVAILED
354	6-Apr-2022	MYSURU	66	THALAKDU-PARIMAIPURA	PARINAMIPURA_66 THALAKADU_66	15:50	15:53	0:02	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
355	6-Apr-2022	MYSURU	66	CHUNCHANKATTE-K R NAGARA	NO STATIONS EFFECTED	6:20:00 PM (6/4/2022)			LINE OPEN,LINE FAULT
356	6-Apr-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN, LINE CLEAR AVAILED
357	6-Apr-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN, LINE CLEAR AVAILED
358	6-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
359	6-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
360	6-Apr-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	8:03	16:23	8:20	NFBC ISSUED
361	6-Apr-2022	TUMKUR	220	TR-1	GUTTUR_220	7:42	14:24	6:41	TRANSFORMER FAULT
362	6-Apr-2022	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	7:50	16:01	8:10	LINE CLEAR AVAILED
363	6-Apr-2022	TUMKUR	220	TR-1	HONNALLI	15:14	16:03	0:49	MAIN SUPPLY FAILURE
364	6-Apr-2022	TUMKUR	220	KB CROSS 220kV-NELAMANGALA	KBCROSS_220	13:14	17:30	4:15	LOAD CURTAILMENT
365	6-Apr-2022	TUMKUR	110	TR-1	KBCROSS_220	13:14	13:17	0:03	LOAD CURTAILMENT
366	6-Apr-2022	TUMKUR	110	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	13:14	17:41	4:26	LOAD CURTAILMENT
367	6-Apr-2022	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	15:15	16:08	0:53	LOAD CURTAILMENT
368	6-Apr-2022	TUMKUR	66	TR1	CHITRAHALLI_66	0:24	0:28	0:03	TRANSFORMER FAULT
369	6-Apr-2022	TUMKUR	66	TR1	CHITRAHALLI_66	6:50	6:54	0:04	TRANSFORMER FAULT
370	6-Apr-2022	TUMKUR	66	TR1	CHITRAHALLI_66	7:16	7:20	0:03	TRANSFORMER FAULT
371	6-Apr-2022	TUMKUR	66	TR2	CHITRAHALLI_66	14:16	14:17	0:01	TRANSFORMER FAULT
372	6-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:19	18:31	0:11	LINE FAULT
373	6-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	21:05	21:15	0:09	LINE FAULT
374	6-Apr-2022	TUMKUR	66	TR-1(LV1)	GUTTUR_220	7:42	14:26	6:44	LINE CLEAR AVAILED
375	6-Apr-2022	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	15:22	15:48	0:26	LINE FAULT
376	6-Apr-2022	TUMKUR	66	TR-1	HAGALWADI_66	13:07	13:54	0:47	LINE CLEAR AVAILED
377	6-Apr-2022	TUMKUR	66	TR-1(LV)	HAGALWADI_66	13:09	13:54	0:45	LINE CLEAR AVAILED
378	6-Apr-2022	TUMKUR	66	TR-1(HV & LV SIDE)	HONNALLI_220	15:13	16:08	0:55	MAIN SUPPLY FAILURE
379	6-Apr-2022	TUMKUR	66	TR-2(HV & LV SIDE)	HONNALLI_220	15:13	16:13	0:59	MAIN SUPPLY FAILURE
380	6-Apr-2022	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR_66,MALEBENNUR_66,DEVARABELKERE_66	15:13	16:28	1:15	MAIN SUPPLY FAILURE
381	6-Apr-2022	TUMKUR	66	HONNALLI 220kV-LINGADAHALLI-CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:13	16:28	1:14	MAIN SUPPLY FAILURE
382	6-Apr-2022	TUMKUR	66	HONNALLI 220kV-LINGADAHALLI-CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:13	16:08	0:55	MAIN SUPPLY FAILURE
383	6-Apr-2022	TUMKUR	66	TR-2	KOLALA_66	9:10	9:24	0:13	TRANSFORMER FAULT
384	6-Apr-2022	TUMKUR	66	KUNDUR- HONNALI	KUNDUR_66,MALEBENNUR_66	15:39	16:14	0:35	MAIN SUPPLY FAILURE
385	6-Apr-2022	TUMKUR	66	TR-2	MELEKOTE_66	12:28	12:42	0:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
386	6-Apr-2022	TUMKUR	66	TR-2	PATNAYAKANAHALLI LINE2	11:48	12:25	0:37	LINE CLEAR AVAILED
387	6-Apr-2022	TUMKUR	66	TR-2	SASALUHALLA_66	12:47	12:49	0:02	LOAD CURTAILMENT
388	6-Apr-2022	TUMKUR	66	TR-1	SASALUHALLA_66	11:00	12:47	1:47	LINE CLEAR AVAILED
389	6-Apr-2022	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	8:45	8:48	0:03	LINE FAULT
390	6-Apr-2022	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	17:00	18:12	1:12	MAIN SUPPLY FAILURE
391	7-Apr-2022	BAGALKOT	220	MUGALKHOD- GHATAPRABHA2	MUGALKHOD_220	21:25 (07.04.2022)			LINE OPEN,LINE FAULT
392	7-Apr-2022	BAGALKOT	110	HUBLI-TARIHAL 2	TARIHAL_110	18:20	18:39	0:19	LINE FAULT
393	7-Apr-2022	BAGALKOT	220	BAGALKOT - KOPPAL LIS	BAGALKOT_220	15:30	17:15	1:45	LINE CLEAR AVAILED
394	7-Apr-2022	BAGALKOT	110	BAGALKOT-GULEDAGUDDA	GLEDAGUDDA_110	18:56	19:12	0:16	LINE FAULT
395	7-Apr-2022	BAGALKOT	110	110/33KV,HV1	KATAGERI_33.GADDANANAKE RI_33 BAGALKOT_220	18:56	19:14	0:18	TRANSFORMER FAULT
396	7-Apr-2022	BAGALKOT	220	MAHALINGAPUR-ATHANI	ATHANI_220	10:00	11:58	1:58	LINE CLEAR AVAILED
397	7-Apr-2022	BAGALKOT	220	MAHALINGAPUR-ATHANI	ATHANI_220	20:30	21:07	0:37	LINE FAULT
398	7-Apr-2022	BAGALKOT	220	ATHANI-KUDACHI	ATHANI_220	10:00	12:00	2:00	LINE CLEAR AVAILED
399	7-Apr-2022	BAGALKOT	220	220/110KV,HV1,LV1	ATHANI_220	10:00	12:08	2:08	LINE CLEAR AVAILED
400	7-Apr-2022	BAGALKOT	220	220/110KV,HV1,LV1	ATHANI_220	12:56	16:42	3:46	LINE CLEAR AVAILED
401	7-Apr-2022	BAGALKOT	110	ATHANI220-ATHANI	ATHANI_110	10:00	12:08	2:08	LINE CLEAR AVAILED
402	7-Apr-2022	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	10:00	11:04	1:04	LINE CLEAR AVAILED
403	7-Apr-2022	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	12:02	12:08	0:06	HAND TRIPPED
404	7-Apr-2022	BAGALKOT	110	ATHANI-KARIMASUTTI LIS	ATHANI_220	10:00	12:08	2:08	LINE CLEAR AVAILED
405	7-Apr-2022	BAGALKOT	110	ATHANI220-HALYAL	HALIYAL_110	12:02	12:08	0:06	HAND TRIPPED
406	7-Apr-2022	BAGALKOT	110	ATHANI220-HALYAL	HALIYAL_110	17:26	17:45	0:19	LINE FAULT
407	7-Apr-2022	BAGALKOT	110	ATHANI220-KSSKN	ATHANI_220	10:00	12:08	2:08	LINE CLEAR AVAILED
408	7-Apr-2022	BAGALKOT	110	110/11KV,HV1	VAJJRAMATTI_220	12:01	12:06	0:05	TRANSFORMER FAULT
409	7-Apr-2022	BAGALKOT	110	MAREGUDDI-MUNDAGNUR	MAREGUDDI_110	1:15	1:20	0:05	HAND TRIPPED
410	7-Apr-2022	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	19:52	22:04	2:12	LINE FAULT
411	7-Apr-2022	BAGALKOT	110	HALIYAL-ALNAVAR	ALNAVAR_110	5:40	6:00	0:20	LINE FAULT
412	7-Apr-2022	BAGALKOT	110	HALIYAL-KAWALWADA	HALIYAL_110	17:56(07.04.2022)			LINE OPEN,LINE FAULT
413	7-Apr-2022	BAGALKOT	220	MAHALINGAPUR- ATHANI	STATION NOT AFFECTED MAHALINGAPUR_220	20:30	21:08	0:38	LINE FAULT
414	7-Apr-2022	BENGALURU	66	AMAR JYOTHI - LEELA VENTRUE	AMAR JYOTHI	15:05	15:29	0:24	LOAD CHANGE OVER
415	7-Apr-2022	BENGALURU	66	HV2	CHATRA	10:59	11:08	0:09	LINE CLEAR AVAILED
416	7-Apr-2022	BENGALURU	220	HOODY 220 - ITI 220	ITI 220	15:05	15:10	0:05	LINE FAULT
417	7-Apr-2022	BENGALURU	66	HV2	BANASAWADI	15:05	15:10	0:05	MAIN SUPPLY FAILURE
418	7-Apr-2022	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	15:05	15:10	0:05	MAIN SUPPLY FAILURE
419	7-Apr-2022	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	15:05	15:10	0:05	MAIN SUPPLY FAILURE
420	7-Apr-2022	BENGALURU	66	ITI 220 - NGEF	NGEF, NGEF(EHT)	15:05	15:10	0:05	MAIN SUPPLY FAILURE
421	7-Apr-2022	BENGALURU	66	KACHAMARANAHALLI - DIVYASHREE TECH PARK	KACHAMARANAHALLI	13:30	16:30	3:00	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
422	7-Apr-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	8:40	9:00	0:20	LINE CLEAR AVAILED
423	7-Apr-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:40	12:35	0:55	LINE CLEAR AVAILED
424	7-Apr-2022	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 66	14:45	17:10	2:25	LINE CLEAR AVAILED
425	7-Apr-2022	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 66	20:51	21:12	0:21	LINE FAULT
426	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	11:20	11:30	0:10	LINE CLEAR AVAILED
427	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	11:20	11:30	0:10	LINE CLEAR AVAILED
428	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:20	11:30	0:10	LINE CLEAR AVAILED
429	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	11:20	11:30	0:10	LINE CLEAR AVAILED
430	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - CESSNA	CESSNA	11:20	11:30	0:10	LINE CLEAR AVAILED
431	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	11:20	11:30	0:10	LINE CLEAR AVAILED
432	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:40	14:05	0:25	LINE CLEAR AVAILED
433	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	13:40	14:05	0:25	LINE CLEAR AVAILED
434	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:40	14:05	0:25	LINE CLEAR AVAILED
435	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	13:40	14:05	0:25	LINE CLEAR AVAILED
436	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - CESSNA	CESSNA	13:40	14:05	0:25	LINE CLEAR AVAILED
437	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:40	14:05	0:25	LINE CLEAR AVAILED
438	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	15:00	15:15	0:15	LINE CLEAR AVAILED
439	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	15:00	15:15	0:15	LINE CLEAR AVAILED
440	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	15:00	15:15	0:15	LINE CLEAR AVAILED
441	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	15:00	15:15	0:15	LINE CLEAR AVAILED
442	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - CESSNA	CESSNA	15:00	15:15	0:15	LINE CLEAR AVAILED
443	7-Apr-2022	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	15:00	15:15	0:15	LINE CLEAR AVAILED
444	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS	17:50	18:12	0:22	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
445	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI	17:50	18:15	0:25	MAIN SUPPLY FAILURE
446	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	17:50	18:13	0:23	MAIN SUPPLY FAILURE
447	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	17:50	18:13	0:23	MAIN SUPPLY FAILURE
448	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	17:50	18:04	0:14	MAIN SUPPLY FAILURE
449	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	17:50	18:16	0:26	MAIN SUPPLY FAILURE
450	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	17:50	18:14	0:24	MAIN SUPPLY FAILURE
451	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	17:50	18:11	0:21	MAIN SUPPLY FAILURE
452	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	17:50	18:15	0:25	MAIN SUPPLY FAILURE
453	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:50	18:12	0:22	MAIN SUPPLY FAILURE
454	7-Apr-2022	BENGALURU	220	HV1	CHINTAMANI 220	17:50	18:04	0:14	MAIN SUPPLY FAILURE
455	7-Apr-2022	BENGALURU	220	HV2	CHINTAMANI 220	17:50	18:05	0:15	MAIN SUPPLY FAILURE
456	7-Apr-2022	BENGALURU	220	HV3	CHINTAMANI 220	17:50	18:06	0:16	MAIN SUPPLY FAILURE
457	7-Apr-2022	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	17:50	18:00	0:10	MAIN SUPPLY FAILURE
458	7-Apr-2022	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	17:50	18:00	0:10	MAIN SUPPLY FAILURE
459	7-Apr-2022	BENGALURU	66	HV1	TYAMAGONDLU	19:50	20:24	0:34	TRANSFORMER FAULT
460	7-Apr-2022	BENGALURU	66	HV2	M GOLLAHALLI	12:50	13:23	0:33	LINE CLEAR AVAILED
461	7-Apr-2022	BENGALURU	66	HV1	M GOLLAHALLI	13:23	15:29	2:06	LINE CLEAR AVAILED
462	7-Apr-2022	BENGALURU	66	HV2	M GOLLAHALLI	15:09	15:29	0:20	LINE CLEAR AVAILED
463	7-Apr-2022	BENGALURU	66	HV1	KACHAMARANAHALLI	13:15	13:20	0:05	TRANSFORMER FAULT
464	7-Apr-2022	BENGALURU	66	HV2	IRGAMPALLI	12:02	13:17	1:14	LINE CLEAR AVAILED
465	7-Apr-2022	BENGALURU	66	TADIGOL CROSS - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	17:55	18:15	0:20	LINE FAULT
466	7-Apr-2022	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	10:23	12:53	2:30	LINE CLEAR AVAILED
467	7-Apr-2022	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	14:47	15:15	0:27	LINE FAULT
468	7-Apr-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	22:16	22:26	0:09	LINE FAULT
469	7-Apr-2022	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	8:35	8:43	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
470	7-Apr-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	19:30	19:55	0:25	LOAD CURTAILMENT
471	7-Apr-2022	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	19:00	19:30	0:30	LOAD CURTAILMENT
472	7-Apr-2022	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	17:12	19:55	2:42	LINE FAULT
473	7-Apr-2022	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	19:29	19:55	0:26	LOAD CURTAILMENT
474	7-Apr-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	10:27(07.04.2022)			LINE OPEN, LINE CLEAR AVAILED
475	7-Apr-2022	GULBARGA	220	HV2	SULEKAL_220	12:00	15:25	3:25	LINE CLEAR AVAILED
476	7-Apr-2022	GULBARGA	220	HV1,HV2	KUSTAGI_220	8:50	9:52	1:02	TRANSFORMER FAULT
477	7-Apr-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	9:47	12:19	2:32	NFBC ISSUED
478	7-Apr-2022	GULBARGA	220	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	11:01	18:13	7:12	LINE CLEAR AVAILED
479	7-Apr-2022	GULBARGA	110	HV2	NIRNA_110	13:35	13:40	0:05	TRANSFORMER FAULT
480	7-Apr-2022	GULBARGA	110	HV1	BELLARYSOUTH_110	16:19	16:34	0:15	TRANSFORMER FAULT
481	7-Apr-2022	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	15:56	18:08	2:12	LINE FAULT
482	7-Apr-2022	GULBARGA	110	HUMNABAD-MANEIKHELLI	MANAIKHELLI_110	16:24	16:27	0:03	HAND TRIPPED
483	7-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	12:22	12:27	0:05	LINE FAULT
484	7-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	4:48	5:15	0:27	LINE FAULT
485	7-Apr-2022	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	11:10	11:23	0:13	LINE FAULT
486	7-Apr-2022	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	11:23	11:59	0:36	LINE FAULT
487	7-Apr-2022	GULBARGA	110	VAJRABANDI-KUSHTAGI	VAJRABANDI_110	8:55	9:55	1:00	MAIN SUPPLY FAILURE
488	7-Apr-2022	GULBARGA	110	MALLAPURA-MUNIRABAD	MALLAPUR	8:55	9:55	1:00	MAIN SUPPLY FAILURE
489	7-Apr-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110, KEREHALLI_110,MALLAPUR_110	12:36	12:41	0:05	LINE FAULT
490	7-Apr-2022	GULBARGA	66	HV2	BENNEHALLI_66	17:40	17:45	0:05	TRANSFORMER FAULT
491	7-Apr-2022	GULBARGA	66	HV2	TELAGI_66	15:05	15:40	0:35	LINE CLEAR AVAILED
492	7-Apr-2022	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	0:27	0:35	0:08	LINE FAULT
493	7-Apr-2022	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	17:03(06/04/2022)	17:26(07.04.2022)	16:23HRS	LINE CHARGED
494	7-Apr-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN,LINE FAULT
495	7-Apr-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	10:54 (24.03.2022)			LINE OPEN, LINE CLEAR AVAILED
496	7-Apr-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN,LINE FAULT
497	7-Apr-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
498	7-Apr-2022	HASSAN	220	VARAHI-SHIMOGA2	VARAHI_GEN	18:47(03.04.2022)			LINE OPEN,LINE FAULT
499	7-Apr-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
500	7-Apr-2022	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	7:15(07.04.2022)			LINE OPEN, LINE CLEAR AVAILED
501	7-Apr-2022	HASSAN	220	VARAH1-SHIMOGA1	gen_varahi	7:20(07.04.2022)			LINE OPEN, LINE CLEAR AVAILED
502	7-Apr-2022	HASSAN	400	HASSAN2-UPCL2	SHANTIGRAMA_400	7:54	20:29	12:35	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
503	7-Apr-2022	HASSAN	400	UPCL-HASSAN2	gen_upcl	7:54	20:29	12:35	LINE CLEAR AVAILED
504	7-Apr-2022	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:26	16:19	2:53	NFBC ISSUED
505	7-Apr-2022	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	13:12	14:17	1:05	LINE FAULT
506	7-Apr-2022	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	10:25	17:40	7:15	LINE CLEAR AVAILED
507	7-Apr-2022	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	17:45	18:20	0:35	LINE CLEAR AVAILED
508	7-Apr-2022	HASSAN	110	HV1	GURUVAYANAKERE_110	13:27	13:35	0:08	TRANSFORMER FAULT
509	7-Apr-2022	HASSAN	110	HV1	KADUR_220	13:20	13:33	0:13	TRANSFORMER FAULT
510	7-Apr-2022	HASSAN	110	HV2	MSEZ_220	10:09	15:15	5:06	LINE CLEAR AVAILED
511	7-Apr-2022	HASSAN	110	HV2	NITTUR_110	8:19	8:29	0:10	TRANSFORMER FAULT
512	7-Apr-2022	HASSAN	110	HV1	SORABA_110	15:00	17:15	2:15	LINE CLEAR AVAILED
513	7-Apr-2022	HASSAN	66	HV2	BASAVAGATTA_66	17:55	18:10	0:15	TRANSFORMER FAULT
514	7-Apr-2022	HASSAN	66	HV1	CR PATNA_220	14:26	14:45	0:19	LINE CLEAR AVAILED
515	7-Apr-2022	HASSAN	66	HV1	MALLAPURA_66	13:00	13:15	0:15	MAIN SUPPLY FAILURE
516	7-Apr-2022	MYSURU	66	KUNTHUR-MADHUVANAHALLI	NO STATIONS EFFECTED	15:52	15:57	0:05	LINE FAULT
517	7-Apr-2022	MYSURU	66	HANNUR-AJJIPURA	AJJIPURA_66,BANDALLI COWDALLI_66 RAMAPURA_MYS_66 MARTALLI_66	17:10	17:45	0:35	LINE CLEAR AVAILED
518	7-Apr-2022	MYSURU	66	HOOTAGALLI-BOGHADI	BOGADHI_66	6:29	7:35	1:06	LINE FAULT
519	7-Apr-2022	MYSURU	66	KUSHALNAGARA-MYSORE-1	BILIKERE_66 GVGUDI_66 KRNAGARA_66 MIRLE_66	8:55	9:02	0:07	LINE FAULT
520	7-Apr-2022	MYSURU	66	KUSHALNAGARA-MYSORE-1	BILIKERE_66 GVGUDI_66 KRNAGARA_66 MIRLE_66	10:08	10:21	0:13	LINE FAULT
521	7-Apr-2022	MYSURU	66	KUSHALNAGARA-MYSORE-1	BILIKERE_66 GVGUDI_66 KRNAGARA_66 MIRLE_66	13:05	13:18	0:13	LINE FAULT
522	7-Apr-2022	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	11:16	13:18	2:02	LINE CLEAR AVAILED
523	7-Apr-2022	MYSURU	220	CR NAGARA-BEGUR 2	NO STATIONS EFFECTED	1:57	2:57	1:00	LINE FAULT
524	7-Apr-2022	MYSURU	66	HV2	ADDIHALLI_66	17:55	18:05	0:09	LOAD CURTAILMENT
525	7-Apr-2022	MYSURU	66	HV1	ARAKERE_66	12:00	12:09	0:09	TRANSFORMER FAULT
526	7-Apr-2022	MYSURU	66	BESAGARAHALLY-DUNDANAHALLY	NO STATIONS EFFECTED	15:00	15:13	0:12	LINE FAULT
527	7-Apr-2022	MYSURU	66	HV1	BGNAGARA_66	17:55	18:00	0:04	LOAD CURTAILMENT
528	7-Apr-2022	MYSURU	66	HV1	BGPURA_66	17:55	18:15	0:20	LOAD CURTAILMENT
529	7-Apr-2022	MYSURU	66	HV1	BILIKERE_66	17:57	18:05	0:08	LOAD CURTAILMENT
530	7-Apr-2022	MYSURU	66	HV3	DODDARAYAPET_66	17:56	18:10	0:13	LOAD CURTAILMENT
531	7-Apr-2022	MYSURU	66	HUNSUR - ILAWALA	GAVADAGERE_66	2:02	2:15	0:12	LINE FAULT
532	7-Apr-2022	MYSURU	66	HV2	KIKKERI_66	17:55	18:03	0:07	LOAD CURTAILMENT
533	7-Apr-2022	MYSURU	66	PERIYAPATNA-KAMPLAPURA	KAMPLAPURA_66	9:56	10:06	0:09	LINE FAULT
534	7-Apr-2022	MYSURU	66	HV3	PONNAMPET_66	8:05	16:27	8:21	LINE CLEAR AVAILED
535	7-Apr-2022	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	8:14	11:01	2:46	LINE CLEAR AVAILED
536	7-Apr-2022	MYSURU	66	SFCSIVA-PPCL	NO STATIONS EFFECTED	8:18	11:07	2:48	LINE CLEAR AVAILED
537	7-Apr-2022	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	9:00:00 AM (4/7/2022)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
538	7-Apr-2022	MYSURU	66	CHUNCHANKATTE-K R NAGARA	NO STATIONS EFFECTED	6:20:00 PM (6/4/2022)			LINE OPEN,LINE FAULT
539	7-Apr-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN, LINE CLEAR AVAILED
540	7-Apr-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN, LINE CLEAR AVAILED
541	7-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
542	7-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
543	7-Apr-2022	TUMKUR	400	TR2	JAGALURU_400	10:03	14:15	4:11	LINE CLEAR AVAILED
544	7-Apr-2022	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:39	14:29	0:49	LINE FAULT
545	7-Apr-2022	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	13:06	16:08	3:02	LINE CLEAR AVAILED
546	7-Apr-2022	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	13:38	14:29	0:50	LINE FAULT
547	7-Apr-2022	TUMKUR	220	TR-2	JAGALURU_400	10:02	14:15	4:12	LINE CLEAR AVAILED
548	7-Apr-2022	TUMKUR	220	TR-1	KBCROSS_220	13:12	14:20	1:08	MAIN SUPPLY FAILURE
549	7-Apr-2022	TUMKUR	220	TR-2	KBCROSS_220	13:12	14:20	1:08	MAIN SUPPLY FAILURE
550	7-Apr-2022	TUMKUR	220	TR-1	PAVAGADA_220	12:04	12:56	0:51	LINE CLEAR AVAILED
551	7-Apr-2022	TUMKUR	220	TR-2	PAVAGADA_220	10:45	11:45	1:00	LINE CLEAR AVAILED
552	7-Apr-2022	TUMKUR	110	TR-2	KBCROSS_220	13:12	14:20	1:08	MAIN SUPPLY FAILURE
553	7-Apr-2022	TUMKUR	110	TR-1	MAYASANDRA_110	7:27	7:44	0:17	TRANSFORMER FAULT
554	7-Apr-2022	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	18:56	19:01	0:04	LOAD CURTAILMENT
555	7-Apr-2022	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	18:56	19:04	0:08	LOAD CURTAILMENT
556	7-Apr-2022	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	22:25	22:37	0:12	LOAD CURTAILMENT
557	7-Apr-2022	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	12:43	12:56	0:13	HAND TRIPPED
558	7-Apr-2022	TUMKUR	66	TR-2	BENNEHALLI_66	17:38	17:45	0:07	TRANSFORMER FAULT
559	7-Apr-2022	TUMKUR	66	DAVANGERE SRS - HARIHARA	HARIHARA_66	16:43	16:45	0:02	HAND TRIPPED
560	7-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	3:03	3:11	0:08	LINE FAULT
561	7-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:56	11:10	0:14	LINE FAULT
562	7-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:17	15:23	3:05	LINE CLEAR AVAILED
563	7-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:08	16:13	0:04	LINE FAULT
564	7-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:43	16:45	0:01	HAND TRIPPED
565	7-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:45	18:56	0:10	LINE FAULT
566	7-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:44	20:57	0:12	LINE FAULT
567	7-Apr-2022	TUMKUR	66	KORATAGERE-MADHUGIRI2	KORATAGERE_66	13:23	13:28	0:05	MAIN SUPPLY FAILURE
568	7-Apr-2022	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE	KORATAGERE_66	13:23	13:28	0:04	HAND TRIPPED
569	7-Apr-2022	TUMKUR	66	MADHUGIRI 220kV- NITRAHALLI	NITRAHALLI_66	13:23	13:28	0:05	HAND TRIPPED
570	7-Apr-2022	TUMKUR	66	TR-2	MELEKOTE_66	11:29	13:14	1:44	LINE CLEAR AVAILED
571	7-Apr-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	7:00	16:55	9:54	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
572	7-Apr-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:43	18:53	0:10	LINE FAULT
573	7-Apr-2022	TUMKUR	66	TR-1	PANDRAHALLI_66	17:56	18:03	0:07	TRANSFORMER FAULT
574	7-Apr-2022	TUMKUR	66	TR-1	PAVAGADA_220	12:05	12:57	0:51	LINE CLEAR AVAIED
575	7-Apr-2022	TUMKUR	66	TR-2	PAVAGADA_220	10:45	11:45	1:00	LINE CLEAR AVAIED
576	7-Apr-2022	TUMKUR	66	TR-2	SASALUHALLA_66	9:20	10:15	0:55	LINE CLEAR AVAIED
577	7-Apr-2022	TUMKUR	66	TR-1	SIRA_220	18:08	18:24	0:16	TRANSFORMER FAULT
578	7-Apr-2022	TUMKUR	66	THALLAK 220kV- CHALLAKERE	CHALLAKERE_66, SANIKERE_66	1:27	1:53	0:26	LINE FAULT
579	8-Apr-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN, LINE CLEAR AVAIED
580	8-Apr-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13(03.03.2022)			LINE OPEN, LINE CLEAR AVAIED
581	8-Apr-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAIED
582	8-Apr-2022	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59(31.03.2022)			LINE OPEN, LINE CLEAR AVAIED
583	8-Apr-2022	BAGALKOT	220	CHIKKODI- BELGAUM1 (AQUES)	STATION NOT AFFECTED CHIKKODI_220	11:17(06.04.2022)			LINE OPEN, LINE CLEAR AVAIED
584	8-Apr-2022	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	22:45(07.04.2022)	33(08.04.2022)	9:48HRS	LINE CHARGED
585	8-Apr-2022	BAGALKOT	220	HUBLI-SIRSI 1	STATION NOT AFFECTED HUBLI_220	17:35(07.04.2022)	08 (08.04.2022)	25:33HRS	LINE CHARGED
586	8-Apr-2022	BAGALKOT	220	HUBLI-SIRSI 2	STATION NOT AFFECTED HUBLI_220	17:53(07.04.2022)	25 (08.04.2022)	20:32HRS	LINE CHARGED
587	8-Apr-2022	BAGALKOT	110	HUBLI-SIRSI(KALAGHATAGI)	STATION NOT AFFECTED HUBLI_220	18:58(07.04.2022)	53 (08.04.2022)	16:55HRS	LINE CHARGED
588	8-Apr-2022	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	22:06(07.04.2022)	33(08.04.2022)	10:27HRS	LINE CHARGED
589	8-Apr-2022	BAGALKOT	110	110//KV,HV2	AINAPUR_110	16:49	17:16	0:27	LOAD CURTAILMENT
590	8-Apr-2022	BAGALKOT	110	110//KV,HV1	ANKOLA_110	14:35	18:08	3:33	LINE CLEAR AVAIED
591	8-Apr-2022	BAGALKOT	110	MAHALINGAPUR- DHAVALSHWAR	(STATION NOT AFFECTED DHAVALSHWAR_110	10:00	19:13	9:13	LINE CLEAR AVAIED
592	8-Apr-2022	BAGALKOT	110	MAMADAPUR-DEVAR GENNUR	DEVAR GENNUR_110, SHIRABUR_110	20:25	20:45	0:20	LINE FAULT
593	8-Apr-2022	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	16:50	16:58	0:08	LOAD CURTAILMENT
594	8-Apr-2022	BAGALKOT	110	110/33KV,HV1	HANGAL_110 &PALA,BASAPUR_33	0:57	1:02	0:05	LOAD CURTAILMENT
595	8-Apr-2022	BAGALKOT	110	BADAMI(IDLE)-HIREHAL	HIREHAL_110	1:18	1:34	0:16	HAND TRIPPED
596	8-Apr-2022	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	16:37	16:41	0:04	TRANSFORMER FAULT
597	8-Apr-2022	BAGALKOT	110	(MAHALINGAPUR)NAVALAGI- JAMAKHANDI	JAMAKHANDI_110	15:12	18:40	3:28	LINE CLEAR AVAIED
598	8-Apr-2022	BAGALKOT	110	110/11KV,HV1	LAXMESHVAR_110	16:49	17:09	0:20	LOAD CURTAILMENT
599	8-Apr-2022	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	0:57	1:01	0:04	LOAD CURTAILMENT
600	8-Apr-2022	BAGALKOT	110	MUDEDEBIHAL-KNM SOLAR	STATION NOT AFFECTED MUDEDEBIHAL_110	17:07 (08.04.2022)			LINE OPEN, LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
601	8-Apr-2022	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	19:19	19:28	0:09	TRANSFORMER FAULT
602	8-Apr-2022	BAGALKOT	110	110/11KV, HV1	MAMADAPUR(B)_110	16:46	18:39	1:53	LINE CLEAR AVAILED
603	8-Apr-2022	BAGALKOT	110	110/11KV, HV2	GUTTAL_110	11:15	13:50	2:35	LINE CLEAR AVAILED
604	8-Apr-2022	BAGALKOT	220	AQUES- BELGAUM1	STATION NOT AFFECTED AQUES_220	11:07	17:07	6:00	NFBC ISSUED
605	8-Apr-2022	BAGALKOT	220	AQUES- CHIKKODI1	STATION NOT AFFECTED AQUES_220	18:10	18:47	0:37	HAND TRIPPED
606	8-Apr-2022	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED MAHALINGAPUR_220	10:00	18:05	8:05	LINE CLEAR AVAILED
607	8-Apr-2022	BAGALKOT	110	NARENDRA-BELUR2	NARENDRA_220	12:02	13:58	1:56	LINE CLEAR AVAILED
608	8-Apr-2022	BAGALKOT	220	BELGAUM-CHIKKODI1(AEQUS)	BELGAUM_220	0:57	1:19	0:22	LINE FAULT
609	8-Apr-2022	BAGALKOT	220	BELGAUM-CHIKKODI1(AEQUS)	BELGAUM_220	11:07	17:06	5:59	LINE CLEAR AVAILED
610	8-Apr-2022	BAGALKOT	110	VAJJRAMATTI- K D JAMBAGI	VAJJRAMATTI_220	13:56	17:21	3:25	LINE CLEAR AVAILED
611	8-Apr-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	17:30 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
612	8-Apr-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	9:40 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
613	8-Apr-2022	BAGALKOT	110	HALIYAL-KAWALWADA	STATION NOT AFFECTED HALIYAL_110	17:56(07.04.2022)			LINE OPEN,LINE FAULT
614	8-Apr-2022	BAGALKOT	110	BELGAUM220- UDAYMBAG	STATION NOT AFFECTED UDAYMBAG_110	17:53	18:18	0:25	MAIN SUPPLY FAILURE
615	8-Apr-2022	BAGALKOT	110	BELGAUM220- UCHAGOAN	UCHAGOAN_110	17:55	19:05	1:10	MAIN SUPPLY FAILURE
616	8-Apr-2022	BAGALKOT	110	AMBEWADI-NK-2(KAVALWADA)	AMBEWADI_220	15:07	15:25	0:18	HAND TRIPPED
617	8-Apr-2022	BAGALKOT	110	AMBEWADI-NK-2(KAVALWADA)	AMBEWADI_220	13:56	14:01	0:05	HAND TRIPPED
618	8-Apr-2022	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	6:49	7:06	0:17	MAIN SUPPLY FAILURE
619	8-Apr-2022	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	10:12	10:49	0:37	MAIN SUPPLY FAILURE
620	8-Apr-2022	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	NO STATION AFFECTED	12:58	13:28	0:30	LINE FAULT
621	8-Apr-2022	BENGALURU	220	HSR LAYOUT 220 - HOODY 400	NO STATION AFFECTED	12:58	13:43	0:45	LINE FAULT
622	8-Apr-2022	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 2	SHOBHA CITY	10:12	11:21	1:09	LINE FAULT
623	8-Apr-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:18	22:56	3:38	LINE FAULT
624	8-Apr-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	13:05	13:12	0:07	LINE CLEAR AVAILED
625	8-Apr-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	17:02	17:07	0:05	LINE CLEAR AVAILED
626	8-Apr-2022	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	12:50	13:05	0:15	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
627	8-Apr-2022	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA, WIPRO (EHT)	12:30	12:35	0:05	LINE CLEAR AVAILED
628	8-Apr-2022	BENGALURU	66	DOMMASANDRA - WIPRO(EHT)	WIPRO(EHT)	11:10	11:50	0:40	LINE CLEAR AVAILED
629	8-Apr-2022	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	16:10	16:15	0:05	LINE CLEAR AVAILED
630	8-Apr-2022	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 220	BAGEPALLI	15:40	15:55	0:15	LOAD CHANGE OVER
631	8-Apr-2022	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	16:25	17:00	0:35	LINE CLEAR AVAILED
632	8-Apr-2022	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	18:38	18:43	0:05	LINE CLEAR AVAILED
633	8-Apr-2022	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	16:15	18:53	2:38	LINE CLEAR AVAILED
634	8-Apr-2022	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	17:45	18:32	0:47	LINE CLEAR AVAILED
635	8-Apr-2022	BENGALURU	220	HV1	MITTEMARI 220	17:35	18:35	1:00	LINE CLEAR AVAILED
636	8-Apr-2022	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	18:15	18:25	0:10	LINE CLEAR AVAILED
637	8-Apr-2022	BENGALURU	66	HV2	TYAMAGONDLU	14:50	14:55	0:05	TRANSFORMER FAULT
638	8-Apr-2022	BENGALURU	66	HV1	SOMENAHALLI	11:57	12:42	0:45	LINE CLEAR AVAILED
639	8-Apr-2022	BENGALURU	66	HV2	SARJAPURA 220	14:54	15:23	0:28	LINE CLEAR AVAILED
640	8-Apr-2022	BENGALURU	66	HV1	MULABAGALU	18:01	18:46	0:45	TRANSFORMER FAULT
641	8-Apr-2022	BENGALURU	66	HV2	MANCHENAHALLI	8:40	8:52	0:12	LINE CLEAR AVAILED
642	8-Apr-2022	BENGALURU	66	HV2	MAASTHI	6:03	6:14	0:10	TRANSFORMER FAULT
643	8-Apr-2022	BENGALURU	66	HV2	DODDABELAVANGALA	17:41	18:03	0:21	LINE CLEAR AVAILED
644	8-Apr-2022	BENGALURU	220	HV3	CHINTAMANI 220	6:40	7:40	1:00	LINE CLEAR AVAILED
645	8-Apr-2022	BENGALURU	66	HV1	CB PURA URBAN	11:36	11:42	0:06	TRANSFORMER FAULT
646	8-Apr-2022	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	6:48	10:44	3:55	LINE FAULT
647	8-Apr-2022	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	17:52	18:32	0:40	LINE CLEAR AVAILED
648	8-Apr-2022	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	17:52	18:30	0:37	LINE CLEAR AVAILED
649	8-Apr-2022	BENGALURU	66	SOMENAHALLI - AFTL SLR (IPP)	NO STATION AFFECTED	17:52	18:30	0:38	LINE CLEAR AVAILED
650	8-Apr-2022	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	13:03	13:12	0:09	LINE FAULT
651	8-Apr-2022	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADOSANAHALLI	18:50	18:58	0:08	LINE FAULT
652	8-Apr-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:20	10:25	0:04	LINE CLEAR AVAILED
653	8-Apr-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:48	10:49	0:01	LINE FAULT
654	8-Apr-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:45	15:49	0:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
655	8-Apr-2022	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	22:07	22:14	0:06	LINE FAULT
656	8-Apr-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	10:27(07.04.2022)	09:59(08.04.2022)	33:32HRS	LINE CHARGED
657	8-Apr-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN ,TRANSFORMER FAULT
658	8-Apr-2022	GULBARGA	220	MALLAT-RTPS	MALLAT_220	3:21	3:40	0:19	LINE FAULT
659	8-Apr-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
660	8-Apr-2022	GULBARGA	110	HV3	YELBURGA_110	0:57	1:26	0:29	LOAD CURTAILMENT
661	8-Apr-2022	GULBARGA	110	HV4	YELBURGA_110	0:57	1:26	0:29	LOAD CURTAILMENT
662	8-Apr-2022	GULBARGA	110	HV4	YELBURGA_110	16:50	17:11	0:21	LOAD CURTAILMENT
663	8-Apr-2022	GULBARGA	110	HV4	KOLHAR_110	9:20	9:40	0:20	TRANSFORMER FAULT
664	8-Apr-2022	GULBARGA	110	HV4	KOLHAR_110	10:25	10:35	0:10	TRANSFORMER FAULT
665	8-Apr-2022	GULBARGA	110	HV2	GHATTARGA_110	16:45	17:25	0:40	LINE CLEAR AVAILED
666	8-Apr-2022	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI	4:10	4:20	0:10	MAIN SUPPLY FAILURE
667	8-Apr-2022	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI	11:45	11:55	0:10	MAIN SUPPLY FAILURE
668	8-Apr-2022	GULBARGA	110	HV1	PD_HALLI_110	0:57	1:02	0:05	LOAD CURTAILMENT
669	8-Apr-2022	GULBARGA	110	HV2	CHINCHOLI_110	0:56	1:26	0:30	LOAD CURTAILMENT
670	8-Apr-2022	GULBARGA	110	HV1	MAHAGAON_110	0:55	1:20	0:25	LOAD CURTAILMENT
671	8-Apr-2022	GULBARGA	110	HV1	MAHAGAON_110	16:50	17:05	0:15	LOAD CURTAILMENT
672	8-Apr-2022	GULBARGA	110	HV1	KURKUNTA_110	1:00	1:20	0:20	LOAD CURTAILMENT
673	8-Apr-2022	GULBARGA	110	HV1	KURKUNTA_110	16:50	17:10	0:20	LOAD CURTAILMENT
674	8-Apr-2022	GULBARGA	110	HV1	GABBUR_110	16:50	16:55	0:05	LOAD CURTAILMENT
675	8-Apr-2022	GULBARGA	110	GABBUR-BPSSOLAR_IPP	GABBUR_110	18:25	19:05	0:40	LINE CLEAR AVAILED
676	8-Apr-2022	GULBARGA	110	HV1,HV2	MYLAR_110	11:10	11:50	0:40	LINE CLEAR AVAILED
677	8-Apr-2022	GULBARGA	110	HV3	TEKKALKOTE_110	1:25	1:40	0:15	TRANSFORMER FAULT
678	8-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:12	5:18	0:06	LINE FAULT
679	8-Apr-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	11:55	13:20	1:25	LINE FAULT
680	8-Apr-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	1:45	1:53	0:08	LINE FAULT
681	8-Apr-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	4:38	4:45	0:07	LINE FAULT
682	8-Apr-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	5:15	5:25	0:10	LINE FAULT
683	8-Apr-2022	GULBARGA	110	SHAHAPUR-YADGIR	SAIDAPUR_110,KHANAPUR_1 10,YADGIR_110	4:08	4:17	0:09	LINE FAULT
684	8-Apr-2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSA GI_110	4:09	4:19	0:10	LINE FAULT
685	8-Apr-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_1 10,WADAGERA_110,SANNATH I_IPP,COREGREENSUGARS_IPP	9:24 (27.03.2022)			LINE OPEN, LINE CLEAR AVAILED
686	8-Apr-2022	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	10:49	17:05	6:16	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
687	8-Apr-2022	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	16:20	16:54	0:34	LINE FAULT
688	8-Apr-2022	GULBARGA	110	LV1	KAPNOOR_220	10:20	16:17	5:57	LINE CLEAR AVAILED
689	8-Apr-2022	GULBARGA	110	HV2	HATTI_110	16:48	16:50	0:02	LOAD CURTAILMENT
690	8-Apr-2022	GULBARGA	110	HV2	JEWARGI_110	0:57	1:04	0:07	LOAD CURTAILMENT
691	8-Apr-2022	GULBARGA	110	HV1	KOLHAR_110	9:20	9:40	0:20	TRANSFORMER FAULT
692	8-Apr-2022	GULBARGA	110	HV1	KOLHAR_110	10:25	10:35	0:10	TRANSFORMER FAULT
693	8-Apr-2022	GULBARGA	110	KOPPAL-HALWARTH1&2	KOPPAL_110	9:29	13:12	3:43	NFBC ISSUED
694	8-Apr-2022	GULBARGA	66	HV1	TELAGI_66	11:20	11:40	0:20	LINE CLEAR AVAILED
695	8-Apr-2022	GULBARGA	66	HV1	KUDLIGI_220	12:45	12:55	0:10	TRANSFORMER FAULT
696	8-Apr-2022	GULBARGA	66	HV1	KUDLIGI_220	13:45	13:55	0:10	TRANSFORMER FAULT
697	8-Apr-2022	GULBARGA	66	HV1	KUDLIGI_220	15:05	15:20	0:15	TRANSFORMER FAULT
698	8-Apr-2022	HASSAN	220	VARAHI-SHIMOGA1	gen_varahi	7:15(07.04.2022)	5:16 (8.04.2022)	33:00 hrs	LINE CHARGED
699	8-Apr-2022	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	7:15(07.04.2022)	5:16 (8.04.2022)	33:00 hrs	LINE CHARGED
700	8-Apr-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN, LINE CLEAR AVAILED
701	8-Apr-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	10:54 (24.03.2022)			LINE OPEN, LINE CLEAR AVAILED
702	8-Apr-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN,LINE FAULT
703	8-Apr-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
704	8-Apr-2022	HASSAN	220	VARAHI-SHIMOGA2	VARAHI_GEN	18:47(03.04.2022)			LINE OPEN,LINE FAULT
705	8-Apr-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
706	8-Apr-2022	HASSAN	400	UPCL-HASSAN2	gen_upcl	7:59	20:23	12:24	LINE CLEAR AVAILED
707	8-Apr-2022	HASSAN	220	KEMAR-Varahi1	KEMAR_220	12:16	15:37	3:21	LINE CLEAR AVAILED
708	8-Apr-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:28	13:58	3:30	NFBC ISSUED
709	8-Apr-2022	HASSAN	220	VARAHI-KEMAR1	gen_varahi	12:16	15:38	3:22	LINE CLEAR AVAILED
710	8-Apr-2022	HASSAN	110	MRSSHM-MPM	MRSMSG_220	9:21	12:31	3:10	LINE CLEAR AVAILED
711	8-Apr-2022	HASSAN	110	HV2	MSEZ_220	10:11	14:52	4:41	LINE CLEAR AVAILED
712	8-Apr-2022	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	9:49	14:27	4:38	LINE CLEAR AVAILED
713	8-Apr-2022	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	9:49	14:27	4:38	LINE CLEAR AVAILED
714	8-Apr-2022	HASSAN	110	HV1	BARANGI_110	11:10	14:00	2:50	LINE CLEAR AVAILED
715	8-Apr-2022	HASSAN	110	HV2	GERUMARA_110	0:55	1:05	0:10	TRANSFORMER FAULT
716	8-Apr-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	10:27	13:59	3:32	LINE CLEAR AVAILED
717	8-Apr-2022	HASSAN	110	NANDIKU-ISTRIL	NANDIKUR_110	10:45	12:45	2:00	LINE CLEAR AVAILED
718	8-Apr-2022	HASSAN	110	HV1	NERALEKERE_110	16:50	17:42	0:52	TRANSFORMER FAULT
719	8-Apr-2022	HASSAN	110	NERALA-TEREKERE	NERALEKERE_110	11:52	13:10	1:18	LINE FAULT
720	8-Apr-2022	HASSAN	110	HV1	SINGATGERE_110	10:20	17:50	7:30	LINE CLEAR AVAILED
721	8-Apr-2022	HASSAN	66	HV1	DODDAHAILI_66	13:15	14:10	0:55	MAIN SUPPLY FAILURE
722	8-Apr-2022	HASSAN	66	DODDAKA-HNPURA	DODDAKADNUR_66	13:10	14:05	0:55	MAIN SUPPLY FAILURE
723	8-Apr-2022	HASSAN	66	HV1	DODDAKADNUR_66	13:10	14:05	0:55	MAIN SUPPLY FAILURE
724	8-Apr-2022	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADNUR_66	13:10	14:05	0:55	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
725	8-Apr-2022	HASSAN	66	HV1	HALLIMYSORE_66	0:10	1:56	1:46	LOAD CURTAILMENT
726	8-Apr-2022	HASSAN	66	HV1	HANGARAHALLI_66	0:10	1:56	1:46	LOAD CURTAILMENT
727	8-Apr-2022	HASSAN	66	MYSOR1	HOLENARASIPURA_220	13:15	14:05	0:50	LINE CLEAR AVAILED
728	8-Apr-2022	HASSAN	66	MYSOR2	HOLENARASIPURA_220	13:15	14:05	0:50	LINE CLEAR AVAILED
729	8-Apr-2022	HASSAN	66	HV1	HOLALUR_66	6:10	6:50	0:40	TRANSFORMER FAULT
730	8-Apr-2022	HASSAN	66	HV1	MOSALEHOSALLI_66	10:40	13:00	2:20	TRANSFORMER FAULT
731	8-Apr-2022	HASSAN	66	HV1 CB	NAGARTHI_66	13:15	14:10	0:55	MAIN SUPPLY FAILURE
732	8-Apr-2022	HASSAN	66	L1 CB	NAGARTHI_66	13:15	14:10	0:55	MAIN SUPPLY FAILURE
733	8-Apr-2022	HASSAN	66	L2 CB	NAGARTHI_66	13:23	13:55	0:32	NFBC ISSUED
734	8-Apr-2022	HASSAN	66	HV1	RAMESHWARNAGAR_66	10:48	11:35	0:47	LINE CLEAR AVAILED
735	8-Apr-2022	MYSURU	66	HV2	AKKIHBBAL_66	0:56	1:06	0:10	LOAD CURTAILMENT
736	8-Apr-2022	MYSURU	66	BGNAGAR-HIRISAVE	NO STATIONS EFFECTED	18:11	18:21	0:09	LINE FAULT
737	8-Apr-2022	MYSURU	66	HV2	BGNAGAR_66	10:10	17:52	7:41	LINE CLEAR AVAILED
738	8-Apr-2022	MYSURU	66	HV1	BOOKANKERE_66	13:43	15:31	1:47	LINE CLEAR AVAILED
739	8-Apr-2022	MYSURU	66	HV2	BOOKANKERE_66	0:56	1:05	0:09	LOAD CURTAILMENT
740	8-Apr-2022	MYSURU	66	HV2	BOOKANKERE_66	10:41	13:43	3:02	LINE CLEAR AVAILED
741	8-Apr-2022	MYSURU	220	CRNAGARA-BEGUR 2	NO STATIONS EFFECTED	1:57	2:57	1:00	LINE FAULT
742	8-Apr-2022	MYSURU	66	CRNAGARA-KABBALLY	NO STATIONS EFFECTED	19:34	19:43	0:09	LINE FAULT
743	8-Apr-2022	MYSURU	66	CRNAGARA-GUNDLUPETE	NO STATIONS EFFECTED	19:34	19:46	0:12	LINE FAULT
744	8-Apr-2022	MYSURU	66	DEVNUR(N'GUD)-KDKOLA	NO STATIONS EFFECTED	14:12	14:14	0:01	HAND TRIPPED
745	8-Apr-2022	MYSURU	66	HV1	DODDINDUVADI_66	0:55	1:06	0:10	LOAD CURTAILMENT
746	8-Apr-2022	MYSURU	66	HV2	GVGUDI_66	0:55	1:06	0:10	LOAD CURTAILMENT
747	8-Apr-2022	MYSURU	66	HEBBANI-MEGHALAPURA	BG PURA_66 CHIDRAWALLI_66 THUMBLA_66 GARGESHWARI_66 VYASARAJAPURA_66	11:50	11:56	0:06	HAND TRIPPED
748	8-Apr-2022	MYSURU	66	HEBBANI-MEGHALAPURA	BG PURA_66 CHIDRAWALLI_66 THUMBLA_66 GARGESHWARI_66 VYASARAJAPURA_66	19:37	19:54	0:17	LINE FAULT
749	8-Apr-2022	MYSURU	66	HEBBANI-VADKEPURA	VADKEPURA_66 KIRUGAVALU_66 MALIYUR_66	19:37	19:54	0:17	LINE FAULT
750	8-Apr-2022	MYSURU	66	HV2	HDKOTE_66	0:57	3:45	2:47	LOAD CURTAILMENT
751	8-Apr-2022	MYSURU	66	HV2	HOSURGATE-66	11:35	12:35	1:00	LINE CLEAR AVAILED
752	8-Apr-2022	MYSURU	66	HOOTGALLY-FTS2	NO STATIONS EFFECTED	11:04	13:04	2:00	LINE FAULT
753	8-Apr-2022	MYSURU	66	HV1	JAYAPURA_66	11:40	12:47	1:07	LINE CLEAR AVAILED
754	8-Apr-2022	MYSURU	66	KADAKOLA-NANJANGUD	NO STATIONS EFFECTED	6:26	6:30	0:04	LINE FAULT
755	8-Apr-2022	MYSURU	66	KADAKOLA-SARGUR2	HURA_66 DOORA_66 HULLALI_66	14:25	14:32	0:06	HAND TRIPPED
756	8-Apr-2022	MYSURU	66	KADAKOLA-SARGUR1	JAYAPURA_66 HAMPAPURA(K)_66	14:25	14:32	0:06	HAND TRIPPED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
757	8-Apr-2022	MYSURU	66	KIADBMANDYA-TUMBEKERE	THUMBKERE_66	10:45	12:10	1:25	LINE CLEAR AVAILED
758	8-Apr-2022	MYSURU	66	KIADBMANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	9:05	12:45	3:40	LINE CLEAR AVAILED
759	8-Apr-2022	MYSURU	66	HV2	KIKKERI_66	16:04	16:19	0:15	LINE CLEAR AVAILED
760	8-Apr-2022	MYSURU	66	HV2	KMDODDI_66	0:56	1:05	0:09	LOAD CURTAILMENT
761	8-Apr-2022	MYSURU	66	KMDODDI-TKHALI	NO STATIONS EFFECTED	19:18	22:58	3:39	LINE FAULT
762	8-Apr-2022	MYSURU	66	HV2	KOLLEGALA_66	0:56	1:00	0:03	LOAD CURTAILMENT
763	8-Apr-2022	MYSURU	66	KUSHALNAGARA-MYSORE1	MIRLE_66 BHERYA_66 BILIKERE_66 GV GUDI_66 KR NAGARA_66	9:56	10:06	0:10	LINE FAULT
764	8-Apr-2022	MYSURU	66	KUSHALNAGARA-MYSORE1	MIRLE_66 BHERYA_66 BILIKERE_66 GV GUDI_66 KR NAGARA_66	15:37	15:44	0:06	LINE FAULT
765	8-Apr-2022	MYSURU	66	MADHUVANAHALLI- MAMBALLY	NO STATIONS EFFECTED	5:55	6:02	0:06	LINE FAULT
766	8-Apr-2022	MYSURU	66	MADHUVANAHALLI- LOKKANAHALLY	LOKKANAHALLY_66 PG PALYA_66	2:25	2:33	0:07	LINE FAULT
767	8-Apr-2022	MYSURU	66	MADHUVANAHALLI- LOKKANAHALLY	LOKKANAHALLY_66 PG PALYA_66	23:00	23:07	0:06	LINE FAULT
768	8-Apr-2022	MYSURU	66	HV1	MANDGERE_66	13:15	14:00	0:45	HAND TRIPPED
769	8-Apr-2022	MYSURU	66	HV5	SFCSIVA_66	6:25	11:57	5:32	LINE CLEAR AVAILED
770	8-Apr-2022	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	8:25	11:46	3:21	LINE CLEAR AVAILED
771	8-Apr-2022	MYSURU	66	HV2	SRIRANGAPATNA_66	10:45	11:40	0:55	LINE CLEAR AVAILED
772	8-Apr-2022	MYSURU	66	HV1	TERAKANAMBI_66	10:07	12:17	2:10	LINE CLEAR AVAILED
773	8-Apr-2022	MYSURU	220	TUBINKKERE-HUYOGNAHALLI	NO STATIONS EFFECTED	16:37	17:05	0:28	LINE FAULT
774	8-Apr-2022	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	9:00:00 AM (4/7/2022)			LINE OPEN, LINE CLEAR AVAILED
775	8-Apr-2022	MYSURU	66	CHUNCHANKATTE-K R NAGARA	NO STATIONS EFFECTED	6:20:00 PM (6/4/2022)	5:00 (8.4.2)	45:55HRS	LINE CHARGED
776	8-Apr-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN, LINE CLEAR AVAILED
777	8-Apr-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN, LINE CLEAR AVAILED
778	8-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
779	8-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
780	8-Apr-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	5:42	5:55	0:13	LINE FAULT
781	8-Apr-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	9:50	9:55	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
782	8-Apr-2022	TUMKUR	110	TR-1	SAMPIGE_110	17:02	17:08	0:06	HAND TRIPPED
783	8-Apr-2022	TUMKUR	66	BHARAMAGIRI66-SRS 220KV HIRIYUR	BHARAMAGIRI_66	1:23	1:38	0:14	MAIN SUPPLY FAILURE
784	8-Apr-2022	TUMKUR	66	TR-2	BHARAMAGIRI_66	9:25	9:50	0:25	TRANSFORMER FAULT
785	8-Apr-2022	TUMKUR	66	BHARAMAGIRI66-MATHOD66	BHARAMAGIRI_66	9:25	9:35	0:10	LINE FAULT
786	8-Apr-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	23:18	23:39	0:21	TRANSFORMER FAULT
787	8-Apr-2022	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:39	13:05	0:25	LINE CLEAR AVAILED
788	8-Apr-2022	TUMKUR	66	TR-2	CHIKKABANAGERE_66	13:10	13:28	0:17	LINE CLEAR AVAILED
789	8-Apr-2022	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	11:39	11:56	0:16	LINE FAULT
790	8-Apr-2022	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	12:20	15:05	2:44	LINE FAULT
791	8-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	4:38	4:46	0:08	LINE FAULT
792	8-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:09	8:14	0:04	LINE FAULT
793	8-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:33	20:43	0:09	LINE FAULT
794	8-Apr-2022	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	15:45	17:20	1:35	MAIN SUPPLY FAILURE
795	8-Apr-2022	TUMKUR	66	KORATAGERE66-MADHUGIRI	KORATAGERE_66	5:40	6:07	0:27	LINE FAULT
796	8-Apr-2022	TUMKUR	66	TR-1	SAVALANGA_66	12:49	15:50	3:01	LINE CLEAR AVAILED
797	8-Apr-2022	TUMKUR	66	TR-1	SAVALANGA_66	16:28	17:13	0:44	LINE CLEAR AVAILED
798	8-Apr-2022	TUMKUR	66	PD KOTE66-AZURE POWER IPP_66	AZURE POWER_IPP_66	15:28	15:43	0:14	MAIN SUPPLY FAILURE
799	8-Apr-2022	TUMKUR	66	PD KOTE 66-CLEAR SOLAR IPP_66	CLEAR SOLAR_IPP_66	15:28	15:43	0:14	MAIN SUPPLY FAILURE
800	8-Apr-2022	TUMKUR	66	PD KOTE66-SOLITAIRE_IPP_66	SOLITAIRE_IPP_66	11:58	12:06	0:08	MAIN SUPPLY FAILURE
801	8-Apr-2022	TUMKUR	66	PD KOTE66-SOLITAIRE_IPP_66	SOLITAIRE_IPP_66	15:28	15:44	0:15	MAIN SUPPLY FAILURE
802	8-Apr-2022	TUMKUR	66	TR-2	PD KOTE_66	11:58	12:06	0:08	MAIN SUPPLY FAILURE
803	8-Apr-2022	TUMKUR	66	TR-2	PAVAGADA-66	9:42	9:46	0:03	TRANSFORMER FAULT
804	9-Apr-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
805	9-Apr-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13(03.03.2022)			LINE OPEN, LINE CLEAR AVAILED
806	9-Apr-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
807	9-Apr-2022	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59(31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
808	9-Apr-2022	BAGALKOT	220	CHIKKODI- BELGAUM1 (AQUES)	STATION NOT AFFECTED CHIKKODI_220	11:17(06.04.2022)	50 (09.04.2022)	76:33HRS	LINE CHARGED
809	9-Apr-2022	BAGALKOT	110	MUDDEBIHAL-KNM SOLAR	STATION NOT AFFECTED MUDDEBIHAL_110	17:07 (08.04.2022)	12 (09.04.2022)	8:05HRS	LINE CHARGED
810	9-Apr-2022	BAGALKOT	220	BAGEWADI-ATRIA 1&2	BAGEWADI_220	11:38	18:33	6:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
811	9-Apr-2022	BAGALKOT	110	DAMBAL-ENERCON(EILS 1)	DAMBAL_110	1:33	13:56	12:23	LINE FAULT
812	9-Apr-2022	BAGALKOT	110	110/11KV,HV1	KUDACHI_220	19:17	19:21	0:04	TRANSFORMER FAULT
813	9-Apr-2022	BAGALKOT	110	KABBUR-SULTANPUR	SULTANPUR_110	9:00	15:25	6:25	LINE CLEAR AVAILED
814	9-Apr-2022	BAGALKOT	110	SAVALAGI- AIGALI	STATION NOT AFFECTED SAVALAGI_110	8:01	19:18	11:17	LINE CLEAR AVAILED
815	9-Apr-2022	BAGALKOT	110	MUDEDEBIHAL-KNM SOLAR	STATION NOT AFFECTED MUDEDEBIHAL_110	6:27	7:25	0:58	LINE CLEAR AVAILED
816	9-Apr-2022	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	8:00	9:21	1:21	LINE CLEAR AVAILED
817	9-Apr-2022	BAGALKOT	110	MUNDARGI- VIJAYA NAGAR SUGARS	MUNDARGI_110	8:52	9:10	0:18	LINE FAULT
818	9-Apr-2022	BAGALKOT	110	MAMADAPUR(B)- TODALBAGI	MAMADAPUR(B)_110	9:32	9:48	0:16	HAND TRIPPED
819	9-Apr-2022	BAGALKOT	110	MALGHAN(B)- BASAVA SUGARS	MALGHAN(B)_110	2:12	2:17	0:05	LINE FAULT
820	9-Apr-2022	BAGALKOT	110	YLWD-F2 Cbreaker( SAVALAGI)	STATION NOT AFFECTED YELLAMANAWADI_110	8:02	19:13	11:11	NFBC ISSUED
821	9-Apr-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDYELLAMANAWADI_1 10	16:57	16:59	0:02	TRANSFORMER FAULT
822	9-Apr-2022	BAGALKOT	110	110/11KV,HV1	UCHAGOAN_110	20:44	21:16	0:32	LINE CLEAR AVAILED
823	9-Apr-2022	BAGALKOT	220	NARENDRA-BELGAUM2	NARENDRA_220	14:33	17:12	2:39	LINE FAULT
824	9-Apr-2022	BAGALKOT	220	NARENDRA- (KANABARGI)BELGAUM1	NARENDRA_220	14:44	17:13	2:29	LINE FAULT
825	9-Apr-2022	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34(09.04.2022)			LINE OPEN,LINE FAULT
826	9-Apr-2022	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34(09.04.2022)			LINE OPEN,LINE FAULT
827	9-Apr-2022	BAGALKOT	220	BELGAUM- KANABARGI(NARENDRA1)	BELGAUM_220	14:42	17:12	2:30	LINE FAULT
828	9-Apr-2022	BAGALKOT	220	BELGAUM- KANABARGI(NARENDRA2)	BELGAUM_220	14:32	17:12	2:40	LINE FAULT
829	9-Apr-2022	BAGALKOT	220	BELGAUM-CHIKKODI1(AEQUS)	STATION NOT AFFECTED BELGAUM_220	17:26(09.04.2022)			LINE OPEN, LINE CLEAR AVAILED
830	9-Apr-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	17:30 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
831	9-Apr-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	9:40 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
832	9-Apr-2022	BAGALKOT	110	HALIYAL-KAWALWADA	STATION NOT AFFECTED HALIYAL_110	17:56(07.04.2022)			LINE OPEN,LINE FAULT
833	9-Apr-2022	BAGALKOT	110	MK HUBLI220-BIDI	BIDI_110	15:10	16:33	1:23	LINE CLEAR AVAILED
834	9-Apr-2022	BAGALKOT	110	MK HUBLI220-BIDI	BIDI_110	23:32	23:58	0:26	LINE FAULT
835	9-Apr-2022	BENGALURU	66	HV2	AMAR JYOTHI	7:20	8:38	1:18	LINE CLEAR AVAILED
836	9-Apr-2022	BENGALURU	66	HV2	AMAR JYOTHI	15:52	15:58	0:06	LOAD CHANGE OVER
837	9-Apr-2022	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	11:20	11:25	0:05	LOAD CHANGE OVER
838	9-Apr-2022	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	13:21	13:25	0:04	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
839	9-Apr-2022	BENGALURU	66	ISRO LAYOUT - SARAKKI	NO STATION AFFECTED	7:27	11:12	3:45	LINE FAULT
840	9-Apr-2022	BENGALURU	66	HV1	NGEF	0:00	1:32	1:32	TRANSFORMER FAULT
841	9-Apr-2022	BENGALURU	66	HV2	NGEF	0:10	0:47	0:37	LINE CLEAR AVOIDED
842	9-Apr-2022	BENGALURU	66	HV2	VIJAYANAGARA	11:44	11:52	0:08	LOAD CHANGE OVER
843	9-Apr-2022	BENGALURU	66	HV1	VIJAYANAGARA	11:50	11:52	0:02	LOAD CHANGE OVER
844	9-Apr-2022	BENGALURU	66	HV2	VIJAYANAGARA	13:20	13:44	0:24	LOAD CHANGE OVER
845	9-Apr-2022	BENGALURU	66	HV1	VIJAYANAGARA	13:20	13:44	0:24	LOAD CHANGE OVER
846	9-Apr-2022	BENGALURU	220	HV1	YARANDANAHALLI 220	7:31	8:20	0:49	TRANSFORMER FAULT
847	9-Apr-2022	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	7:31	8:30	0:59	LINE FAULT
848	9-Apr-2022	BENGALURU	66	YARANDANAHALLI 220 - JIGANI	KUMBARANAHALLI	9:45	12:30	2:45	LINE CLEAR AVOIDED
849	9-Apr-2022	BENGALURU	66	HV3	NELAMANGALA 66	15:40	17:50	2:10	TRANSFORMER FAULT
850	9-Apr-2022	BENGALURU	66	BAIRPATNA - CHANNAPATNA 220	BAIRPATNA(SANKALGERE)	19:55	20:14	0:19	MAIN SUPPLY FAILURE
851	9-Apr-2022	BENGALURU	66	HV2	GUNDAMGERE	15:01	15:08	0:06	TRANSFORMER FAULT
852	9-Apr-2022	BENGALURU	220	HV1	DB PURA 220	18:09	18:48	0:39	TRANSFORMER FAULT
853	9-Apr-2022	BENGALURU	220	LV1	DB PURA 220	18:09	18:48	0:39	TRANSFORMER FAULT
854	9-Apr-2022	BENGALURU	66	HV2	ATTIBELE	10:40	13:06	2:26	TRANSFORMER FAULT
855	9-Apr-2022	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	6:31	6:55	0:23	LINE FAULT
856	9-Apr-2022	BENGALURU	66	HV2	ATTIBELE	10:10	10:15	0:05	LOAD CHANGE OVER
857	9-Apr-2022	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	14:52	14:59	0:07	LINE FAULT
858	9-Apr-2022	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	19:22	19:47	0:24	LOAD CURTAILMENT
859	9-Apr-2022	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	19:22	20:01	0:38	LOAD CURTAILMENT
860	9-Apr-2022	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR	19:47	20:01	0:14	LOAD CURTAILMENT
861	9-Apr-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	18:09	18:50	0:41	MAIN SUPPLY FAILURE
862	9-Apr-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	20:11	21:06	0:54	MAIN SUPPLY FAILURE
863	9-Apr-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	18:26	19:13	0:47	LINE FAULT
864	9-Apr-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	18:09	18:50	0:41	MAIN SUPPLY FAILURE
865	9-Apr-2022	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	18:09	18:51	0:42	LINE CLEAR AVOIDED
866	9-Apr-2022	BENGALURU	66	CHINTAMANI 220 - SRINIVASAPURA	G KODIHALLI, SRINIVASAPURA, YELDUR	19:24	19:40	0:15	LOAD CURTAILMENT
867	9-Apr-2022	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, BIEC	11:59	12:13	0:14	LINE CLEAR AVOIDED
868	9-Apr-2022	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:52	14:16	0:24	LINE FAULT
869	9-Apr-2022	GULBARGA	400	BTPSG-GUTTUR	GUTTUR_400	09:02(09.04.2022)			LINE OPEN, LINE CLEAR AVOIDED
870	9-Apr-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN ,TRANSFORMER FAULT
871	9-Apr-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	18:50 (9.04.2022)			LINE OPEN,LINE FAULT
872	9-Apr-2022	GULBARGA	220	HV2	RAICHUR_220	15:16	15:46	0:30	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
873	9-Apr-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
874	9-Apr-2022	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI	5:40	5:45	0:05	MAIN SUPPLY FAILURE
875	9-Apr-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVAT HI_110,DR NAGAR_110,KARATAGI_110	18:59	19:11	0:12	LINE FAULT
876	9-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:38	5:45	0:07	LINE FAULT
877	9-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	13:05	13:11	0:06	LINE FAULT
878	9-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	13:06	13:36	0:30	LINE FAULT
879	9-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	13:36	16:33	2:57	LINE CLEAR AVAILED
880	9-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	14:02	14:08	0:06	LINE FAULT
881	9-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	15:16	15:27	0:11	LINE FAULT
882	9-Apr-2022	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHIKKASUGUR_11 0,SHAKTHINAGA_110	15:16	16:12	0:56	LINE FAULT
883	9-Apr-2022	GULBARGA	110	LV1	RAICHUR_220	15:16	15:45	0:29	TRANSFORMER FAULT
884	9-Apr-2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSA GI_110	5:43	5:50	0:07	LINE FAULT
885	9-Apr-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_1 10,WADAGERA_110,SANNATH I_IPP,COREGREENSUGARS_IPP	9:24 (27.03.2022)			LINE OPEN, LINE CLEAR AVAILED
886	9-Apr-2022	GULBARGA	110	LV1	KAPNOOR_220	9:10	15:53	6:43	LINE CLEAR AVAILED
887	9-Apr-2022	GULBARGA	110	KAPNOOR-DUBALGUNDI	DUBALGUNDI_110	17:56	18:28	0:32	LINE FAULT
888	9-Apr-2022	GULBARGA	110	KAPNOOR-DUBALGUNDI	DUBALGUNDI_110	19:26	19:40	0:14	LINE FAULT
889	9-Apr-2022	GULBARGA	110	CHOWDAPUR-AFZALPUR	AFZALPUR_110	19:30	19:50	0:20	LINE FAULT
890	9-Apr-2022	GULBARGA	110	HV1	GOOGAL_110	13:55	14:00	0:05	TRANSFORMER FAULT
891	9-Apr-2022	GULBARGA	110	HV1	GOOGAL_110	17:40	17:45	0:05	TRANSFORMER FAULT
892	9-Apr-2022	GULBARGA	66	KUDLIGI-BANVIKAL	BANVIKAL_66	15:50	16:00	0:10	LINE FAULT
893	9-Apr-2022	GULBARGA	66	HV2	KOGALI_66	12:10	12:30	0:20	LINE CLEAR AVAILED
894	9-Apr-2022	GULBARGA	66	HOSAHALLI- SML_WIND&AWADASOLAR_IP P	HOSAHALLI_66	18:55	19:05	0:10	LINE FAULT
895	9-Apr-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN,LINE FAULT
896	9-Apr-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	10:54 (24.03.2022)			LINE OPEN, LINE CLEAR AVAILED
897	9-Apr-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN,LINE FAULT
898	9-Apr-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
899	9-Apr-2022	HASSAN	220	VARAHI-SHIMOGA2	VARAHI_GEN	18:47(03.04.2022)			LINE OPEN,LINE FAULT
900	9-Apr-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
901	9-Apr-2022	HASSAN	220	KEMAR-Varahi1	KEMAR_220	19:03(09.04.2022)			LINE OPEN,LINE FAULT
902	9-Apr-2022	HASSAN	66	HV2	BALEHONNUR_66	9:24 (9.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
903	9-Apr-2022	HASSAN	220	VARAHI-KEMAR1	gen_varahi	19:03(09.04.2022)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
904	9-Apr-2022	HASSAN	220	VARAHI-SHMG3	gen_varahi	7:47 (9.04.2022)			LINE OPEN, LINE CLEAR AVAILED
905	9-Apr-2022	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	7:46 (9.04.2022)			LINE OPEN, LINE CLEAR AVAILED
906	9-Apr-2022	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	19:02 (9.04.2022)			MAIN SUPPLY FAILURE
907	9-Apr-2022	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	23:48 (9.04.2022)			LINE OPEN, LINE FAULT
908	9-Apr-2022	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	17:30 (9.04.2022)			LINE OPEN, LINE FAULT
909	9-Apr-2022	HASSAN	400	UPCL-HASSAN1	gen_upcl	17:28	22:27	4:59	LINE FAULT
910	9-Apr-2022	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	16:15	20:33	4:18	LINE FAULT
911	9-Apr-2022	HASSAN	220	KADUR-SHIMOGA	KADUR_220	16:22	17:45	1:23	LINE FAULT
912	9-Apr-2022	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	19:09	19:51	0:42	LINE FAULT
913	9-Apr-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	19:03	19:45	0:42	LINE FAULT
914	9-Apr-2022	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	19:02	19:55	0:53	LINE FAULT
915	9-Apr-2022	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	16:48	18:59	2:11	LINE FAULT
916	9-Apr-2022	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	19:48	21:21	1:33	LINE CLEAR AVAILED
917	9-Apr-2022	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	16:15	20:34	4:19	LINE FAULT
918	9-Apr-2022	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	16:49	22:40	5:51	LINE FAULT
919	9-Apr-2022	HASSAN	220	SHARAVATY-SHIRALKOPPA	sharavathy_gen	16:33	17:03	0:30	LINE FAULT
920	9-Apr-2022	HASSAN	220	HV1	SHRIRALKOPPA_220	16:35	17:04	0:29	TRANSFORMER FAULT
921	9-Apr-2022	HASSAN	220	HV2	SHRIRALKOPPA_220	16:40	17:07	0:27	TRANSFORMER FAULT
922	9-Apr-2022	HASSAN	220	SHIRAL-SGS	SHRIRALKOPPA_220	16:35	17:02	0:27	LINE FAULT
923	9-Apr-2022	HASSAN	110	BANTWA-KONAJE	BANTWAL_110	19:55	20:45	0:50	LINE FAULT
924	9-Apr-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	19:01	20:03	1:02	MAIN SUPPLY FAILURE
925	9-Apr-2022	HASSAN	110	HULICA-HSNGD	HULICAL_110	10:40	12:00	1:20	LINE CLEAR AVAILED
926	9-Apr-2022	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	19:24	20:13	0:49	MAIN SUPPLY FAILURE
927	9-Apr-2022	HASSAN	110	HV2	KONDENALU_110	13:01	14:45	1:44	LINE CLEAR AVAILED
928	9-Apr-2022	HASSAN	110	NANDIKU-ISTRL	NANDIKUR_110	19:20	20:30	1:10	MAIN SUPPLY FAILURE
929	9-Apr-2022	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	19:20	20:30	1:10	MAIN SUPPLY FAILURE
930	9-Apr-2022	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	18:05	18:52	0:47	LINE FAULT
931	9-Apr-2022	HASSAN	110	PUTTUR-VITTLA	PUTTUR_220	19:25	19:40	0:15	LINE FAULT
932	9-Apr-2022	HASSAN	110	PUTTUR-PUTTUR2	PUTTUR_220	19:18	20:30	1:12	LINE FAULT
933	9-Apr-2022	HASSAN	110	PUUTUR-MADAVU	PUTTUR_220	18:11	18:43	0:32	LINE FAULT
934	9-Apr-2022	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	19:25	19:46	0:21	MAIN SUPPLY FAILURE
935	9-Apr-2022	HASSAN	110	SHRLKP-BARANG	SHRIRALKOPPA_220	16:35	17:10	0:35	MAIN SUPPLY FAILURE
936	9-Apr-2022	HASSAN	110	HV1	SHRIRALKOPPA_220	16:35	17:10	0:35	MAIN SUPPLY FAILURE
937	9-Apr-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHRIRALKOPPA_220	16:35	17:10	0:35	MAIN SUPPLY FAILURE
938	9-Apr-2022	HASSAN	110	LV1	SHRIRALKOPPA_220	16:35	17:10	0:35	MAIN SUPPLY FAILURE
939	9-Apr-2022	HASSAN	110	LV2	SHRIRALKOPPA_220	16:35	17:10	0:35	MAIN SUPPLY FAILURE
940	9-Apr-2022	HASSAN	110	SHRLKP-SHIRALKOPPA	SHRIRALKOPPA_220	16:35	17:10	0:35	MAIN SUPPLY FAILURE
941	9-Apr-2022	HASSAN	110	SHRLKP-SORAB	SHRIRALKOPPA_220	16:35	17:10	0:35	MAIN SUPPLY FAILURE
942	9-Apr-2022	HASSAN	110	VITTAL-PUTR_SLTUR	VITTAL_110	19:25	19:40	0:15	MAIN SUPPLY FAILURE
943	9-Apr-2022	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	17:36	18:15	0:39	LINE FAULT
944	9-Apr-2022	HASSAN	66	HV2	BELUR_66	10:40	11:00	0:20	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
945	9-Apr-2022	MYSURU	66	HUNSUR-BANNIKUPPE	HOSURGATE_66	6:21	6:33	0:12	LINE FAULT
946	9-Apr-2022	MYSURU	66	HUNSUR-ELWALA	HUNSUR_66 HANAGODU_66	6:21	6:27	0:05	LINE FAULT
947	9-Apr-2022	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66	18:46	18:53	0:06	LINE FAULT
948	9-Apr-2022	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	KITTUR_66RAVANDUR_66BET TADHAPURA_66	17:01	21:42	4:41	LINE FAULT
949	9-Apr-2022	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	CHUNCHUNKATTE_66BILIKERE_66 KRNAGARA_66GVGUDI_66BH ERYA_66MIRLE_66	17:07	17:38	0:31	LINE FAULT
950	9-Apr-2022	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	CHUNCHUNKATTE_66BILIKERE_66 KRNAGARA_66GVGUDI_66BH ERYA_66MIRLE_66	20:12	21:44	1:32	LINE CLEAR AVAILED
951	9-Apr-2022	MYSURU	220	KUSHALNAGARA 220-BASTIPURA 1	NO STATIONS EFFECTED	17:07	18:34	1:27	LINE FAULT
952	9-Apr-2022	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-1	PONNAMPET_66VIRAJPET_66 PERIYAPATNA_66KAMPLAPUR A_66	17:08	17:35	0:27	LINE FAULT
953	9-Apr-2022	MYSURU	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	17:08	17:35	0:27	LINE FAULT
954	9-Apr-2022	MYSURU	66	KUSHALNAGARA 220-MERCERA 1	MADIKERI_66	17:18	17:49	0:31	LINE FAULT
955	9-Apr-2022	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	17:18	17:49	0:31	LINE FAULT
956	9-Apr-2022	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	PG PALYA_66LOKKANAHALLI_66	2:49	2:55	0:05	LINE FAULT
957	9-Apr-2022	MYSURU	66	HV2	SANTHEMARAHALLI_66	12:15	12:25	0:09	TRANSFORMER FAULT
958	9-Apr-2022	MYSURU	66	HV4	SFCSHIVA_66	16:27	16:51	0:24	LINE CLEAR AVAILED
959	9-Apr-2022	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	9:00:00 AM (4/7/2022)			LINE OPEN, LINE CLEAR AVAILED
960	9-Apr-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN, LINE CLEAR AVAILED
961	9-Apr-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN, LINE CLEAR AVAILED
962	9-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
963	9-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
964	9-Apr-2022	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	18:59:19 (9/4/2022)			LINE OPEN, LINE CLEAR AVAILED
965	9-Apr-2022	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	0:08	0:16	0:07	LINE FAULT
966	9-Apr-2022	TUMKUR	110	TR-1	MAYASANDRA_110	3:52	4:09	0:17	TRANSFORMER FAULT
967	9-Apr-2022	TUMKUR	66	TR-1	BADAVANAHALLI	3:52	15:06	11:14	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
968	9-Apr-2022	TUMKUR	66	BHARAMAGIRI66-SRS 220KV HIRIYUR	BHARAMAGIRI_66	18:00	18:20	0:20	MAIN SUPPLY FAILURE
969	9-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	4:10	4:22	0:11	LINE FAULT
970	9-Apr-2022	TUMKUR	66	TR-2	KOLALA_66	14:10	14:21	0:10	TRANSFORMER FAULT
971	9-Apr-2022	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANAHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	14:16	14:25	0:08	LINE FAULT
972	9-Apr-2022	TUMKUR	66	TR-2	PAVAGADA-66	10:40	10:45	0:05	TRANSFORMER FAULT
973	9-Apr-2022	TUMKUR	66	TR-1	PD KOTE_66	7:43	10:48	3:04	LINE CLEAR AVAILED
974	9-Apr-2022	TUMKUR	66	SHYLA PURA-MADHUGIRI220	SHYLA PURA_66	6:00	7:47	1:47	LINE CLEAR AVAILED
975	9-Apr-2022	TUMKUR	66	TR-2	SHYLA PURA_66	6:00	7:47	1:47	LINE CLEAR AVAILED
976	9-Apr-2022	TUMKUR	66	TR-1	SAVALANGA_66	16:59	18:09	1:09	LINE CLEAR AVAILED
977	10-Apr-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
978	10-Apr-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13(03.03.2022)			LINE OPEN, LINE CLEAR AVAILED
979	10-Apr-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
980	10-Apr-2022	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59(31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
981	10-Apr-2022	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34(09.04.2022)			LINE OPEN,LINE FAULT
982	10-Apr-2022	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34(09.04.2022)			LINE OPEN,LINE FAULT
983	10-Apr-2022	BAGALKOT	220	BELGAUM-CHIKKODI1(AEQU)	STATION NOT AFFECTED BELGAUM_220	17:26(09.04.2022)	17(10.04.2022)	28:51HRS	LINE CHARGED
984	10-Apr-2022	BAGALKOT	110	110//KV,HV1	AINAPUR_110	7:20	7:41	0:21	TRANSFORMER FAULT
985	10-Apr-2022	BAGALKOT	110	110//KV,HV2	BABALESHWAR_110	5:44	6:08	0:24	TRANSFORMER FAULT
986	10-Apr-2022	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	15:44	16:54	1:10	LINE FAULT
987	10-Apr-2022	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	15:45	17:02	1:17	LINE FAULT
988	10-Apr-2022	BAGALKOT	110	BAGEWADI-RAMPUR	RAMPUR_110	15:50	16:56	1:06	LINE FAULT
989	10-Apr-2022	BAGALKOT	110	SINDAGI(F1)-CHANDKAVATE	CHANDKAVATE_110,ALMEL_110	16:26	16:52	0:26	HAND TRIPPED
990	10-Apr-2022	BAGALKOT	110	HIREBEVANUR-RODAGI(INDI-LACHYAN)	RODAGI_110	18:19	18:37	0:18	LINE FAULT
991	10-Apr-2022	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	1:38	16:40	15:02	LINE FAULT
992	10-Apr-2022	BAGALKOT	110	110/11KV,HV4	KERUR_110	1:38	1:40	0:02	TRANSFORMER FAULT
993	10-Apr-2022	BAGALKOT	110	BADAMI-KERUR	KERUR_110	16:40	16:41	0:01	HAND TRIPPED
994	10-Apr-2022	BAGALKOT	110	KULAGERI CROSS -MRN SUGARS	KULAGERI CROSS_110	0:44	1:17	0:33	HAND TRIPPED
995	10-Apr-2022	BAGALKOT	66	66/33KV,HV4	HARIHAR-HOSPET_66	0:58	4:02	3:04	LOAD CURTAILMENT
996	10-Apr-2022	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	16:35	20:52	4:17	LINE FAULT
997	10-Apr-2022	BAGALKOT	110	SOUDATTI220- NARAGUND (RAMDURGA1)	STATION NOT AFFECTED SOUDATTI_220	16:29	17:32	1:03	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
998	10-Apr-2022	BAGALKOT	110	SODATTI220- NARAGUND (RAMDURGA1)	STATION NOT AFFECTED SODATTI_220	18:49 (10.04.2022)			LINE OPEN,LINE FAULT
999	10-Apr-2022	BAGALKOT	110	SAVALAGI- AIGALI	STATION NOT AFFECTED SAVALAGI_110	8:27	18:25	9:58	LINE CLEAR AVAILED
1000	10-Apr-2022	BAGALKOT	110	RON- HIREHAL	STATION NOT AFFECTED RON_110	1:08	1:13	0:05	HAND TRIPPED
1001	10-Apr-2022	BAGALKOT	110	RON- GAMESHA	RON_110	0:01	0:08	0:07	HAND TRIPPED
1002	10-Apr-2022	BAGALKOT	110	NEERBUDIHAI- KATARAKI	STATION NOT AFFECTED NEERABUDIHAI_110	17:46	18:00	0:14	HAND TRIPPED
1003	10-Apr-2022	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	17:35	17:59	0:24	TRANSFORMER FAULT
1004	10-Apr-2022	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	8:19	8:31	0:12	HAND TRIPPED
1005	10-Apr-2022	BAGALKOT	110	MUKARTIHAL- BAGEWADI2 (NIDAGUNDI)	MUKARTIHAL_110	17:05	17:14	0:09	HAND TRIPPED
1006	10-Apr-2022	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	20:34 (10.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1007	10-Apr-2022	BAGALKOT	220	AQUES- CHIKKODI1	STATION NOT AFFECTED AQUES_220	17:41 (10.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1008	10-Apr-2022	BAGALKOT	110	YLWD-F2 Cbreaker( SAVALAGI)	STATION NOT AFFECTED YELLAMANAWADI_110	8:22	18:17	9:55	LINE CLEAR AVAILED
1009	10-Apr-2022	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED VAJRAMATTI_110	17:39	17:46	0:07	TRANSFORMER FAULT
1010	10-Apr-2022	BAGALKOT	110	YARAGATTI-KATAKOL	KATAKOL_110	1:01	1:07	0:06	HAND TRIPPED
1011	10-Apr-2022	BAGALKOT	110	UKKALI-F2 Cbreaker( BAGEWADI)	UKKALI_110	17:30	18:20	0:50	LINE CLEAR AVAILED
1012	10-Apr-2022	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10(10.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1013	10-Apr-2022	BAGALKOT	110	F1 (NARENDRA 220)-UAS	STATION NOT AFFECTED UAS DHARWAD_110	15:24	19:26	4:02	LINE FAULT
1014	10-Apr-2022	BAGALKOT	110	TARIHAL-KIADB GAMANAGHATTI	STATION NOT AFFECTED TARIHAL_110	11:42(05.04.2022)	00(10.04.2022)		LINE OPEN, LINE CLEAR AVAILED
1015	10-Apr-2022	BAGALKOT	110	TARIHAL(NARENDRA220)-TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	16:06(10.04.2022)			MAIN SUPPLY FAILURE
1016	10-Apr-2022	BAGALKOT	220	BIDNAL-SODATTI	STATION NOT AFFECTED BIDNAL_220	16:35	21:09	4:34	LINE FAULT
1017	10-Apr-2022	BAGALKOT	110	HAVERI-TILUVALI(HANAGAL)	HANAGAL_110	1:51	2:10	0:19	LINE FAULT
1018	10-Apr-2022	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	6:04	6:40	0:36	LINE FAULT
1019	10-Apr-2022	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	STATION NOT AFFECTED MAHALINGAPUR_220	16:25	17:48	1:23	LINE FAULT
1020	10-Apr-2022	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	STATION NOT AFFECTED MAHALINGAPUR_220	18:47	20:47	2:00	LINE FAULT
1021	10-Apr-2022	BAGALKOT	220	MAHALINGAPUR-NARENDRA2	STATION NOT AFFECTED MAHALINGAPUR_220	18:47	20:47	2:00	LINE FAULT
1022	10-Apr-2022	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	10:28	20:16	9:48	LINE CLEAR AVAILED
1023	10-Apr-2022	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	14:44	20:48	6:04	LINE CLEAR AVAILED
1024	10-Apr-2022	BAGALKOT	110	NARENDRA-MRUTHYUNJAYANAGAR2(UAS )	NARENDRA_220	15:21	19:19	3:58	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1025	10-Apr-2022	BAGALKOT	110	NARENDRA-TADASINAKOPPA	STATION NOT AFFECTED NARENDRA_220	15:18(10.04.2022)			LINE OPEN,LINE FAULT
1026	10-Apr-2022	BAGALKOT	220	AMBEWADI-NARENDRA-1	AMBEWADI_220	10:29	20:17	9:48	NFBC ISSUED
1027	10-Apr-2022	BAGALKOT	110	AMBEWADI-NK-2(KAVALWADA)	AMBEWADI_220	17:16	17:53	0:37	LINE FAULT
1028	10-Apr-2022	BAGALKOT	220	CHIKKODI-BELGAUM1(AEQU)	CHIKODI_220	1:24	2:34	1:10	LINE FAULT
1029	10-Apr-2022	BAGALKOT	220	CHIKKODI-BELGAUM1(AEQU)	STATION NOT AFFECTED CHIKODI_220	17:40(10.04.2022)			LINE OPEN,LINE FAULT
1030	10-Apr-2022	BAGALKOT	110	BELGAUM-HUKKERI(UCHAGOAN)	UCHAGOAN_110	15:51	16:27	0:36	LINE FAULT
1031	10-Apr-2022	BAGALKOT	110	BAGALKOT-KERUR	BAGALKOT_220	0:44	16:23	15:39	LINE FAULT
1032	10-Apr-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	17:30 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1033	10-Apr-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	9:40 (31.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1034	10-Apr-2022	BAGALKOT	110	HALIYAL-KAWALWADA	STATION NOT AFFECTED HALIYAL_110	17:56(07.04.2022)			LINE OPEN,LINE FAULT
1035	10-Apr-2022	BAGALKOT	110	MK HUBLI220-KHANAPUR	KHANAPUR_110	7:00	9:13	2:13	LINE CLEAR AVAILED
1036	10-Apr-2022	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	7:15	9:01	1:46	LINE CLEAR AVAILED
1037	10-Apr-2022	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	15:46	16:49	1:03	LINE FAULT
1038	10-Apr-2022	BAGALKOT	110	BELGAUM220- UDAYMBAG	UDAYMBAG_110	15:52	16:28	0:36	MAIN SUPPLY FAILURE
1039	10-Apr-2022	BAGALKOT	110	BELGAUM220- UCHAGOAN	UCHAGOAN_110	15:50	16:30	0:40	MAIN SUPPLY FAILURE
1040	10-Apr-2022	BENGALURU	66	A STATION 220 - A STATION 2 66	A STATION 2 66	12:22	12:32	0:10	MAIN SUPPLY FAILURE
1041	10-Apr-2022	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	12:22	12:32	0:10	MAIN SUPPLY FAILURE
1042	10-Apr-2022	BENGALURU	66	HV2	BIDADI 220	7:35	7:43	0:08	TRANSFORMER FAULT
1043	10-Apr-2022	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	12:20	12:32	0:12	MAIN SUPPLY FAILURE
1044	10-Apr-2022	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	14:42	14:48	0:06	LOAD CHANGE OVER
1045	10-Apr-2022	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	3:06	3:12	0:06	LINE FAULT
1046	10-Apr-2022	BENGALURU	66	HV1	KENGARI SATELLITE TOWN	0:50	3:20	2:30	TRANSFORMER FAULT
1047	10-Apr-2022	BENGALURU	220	NRS 220 - NELAMANGALA 400	NRS 220	12:19	12:49	0:30	MAIN SUPPLY FAILURE
1048	10-Apr-2022	BENGALURU	220	HV1	NRS 220	12:19	12:49	0:30	MAIN SUPPLY FAILURE
1049	10-Apr-2022	BENGALURU	220	HV2	NRS 220	12:19	12:49	0:30	MAIN SUPPLY FAILURE
1050	10-Apr-2022	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	12:19	12:50	0:31	MAIN SUPPLY FAILURE
1051	10-Apr-2022	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	12:19	12:50	0:31	MAIN SUPPLY FAILURE
1052	10-Apr-2022	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	12:19	12:50	0:31	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1053	10-Apr-2022	BENGALURU	66	HV1	NRS 220	12:19	12:55	0:36	MAIN SUPPLY FAILURE
1054	10-Apr-2022	BENGALURU	66	HV2	NRS 220	12:19	12:55	0:36	MAIN SUPPLY FAILURE
1055	10-Apr-2022	BENGALURU	66	HV3	NRS 220	12:19	12:55	0:36	MAIN SUPPLY FAILURE
1056	10-Apr-2022	BENGALURU	66	HV4	NRS 220	12:19	12:55	0:36	MAIN SUPPLY FAILURE
1057	10-Apr-2022	BENGALURU	66	HV5	NRS 220	12:19	12:55	0:36	MAIN SUPPLY FAILURE
1058	10-Apr-2022	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	7:42	8:13	0:31	TRANSFORMER FAULT
1059	10-Apr-2022	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	12:21	12:30	0:09	TRANSFORMER FAULT
1060	10-Apr-2022	BENGALURU	66	SOLDEVANAHALLI - YELAHANAK 220	SOLDEVANAHALLI	13:18	13:37	0:19	MAIN SUPPLY FAILURE
1061	10-Apr-2022	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	16:13	16:16	0:03	LOAD CHANGE OVER
1062	10-Apr-2022	BENGALURU	66	HV2	SRS PEENYA 220	12:08	12:10	0:02	HAND TRIPPED
1063	10-Apr-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	21:03	21:06	0:03	LINE FAULT
1064	10-Apr-2022	BENGALURU	66	HV2	VIJAYANAGARA	12:20	12:31	0:11	MAIN SUPPLY FAILURE
1065	10-Apr-2022	BENGALURU	66	HV2	VIJAYANAGARA	14:37	14:39	0:02	LOAD CHANGE OVER
1066	10-Apr-2022	BENGALURU	66	YARANDANAHALLI 220 - JIGANI	KUMBARANAHALLI	11:32	12:26	0:54	LINE CLEAR AVAILED
1067	10-Apr-2022	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	13:18	13:37	0:18	LINE FAULT
1068	10-Apr-2022	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	NRS RAJAJINAGAR 220	12:19	13:47	1:28	LINE FAULT
1069	10-Apr-2022	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	9:19	9:32	0:13	LINE FAULT
1070	10-Apr-2022	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	11:16	11:27	0:11	LOAD CHANGE OVER
1071	10-Apr-2022	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	14:44	15:44	1:00	LINE CLEAR AVAILED
1072	10-Apr-2022	BENGALURU	66	KOLAR 220 - BANGARPET 2	NO STATION AFFECTED	11:16	11:27	0:11	LOAD CHANGE OVER
1073	10-Apr-2022	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	14:44	15:44	1:00	LINE CLEAR AVAILED
1074	10-Apr-2022	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	2:20	2:38	0:18	LINE FAULT
1075	10-Apr-2022	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	6:31	7:13	0:42	LINE FAULT
1076	10-Apr-2022	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	13:44	13:53	0:08	LINE FAULT
1077	10-Apr-2022	BENGALURU	66	TADIGOL CROSS - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	13:45	13:57	0:12	LINE FAULT
1078	10-Apr-2022	BENGALURU	66	SIDLAGHATTA - CHINTAMANI 220	SIDLAGHATTA, MELUR	5:44	6:00	0:16	LINE FAULT
1079	10-Apr-2022	BENGALURU	66	MALUR 220 - KGF 2	NO STATION AFFECTED	10:44	15:54	5:09	LINE FAULT
1080	10-Apr-2022	GULBARGA	220	LINGASUGUR-BAGEWADI1	BAGEWADI_220	16:22	17:18	0:56	LINE FAULT
1081	10-Apr-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN ,TRANSFORMER FAULT
1082	10-Apr-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	18:50 (9.04.2022)	18:55 (10.04.2022)	16:05 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1083	10-Apr-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
1084	10-Apr-2022	GULBARGA	110	ALIPUR-BELLARY NORTH	BELLARY NORTH,SOMASAMUDRA_110, MOKA_110,PD HALLI_110,BISIHALLI_110,JAN AKI_IPP,BASAI STEELS	5:12	5:20	0:08	LINE FAULT
1085	10-Apr-2022	GULBARGA	110	LINGASUGUR-KPRL	CYAYADEVI_IPP,KAREPOWER_IPP	16:22	16:47	0:25	LINE FAULT
1086	10-Apr-2022	GULBARGA	110	LINGASUGUR-CHAYADEVI	CYAYADEVI_IPP,KAREPOWER_IPP	16:22	16:49	0:27	LINE FAULT
1087	10-Apr-2022	GULBARGA	110	GABBUR-RAICHUR1	GABBUR-110,DEODURGA_110	13:30	16:30	3:00	LINE CLEAR AVAILED
1088	10-Apr-2022	GULBARGA	110	HV1 (20 MVA)	KUSTAGI_220	16:41	17:13	0:32	TRANSFORMER FAULT
1089	10-Apr-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	2:42	2:52	0:10	LINE FAULT
1090	10-Apr-2022	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	4:20	4:25	0:05	LINE FAULT
1091	10-Apr-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	20:23	20:33	0:10	LINE FAULT
1092	10-Apr-2022	GULBARGA	110	MALLAT-KONDAPURAM SOLAR_IPP	MALLAT_220	19:36	22:10	2:34	LINE CLEAR AVAILED
1093	10-Apr-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	9:24 (27.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1094	10-Apr-2022	GULBARGA	110	LV1	KAPNOOR_220	10:31	15:34	5:03	LINE CLEAR AVAILED
1095	10-Apr-2022	GULBARGA	110	CHOWDAPUR-AFZALPUR	AFZALPUR_110	9:00	10:00	1:00	LINE FAULT
1096	10-Apr-2022	GULBARGA	110	CHOWDAPUR-AFZALPUR	AFZALPUR_110	10:00	10:10	0:10	LINE CLEAR AVAILED
1097	10-Apr-2022	GULBARGA	110	CHOWDAPUR-AFZALPUR	AFZALPUR_110	14:05	14:16	0:11	LINE FAULT
1098	10-Apr-2022	GULBARGA	110	HV1	GOOGAL_110	12:25	12:35	0:10	TRANSFORMER FAULT
1099	10-Apr-2022	GULBARGA	66	HV2	HALVAGALU_66	17:15	17:20	0:05	TRANSFORMER FAULT
1100	10-Apr-2022	GULBARGA	66	HV2	KOGALI_66	7:00	8:15	1:15	TRANSFORMER FAULT
1101	10-Apr-2022	GULBARGA	66	HV1	KOGALI_66	8:20	8:30	0:10	TRANSFORMER FAULT
1102	10-Apr-2022	GULBARGA	66	HV2	KOGALI_66	16:05	16:45	0:40	TRANSFORMER FAULT
1103	10-Apr-2022	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALLI_66	16:53	18:35	1:42	LINE FAULT
1104	10-Apr-2022	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	19:02 (9.04.2022)	19:05(10/04/2022)	15:03 hrs	LINE CHARGED
1105	10-Apr-2022	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	23:48 (9.04.2022)	20:00(10.04.2022)	0:31 hrs	LINE CHARGED
1106	10-Apr-2022	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	17:30 (9.04.2022)	17:20(10/04/2022)	17:49 hrs	LINE CHARGED
1107	10-Apr-2022	HASSAN	220	KEMAR-Varahi1	KEMAR_220	19:03(09.04.2022)	19:42(10.4.2022)	19:19 hrs	LINE CHARGED
1108	10-Apr-2022	HASSAN	220	VARAHI-KEMAR1	gen_varahi	19:03(09.04.2022)	19:25(10.04.2022)	19:21 hrs	LINE CHARGED
1109	10-Apr-2022	HASSAN	220	VARAHI-SHMG3	gen_varahi	7:47 (9.04.2022)	7:04 (10.04.2022)	22:16 hrs	LINE CHARGED
1110	10-Apr-2022	HASSAN	220	MRSSHM-VARAH13	MRS MG_220	7:46 (9.04.2022)	7:04(10.04.2022)	22:17 hrs	LINE CHARGED
1111	10-Apr-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1112	10-Apr-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	10:54 (24.03.2022)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1113	10-Apr-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN,LINE FAULT
1114	10-Apr-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1115	10-Apr-2022	HASSAN	220	VARAHI-SHIMOGA2	VARAHI_GEN	18:47(03.04.2022)			LINE OPEN,LINE FAULT
1116	10-Apr-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1117	10-Apr-2022	HASSAN	66	HV2	BALEHONNUR_66	9:24 (9.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1118	10-Apr-2022	HASSAN	66	BHADRA-LINGADAHALLI	bhara_gen	23:40 (10.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1119	10-Apr-2022	HASSAN	66	BHADRA-SHMGA 1	bhara_gen	21:43 (10.04.2022)			LINE OPEN,LINE FAULT
1120	10-Apr-2022	HASSAN	66	BHADRA-SHMGA 2	bhara_gen	21:15 (10.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1121	10-Apr-2022	HASSAN	110	LPH-MGHE 1	lph_gen	20:31 (10.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1122	10-Apr-2022	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	20:16 (10.04.2022)			LINE OPEN,LINE FAULT
1123	10-Apr-2022	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	21:43 (10.04.2022)			LINE OPEN,LINE FAULT
1124	10-Apr-2022	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	21:14 (10.04.2022)			LINE OPEN,LINE FAULT
1125	10-Apr-2022	HASSAN	220	SHARAVATY-SIRISI 1	sharavathy_gen	20:26 (10.04.2022 )			LINE OPEN,LINE FAULT
1126	10-Apr-2022	HASSAN	220	SHARAVATY-TALAGUPPA 2	sharavathy_gen	20:16 (10.04.2022)			LINE OPEN,LINE FAULT
1127	10-Apr-2022	HASSAN	220	VARAHI-SHIMOGA1	VARAHI_GEN	18:55 (10.04.2022)			LINE OPEN,LINE FAULT
1128	10-Apr-2022	HASSAN	66	MRSSHM-VARAH1	MRSMSG_220	18:55 (10.04.2022)			LINE OPEN,LINE FAULT
1129	10-Apr-2022	HASSAN	110	HV1	BARANGI_110	14:00	15:05	1:05	LINE CLEAR AVAILED
1130	10-Apr-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	21:08	21:59	0:51	MAIN SUPPLY FAILURE
1131	10-Apr-2022	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	21:08	21:59	0:51	MAIN SUPPLY FAILURE
1132	10-Apr-2022	HASSAN	110	JOG110-AMBTR1	JOG_110	20:30	22:20	1:50	MAIN SUPPLY FAILURE
1133	10-Apr-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	20:30	22:50	2:20	MAIN SUPPLY FAILURE
1134	10-Apr-2022	HASSAN	110	JOG110-LPH	JOG_110	20:30	22:20	1:50	MAIN SUPPLY FAILURE
1135	10-Apr-2022	HASSAN	110	SAGARA-ALKLA	SAGARA_110	18:50	19:15	0:25	LINE FAULT
1136	10-Apr-2022	HASSAN	66	BHADRA-SHMGA 2	bhara_gen	17:10	20:20	3:10	LINE FAULT
1137	10-Apr-2022	HASSAN	66	HV1	BALEHONNUR_66	9:48	9:53	0:05	LINE CLEAR AVAILED
1138	10-Apr-2022	HASSAN	66	HV1	HASSAN_66	5:20	7:23	2:03	LINE CLEAR AVAILED
1139	10-Apr-2022	HASSAN	66	HV1	HASSAN_66	7:25	7:58	0:33	LINE CLEAR AVAILED
1140	10-Apr-2022	HASSAN	66	HV1	HASSAN_66	14:33	18:10	3:37	LINE CLEAR AVAILED
1141	10-Apr-2022	HASSAN	66	HV1	HOLALUR_66	14:25	14:45	0:20	TRANSFORMER FAULT
1142	10-Apr-2022	HASSAN	66	SAKLESHPUR	KANDLI_66	9:10	10:30	1:20	LINE FAULT
1143	10-Apr-2022	HASSAN	66	SIGEBAGI	KUDLIGERE_66	16:55	18:25	1:30	MAIN SUPPLY FAILURE
1144	10-Apr-2022	HASSAN	66	SIGEBAGI	KUDLIGERE_66	13:10	13:35	0:25	MAIN SUPPLY FAILURE
1145	10-Apr-2022	HASSAN	66	HV2	RAMESHWARNAGAR_66	10:10	14:00	3:50	LINE CLEAR AVAILED
1146	10-Apr-2022	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	13:10	13:35	0:25	LINE FAULT
1147	10-Apr-2022	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	16:55	17:35	0:40	LINE FAULT
1148	10-Apr-2022	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	18:00	18:28	0:28	LINE CLEAR AVAILED
1149	10-Apr-2022	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	19:28	22:34	3:06	LINE FAULT
1150	10-Apr-2022	HASSAN	220	KEMAR-Varahi1	KEMAR_220	21:03	21:21	0:18	LINE CLEAR AVAILED
1151	10-Apr-2022	HASSAN	220	KEMAR-Varahi2	KEMAR_220	11:14	13:32	2:18	LINE FAULT
1152	10-Apr-2022	HASSAN	220	KEMAR-Varahi2	KEMAR_220	21:03	21:47	0:44	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1153	10-Apr-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	21:08	21:59	0:51	LINE FAULT
1154	10-Apr-2022	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	21:08	21:55	0:47	LINE FAULT
1155	10-Apr-2022	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	21:14	22:07	0:53	LINE FAULT
1156	10-Apr-2022	HASSAN	220	VARAHI-KEMAR2	gen_varahi	11:14	13:32	2:18	LINE CLEAR AVAILED
1157	10-Apr-2022	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	17:10	19:20	2:10	LINE FAULT
1158	10-Apr-2022	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	17:10	20:20	3:10	LINE FAULT
1159	10-Apr-2022	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	18:58	19:15	0:17	LINE FAULT
1160	10-Apr-2022	HASSAN	110	HV2	ANAVATTI_110	19:15	20:30	1:15	TRANSFORMER FAULT
1161	10-Apr-2022	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	0:06	0:18	0:12	LINE FAULT
1162	10-Apr-2022	MYSURU	66	HV1	ARAKERE_66	8:15	8:22	0:07	TRANSFORMER FAULT
1163	10-Apr-2022	MYSURU	66	HV1	ARAKERE_66	9:29	9:35	0:05	TRANSFORMER FAULT
1164	10-Apr-2022	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	17:10	17:30	0:20	LINE FAULT
1165	10-Apr-2022	MYSURU	66	MANDYA-CHIKKAMANDYA	CHIKKA_MANDYA_66BESAGA RAHALLI_66 KOPPA_66HAMPAPURA_66	10:09	10:15	0:05	LINE FAULT
1166	10-Apr-2022	MYSURU	66	HV4	SFCSHIVA_66	9:26	11:52	2:26	LINE CLEAR AVAILED
1167	10-Apr-2022	MYSURU	66	HV1	SFCSHIVA_66	6:40	7:00	0:20	TRANSFORMER FAULT
1168	10-Apr-2022	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	9:00:00 AM (4/7/2022)	26:00 (10/4/2022)	82:26HRS	LINE CHARGED
1169	10-Apr-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1170	10-Apr-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1171	10-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1172	10-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1173	10-Apr-2022	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	18:59:19 (9/4/2022)	0:00 (10/4/2022)	10:40HRS	LINE CHARGED
1174	10-Apr-2022	TUMKUR	220	JAGALUR_400-THALLAK-2	THALLAK_220	15:28	15:58	0:29	HAND TRIPPED
1175	10-Apr-2022	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	5:44	6:02	0:18	TRANSFORMER FAULT
1176	10-Apr-2022	TUMKUR	220	TR-2(HV & LV SIDE)	PAVAGADA_220	5:44	6:00	0:15	TRANSFORMER FAULT
1177	10-Apr-2022	TUMKUR	110	TR-1	MAYASANDRA_110	5:44	6:00	0:15	TRANSFORMER FAULT
1178	10-Apr-2022	TUMKUR	66	TR-2	GULIGENAHALLI_66	8:53	11:11	2:18	LINE CLEAR AVAILED
1179	10-Apr-2022	TUMKUR	66	TR-2	HOLALKERE_66	19:34	20:56	1:21	TRANSFORMER FAULT
1180	10-Apr-2022	TUMKUR	66	TR-2	HOLALKERE_66	21:04	21:56	0:51	TRANSFORMER FAULT
1181	10-Apr-2022	TUMKUR	66	TR-1	PAVAGADA_220	5:44	6:03	0:19	TRANSFORMER FAULT
1182	10-Apr-2022	TUMKUR	66	TR-2	PAVAGADA_220	5:44	5:59	0:15	TRANSFORMER FAULT
1183	10-Apr-2022	TUMKUR	66	PAVAGADA66-MADHUGIRI66	PAVAGADA_66	5:44	5:56	0:12	LINE FAULT
1184	11-Apr-2022	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
1185	11-Apr-2022	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13(03.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1186	11-Apr-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1187	11-Apr-2022	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59(31.03.2022)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1188	11-Apr-2022	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34(09.04.2022)			LINE OPEN,LINE FAULT
1189	11-Apr-2022	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34(09.04.2022)			LINE OPEN,LINE FAULT
1190	11-Apr-2022	BAGALKOT	110	SOUDATTI220- NARAGUND (RAMDURGA1)	STATION NOT AFFECTED SOUDATTI_220	18:49 (10.04.2022)	56 (11.04.2022)	14:07HRS	LINE CHARGED
1191	11-Apr-2022	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	20:34 (10.04.2022)	41 (11.04.2022)	14:07HRS	LINE CHARGED
1192	11-Apr-2022	BAGALKOT	220	AQUES- CHIKKODI1	STATION NOT AFFECTED AQUES_220	17:41 (10.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1193	11-Apr-2022	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10(10.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1194	11-Apr-2022	BAGALKOT	110	TARIHAL(NARENDRA220)- TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	16:06(10.04.2022)			MAIN SUPPLY FAILURE
1195	11-Apr-2022	BAGALKOT	110	NARENDRA-TASINAKOPPA	STATION NOT AFFECTED NARENDRA_220	15:18(10.04.2022)	56(11.04.2022)	19:38HRS	LINE CHARGED
1196	11-Apr-2022	BAGALKOT	220	CHIKKODI-BELGAUM1(AEQU)	STATION NOT AFFECTED CHIKKODI_220	17:40(10.04.2022)			LINE OPEN,LINE FAULT
1197	11-Apr-2022	BAGALKOT	110	110/11KV,HV2	ALMEL_110	23:38	23:40	0:02	TRANSFORMER FAULT
1198	11-Apr-2022	BAGALKOT	110	110/11KV,HV1	DADDI_110	17:30	17:49	0:19	TRANSFORMER FAULT
1199	11-Apr-2022	BAGALKOT	110	DAMBAL-MUNDARAGI	MUNDARAGI_110 (STATION NOT AFFECTED)	11:37	16:30	4:53	LINE FAULT
1200	11-Apr-2022	BAGALKOT	110	110/11KV,HV1	GADAG_110	18:42	18:56	0:14	TRANSFORMER FAULT
1201	11-Apr-2022	BAGALKOT	110	ITNAL-KABBUR(HIDIKAL2)	KABBUR_110	10:02	11:55	1:53	LINE CLEAR AVAILED
1202	11-Apr-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KULAGERI CROSS_110	7:53	7:57	0:04	TRANSFORMER FAULT
1203	11-Apr-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KULIGOD_110	14:32	15:29	0:57	LINE CLEAR AVAILED
1204	11-Apr-2022	BAGALKOT	110	110/33KV, HV2	NTPC_33, KOLAR WS_33, KARJOL LIS_33 STATION NOT AFFECTED MATTIHAL_110	14:40	14:43	0:03	TRANSFORMER FAULT
1205	11-Apr-2022	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MANALI SUGARS_110 STATION NOT AFFECTED MALGHAN(S)_110	18:24	18:39	0:15	LINE FAULT
1206	11-Apr-2022	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	4:24	5:11	0:47	LINE FAULT
1207	11-Apr-2022	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	14:20	17:53	3:33	LINE CLEAR AVAILED
1208	11-Apr-2022	BAGALKOT	220	CHIKKODI- MUDASHINGI	STATION NOT AFFECTED CHIKKODI_220	14:55	22:16	7:21	NFBC ISSUED
1209	11-Apr-2022	BAGALKOT	220	SIRSI-SHARAVATI2	STATION NOT AFFECTED SIRSI_220	11:46	15:46	4:00	LINE FAULT
1210	11-Apr-2022	BAGALKOT	110	MUGALAKHOD- LN4(ITNAL3)	STATION NOT AFFECTED MUGALAKHOD_220	10:02	11:50	1:48	LINE CLEAR AVAILED
1211	11-Apr-2022	BAGALKOT	110	MUGALAKHOD- LN6(HIDIKAL)	STATION NOT AFFECTED MUGALAKHOD_220	10:44	13:27	2:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1212	11-Apr-2022	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI2	STATION NOT AFFECTED MAHALINGAPUR 220	4:22	5:01	0:39	LINE FAULT
1213	11-Apr-2022	BAGALKOT	110	AMBEWADI - NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI 220	10:32	10:38	0:06	HAND TRIPPED
1214	11-Apr-2022	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI 220	17:30 (31.03.2022)			LINE OPEN, LINE CLEAR AVOIDED
1215	11-Apr-2022	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	9:40 (31.03.2022)			LINE OPEN, LINE CLEAR AVOIDED
1216	11-Apr-2022	BAGALKOT	110	HALIYAL-KAWALWADA	STATION NOT AFFECTED HALIYAL 110	17:56(07.04.2022)			LINE OPEN, LINE FAULT
1217	11-Apr-2022	BAGALKOT	110	110/11KV, HV1	MANTUR(B) 110	22:25	22:30	0:05	TRANSFORMER FAULT
1218	11-Apr-2022	BAGALKOT	220	RANEBENNUR- GUTTUR	STATION NOT AFFECTED RANEBENNUR 220	15:42	16:35	0:53	LINE FAULT
1219	11-Apr-2022	BAGALKOT	110	110/11KV, HV1	SADALAGA 110	9:00	9:15	0:15	TRANSFORMER FAULT
1220	11-Apr-2022	BAGALKOT	110	SOUDATTI220- KATAKOL	STATION NOT AFFECTED KATAKOL 110	1:02	1:08	0:06	MAIN SUPPLY FAILURE
1221	11-Apr-2022	BENGALURU	66	HV2	DEVARABISANAHALLI	12:45	12:48	0:03	LINE CLEAR AVOIDED
1222	11-Apr-2022	BENGALURU	66	HV1	EXORA	11:05	11:10	0:05	LINE CLEAR AVOIDED
1223	11-Apr-2022	BENGALURU	66	HV2	EXORA	11:30	11:35	0:05	TRANSFORMER FAULT
1224	11-Apr-2022	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	14:39	14:43	0:04	LOAD CHANGE OVER
1225	11-Apr-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	18:54	19:00	0:06	LINE FAULT
1226	11-Apr-2022	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	18:54	19:00	0:06	LINE FAULT
1227	11-Apr-2022	BENGALURU	66	HV3	NAGANATHPURA 220	11:18	11:20	0:02	LINE CLEAR AVOIDED
1228	11-Apr-2022	BENGALURU	66	HV1	KUMBALAGODU	3:33	3:50	0:17	TRANSFORMER FAULT
1229	11-Apr-2022	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	13:16	13:21	0:05	LINE FAULT
1230	11-Apr-2022	BENGALURU	66	HV2	MULBAGLU	15:17	15:20	0:02	LINE CLEAR AVOIDED
1231	11-Apr-2022	BENGALURU	66	HV1	MALLANAYAKANA HALLI	13:24	13:48	0:23	TRANSFORMER FAULT
1232	11-Apr-2022	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	18:43	18:55	0:12	LINE FAULT
1233	11-Apr-2022	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	19:20	19:40	0:20	LINE FAULT
1234	11-Apr-2022	BENGALURU	66	MARALWADI - GODURU	GODURU	9:45	9:55	0:10	LINE FAULT
1235	11-Apr-2022	BENGALURU	66	MARALWADI - GODURU	GODURU	13:25	13:35	0:10	LINE FAULT
1236	11-Apr-2022	GULBARGA	110	HV1	CHOWDAPUR 110	11:45	11:50	0:05	TRANSFORMER FAULT
1237	11-Apr-2022	GULBARGA	110	HV1	CHOWDAPUR 110	11:55	12:00	0:05	TRANSFORMER FAULT
1238	11-Apr-2022	GULBARGA	110	HV1	CHOWDAPUR 110	16:00	16:05	0:05	TRANSFORMER FAULT
1239	11-Apr-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR 110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVOIDED
1240	11-Apr-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR 110,SAIDAPUR 110,WADAGERA 110,SANNATH I_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVOIDED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1241	11-Apr-2022	GULBARGA	110	SHAHAPUR-YADGIR	SAIDAPUR_110	3:13	10:19	7:06	LINE FAULT
1242	11-Apr-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	9:24 (27.03.2022)	36 (11.04.2022)	354:12 HRS	LINE CHARGED
1243	11-Apr-2022	GULBARGA	110	MASKI-RNWSLR_IPP	MASKI_110	9:45	10:04	0:19	LINE FAULT
1244	11-Apr-2022	GULBARGA	110	MASKI-RNWSLR_IPP	MASKI_110	12:55	13:01	0:06	LINE FAULT
1245	11-Apr-2022	GULBARGA	110	MASKI-RNWSLR_IPP	MASKI_110	13:22	13:38	0:16	LINE FAULT
1246	11-Apr-2022	GULBARGA	110	KAVITAL-GMSH_IPP	KAVITAL_110	4:20	5:20	1:00	LINE FAULT
1247	11-Apr-2022	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110,MASKI_110	12:33	12:40	0:07	LINE FAULT
1248	11-Apr-2022	GULBARGA	110	MYLAR-GUTAL	MYLAR_110	13:00	13:15	0:15	MAIN SUPPLY FAILURE
1249	11-Apr-2022	GULBARGA	110	MYLAR-GUTAL	MYLAR_110	15:13	16:20	1:07	MAIN SUPPLY FAILURE
1250	11-Apr-2022	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:25	5:35	0:10	LINE FAULT
1251	11-Apr-2022	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	4:20	4:25	0:05	LINE FAULT
1252	11-Apr-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	22:58	23:08	0:10	LINE FAULT
1253	11-Apr-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	23:42	23:52	0:10	LINE FAULT
1254	11-Apr-2022	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHADESUGUR_110,SIRIGERACROSS_110,NSLSUGAR_IPP,VOORA_IPP	3:05	3:15	0:10	LINE FAULT
1255	11-Apr-2022	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHADESUGUR_110,SIRIGERACROSS_110,NSLSUGAR_IPP,VOORA_IPP	5:13	5:23	0:10	LINE FAULT
1256	11-Apr-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	6:13	6:23	0:10	LINE FAULT
1257	11-Apr-2022	GULBARGA	110	KUSTAGI-KUSTAGI SOLAR_IPP	KUSTAGI_220	19:00	23:52	4:52	LINE CLEAR AVAILED
1258	11-Apr-2022	GULBARGA	66	HV1	UCHCHANGIDURGA_66	15:30	16:25	0:55	LINE CLEAR AVAILED
1259	11-Apr-2022	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	18:55 (10.04.2022)	48 (11.04.2022)	9:52 hrs	LINE CHARGED
1260	11-Apr-2022	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	21:14 (10.04.2022)	20 (11.04.2022)	4:05 hrs	LINE CHARGED
1261	11-Apr-2022	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	21:14 (10.04.2022)	01 (11.04.2022)	2:46 hrs	LINE CHARGED
1262	11-Apr-2022	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	20:16 (10.04.2022)	13 (11.04.2022)	13:56 hrs	LINE CHARGED
1263	11-Apr-2022	HASSAN	220	VARHI-SHIMOGA1	varahi_gen	18:55 (10.04.2022)	48 (11.04.2022)	12:52 hrs	LINE CHARGED
1264	11-Apr-2022	HASSAN	66	HV2	BALEHONNUR_66	9:24 (9.04.2022)	1:55 (11.04.2022)	54:30 hrs	TRANSFORMER CHARGED
1265	11-Apr-2022	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	23:40 (10.04.2022)	00 (11.04.2022)	8:19 hrs	LINE CHARGED
1266	11-Apr-2022	HASSAN	66	BHADRA-SHMG1	bhadra_gen	21:43 (10.04.2022)	00 (11.04.2022)	4:54 hrs	LINE CHARGED
1267	11-Apr-2022	HASSAN	66	BHADRA-SHMG2	bhadra_gen	21:15 (10.04.2022)	05 (11.04.2022)	2:50 hrs	LINE CHARGED
1268	11-Apr-2022	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41 (11.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1269	11-Apr-2022	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	10:54 (24.03.2022)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1270	11-Apr-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN,LINE FAULT
1271	11-Apr-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1272	11-Apr-2022	HASSAN	220	VARAHI-SHIMOGA2	VARAHI_GEN	18:47(03.04.2022)			LINE OPEN,LINE FAULT
1273	11-Apr-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1274	11-Apr-2022	HASSAN	110	LPH-MGHE 1	lph_gen	20:31 (10.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1275	11-Apr-2022	HASSAN	220	SHARAVATY-SIRISI 1	sharavathy_gen	20:26 (10.04.2022 )			LINE OPEN,LINE FAULT
1276	11-Apr-2022	HASSAN	220	SHARAVATY-TALAGUPPA 2	sharavathy_gen	20:16 (10.04.2022)			LINE OPEN,LINE FAULT
1277	11-Apr-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	10:05 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1278	11-Apr-2022	HASSAN	220	HV2	KADUR_220	13:14	13:17	0:03	HAND TRIPPED
1279	11-Apr-2022	HASSAN	110	HV2	MSEZ_220	10:06	15:32	5:26	LINE CLEAR AVAILED
1280	11-Apr-2022	HASSAN	110	HV2	BARANGI_110	10:44	12:39	1:55	LINE CLEAR AVAILED
1281	11-Apr-2022	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	21:20	21:40	0:20	LINE FAULT
1282	11-Apr-2022	HASSAN	110	BRAHMAV-NITTUR	BRAHMAVARA_110	21:00	21:05	0:05	HAND TRIPPED
1283	11-Apr-2022	HASSAN	110	JOG110-AMBTR1	JOG_110	10:05	17:57	7:52	LINE CLEAR AVAILED
1284	11-Apr-2022	HASSAN	110	HV1	JOG_110	10:05	17:56	7:51	LINE CLEAR AVAILED
1285	11-Apr-2022	HASSAN	110	HV2	JOG_110	10:05	17:56	7:51	LINE CLEAR AVAILED
1286	11-Apr-2022	HASSAN	110	JOG110-MGHE	JOG_110	10:05	17:56	7:51	LINE CLEAR AVAILED
1287	11-Apr-2022	HASSAN	110	KADUR-AJAMPURA	KADUR_220	13:14	13:18	0:04	LINE FAULT
1288	11-Apr-2022	HASSAN	110	HV2	KADUR_220	13:14	13:18	0:04	TRANSFORMER FAULT
1289	11-Apr-2022	HASSAN	110	LV1	KADUR_220	13:14	13:18	0:04	TRANSFORMER FAULT
1290	11-Apr-2022	HASSAN	110	LV2	KADUR_220	13:14	13:18	0:04	TRANSFORMER FAULT
1291	11-Apr-2022	HASSAN	110	KADUR-NERELEKERE	KADUR_220	13:14	13:18	0:04	LINE FAULT
1292	11-Apr-2022	HASSAN	110	KADUR-NGNHL	KADUR_220	13:14	13:18	0:04	LINE FAULT
1293	11-Apr-2022	HASSAN	110	KADUR-TNGL	KADUR_220	13:14	13:18	0:04	LINE FAULT
1294	11-Apr-2022	HASSAN	110	KADUR-YGTI	KADUR_220	13:14	13:18	0:04	LINE FAULT
1295	11-Apr-2022	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARAR_110	17:18	17:23	0:05	LINE FAULT
1296	11-Apr-2022	HASSAN	110	NERALA-TEREKERE	NERALEKERE_110	8:49	12:34	3:45	LINE CLEAR AVAILED
1297	11-Apr-2022	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	20:32	21:05	0:33	LINE FAULT
1298	11-Apr-2022	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	21:21	21:33	0:12	LINE FAULT
1299	11-Apr-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	19:11	19:20	0:09	LINE FAULT
1300	11-Apr-2022	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	19:18	19:20	0:02	LINE FAULT
1301	11-Apr-2022	HASSAN	66	HV1	CHIKKAKondagola_66	9:37	10:22	0:45	HAND TRIPPED
1302	11-Apr-2022	HASSAN	66	CRPATNA-CRPTNA1	CHANNARAYAPATNA_220	18:53	19:10	0:17	LINE FAULT
1303	11-Apr-2022	HASSAN	66	CRPATNA-CRPTNA2	CHANNARAYAPATNA_220	18:53	19:10	0:17	LINE FAULT
1304	11-Apr-2022	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_220	18:53	19:10	0:17	LINE FAULT
1305	11-Apr-2022	HASSAN	66	CRPATNA-SBELAGOLA	CHANNARAYAPATNA_220	18:53	19:10	0:17	LINE FAULT
1306	11-Apr-2022	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	23:33	23:45	0:12	LINE FAULT
1307	11-Apr-2022	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	14:30	19:15	4:45	LINE CLEAR AVAILED
1308	11-Apr-2022	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	14:30	19:15	4:45	LINE CLEAR AVAILED
1309	11-Apr-2022	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	12:25	12:50	0:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1310	11-Apr-2022	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	12:25	12:30	0:05	LINE CLEAR AVAILED
1311	11-Apr-2022	MYSURU	66	TUBINKERE-G UKKADA	NO STATIONS EFFECTED	11:32	11:43	0:11	HAND TRIPPED
1312	11-Apr-2022	MYSURU	66	TUBINKERE-G UKKADA	GARUDANAUKADDA_66SRIRANGAPATNA_66	18:53	19:24	0:30	LINE FAULT
1313	11-Apr-2022	MYSURU	66	HEBBANI-VADKEPURA	KIRUGAVALU_66 KIRUGAVALU_66MALIYURU_66	8:09	8:18	0:09	LINE FAULT
1314	11-Apr-2022	MYSURU	66	HV3	KUSHALNAGARA_220	9:58	14:38	4:39	LINE CLEAR AVAILED
1315	11-Apr-2022	MYSURU	66	BEGUR 220-SARGUR	SANTHESARAGUR_66HDKOTE_66ANTHARSANTHE_66YEREHALLI_66CHANDRAVADI_66	18:43	18:52	0:09	LINE FAULT
1316	11-Apr-2022	MYSURU	66	BEGUR 220-HARVEY	HARVEY_66	18:43	18:51	0:08	LINE FAULT
1317	11-Apr-2022	MYSURU	66	BEGUR 220-BEGUR 1	B MATKERE_66BEGUR_66	18:43	18:54	0:11	LINE FAULT
1318	11-Apr-2022	MYSURU	66	BEGUR 220-BEGUR 2	NO STATIONS EFFECTED	18:43	18:54	0:11	LINE FAULT
1319	11-Apr-2022	MYSURU	66	BEGUR 220-SARGUR	SANTHESARAGUR_66HDKOTE_66ANTHARSANTHE_66YEREHALLI_66CHANDRAVADI_66	18:57	19:13	0:16	LINE FAULT
1320	11-Apr-2022	MYSURU	66	BEGUR 220-HARVEY	HARVEY_66	18:57	19:11	0:14	LINE FAULT
1321	11-Apr-2022	MYSURU	66	BEGUR 220-BEGUR 1	B MATKERE_66BEGUR_66	18:57	19:12	0:15	LINE FAULT
1322	11-Apr-2022	MYSURU	66	BEGUR 220-BEGUR 2	NO STATIONS EFFECTED	18:57	19:11	0:14	LINE FAULT
1323	11-Apr-2022	MYSURU	66	BEGUR 220-SARGUR	SANTHESARAGUR_66HDKOTE_66ANTHARSANTHE_66YEREHALLI_66CHANDRAVADI_66	19:18	20:02	0:44	LINE FAULT
1324	11-Apr-2022	MYSURU	66	BEGUR 220-HARVEY	HARVEY_66	19:18	19:59	0:41	LINE FAULT
1325	11-Apr-2022	MYSURU	66	BEGUR 220-BEGUR 1	B MATKERE_66BEGUR_66	19:18	20:00	0:42	LINE FAULT
1326	11-Apr-2022	MYSURU	66	BEGUR 220-BEGUR 2	NO STATIONS EFFECTED	19:18	20:01	0:43	LINE FAULT
1327	11-Apr-2022	MYSURU	66	BESAGRALLI-DUNDANAHALLI	NO STATIONS EFFECTED	21:23	21:31	0:07	HAND TRIPPED
1328	11-Apr-2022	MYSURU	66	HAMPAPURA-KOPPA	KOPPA_66BESAGARAHALLI_66	15:55	17:50	1:55	LINE CLEAR AVAILED
1329	11-Apr-2022	MYSURU	66	KOPPA-BESAGARAHALLI	KOPPA_66BESAGARAHALLI_66DUNDANAHALLI_66	21:00	21:20	0:20	LINE FAULT
1330	11-Apr-2022	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	18:53	19:07	0:14	LINE FAULT
1331	11-Apr-2022	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORMYS_66SUTTUR_66	5:40	5:50	0:10	LINE FAULT
1332	11-Apr-2022	MYSURU	66	DUNDANAHALLI-HULIYUR DURGA	NO STATIONS EFFECTED	18:45	21:20	2:34	LINE CLEAR AVAILED
1333	11-Apr-2022	MYSURU	66	DEVNOOR MYSORE-RAJEEV NAGARA	NO STATIONS EFFECTED	8:34	9:24	0:49	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1334	11-Apr-2022	MYSURU	66	VAJMANGALA-DEVNOOR MYSORE	DEVANOORMYS_66	8:35	9:14	0:39	LINE FAULT
1335	11-Apr-2022	MYSURU	66	HV1	GAMANAHALLY_66	10:33	12:30	1:56	LINE CLEAR AVAILED
1336	11-Apr-2022	MYSURU	66	HV2	GAMANAHALLY_66	12:02	13:50	1:47	LINE CLEAR AVAILED
1337	11-Apr-2022	MYSURU	66	HV4	SFCSHIVA_66	9:51	11:55	2:03	LINE CLEAR AVAILED
1338	11-Apr-2022	MYSURU	66	SFCSHIVA_66	NO STATION AFFECTED	8:09	8:11	0:02	LINE FAULT
1339	11-Apr-2022	MYSURU	66	SFCSHIVA_66	NO STATIONS EFFECTED	8:08	8:14	0:06	LINE FAULT
1340	11-Apr-2022	MYSURU	66	SFCSHIVA_66	NO STATIONS EFFECTED	18:20	21:18	2:58	LINE FAULT
1341	11-Apr-2022	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	10:05	10:15	0:10	LINE FAULT
1342	11-Apr-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1343	11-Apr-2022	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1344	11-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1345	11-Apr-2022	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1346	11-Apr-2022	MYSURU	66	HV2	HARVEY_66	21:45:08 (11.04.2022)			TRANSFORMER OPEN ,TRANSFORMER FAULT
1347	11-Apr-2022	MYSURU	66	HV1	SANIVARASANTHE_66	15:29:47 (11.04.2022)			TRANSFORMER OPEN ,TRANSFORMER FAULT
1348	11-Apr-2022	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:16	18:03	6:47	LINE CLEAR AVAILED
1349	11-Apr-2022	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:15	18:02	6:47	LINE CLEAR AVAILED
1350	11-Apr-2022	TUMKUR	110	TR-1	TURUVEKERE_110	14:15	14:26	0:11	TRANSFORMER FAULT
1351	11-Apr-2022	TUMKUR	110	TR-1	KALLUR_110	2:20	2:57	0:36	TRANSFORMER FAULT
1352	11-Apr-2022	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_110,	18:57	19:13	0:15	LINE FAULT
1353	11-Apr-2022	TUMKUR	110	SHEETTIKERE- HANDANKERE(KB CROSS 220)	SHEETTIKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	12:37	12:46	0:09	HAND TRIPPED
1354	11-Apr-2022	TUMKUR	66	TR-1	BEVINAHALLI_66	11:55	12:32	0:37	LINE CLEAR AVAILED
1355	11-Apr-2022	TUMKUR	66	TR-2	BEVINAHALLI_66	12:40	12:55	0:15	LINE CLEAR AVAILED
1356	11-Apr-2022	TUMKUR	66	CHITRADURGA 220kV- SUZLON 2	SUZLON2_IPP_66	9:14	9:29	0:15	LINE CLEAR AVAILED
1357	11-Apr-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:20	18:27	0:07	LINE FAULT
1358	11-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	7:27	7:36	0:08	LINE FAULT
1359	11-Apr-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:46	20:54	0:07	LINE FAULT
1360	11-Apr-2022	TUMKUR	66	TR-1	HONNALI_66	13:47	13:57	0:09	LINE CLEAR AVAILED
1361	11-Apr-2022	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR IPP_66	BPCLSOLAR_IPP_66	9:27	9:45	0:17	HAND TRIPPED
1362	11-Apr-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	12:01	12:49	0:48	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1363	11-Apr-2022	TUMKUR	66	MADHUGIRI 66KV- BADAVANAHALLI	BADAVANAHALLI_66	6:33	7:23	0:49	LINE FAULT
1364	11-Apr-2022	TUMKUR	66	NAGALAMADIKE- PAVAGADA220KV	NAGALMADIKE_66	16:35	16:40	0:05	LINE CLEAR AVAILED
1365	11-Apr-2022	TUMKUR	66	NAGALAMADIKE- MUNIRAJ SOLAR IPP_66	MUNIRAJ SOLAR_IPP_66	14:25	16:35	2:10	LINE CLEAR AVAILED
1366	11-Apr-2022	TUMKUR	66	NAGALAMADIKE- MUNIRAJ SOLAR IPP_66	MUNIRAJ SOLAR_IPP_66	17:35	19:50	2:15	LINE CLEAR AVAILED
1367	11-Apr-2022	TUMKUR	66	NAGALAMADIKE-RNS INFRA SOLAR IPP_66	RNS INFRA SOLAR_IPP_66	14:25	16:35	2:10	LINE CLEAR AVAILED
1368	11-Apr-2022	TUMKUR	66	NAGALAMADIKE-RNS INFRA SOLAR IPP_66	RNS INFRA SOLAR_IPP_66	17:35	19:50	2:15	LINE CLEAR AVAILED
1369	11-Apr-2022	TUMKUR	66	NAGALAMADIKE- SUNDER RAJU SOLAR IPP_66	SUNDER RAJU SOLAR_IPP_66	14:25	16:35	2:10	LINE CLEAR AVAILED
1370	11-Apr-2022	TUMKUR	66	NAGALAMADIKE- SUNDER RAJU SOLAR IPP_66	SUNDER RAJU SOLAR_IPP_66	17:35	19:50	2:15	LINE CLEAR AVAILED
1371	11-Apr-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	14:00	14:24	0:24	LINE CLEAR AVAILED
1372	11-Apr-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	17:40	17:50	0:10	LINE FAULT
1373	11-Apr-2022	TUMKUR	66	TR-2 (LV SIDE)	THALLAKK_220	18:13	18:42	0:29	HAND TRIPPED