

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 03.12.2019 TO 09.12.2019**

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	3-Dec-19	BAGALKOT	110	BIJAPUR220-ENERGAON	BIJAPUR_220	5:58	6:41	0:43	LINE FAULT
2	3-Dec-19	BAGALKOT	110	RON2-GAJENDRAGAD	GAJENDRAGAD_110	10:30	12:11	1:41	LINE FAULT
3	3-Dec-19	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	10:30	23:59	13:29	LINE CLEAR AVAILED
4	3-Dec-19	BAGALKOT	220	CHIKKODI-GHATAPRABHA	CHIKKODI_220	10:38	18:08	7:30	NFBC ISSUED
5	3-Dec-19	BAGALKOT	220	DHONI1&2-GADAG	GADAG_220	17:45	23:59	6:14	LINE CLEAR AVAILED
6	3-Dec-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	0:00	9:06	9:06	LINE CLEAR AVAILED
7	3-Dec-19	BAGALKOT	110	HUBLI220-KADANAKOPPA	KADANAKOPPA_110	16:40	18:55	2:15	MAIN SUPPLY FAILURE
8	3-Dec-19	BAGALKOT	110	KAVALAWADA-KADANAKOPPA	KADANAKOPPA_110	16:41	23:59	7:18	LINE CLEAR AVAILED
9	3-Dec-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	11:25	11:33	0:08	TRANSFORMER FAULT
10	3-Dec-19	BAGALKOT	110	GAMESH-RON	RON_110	11:00	11:14	0:14	MAIN SUPPLY FAILURE
11	3-Dec-19	BAGALKOT	110	RON-GAJENDRAGHAD1	GAJENDRAGHAD_110	11:00	11:04	0:04	MAIN SUPPLY FAILURE
12	3-Dec-19	BAGALKOT	110	NAREGAL-RON	RON_110	10:28	10:52	0:24	MAIN SUPPLY FAILURE
13	3-Dec-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	10:28	10:50	0:22	LINE FAULT
14	3-Dec-19	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	11:18	11:22	0:04	TRANSFORMER FAULT
15	3-Dec-19	BAGALKOT	110	110/11KV,HV1	MALLIGERE_110	13:21	15:16	1:55	LINE CLEAR AVAILED
16	3-Dec-19	BAGALKOT	110	110/11KV,HV4	KULIGOD_110	9:23	10:35	1:12	TRANSFORMER FAULT
17	3-Dec-19	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:35	10:45	0:10	LINE FAULT
18	3-Dec-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	16:14	16:24	0:10	MAIN SUPPLY FAILURE
19	3-Dec-19	BENGALURU	66	HEBBAL 220 - C STATION 1 & 2	C STATION	16:14	16:24	0:10	MAIN SUPPLY FAILURE
20	3-Dec-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	16:14	16:24	0:10	MAIN SUPPLY FAILURE
21	3-Dec-19	BENGALURU	220	MANYATHA 220 - HEBBAL 220	HEBBAL 220	16:14	16:49	0:35	LINE FAULT
22	3-Dec-19	BENGALURU	66	HEBBAL 220 - IISC	IISC	16:14	16:24	0:10	LINE CLEAR AVAILED
23	3-Dec-19	BENGALURU	66	NANGALI - KEMPANAHALLI	NANGALI	15:55	16:55	1:00	LINE CLEAR AVAILED
24	3-Dec-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	13:25	13:28	0:02	LINE FAULT
25	3-Dec-19	BENGALURU	66	TELECOM LAYOUT - NRS 1	TELECOM LAYOUT	17:30	18:08	0:37	LINE FAULT
26	3-Dec-19	BENGALURU	66	HV2	SULIBELE	13:01	13:10	0:08	TRANSFORMER FAULT
27	3-Dec-19	BENGALURU	66	HV1	MUDIYANUR	11:06	12:43	1:36	TRANSFORMER FAULT
28	3-Dec-19	BENGALURU	66	HV2	MUDIYANUR	12:25	12:35	0:10	TRANSFORMER FAULT
29	3-Dec-19	BENGALURU	66	HV2	TK HALLI 220	11:57	18:31	6:33	LINE CLEAR AVAILED
30	3-Dec-19	BENGALURU	66	HV2	TK HALLI 220	18:33	18:37	0:04	TRANSFORMER FAULT
31	3-Dec-19	BENGALURU	66	HV1	JAYADEVA	14:23	15:32	1:09	LINE CLEAR AVAILED
32	3-Dec-19	BENGALURU	66	HV2	TELECOM LAYOUT	12:07	13:57	1:49	LINE CLEAR AVAILED
33	3-Dec-19	GULBARGA	220	HUMNB 220 -HALBURGA 1	HALBARGA_220	0:00	6:38	6:38	LINE CLEAR AVAILED
34	3-Dec-19	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	0:00	12:50	12:50	LINE CLEAR AVAILED
35	3-Dec-19	GULBARGA	220	HV2	SHAHPUR_220	15:00	17:25	2:25	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
36	3-Dec-19	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	11:04	13:32	2:28	NFBC ISSUED
37	3-Dec-19	GULBARGA	110	KAPANOOR-MADYAL	MADYAL_110	5:50	5:55	0:05	LINE FAULT
38	3-Dec-19	GULBARGA	110	KAPANOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	15:25	15:42	0:17	LINE FAULT
39	3-Dec-19	GULBARGA	110	HV2	GULBARGASOUTH_110	13:35	13:45	0:10	LINE CLEAR AVAILED
40	3-Dec-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	4:07	4:14	0:07	LINE FAULT
41	3-Dec-19	GULBARGA	110	HV2	CHINCHOLI_110	5:45	23:59	18:14	TRANSFORMER FAULT
42	3-Dec-19	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHPUR_110	0:00	23:59	23:59	LINE FAULT
43	3-Dec-19	GULBARGA	110	RAJESHWAR-WARADA SOLAR	WARADA SOLAR_110	0:00	7:00	7:00	LINE CLEAR AVAILED
44	3-Dec-19	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	1:10	1:25	0:15	LINE FAULT
45	3-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	6:54	6:54	LINE CLEAR AVAILED
46	3-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	1:35	1:35	LINE CLEAR AVAILED
47	3-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:43	23:59	7:16	LINE CLEAR AVAILED
48	3-Dec-19	HASSAN	220	HV1	KEMAR_220	9:53	11:53	2:00	LINE CLEAR AVAILED
49	3-Dec-19	HASSAN	220	HV1	KEMAR_220	12:33	12:35	0:02	HAND TRIPPED
50	3-Dec-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:54	11:53	1:59	LINE CLEAR AVAILED
51	3-Dec-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	12:34	13:01	0:27	HAND TRIPPED
52	3-Dec-19	HASSAN	220	HV2	MSEZ_220	9:48	15:42	5:54	LINE CLEAR AVAILED
53	3-Dec-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:55	11:52	1:57	LINE CLEAR AVAILED
54	3-Dec-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	12:34	13:01	0:27	HAND TRIPPED
55	3-Dec-19	HASSAN	110	LV1	KEMAR_220	9:53	11:54	2:01	LINE CLEAR AVAILED
56	3-Dec-19	HASSAN	110	LV1	KEMAR_220	12:33	12:35	0:02	HAND TRIPPED
57	3-Dec-19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	9:49	11:54	2:05	LINE CLEAR AVAILED
58	3-Dec-19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	12:33	12:37	0:04	HAND TRIPPED
59	3-Dec-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	12:33	13:24	0:51	HAND TRIPPED
60	3-Dec-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	9:49	11:54	2:05	LINE CLEAR AVAILED
61	3-Dec-19	HASSAN	110	KEMAR-MOODABIDRE	KEMAR_220	0:00	14:28	14:28	LINE CLEAR AVAILED
62	3-Dec-19	HASSAN	110	KEMAR-MOODABIDRE	KEMAR_220	14:47	23:59	9:12	LINE CLEAR AVAILED
63	3-Dec-19	HASSAN	110	LV2	MSEZ_220	9:46	15:43	5:57	LINE CLEAR AVAILED
64	3-Dec-19	HASSAN	110	ANAVATTI-BARNGI	ANAVATTI_110	11:20	11:30	0:10	LINE CLEAR AVAILED
65	3-Dec-19	HASSAN	110	ANAVATTI-BARNGI	ANAVATTI_110	15:05	15:20	0:15	LINE CLEAR AVAILED
66	3-Dec-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	9:51	12:10	2:19	LINE CLEAR AVAILED
67	3-Dec-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	12:32	12:43	0:11	HAND TRIPPED
68	3-Dec-19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	9:48	11:54	2:06	LINE CLEAR AVAILED
69	3-Dec-19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	12:31	12:37	0:06	HAND TRIPPED
70	3-Dec-19	HASSAN	110	MOODABIDRE-GURUPURA	MOODABIDRE_110	14:20	14:43	0:23	HAND TRIPPED
71	3-Dec-19	HASSAN	110	HV1	MOODABIDRE_110	12:25	14:51	2:26	LINE CLEAR AVAILED
72	3-Dec-19	HASSAN	110	HV2	MOODABIDRE_110	12:25	15:09	2:44	LINE CLEAR AVAILED
73	3-Dec-19	HASSAN	110	MOODABIDRE-KEMAR	MOODABIDRE_110	14:29	14:34	0:05	HAND TRIPPED
74	3-Dec-19	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	15:50	16:13	0:23	LINE FAULT
75	3-Dec-19	HASSAN	66	HV2	BELUR_66	15:35	17:05	1:30	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
76	3-Dec-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:30	11:01	0:31	LINE FAULT
77	3-Dec-19	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	10:54	10:58	0:04	LINE FAULT
78	3-Dec-19	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	10:12	10:20	0:08	LINE FAULT
79	3-Dec-19	HASSAN	66	CHANNAR-SHETTIHALLY	CHANNARAYAPATNA_66	10:12	10:26	0:14	LINE FAULT
80	3-Dec-19	MYSORE	66	HV2	BOMMALAPURA_66	12:42	13:52	1:10	LINE CLEAR AVAILED
81	3-Dec-19	MYSORE	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	6:30	6:34	0:04	LINE FAULT
82	3-Dec-19	MYSORE	66	SANTHE SARAGUR-B MATTGERE	B MATKERE_66	6:03	6:17	0:13	LINE FAULT
83	3-Dec-19	MYSORE	66	HV1	SANTHEBACHALLI_66	13:20	13:25	0:05	HAND TRIPPED
84	3-Dec-19	MYSORE	66	HV2	SANTHEBACHALLI_66	12:13	12:52	0:39	LINE CLEAR AVAILED
85	3-Dec-19	MYSORE	66	TALAKADU-PARINAMIPURA	THALAKADU_66	9:21	18:22	9:01	LINE CLEAR AVAILED
86	3-Dec-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66 BASARALU_66 KESLAGERE_66	9:44	9:51	0:06	LINE FAULT
87	3-Dec-19	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	11:22	18:23	7:01	LINE CLEAR AVAILED
88	3-Dec-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	8:33	9:05	0:32	LINE FAULT
89	3-Dec-19	TUMKUR	66	TR-4(HV SIDE)	CHITRADURGA_220	11:49	11:59	0:09	LINE CLEAR AVAILED
90	3-Dec-19	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	11:39	18:26	6:46	LINE CLEAR AVAILED
91	3-Dec-19	TUMKUR	66	CHITRADURGA 220kV- SUZLON 1	SUZLON1_IPP_66	11:50	11:56	0:05	LINE CLEAR AVAILED
92	3-Dec-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:50	11:57	0:07	LINE CLEAR AVAILED
93	3-Dec-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:07	18:30	0:23	LINE CLEAR AVAILED
94	3-Dec-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:36	11:50	0:14	LINE FAULT
95	3-Dec-19	TUMKUR	66	SOKKE-JAGLUR	JAGALUR_66	15:15	15:23	0:08	HAND TRIPPED
96	3-Dec-19	TUMKUR	66	TAVAREKERE (C)- GOPPENAHALLI	TAVAREKERE(C)_66	11:18	11:22	0:04	LINE FAULT
97	3-Dec-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	11:18	11:23	0:04	TRANSFORMER FAULT
98	3-Dec-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	11:18	11:23	0:04	TRANSFORMER FAULT
99	3-Dec-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:53	10:44	1:51	LINE FAULT
100	3-Dec-19	TUMKUR	66	VENKATAPURA- GOWRIBIDNUR	VENKATAPUR_66	1:49	2:33	0:44	LINE FAULT
101	3-Dec-19	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	1:49	9:10	7:20	LINE FAULT
102	4-Dec-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	8:38	15:45	7:07	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
103	4-Dec-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	10:43	20:09	9:26	LINE CLEAR AVAILED
104	4-Dec-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	3:56	8:56	5:00	TRANSFORMER FAULT
105	4-Dec-19	BAGALKOT	220	ADPH2-BAGEWADI	BAGEWADI_220	13:07	18:34	5:27	NFBC ISSUED
106	4-Dec-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	12:15	13:58	1:43	LINE CLEAR AVAILED
107	4-Dec-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	4:37	4:50	0:13	LINE FAULT
108	4-Dec-19	BAGALKOT	220	DHONI1&2-GADAG	GADAG_220	0:00	15:31	15:31	LINE CLEAR AVAILED
109	4-Dec-19	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	23:43	23:59	0:16	LINE FAULT
110	4-Dec-19	BAGALKOT	110	110/11KV,HV2	HIDIKALDAM_110	15:56	17:01	1:05	LINE CLEAR AVAILED
111	4-Dec-19	BAGALKOT	110	110/11KV,HV1	KALAGATAGI_110	13:55	14:50	0:55	LINE CLEAR AVAILED
112	4-Dec-19	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	10:06	13:44	3:38	LINE CLEAR AVAILED
113	4-Dec-19	BAGALKOT	110	GAMESH WIND-KULIGOD	KULIGOD_110	6:30	6:44	0:14	LINE FAULT
114	4-Dec-19	BAGALKOT	110	110/33KV,HV1	KUMATA_110,ANKOLA_33,HONNAVAR_33	20:16	20:33	0:17	MAIN SUPPLY FAILURE
115	4-Dec-19	BAGALKOT	110	110/11KV,HV3	KUMATA_110	20:16	20:30	0:14	MAIN SUPPLY FAILURE
116	4-Dec-19	BAGALKOT	110	110/11KV,HV2	ZALKI_110	10:50	10:55	0:05	TRANSFORMER FAULT
117	4-Dec-19	BAGALKOT	110	110/11KV,HV2	ZALKI_110	16:24	17:30	1:06	LINE CLEAR AVAILED
118	4-Dec-19	BAGALKOT	110	ZALKI-INCHIGERI	INCHIGERI_110	15:44	15:49	0:05	LINE CLEAR AVAILED
119	4-Dec-19	BAGALKOT	110	110/33KV,HV3	TARIHAL_110,DUMMAWAD_33,INDUSTRIAL ESTATE_33	10:24	12:51	2:27	LINE CLEAR AVAILED
120	4-Dec-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	20:16	22:13	1:57	LINE FAULT
121	4-Dec-19	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	20:16	22:25	2:09	LINE FAULT
122	4-Dec-19	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	0:00	18:20	18:20	LINE CLEAR AVAILED
123	4-Dec-19	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	11:25	11:57	0:32	LINE CLEAR AVAILED
124	4-Dec-19	BAGALKOT	220	MK HUBLI220-NARENDRA1	MK HUBLI_220	11:57	19:33	7:36	LINE CLEAR AVAILED
125	4-Dec-19	BAGALKOT	220	220/110KV,HV2,LV2	MK HUBLI_220	14:56	19:11	4:15	LINE CLEAR AVAILED
126	4-Dec-19	BAGALKOT	110	RANEENNUR-TUMMINKATTI	TUMMINKATTI_110	21:18	21:25	0:07	LINE FAULT
127	4-Dec-19	BAGALKOT	110	110/33KV,HV1	MK HUBLI_110,GANDIGWAD_33,SOLAR_33	13:10	13:27	0:17	LINE CLEAR AVAILED
128	4-Dec-19	BAGALKOT	110	CHIKKODI-RAIBAG	RAIBAG_110	15:09	17:08	1:59	NFBC ISSUED
129	4-Dec-19	BENGALURU	66	SUBRAMNYAPURA 220 - REMCO 2	GLOBAL TECH PARK,R R NAGAR	8:30	9:27	0:57	LINE FAULT
130	4-Dec-19	BENGALURU	66	HV1	MUDIYANUR	2:05	2:15	0:10	TRANSFORMER FAULT
131	4-Dec-19	BENGALURU	66	HV2	NANGALI	9:35	10:10	0:35	TRANSFORMER FAULT
132	4-Dec-19	BENGALURU	66	HV1	MUDIYANUR	2:05	2:15	0:10	TRANSFORMER FAULT
133	4-Dec-19	BENGALURU	66	HV2	MUDIYANUR	14:30	16:10	1:40	LINE CLEAR AVAILED
134	4-Dec-19	BENGALURU	66	HV1	MUDIYANUR	15:15	17:00	1:45	LINE CLEAR AVAILED
135	4-Dec-19	BENGALURU	66	HV1	MUDIYANUR	6:20	6:40	0:20	TRANSFORMER FAULT
136	4-Dec-19	BENGALURU	66	HV2	CHANDAPURA	17:44	17:55	0:10	TRANSFORMER FAULT
137	4-Dec-19	BENGALURU	66	HV2	EPIP 220	1:30	2:49	1:18	TRANSFORMER FAULT
138	4-Dec-19	GULBARGA	110	HV2	SHAHAPUR_220	11:27	12:52	1:25	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
139	4-Dec-19	GULBARGA	110	BUSCOUPLER	SEDAM_220	12:15	14:10	1:55	LINE CLEAR AVAILED
140	4-Dec-19	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHPUR_110	0:00	0:36	0:36	LINE FAULT
141	4-Dec-19	GULBARGA	110	HV3	GULBARGASOUTH_110	17:20	17:25	0:05	TRANSFORMER FAULT
142	4-Dec-19	GULBARGA	110	HV2	GULBARGASOUTH_110	12:25	16:25	4:00	TRANSFORMER FAULT
143	4-Dec-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITAKAL_110,KONKAL_110	18:25	18:30	0:05	LINE FAULT
144	4-Dec-19	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	18:25	18:30	0:05	LINE FAULT
145	4-Dec-19	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	20:15	20:30	0:15	LINE FAULT
146	4-Dec-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITAKAL_110,KONKAL_110	20:15	20:30	0:15	LINE FAULT
147	4-Dec-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITAKAL_110,KONKAL_110	21:55	22:00	0:05	LINE FAULT
148	4-Dec-19	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	21:55	23:59	2:04	LINE FAULT
149	4-Dec-19	GULBARGA	110	LV1	ITTAGI_220	22:35	22:45	0:10	TRANSFORMER FAULT
150	4-Dec-19	GULBARGA	66	ITTAGI-RNWSLR	ITTAGI_220	9:40	10:00	0:20	LINE CLEAR AVAILED
151	4-Dec-19	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66,KUDLIGI_66,HANASI_66	10:24	10:34	0:10	LINE FAULT
152	4-Dec-19	GULBARGA	66	ITTAGI-KUDLIGI2	CJ HALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANVEKAL_66,CHORNOOR_66	10:24	10:34	0:10	LINE FAULT
153	4-Dec-19	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALI_66,GIRIYAPURA_66, MAGALA_66,SOVENHALLI_66	12:35	13:35	1:00	LINE CLEAR AVAILED
154	4-Dec-19	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUT_66,UJJAINI_66,BENNEHALLI_66	22:35	22:45	0:10	LINE FAULT
155	4-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:58	6:58	LINE CLEAR AVAILED
156	4-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:46	23:59	1:13	LINE CLEAR AVAILED
157	4-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:10	23:59	0:49	HAND TRIPPED
158	4-Dec-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:15	11:34	0:19	LINE CLEAR AVAILED
159	4-Dec-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:35	12:01	0:26	LINE CLEAR AVAILED
160	4-Dec-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	11:16	11:37	0:21	LINE CLEAR AVAILED
161	4-Dec-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	11:59	12:03	0:04	LINE CLEAR AVAILED
162	4-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRMSG_220	11:16	12:02	0:46	LINE CLEAR AVAILED
163	4-Dec-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:17	12:03	0:46	LINE CLEAR AVAILED
164	4-Dec-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	11:32	13:28	1:56	LINE CLEAR AVAILED
165	4-Dec-19	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	9:09	17:07	7:58	LINE CLEAR AVAILED
166	4-Dec-19	HASSAN	110	HV1	KONAJE_110	10:02	17:09	7:07	LINE CLEAR AVAILED
167	4-Dec-19	HASSAN	110	HV2	KONAJE_110	10:02	17:38	7:36	LINE CLEAR AVAILED
168	4-Dec-19	HASSAN	110	HV3	KONAJE_110	10:02	17:09	7:07	LINE CLEAR AVAILED
169	4-Dec-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	13:00	15:13	2:13	NFBC ISSUED
170	4-Dec-19	HASSAN	66	HV1	DODDAKADANUR_66	13:00	15:25	2:25	NFBC ISSUED
171	4-Dec-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	12:48	15:28	2:40	LINE FAULT
172	4-Dec-19	HASSAN	66	HV1	HIRISAVE_66	11:19	12:27	1:08	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
173	4-Dec-19	HASSAN	66	HV1	HIRISAVE_66	13:51	14:32	0:41	LINE CLEAR AVAILED
174	4-Dec-19	HASSAN	66	HV2	HIRISAVE_66	12:27	13:51	1:24	LINE CLEAR AVAILED
175	4-Dec-19	HASSAN	66	Lv1	HOLENARASIPURA_220	11:06	13:42	2:36	LINE CLEAR AVAILED
176	4-Dec-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	12:47	15:25	2:38	LINE CLEAR AVAILED
177	4-Dec-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	12:48	15:25	2:37	LINE CLEAR AVAILED
178	4-Dec-19	MYSORE	66	HV2	BOMMALAPURA_66	12:53	13:57	1:03	LINE CLEAR AVAILED
179	4-Dec-19	MYSORE	66	DR PETE-KUNTHUR	JANNUR_66, MUGUR_66, SANTHEMARAHALLI_66, THAYURU_66	18:04	18:11	0:07	LINE FAULT
180	4-Dec-19	MYSORE	66	HV1	DUNDANAHALLI_66	10:36	13:50	3:13	LINE CLEAR AVAILED
181	4-Dec-19	MYSORE	66	HV1	DUNDANAHALLI_66	17:02	17:14	0:12	LINE CLEAR AVAILED
182	4-Dec-19	MYSORE	66	METAGALLI-SR PATNA	SRIRANGAPATNA_66	10:12	14:01	3:49	NFBC ISSUED
183	4-Dec-19	MYSORE	66	HV1	SRIRANGAPATNA_66	10:00	14:15	4:14	LINE CLEAR AVAILED
184	4-Dec-19	MYSORE	66	HV2	SRIRANGAPATNA_66	10:00	14:15	4:14	LINE CLEAR AVAILED
185	4-Dec-19	MYSORE	66	HV1	SUNTIKOPPA_66	10:05	16:33	6:28	LINE CLEAR AVAILED
186	4-Dec-19	MYSORE	66	HV2	THALAKADU_66	12:45	13:55	1:10	LINE CLEAR AVAILED
187	4-Dec-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66, TARIPURA_66	13:59	14:04	0:04	LINE FAULT
188	4-Dec-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66, TARIPURA_66	15:15	15:19	0:03	LINE FAULT
189	4-Dec-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66, TARIPURA_66	15:32	15:46	0:13	LINE FAULT
190	4-Dec-19	TUMKUR	110	TR-1	KADABA_110	13:28	15:17	1:49	LINE CLEAR AVAILED
191	4-Dec-19	TUMKUR	110	TR-1	KGTEMPLE_110	10:38	14:09	3:30	LINE CLEAR AVAILED
192	4-Dec-19	TUMKUR	110	K G TEMPLE-NITTUR220	KGTEMPLE_110	13:00	13:43	0:43	LINE CLEAR AVAILED
193	4-Dec-19	TUMKUR	110	TR-2	SAMPIGE_110	14:52	14:58	0:05	TRANSFORMER FAULT
194	4-Dec-19	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	10:56	20:00	9:03	MAIN SUPPLY FAILURE
195	4-Dec-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:31	12:05	1:34	LINE CLEAR AVAILED
196	4-Dec-19	TUMKUR	66	GUTUR 66-DAVANGERE SRS	GUTUR_66	10:36	12:06	1:30	LINE CLEAR AVAILED
197	4-Dec-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:54	19:45	8:50	LINE CLEAR AVAILED
198	4-Dec-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	10:54	19:42	8:48	LINE CLEAR AVAILED
199	4-Dec-19	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	12:50	14:19	1:29	LINE CLEAR AVAILED
200	4-Dec-19	TUMKUR	66	TR-2	MANGALWADA_66	12:02	15:40	3:38	LINE CLEAR AVAILED
201	4-Dec-19	TUMKUR	66	TR-2	MELKOTE_66	7:58	8:41	0:43	TRANSFORMER FAULT
202	4-Dec-19	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	12:49	14:19	1:30	LINE CLEAR AVAILED
203	4-Dec-19	TUMKUR	66	MYLANAHALLI-THALLAK	MYLANAHALLI_66	4:43	5:43	1:00	LINE FAULT
204	4-Dec-19	TUMKUR	66	TR-1	MYLANAHALLI_66	4:43	5:43	1:00	TRANSFORMER FAULT
205	4-Dec-19	TUMKUR	66	NAGALAMADIKE-SUNDER RAJU SOLAR_IPP_66	SUNDER RAJU SOLAR_IPP_66	9:14	9:24	0:09	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
206	4-Dec-19	TUMKUR	66	NAGALAMADIKE-SUNDER RAJU SOLAR_IPP_66	SUNDER RAJU SOLAR_IPP_66	10:35	10:47	0:12	HAND TRIPPED
207	5-Dec-19	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	8:43	11:40	2:57	LINE FAULT
208	5-Dec-19	BAGALKOT	220	ADPH1-BAGALKOT	BAGALKOT_220	10:04	13:11	3:07	LINE CLEAR AVAILED
209	5-Dec-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	21:09	21:24	0:15	HAND TRIPPED
210	5-Dec-19	BAGALKOT	220	DHONI1&2-GADAG	GADAG_220	21:14	23:59	2:45	LINE CLEAR AVAILED
211	5-Dec-19	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	13:08	16:05	2:57	LINE CLEAR AVAILED
212	5-Dec-19	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220	17:57	19:19	1:22	LINE CLEAR AVAILED
213	5-Dec-19	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI_220	15:51	17:50	1:59	LINE CLEAR AVAILED
214	5-Dec-19	BAGALKOT	110	SOUDATTI220-RAMDURGA1	RAMDURGA_110	4:06	8:44	4:38	LINE FAULT
215	5-Dec-19	BAGALKOT	110	SOUDATTI220-RAMDURGA2	RAMDURGA_110	4:06	8:44	4:38	LINE FAULT
216	5-Dec-19	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	12:30	12:45	0:15	LINE CLEAR AVAILED
217	5-Dec-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	5:05	9:16	4:11	LINE CLEAR AVAILED
218	5-Dec-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	12:39	12:49	0:10	LINE CLEAR AVAILED
219	5-Dec-19	BAGALKOT	110	SOUDATTI-RAMDURGA	RAMDURGA_110	4:53	9:18	4:25	LINE CLEAR AVAILED
220	5-Dec-19	BAGALKOT	220	220/110KV,HV2,L2	MK HUBLI_220	13:00	18:31	5:31	LINE CLEAR AVAILED
221	5-Dec-19	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110,NTPCL_33,KARJOL LIS_33,KOLAR WATER SUPPLY_33	12:17	16:58	4:41	LINE CLEAR AVAILED
222	5-Dec-19	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	15:08	23:59	8:51	LINE CLEAR AVAILED
223	5-Dec-19	BAGALKOT	110	110/11KV,HV2	KUDUCHI_110,CHINCHALI_33	15:07	15:29	0:22	LINE CLEAR AVAILED
224	5-Dec-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY	6:24	6:35	0:11	LINE FAULT
225	5-Dec-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD	7:20	10:20	3:00	LINE CLEAR AVAILED
226	5-Dec-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	13:00	13:10	0:10	LINE CLEAR AVAILED
227	5-Dec-19	BENGALURU	66	HV2	MUDIYANUR	6:17	6:44	0:26	TRANSFORMER FAULT
228	5-Dec-19	BENGALURU	66	HV1	JIGANI 66	7:20	8:05	0:45	MAIN SUPPLY FAILURE
229	5-Dec-19	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	7:20	8:09	0:49	MAIN SUPPLY FAILURE
230	5-Dec-19	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI LINK ROAD	10:06	10:19	0:13	LOAD CHANGE OVER
231	5-Dec-19	BENGALURU	66	HV1	JIGANI 66	10:05	10:18	0:13	LOAD CHANGE OVER
232	5-Dec-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	7:23	7:45	0:22	LOAD CHANGE OVER
233	5-Dec-19	BENGALURU	66	RBI - ELITA	RBI	10:25	10:30	0:05	LOAD CHANGE OVER
234	5-Dec-19	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	7:23	7:51	0:28	LOAD CHANGE OVER
235	5-Dec-19	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	10:25	10:32	0:07	LOAD CHANGE OVER
236	5-Dec-19	BENGALURU	66	SRS PEENYA 220 - ALUR	ALUR, NELAMANGALA 66	7:25	7:45	0:20	LINE FAULT
237	5-Dec-19	BENGALURU	66	NELAMANGALA 66 - DABASPETE 220	NELAMANGALA 66	7:35	7:38	0:03	LINE CLEAR AVAILED
238	5-Dec-19	BENGALURU	66	NELAMANGALA 66 - DABASPETE 220	NELAMANGALA 66	8:58	9:01	0:03	LINE CLEAR AVAILED
239	5-Dec-19	BENGALURU	66	NELAMANGALA 66 - ALUR	ALUR	8:55	9:10	0:15	LOAD CHANGE OVER
240	5-Dec-19	BENGALURU	66	DABASPETE 220 - HIREHALLI	HIREHALLI, HONNUDUKE	13:00	18:00	5:00	LINE CLEAR AVAILED
241	5-Dec-19	BENGALURU	66	VIDYANAGAR - SAHAKARNAGARA	HENNUR CROSS	6:13	6:36	0:23	LINE FAULT
242	5-Dec-19	GULBARGA	220	KUSHTAGI-OPDWIND_IPP	KUSHTAGI_220	1:45	2:10	0:25	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
243	5-Dec-19	GULBARGA	220	KUSHTAGI-LINGASUGUR	LINGASUGUR_220	16:22	21:37	5:15	LINE CLEAR AVAILED
244	5-Dec-19	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	0:00	7:25	7:25	LINE FAULT
245	5-Dec-19	GULBARGA	110	BETAGERA-KESHAVCEMENT_IPP	BETAGERA_110	5:23	5:34	0:11	LINE FAULT
246	5-Dec-19	GULBARGA	110	BHALKI-HUMNABAD	BHALKI_110,LADHA_110	3:32	3:40	0:08	LINE FAULT
247	5-Dec-19	GULBARGA	110	HV3	HATTI_110	13:38	13:52	0:14	TRANSFORMER FAULT
248	5-Dec-19	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITAKAL_110,KONKAL_110	19:05	19:10	0:05	LINE FAULT
249	5-Dec-19	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	19:05	19:25	0:20	LINE FAULT
250	5-Dec-19	GULBARGA	110	KUSHTAGI-INRSOLAR_IPP	KUSHTAGI_220	1:45	2:10	0:25	LINE FAULT
251	5-Dec-19	GULBARGA	110	HV2	KUSHTAGI_220	12:05	12:50	0:45	TRANSFORMER FAULT
252	5-Dec-19	GULBARGA	110	HV2	MADIYAL_110	17:30	18:22	0:52	LINE CLEAR AVAILED
253	5-Dec-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	5:45	6:55	1:10	LINE FAULT
254	5-Dec-19	GULBARGA	110	YELBURGA-PRPJSLR_IPP	YELBURGA_110	19:50	22:05	2:15	LINE FAULT
255	5-Dec-19	GULBARGA	110	SINDHANOOR-NIRLOOPI_IPP	SINDHANOOR_220	22:30	22:50	0:20	LINE FAULT
256	5-Dec-19	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	23:55	23:59	0:04	LINE FAULT
257	5-Dec-19	GULBARGA	66	ITTAGI-HIREHADAGALLI1&2	HIREHADAGALI_66,GIRIYAPURA_66, MAGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	11:45	12:50	1:05	LINE CLEAR AVAILED
258	5-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	6:55	6:55	LINE CLEAR AVAILED
259	5-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52	23:59	7:07	LINE CLEAR AVAILED
260	5-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:00	7:00	LINE CLEAR AVAILED
261	5-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:34	23:59	0:25	HAND TRIPPED
262	5-Dec-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:21	12:43	1:22	LINE CLEAR AVAILED
263	5-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	9:11	12:45	3:34	LINE CLEAR AVAILED
264	5-Dec-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	19:34	22:10	2:36	LINE CLEAR AVAILED
265	5-Dec-19	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	9:11	12:45	3:34	LINE CLEAR AVAILED
266	5-Dec-19	HASSAN	220	VARAH1-KEMAR1	varahi_gen	11:21	12:44	1:23	NFBC ISSUED
267	5-Dec-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	19:33	22:10	2:37	LINE CLEAR AVAILED
268	5-Dec-19	HASSAN	110	HV3	BHADRAVATHI_110	16:08	17:35	1:27	LINE CLEAR AVAILED
269	5-Dec-19	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	0:00	12:38	12:38	NFBC ISSUED
270	5-Dec-19	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	13:09	17:28	4:19	LINE FAULT
271	5-Dec-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	13:23	13:41	0:18	MAIN SUPPLY FAILURE
272	5-Dec-19	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	13:23	13:41	0:18	MAIN SUPPLY FAILURE
273	5-Dec-19	HASSAN	66	HV2	BASAVAGHATTA_66	10:59	13:03	2:04	LINE CLEAR AVAILED
274	5-Dec-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:05	17:54	7:49	LINE CLEAR AVAILED
275	5-Dec-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	4:33	4:48	0:15	LINE FAULT
276	5-Dec-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:18	12:11	1:53	NFBC ISSUED
277	5-Dec-19	HASSAN	66	GANGUR-HASSAN	GANGUR_66	9:36	17:44	8:08	MAIN SUPPLY FAILURE
278	5-Dec-19	HASSAN	66	HV1	GANGUR_66	9:36	17:46	8:10	MAIN SUPPLY FAILURE
279	5-Dec-19	HASSAN	66	HV2	HALEBEEDU_66	9:25	18:10	8:45	MAIN SUPPLY FAILURE
280	5-Dec-19	HASSAN	66	HV1	SIGEBAGI_66	16:56	17:22	0:26	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
281	5-Dec-19	MYSORE	66	HV1	DUNDANAHALLI_66	12:53	13:10	0:16	HAND TRIPPED
282	5-Dec-19	MYSORE	66	HV1	DUNDANAHALLI_66	14:14	14:35	0:21	HAND TRIPPED
283	5-Dec-19	MYSORE	66	HV2	DUNDANAHALLI_66	13:02	13:18	0:15	HAND TRIPPED
284	5-Dec-19	MYSORE	66	HV1	KADAKOLA_220	12:14	14:22	2:08	LINE CLEAR AVAILED
285	5-Dec-19	MYSORE	66	HV1	KIRUGAVALU_66	11:19	18:41	7:21	LINE CLEAR AVAILED
286	5-Dec-19	MYSORE	66	HV2	KIRUGAVALU_66	11:19	18:41	7:21	LINE CLEAR AVAILED
287	5-Dec-19	MYSORE	66	KR PETE 220-MADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, JAKKANAHALLY_66, NAGAMANGALA_66	3:20	3:25	0:05	LINE FAULT
288	5-Dec-19	MYSORE	66	HV1	SANTHESARAGUR_66	13:38	13:42	0:04	TRANSFORMER FAULT
289	5-Dec-19	MYSORE	66	HV2	THALAKADU_66	7:30	8:49	1:19	LINE CLEAR AVAILED
290	5-Dec-19	MYSORE	66	HV2	THALAKADU_66	11:33	14:04	2:30	LINE CLEAR AVAILED
291	5-Dec-19	MYSORE	66	HV2	THALAKADU_66	14:12	14:33	0:20	LINE CLEAR AVAILED
292	5-Dec-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66, MALIYURU_66	12:55	13:12	0:17	HAND TRIPPED
293	5-Dec-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66, MALIYURU_66	16:42	16:48	0:05	HAND TRIPPED
294	5-Dec-19	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	9:36	9:39	0:03	HAND TRIPPED
295	5-Dec-19	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	12:55	13:10	0:15	HAND TRIPPED
296	5-Dec-19	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	DEVANOORMYS_66, FTS_66, RAJEEVNAGARA_66	9:36	9:39	0:03	HAND TRIPPED
297	5-Dec-19	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	DEVANOORMYS_66, FTS_66, RAJEEVNAGARA_66	12:55	13:10	0:14	HAND TRIPPED
298	5-Dec-19	MYSORE	220	VAJAMANGALA-HOOTAGALLY	VAJAMANGALA_220	17:53	18:45	0:52	LINE FAULT
299	5-Dec-19	MYSORE	220	VAJAMANGALA-TK HALLI	VAJAMANGALA_220	17:53	19:02	1:09	LINE FAULT
300	5-Dec-19	MYSORE	66	HV1	VAJAMANGALA_220	13:00	13:09	0:08	HAND TRIPPED
301	5-Dec-19	MYSORE	66	HV2	VAJAMANGALA_220	9:36	9:39	0:03	HAND TRIPPED
302	5-Dec-19	MYSORE	220	HV1	VAJAMANGALA_220	13:44	16:37	2:53	LINE CLEAR AVAILED
303	5-Dec-19	MYSORE	220	HV2	VAJAMANGALA_220	9:37	12:49	3:11	LINE CLEAR AVAILED
304	5-Dec-19	MYSORE	220	HV1	VAJAMANGALA_220	17:53	18:45	0:52	MAIN SUPPLY FAILURE
305	5-Dec-19	MYSORE	220	HV2	VAJAMANGALA_220	17:53	18:51	0:58	MAIN SUPPLY FAILURE
306	5-Dec-19	MYSORE	66	HV1	VAJAMANGALA_220	17:53	18:55	1:02	MAIN SUPPLY FAILURE
307	5-Dec-19	MYSORE	66	HV2	VAJAMANGALA_220	17:53	18:55	1:02	MAIN SUPPLY FAILURE
308	5-Dec-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66, MARADIHUNDI_66	12:55	13:12	0:16	HAND TRIPPED
309	5-Dec-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66, MARADIHUNDI_66	16:42	16:48	0:05	HAND TRIPPED
310	5-Dec-19	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	12:39	15:56	3:17	LINE CLEAR AVAILED
311	5-Dec-19	TUMKUR	110	TR-1	KADABA_110	14:27	14:31	0:03	LINE CLEAR AVAILED
312	5-Dec-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	12:39	15:57	3:18	LINE CLEAR AVAILED
313	5-Dec-19	TUMKUR	110	TR-2	SAMPIGE_110	3:14	3:19	0:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
314	5-Dec-19	TUMKUR	110	TR-2	SAMPIGE_110	8:03	8:11	0:08	TRANSFORMER FAULT
315	5-Dec-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	13:30	13:35	0:05	HAND TRIPPED
316	5-Dec-19	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	12:02	13:32	1:29	LINE CLEAR AVAILED
317	5-Dec-19	TUMKUR	66	TR-2	BADDIHALLI_66	20:04	20:12	0:07	HAND TRIPPED
318	5-Dec-19	TUMKUR	66	TR-2	BADDIHALLI_66	21:23	22:13	0:50	HAND TRIPPED
319	5-Dec-19	TUMKUR	66	HIREHALLI - ANTHRASANAHALLI	HIREHALLY_66	13:36	17:47	4:11	LINE CLEAR AVAILED
320	5-Dec-19	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	11:18	13:27	2:09	LINE CLEAR AVAILED
321	5-Dec-19	TUMKUR	66	NAGALAMADIKE- ATRIA_IPP_66	ATRIA_IPP_66	12:26	12:30	0:03	HAND TRIPPED
322	5-Dec-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	10:11	14:40	4:28	LINE CLEAR AVAILED
323	5-Dec-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	17:34	17:36	0:01	LINE CLEAR AVAILED
324	5-Dec-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	10:11	14:40	4:28	LINE CLEAR AVAILED
325	5-Dec-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	17:34	17:36	0:01	LINE CLEAR AVAILED
326	5-Dec-19	TUMKUR	66	TAVAREKERE (C)- GOPPENAHALLI	TAVAREKERE(C)_66	10:11	14:40	4:28	LINE CLEAR AVAILED
327	5-Dec-19	TUMKUR	66	TAVAREKERE (C)- GOPPENAHALLI	TAVAREKERE(C)_66	17:34	17:35	0:01	LINE CLEAR AVAILED
328	5-Dec-19	TUMKUR	66	TR-2	TAVAREKERE(H)_66	12:05	12:55	0:50	LINE CLEAR AVAILED
329	5-Dec-19	TUMKUR	66	TR-2	THOVINAKERE_66	11:40	12:19	0:39	LINE CLEAR AVAILED
330	5-Dec-19	TUMKUR	66	TR-2	TAVAREKERE(H)_66	12:50	12:52	0:02	LINE CLEAR AVAILED
331	5-Dec-19	TUMKUR	66	TR-2	THOVINAKERE_66	13:02	18:40	5:38	LINE CLEAR AVAILED
332	5-Dec-19	TUMKUR	66	TR-1	TUMKUR_66	21:11	21:55	0:43	LINE CLEAR AVAILED
333	5-Dec-19	TUMKUR	66	VENKATAPURA- GOWRIBIDNUR	VENKATAPUR_66	15:20	16:21	1:00	LINE FAULT
334	5-Dec-19	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	16:21	16:23	0:01	HAND TRIPPED
335	6-Dec-19	BAGALKOT	110	110/33KV,HV2	ANKALAGI_110,KANAGAV_33,NESAR GI_33	12:48	15:40	2:52	LINE CLEAR AVAILED
336	6-Dec-19	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_33,SEADB IRD_33	10:33	13:03	2:30	LINE CLEAR AVAILED
337	6-Dec-19	BAGALKOT	110	ANKOLA-ARGA	ARGA_110	21:26	21:29	0:03	HAND TRIPPED
338	6-Dec-19	BAGALKOT	220	DHONI1&2-GADAG	GADAG_220	0:00	3:30	3:30	LINE CLEAR AVAILED
339	6-Dec-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	11:23	15:16	3:53	LINE CLEAR AVAILED
340	6-Dec-19	BAGALKOT	110	110/11KV,HV1	BETAGERI_110	11:20	12:25	1:05	LINE CLEAR AVAILED
341	6-Dec-19	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	0:00	11:20	11:20	LINE CLEAR AVAILED
342	6-Dec-19	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	15:18	23:59	8:41	LINE CLEAR AVAILED
343	6-Dec-19	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	0:00	12:41	12:41	LINE CLEAR AVAILED
344	6-Dec-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	11:11	11:55	0:44	LINE CLEAR AVAILED
345	6-Dec-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	17:49	19:06	1:17	LINE CLEAR AVAILED
346	6-Dec-19	BAGALKOT	110	RANEENNUR-TUMMINAKATTI	TUMMINAKATTI_110	10:40	18:12	7:32	LINE CLEAR AVAILED
347	6-Dec-19	BAGALKOT	110	220/110KV,LV1	RANEENNUR_220	17:56	17:59	0:03	HAND TRIPPED
348	6-Dec-19	BAGALKOT	110	NAREGAL-RON	RON_110	14:35	14:58	0:23	LINE CLEAR AVAILED
349	6-Dec-19	BAGALKOT	220	220/110KV,HV2,LV2	MK HUBLI_220	11:47	22:07	10:20	LINE CLEAR AVAILED
350	6-Dec-19	BAGALKOT	110	MAMADAPUR(B)-SHIRBUR	SHIRBUR_110	10:06	17:19	7:13	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
351	6-Dec-19	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	0:00	19:46	19:46	LINE CLEAR AVAILED
352	6-Dec-19	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	11:26	12:13	0:47	LINE CLEAR AVAILED
353	6-Dec-19	BAGALKOT	110	KARWAR-ARGA	ARGA_110	19:31	22:41	3:10	LINE FAULT
354	6-Dec-19	BAGALKOT	110	110/11KV,HV2	KALGHATAGI_110	7:42	8:08	0:26	LINE CLEAR AVAILED
355	6-Dec-19	BAGALKOT	110	110/11KV,HV2	KALGHATAGI_110	20:46	22:56	2:10	TRANSFORMER FAULT
356	6-Dec-19	BAGALKOT	110	KAVALAWADA-KADANAKOPPA	KADANAKOPPA_110	0:00	21:00	21:00	LINE CLEAR AVAILED
357	6-Dec-19	BENGALURU	66	HV2	ISROLAYOUT	7:02	7:15	0:12	TRANSFORMER FAULT
358	6-Dec-19	BENGALURU	66	HV2	SOLDEVANAHALLI	12:14	12:20	0:06	MAIN SUPPLY FAILURE
359	6-Dec-19	BENGALURU	66	HV2	KUNDANA	13:30	14:45	1:15	LINE CLEAR AVAILED
360	6-Dec-19	BENGALURU	66	HV2	NANGLI	17:55	18:24	0:29	TRANSFORMER FAULT
361	6-Dec-19	BENGALURU	66	HV2	KYALANUR	18:29	18:34	0:05	TRANSFORMER FAULT
362	6-Dec-19	BENGALURU	66	CHANDRAPPA CIRCLE - KUMLUGODU	CHANDRAPPA CIRCLE	15:34	15:39	0:05	LINE FAULT
363	6-Dec-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	0:05	0:10	0:05	LINE FAULT
364	6-Dec-19	GULBARGA	110	SINDHANOOR-NIRLOOPI_IPP	SINDHANOOR_220	23:32	23:45	0:13	LINE FAULT
365	6-Dec-19	GULBARGA	110	BETAGERA-KESHAVCEMENT_IPP	BETAGERA_110	1:34	1:45	0:11	LINE FAULT
366	6-Dec-19	GULBARGA	110	SIDHANOOR-MUNIRABAD2	KAMPLI_GLB_110,MUKUNDA_110,KE REHALLI_110,MALLAPUR_110	5:05	5:20	0:15	LINE FAULT
367	6-Dec-19	GULBARGA	110	HV2	KOGALI_110	13:10	14:55	1:45	LINE CLEAR AVAILED
368	6-Dec-19	GULBARGA	110	HV1	KOGALI_110	14:50	15:25	0:35	HAND TRIPPED
369	6-Dec-19	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	0:00	0:03	0:03	LINE FAULT
370	6-Dec-19	GULBARGA	66	ITTAGI-HIREHADAGALLI1&2	HIREHADAGALI_66,GIRIYAPURA_66, MAGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	10:21	14:32	4:11	LINE CLEAR AVAILED
371	6-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	6:19	6:19	LINE CLEAR AVAILED
372	6-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:09	23:59	14:50	LINE CLEAR AVAILED
373	6-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:25	6:25	LINE CLEAR AVAILED
374	6-Dec-19	HASSAN	220	HV2	MSEZ_220	9:46	15:26	5:40	LINE CLEAR AVAILED
375	6-Dec-19	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	9:12	11:52	2:40	LINE CLEAR AVAILED
376	6-Dec-19	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	9:12	11:52	2:40	LINE CLEAR AVAILED
377	6-Dec-19	HASSAN	110	HV1	MSEZ_220	10:27	15:33	5:06	LINE CLEAR AVAILED
378	6-Dec-19	HASSAN	110	LV2	MSEZ_220	9:45	15:27	5:42	LINE CLEAR AVAILED
379	6-Dec-19	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:17	15:15	3:58	LINE CLEAR AVAILED
380	6-Dec-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	7:04	7:15	0:11	MAIN SUPPLY FAILURE
381	6-Dec-19	HASSAN	66	HV2	SHRAVANABELAGOLA_66	12:18	12:41	0:23	LINE CLEAR AVAILED
382	6-Dec-19	MYSORE	66	HV1	ADICHUNCHANAGIRI_66	12:15	14:00	1:44	LINE CLEAR AVAILED
383	6-Dec-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	12:23	12:51	0:28	LINE CLEAR AVAILED
384	6-Dec-19	MYSORE	66	HV2	HAMPAPURA_66	10:08	10:18	0:10	TRANSFORMER FAULT
385	6-Dec-19	MYSORE	66	HV1	HALAGUR_66	11:28	11:41	0:12	LINE CLEAR AVAILED
386	6-Dec-19	MYSORE	66	HV2	HALAGUR_66	11:25	11:40	0:15	LINE CLEAR AVAILED
387	6-Dec-19	MYSORE	66	HALAGURU-TK HALLI	HALAGUR_66	12:25	23:59	11:33	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
388	6-Dec-19	MYSORE	66	HV1	HDKOTE_66	11:07	11:24	0:17	HAND TRIPPED
389	6-Dec-19	MYSORE	66	HV1	HOOTAGALLY_220	10:30	17:15	6:44	LINE CLEAR AVAILED
390	6-Dec-19	MYSORE	66	HV2	HOOTAGALLY_220	10:30	17:56	7:25	LINE CLEAR AVAILED
391	6-Dec-19	MYSORE	66	KIRUGAVLU-MALIYUR	BANNUR_66, MALIYURU_66	15:11	15:37	0:26	LINE FAULT
392	6-Dec-19	MYSORE	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	18:15	18:23	0:08	LINE FAULT
393	6-Dec-19	MYSORE	66	KR NAGARA-BHERYA	BHERYA_66	14:05	14:15	0:10	LINE FAULT
394	6-Dec-19	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	7:08	7:13	0:05	LINE FAULT
395	6-Dec-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	14:15	15:02	0:47	LINE CLEAR AVAILED
396	6-Dec-19	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66, MALIYURU_66	15:08	17:30	2:22	LINE FAULT
397	6-Dec-19	MYSORE	220	VAJMANGALA-HOOTAGALLY	CHIDRAVALLI_66, DEVANOORMYS_66, FTS_66, RAJEEVNAGARA_66, JYOTHINAGARA_66, AYRALLI_66, MARADIHUNDI_66, MEGALAPURA_66, THUMBLA_66, VAJAMANGALA_220, TNARASIPURA_66	15:08	15:36	0:28	LINE FAULT
398	6-Dec-19	MYSORE	66	HV1	VAJAMANGALA_220	15:08	15:43	0:35	MAIN SUPPLY FAILURE
399	6-Dec-19	MYSORE	66	HV2	VAJAMANGALA_220	15:08	15:43	0:35	MAIN SUPPLY FAILURE
400	6-Dec-19	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI_220	12:09	12:58	0:49	LINE CLEAR AVAILED
401	6-Dec-19	TUMKUR	66	DASUDI-M/S CLEAN SOLAR	M/S CLEAN SOLAR _IPP_66	5:38	18:10	12:32	LINE CLEAR AVAILED
402	6-Dec-19	TUMKUR	66	HIRIYURkV 220kV- SUZLON 2	SUZLON1_IPP_66	7:20	7:22	0:01	LINE FAULT
403	6-Dec-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:40	11:54	0:14	LINE FAULT
404	6-Dec-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:41	13:52	0:11	LINE FAULT
405	6-Dec-19	TUMKUR	66	TR-2(LV SIDE)	MADHUGIRI_220	12:09	12:58	0:49	LINE CLEAR AVAILED
406	6-Dec-19	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	10:42	14:20	3:38	LINE CLEAR AVAILED
407	6-Dec-19	TUMKUR	66	TR-2	THOVINAKERE_66	11:30	12:41	1:10	LINE CLEAR AVAILED
408	7-Dec-19	BAGALKOT	110	BAGALKOT-LOKAPUR 1	LOKAPUR_110	2:25	2:43	0:18	LINE FAULT
409	7-Dec-19	BAGALKOT	110	BAGALKOT-LOKAPUR 1	LOKAPUR_110	3:17	4:02	0:45	LINE CLEAR AVAILED
410	7-Dec-19	BAGALKOT	110	BAGALKOT-LOKAPUR 1	LOKAPUR_110	4:14	4:27	0:13	HAND TRIPPED
411	7-Dec-19	BAGALKOT	110	BIDNAL-GADAG ROAD	GADAG ROAD_110	10:12	15:30	5:18	NFBC ISSUED
412	7-Dec-19	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110,TAKKALAKI_110&TO RVI_110	6:58	17:14	10:16	LINE CLEAR AVAILED
413	7-Dec-19	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPANAKOPPA_110	9:49	16:07	6:18	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
414	7-Dec-19	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	14:30	14:35	0:05	HAND TRIPPED
415	7-Dec-19	BAGALKOT	110	110/11KV,HV1	MAHALINGAPUR_220	11:25	14:25	3:00	LINE CLEAR AVAILED
416	7-Dec-19	BAGALKOT	110	110/33KV,HV1	MAHALINGAPUR_220	16:05	18:05	2:00	LINE CLEAR AVAILED
417	7-Dec-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	10:46	10:50	0:04	LINE CLEAR AVAILED
418	7-Dec-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR2	VAJRAMATTI_220	10:51	10:53	0:02	LINE CLEAR AVAILED
419	7-Dec-19	BAGALKOT	110	JAMKHANDI SUGARS-TODALBAGI	TODALBAGI_110	1:15	1:25	0:10	LINE FAULT
420	7-Dec-19	BAGALKOT	110	110/11KV, HV3	TODALBAGI_110	10:40	18:22	7:42	LINE CLEAR AVAILED
421	7-Dec-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	11:54	12:01	0:07	LINE CLEAR AVAILED
422	7-Dec-19	BAGALKOT	110	SAVALGI-TODALBAGI	TODALBAGI_110	17:48	18:15	0:27	LINE CLEAR AVAILED
423	7-Dec-19	BAGALKOT	220	220/110KV, HV2,LV2	MKHUBLI_220	11:40	21:36	9:56	LINE CLEAR AVAILED
424	7-Dec-19	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	2:25	4:49	2:24	LINE FAULT
425	7-Dec-19	BAGALKOT	110	110/33KV, HV3	SALAHALLI_110,BATAKURKI_33,RSSK N_33	2:25	4:36	2:11	TRANSFORMER FAULT
426	7-Dec-19	BAGALKOT	220	MK HUBLI-NARENDRA1	MK HUBLI_220	10:38	15:38	5:00	LINE CLEAR AVAILED
427	7-Dec-19	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	16:28	23:59	7:31	LINE CLEAR AVAILED
428	7-Dec-19	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMNAYAPURA 66	10:28	10:36	0:08	LOAD CHANGE OVER
429	7-Dec-19	BENGALURU	66	HV3	YARANDANAHALLI	9:47	10:13	0:25	LINE CLEAR AVAILED
430	7-Dec-19	BENGALURU	66	HV1	YARANDANAHALLI	9:52	10:14	0:22	LINE CLEAR AVAILED
431	7-Dec-19	BENGALURU	66	BOMMASANDRA I/A - YARANDANAHALLI 220	BOMMASANDRA I/A	9:30	10:02	0:32	LOAD CHANGE OVER
432	7-Dec-19	BENGALURU	66	HV2	VIJAYAPURA	14:44	15:35	0:51	LINE CLEAR AVAILED
433	7-Dec-19	BENGALURU	66	HV1	SIDDALAGHATTA	12:18	13:24	1:05	LINE CLEAR AVAILED
434	7-Dec-19	BENGALURU	66	HV2	SIDDALAGHATTA	12:18	12:36	0:17	LINE CLEAR AVAILED
435	7-Dec-19	BENGALURU	66	HV2	SHAMRAJ TECHPARK	11:10	11:30	0:20	LINE CLEAR AVAILED
436	7-Dec-19	BENGALURU	66	SHAMRAJ TECHPARK - EPIP 220	SHAMRAJ TECHPARK	9:59	10:04	0:04	MAIN SUPPLY FAILURE
437	7-Dec-19	BENGALURU	66	SHAMRAJ TECHPARK - EPIP 220	SHAMRAJ TECHPARK	15:21	15:26	0:04	MAIN SUPPLY FAILURE
438	7-Dec-19	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	9:45	9:52	0:07	LOAD CHANGE OVER
439	7-Dec-19	BENGALURU	66	HV2	JAYADEVA	10:49	13:44	2:54	LINE CLEAR AVAILED
440	7-Dec-19	BENGALURU	66	HSR 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	9:43	10:02	0:18	LINE CLEAR AVAILED
441	7-Dec-19	BENGALURU	66	HV1	EPIP 220	20:28	20:56	0:28	TRANSFORMER FAULT
442	7-Dec-19	BENGALURU	66	HV1	ELECTRONIC P1 S1	5:31	8:29	2:58	TRANSFORMER FAULT
443	7-Dec-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	16:19	16:34	0:15	LINE FAULT
444	7-Dec-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	2:43	2:50	0:07	LINE FAULT
445	7-Dec-19	BENGALURU	66	AUSTIN TOWN - HSR LAYOUT 220	AUSTIN TOWN	16:37	16:48	0:10	LINE FAULT
446	7-Dec-19	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	6:40	6:45	0:05	LOAD CHANGE OVER
447	7-Dec-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	9:10	9:15	0:05	LOAD CHANGE OVER
448	7-Dec-19	BENGALURU	66	HV1	ATTIBELE	14:49	15:04	0:15	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
449	7-Dec-19	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	11:45	12:44	0:58	LINE CLEAR AVAILED
450	7-Dec-19	GULBARGA	220	RTPS-SEDAM2	EDAM_220	10:27	23:59	13:32	NFBC ISSUED
451	7-Dec-19	GULBARGA	220	SEDAM-CLNMAX_IPP	SEDAM_220	19:05	19:57	0:52	LINE CLEAR AVAILED
452	7-Dec-19	GULBARGA	110	PDHALLI-BASAI	PDHALLI_110	10:24	12:20	1:56	LINE CLEAR AVAILED
453	7-Dec-19	GULBARGA	110	RAICHUR-MATAMARI	MATMARI_110	10:30	12:11	1:41	LINE CLEAR AVAILED
454	7-Dec-19	GULBARGA	110	RAICHUR-MATAMARI	MATMARI_110	14:23	14:28	0:05	LINE FAULT
455	7-Dec-19	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	12:24	13:40	1:16	LINE CLEAR AVAILED
456	7-Dec-19	GULBARGA	110	SIDHANOOR-PGLR_WIND	SIDHANOOR_220	3:51	4:15	0:24	LINE FAULT
457	7-Dec-19	GULBARGA	110	SIDHANOOR-PGLR_WIND	SIDHANOOR_220	4:52	10:25	5:33	LINE FAULT
458	7-Dec-19	GULBARGA	110	SIDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPS WATER WORKS	5:57	6:06	0:09	LINE FAULT
459	7-Dec-19	GULBARGA	110	HV2	HANUMANAL_110	13:05	13:10	0:05	TRANSFORMER FAULT
460	7-Dec-19	GULBARGA	110	HV2	HANUMANAL_110	14:30	14:35	0:05	TRANSFORMER FAULT
461	7-Dec-19	GULBARGA	110	HV2	HANUMANAL_110	16:00	17:00	1:00	LINE CLEAR AVAILED
462	7-Dec-19	HASSAN	400	HASSAN4-UPCL1	HASSAN_400	1:25	7:40	6:15	LINE CLEAR AVAILED
463	7-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	7:18	7:18	LINE CLEAR AVAILED
464	7-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:48	23:59	6:11	LINE CLEAR AVAILED
465	7-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	1:24	7:40	6:16	LINE CLEAR AVAILED
466	7-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:29	21:38	0:09	HAND TRIPPED
467	7-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:54	23:59	2:05	LINE CLEAR AVAILED
468	7-Dec-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	13:56	14:13	0:17	LINE FAULT
469	7-Dec-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	14:37	20:52	6:15	LINE FAULT
470	7-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:49	14:39	3:50	LINE CLEAR AVAILED
471	7-Dec-19	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	10:49	14:39	3:50	NFBC ISSUED
472	7-Dec-19	HASSAN	220	HV2	SHIRALKOPPA_220	13:11	13:43	0:32	HAND TRIPPED
473	7-Dec-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	13:56	14:13	0:17	LINE FAULT
474	7-Dec-19	HASSAN	110	LV2	SHIRALKOPPA_220	13:09	13:44	0:35	HAND TRIPPED
475	7-Dec-19	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:06	13:51	3:45	LINE CLEAR AVAILED
476	7-Dec-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	10:08	13:50	3:42	LINE CLEAR AVAILED
477	7-Dec-19	HASSAN	66	HV2	CHIKMAGALUR_66	16:37	17:40	1:03	LINE CLEAR AVAILED
478	7-Dec-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:01	15:06	0:05	HAND TRIPPED
479	7-Dec-19	MYSORE	66	HV2	COWDALLI_66	8:45	10:00	1:15	LINE CLEAR AVAILED
480	7-Dec-19	MYSORE	66	KADAKOLA-SARGURU 2	CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66	8:20	8:27	0:06	LINE FAULT
481	7-Dec-19	MYSORE	66	MUGUR-THAYURU	THAYURU_66	23:07	23:13	0:06	LINE FAULT
482	7-Dec-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:05	10:23	0:18	TRANSFORMER FAULT
483	7-Dec-19	MYSORE	66	HV1	TNARASIPURA_66	10:00	17:25	7:25	LINE CLEAR AVAILED
484	7-Dec-19	MYSORE	66	HV2	TNARASIPURA_66	10:00	17:25	7:25	LINE CLEAR AVAILED
485	7-Dec-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	14:37	20:51	6:14	LINE FAULT
486	7-Dec-19	TUMKUR	110	TR-2	TURUVEKERE_110	12:00	12:21	0:20	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
487	7-Dec-19	TUMKUR	110	TR-3	KBCROSS_220	14:40	14:55	0:15	TRANSFORMER FAULT
488	7-Dec-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	14:40	14:58	0:17	HAND TRIPPED
489	7-Dec-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	15:31	17:52	2:20	LINE CLEAR AVAILED
490	7-Dec-19	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	6:37	6:52	0:15	LINE FAULT
491	7-Dec-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	4:58	5:13	0:14	LINE FAULT
492	7-Dec-19	TUMKUR	66	HARIHARA-DAVANGERE	HARIHAR_66	12:56	18:58	6:02	LOAD CURTAILMENT
493	7-Dec-19	TUMKUR	66	TR-1	HARIHAR_66	12:56	17:22	4:26	LOAD CURTAILMENT
494	7-Dec-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:14	18:46	8:32	LINE CLEAR AVAILED
495	7-Dec-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:14	18:46	8:32	LINE CLEAR AVAILED
496	7-Dec-19	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	11:00	18:54	7:53	LINE CLEAR AVAILED
497	7-Dec-19	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	16:36	16:47	0:10	HAND TRIPPED
498	7-Dec-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	16:19	16:21	0:02	HAND TRIPPED
499	7-Dec-19	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	16:32	19:04	2:32	LINE CLEAR AVAILED
500	7-Dec-19	TUMKUR	66	TR-2	NITRAHALLI_66	12:25	13:07	0:41	LINE CLEAR AVAILED
501	7-Dec-19	TUMKUR	66	TR-2	TAVAREKERE(H)_66	13:02	13:25	0:23	LINE CLEAR AVAILED
502	7-Dec-19	TUMKUR	66	TR-1	TYAVANAGI_66	10:03	15:31	5:27	MAIN SUPPLY FAILURE
503	8-Dec-19	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	16:35	17:05	0:30	HAND TRIPPED
504	8-Dec-19	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	17:06	17:34	0:28	HAND TRIPPED
505	8-Dec-19	BAGALKOT	110	110/11KV,HV1A	JAMAKHANDI_110	11:23	14:00	2:37	LINE CLEAR AVAILED
506	8-Dec-19	BAGALKOT	110	110/33KV,HV1	JAMAKHANDI_110	14:54	16:39	1:45	LINE CLEAR AVAILED
507	8-Dec-19	BAGALKOT	110	110/33KV,HV2	JAMAKHANDI_110	16:42	18:20	1:38	LINE CLEAR AVAILED
508	8-Dec-19	BAGALKOT	110	110/33KV, HV3	SANKESHWAR_110, HEBBAL_33, KANAGALA_33	10:50	11:03	0:13	LINE CLEAR AVAILED
509	8-Dec-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	19:53	23:59	4:06	LINE CLEAR AVAILED
510	8-Dec-19	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110,LINGADALLI_33 &DEVAR GENNUR_33	8:50	9:02	0:12	TRANSFORMER FAULT
511	8-Dec-19	BAGALKOT	110	KUDUCHI220-MORAB	MORAB_110	12:29	12:56	0:27	LINE CLEAR AVAILED
512	8-Dec-19	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	0:00	11:34	11:34	LINE CLEAR AVAILED
513	8-Dec-19	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMNAYAPURA 220	SUBRAMNAYAPURA 66	14:32	14:48	0:16	LOAD CHANGE OVER
514	8-Dec-19	BENGALURU	66	HV1	SURYANAGARA	11:52	12:13	0:20	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
515	8-Dec-19	BENGALURU	66	HV1	MUDIYANUR	18:03	18:11	0:07	TRANSFORMER FAULT
516	8-Dec-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:04	10:42	0:37	LINE FAULT
517	8-Dec-19	BENGALURU	66	HV1	JANGAMAKOTE	11:55	12:30	0:34	LINE CLEAR AVAILED
518	8-Dec-19	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DAALSNUR	10:00	10:08	0:07	LINE FAULT
519	8-Dec-19	BENGALURU	66	HV2	ITI	5:30	7:30	2:00	TRANSFORMER FAULT
520	8-Dec-19	BENGALURU	66	HV1	ISRO LAYOUT	10:18	10:45	0:26	TRANSFORMER FAULT
521	8-Dec-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	9:20	9:57	0:36	LINE FAULT
522	8-Dec-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:23	6:29	0:05	LINE FAULT
523	8-Dec-19	GULBARGA	400	YTPS-BPS2	YTPS_400	2:00	23:59	21:59	LINE FAULT
524	8-Dec-19	GULBARGA	220	HUMNABAD-SEDAM1	SEDAM_220	1:58	2:31	0:33	LINE FAULT
525	8-Dec-19	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	1:58	2:33	0:35	LINE FAULT
526	8-Dec-19	GULBARGA	220	SEDAM-CLNMAX_IPP	SEDAM_220	8:35	8:48	0:13	LINE FAULT
527	8-Dec-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALU_110,KUDITNI_110,KURU GOD_110,KAMALAPUR_110,METRI_110	15:05	15:15	0:10	LINE FAULT
528	8-Dec-19	GULBARGA	110	HV3	BEVOOR_110	8:03	8:10	0:07	TRANSFORMER FAULT
529	8-Dec-19	GULBARGA	110	HV5	LINGASUGUR_220	9:05	14:45	5:40	LINE CLEAR AVAILED
530	8-Dec-19	GULBARGA	110	HV5	LINGASUGUR_220	16:05	16:35	0:30	LINE CLEAR AVAILED
531	8-Dec-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	16:50	16:55	0:05	TRANSFORMER FAULT
532	8-Dec-19	GULBARGA	66	CHORNOOR-KUDLIGI	CHORNOOR_66	19:30	19:50	0:20	LINE FAULT
533	8-Dec-19	HASSAN	400	HASSAN4-UPCL1	HASSAN_400	23:47	23:59	0:12	HAND TRIPPED
534	8-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	7:18	7:18	LINE CLEAR AVAILED
535	8-Dec-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	20:44	23:59	3:15	LINE CLEAR AVAILED
536	8-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:46	23:59	0:13	HAND TRIPPED
537	8-Dec-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	14:34	19:54	5:20	MAIN SUPPLY FAILURE
538	8-Dec-19	HASSAN	110	HV1	MOODABIDRE_110	14:39	18:59	4:20	MAIN SUPPLY FAILURE
539	8-Dec-19	HASSAN	110	HV2	MOODABIDRE_110	14:38	18:58	4:20	MAIN SUPPLY FAILURE
540	8-Dec-19	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	14:20	18:55	4:35	MAIN SUPPLY FAILURE
541	8-Dec-19	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:33	19:06	4:33	MAIN SUPPLY FAILURE
542	8-Dec-19	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	14:20	19:06	4:46	MAIN SUPPLY FAILURE
543	8-Dec-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	4:43	4:48	0:05	LINE FAULT
544	8-Dec-19	HASSAN	66	CHANNAR-SHETTIHALLY	CHANNARAYAPATNA_66	6:34	6:48	0:14	LINE FAULT
545	8-Dec-19	MYSORE	66	HV1	DUNDANAHALLI_66	14:47	15:03	0:15	TRANSFORMER FAULT
546	8-Dec-19	MYSORE	66	HV1	KIADBMANDYA_66	9:37	14:59	5:21	LINE CLEAR AVAILED
547	8-Dec-19	MYSORE	66	HV2	KIADBMANDYA_66	9:37	14:59	5:21	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
548	8-Dec-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	10:19	12:21	2:01	LINE CLEAR AVAILED
549	8-Dec-19	MYSORE	66	HV1	KRNAGARA_66	19:51	20:02	0:11	TRANSFORMER FAULT
550	8-Dec-19	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	13:49	16:45	2:56	NFBC ISSUED
551	8-Dec-19	TUMKUR	110	TR-1	GUBBI_110	22:04	22:05	0:00	TRANSFORMER FAULT
552	8-Dec-19	TUMKUR	66	ANCHEPALYA 220KV- YEDIYUR(BG NAGAR)	YEDIYUR_66	15:08	15:22	0:13	LINE FAULT
553	8-Dec-19	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	11:12	11:34	0:22	LINE FAULT
554	8-Dec-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	17:49	18:07	0:18	LINE FAULT
555	8-Dec-19	TUMKUR	66	CHELLUR-ANTHRASANAHALLI	CHELURU_66	17:57	18:09	0:11	MAIN SUPPLY FAILURE
556	8-Dec-19	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	19:40	20:40	0:59	LINE FAULT
557	8-Dec-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	8:47	8:58	0:10	LINE FAULT
558	8-Dec-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:44	12:46	0:01	LINE FAULT
559	8-Dec-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	13:40	13:48	0:07	LINE FAULT
560	8-Dec-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	13:40	13:48	0:07	LINE FAULT
561	9-Dec-19	BAGALKOT	110	ANKOLA-ARGA(L1)	ARGA_110	16:58	17:10	0:12	LOAD CHANGE OVER
562	9-Dec-19	BAGALKOT	110	110/11KV,HV 2	BANAHATTI_110	9:35	9:47	0:12	HAND TRIPPED
563	9-Dec-19	BAGALKOT	110	110/11KV,HV 2	THORVI_110	11:30	11:55	0:25	HAND TRIPPED
564	9-Dec-19	BAGALKOT	220	AMBEWADI-PONDA 1&2	AMBEWADI_220	10:47	23:59	13:12	LINE CLEAR AVAILED
565	9-Dec-19	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	10:47	12:48	2:01	NFBC ISSUED
566	9-Dec-19	BAGALKOT	110	110/11KV,HV 2	BIJAPUR CITY_110	6:01	11:55	5:54	LINE CLEAR AVAILED
567	9-Dec-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	2:47	3:03	0:16	LINE FAULT
568	9-Dec-19	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	3:52	9:58	6:06	LINE FAULT
569	9-Dec-19	BAGALKOT	110	110/11KV,HVA1	JAMAKHANDI_110	10:11	11:38	1:27	LINE CLEAR AVAILED
570	9-Dec-19	BAGALKOT	110	GHATAPRABHA220-PG HUNSHYAL	PG HUNSHYAL_110	6:40	7:16	0:36	LINE FAULT
571	9-Dec-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:00	19:29	19:29	LINE CLEAR AVAILED
572	9-Dec-19	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	9:49	16:37	6:48	NFBC ISSUED
573	9-Dec-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	11:38	17:27	5:49	LINE CLEAR AVAILED
574	9-Dec-19	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	17:22	20:31	3:09	LINE CLEAR AVAILED
575	9-Dec-19	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	15:43	17:37	1:54	LINE CLEAR AVAILED
576	9-Dec-19	BAGALKOT	110	ANKOLA-ARGA(L1)	ARGA_110	16:58	17:10	0:12	LOAD CHANGE OVER
577	9-Dec-19	BAGALKOT	110	110/11KV,HV 2	BANAHATTI_110	9:35	9:47	0:12	HAND TRIPPED
578	9-Dec-19	BAGALKOT	110	110/11KV,HV 2	THORVI_110	11:30	11:55	0:25	HAND TRIPPED
579	9-Dec-19	BAGALKOT	220	AMBEWADI-PONDA 1&2	AMBEWADI_220	10:47	23:59	13:12	LINE CLEAR AVAILED
580	9-Dec-19	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	10:47	12:48	2:01	NFBC ISSUED
581	9-Dec-19	BAGALKOT	110	110/11KV,HV 2	BIJAPUR CITY_110	6:01	11:55	5:54	LINE CLEAR AVAILED
582	9-Dec-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	2:47	3:03	0:16	LINE FAULT
583	9-Dec-19	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	3:52	9:58	6:06	LINE FAULT
584	9-Dec-19	BAGALKOT	110	110/11KV,HVA1	JAMAKHANDI_110	10:11	11:38	1:27	LINE CLEAR AVAILED
585	9-Dec-19	BAGALKOT	110	GHATAPRABHA220-PG HUNSHYAL	PG HUNSHYAL_110	6:40	7:16	0:36	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
586	9-Dec-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:00	19:29	19:29	LINE CLEAR AVAILED
587	9-Dec-19	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	9:49	16:37	6:48	NFBC ISSUED
588	9-Dec-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	11:38	17:27	5:49	LINE CLEAR AVAILED
589	9-Dec-19	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	17:22	20:31	3:09	LINE CLEAR AVAILED
590	9-Dec-19	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	15:43	17:37	1:54	LINE CLEAR AVAILED
591	9-Dec-19	BENGALURU	66	HOSKOTE 66-MALUR 2	HOSKOTE 66	11:35	11:40	0:05	LOAD CHANGE OVER
592	9-Dec-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	10:12	10:53	0:41	LINE FAULT
593	9-Dec-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	14:26	15:32	1:06	LINE CLEAR AVAILED
594	9-Dec-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:28	14:32	0:04	LINE CLEAR AVAILED
595	9-Dec-19	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	14:20	14:36	0:16	LINE CLEAR AVAILED
596	9-Dec-19	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	15:28	15:39	0:11	LINE CLEAR AVAILED
597	9-Dec-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	15:28	15:39	0:11	LINE CLEAR AVAILED
598	9-Dec-19	BENGALURU	66	HV1	MUDIYANUR	11:57	13:10	1:13	TRANSFORMER FAULT
599	9-Dec-19	BENGALURU	66	HV2	Y HUNSENAHALLI	11:23	11:30	0:07	LINE CLEAR AVAILED
600	9-Dec-19	BENGALURU	66	Y HUNASENAHALLI - TALAWARA	Y HUNASENAHALLI	15:10	15:25	0:15	LINE CLEAR AVAILED
601	9-Dec-19	BENGALURU	66	HAL 220-HOODY 1	ISRO (EHT)	18:37	19:44	1:07	LINE CLEAR AVAILED
602	9-Dec-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	18:37	19:44	1:07	LINE CLEAR AVAILED
603	9-Dec-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	9:59	10:20	0:21	LINE FAULT
604	9-Dec-19	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	10:20	10:35	0:15	LINE FAULT
605	9-Dec-19	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	18:37	19:07	0:30	MAIN SUPPLY FAILURE
606	9-Dec-19	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI, EXORA	19:40	19:45	0:05	LOAD CHANGE OVER
607	9-Dec-19	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 220	JIGANI 220	10:18	10:46	0:28	LINE FAULT
608	9-Dec-19	BENGALURU	66	HV2	ANEKAL	11:10	11:39	0:28	LINE CLEAR AVAILED
609	9-Dec-19	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	12:25	12:28	0:03	LINE CLEAR AVAILED
610	9-Dec-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	TUBUGERE	14:02	14:31	0:29	MAIN SUPPLY FAILURE
611	9-Dec-19	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	14:02	14:31	0:29	MAIN SUPPLY FAILURE
612	9-Dec-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	14:02	14:31	0:29	MAIN SUPPLY FAILURE
613	9-Dec-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:17	15:24	0:07	LINE FAULT
614	9-Dec-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:17	16:31	0:14	LINE CLEAR AVAILED
615	9-Dec-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	16:17	16:35	0:18	LINE CLEAR AVAILED
616	9-Dec-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	16:17	16:35	0:18	LINE CLEAR AVAILED
617	9-Dec-19	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	14:37	14:43	0:06	LINE CLEAR AVAILED
618	9-Dec-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	16:34	19:38	3:04	LINE FAULT
619	9-Dec-19	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR	11:56	13:28	1:31	LINE CLEAR AVAILED
620	9-Dec-19	BENGALURU	66	BOMMASANDRA I/A - ELECTRONIC CITY	BOMMASANDRA I/A	9:30	9:32	0:02	LOAD CHANGE OVER
621	9-Dec-19	BENGALURU	220	HV1	YARANDANAHALLI 220	10:18	10:31	0:13	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
622	9-Dec-19	BENGALURU	220	HV1	DB PURA 220	14:02	14:30	0:28	MAIN SUPPLY FAILURE
623	9-Dec-19	BENGALURU	220	HV2	DB PURA 220	14:02	14:24	0:22	MAIN SUPPLY FAILURE
624	9-Dec-19	BENGALURU	220	HV2	DB PURA 220	14:24	16:09	1:45	TRANSFORMER FAULT
625	9-Dec-19	GULBARGA	110	HV2	BETAGERA_110	11:07	11:38	0:31	HAND TRIPPED
626	9-Dec-19	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	2:55	3:05	0:10	LINE FAULT
627	9-Dec-19	GULBARGA	110	GURUMITKAL-SEDAM	GURUMITAKAL_110,KONKAL_110	2:55	3:05	0:10	LINE FAULT
628	9-Dec-19	GULBARGA	110	SHAHPUR-KHANAPUR	WADAGERA_110KHANAPUR_GLB_110,SAIDAPUR_GLB_110,	19:02	19:30	0:28	LINE FAULT
629	9-Dec-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	20:45	20:51	0:06	LINE FAULT
630	9-Dec-19	GULBARGA	110	HV2	CHITGUPPA_110	16:05	16:45	0:40	LINE CLEAR AVAILED
631	9-Dec-19	GULBARGA	110	LADHA-RENEWSOLAR_IPP	LADHA_110	17:40	23:29	5:49	LINE CLEAR AVAILED
632	9-Dec-19	GULBARGA	110	YELBURGA-TALATUTAISOLAR_IPP	YELBURGA_110	18:48	19:15	0:27	LINE CLEAR AVAILED
633	9-Dec-19	GULBARGA	66	HV1	KOGALI_66	15:30	15:40	0:10	TRANSFORMER FAULT
634	9-Dec-19	GULBARGA	66	KOGALI-ITTAGI	KOGALI_66	10:10	10:20	0:10	HAND TRIPPED
635	9-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	2:06	2:06	LINE CLEAR AVAILED
636	9-Dec-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:09	23:59	0:50	HAND TRIPPED
637	9-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	5:32	5:32	LINE CLEAR AVAILED
638	9-Dec-19	HASSAN	220	HV3	KAVOOR_220	9:30	16:10	6:40	LINE CLEAR AVAILED
639	9-Dec-19	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	0:00	6:45	6:45	LINE FAULT
640	9-Dec-19	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	10:07	12:25	2:18	LINE CLEAR AVAILED
641	9-Dec-19	HASSAN	110	HV1	PUTTUR_110	15:26	15:45	0:19	LINE CLEAR AVAILED
642	9-Dec-19	HASSAN	66	HASSN220-HN PURA	HASSAN_220	10:25	15:12	4:47	LINE CLEAR AVAILED
643	9-Dec-19	HASSAN	66	HASSN220-MALLALI	HASSAN_220	10:25	14:42	4:17	LINE CLEAR AVAILED
644	9-Dec-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	13:07	14:57	1:50	LINE CLEAR AVAILED
645	9-Dec-19	MYSORE	66	HV1	CHUNCHUNKATTE_66	13:49	14:09	0:19	LINE CLEAR AVAILED
646	9-Dec-19	MYSORE	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66	18:30	18:41	0:10	LINE FAULT
647	9-Dec-19	MYSORE	66	HV1	DUNDANAHALLI_66	5:23	5:42	0:19	TRANSFORMER FAULT
648	9-Dec-19	MYSORE	66	HV1	FTS_66	12:36	18:11	5:34	LINE CLEAR AVAILED
649	9-Dec-19	MYSORE	66	SANTHE SARAGUR-B MATTGERE	B MATKERE_66	5:29	5:38	0:08	LINE FAULT
650	9-Dec-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	6:46	6:51	0:05	LINE FAULT
651	9-Dec-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	3:28	3:32	0:04	LINE FAULT
652	9-Dec-19	TUMKUR	220	TR-2	MADHUGIRI_220	10:58	11:35	0:36	LINE CLEAR AVAILED
653	9-Dec-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	9:58	10:08	0:09	HAND TRIPPED
654	9-Dec-19	TUMKUR	66	TR-2	MADHUGIRI_220	10:58	11:36	0:37	LINE CLEAR AVAILED
655	9-Dec-19	TUMKUR	66	TR-2	MALEBENNUR_66	13:29	13:37	0:08	TRANSFORMER FAULT
656	9-Dec-19	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66,SOKKE_66,JAGALUR_66	1:36	1:44	0:08	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
657	9-Dec-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGID URGA_66,SOKKE_66,JAGALUR_66	5:43	5:55	0:12	LINE FAULT
658	9-Dec-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	23:17	23:24	0:07	LINE FAULT
659	9-Dec-19	TUMKUR	66	TR-1	PANDARAHALLI_66	16:11	16:32	0:21	LINE CLEAR AVAILED
660	9-Dec-19	TUMKUR	66	TR-1	PANDARAHALLI_66	17:22	17:41	0:19	LINE CLEAR AVAILED