

400/220/110/66 kV TRANSMISSION OUTAGES FROM 01.03.22 TO 07.03.22

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1	1-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LOKAPUR_110	22:05	22:26	0:21	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
2	1-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TAKKALAKI_110	17:45	18:11	0:26	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
3	1-Mar-22	BAGALKOT	110	110/11KV,HV2	HANAGAL_110	9:16	9:27	0:11	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
4	1-Mar-22	BAGALKOT	110	110/11KV,HV2	HANAGAL_110	11:10 (01.03.2022)			TRUE	FALSE	FALSE	FALSE	TRANSFORMER OPEN:LINE CLEAR AVAILED
5	1-Mar-22	BAGALKOT	110	110/33KV, HV3	RAMADURGA_110	11:00	11:27	0:27	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
6	1-Mar-22	BAGALKOT	110	110/33KV,HV1	HUBLI_220	11:51	20:48	8:57	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
7	1-Mar-22	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	13:11(23.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
8	1-Mar-22	BAGALKOT	110	BILAGI - BISNAL	BISNAL_110	4:00	4:10	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
9	1-Mar-22	BAGALKOT	110	BILAGI-GIRISAGAR	GIRISAGAR_110	4:00	4:10	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
10	1-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
11	1-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
12	1-Mar-22	BAGALKOT	110	HUBLI-TARIHAL2	STATION NOT AFFECTED HUBLI_220	0:25	1:11	0:46	FALSE	FALSE	FALSE	TRUE	LINE FAULT
13	1-Mar-22	BAGALKOT	110	MUGALKHOD- KULIGOD	STATION NOT AFFECTED MUGALKHOD_220	9:01	19:41	10:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
14	1-Mar-22	BAGALKOT	110	MUGALKHOD- PG HUNSHYAL	STATION NOT AFFECTED MUGALKHOD_220	9:01	19:39	10:38	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
15	1-Mar-22	BAGALKOT	110	MUGALKHOD- SAIDAPUR	STATION NOT AFFECTED MUGALKHOD_220	9:01	19:42	10:41	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
16	1-Mar-22	BAGALKOT	110	MUGALKHOD- SAIDAPUR	STATION NOT AFFECTED MUGALKHOD_220	20:16 (01.03.2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
17	1-Mar-22	BAGALKOT	110	MUGALKHOD-NAGANUR	STATION NOT AFFECTED MUGALKHOD_220	9:01	19:40	10:39	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
18	1-Mar-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
19	1-Mar-22	BAGALKOT	110	SHIRAGUPPI - BILAGI	BILAGI_110	4:00	4:10	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
20	1-Mar-22	BAGALKOT	110	SHIRAGUPPI - VAJRAMATI	SHIRAGUPPI_110	4:00	4:10	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
21	1-Mar-22	BAGALKOT	110	SIRAGUPPI-TOLAMATTI	TOLAMATTI_110	4:00	4:10	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
22	1-Mar-22	BAGALKOT	110	VAJRAMATTI220 - KATARKI	STATION NOT AFFECTED VAJRAMATTI_220	3:51	4:04	0:13	FALSE	FALSE	FALSE	TRUE	LINE FAULT
23	1-Mar-22	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	13:36	14:36	1:00	FALSE	FALSE	FALSE	TRUE	LINE FAULT
24	1-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
25	1-Mar-22	BAGALKOT	220	DHONI-GADAG1	DHONI_400	13:05	16:32	3:27	FALSE	FALSE	FALSE	TRUE	LINE FAULT
26	1-Mar-22	BAGALKOT	220	DHONI-GADAG2	DHONI_400	16:30 (01.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
27	1-Mar-22	BAGALKOT	220	DHONI-HALVARTI 1	DHONI_400	18:34 (01.03.2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
28	1-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
29	1-Mar-22	BAGALKOT	220	GADAG-LINGAPUR(DHONI1)	STATION NOT AFFECTED GADAG_220	13:06	16:32	3:26	FALSE	FALSE	FALSE	TRUE	LINE FAULT
30	1-Mar-22	BAGALKOT	220	GADAG-LINGAPUR(DHONI2)	STATION NOT AFFECTED GADAG_220	13:07	16:31	3:24	FALSE	FALSE	FALSE	TRUE	LINE FAULT
31	1-Mar-22	BAGALKOT	220	GADAG-LINGAPUR(DHONI2)	STATION NOT AFFECTED GADAG_220	17:34 (01.03.2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
32	1-Mar-22	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	9:42	17:42	8:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
33	1-Mar-22	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	9:42	17:46	8:04	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
34	1-Mar-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
35	1-Mar-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
36	1-Mar-22	BAGALKOT	400	DHONI-GUTTUR	DHONI_400	15:10	19:19	4:09	FALSE	FALSE	FALSE	TRUE	LINE FAULT
37	1-Mar-22	BENGALURU	66	ALUR - NELAMANGALA 66	BIEC, ALUR	12:42	12:49	0:07	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
38	1-Mar-22	BENGALURU	66	ALUR - SRS PEENYA 220	BIEC, ALUR	6:47	9:52	3:05	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
39	1-Mar-22	BENGALURU	66	BG ROAD - JIGANI 66	BG ROAD, JIGANI 66	9:37	9:47	0:10	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
40	1-Mar-22	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	9:47	9:54	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
41	1-Mar-22	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	6:47	7:21	0:34	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
42	1-Mar-22	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	12:42	12:51	0:09	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
43	1-Mar-22	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA	12:42	12:51	0:09	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
44	1-Mar-22	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	6:47	7:21	0:34	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
45	1-Mar-22	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	12:42	12:51	0:09	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
46	1-Mar-22	BENGALURU	66	GOKULA - SRS PEENYA 220 1 & 2	GOKULA	6:47	7:21	0:34	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
47	1-Mar-22	BENGALURU	66	HEBBALA 220 - ITI 1	BANASAWADI	7:54	8:04	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
48	1-Mar-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:35	10:53	0:18	FALSE	FALSE	FALSE	TRUE	LINE FAULT
49	1-Mar-22	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	7:33	7:37	0:04	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
50	1-Mar-22	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	7:13	7:52	0:39	FALSE	FALSE	FALSE	TRUE	LINE FAULT
51	1-Mar-22	BENGALURU	66	HV1	BANASAWADI	7:54	8:04	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
52	1-Mar-22	BENGALURU	66	HV1	KONDASPURA	10:39	11:01	0:22	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
53	1-Mar-22	BENGALURU	66	HV2	KACHAMARANAHALLI	8:28	8:36	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
54	1-Mar-22	BENGALURU	66	HV2	MAASTHI	6:05	6:35	0:30	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
55	1-Mar-22	BENGALURU	66	HV2	SRS PEENYA 220	6:47	13:00	6:13	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
56	1-Mar-22	BENGALURU	66	HV3	BANASAWADI	7:54	8:04	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
57	1-Mar-22	BENGALURU	66	HV4	SRS PEENYA 220	6:47	7:48	1:01	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
58	1-Mar-22	BENGALURU	66	IISc - HEBBALA 220	IISc	7:27	7:30	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
59	1-Mar-22	BENGALURU	66	IISc - NRS 220	IISc	17:08	17:13	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
60	1-Mar-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	12:00	12:16	0:16	FALSE	FALSE	FALSE	TRUE	LINE FAULT
61	1-Mar-22	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	13:20	13:25	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
62	1-Mar-22	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	6:47	7:04	0:17	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
63	1-Mar-22	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	6:47	7:00	0:13	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
64	1-Mar-22	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	13:50	13:55	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
65	1-Mar-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	13:20	13:25	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
66	1-Mar-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	6:47	7:04	0:17	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
67	1-Mar-22	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	10:19	10:22	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
68	1-Mar-22	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	6:47	7:10	0:23	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
69	1-Mar-22	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	6:47	7:00	0:13	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
70	1-Mar-22	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	13:08	13:12	0:04	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
71	1-Mar-22	BENGALURU	66	SIDLAGATTA - MELUR	MELUR	8:50	8:55	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
72	1-Mar-22	BENGALURU	66	SIDLAGATTA - MELUR	MELUR	9:49	9:55	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
73	1-Mar-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66	8:05	8:56	0:51	FALSE	FALSE	FALSE	TRUE	LINE FAULT
74	1-Mar-22	BENGALURU	66	SOMENAHALLI - GOWRIBIDANUR 220	SOMENAHALLI, PERESANDRA	8:30	8:45	0:15	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
75	1-Mar-22	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI, PERESANDRA	12:21	12:42	0:20	FALSE	FALSE	FALSE	TRUE	LINE FAULT
76	1-Mar-22	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	6:47	7:28	0:41	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
77	1-Mar-22	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	13:00	13:08	0:08	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
78	1-Mar-22	BENGALURU	220	HV2	MITTEMARI 220	4:00(28-2-2022)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
79	1-Mar-22	BENGALURU	220	HV2	SRS PEENYA 220	6:47	12:20	5:33	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
80	1-Mar-22	BENGALURU	220	HV4	SRS PEENYA 220	6:47	12:20	5:33	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
81	1-Mar-22	GULBARGA	66	HV1	HARVI_66	7:44	8:30	0:46	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
82	1-Mar-22	GULBARGA	66	HV2	TAMBRAHALLI_66	7:02	7:08	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
83	1-Mar-22	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	18:16	19:01	0:45	FALSE	FALSE	FALSE	TRUE	LINE FAULT
84	1-Mar-22	GULBARGA	110	HV2	GHATTARGA_110	11:40(28.02.2022)	14:40(01.03.2022)	27:00 hrs	TRUE	FALSE	FALSE	FALSE	TRANSFORMER CHARGED
85	1-Mar-22	GULBARGA	110	JAWALGERA-ADAVI AMARESHWAR_110	ADAVI AMARESHWAR_110	2:50	3:00	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
86	1-Mar-22	GULBARGA	110	MASKI-RENEW SOLAR	MASKI_110	14:46	14:52	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
87	1-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:35	3:40	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
88	1-Mar-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	7:18	7:26	0:08	FALSE	FALSE	FALSE	TRUE	LINE FAULT
89	1-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
90	1-Mar-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	18:44	18:48	0:04	FALSE	FALSE	FALSE	TRUE	LINE FAULT
91	1-Mar-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	21:28	21:38	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
92	1-Mar-22	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	18:24	18:37	0:13	FALSE	FALSE	FALSE	TRUE	LINE FAULT
93	1-Mar-22	GULBARGA	220	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(28.02.2022)	15:54(01.03.2022)	23:42HRS	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
94	1-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
95	1-Mar-22	GULBARGA	220	ITTAGI-LINGAPUR	ITTAGI_220	13:06 (28.02.2022)	3:19 (1.03.2022)	14:13 HRS	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
96	1-Mar-22	GULBARGA	220	LINGAPUR-HALAVARTHY	HALAVARTHY_220	18:24	21:34	3:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
97	1-Mar-22	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	7:57	8:21	0:24	FALSE	FALSE	FALSE	TRUE	LINE FAULT
98	1-Mar-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	14:05	14:11	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
99	1-Mar-22	HASSAN	66	HV1	SAKALESHPURA_66	1:36	1:45	0:09	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
100	1-Mar-22	HASSAN	66	HV1	SAKALESHPURA_66	1:54	3:25	1:31	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
101	1-Mar-22	HASSAN	66	HV1	SAKALESHPURA_66	3:30	3:56	0:26	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
102	1-Mar-22	HASSAN	66	HV1	SAKALESHPURA_66	3:59	4:34	0:35	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
103	1-Mar-22	HASSAN	66	HV1	SAKALESH PURA_66	4:49	4:56	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
104	1-Mar-22	HASSAN	66	HV1	SAKALESH PURA_66	5:48	5:56	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
105	1-Mar-22	HASSAN	66	HV1	SAKALESH PURA_66	16:11	16:19	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
106	1-Mar-22	HASSAN	66	HV1	SAKALESH PURA_66	18:10	18:18	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
107	1-Mar-22	HASSAN	66	HV1	SAKALESH PURA_66	18:20	18:26	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
108	1-Mar-22	HASSAN	66	HV1	SOMANAHALLY_66	10:38	10:46	0:08	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
109	1-Mar-22	HASSAN	66	HV1	SOMANAHALLY_66	16:35	16:42	0:07	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
110	1-Mar-22	HASSAN	66	HV4	BALEHONNUR_66	10:27	10:55	0:28	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
111	1-Mar-22	HASSAN	66	MALALI-CRPATNA	MALALI_66	14:09	14:25	0:16	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
112	1-Mar-22	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	15:28	15:35	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
113	1-Mar-22	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	10:29	18:42	8:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
114	1-Mar-22	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	10:29	18:42	8:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
115	1-Mar-22	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
116	1-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	11:22	11:57	0:35	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
117	1-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	12:42	13:20	0:38	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
118	1-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	14:56	17:06	2:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
119	1-Mar-22	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	6:44	6:57	0:13	FALSE	FALSE	FALSE	TRUE	LINE FAULT
120	1-Mar-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	14:02	14:17	0:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
121	1-Mar-22	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
122	1-Mar-22	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	13:06	15:11	2:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
123	1-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
124	1-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
125	1-Mar-22	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66 ARKALWADI_66	6:13	6:19	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
126	1-Mar-22	MYSURU	66	HARADANAHALLI (JAK)-LAXJEET	NO STATIONS EFFECTED	9:34	9:41	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
127	1-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8/12/2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
128	1-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8/12/2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
129	1-Mar-22	MYSURU	66	HOOTAGALLY-FTS 1	NO STATIONS EFFECTED	10:09	18:13	8:04	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
130	1-Mar-22	MYSURU	66	HOOTAGALLY-FTS 2	NO STATIONS EFFECTED	10:09	18:13	8:04	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
131	1-Mar-22	MYSURU	66	HOOTGALLI-DATTAGALLI	DATTAGALLY_66 RKNAGARA_66	20:36	20:48	0:12	FALSE	FALSE	FALSE	TRUE	LINE FAULT
132	1-Mar-22	MYSURU	66	HV1	BHARGI_66	12:40	12:45	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
133	1-Mar-22	MYSURU	66	HV1	PONNAMPET_66	11:32	11:40	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
134	1-Mar-22	MYSURU	66	HV2	BILIKERE_66	8:03	8:13	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
135	1-Mar-22	MYSURU	66	HV2	BILIKERE_66	8:51	9:02	0:11	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
136	1-Mar-22	MYSURU	66	HV2	THUMBLA_66	13:25	17:20	3:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
137	1-Mar-22	MYSURU	66	HV4	SFCSHIVA_66	21:39:38 (28/02/2022)	14:56(1.03.22)	17:16HRs	TRUE	FALSE	FALSE	FALSE	TRANSFORMER CHARGED
138	1-Mar-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
139	1-Mar-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
140	1-Mar-22	MYSURU	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	22:47:36 (28/02/2022)	9:30:(1.03.22)	10:42HRs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
141	1-Mar-22	MYSURU	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	0:36	0:57	0:21	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
142	1-Mar-22	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	14:30	14:36	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
143	1-Mar-22	MYSURU	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	11:32	11:43	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
144	1-Mar-22	MYSURU	66	NANJANAGUDU-SINDHUVALLI	NO STATIONS EFFECTED	22:48:00 (28/02/2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
145	1-Mar-22	MYSURU	66	NANJANAGUDU-THANDYA	NANJANGUDU_66	22:48:00 (28/02/2022)	9:40(1.03.22)	10:52HRs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
146	1-Mar-22	MYSURU	66	THANDYA-NANJANGUDU	NO STATIONS EFFECTED	23:26:31 (28/02/2022)	9:39(1.03.22)	10:12HRs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
147	1-Mar-22	TUMKUR	66	DAVANGERE SRS-SOKKE	MELLEKATTE_66, SOKKE_66	13:07	13:17	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
148	1-Mar-22	TUMKUR	66	DAVANGERE SRS-SOKKE	MELLEKATTE_66, SOKKE_66	18:01	18:43	0:42	FALSE	FALSE	FALSE	TRUE	LINE FAULT
149	1-Mar-22	TUMKUR	66	DEVARAHALLI-NALLUR	DEVARAHALLI_66	19:02	19:06	0:04	FALSE	FALSE	FALSE	TRUE	LINE FAULT
150	1-Mar-22	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-2	INFOSYS-2	8:24	8:39	0:15	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
151	1-Mar-22	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-2	INFOSYS-2	11:50	12:38	0:48	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
152	1-Mar-22	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	17:55	18:26	0:31	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
153	1-Mar-22	TUMKUR	66	PD KOTE -CLEAR SOLAR-IPP	CLEAR SOLAR_IPP_66	13:32	13:39	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
154	1-Mar-22	TUMKUR	66	PD KOTE -CLEAR SOLAR-IPP	CLEAR SOLAR_IPP_66	14:06	14:12	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
155	1-Mar-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	3:40	3:45	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
156	1-Mar-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	8:05	8:10	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
157	1-Mar-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	16:20	16:25	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
158	1-Mar-22	TUMKUR	66	TR-1	SIRA_66	13:30	13:35	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
159	1-Mar-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	9:10	9:15	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
160	1-Mar-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	9:30	9:35	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
161	1-Mar-22	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	10:43	11:55	1:12	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
162	1-Mar-22	TUMKUR	66	TR-2	KADAJJI_66	9:04	9:55	0:51	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
163	1-Mar-22	TUMKUR	66	TR-2	KOLALA_66	14:41	14:55	0:14	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
164	1-Mar-22	TUMKUR	110	TR-1	MAYASANDRA_110	8:41	8:54	0:13	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
165	1-Mar-22	TUMKUR	220	KB CROSS-SHIMOGA	KB CROSS_220	13:08	13:19	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
166	1-Mar-22	TUMKUR	220	TR-1	KB CROSS_220	14:12	15:16	1:04	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
167	1-Mar-22	TUMKUR	220	TR-2	KB CROSS_220	14:12	15:16	1:04	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
168	02-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED,MUNDUGANUR_110	17:15	17:25	0:10	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
169	02-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED,NIDAGUNDI_110	9:15	9:18	0:03	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
170	02-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED,UKKALI_110	15:24	15:29	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
171	02-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED,NANADI_110	22:13	23:20	1:07	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
172	02-Mar-22	BAGALKOT	110	110/11KV,HV1	GOKAK_110	22:28	22:31	0:03	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
173	02-Mar-22	BAGALKOT	110	110/11KV,HV2	AIGALI_110	13:14	13:22	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
174	02-Mar-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED HANAGAL_110	11:10 (01.03.2022)			TRUE	FALSE	FALSE	FALSE	TRANSFORMER OPEN:LINE CLEAR AVAILED
175	02-Mar-22	BAGALKOT	110	110/33KV,HV2	HANAGAL_110 & BOMMANALLI_33	9:10	9:20	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
176	02-Mar-22	BAGALKOT	110	AMBEWADI-(KAVALWADA)NK-2	STATION NOT AFFECTED AMBEWADI_220	15:18	15:54	0:36	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
177	02-Mar-22	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	13:11(23.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
178	02-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
179	02-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVKLD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
180	02-Mar-22	BAGALKOT	110	HIREMASALI-ATHARGA(F2)	ATHARGA_110	16:09	16:17	0:08	FALSE	FALSE	FALSE	TRUE	LINE FAULT
181	02-Mar-22	BAGALKOT	110	HUKKERI-HATTARAGI	HUKKERI_110 (STATION NOT AFFECTED)	12:56	21:57	9:01	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
182	02-Mar-22	BAGALKOT	110	HUKKERI-VS	HUKKERI_110	12:56	13:01	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
183	02-Mar-22	BAGALKOT	110	MUGALKHOD- SAIDAPUR	STATION NOT AFFECTED,MUGALKHOD_220	20:16 (01.03.2022)	18:51(02.03.2022)	22:35 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
184	02-Mar-22	BAGALKOT	110	MUGALKHOD-KULIGOD	STATION NOT AFFECTED MUGALKHOD_220	8:55	18:52	9:57	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
185	02-Mar-22	BAGALKOT	110	MUGALKHOD-NAGANUR	STATION NOT AFFECTED MUGALKHOD_220	8:55	18:53	9:58	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
186	02-Mar-22	BAGALKOT	110	MUGALKHOD-P G HUNSHYAL	STATION NOT AFFECTED MUGALKHOD_220	9:03	18:54	9:51	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
187	02-Mar-22	BAGALKOT	110	RANEBENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	18:42(14.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
188	02-Mar-22	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	12:44	12:51	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
189	02-Mar-22	BAGALKOT	110	SOUDATTI-ENERCON 1&2	ENERCON_110 STATION NOT AFFECTED SOUDATTI_110	15:06	17:00	1:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
190	02-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
191	02-Mar-22	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI_400	12:17	15:09	2:52	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
192	02-Mar-22	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI_400	16:02 (02.03.2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
193	02-Mar-22	BAGALKOT	220	DHONI-GADAG2	STATION NOT AFFECTED DHONI_400	16:30 (01.03.2022)	16:41 (02.03.2022)	24:11 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
194	02-Mar-22	BAGALKOT	220	DHONI-HALVARTI 1	STATION NOT AFFECTED DHONI_400	18:34 (01.03.2022)	16:35 (02.03.2022)	22:01 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
195	02-Mar-22	BAGALKOT	220	GADAG-DHONI1	STATION NOT AFFECTED GADAG_220	12:17	15:09	2:52	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
196	02-Mar-22	BAGALKOT	220	GADAG-DHONI1	STATION NOT AFFECTED GADAG_220	16:02 (02.03.2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
197	02-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
198	02-Mar-22	BAGALKOT	220	GADAG-LINGAPUR(DHONI2)	STATION NOT AFFECTED GADAG_220	17:34 (01.03.2022)	16:41 (02.03.2022)	23:07 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
199	02-Mar-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
200	02-Mar-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
201	02-Mar-22	BENGALURU	66	GANIJUGUNTE - DIBBURAHALLI	DIBBURAHALLI	7:54	8:06	0:12	FALSE	FALSE	FALSE	TRUE	LINE FAULT
202	02-Mar-22	BENGALURU	66	GLOBAL TECH PARK - HSR LAYOUT 220	GLOBAL TECH PARK	11:28	11:32	0:04	FALSE	FALSE	FALSE	TRUE	LINE FAULT
203	02-Mar-22	BENGALURU	66	HV2	GUDIBANDE	9:10	9:19	0:09	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
204	02-Mar-22	BENGALURU	66	HV2	SRS PEENYA 220	8:02	8:21	0:19	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
205	02-Mar-22	BENGALURU	66	HV2	SRS PEENYA 220	8:30	8:40	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
206	02-Mar-22	BENGALURU	66	HV2	SRS PEENYA 220	9:36	9:43	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
207	02-Mar-22	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	13:28	13:52	0:24	FALSE	FALSE	FALSE	TRUE	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
208	02-Mar-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	NO STATION AFFECTED	18:46	18:57	0:10	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
209	02-Mar-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	18:46	18:48	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
210	02-Mar-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	6:18	6:22	0:04	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
211	02-Mar-22	BENGALURU	66	PALLICHERLU - ACME SOLAR(IPP)	NO STATION AFFECTED	7:54	8:30	0:35	FALSE	FALSE	FALSE	TRUE	LINE FAULT
212	02-Mar-22	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	14:22	14:25	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
213	02-Mar-22	BENGALURU	66	VIDHURASHRAWATHA - GREEN SOLAR(IPP)	NO STATION AFFECTED	6:54	12:52	5:58	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
214	02-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	12:56	13:26	0:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
215	02-Mar-22	BENGALURU	220	HV1	YARANDANAHALLI 220	12:56	13:26	0:30	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
216	02-Mar-22	BENGALURU	220	HV2	MITTEMARI 220	4:00(28-2-2022)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
217	02-Mar-22	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKA NAHALLI_66,HAGARIBOMMAN AHALLI_66,RR STEELS_IPP	5:56	6:05	0:09	FALSE	FALSE	FALSE	TRUE	LINE FAULT
218	02-Mar-22	GULBARGA	110	HATTI-GAMESH	HATTI_110	14:05	14:23	0:18	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
219	02-Mar-22	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	12:00(2.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
220	02-Mar-22	GULBARGA	110	HV1	CHINCHOLI_110	14:15	18:40	4:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
221	02-Mar-22	GULBARGA	110	HV1	NIRNA_110	14:49	14:56	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
222	02-Mar-22	GULBARGA	110	HV2	SREERAMANAGAR_110	10:10	11:29	1:19	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
223	02-Mar-22	GULBARGA	110	HV2	SREERAMANAGAR_110	11:29	18:50	7:21	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
224	02-Mar-22	GULBARGA	110	JAWALGERA-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	3:20	3:25	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
225	02-Mar-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	23:19	23:29	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
226	02-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
227	02-Mar-22	GULBARGA	110	SINDHANOOR-NIRLOTI_IPP	SINDHANOOR_220	5:07	5:17	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
228	02-Mar-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	2:15	2:25	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
229	02-Mar-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	21:55	22:05	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
230	02-Mar-22	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	22:10	22:25	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
231	02-Mar-22	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	20:53	20:57	0:04	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
232	02-Mar-22	GULBARGA	220	HV2	HALBARGA_220	16:03	17:05	1:02	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
233	02-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
234	02-Mar-22	GULBARGA	220	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_I PP,HUNASIGI_110,ASKI_110	3:42	3:48	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
235	02-Mar-22	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	6:05	6:10	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
236	02-Mar-22	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	5:58	6:05	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
237	02-Mar-22	HASSAN	66	HV1	BYACHANAHALLY_66	10:45	12:28	1:43	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
238	02-Mar-22	HASSAN	66	HV1	CHANNARAYPATTANA_220	0:57	1:32	0:35	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
239	02-Mar-22	HASSAN	66	HV1	CHIKMANGALORE_66	18:46	19:10	0:24	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
240	02-Mar-22	HASSAN	66	HV1	DUDDA_66	8:06	8:30	0:24	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
241	02-Mar-22	HASSAN	66	HV1	HNPURA_66	6:05	6:10	0:05	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
242	02-Mar-22	HASSAN	66	HV2	HNPURA_66	6:05	6:10	0:05	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
243	02-Mar-22	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	22:06	22:13	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
244	02-Mar-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	10:50	16:56	6:06	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
245	02-Mar-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	10:50	16:56	6:06	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
246	02-Mar-22	HASSAN	110	HV2	KADUR_220	18:35	19:10	0:35	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
247	02-Mar-22	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
248	02-Mar-22	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
249	02-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
250	02-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
251	02-Mar-22	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66 ARKALWADI_66	6:13	6:19	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
252	02-Mar-22	MYSURU	66	HARADANAHALLI (JAK)-LAXJEET	NO STATIONS EFFECTED	9:34	9:41	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
253	02-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16(8/12/2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
254	02-Mar-22	MYSURU	66	HOOTGALLI-DATTAGALLI	DATTAGALLY_66 RKNAGARA_66	20:36	20:48	0:12	FALSE	FALSE	FALSE	TRUE	LINE FAULT
255	02-Mar-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38(9/1/2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
256	02-Mar-22	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66,NIDSALE_66,DUNDANAHALLI_66	6:19	6:29	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
257	02-Mar-22	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	7:22	7:35	0:13	FALSE	FALSE	FALSE	TRUE	LINE FAULT
258	02-Mar-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:22	7:35	0:13	FALSE	FALSE	FALSE	TRUE	LINE FAULT
259	02-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	7:22	7:36	0:13	FALSE	FALSE	FALSE	TRUE	LINE FAULT
260	02-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:51	20:08	0:16	FALSE	FALSE	FALSE	TRUE	LINE FAULT
261	02-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:14	18:34	0:20	FALSE	FALSE	FALSE	TRUE	LINE FAULT
262	02-Mar-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	7:23	7:35	0:12	FALSE	FALSE	FALSE	TRUE	LINE FAULT
263	02-Mar-22	TUMKUR	66	H D PURA- SUZLON_IPP_66	SUZLON_IPP_66	6:43	7:39	0:56	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
264	02-Mar-22	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66,HOLAVINAHALLI_66	18:08	18:10	0:01	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
265	02-Mar-22	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI66	MADHUGIRI_66, BADAVANAHALLI_66	17:12	18:07	0:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
266	02-Mar-22	TUMKUR	66	MADHUGIRI 220kV-PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	18:08	18:10	0:01	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
267	02-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:42	7:38	0:56	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
268	02-Mar-22	TUMKUR	66	TR-1	CHITRADURGA_66	11:47	16:02	4:14	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
269	02-Mar-22	TUMKUR	66	TR-1	CHITRADURGA_66	14:26	16:01	1:34	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
270	02-Mar-22	TUMKUR	66	TR-1(HV SIDE)	KIADB V N PURA_220	10:14	16:17	6:02	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
271	02-Mar-22	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI 220kV	11:32	17:46	6:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
272	02-Mar-22	TUMKUR	66	TR-2	GUTTUR_66	16:42	16:44	0:01	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
273	02-Mar-22	TUMKUR	66	TR-2	KOLALA_66	15:07	15:39	0:31	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
274	02-Mar-22	TUMKUR	66	TR-2	LINGADHALLI_66	10:43	11:50	1:07	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
275	02-Mar-22	TUMKUR	66	TR-2	SHYLAPURA_66	12:24	12:27	0:03	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
276	02-Mar-22	TUMKUR	66	TR-2	BADAVANAHALLI_66	7:04	7:15	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
277	02-Mar-22	TUMKUR	66	TR-2	BENKIKERE_66	2:57	3:03	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
278	02-Mar-22	TUMKUR	66	TR-2	BRAHMASANDRA_66	10:26	10:51	0:24	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
279	02-Mar-22	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	12:29	12:37	0:08	FALSE	FALSE	FALSE	TRUE	LINE FAULT
280	02-Mar-22	TUMKUR	110	TR-1	BIDARE_110	12:09	12:40	0:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
281	02-Mar-22	TUMKUR	110	TR-1	MAYASANDRA_110	12:07	12:15	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
282	02-Mar-22	TUMKUR	110	TR-2	BIDARE_110	12:09	12:40	0:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
283	02-Mar-22	TUMKUR	220	TR-1(HV SIDE)	KIADB V N PURA_220	10:15	16:16	6:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
284	02-Mar-22	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI 220kV	11:32	18:06	6:34	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
285	3-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TAKKALAKI_110	7:01	7:50	0:49	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
286	3-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UKALI_110	12:32	12:50	0:18	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
287	3-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UKALI_110	12:50	13:01	0:11	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
288	3-Mar-22	BAGALKOT	110	110/11KV, HV1	UMMACHAGI_110	4:40	4:50	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
289	3-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_220	19:15	19:25	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
290	3-Mar-22	BAGALKOT	110	110/11KV,HV 2	HIDIKAL DAM_110	14:57	15:18	0:21	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
291	3-Mar-22	BAGALKOT	110	110/11KV,HV1	DEVAR GENNUR_110	12:10	12:29	0:19	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
292	3-Mar-22	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	11:49	11:56	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
293	3-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	10:26	10:31	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
294	3-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	12:14	12:36	0:22	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
295	3-Mar-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	18:33	18:34	0:01	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
296	3-Mar-22	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	22:34 (3.3.2022)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
297	3-Mar-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED HANAGAL_110	11:10 (01.03.2022)	12:30 (3.3.2022)	29:20 hrs	TRUE	FALSE	FALSE	FALSE	TRANSFORMER CHARGED
298	3-Mar-22	BAGALKOT	110	110/11KV,HV3	HANAGALL_110	12:33 (3.3.2022)			TRUE	FALSE	FALSE	FALSE	TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
299	3-Mar-22	BAGALKOT	110	110/11KV,HV3	MUNDARAGI_110	14:20	14:24	0:04	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
300	3-Mar-22	BAGALKOT	110	110/11KV,HV4	KULIGOD_110	8:54	18:20	9:26	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
301	3-Mar-22	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	12:35	14:36	2:01	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
302	3-Mar-22	BAGALKOT	110	AMBEWADI- NK-2 (KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	14:18	14:25	0:07	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
303	3-Mar-22	BAGALKOT	110	AMBEWADI- NK-2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	21:50	22:05	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
304	3-Mar-22	BAGALKOT	110	ANKOLA-KUMATA(L2)	KUMATA_110	10:36	13:24	2:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
305	3-Mar-22	BAGALKOT	110	BAGALKOT(KATARAKI)- NEERBUDIHAI	NEERBUDIHAI_110	12:35	14:43	2:08	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
306	3-Mar-22	BAGALKOT	110	BAGALKOT220-KALADAGI	STATION NOT AFFECTED BAGALKOT_220	9:50	18:30	8:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
307	3-Mar-22	BAGALKOT	110	BAGALKOT-KALADAGI	KALADAGI_110	9:50	18:47	8:57	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
308	3-Mar-22	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	13:11 (23.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
309	3-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
310	3-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
311	3-Mar-22	BAGALKOT	110	HUNGUND-JINDAL	HUNGUND_110 (STATION NOT AFFECTED)	11:06	18:46	7:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
312	3-Mar-22	BAGALKOT	110	KARWAR220-ARGA(KUMATA)	STATION NOT AFFECTED KARWAR_220	15:12	15:25	0:13	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
313	3-Mar-22	BAGALKOT	110	KARWAR220-SOLARIS(BINAGA)	STATION NOT AFFECTED KARWAR_220	14:00	14:30	0:30	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
314	3-Mar-22	BAGALKOT	110	KARWAR220-SOLARIS(BINAGA)	STATION NOT AFFECTED KARWAR_220	15:12	15:25	0:13	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
315	3-Mar-22	BAGALKOT	110	KIRUVATTI-UMACHAGI	UMACHAGI_110	21:49	22:14	0:25	FALSE	FALSE	FALSE	TRUE	LINE FAULT
316	3-Mar-22	BAGALKOT	110	KULIGOD-GMSH	STATION NOT AFFECTED KULIGOD_110	17:12	17:18	0:06	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
317	3-Mar-22	BAGALKOT	110	KUMATA-SIRSI 1	STATION NOT AFFECTED KUMATA_110	13:30	14:42	1:12	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
318	3-Mar-22	BAGALKOT	110	MRUTYUNJAY NAGAR- L1 GOPANAKOPPA	MRUTYUNJAY NAGAR_110 (STATION NOT AFFECTED)	11:24	13:41	2:17	FALSE	FALSE	FALSE	TRUE	LINE FAULT
319	3-Mar-22	BAGALKOT	110	MUGALKHOD- KULIGOD	STATION NOT AFFECTED MUGALKHOD_220	9:04	16:50	7:46	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
320	3-Mar-22	BAGALKOT	110	MUGALKHOD- PG HUNSHYAL	STATION NOT AFFECTED MUGALKHOD_220	9:11	21:11	12:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
321	3-Mar-22	BAGALKOT	110	MUGALKHOD- SAIDAPUR	STATION NOT AFFECTED MUGALKHOD_220	9:03	17:31	8:28	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
322	3-Mar-22	BAGALKOT	110	MUGALKHOD- SULTANPUR	STATION NOT AFFECTED MUGALKHOD_220	16:43	17:27	0:44	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
323	3-Mar-22	BAGALKOT	110	MUGALKHOD-NAGANUR	STATION NOT AFFECTED MUGALKHOD_220	9:06	21:07	12:01	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
324	3-Mar-22	BAGALKOT	110	MUNAVALLI(SOUDATTI220)1- SOUDATTI	STATION NOT AFFECTED SOUDATTI_110	10:09	14:27	4:18	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
325	3-Mar-22	BAGALKOT	110	NAGANUR-F1(PG HUNASYAL)	NAGANUR_110	17:44	20:35	2:51	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
326	3-Mar-22	BAGALKOT	110	NAGANUR-F1(PG HUNASYAL)	NAGANUR_110	21:02 (3.3.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
327	3-Mar-22	BAGALKOT	110	NAGANUR-F2(MUDALAGI)	NAGANUR_110	10:01	14:13	4:12	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
328	3-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI	STATION NOT AFFECTED PG HUNSHYAL_110	17:43	20:20	2:37	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
329	3-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI	STATION NOT AFFECTED PG HUNSHYAL_110	20:28 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
330	3-Mar-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
331	3-Mar-22	BAGALKOT	110	SIRSI220- KAVALLWADA	KAVALLWADA_110	14:19	14:28	0:09	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
332	3-Mar-22	BAGALKOT	110	SIRSI220- KAVALLWADA	STATION NOT AFFECTED SIRSI_220	14:30	14:58	0:28	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
333	3-Mar-22	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	14:30	14:58	0:28	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
334	3-Mar-22	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	10:12	13:23	3:11	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
335	3-Mar-22	BAGALKOT	110	SOUDATTI220- RAMDURGA1	STATION NOT AFFECTED SOUDATTI_220	10:10	14:22	4:12	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
336	3-Mar-22	BAGALKOT	110	SOUDATTI220- SOUDATTI1	STATION NOT AFFECTED SOUDATTI_220	10:09	14:24	4:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
337	3-Mar-22	BAGALKOT	110	SOUDATTI-ENERCON1	STATION NOT AFFECTED SOUDATTI_110	11:38	12:23	0:45	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
338	3-Mar-22	BAGALKOT	110	SOUDATTI-ENERCON1	STATION NOT AFFECTED SOUDATTI_110	13:23	14:47	1:24	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
339	3-Mar-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED BAGALKOT_220	12:35	14:32	1:57	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
340	3-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
341	3-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
342	3-Mar-22	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	11:39 (03.03.2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
343	3-Mar-22	BAGALKOT	220	BIDNAL-NARENDRA	STATION NOT AFFECTED BIDNAL_220	11:07	14:35	3:28	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
344	3-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
345	3-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
346	3-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:33 (3.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
347	3-Mar-22	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI_400	16:02 (02.03.2022)	15:40 (03.03.2022)	23:38	FALSE	FALSE	FALSE	TRUE	LINE CHARGED
348	3-Mar-22	BAGALKOT	220	DHONI-GADAG2	STATION NOT AFFECTED DHONI_400	11:04	15:41	4:37	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
349	3-Mar-22	BAGALKOT	220	GADAG-DHONI1	STATION NOT AFFECTED GADAG_220	16:02 (02.03.2022)	15:41 (03.03.2022)	23:39	FALSE	FALSE	FALSE	TRUE	LINE CHARGED
350	3-Mar-22	BAGALKOT	220	GADAG-DHONI2	STATION NOT AFFECTED GADAG_220	11:04	15:41	4:37	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
351	3-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)	12:28 (03.03.2022)	696:00 hrs	FALSE	FALSE	FALSE	TRUE	LINE CHARGED
352	3-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
353	3-Mar-22	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	12:45	13:32	0:47	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
354	3-Mar-22	BAGALKOT	220	KARWAR- KADRA 1	KARWAR_220	14:00	14:26	0:26	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
355	3-Mar-22	BAGALKOT	220	KARWAR- KADRA 1	KARWAR_220	14:55	15:14	0:19	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
356	3-Mar-22	BAGALKOT	220	KARWAR- KADRA 2	KARWAR_220	14:00	14:26	0:26	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
357	3-Mar-22	BAGALKOT	220	KARWAR- KADRA 2	KARWAR_220	14:55	15:14	0:19	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
358	3-Mar-22	BAGALKOT	220	NARENDRA-HAVERI1(BIDNAL)	STATION NOT AFFECTED NARENDRA_220	11:07	14:17	3:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
359	3-Mar-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
360	3-Mar-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
361	3-Mar-22	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	4:02	4:22	0:20	FALSE	FALSE	FALSE	TRUE	LINE FAULT
362	3-Mar-22	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	KEMPANAHALLI, AGALKOTE, MATHIKERE (NEL)	11:00	18:00	7:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
363	3-Mar-22	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	18:20	18:25	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
364	3-Mar-22	BENGALURU	66	ATTIBELE - YERANDANAHALLI 220	ATTIBELE	16:55	17:50	0:55	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
365	3-Mar-22	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	23:23	23:42	0:19	FALSE	FALSE	FALSE	TRUE	LINE FAULT
366	3-Mar-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	11:03	16:43	5:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
367	3-Mar-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	13:45	14:03	0:17	FALSE	FALSE	FALSE	TRUE	LINE FAULT
368	3-Mar-22	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	9:30	9:35	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
369	3-Mar-22	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SIRIGEREPURA	9:00	18:00	9:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
370	3-Mar-22	BENGALURU	66	HV1	CHELUR	13:15	13:30	0:14	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
371	3-Mar-22	BENGALURU	66	HV1	DEVANAHALLI	10:21	10:28	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
372	3-Mar-22	BENGALURU	66	HV1	HANUMANTHAGARA	13:31	13:36	0:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
373	3-Mar-22	BENGALURU	66	HV1	HUKUNDA	12:17	12:25	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
374	3-Mar-22	BENGALURU	66	HV1	HUKUNDA	12:29	12:35	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
375	3-Mar-22	BENGALURU	66	HV1	YARANDANAHALLI 220	16:57	18:10	1:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
376	3-Mar-22	BENGALURU	66	HV2	HANUMANTHAGARA	10:37	10:43	0:06	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
377	3-Mar-22	BENGALURU	66	HV2	KYALANUR	10:50	11:00	0:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
378	3-Mar-22	BENGALURU	66	HV2	MAASTHI	21:09	21:16	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
379	3-Mar-22	BENGALURU	66	HV2	SUBRAMANYAPURA 66	12:45	12:50	0:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
380	3-Mar-22	BENGALURU	66	HV2	SUBRAMANYAPURA 66	18:16	18:18	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
381	3-Mar-22	BENGALURU	66	HV2	THIMMAMPALLI	11:08	11:24	0:16	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
382	3-Mar-22	BENGALURU	66	HV2	YARANDANAHALLI 220	16:57	18:10	1:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
383	3-Mar-22	BENGALURU	66	HV3	YARANDANAHALLI 220	16:57	18:10	1:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
384	3-Mar-22	BENGALURU	66	JIGANI 220 - JIGANI LINK ROAD	JIGANI LINK ROAD	16:57	17:08	0:11	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
385	3-Mar-22	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	16:57	18:17	1:20	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
386	3-Mar-22	BENGALURU	66	KONDASPURA - HBR LAYOUT 220	KONDASPURA	9:15	9:20	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
387	3-Mar-22	BENGALURU	66	LAKSHMIPURA - SOMAYJANAHALLI	LAKSHMIPURA	14:10	17:10	3:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
388	3-Mar-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	10:18	10:29	0:11	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
389	3-Mar-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	10:05	10:10	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
390	3-Mar-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	17:04	17:07	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
391	3-Mar-22	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	17:13	17:18	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
392	3-Mar-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	17:13	17:18	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
393	3-Mar-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	8:14	8:23	0:09	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
394	3-Mar-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	5:43	5:50	0:07	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
395	3-Mar-22	BENGALURU	66	NRS 220 - NANDINI LAYOUT	NO STATION AFFECTED	0:04	2:31	2:27	FALSE	FALSE	FALSE	TRUE	LINE FAULT
396	3-Mar-22	BENGALURU	66	SARIAPURA 220 - ATTIBELE	NO STATION AFFECTED	7:23	7:49	0:25	FALSE	FALSE	FALSE	TRUE	LINE FAULT
397	3-Mar-22	BENGALURU	66	SOMAYAJANAHALLI - TATA SOLAR(IPP)	NO STATION AFFECTED	14:20	17:15	2:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
398	3-Mar-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	10:19	11:38	1:19	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
399	3-Mar-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	17:42	18:39	0:57	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
400	3-Mar-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	10:19	11:38	1:19	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
401	3-Mar-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	17:42	18:39	0:57	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
402	3-Mar-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	10:20	10:25	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
403	3-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	16:57	18:10	1:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
404	3-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	16:57	18:10	1:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
405	3-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	16:57	18:10	1:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
406	3-Mar-22	BENGALURU	220	HV1	JIGANI 220	16:57	18:17	1:20	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
407	3-Mar-22	BENGALURU	220	HV2	JIGANI 220	16:57	18:17	1:20	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
408	3-Mar-22	BENGALURU	220	HV2	MITTEMARI 220	4:00(28-2-2022)	16:57(3-3-2022)	12:56	FALSE	FALSE	FALSE	TRUE	TRANSFORMER CHARGED
409	3-Mar-22	BENGALURU	220	HV2	YARANDANAHALLI 220	16:57	18:04	1:07	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
410	3-Mar-22	BENGALURU	220	HV3	YARANDANAHALLI 220	16:57	18:04	1:07	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
411	3-Mar-22	BENGALURU	220	MYLASANDRA 400 - YARANDANAHALLI 220	YARANDANAHALLI 220, JIGANI 220	16:57	18:02	1:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
412	3-Mar-22	BENGALURU	220	SRS PEENYA 220 - BYDRAHALLI	BYDRAHALLI, SRIGANDAKAVALU, KODIGEHALI	6:15	8:10	1:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
413	3-Mar-22	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	10:50	17:55	7:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
414	3-Mar-22	BENGALURU	220	YARANDANAHALLI 220 - MYLASANDRA 400	YARANDANAHALLI 220, JIGANI 220	16:57	18:03	1:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
415	3-Mar-22	GULBARGA	66	HV1	BENNEHALLI_66	12:40	12:45	0:05	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
416	3-Mar-22	GULBARGA	66	HV2	TAMBRAHALI_66	13:52	14:03	0:11	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
417	3-Mar-22	GULBARGA	66	HV2	TAMBRAHALI_66	12:12	12:22	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
418	3-Mar-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNE HALLI_66	6:58	7:07	0:09	FALSE	FALSE	FALSE	TRUE	LINE FAULT
419	3-Mar-22	GULBARGA	66	ITTAGI-TAMBRAHALI	HAMPASAGAR_66,MORGERE_66,TAMBRAHALI_66	11:57	12:05	0:08	FALSE	FALSE	FALSE	TRUE	LINE FAULT
420	3-Mar-22	GULBARGA	66	ITTAGI-TAMBRAHALI	HAMPASAGAR_66,MORGERE_66,TAMBRAHALI_66	13:43	13:50	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
421	3-Mar-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	0:50	0:58	0:08	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
422	3-Mar-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	2:15	2:25	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
423	3-Mar-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMSAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANA KI_IPP,BASAI STEELS ACC	11:06	15:00	3:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
424	3-Mar-22	GULBARGA	110	ALIPUR-BELLARY SOUTH	BELLARY SOUTH_110,HALKUNDI_110	11:06	15:00	3:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
425	3-Mar-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATAVAHANA_IPP,AGARWAL_IPP,KAMLAPUR_110,MATRI_110,RBNS FACTORY	11:06	15:00	3:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
426	3-Mar-22	GULBARGA	110	ALIPUR-RVNL	RVNL_110	11:06	15:11	4:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
427	3-Mar-22	GULBARGA	110	BELLARYNORTH-ALIPUR	BELLARYNORTH_110	11:10	15:10	4:00	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
428	3-Mar-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	11:12	14:37	3:25	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
429	3-Mar-22	GULBARGA	110	HALAKUNDI-ALIPUR	HALAKUNDI_110	11:09	14:39	3:30	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
430	3-Mar-22	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	12:00(2.03.2022)	6:50(03.03.2022)	18:50 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
431	3-Mar-22	GULBARGA	110	HUMNABAD-MANN EK HALLI	MANNA-EK-HALLI_110	1:57	2:10	0:13	FALSE	FALSE	FALSE	TRUE	LINE FAULT
432	3-Mar-22	GULBARGA	110	HUMNABAD-MANN EK HALLI	MANNA-EK-HALLI_110	3:04	3:20	0:16	FALSE	FALSE	FALSE	TRUE	LINE FAULT
433	3-Mar-22	GULBARGA	110	HV1	HUNSAGI_110	12:50	14:05	1:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
434	3-Mar-22	GULBARGA	110	HV1	TAVAGERA_110	12:40	13:50	1:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
435	3-Mar-22	GULBARGA	110	HV2	ALIPUR_220	11:06	19:43	8:37	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
436	3-Mar-22	GULBARGA	110	HV2	BELLARYNORTH_110	17:02	17:30	0:28	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
437	3-Mar-22	GULBARGA	110	HV2	CHITGUPPA_110	17:20	18:45	1:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
438	3-Mar-22	GULBARGA	110	HV2	SHAHAPUR_110	10:00	21:25	11:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
439	3-Mar-22	GULBARGA	110	JAWALGERA-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	5:50	5:55	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
440	3-Mar-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	2:16	2:26	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
441	3-Mar-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	23:51	23:58	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
442	3-Mar-22	GULBARGA	110	MANVI-RAICHUR	MANVI_110	0:52	0:57	0:05	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
443	3-Mar-22	GULBARGA	110	METRI-ALIPUR	METRI_110	11:10	14:40	3:30	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
444	3-Mar-22	GULBARGA	110	PDHALLI-CLEAN MAX SOLAR	PD_HALLI_110	11:25	11:50	0:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
445	3-Mar-22	GULBARGA	110	PDHALLI-CLEAN SOLAR,BASAI	PD_HALLI_110	14:30	14:50	0:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
446	3-Mar-22	GULBARGA	110	PDHALLI-JANAKI STEELS	PD_HALLI_110	10:45	15:15	4:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
447	3-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:12	20:16	0:04	FALSE	FALSE	FALSE	TRUE	LINE FAULT
448	3-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
449	3-Mar-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	21:06	21:20	0:14	FALSE	FALSE	FALSE	TRUE	LINE FAULT
450	3-Mar-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP,HUNASIGI_110,ASKI_110	21:57	22:03	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
451	3-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	21:30	21:45	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
452	3-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	22:25	22:40	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
453	3-Mar-22	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	22:45	22:55	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
454	3-Mar-22	GULBARGA	220	ALIPUR-BTPSG	ALIPUR_220	11:06	0:00	12:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
455	3-Mar-22	GULBARGA	220	ALIPUR-RAGALPADU	ALIPUR_220	11:04	14:23	3:19	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
456	3-Mar-22	GULBARGA	220	HV1,HV2	ALIPUR_220	11:06	14:35	3:29	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
457	3-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
458	3-Mar-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	1:06	1:21	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
459	3-Mar-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	3:37	3:50	0:13	FALSE	FALSE	FALSE	TRUE	LINE FAULT
460	3-Mar-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	3:05	14:01	10:56	FALSE	FALSE	FALSE	TRUE	LINE FAULT
461	3-Mar-22	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	1:09	1:27	0:18	FALSE	FALSE	FALSE	TRUE	LINE FAULT
462	3-Mar-22	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	3:35	3:52	0:17	FALSE	FALSE	FALSE	TRUE	LINE FAULT
463	3-Mar-22	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	9:54	13:36	3:42	FALSE	FALSE	FALSE	TRUE	LINE FAULT
464	3-Mar-22	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	13:45	14:39	0:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
465	3-Mar-22	HASSAN	66	BHADRA-SHMGGA 1	gen_bhadr	12:13	14:02	1:49	FALSE	FALSE	FALSE	TRUE	LINE FAULT
466	3-Mar-22	HASSAN	66	CRPATNA2-HNPURA	CHANNARAYPATTANA_220	10:54	17:56	7:02	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
467	3-Mar-22	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	14:05	16:01	1:56	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
468	3-Mar-22	HASSAN	66	HV1	BALLUPETE_66	13:45	14:39	0:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
469	3-Mar-22	HASSAN	66	HV1	KUDLIGERE_66	10:05	10:50	0:45	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
470	3-Mar-22	HASSAN	66	HV1	SIGEBAGI_66	9:11	10:12	1:01	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
471	3-Mar-22	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	12:13	14:02	1:49	FALSE	FALSE	FALSE	TRUE	LINE FAULT
472	3-Mar-22	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	16:17	16:24	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
473	3-Mar-22	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	13:20	13:55	0:35	FALSE	FALSE	FALSE	TRUE	LINE FAULT
474	3-Mar-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:54	18:42	8:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
475	3-Mar-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	9:54	18:42	8:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
476	3-Mar-22	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGI_66	9:11	10:11	1:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
477	3-Mar-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	11:02	17:56	6:54	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
478	3-Mar-22	HASSAN	66	SOMNHL-HN PURA	SOMANAHALLY_66	14:08	16:06	1:58	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
479	3-Mar-22	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
480	3-Mar-22	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
481	3-Mar-22	HASSAN	220	KMR2-HGUNJE	HEGGUNJE_220	11:00	12:12	1:12	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
482	3-Mar-22	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	14:29	14:43	0:14	FALSE	FALSE	FALSE	TRUE	LINE FAULT
483	3-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
484	3-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
485	3-Mar-22	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	11:19	11:33	0:14	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
486	3-Mar-22	MYSURU	66	DATTAGALLI-HOOTAGALLI	NO STATIONS EFFECTED	10:16	13:16	2:59	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
487	3-Mar-22	MYSURU	66	DUNDANAHALLI-HULIYUR DURGA	DUNDANAHALLI_66	8:25	9:16	0:51	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
488	3-Mar-22	MYSURU	66	DUNDANAHALLI-HULIYUR DURGA	DUNDANAHALLI_66	19:27	19:35	0:07	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
489	3-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8/12/2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
490	3-Mar-22	MYSURU	66	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	20:13	20:24	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
491	3-Mar-22	MYSURU	66	HV1	BANANGADI_66	7:05	7:35	0:29	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
492	3-Mar-22	MYSURU	66	HV1	BEGUR_66	13:40	13:45	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
493	3-Mar-22	MYSURU	66	HV1	BEGUR_66	14:55	15:00	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
494	3-Mar-22	MYSURU	66	HV1	HONNALLY_MYS_66	16:04	17:23	1:19	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
495	3-Mar-22	MYSURU	66	HV1	KADAKOLA_220	12:16	13:25	1:08	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
496	3-Mar-22	MYSURU	66	HV1	PONNAMPET_66	12:39	12:51	0:11	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
497	3-Mar-22	MYSURU	66	HV1	TALAGAVADI_66	10:20	10:25	0:05	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
498	3-Mar-22	MYSURU	66	HV1	VAJAMANGALA_220	10:40	18:31	7:51	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
499	3-Mar-22	MYSURU	66	HV2	BANANGADI_66	7:08	7:35	0:27	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
500	3-Mar-22	MYSURU	66	HV2	CHIKKA_MANDYA_66	12:55	13:00	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
501	3-Mar-22	MYSURU	66	HV2	SRIRANGAPATNA_66	16:02	16:43	0:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
502	3-Mar-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
503	3-Mar-22	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBKERE_66	10:20	10:32	0:12	FALSE	FALSE	FALSE	TRUE	LINE FAULT
504	3-Mar-22	MYSURU	66	KR PETE 220-KR PETE 1	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	7:20	7:32	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
505	3-Mar-22	MYSURU	66	KR PETE-HUYGONAHALLI 1	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	7:20	7:35	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
506	3-Mar-22	MYSURU	66	KR PETE-HUYGONAHALLI 2	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	7:20	7:35	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
507	3-Mar-22	MYSURU	66	KUSHALANAGARA 220- PERIYAPATNA-1	NO STATIONS EFFECTED	4:15	4:21	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
508	3-Mar-22	MYSURU	66	MALAVALLI-TUBINAKERE	HADLI_66 MALAVALLI_66	10:18	18:45	8:27	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
509	3-Mar-22	MYSURU	66	NANJANAGUDU-SINDHUVALLI	NO STATIONS EFFECTED	22:48:00 (28/02/2022)			FALSE	FALSE	FALSE	TRUE	LINE OPEN:LINE FAULT
510	3-Mar-22	MYSURU	220	HV1	MADHUVANAHALLI_220	9:14	13:20	4:06	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
511	3-Mar-22	MYSURU	220	HV2	MADHUVANAHALLI_220	13:27	16:50	3:23	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
512	3-Mar-22	TUMKUR	66	HULIYURDURGA- ANCHEPALYA220	HULIYURDURGA_66	8:20	9:00	0:40	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
513	3-Mar-22	TUMKUR	66	HULIYURDURGA- ANCHEPALYA220	HULIYURDURGA_66	17:32	19:33	2:01	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
514	3-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:11	19:03	0:52	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
515	3-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	19:58	20:05	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
516	3-Mar-22	TUMKUR	66	PAVAGADA220-MEDEGESHI66	MEDIGESHI_66,I D HALLI_66,HOSKERE_66	14:32	14:39	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
517	3-Mar-22	TUMKUR	66	PAVAGADA220-PAVAGADA1	PAVAGADA_220	8:21	8:32	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
518	3-Mar-22	TUMKUR	66	PAVAGADA66-MADHUGIRI66	PAVAGADA_66	8:21	8:33	0:11	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
519	3-Mar-22	TUMKUR	66	PAVAGADA66-VENKATAPURA66	PAVAGADA_66	8:21	8:37	0:16	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
520	3-Mar-22	TUMKUR	66	PAVAGADA66-VENKATAPURA66	PAVAGADA_66	17:09	18:05	0:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
521	3-Mar-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	10:03	10:10	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
522	3-Mar-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	10:23	10:28	0:04	FALSE	FALSE	FALSE	TRUE	LINE FAULT
523	3-Mar-22	TUMKUR	66	THERIYUR66-GOWRIBIDNUR66	THERIYUR_66	9:07	14:35	5:28	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
524	3-Mar-22	TUMKUR	66	THERIYUR66-VENKATAPURA	THERIYUR_66	14:32	17:57	3:24	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
525	3-Mar-22	TUMKUR	66	THIPPUR66-ANCHEPALYA220	THIPPUR_66	8:20	8:55	0:35	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
526	3-Mar-22	TUMKUR	66	THIPPUR66-YEDIYUR	THIPPUR_66	18:20	18:25	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
527	3-Mar-22	TUMKUR	66	TR-1	CHIKKATOTTLUKERE_66	12:56	16:08	3:12	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
528	3-Mar-22	TUMKUR	66	TR-1	CHIKKATOTTLUKERE_66	16:26	17:17	0:50	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
529	3-Mar-22	TUMKUR	66	TR-1	HARIYABB_66	12:55	13:05	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
530	3-Mar-22	TUMKUR	66	TR-1	KORATAGERE_66	8:02	8:11	0:09	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
531	3-Mar-22	TUMKUR	66	TR-1	LINGADHALLI_66	22:02	22:07	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
532	3-Mar-22	TUMKUR	66	TR-1	MADHUGIRI_220	11:01	11:23	0:21	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
533	3-Mar-22	TUMKUR	66	TR-1	MADHUGIRI_220	13:57	14:11	0:14	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
534	3-Mar-22	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI_220	11:04	17:59	6:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
535	3-Mar-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	0:15	0:20	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
536	3-Mar-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	0:30	0:35	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
537	3-Mar-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	7:25	7:30	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
538	3-Mar-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	9:05	9:10	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
539	3-Mar-22	TUMKUR	66	TR-2	HOSAKRE_66	12:55	13:09	0:14	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
540	3-Mar-22	TUMKUR	66	TR-2	HOSAKRE_66	14:22	14:29	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
541	3-Mar-22	TUMKUR	66	TR-2	MATHOD_66	10:49	10:57	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
542	3-Mar-22	TUMKUR	66	TR-3	HARIYABB_66	13:11	13:17	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
543	3-Mar-22	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	12:44	13:31	0:47	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
544	3-Mar-22	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	12:39	13:29	0:49	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
545	3-Mar-22	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI_220	11:04	17:59	6:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
546	4-Mar-22	BAGALKOT	66	66/33KV, HV3&HV4	HARIHAR-HOSPET_66	18:44	18:57	0:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
547	4-Mar-22	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	10:50	11:01	0:11	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
548	4-Mar-22	BAGALKOT	110	110/11KV, HV1	TUMMINAKATTI_110	8:50	9:20	0:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
549	4-Mar-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED VAJRAMATTI_110	12:32	12:36	0:04	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
550	4-Mar-22	BAGALKOT	110	110/11KV, HV2	TUMMINAKATTI_110	11:40	12:04	0:24	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
551	4-Mar-22	BAGALKOT	110	110/11KV, HV2	TUMMINAKATTI_110	8:50	9:20	0:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
552	4-Mar-22	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	18:08	18:18	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
553	4-Mar-22	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	10:10	16:25	6:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
554	4-Mar-22	BAGALKOT	110	110/11KV,HV1	HUKKERI_110	18:15	18:20	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
555	4-Mar-22	BAGALKOT	110	110/11KV,HV1	SANKESHWAR_110	18:05	18:10	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
556	4-Mar-22	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	22:34(3.3.2022)	01:31 (04.03.2022)	2:57 hrs	TRUE	FALSE	FALSE	FALSE	TRANSFORMER CHARGED
557	4-Mar-22	BAGALKOT	110	110/11KV,HV2	MANTUR_110	13:02	13:07	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
558	4-Mar-22	BAGALKOT	110	110/11KV,HV2	HUKKERI_110	10:10	16:25	6:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
559	4-Mar-22	BAGALKOT	110	110/11KV,HV3	HANAGAL_110	12:33 (3.3.2022)			TRUE	FALSE	FALSE	FALSE	TRANSFORMER OPEN:LINE CLEAR AVAILED
560	4-Mar-22	BAGALKOT	110	110/33KV, HV1	JAMKHANDI_110, HIPPARAGI_33	13:23	13:28	0:05	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
561	4-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, BOMMANAHALLI_33, LAXMIPURA_33	8:42	9:15	0:33	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
562	4-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, BOMMANAHALLI_33, LAXMIPURA_33, BELAGALPET_33	14:03	18:04	4:01	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
563	4-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, BOMMANAHALLI_33, LAXMIPURA_33, BELAGALPET_33	23:44	23:48	0:04	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
564	4-Mar-22	BAGALKOT	110	110/33KV,HV1	HUKKERI_110	10:10	16:25	6:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
565	4-Mar-22	BAGALKOT	110	AMBEWADI-NK-1(HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	9:43	9:55	0:12	FALSE	FALSE	FALSE	TRUE	LINE FAULT
566	4-Mar-22	BAGALKOT	110	ANKOLA- ARGA	ANKOLA_110	9:42	9:54	0:12	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
567	4-Mar-22	BAGALKOT	110	ANKOLA- ARGA	ANKOLA_110	10:50	13:28	2:38	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
568	4-Mar-22	BAGALKOT	110	BAGEWADI- RAMPUR(NIDAGUNDI)	NIDAGUNDI_110, MUKARTIHAL_110	13:02	13:13	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
569	4-Mar-22	BAGALKOT	110	BAGEWADI- RAMPUR(NIDAGUNDI)	NIDAGUNDI_110, MUKARTIHAL_110	13:14	13:20	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
570	4-Mar-22	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	13:11 (23.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
571	4-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
572	4-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
573	4-Mar-22	BAGALKOT	110	HIREBEVNUR- SHIVASAGAR SUGARS	STATION NOT AFFECTED HIREBEVNUR_110	19:44	19:51	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
574	4-Mar-22	BAGALKOT	110	HUNGUND- JINDAL (EHT LINE)	STATION NOT AFFECTED HUNGUND_110	10:23	14:50	4:27	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
575	4-Mar-22	BAGALKOT	110	KARWAR-KUMTA(ARGA)	ARGA_110	10:56	13:10	2:15	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
576	4-Mar-22	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	KIRUVATTI_110	9:43	10:20	0:37	FALSE	FALSE	FALSE	TRUE	LINE FAULT
577	4-Mar-22	BAGALKOT	110	MUGALKHOD-KULIGOD	STATION NOT AFFECTED MUGALKHOD_220	15:01	15:55	0:54	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
578	4-Mar-22	BAGALKOT	110	MUGALKHOD-NAGANUR	STATION NOT AFFECTED MUGALKHOD_220	11:38	16:22	4:44	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
579	4-Mar-22	BAGALKOT	110	MUGALKHOD-NAGANUR	STATION NOT AFFECTED MUGALKHOD_220	16:29	17:56	1:27	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
580	4-Mar-22	BAGALKOT	110	MUGALKHOD-PG HUNSHYAL	STATION NOT AFFECTED MUGALKHOD_220	11:35	16:09	4:34	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
581	4-Mar-22	BAGALKOT	110	MUKARTIHAL- MATRIX WIND	MUKARTIHAL_110	13:33	13:35	0:02	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
582	4-Mar-22	BAGALKOT	110	MUKARTIHAL- SPV SOLAR	MUKARTIHAL_110	13:33	13:36	0:03	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
583	4-Mar-22	BAGALKOT	110	NAGANUR-F1(PG HUNASYAL)	NAGANUR_110	21:02 (3.3.2022)	16:22 (04.03.2022)	19:20 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
584	4-Mar-22	BAGALKOT	110	NAGANUR-F1(PG HUNASYAL)	NAGANUR_110	16:30	17:52	1:22	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
585	4-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI	STATION NOT AFFECTED PG HUNSHYAL_110	20:28 (03.03.2022)	16:09 (04.03.2022)	19:41 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
586	4-Mar-22	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
587	4-Mar-22	BAGALKOT	110	RAMDURGA- BAGALKOT(SOUDATTI2)	STATION NOT AFFECTED RAMADURGA_110	10:15	16:03	5:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
588	4-Mar-22	BAGALKOT	110	RANEENNUR220- TUMMINAKATTI	TUMMINAKATTI_110	8:49	9:15	0:26	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
589	4-Mar-22	BAGALKOT	110	RANEENNUR220- TUMMINAKATTI	TUMMINAKATTI_110	11:40	12:00	0:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
590	4-Mar-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
591	4-Mar-22	BAGALKOT	110	RATTIHALI-TUMMINAKATTI (RANEENNUR220)	STATION NOT AFFECTED RATTIHALI_110	9:31	11:40	2:09	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
592	4-Mar-22	BAGALKOT	110	SOUDATTI220-SOUDATTI2	STATION NOT AFFECTED SOUNDATTI_220	10:10	16:07	5:49	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
593	4-Mar-22	BAGALKOT	110	SOUDATTI-ENERCON L2(NARAGUND)	STATION NOT AFFECTED SOUDATTI_110	10:13	16:07	5:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
594	4-Mar-22	BAGALKOT	110	SOUDATTI-RAMADURGA2	STATION NOT AFFECTED SOUNDATTI_220	10:15	16:05	5:50	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
595	4-Mar-22	BAGALKOT	110	SOUDATTI-SOUDATTI2	STATION NOT AFFECTED SOUNDATTI_110	10:10	16:07	5:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
596	4-Mar-22	BAGALKOT	110	TUMMINAKATTI-RATTIHALI	RATTIHALI_110	11:41	12:30	0:49	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
597	4-Mar-22	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	RATTIHALLI_110	8:50	9:15	0:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
598	4-Mar-22	BAGALKOT	110	UDIKERI-NOKUR SOLAR	NOKUR SOLAR_110 STATION NOT AFFECTED UDIKERI_110	20:18	23:16	2:58	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
599	4-Mar-22	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED GHATAPRABHA_220	12:35	16:17	3:42	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
600	4-Mar-22	BAGALKOT	220	ATHANI220-MAHALINGAPUR	STATION NOT AFFECTED ATHANI_220	12:06	19:57	7:51	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
601	4-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
602	4-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
603	4-Mar-22	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	5:10	7:00	1:50	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
604	4-Mar-22	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	11:39 (03.03.2022)	14:37 (04.03.2022)	26:58 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
605	4-Mar-22	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	9:42	14:37	4:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
606	4-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
607	4-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
608	4-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:33 (3.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
609	4-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
610	4-Mar-22	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	5:12	7:00	1:48	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
611	4-Mar-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24(09.02.2022)	9:56(04.03.2022)	543:40hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
612	4-Mar-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24(09.02.2022)	9:56(04.03.2022)	543:40hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
613	4-Mar-22	BENGALURU	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	14:50	14:59	0:09	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
614	4-Mar-22	BENGALURU	66	HV1	EPIP 220	12:50	12:55	0:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
615	4-Mar-22	BENGALURU	66	HV1	KORAMANGALA 220	7:09	10:04	2:55	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
616	4-Mar-22	BENGALURU	66	HV1	WIDIA	16:30	17:45	1:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
617	4-Mar-22	BENGALURU	66	HV1	SM MANGALA	12:15	15:30	3:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
618	4-Mar-22	BENGALURU	66	HV1	SURYANAGARA	10:05	15:28	5:23	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
619	4-Mar-22	BENGALURU	66	HV2	APPAREL PARK	6:28	6:33	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
620	4-Mar-22	BENGALURU	66	HV2	MAASTHI	21:31	21:38	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
621	4-Mar-22	BENGALURU	66	HV2	SM MANGALA	12:15	15:30	3:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
622	4-Mar-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	14:53	15:02	0:09	FALSE	FALSE	FALSE	TRUE	LINE FAULT
623	4-Mar-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	13:05	13:16	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
624	4-Mar-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	9:15	9:30	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
625	4-Mar-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	17:50	17:55	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
626	4-Mar-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	14:27	14:43	0:16	FALSE	FALSE	FALSE	TRUE	LINE FAULT
627	4-Mar-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	10:51	10:57	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
628	4-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	7:37	7:57	0:20	FALSE	FALSE	FALSE	TRUE	LINE FAULT
629	4-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	15:10	16:56	1:46	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
630	4-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	18:01	18:02	0:01	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
631	4-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	17:58	18:00	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
632	4-Mar-22	BENGALURU	400	HOODY 400 - KOLAR 2 400	NO STATION AFFECTED	6:45	7:10	0:25	FALSE	FALSE	FALSE	TRUE	LINE FAULT
633	4-Mar-22	GULBARGA	110	ALUPUR-RVNL	RVNAL_110	10:13	10:54	0:41	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
634	4-Mar-22	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	17:34	17:45	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
635	4-Mar-22	GULBARGA	110	HV2	SREERAMANAGAR_110	16:05	16:15	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
636	4-Mar-22	GULBARGA	110	HV2	HALVAGALU_66	14:05	14:10	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
637	4-Mar-22	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	6:07	6:12	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
638	4-Mar-22	GULBARGA	110	NALWAR-SHAHBAD	NALWAR_110	12:00	13:35	1:35	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
639	4-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
640	4-Mar-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	12:10	13:19	1:09	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
641	4-Mar-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAIDHAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP	4:40	4:46	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
642	4-Mar-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:20	4:25	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
643	4-Mar-22	GULBARGA	110	SINDHANOOR-NIRLOTI_IPP	SINDHANOOR_220	5:50	6:05	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
644	4-Mar-22	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	16:34	17:06	0:32	FALSE	FALSE	FALSE	TRUE	LINE FAULT
645	4-Mar-22	GULBARGA	220	HV1	MUNIRABAD_220	16:28	17:02	0:34	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
646	4-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
647	4-Mar-22	GULBARGA	220	HV2	MUNIRABAD_220	16:28	17:01	0:33	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
648	4-Mar-22	GULBARGA	220	LINGAPUR-HALAWARTHY	HALAWARTHY_220	16:28	17:50	1:22	FALSE	FALSE	FALSE	TRUE	LINE FAULT
649	4-Mar-22	GULBARGA	220	LINGAPUR-JVSL1	LINGAPUR_220	10:06	17:44	7:38	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
650	4-Mar-22	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	4:10	10:22	6:12	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
651	4-Mar-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	3:22	4:07	0:45	FALSE	FALSE	FALSE	TRUE	LINE FAULT
652	4-Mar-22	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	1:21	1:36	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
653	4-Mar-22	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	2:23	15:11	12:48	FALSE	FALSE	FALSE	TRUE	LINE FAULT
654	4-Mar-22	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	13:19	15:12	1:53	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
655	4-Mar-22	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	9:44	18:16	8:32	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
656	4-Mar-22	HASSAN	66	HV	CHIKKABOMMENAHALLY_66	17:06	18:09	1:03	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
657	4-Mar-22	HASSAN	66	HV1	MOSALEHOSAHALLY_66	23:57(04.03.2022)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
658	4-Mar-22	HASSAN	66	HV1	DODDAKADANUR_66	11:39	11:49	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
659	4-Mar-22	HASSAN	66	HV1	HNPURA_66	11:09	13:11	2:02	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
660	4-Mar-22	HASSAN	66	HV1	SAKLESH PURA_66	14:58	15:23	0:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
661	4-Mar-22	HASSAN	66	HV1	SINGAPURA_66	13:00	13:46	0:46	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
662	4-Mar-22	HASSAN	66	HV2	HNPUA_66	11:09	13:12	2:03	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
663	4-Mar-22	HASSAN	66	HV2	HOLEHONNUR_66	5:22	6:12	0:50	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
664	4-Mar-22	HASSAN	66	HV2	SINGAPURA_66	8:17	8:22	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
665	4-Mar-22	HASSAN	66	HV2	UDAYAPURA_66	5:45	5:55	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
666	4-Mar-22	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:37	11:41	0:04	FALSE	FALSE	FALSE	TRUE	LINE FAULT
667	4-Mar-22	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUA_66	11:16	14:04	2:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
668	4-Mar-22	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	11:11	18:06	6:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
669	4-Mar-22	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	11:11	18:06	6:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
670	4-Mar-22	HASSAN	66	SINGAP-HNPUA	SINGAPURA_66	9:45	18:17	8:32	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
671	4-Mar-22	HASSAN	110	ARSK2-HARSKR	ARASIKERE_220	14:30	14:55	0:25	FALSE	FALSE	FALSE	TRUE	LINE FAULT
672	4-Mar-22	HASSAN	110	ARSK2-HGANDASI	ARASIKERE_220	14:30	14:55	0:25	FALSE	FALSE	FALSE	TRUE	LINE FAULT
673	4-Mar-22	HASSAN	110	ARSK2-HGERUMARA	ARASIKERE_220	14:30	14:55	0:25	FALSE	FALSE	FALSE	TRUE	LINE FAULT
674	4-Mar-22	HASSAN	110	HV1	ARASIKERE_220	14:30	14:52	0:22	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
675	4-Mar-22	HASSAN	110	HV1	KEMAR_220	10:16	10:21	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
676	4-Mar-22	HASSAN	110	HV1	TALAGUPPA_110	13:38	14:48	1:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
677	4-Mar-22	HASSAN	110	HV2	KEMAR_220	10:12	15:43	5:31	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
678	4-Mar-22	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
679	4-Mar-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	7:54	8:16	0:22	FALSE	FALSE	FALSE	TRUE	LINE FAULT
680	4-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:20	9:38	0:18	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
681	4-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	15:26	16:17	0:51	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
682	4-Mar-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	15:19	16:22	1:03	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
683	4-Mar-22	HASSAN	220	ARSK2-HHSN	ARASIKERE_220	15:48	19:22	3:34	FALSE	FALSE	FALSE	TRUE	LINE FAULT
684	4-Mar-22	HASSAN	220	ARSK2-HSHMG	ARASIKERE_220	14:30	14:50	0:20	FALSE	FALSE	FALSE	TRUE	LINE FAULT
685	4-Mar-22	HASSAN	220	ARSK2-HSHMG	ARASIKERE_220	22:02	23:51	1:49	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
686	4-Mar-22	HASSAN	220	ARSK2-HSN	ARASIKERE_220	13:02	14:47	1:45	FALSE	FALSE	FALSE	TRUE	LINE FAULT
687	4-Mar-22	HASSAN	220	HGUNJE-KEMAR	HEGGUNJE_220	13:16	15:59	2:43	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
688	4-Mar-22	HASSAN	220	KADUR-DABUSET	KADUR_220	22:04	23:58	1:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
689	4-Mar-22	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
690	4-Mar-22	HASSAN	220	KEMAR-HGUNJE	KEMAR_220	13:16	15:56	2:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
691	4-Mar-22	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	14:30	14:50	0:20	FALSE	FALSE	FALSE	TRUE	LINE FAULT
692	4-Mar-22	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	22:02	23:51	1:49	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
693	4-Mar-22	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	1:01	5:45	4:44	FALSE	FALSE	FALSE	TRUE	LINE FAULT
694	4-Mar-22	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:29	15:37	0:08	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
695	4-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
696	4-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
697	4-Mar-22	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	10:20	16:06	5:46	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
698	4-Mar-22	MYSURU	66	DODDINADHUVADI-KOTHANURU	NO STATIONS EFFECTED	16:15	16:20	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
699	4-Mar-22	MYSURU	66	HAMPAPURA(K)-KADAKOLA 1	HAMPAPURA(K)_66	18:20	18:35	0:15	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
700	4-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16(8/12/2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
701	4-Mar-22	MYSURU	66	HV1	AYRALLI_66	23:30	23:40	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
702	4-Mar-22	MYSURU	66	HV1	BILIKERE_66	10:00	16:32	6:32	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
703	4-Mar-22	MYSURU	66	HV1	BOGADHI_66	16:00	16:20	0:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
704	4-Mar-22	MYSURU	66	HV1	BOOKANAKERE_66	9:45	18:33	8:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
705	4-Mar-22	MYSURU	66	HV1	VAJAMANGALA_220	12:25	13:29	1:04	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
706	4-Mar-22	MYSURU	66	HV2	BEGUR_66	17:50	18:00	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
707	4-Mar-22	MYSURU	66	HV2	BILIKERE_66	10:00	17:20	7:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
708	4-Mar-22	MYSURU	66	HV2	BILIKERE_66	7:28	7:40	0:11	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
709	4-Mar-22	MYSURU	66	HV2	BOOKANAKERE_66	9:45	18:25	8:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
710	4-Mar-22	MYSURU	66	HV2	CHIKKA_MANDYA_66	11:37	12:03	0:26	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
711	4-Mar-22	MYSURU	66	HV2	HAMPAPURA(K)_66	10:20	16:25	6:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
712	4-Mar-22	MYSURU	66	HV2	KADABALLY_66	10:00	16:00	6:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
713	4-Mar-22	MYSURU	66	HV2	KIKKERI_66	9:32	10:58	1:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
714	4-Mar-22	MYSURU	66	HV2	RAVANDUR_66	10:00	15:00	5:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
715	4-Mar-22	MYSURU	66	HV2	SHEELUNERE_66	10:00	18:05	8:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
716	4-Mar-22	MYSURU	66	HVI	HAMPAPURA(K)_66	10:20	16:25	6:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
717	4-Mar-22	MYSURU	66	HVI	KADABALLY_66	10:00	16:00	6:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
718	4-Mar-22	MYSURU	66	HVI	RAVANDUR_66	10:00	15:00	5:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
719	4-Mar-22	MYSURU	66	HVI	SHEELUNERE_66	10:00	18:05	8:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
720	4-Mar-22	MYSURU	66	HVI	SHEELUNERE_66	18:15	18:20	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
721	4-Mar-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
722	4-Mar-22	MYSURU	66	KITTUR-KUSHALANAGARA	KITTUR_66	10:25	15:00	4:35	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
723	4-Mar-22	MYSURU	66	KITTUR-RAVANDURU	RAVANDUR_66	10:00	15:00	5:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
724	4-Mar-22	MYSURU	66	KR PETE 220-BOOKANAKERE	BOOKANAKERE_66, GANJIGERE_66, SHEELUNERE_66	16:04	18:12	2:08	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
725	4-Mar-22	MYSURU	66	NANJANAGUDU-SINDHUVALLI	NO STATIONS EFFECTED	22:48:00 (28/02/2022)	14:59(4.3.22)	64:11HRs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
726	4-Mar-22	MYSURU	220	HV1	TUBINAKERE_220	16:02	19:16	3:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
727	4-Mar-22	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVA NI_66	10:09	10:16	0:07	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
728	4-Mar-22	TUMKUR	66	ANCHEPALYA 220kv- VIJAYA STEEL	ANCHEPALYA_220	17:19	17:34	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
729	4-Mar-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66,HOSAKERE_66, HAGAL WADI_66	7:17	7:40	0:22	FALSE	FALSE	FALSE	TRUE	LINE FAULT
730	4-Mar-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAG ALUR_66	6:35	7:05	0:29	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
731	4-Mar-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:24	7:02	0:38	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
732	4-Mar-22	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI66	MADHUGIRI_66, BADAVANAHALLI_66	16:28	17:04	0:36	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
733	4-Mar-22	TUMKUR	66	MATHOD- RAMCO CEMENT _EHT_66	RAMCO CEMENT _EHT_66	16:32	19:50	3:17	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
734	4-Mar-22	TUMKUR	66	PAVAGADA220-MEDEGESHI66	MEDIGESI_66,I D HALLI_66,HOSKERE_66	6:10	6:18	0:08	FALSE	FALSE	FALSE	TRUE	LINE FAULT
735	4-Mar-22	TUMKUR	66	THALLAK 220kv- GOWRASAMUDRA	GOWRASAMUDRA_66	6:06	6:14	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
736	4-Mar-22	TUMKUR	66	TR-1	CHIKKATOTLUKERE_66	10:58	11:12	0:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
737	4-Mar-22	TUMKUR	66	TR-1	PULAMGHATTA_66	13:14	14:12	0:58	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
738	4-Mar-22	TUMKUR	66	TR-1(LV SIDE)	THALLAK_220	6:06	6:14	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
739	4-Mar-22	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI_220	16:32	17:02	0:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
740	4-Mar-22	TUMKUR	66	TR-3	HARIYABB_66	9:13	9:16	0:02	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
741	4-Mar-22	TUMKUR	66	TR-3	HARIYABB_66	10:18	10:21	0:02	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
742	4-Mar-22	TUMKUR	66	TR-3	HARIYABB_66	10:28	10:34	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
743	4-Mar-22	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_110,	1:01	5:53	4:52	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
744	4-Mar-22	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_110,	15:25	16:28	1:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
745	4-Mar-22	TUMKUR	110	NITTUR 220-AMMASANDRA110	AMMASANDRA_110,SAMPIGE_110	22:08	22:57	0:49	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
746	4-Mar-22	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	1:01	5:53	4:52	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
747	4-Mar-22	TUMKUR	220	GUTTUR 400- GUTTUR 1	GUTTUR_220	15:59	18:20	2:21	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
748	4-Mar-22	TUMKUR	220	GUTTUR 400- GUTTUR 2	GUTTUR_220	15:20	18:21	3:01	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
749	4-Mar-22	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	1:01	5:53	4:52	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
750	4-Mar-22	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	13:02	14:53	1:51	FALSE	FALSE	FALSE	TRUE	LINE FAULT
751	4-Mar-22	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	15:48	19:42	3:54	FALSE	FALSE	FALSE	TRUE	LINE FAULT
752	4-Mar-22	TUMKUR	220	TR-1	THALLAK_220	6:06	6:13	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
753	4-Mar-22	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI_220	16:33	17:01	0:28	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
754	4-Mar-22	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	1:01	5:53	4:52	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
755	05-Mar-22	BAGALKOT	110	110/11KV, HV1	HANGAL_110	10:02	13:52	3:50	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
756	05-Mar-22	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	18:06	18:42	0:36	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
757	05-Mar-22	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	19:24	19:38	0:14	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
758	05-Mar-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED	22:13	22:24	0:11	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
759	05-Mar-22	BAGALKOT	110	110/11KV, HV1	THORVI_110	3:06	3:12	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
760	05-Mar-22	BAGALKOT	110	110/11KV, HV1	THORVI_110	11:52	11:56	0:04	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
761	05-Mar-22	BAGALKOT	110	110/11KV, HV2	ALMEL_110	12:15	13:15	1:00	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
762	05-Mar-22	BAGALKOT	110	110/11KV, HV2	ALMEL_110	13:59	14:01	0:02	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
763	05-Mar-22	BAGALKOT	110	110/11KV, HV2	NANADI_110	12:55	13:33	0:38	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
764	05-Mar-22	BAGALKOT	110	110/11KV, HV2	SAVANUR_110	16:57	17:28	0:31	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
765	05-Mar-22	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	12:25	13:00	0:35	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
766	05-Mar-22	BAGALKOT	110	110/11KV, HV3	BIJAPUR CITY_110	11:35	12:53	1:18	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
767	05-Mar-22	BAGALKOT	110	110/11KV,HV1	KAWALWAD_110	10:45	12:25	1:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
768	05-Mar-22	BAGALKOT	110	110/11KV,HV1,HV2,HV3	STATION NOT AFFECTED	13:29	13:46	0:17	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
769	05-Mar-22	BAGALKOT	110	110/11KV,HV2	SIRSI_220	7:30	7:40	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
770	05-Mar-22	BAGALKOT	110	110/11KV,HV2	SIRSI_220	8:49	8:54	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
771	05-Mar-22	BAGALKOT	110	110/11KV,HV3	HANAGAL_110	12:33 (03.03.2022)	18:26(05.03.2022)	53:53 hrs	TRUE	FALSE	FALSE	FALSE	TRANSFORMER CHARGED
772	05-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, AKKIALUR_33, LAXMIPURA_33	14:03	17:50	3:47	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
773	05-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, AKKIALUR_33, LAXMIPURA_33	21:04	21:10	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
774	05-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, AKKIALUR_33, LAXMIPURA_33	22:08	22:18	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
775	05-Mar-22	BAGALKOT	110	110/33KV, HV2	KUDACHI_110, CHICHANALLI_33	5:52	6:09	0:17	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
776	05-Mar-22	BAGALKOT	110	110/33KV,HV1,HV2	STATION NOT AFFECTED RANEENNUR_220	13:31	13:46	0:15	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
777	05-Mar-22	BAGALKOT	110	AMBEWADI-KAVALWDA(NK-2)	KAVALWADA_110	16:55	18:43	1:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
778	05-Mar-22	BAGALKOT	110	ANKOLA- ARGA	ANKOLA_110	11:32	16:40	5:08	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
779	05-Mar-22	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	13:11 (23.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
780	05-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
781	05-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
782	05-Mar-22	BAGALKOT	110	KAVALWADA-HALIYAL	STATION NOT AFFECTED HALIYAL_110	10:10	10:45	0:35	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
783	05-Mar-22	BAGALKOT	110	KAVALWADA-HALIYAL	STATION NOT AFFECTED HALIYAL_110	12:55	19:00	6:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
784	05-Mar-22	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	10:09	11:50	1:41	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
785	05-Mar-22	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	12:55	13:01	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
786	05-Mar-22	BAGALKOT	110	KUMATA- SIRSI1	STATION NOT AFFECTED KUMATA_110	9:56	11:29	1:33	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
787	05-Mar-22	BAGALKOT	110	MAHALINGAPUR- DAVALESHWAR	STATION NOT AFFECTED DAVALESHWAR_110	12:12	14:45	2:33	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
788	05-Mar-22	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
789	05-Mar-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
790	05-Mar-22	BAGALKOT	110	RANEENNUR- RATTIHALLI(TUMMINAKATTI)	TUMMINAKETTI_110	13:29	13:53	0:24	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
791	05-Mar-22	BAGALKOT	110	SAMBAPUR ROAD- RVNL TSS(RAILWAY LINE)	STATION NOT AFFECTED SAMBAPUR ROAD_110	18:10	18:29	0:19	FALSE	FALSE	FALSE	TRUE	LINE FAULT
792	05-Mar-22	BAGALKOT	110	SAMBAPUR ROAD- RVNL TSS(RAILWAY LINE)	STATION NOT AFFECTED SAMBAPUR ROAD_110	19:00	19:16	0:16	FALSE	FALSE	FALSE	TRUE	LINE FAULT
793	05-Mar-22	BAGALKOT	110	SIRSI- KUMATA2	STATION NOT AFFECTED SIRSI_110	12:50	18:34	5:44	FALSE	FALSE	FALSE	TRUE	LINE FAULT
794	05-Mar-22	BAGALKOT	110	SOUNDATTI-MMCL	STATION NOT AFFECTED SOUNDATTI_220	4:50	4:55	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
795	05-Mar-22	BAGALKOT	110	UTTUR-MUDHOL(MLPUR)	STATION NOT AFFECTED UTTUR_110	11:56	12:14	0:18	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
796	05-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED ATHANI_220	11:42	17:53	6:11	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
797	05-Mar-22	BAGALKOT	220	220/110KV,LV1,LV2	KARWAR_220	13:05	13:35	0:30	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
798	05-Mar-22	BAGALKOT	220	220/110KV,LV1,LV2	KARWAR_220	16:05	16:23	0:18	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
799	05-Mar-22	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	14:15	14:42	0:27	FALSE	FALSE	FALSE	TRUE	LINE FAULT
800	05-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
801	05-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
802	05-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
803	05-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
804	05-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:33 (3.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
805	05-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
806	05-Mar-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	10:47	11:25	0:38	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
807	05-Mar-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:48	11:25	0:37	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
808	05-Mar-22	BAGALKOT	220	SIRSI-KAVALWADA	STATION NOT AFFECTED SIRSI_220	10:49	11:28	0:39	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
809	05-Mar-22	BAGALKOT	220	SIRSI-SHARAVATI1	STATION NOT AFFECTED SIRSI_220	11:25 (05.03.2022)			FALSE	TRUE	FALSE	FALSE	LOAD CURTAILMENT
810	05-Mar-22	BAGALKOT	220	SIRSI-SHARAVATI2	STATION NOT AFFECTED SIRSI_220	11:26 (05.03.2022)			FALSE	TRUE	FALSE	FALSE	LOAD CURTAILMENT
811	05-Mar-22	BENGALURU	66	ELITE PROMENEDE - SOMANAHALLI 220	ELITE PROMENEDE	9:45	9:50	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
812	05-Mar-22	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	11:26	15:51	4:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
813	05-Mar-22	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	22:25	22:30	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
814	05-Mar-22	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	9:35	9:40	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
815	05-Mar-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	12:10	12:55	0:45	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
816	05-Mar-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	10:07	12:10	2:03	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
817	05-Mar-22	BENGALURU	66	HV1	ANDERSONPET	10:30	10:35	0:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
818	05-Mar-22	BENGALURU	66	HV1	DASHAVARA	21:03	21:10	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
819	05-Mar-22	BENGALURU	66	HV1	DASHAVARA	21:25	21:35	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
820	05-Mar-22	BENGALURU	66	HV1	EPIP 220	23:44:00(05/03/2022)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
821	05-Mar-22	BENGALURU	66	HV1	HUKUNDA	11:36	11:40	0:03	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
822	05-Mar-22	BENGALURU	66	HV1	HUKUNDA	14:34	14:41	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
823	05-Mar-22	BENGALURU	66	HV1	ITI 220	10:03	10:06	0:03	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
824	05-Mar-22	BENGALURU	66	HV1	MAASTHI	14:11	15:15	1:04	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
825	05-Mar-22	BENGALURU	66	HV1	MAASTHI	10:10	10:15	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
826	05-Mar-22	BENGALURU	66	HV1	RAJANUKUNTE	12:15	12:20	0:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
827	05-Mar-22	BENGALURU	66	HV1	SADLI	13:41	13:46	0:04	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
828	05-Mar-22	BENGALURU	66	HV2	ANDERSONPET	15:46	16:48	1:02	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
829	05-Mar-22	BENGALURU	66	HV2	IRGAMPALLI	16:00	16:10	0:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
830	05-Mar-22	BENGALURU	66	HV2	ITI 220	14:22	14:25	0:03	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
831	05-Mar-22	BENGALURU	66	HV2	MAASTHI	10:06	10:15	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
832	05-Mar-22	BENGALURU	66	HV2	SADLI	16:22	16:30	0:07	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
833	05-Mar-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	14:38	14:46	0:08	FALSE	FALSE	FALSE	TRUE	LINE FAULT
834	05-Mar-22	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	16:55	17:45	0:50	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
835	05-Mar-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR	16:55	17:45	0:50	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
836	05-Mar-22	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	12:55	13:00	0:04	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
837	05-Mar-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	11:00	11:28	0:28	FALSE	FALSE	FALSE	TRUE	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
838	05-Mar-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI	17:55	17:57	0:01	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
839	05-Mar-22	BENGALURU	66	PRESTIGE SHANTINIKETHAN - HOODY	PRESTIGE SHANTINIKETHAN	10:10	17:25	7:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
840	05-Mar-22	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	YEDUMADU	10:12	10:17	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
841	05-Mar-22	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	YEDUMADU	18:43	18:45	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
842	05-Mar-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:08	10:14	0:06	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
843	05-Mar-22	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	9:18	9:23	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
844	05-Mar-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	22:05	22:22	0:17	FALSE	TRUE	FALSE	FALSE	LOAD CURTAILMENT
845	05-Mar-22	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	19:58	20:06	0:08	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
846	05-Mar-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	11:31	12:07	0:36	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
847	05-Mar-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	16:42	17:07	0:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
848	05-Mar-22	BENGALURU	66	VR DODDI - SOMANAHALLI 220	VR DODDI	9:35	9:45	0:10	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
849	05-Mar-22	BENGALURU	66	VR DODDI - TK HALLI 220	VR DODDI	19:10	19:15	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
850	05-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	9:25	9:30	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
851	05-Mar-22	BENGALURU	220	HV2	DABUSPETE 220	7:45	8:28	0:43	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
852	05-Mar-22	GULBARGA	66	HV1	ITTAGI_220	11:03 (5.03.2022)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
853	05-Mar-22	GULBARGA	66	HV2	ITTAGI_220	17:25	18:55	1:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
854	05-Mar-22	GULBARGA	66	ITTAGI-HUVINHADAGALI	HUVINAHADGALI_66,HOLAGU NDI_66	16:45	17:45	1:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
855	05-Mar-22	GULBARGA	66	ITTAGI-RENEW SOLAR_IPP	ITTAGI_220	11:10	11:15	0:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
856	05-Mar-22	GULBARGA	66	KUDLIGI-ACME SLOAR_IPP	KUDLIGI_220	18:35	18:45	0:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
857	05-Mar-22	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	15:22	15:37	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
858	05-Mar-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	1:55	2:05	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
859	05-Mar-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	3:49	3:52	0:03	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
860	05-Mar-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	5:49	5:53	0:04	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
861	05-Mar-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	4:40	4:45	0:05	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
862	05-Mar-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	4:40	4:45	0:05	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
863	05-Mar-22	GULBARGA	110	HV1	MANGALORE_110	14:20	14:30	0:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
864	05-Mar-22	GULBARGA	110	HV1	RAICHUR_220	23:05	23:10	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
865	05-Mar-22	GULBARGA	110	HV2	HATTI_10	14:13	14:20	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
866	05-Mar-22	GULBARGA	110	HV2	HATTI_110	14:13	14:20	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
867	05-Mar-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:02	19:13	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
868	05-Mar-22	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHIKKASUGUR_110 ,SHAKTHINAGA_110	4:11	4:25	0:14	FALSE	FALSE	FALSE	TRUE	LINE FAULT
869	05-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:40	20:45	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
870	05-Mar-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:33	22:35	0:02	FALSE	FALSE	FALSE	TRUE	LINE FAULT
871	05-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
872	05-Mar-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:07	17:26	6:19	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
873	05-Mar-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR _110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	11:07	11:17	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
874	05-Mar-22	GULBARGA	110	YELBURGA-TALALUTAI IPP	YELBURGA_110	19:36(05.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED
875	05-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
876	05-Mar-22	GULBARGA	220	ITTAGI-BMM ISPAT	ITTAGI_220	10:48	14:45	3:57	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
877	05-Mar-22	GULBARGA	220	LINGAPUR-JVSL2	LINGAPUR_220	11:28	17:50	6:22	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
878	05-Mar-22	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	4:31	8:53	4:22	FALSE	FALSE	FALSE	TRUE	LINE FAULT
879	05-Mar-22	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	3:45	10:46	7:01	FALSE	FALSE	FALSE	TRUE	LINE FAULT
880	05-Mar-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	4:34	6:13	1:39	FALSE	FALSE	FALSE	TRUE	LINE FAULT
881	05-Mar-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	20:03	20:35	0:32	FALSE	FALSE	FALSE	TRUE	LINE FAULT
882	05-Mar-22	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	10:28	14:46	4:18	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
883	05-Mar-22	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	10:05	14:41	4:36	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
884	05-Mar-22	HASSAN	66	HASSN22-HN PURA	HASSAN_220	11:37	13:58	2:21	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
885	05-Mar-22	HASSAN	66	HASSN22-MALLALI	HASSAN_220	11:37	13:57	2:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
886	05-Mar-22	HASSAN	66	HASSN22-SKPURA	HASSAN_220	13:40	13:57	0:17	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
887	05-Mar-22	HASSAN	66	HASSN2-HSN66	HASSAN_220	12:08	14:51	2:43	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
888	05-Mar-22	HASSAN	66	HV1	HASSAN_66	10:09	17:46	7:37	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
889	05-Mar-22	HASSAN	66	HV1	HOLALUR_66	10:22	18:47	8:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
890	05-Mar-22	HASSAN	66	HV1	KANDLI_66	10:23	16:33	6:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
891	05-Mar-22	HASSAN	66	HV1	MALLIPATTANA_66	10:20	14:50	4:30	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
892	05-Mar-22	HASSAN	66	HV1	MOSALEHOSAHALLI_66	23:57(04.03.2022)	0:15(05.03.2022)	18 hrs	TRUE	FALSE	FALSE	FALSE	TRANSFORMER CHARGED
893	05-Mar-22	HASSAN	66	HV1	SALAGAME_66	10:08	16:25	6:17	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
894	05-Mar-22	HASSAN	66	HV1	YESLUR_66	10:26	17:18	6:52	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
895	05-Mar-22	HASSAN	66	HV2	HOLALUR_66	10:22	18:47	8:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
896	05-Mar-22	HASSAN	66	HV2	KANDLI_66	10:22	16:34	6:12	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
897	05-Mar-22	HASSAN	66	HV2	SALAGAME_66	10:08	16:25	6:17	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
898	05-Mar-22	HASSAN	66	LV1	HASSAN_220	11:37	13:56	2:19	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
899	05-Mar-22	HASSAN	66	MALLIPA-ARAKALGUD	MALLIPATTANA_66	10:20	14:49	4:29	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
900	05-Mar-22	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATTANA_66	10:20	15:46	5:26	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
901	05-Mar-22	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	10:09	16:25	6:16	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
902	05-Mar-22	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	10:09	16:24	6:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
903	05-Mar-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:18	18:52	9:34	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
904	05-Mar-22	HASSAN	66	USSURKOP-CHIKMANGLUR	UDDURKOPPLU_66	10:49	16:21	5:32	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
905	05-Mar-22	HASSAN	66	YESLUR-SNVRST	YESLUR_66	10:26	17:12	6:46	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
906	05-Mar-22	HASSAN	110	HV2	KADUR_220	10:27	11:40	1:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVALIED
907	05-Mar-22	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVALIED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
908	05-Mar-22	HASSAN	220	ARSK2-NITTUR	ARSIKERE_220	16:08	19:46	3:38	FALSE	FALSE	FALSE	TRUE	LINE FAULT
909	05-Mar-22	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	11:11	13:31	2:20	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
910	05-Mar-22	HASSAN	220	HV1	HASSAN_220	11:37	13:37	2:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
911	05-Mar-22	HASSAN	220	KADUR-DABUSET	KADUR_220	11:06	12:59	1:53	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
912	05-Mar-22	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
913	05-Mar-22	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:15	13:33	2:18	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
914	05-Mar-22	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	11:11	13:31	2:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
915	05-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
916	05-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
917	05-Mar-22	MYSURU	66	BGPURA-HEBBANI	BGPURA_66	9:30	14:15	4:45	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
918	05-Mar-22	MYSURU	66	BYLUKUPPE-KUSHALNAGARA	BYLUKUPPE_66	10:01	17:08	7:07	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
919	05-Mar-22	MYSURU	66	CR NAGAR-YALANDUR	NO STATIONS EFFECTED	7:03	7:14	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
920	05-Mar-22	MYSURU	66	DB HALLI-TUBINKERE	DODDABYADARAHALLI_66	10:07	17:15	7:08	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
921	05-Mar-22	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	12:31	12:37	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
922	05-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8/12/2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
923	05-Mar-22	MYSURU	66	HV1	ADDIHALLI_66	13:16	13:26	22:44 hrs	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
924	05-Mar-22	MYSURU	66	HV1	AYRAHALLI_66	23:30	23:40	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
925	05-Mar-22	MYSURU	66	HV1	BANNANGADI_66	10:25	14:29	4:04	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
926	05-Mar-22	MYSURU	66	HV1	BGPURA_66	6:59	14:25	7:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
927	05-Mar-22	MYSURU	66	HV1	GARUDANUKKADA_66	10:00	16:10	6:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
928	05-Mar-22	MYSURU	66	HV2	BGPURA_66	8:15	14:15	6:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
929	05-Mar-22	MYSURU	66	HV2	BOOKANERE_66	8:29	8:37	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
930	05-Mar-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
931	05-Mar-22	MYSURU	66	KADAKOLA-MYSSOUTH	MYSORESOUTH_66	10:54	17:52	6:58	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
932	05-Mar-22	MYSURU	66	KIRUGAVALU-VADKEPURA	KIRUGAVALU_66	9:11	18:06	8:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
933	05-Mar-22	MYSURU	66	MADHUVANALLI-MAMBALLI	NO STATIONS EFFECTED	7:59	8:06	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
934	05-Mar-22	MYSURU	66	SHANIVARSANTE-HV1	SHANIVARSANTE_66 MALLIPATNA_66 YESLOOR_66 HETTUR_66	10:24	16:24	6:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
935	05-Mar-22	MYSURU	66	SOMANAHALLY-MADDUR	NO STATIONS EFFECTED	20:39	20:40	0:01	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
936	05-Mar-22	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66	10:30	13:56	3:26	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
937	05-Mar-22	MYSURU	220	KADAKOLA-KANNENBETTA	NO STATIONS EFFECTED	17:22:00 (5.3.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
938	05-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	0:52	1:13	0:20	FALSE	FALSE	FALSE	TRUE	LINE FAULT
939	05-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	1:29	1:43	0:14	FALSE	FALSE	FALSE	TRUE	LINE FAULT
940	05-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	2:44	3:06	0:22	FALSE	FALSE	FALSE	TRUE	LINE FAULT
941	05-Mar-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	3:14	3:56	0:42	FALSE	FALSE	FALSE	TRUE	LINE FAULT
942	05-Mar-22	TUMKUR	66	HONNALLI 220KV- LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:08	6:17	0:09	FALSE	FALSE	FALSE	TRUE	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
943	05-Mar-22	TUMKUR	66	HONNALLI 220KV- LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:07	12:14	0:07	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
944	05-Mar-22	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	9:04	16:30	7:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
945	05-Mar-22	TUMKUR	66	MADHUGIRI 220KV- KORATAGERE 1	KORATAGERE_66	11:06	11:15	0:09	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
946	05-Mar-22	TUMKUR	66	MADHUGIRI 220KV- PULLAMAGATTA	PULLAMGATTA_66	11:08	11:16	0:08	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
947	05-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	7:20	8:19	0:59	FALSE	FALSE	FALSE	TRUE	LINE FAULT
948	05-Mar-22	TUMKUR	66	TAVAREKERE (H)- I/CHIRIYUR	TAVAREKERE(H)_66	9:37	16:30	6:52	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
949	05-Mar-22	TUMKUR	66	TR-1	MAVINAKATTE_66	8:23	8:29	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
950	05-Mar-22	TUMKUR	66	TR-1(HV-1)	KDBVNP_220	2:04	16:12	14:07	TRUE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
951	05-Mar-22	TUMKUR	66	TR-2	ANTHARASANAHALLI_220	9:14	13:32	4:17	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
952	05-Mar-22	TUMKUR	66	TR-2	CHANNAGIRI_66	12:32	12:34	0:02	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
953	05-Mar-22	TUMKUR	66	TR-2	CHITRADURGA_66	14:04	14:25	0:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
954	05-Mar-22	TUMKUR	66	TR-2	DAVANGERE_66	12:16	12:47	0:31	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
955	05-Mar-22	TUMKUR	66	TR-2	RAMAPURA_66	17:00	18:40	1:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
956	05-Mar-22	TUMKUR	110	TR-1	BIDARE_110	10:30	17:40	7:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
957	05-Mar-22	TUMKUR	110	TR-3	GUBBI_110	10:28	19:12	8:44	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
958	05-Mar-22	TUMKUR	220	GUTTUR 400KV- GUTTUR1	DAVANGERE_SRS_220	12:47	19:19	6:31	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
959	05-Mar-22	TUMKUR	220	GUTTUR 400KV- GUTTUR2	DAVANGERE_SRS_220	12:48	19:19	6:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
960	05-Mar-22	TUMKUR	220	NITTUR 220KV- ARASIKERE	NITTUR_220	16:08	19:49	3:41	TRUE	FALSE	FALSE	TRUE	LINE FAULT
961	05-Mar-22	TUMKUR	220	TR-1	KDBVNP_220	11:53	12:52	0:59	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
962	05-Mar-22	TUMKUR	220	TR-1	KDBVNP_220	12:52	13:01	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
963	05-Mar-22	TUMKUR	220	TR-2	ANTHARASANAHALLI_220	9:15	13:32	4:17	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
964	05-Mar-22	TUMKUR	220	TR-2	MADHUGIRI_220	11:08	19:17	8:08	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
965	06-Mar-22	BAGALKOT	110	110/11KV, HV1	DEVARGENNUR_110	12:00	12:20	0:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
966	06-Mar-22	BAGALKOT	110	110/11KV, HV1	MANTUR(G)_110	13:23	13:31	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
967	06-Mar-22	BAGALKOT	110	110/11KV, HV1	THORVI_110	11:15	11:40	0:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
968	06-Mar-22	BAGALKOT	110	110/11KV, HV2	ALMEL_110	9:10	9:18	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
969	06-Mar-22	BAGALKOT	110	110/11KV, HV2	ALMEL_110	12:24	12:51	0:27	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
970	06-Mar-22	BAGALKOT	110	110/11KV, HV2	MANTUR(G)_110	13:23	13:32	0:09	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
971	06-Mar-22	BAGALKOT	110	110/11KV,HV1,HV2	RAMADURGA_110	9:00	13:47	4:47	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
972	06-Mar-22	BAGALKOT	110	110/11KV,HV1,HV2,HV3	RANEENNUR_220	15:56	16:02	0:06	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
973	06-Mar-22	BAGALKOT	110	110/11KV,HV2	RANEENNUR_220	10:43	11:01	0:18	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
974	06-Mar-22	BAGALKOT	110	110/11KV,HV2	RANEENNUR_220	11:15	11:25	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
975	06-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, AKKIALUR_33, LAXMIPURA_33	7:50	8:00	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
976	06-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, AKKIALUR_33, LAXMIPURA_33	8:50	8:57	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
977	06-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, AKKIALUR_33, LAXMIPURA_33	11:10	11:16	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
978	06-Mar-22	BAGALKOT	110	110/33KV, HV2	HANGAL_110, AKKIALUR_33, LAXMIPURA_33	17:31	17:36	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
979	06-Mar-22	BAGALKOT	110	110/33KV, HV2	RATTIHALI_110, HALLUR_33, MASUR_33	14:18	14:24	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
980	06-Mar-22	BAGALKOT	110	110/33KV,HV1,HV2	RANEENNUR_220	15:56	16:02	0:06	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
981	06-Mar-22	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	13:11 (23.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
982	06-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
983	06-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
984	06-Mar-22	BAGALKOT	110	MAMADAPURA(B)- BABLESHWAR	BABLESHWAR_110	19:53	20:15	0:22	FALSE	FALSE	FALSE	TRUE	LINE FAULT
985	06-Mar-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
986	06-Mar-22	BAGALKOT	110	RANEENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI_110	13:53	16:09	2:16	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
987	06-Mar-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
988	06-Mar-22	BAGALKOT	110	RANEENNUR-RATTIHALI(TUMMINAKATTI)	TUMMINAKETTI_110	15:57	16:01	0:04	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
989	06-Mar-22	BAGALKOT	110	UDIKERI- NOKOR SOLAR	UDIKERI_110	19:31	21:43	2:12	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
990	06-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1	RANEENNUR_220	14:52	16:01	1:09	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
991	06-Mar-22	BAGALKOT	220	220/110KV,HV2,LV2	RANEENNUR_220	15:56	16:02	0:06	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
992	06-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
993	06-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
994	06-Mar-22	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
995	06-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
996	06-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:33 (3.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
997	06-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
998	06-Mar-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:42 (06.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
999	06-Mar-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:43 (06.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVOIDED
1000	06-Mar-22	BAGALKOT	220	SIRSI-SHARAVATI1	STATION NOT AFFECTED SIRSI_220	11:25 (05.03.2022)	15:42 (06.03.2022)	28:17 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
1001	06-Mar-22	BAGALKOT	220	SIRSI-SHARAVATI2	STATION NOT AFFECTED SIRSI_220	11:26 (05.03.2022)	15:43 (06.03.2022)	28:17 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
1002	06-Mar-22	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	15:13	15:18	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1003	06-Mar-22	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	6:25	6:38	0:12	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1004	06-Mar-22	BENGALURU	66	ANEKAL - YARANDANAHALLI 220	ANEKAL	10:15	18:00	7:45	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
1005	06-Mar-22	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	16:46	16:48	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1006	06-Mar-22	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	9:39	9:42	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1007	06-Mar-22	BENGALURU	66	BIEC - SRS PEENYA 220	BIEC	6:31	6:41	0:10	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1008	06-Mar-22	BENGALURU	66	BIEC - SRS PEENYA 220	BIEC	10:44	14:58	4:14	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOIDED
1009	06-Mar-22	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	10:10	10:20	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1010	06-Mar-22	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	16:45	16:50	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1011	06-Mar-22	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	9:49	9:50	0:01	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1012	06-Mar-22	BENGALURU	66	DEVARABISANAHALLI - HSR LAYOUT 220	DEVARABISANAHALLI, GLOBAL TECH PARK	6:41	7:28	0:47	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1013	06-Mar-22	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	10:36	10:41	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1014	06-Mar-22	BENGALURU	66	GOKLUA - SRS PEENYA 1 & 2 220	GOKULA, BEL (EHT), HMT (EHT)	6:30	6:46	0:16	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1015	06-Mar-22	BENGALURU	66	GOKLUA - SRS PEENYA 1 & 2 220	GOKULA, BEL (EHT), HMT (EHT)	15:49	15:58	0:09	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1016	06-Mar-22	BENGALURU	66	HAROBELA - KANAKPURA 220	KUNUR, HAROBELA, HUKUNDA, KODIHALLI, HUNSENAHALLI, BIJJAHALLI	3:10	13:00	9:50	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1017	06-Mar-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:26	13:53	2:27	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1018	06-Mar-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	8:17	9:35	1:18	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1019	06-Mar-22	BENGALURU	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI, GLOBAL TECH PARK	6:41	7:28	0:47	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1020	06-Mar-22	BENGALURU	66	HV1	DASHAVARA	9:38	9:46	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1021	06-Mar-22	BENGALURU	66	HV1	EPIP 220	23:44:00(05/03/2022)	00:09(06/03/2022)	0:25 hrs	TRUE	FALSE	FALSE	FALSE	TRANSFORMER CHARGED
1022	06-Mar-22	BENGALURU	66	HV1	GOWRIBIDANUR 220	13:38	13:44	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1023	06-Mar-22	BENGALURU	66	HV1	HUKUNDA	8:37	8:43	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1024	06-Mar-22	BENGALURU	66	HV1	HUKUNDA	16:29	16:34	0:04	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1025	06-Mar-22	BENGALURU	66	HV1	REMC0	10:23	10:28	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1026	06-Mar-22	BENGALURU	66	HV1	REMC0	16:46	16:48	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1027	06-Mar-22	BENGALURU	66	HV1	SOMAYAJJANAHALLI	12:58	13:13	0:14	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1028	06-Mar-22	BENGALURU	66	HV1	VIJAYANAGARA	6:18	6:39	0:21	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1029	06-Mar-22	BENGALURU	66	HV1	VIJAYANAGARA	17:17	17:22	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1030	06-Mar-22	BENGALURU	66	HV1	VIJAYANAGARA	10:10	10:19	0:09	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1031	06-Mar-22	BENGALURU	66	HV1	YARANDANAHALLI 220	14:15	14:45	0:30	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1032	06-Mar-22	BENGALURU	66	HV2	HOSUR RAMAPURA	20:58	21:22	0:24	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1033	06-Mar-22	BENGALURU	66	HV2	KUMBALAGODU	10:40	10:42	0:02	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1034	06-Mar-22	BENGALURU	66	HV2	VIJAYANAGARA	6:21	6:39	0:18	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1035	06-Mar-22	BENGALURU	66	HV2	VIJAYANAGARA	17:17	17:24	0:07	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1036	06-Mar-22	BENGALURU	66	HV2	VIJAYANAGARA	10:10	10:19	0:09	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1037	06-Mar-22	BENGALURU	66	HV2	YARANDANAHALLI 220	14:15	14:45	0:30	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1038	06-Mar-22	BENGALURU	66	HV3	YARANDANAHALLI 220	14:15	14:45	0:30	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1039	06-Mar-22	BENGALURU	66	IIsc - HEBBALA 220	IIsc	6:25	6:40	0:15	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1040	06-Mar-22	BENGALURU	66	IIsc - NRS 220	IIsc	16:42	16:47	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1041	06-Mar-22	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	16:33	16:53	0:20	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1042	06-Mar-22	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	10:14	10:24	0:10	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1043	06-Mar-22	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	15:50	15:57	0:07	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1044	06-Mar-22	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	6:53	6:58	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1045	06-Mar-22	BENGALURU	66	MANYATHA TECH PARK 220 - BYATARAYANAPURA(L& T REALTY)	BYATARAYANAPURA(L& T REALTY)	13:14	15:35	2:21	FALSE	FALSE	FALSE	TRUE	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1046	06-Mar-22	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	6:30	6:37	0:07	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1047	06-Mar-22	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	16:23	16:26	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1048	06-Mar-22	BENGALURU	66	MEI LAYOUT - SRS PEENYA 220	MEI LAYOUT	8:05	14:59	6:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1049	06-Mar-22	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA	8:05	15:37	7:32	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1050	06-Mar-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	16:08	16:13	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1051	06-Mar-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	7:15	7:22	0:07	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1052	06-Mar-22	BENGALURU	66	NRS 220 - REMCO MY 2	CHANDRA LAYOUT	10:10	10:20	0:10	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1053	06-Mar-22	BENGALURU	66	RANGANDODDI - SOMANHALLI 220	RANGANDODDI	10:09	18:03	7:53	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1054	06-Mar-22	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	6:30	6:33	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1055	06-Mar-22	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	16:13	16:15	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1056	06-Mar-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	6:55	6:59	0:04	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1057	06-Mar-22	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	7:03	7:08	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1058	06-Mar-22	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	14:33	15:01	0:28	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1059	06-Mar-22	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	16:45	17:01	0:16	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1060	06-Mar-22	BENGALURU	66	VISHURASHTRAVATHA - GOWRIBIDANUR 220	VIDHURASHWATHA, GUNDLU KOTTUR, BAGEPALLI	18:45	19:00	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1061	06-Mar-22	BENGALURU	66	VISHURASHTRAVATHA - GREE SOLAR(IPP)	NO STATION AFFECTED	5:48	10:36	4:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1062	06-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	12:41	13:00	0:19	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1063	06-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	10:33	12:35	2:02	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1064	06-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	14:15	14:45	0:30	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1065	06-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	14:15	14:45	0:30	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1066	06-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	17:25	17:33	0:08	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1067	06-Mar-22	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	14:15	14:45	0:30	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1068	06-Mar-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	11:03	20:19	9:16	FALSE	TRUE	FALSE	FALSE	LOAD CURTAILMENT
1069	06-Mar-22	BENGALURU	220	HV2	SRS PEENYA 220	9:06	14:38	5:32	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1070	06-Mar-22	BENGALURU	220	HV2	YARANDANAHALLI 220	14:15	14:45	0:30	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1071	06-Mar-22	BENGALURU	220	HV3	YARANDANAHALLI 220	14:15	14:45	0:30	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1072	06-Mar-22	BENGALURU	220	HV4	SRS PEENYA 220	9:06	14:38	5:32	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1073	06-Mar-22	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220	VRISHABHAVATHI 220	10:26	16:35	6:09	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1074	06-Mar-22	GULBARGA	66	HV1	ITTAGI_220	11:03 (5.03.2022)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
1075	06-Mar-22	GULBARGA	66	HV2	TAMBRAHALI_66	7:15	7:20	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1076	06-Mar-22	GULBARGA	110	HUNSAGI-KEMBHAVI	HUNSAGI_110	19:50	20:00	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1077	06-Mar-22	GULBARGA	110	HV1	GALAG_110	18:40	19:05	0:25	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1078	06-Mar-22	GULBARGA	110	HV1	SHAHAPUR_110	6:25	8:01	1:36	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1079	06-Mar-22	GULBARGA	110	HV1	SHAHAPUR_110	8:01	13:20	5:19	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1080	06-Mar-22	GULBARGA	110	HV2	SHAHAPUR_220	12:15	12:34	0:19	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1081	06-Mar-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	16:04	16:14	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1082	06-Mar-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	9:20	9:30	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1083	06-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1084	06-Mar-22	GULBARGA	110	SHAHAPUR110-SHAHAPUR220	SHAHAPUR_110	6:25	7:45	1:20	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1085	06-Mar-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	6:21	7:42	1:21	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1086	06-Mar-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	9:17	14:53	5:36	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1087	06-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	1:50	2:00	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1088	06-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERDONA_110,SRNAGAR_110,M ALLAPURA_110	5:43	5:53	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1089	06-Mar-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	6:00	6:10	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1090	06-Mar-22	GULBARGA	110	YELBURGA-TALALUTAI IPP	YELBURGA_110	19:36(05.03.2022)	7:22(06.03.2022)	11:46 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
1091	06-Mar-22	GULBARGA	110	YELBURGA-TALALUTAI IPP	YELBURGA_110	22:55(06.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1092	06-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
1093	06-Mar-22	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	5:09	5:24	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1094	06-Mar-22	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	9:26	22:53	13:27	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1095	06-Mar-22	HASSAN	66	HV1	YESLUR_66	10:28	23:05	12:37	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1096	06-Mar-22	HASSAN	66	HV2	SINGAPURA_66	7:17	7:20	0:03	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1097	06-Mar-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:18	18:38	9:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1098	06-Mar-22	HASSAN	66	YESLUR-SNVRSNT	YESLUR_66	12:23	16:29	4:06	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1099	06-Mar-22	HASSAN	110	BARANG-SHR220	BARANGI_110	9:59	19:16	9:17	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
1100	06-Mar-22	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	10:30	15:22	4:52	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1101	06-Mar-22	HASSAN	110	HOSNGD-HULIKAL	HOSANGADI_110	11:28	16:44	5:16	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
1102	06-Mar-22	HASSAN	110	HULICA+MRS	HULICAL_110	11:28	16:45	5:17	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1103	06-Mar-22	HASSAN	110	HULICA-KAVOOR	HULICAL_110	11:19	16:51	5:32	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1104	06-Mar-22	HASSAN	110	HV1	BAIKAMPADI_110	9:54	13:58	4:04	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1105	06-Mar-22	HASSAN	110	HV1	HULICAL_110	11:24	16:47	5:23	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1106	06-Mar-22	HASSAN	110	HV1	SHIKARIPURA_110	11:59	12:27	0:28	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1107	06-Mar-22	HASSAN	110	HV2	ANANDAPURA_110	10:38	10:58	0:20	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1108	06-Mar-22	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1109	06-Mar-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:38	16:45	6:07	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
1110	06-Mar-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_66	11:22	14:22	3:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1111	06-Mar-22	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	16:21	16:33	0:12	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1112	06-Mar-22	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	16:21	16:32	0:11	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1113	06-Mar-22	HASSAN	110	PUTTUR-PUTUR2	PUTTUR_220	16:21	16:32	0:11	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1114	06-Mar-22	HASSAN	110	PUTTUR-VITLA	PUTTUR_220	16:21	16:35	0:14	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1115	06-Mar-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	9:59	19:16	9:17	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1116	06-Mar-22	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1117	06-Mar-22	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	10:58	16:31	5:33	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1118	06-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1119	06-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1120	06-Mar-22	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	14:15	16:39	2:24	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1121	06-Mar-22	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	16:20	16:41	0:21	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1122	06-Mar-22	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:18	13:54	2:36	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
1123	06-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16(8/12/2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1124	06-Mar-22	MYSURU	66	HUNSUR-HANGODU	HANGODU_66	10:06	18:24	8:17	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
1125	06-Mar-22	MYSURU	66	HV1	AJJIPURA_66	7:45	9:25	1:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1126	06-Mar-22	MYSURU	66	HV1	BEGUR_66	8:26	8:40	0:14	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1127	06-Mar-22	MYSURU	66	HV1	COWDALLI_66	13:24	13:28	0:03	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1128	06-Mar-22	MYSURU	66	HV1	MANDAGERE_66	21:05	21:15	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1129	06-Mar-22	MYSURU	66	HV2	PANDAVAPURA_66	0:05	0:34	0:29	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1130	06-Mar-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1131	06-Mar-22	MYSURU	66	KIADB MANDYA-TK HALLI	TUMBEKERE_66 KIADBMANDYA_66	9:06	16:30	7:24	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1132	06-Mar-22	MYSURU	66	KIADB SOMANAHALLI-MADDUR	NO STATIONS EFFECTED	22:50	22:57	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1133	06-Mar-22	MYSURU	66	MADDUR-KIADB MANDYA	MADDUR_66	9:11	18:23	9:11	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1134	06-Mar-22	MYSURU	66	MADDUR-SOMANAHALLI	NO STATIONS EFFECTED	9:11			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1135	06-Mar-22	MYSURU	66	MANDYA-K K HALLI	KADKOTHANAHALLI_66	7:12	7:17	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1136	06-Mar-22	MYSURU	66	SHANIVARSANTHE-MALIPATNA	SHANIVARSANTE_66 YESLOOR_66 HETTUR_66	10:12	16:52	6:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1137	06-Mar-22	MYSURU	66	SHANIVARSANTHE-YESSLUR	NO STATIONS EFFECTED	10:12	16:53	6:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1138	06-Mar-22	MYSURU	220	KADAKOLA-KANNENBETTA	NO STATIONS EFFECTED	17:22:00 (5.3.2022)	0:13:00 (6.03.2022)	6:51 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
1139	06-Mar-22	TUMKUR	66	KUKKAWADA -HONNALLI	KUKKAWADA_66	9:00	18:35	9:34	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1140	06-Mar-22	TUMKUR	66	MADHUGIRI 220-KALLAMBELLA(SIRA2)	KALLAMBELLA_66, SIRA_66	6:20	9:08	2:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1141	06-Mar-22	TUMKUR	66	MADHUGIRI 220KV-PULLAMAGATTA	PULLAMGATTA_66	6:20	9:08	2:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1142	06-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	7:40	7:56	0:16	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1143	06-Mar-22	TUMKUR	66	TR-1	DAVANGERE_220	9:33	9:42	0:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1144	06-Mar-22	TUMKUR	220	CHALLAKERE-THALLAKK	CHALLAKERE_66	8:45	21:31	12:46	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1145	06-Mar-22	TUMKUR	220	HONNALLI 220kv-DAVANAGERE SRS	HONNALLI_220	11:15	16:36	5:21	FALSE	TRUE	FALSE	FALSE	LOAD CURTAILMENT
1146	06-Mar-22	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	11:20	16:53	5:33	FALSE	TRUE	FALSE	FALSE	LOAD CURTAILMENT
1147	06-Mar-22	TUMKUR	220	TR-2	MADHUGIRI_220	6:20	9:08	2:48	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1148	07-Mar-22	BAGALKOT	110	(KABBUR)F2-SULTANPUR	STATION NOT AFFECTED SULTANPUR_110	10:47	13:21	2:34	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1149	07-Mar-22	BAGALKOT	110	110/11KV,(HV2)HV1	UGAR KHUD_110	17:20	17:48	0:28	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1150	07-Mar-22	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	12:29	12:55	0:26	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1151	07-Mar-22	BAGALKOT	110	110/11KV,HV1	THORVI_110	12:01	13:39	1:38	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1152	07-Mar-22	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	11:10	11:25	0:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1153	07-Mar-22	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	23:39	23:58	0:19	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1154	07-Mar-22	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	23:58 (07.03.2022)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
1155	07-Mar-22	BAGALKOT	110	110/11KV,HV2	MUNDUGANUR_110	16:20	17:05	0:45	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1156	07-Mar-22	BAGALKOT	110	110/11KV,HV2(HV1)	SALAHALLI_110	22:50	23:20	0:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1157	07-Mar-22	BAGALKOT	110	110/11KV,HV3	SATTI_33 SATTI_110	12:41	13:21	0:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1158	07-Mar-22	BAGALKOT	110	110/33KV, HV1(HV2)	HUBLI_220	11:26	17:22	5:56	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1159	07-Mar-22	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	8:01	8:16	0:15	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1160	07-Mar-22	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	10:24	10:47	0:23	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1161	07-Mar-22	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	10:52	11:16	0:24	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1162	07-Mar-22	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	14:10	14:20	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1163	07-Mar-22	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	13:11 (23.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1164	07-Mar-22	BAGALKOT	110	DAVALESHWAR-SAIDAPUR	STATION NOT AFFECTED DAVALESHWAR_110	11:49	14:00	2:11	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1165	07-Mar-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1166	07-Mar-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1167	07-Mar-22	BAGALKOT	110	MUGHALKOD- SULTANPUR	MUGALKOD_220	10:48	13:18	2:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1168	07-Mar-22	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1169	07-Mar-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1170	07-Mar-22	BAGALKOT	110	SALAHALLI-GM NAVAR	STATION NOT AFFECTED SALAHALLI_110	23:12	23:45	0:33	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1171	07-Mar-22	BAGALKOT	110	SIRSI-KUMTA1	STATION NOT AFFECTED SIRSI_110	11:00	13:30	2:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1172	07-Mar-22	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	11:00	13:34	2:34	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1173	07-Mar-22	BAGALKOT	110	VAJRAMATTI-BILAGI	BILAGI_110,SHIRAGUPPI_110,T OLAMATTI_110,BISNAL_110,GI RISAGAR_110,BILAGI_110	14:20	16:09	1:49	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1174	07-Mar-22	BAGALKOT	110	VAJRAMATTI-JK CEMENT	VAJRAMTTI_220	14:20	16:00	1:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1175	07-Mar-22	BAGALKOT	110	VAJRAMTTI-KATARAKI	KATARAKI_110	14:50	18:08	3:18	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1176	07-Mar-22	BAGALKOT	110	VAJRAMTTI-KD JAMBAGI	KD JAMBAGI_110,HALKI_110	14:52	15:53	1:01	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1177	07-Mar-22	BAGALKOT	110	VAJRAMTTI-LOKAPUR	LOKAPUR_110	14:52	15:53	1:01	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1178	07-Mar-22	BAGALKOT	110	VAJRAMTTI-MANTUR1&2	MANTUR_110	14:20	16:00	1:40	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1179	07-Mar-22	BAGALKOT	110	VAJRAMTTI-MELLIGERI	MELLIGERI_110	14:20	16:16	1:56	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1180	07-Mar-22	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	VAJRAMTTI_220	14:21	15:47	1:26	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAIED
1181	07-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1182	07-Mar-22	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1183	07-Mar-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1184	07-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:32 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1185	07-Mar-22	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	10:33 (3.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1186	07-Mar-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1187	07-Mar-22	BAGALKOT	220	HUBLI- NARENDRA2	HUBLI_220	18:47	18:57	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1188	07-Mar-22	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	10:02	18:26	8:24	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
1189	07-Mar-22	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	10:02	18:46	8:44	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
1190	07-Mar-22	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	10:01	18:26	8:25	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1191	07-Mar-22	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	10:01	18:46	8:45	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1192	07-Mar-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:42 (06.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1193	07-Mar-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:43 (06.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAIED
1194	07-Mar-22	BAGALKOT	220	VAJRAMTTI-ENERGON SOLAR	VAJRAMTTI_220	11:01	11:22	0:21	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1195	07-Mar-22	BAGALKOT	220	VAJRAMTTI-KAWATAGI LIS	VAJRAMTTI_220	14:20	16:59	2:39	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1196	07-Mar-22	BENGALURU	66	CB PURA I/A - CB PURA URBAN	CB PURA URBAN	13:21	13:25	0:04	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1197	07-Mar-22	BENGALURU	66	CESSNA - SHOBHA APARTMENT	CESSNA	12:10	12:20	0:10	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1198	07-Mar-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	0:40	0:56	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1199	07-Mar-22	BENGALURU	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK	12:20	12:30	0:10	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1200	07-Mar-22	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSUR RAMAPURA	10:40	11:15	0:35	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1201	07-Mar-22	BENGALURU	66	HV1	ATTIBELE	7:11	7:15	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1202	07-Mar-22	BENGALURU	66	HV1	BIDADI 220	15:45	16:53	1:08	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1203	07-Mar-22	BENGALURU	66	HV1	DASHAVARA	10:40	11:15	0:35	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1204	07-Mar-22	BENGALURU	66	HV1	KADUGODI	8:30	8:35	0:05	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1205	07-Mar-22	BENGALURU	66	HV1	KADUGODI	9:57	10:00	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1206	07-Mar-22	BENGALURU	66	HV1	TADIGOLU	10:44	13:20	2:35	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1207	07-Mar-22	BENGALURU	66	HV1	TEKAL	7:28	10:10	2:42	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1208	07-Mar-22	BENGALURU	66	HV2	CB PURA I/A	12:10	13:32	1:22	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1209	07-Mar-22	BENGALURU	66	HV2	DODDABELAVANGALA	14:08	14:10	0:02	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1210	07-Mar-22	BENGALURU	66	HV2	EXORA	20:43	20:50	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1211	07-Mar-22	BENGALURU	66	HV2	KGF	11:00	11:05	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1212	07-Mar-22	BENGALURU	66	HV2	MAASTHI	8:13	8:19	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1213	07-Mar-22	BENGALURU	66	HV2	SM MANGALA	14:29	14:39	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1214	07-Mar-22	BENGALURU	66	HV2	TADIGOLU	13:31	15:26	1:55	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1215	07-Mar-22	BENGALURU	66	HV3	KGF	10:11	17:22	7:11	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVOID
1216	07-Mar-22	BENGALURU	66	HV3	KGF	17:39	21:33	3:53	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1217	07-Mar-22	BENGALURU	66	HV3	YARANDANAHALLI 220	16:56	18:33	1:37	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1218	07-Mar-22	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	10:23	10:28	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1219	07-Mar-22	BENGALURU	66	RBI - KHODAYS 220	RBI	18:28	18:31	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1220	07-Mar-22	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	10:57	11:05	0:08	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1221	07-Mar-22	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	10:58	11:03	0:05	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1222	07-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	3:07	3:22	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1223	07-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	3:22	5:36	2:14	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1224	07-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	5:36	5:55	0:19	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1225	07-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	5:55	8:55	3:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1226	07-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	8:55	9:00	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1227	07-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	9:00	11:33	2:33	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1228	07-Mar-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	11:38	13:22	1:44	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1229	07-Mar-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	9:00	14:46	5:45	FALSE	TRUE	FALSE	FALSE	LOAD CURTAILMENT
1230	07-Mar-22	GULBARGA	66	HV1	ITTAGI_220	11:03 (5.03.2022)	15:10 (7.03.2022)	52:07 HRS	TRUE	FALSE	FALSE	FALSE	TRANSFORMER CHARGED
1231	07-Mar-22	GULBARGA	66	HV1	KUDLIGI_220	9:35	9:45	0:10	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1232	07-Mar-22	GULBARGA	66	HV2	TAMBRAHALLI_66	11:59	12:22	0:23	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1233	07-Mar-22	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	11:01	11:16	0:15	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1234	07-Mar-22	GULBARGA	66	KUDLIGI-CHORNOOR	CHORNOOR_66	10:30	17:00	6:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1235	07-Mar-22	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	22:06	22:30	0:24	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1236	07-Mar-22	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	22:35	23:01		FALSE	FALSE	FALSE	TRUE	LINE FAULT
1237	07-Mar-22	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	18:27	18:49	0:22	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1238	07-Mar-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	10:00	10:10	0:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1239	07-Mar-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATAVAHA NA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMLAPUR_IPP,MATR_110,RBNS FACTORY	0:03	0:13	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1240	07-Mar-22	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	13:39	13:54	0:15	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1241	07-Mar-22	GULBARGA	110	CHICKSUGUR-SHAKTINAGAR	SHAKTINAGAR_110	10:05	14:37	4:32	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1242	07-Mar-22	GULBARGA	110	GALAG-MALLAT	GALAG_110	11:15	11:35	0:20	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1243	07-Mar-22	GULBARGA	110	HALAKUNDI-ALIPUR	HALAKUNDI_110	13:39	13:54	0:15	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1244	07-Mar-22	GULBARGA	110	HV1	JEEWARGI_110	9:20	18:30	9:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1245	07-Mar-22	GULBARGA	110	HV1	MALLAPUR_110	9:30	14:30	5:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1246	07-Mar-22	GULBARGA	110	HV2	SHAHAPUR_220	9:25	10:34	1:09	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1247	07-Mar-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	22:01	22:11	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1248	07-Mar-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:33	20:43	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1249	07-Mar-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:25	21:35	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1250	07-Mar-22	GULBARGA	110	MASKI-RNWSLR	MASKI_110	1:03	1:36	0:33	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1251	07-Mar-22	GULBARGA	110	MASKI-SINDANOOR	MASKI_110	0:55	1:03	0:08	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1252	07-Mar-22	GULBARGA	110	MASKI-SINDANOOR	MASKI_110	6:18	6:35	0:17	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1253	07-Mar-22	GULBARGA	110	MUDDAPUR-SINDANOOR	MUDDAPUR_110	0:55	1:03	0:08	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1254	07-Mar-22	GULBARGA	110	MUDDAPUR-SINDANOOR	MUDDAPUR_110	6:17	6:33	0:16	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1255	07-Mar-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1256	07-Mar-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	4:44	4:56	0:12	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1257	07-Mar-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	4:44	4:56	0:12	FALSE	FALSE	FALSE	TRUE	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1258	07-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	1:01	1:11	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1259	07-Mar-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	13:55	15:15	1:20	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1260	07-Mar-22	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAPUR_110,MASKI_110,VALAKAMADINNI_110	6:17	6:27	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1261	07-Mar-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSLSUGAR_IPP,VOORA_IPP	5:12	5:22	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1262	07-Mar-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSLSUGAR_IPP,VOORA_IPP	5:57	6:07	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1263	07-Mar-22	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	3:45	3:55	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1264	07-Mar-22	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	2:50	3:10	0:20	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1265	07-Mar-22	GULBARGA	110	YELBURGA-PARAMPUJYA IPP	YELBURGA_110	11:06	11:35	0:29	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1266	07-Mar-22	GULBARGA	110	YELBURGA-TALALUTAI IPP	YELBURGA_110	22:55(06.03.2022)	7:45(07.03.2022)	8:50 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
1267	07-Mar-22	GULBARGA	110	YELBURGA-TALALUTAI IPP	YELBURGA_110	19:12(07.03.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1268	07-Mar-22	GULBARGA	220	HV1	SINDHANOOR_220	9:17	16:13	6:56	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1269	07-Mar-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			FALSE	FALSE	FALSE	TRUE	TRANSFORMER OPEN:TRANSFORMER FAULT
1270	07-Mar-22	GULBARGA	220	HV2, LV2	ALIPUR_220	0:03	0:12	0:09	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1271	07-Mar-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	21:47	22:22	0:35	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1272	07-Mar-22	GULBARGA	220	RTPS-LINGASUGUR3	MALLAT_220	21:47	22:12	0:25	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1273	07-Mar-22	GULBARGA	400	RTPS-RAICHUR1	PGCL(RTMC)_400	8:23	18:45	10:22	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1274	07-Mar-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	13:44	14:00	0:16	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1275	07-Mar-22	HASSAN	66	CHIKABO-SIDPR	CHIKABOMMENAHALLY_66	10:39	13:13	2:34	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1276	07-Mar-22	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	12:51	14:53	2:02	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1277	07-Mar-22	HASSAN	66	HV1	ARAKALGUD_66	6:47	7:13	0:26	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1278	07-Mar-22	HASSAN	66	HV1	ARAKALGUD_66	15:30	15:34	0:04	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
1279	07-Mar-22	HASSAN	66	HV1	KIADB_66	10:12	17:12	7:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1280	07-Mar-22	HASSAN	66	HV1	SHANTHIGRAMA_66	11:46	12:33	0:47	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1281	07-Mar-22	HASSAN	66	HV1	SINGAPURA_66	11:57	12:21	0:24	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1282	07-Mar-22	HASSAN	66	HV1	YESLUR_66	12:54	15:05	2:11	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1283	07-Mar-22	HASSAN	66	HV2	HIRISAVE_66	7:05	7:10	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1284	07-Mar-22	HASSAN	66	HV2	KIADB_66	10:12	17:12	7:00	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1285	07-Mar-22	HASSAN	66	HV2	SHANTHIGRAMA_66	12:25	12:55	0:30	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1286	07-Mar-22	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	9:27	11:53	2:26	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1287	07-Mar-22	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	12:38	12:46	0:08	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1288	07-Mar-22	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	14:46	14:53	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1289	07-Mar-22	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	15:17	15:22	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1290	07-Mar-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	14:21	14:27	0:06	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1291	07-Mar-22	HASSAN	110	HV1	SHIVPURA_110	12:00	13:45	1:45	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1292	07-Mar-22	HASSAN	110	KAVOOR-KVRBJP2	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1293	07-Mar-22	HASSAN	220	KAVOOR-KVRBJP1	KAVOOR_220	8:59(22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1294	07-Mar-22	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	15:04	16:20	1:16	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1295	07-Mar-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1296	07-Mar-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:59 (22.02.2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1297	07-Mar-22	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	15:04	16:20	1:16	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1298	07-Mar-22	MYSURU	66	BANNIMANTAP-VIJAYNAGAR	BANNIMANTAP_66	11:22	11:36	0:13	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1299	07-Mar-22	MYSURU	66	D B HALLI-TUBINAKERE	DODDABYADARAHALLI_66	10:05	17:15	7:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1300	07-Mar-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8/12/2021)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1301	07-Mar-22	MYSURU	66	HOOTAGALLY-FTS 1	NO STATIONS EFFECTED	10:52	18:38	7:46	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1302	07-Mar-22	MYSURU	66	HOOTAGALLY-FTS 2	NO STATIONS EFFECTED	10:52	18:38	7:46	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1303	07-Mar-22	MYSURU	66	HV1	TERAKANAMBE_66	10:55	11:48	0:53	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1304	07-Mar-22	MYSURU	66	HV2	KADAKOLA_220	12:19	14:34	2:15	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1305	07-Mar-22	MYSURU	66	HV2	MADDUR_66	11:05	12:59	1:54	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1306	07-Mar-22	MYSURU	66	HV3	KUSHALNAGARA_66	10:00	17:39	7:39	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1307	07-Mar-22	MYSURU	66	HV4	KUSHALNAGARA_66	10:00	17:39	7:39	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1308	07-Mar-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			TRUE	FALSE	FALSE	FALSE	LINE OPEN:LINE CLEAR AVAILED
1309	07-Mar-22	MYSURU	66	KIADB SOMANAHALLI-MADDUR	NO STATIONS EFFECTED	13:22	14:35	1:13	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1310	07-Mar-22	MYSURU	66	KR NAGAR-BILIKERE	BILIKERE_66GVGUDI_66DMG_HALLI_66	9:15	10:02	0:47	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
1311	07-Mar-22	MYSURU	66	KR NAGAR-CHUNCHUNKATTE	NO STATIONS EFFECTED	7:45	9:50	2:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1312	07-Mar-22	MYSURU	66	KR NAGAR-KUSHALANAGRA	KR NAGARA_66	7:55	8:45	0:50	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1313	07-Mar-22	MYSURU	66	KR NAGAR-KUSHALANAGRA	KR NAGARA_66	8:50	9:20	0:30	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1314	07-Mar-22	MYSURU	66	KUSHALANAGARA-MADIKERI	MADIKERI_66	10:30	17:03	6:33	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1315	07-Mar-22	MYSURU	66	KUSHALANAGARA-MADIKERI	MADIKERI_66	17:03	17:11	0:08	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1316	07-Mar-22	MYSURU	66	KUSHALANAGARA-SUNTIKOPPA	SUNTIKOPPA_66	10:30	17:04	6:34	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1317	07-Mar-22	MYSURU	66	MADDUR-SOMANAHALLI	NO STATIONS EFFECTED	9:11:50 (6.03.2022)	13:25:00 (7.03.2022)	28:13 hrs	TRUE	FALSE	FALSE	FALSE	LINE CHARGED
1318	07-Mar-22	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	12:20	12:24	0:03	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
1319	07-Mar-22	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	13:01	13:25	0:24	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1320	07-Mar-22	MYSURU	220	KADAKOLA-BASTIPURA 1	NO STATIONS EFFECTED	7:44	10:58	3:14	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1321	07-Mar-22	TUMKUR	66	BADAVANAHALLI-MADHUGIRI	BADAVANAHALLI_66	11:45	12:12	0:27	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1322	07-Mar-22	TUMKUR	66	BADAVANAHALLI-MADHUGIRI	BADAVANAHALLI_66	13:01	13:08	0:07	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1323	07-Mar-22	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	12:27	14:11	1:44	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1324	07-Mar-22	TUMKUR	66	BHARAMAGIRI-MATHOD	BHARAMAGIRI_66	10:51	11:05	0:13	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1325	07-Mar-22	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	12:30	12:55	0:24	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1326	07-Mar-22	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	15:13	17:24	2:10	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1327	07-Mar-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	10:50	12:08	1:18	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1328	07-Mar-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	12:22	12:33	0:11	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1329	07-Mar-22	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	13:20	13:30	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1330	07-Mar-22	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	14:43	14:46	0:02	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1331	07-Mar-22	TUMKUR	66	HOSAKERE- MIDIGESHI	MEDIGESHI_66, PAVAGADA_66, VENKATAPURA_66	7:30	7:34	0:03	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1332	07-Mar-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKWADA_66	9:25	10:47	1:22	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1333	07-Mar-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKWADA_66	13:38	13:40	0:02	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1334	07-Mar-22	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	13:18	13:23	0:05	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1335	07-Mar-22	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	13:23	13:28	0:05	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1336	07-Mar-22	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	13:30	13:40	0:10	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1337	07-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	6:59	7:49	0:49	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1338	07-Mar-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	17:33	18:51	1:17	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1339	07-Mar-22	TUMKUR	66	PAVAGADA 220kV- SHYLAPURA	SHYLAPURA_66	13:38	13:40	0:02	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1340	07-Mar-22	TUMKUR	66	PAVAGADA 220kV- SHYLAPURA	SHYLAPURA_66	15:15	15:24	0:09	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1341	07-Mar-22	TUMKUR	66	PAVAGADA220-MIDIGESHI	MIDIGESHI_66	6:17	11:12	4:54	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1342	07-Mar-22	TUMKUR	66	PDKOTE-AZURE SOLAR	PDKOTE_66	12:28	17:31	5:03	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1343	07-Mar-22	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	9:31	17:34	8:02	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1344	07-Mar-22	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	12:28	17:58	5:30	FALSE	FALSE	TRUE	FALSE	MAIN SUPPLY FAILURE
1345	07-Mar-22	TUMKUR	66	SIRA- MADHUGIRI 1	BUKKAPATNA_66, KALLAMBELLA_66	11:02	11:52	0:50	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1346	07-Mar-22	TUMKUR	66	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	11:47	11:49	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1347	07-Mar-22	TUMKUR	66	SIRA220-PATNAYAKANAHALLI 2	PATNAYAKANAHALLI LINE2	10:02	10:10	0:08	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1348	07-Mar-22	TUMKUR	66	SIRA220-PATNAYAKANAHALLI 2	PATNAYAKANAHALLI LINE2	11:44	11:46	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1349	07-Mar-22	TUMKUR	66	SIRA220-SIRA 1	SIRA_66	11:57	11:59	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1350	07-Mar-22	TUMKUR	66	SIRA220-SIRA 3	SIRA_66	11:47	11:49	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1351	07-Mar-22	TUMKUR	66	TR-1	CHIKKABANAGERE_66	10:33	10:39	0:05	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
1352	07-Mar-22	TUMKUR	66	TR-1	CHITRADURGA_220	15:57	16:35	0:37	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1353	07-Mar-22	TUMKUR	66	TR-1	HIRIYUR_66	13:29	14:07	0:37	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1354	07-Mar-22	TUMKUR	66	TR-1	PAVAGADA_66	13:56	14:03	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1355	07-Mar-22	TUMKUR	66	TR-2	BEVINAHALLI_66	18:08	18:40	0:31	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1356	07-Mar-22	TUMKUR	66	TR-2	CHIKKABANAGERE_66	10:33	10:39	0:05	TRUE	FALSE	FALSE	FALSE	HAND TRIPPED
1357	07-Mar-22	TUMKUR	66	TR-2	HIRIYUR_66	14:07	14:26	0:19	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1358	07-Mar-22	TUMKUR	66	TR-2	KADAJJI_66	3:02	3:09	0:06	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1359	07-Mar-22	TUMKUR	66	TR-2	KORATAGERE_66	10:15	10:35	0:20	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1360	07-Mar-22	TUMKUR	66	TR-2	MALEBENNUR_66	13:44	16:07	2:22	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1361	07-Mar-22	TUMKUR	66	TR-2	SANIKERE_66	13:05	13:10	0:05	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1362	07-Mar-22	TUMKUR	66	TR2(LV SIDE)	PAVAGADA_220	6:17	6:27	0:09	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	LC	LS	MSF	FAULT	REMARKS
1363	07-Mar-22	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	15:29	15:52	0:22	FALSE	FALSE	FALSE	TRUE	LINE FAULT
1364	07-Mar-22	TUMKUR	110	KB CROSS 220kv- BANDIHALLI(TIPTUR)	BANDIHALLI_110, TIPTUR_110, HALKURKE_110, HUNASEGHTT_110, KEREKODI_110, HONNAVALLI_110, D M KURKE	10:42	10:45	0:03	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1365	07-Mar-22	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	10:44	10:46	0:02	TRUE	FALSE	FALSE	FALSE	LOAD CHANGE OVER
1366	07-Mar-22	TUMKUR	110	NITTUR 220kv- KADABA	KADABA_110	9:55	10:02	0:07	FALSE	TRUE	FALSE	FALSE	LOAD CURTAILMENT
1367	07-Mar-22	TUMKUR	110	TR-1	MAYASANDRA_110	14:02	14:28	0:25	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1368	07-Mar-22	TUMKUR	110	TR-2	SANEKERE_110	17:41	17:51	0:10	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED
1369	07-Mar-22	TUMKUR	220	PAVAGADA 220kv- MADHUGIRI 2	PAVAGADA_220	11:35	18:53	7:17	TRUE	FALSE	FALSE	FALSE	NFBC ISSUED
1370	07-Mar-22	TUMKUR	220	TR-2	PAVAGADA_220	6:17	6:25	0:07	FALSE	FALSE	FALSE	TRUE	TRANSFORMER FAULT
1371	07-Mar-22	TUMKUR	220	TR-2	SIRA_220	11:49	17:07	5:18	TRUE	FALSE	FALSE	FALSE	LINE CLEAR AVAILED