

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 10.09.2019 TO 16.09.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	10-Sep-19	BAGALKOT	110	KUMTA-ANKOLA	ANKOLA_110	0:00	8:01	8:01	LINE CLEAR AVAILED
2	10-Sep-19	BAGALKOT	110	BAGALKOT220-NAVANAGAR2	NAVANAGAR_110	9:30	9:40	0:10	LINE FAULT
3	10-Sep-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	11:24	14:50	3:26	LINE CLEAR AVAILED
4	10-Sep-19	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	10:53	14:55	4:02	LINE CLEAR AVAILED
5	10-Sep-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	10:53	14:55	4:02	LINE CLEAR AVAILED
6	10-Sep-19	BAGALKOT	110	GHATAPRABHA220-P G HUNSYAL	P G HUNSYAL_110	5:49	6:14	0:25	LINE FAULT
7	10-Sep-19	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DUMMWAD_33	6:51	7:11	0:20	TRANSFORMER FAULT
8	10-Sep-19	BAGALKOT	110	PG HUNSHYAL-MUDALGI	MUDALGI_110, NAGNUR_110	5:47	6:29	0:42	MAIN SUPPLY FAILURE
9	10-Sep-19	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	11:42	11:50	0:08	LINE FAULT
10	10-Sep-19	BENGALURU	66	HV1	TK HALLI 220	15:25	15:40	0:14	TRANSFORMER FAULT
11	10-Sep-19	BENGALURU	66	HV1	MEI LAYOUT	9:36	9:40	0:03	TRANSFORMER FAULT
12	10-Sep-19	BENGALURU	66	HV1	BOODIGERE	9:54	10:31	0:37	LINE CLEAR AVAILED
13	10-Sep-19	BENGALURU	66	HV2	BOODIGERE	10:31	10:35	0:03	LINE CLEAR AVAILED
14	10-Sep-19	BENGALURU	66	HV1	BG ROAD	15:16	15:18	0:01	LINE CLEAR AVAILED
15	10-Sep-19	BENGALURU	66	HV3	A STATION 66	14:50	14:55	0:04	LINE CLEAR AVAILED
16	10-Sep-19	BENGALURU	66	MEI LAYOUT - SRS PEENYA 220	MEI LAYOUT, WIDIA, WIDIA (EHT)	11:00	11:10	0:10	LINE CLEAR AVAILED
17	10-Sep-19	BENGALURU	66	HV2	JANGAMAKOTE	5:21	5:30	0:09	TRANSFORMER FAULT
18	10-Sep-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:42	10:50	0:08	LINE FAULT
19	10-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKALLU	2:10	2:20	0:10	LOAD CHANGEOVER
20	10-Sep-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	SOMENAHALLI, PERESANDRA, MANDIKALLU	11:05	11:24	0:19	LOAD CHANGEOVER
21	10-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKALLU	19:11	19:15	0:04	LOAD CHANGEOVER
22	10-Sep-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	10:23	10:33	0:10	LINE FAULT
23	10-Sep-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	11:01	11:13	0:12	LINE FAULT
24	10-Sep-19	GULBARGA	110	ALIPUR-PDHALLI	PDHALLI_110	0:00	0:20	0:20	MAIN SUPPLY FAILURE
25	10-Sep-19	GULBARGA	110	KAPNOOR-GLBNR1	GULBARGANORTH_110,GULBARGASOUTH_110,GULUNI_110	7:10	8:15	1:05	LINE CLEAR AVAILED
26	10-Sep-19	GULBARGA	110	KAPNOOR-GLBNR2	GULBARGANORTH_110,GULBARGASOUTH_110,GULUNI_110	7:10	19:45	12:35	LINE CLEAR AVAILED
27	10-Sep-19	GULBARGA	110	HV3	BEVOOR_110	16:52	19:00	2:08	TRANSFORMER FAULT
28	10-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	12:00	12:09	0:09	TRANSFORMER FAULT
29	10-Sep-19	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110, NALWAR_110	3:40	3:50	0:10	LINE FAULT
30	10-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP	4:50	4:58	0:08	LINE FAULT
31	10-Sep-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	6:00	6:10	0:10	LINE FAULT
32	10-Sep-19	GULBARGA	66	HV1	HAMPASAGAR_66	13:06	13:10	0:04	TRANSFORMER FAULT
33	10-Sep-19	GULBARGA	66	LV1&LV2	ITTAGI_220	12:40	12:51	0:11	TRANSFORMER FAULT
34	10-Sep-19	GULBARGA	66	HV3	ITTAGI_220	13:02	13:10	0:08	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
35	10-Sep-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	11:09	23:59	12:50	LINE FAULT
36	10-Sep-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	23:20	23:59	0:39	LINE FAULT
37	10-Sep-19	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	0:00	11:10	11:10	LINE FAULT
38	10-Sep-19	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	23:19	23:59	0:40	LINE FAULT
39	10-Sep-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	7:48	11:30	3:42	LINE CLEAR AVAILED
40	10-Sep-19	HASSAN	110	HV1	KARAYA_110	16:46	19:02	2:16	TRANSFORMER FAULT
41	10-Sep-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	1:23	1:31	0:08	LINE FAULT
42	10-Sep-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	2:42	2:47	0:05	LINE FAULT
43	10-Sep-19	HASSAN	66	HV1	SINGAPURA_66	18:46	19:58	1:12	MAIN SUPPLY FAILURE
44	10-Sep-19	HASSAN	66	HV2	SINGAPURA_66	18:46	19:58	1:12	MAIN SUPPLY FAILURE
45	10-Sep-19	MYSORE	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	18:40	18:48	0:08	LINE FAULT
46	10-Sep-19	TUMKUR	66	TR-1	SAMPIGE_110	16:50	17:39	0:49	LINE CLEAR AVAILED
47	10-Sep-19	TUMKUR	66	TR-2	SAMPIGE_110	16:50	17:42	0:51	LINE CLEAR AVAILED
48	10-Sep-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	1:53	2:03	0:10	LINE FAULT
49	10-Sep-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	5:06	5:12	0:06	LINE FAULT
50	10-Sep-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:16	6:27	0:11	LINE FAULT
51	10-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	14:17	14:22	0:04	HAND TRIPPED
52	10-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:48	13:54	0:06	HAND TRIPPED
53	10-Sep-19	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	1:35	3:01	1:26	LINE FAULT
54	10-Sep-19	TUMKUR	66	MADHUGIRI 220kv- SIRA	GULIGENAHALLI_66,SIRA_66	23:21	23:32	0:11	LINE FAULT
55	10-Sep-19	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	5:57	6:09	0:11	LINE FAULT
56	10-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	17:58	18:10	0:11	LINE FAULT
57	10-Sep-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	11:51	12:23	0:31	HAND TRIPPED
58	10-Sep-19	TUMKUR	66	TR-1	SAVALANGA_66	18:08	18:20	0:12	LINE CLEAR AVAILED
59	10-Sep-19	TUMKUR	66	TR-2	THOVINAKERE_66	12:13	13:24	1:10	LINE CLEAR AVAILED
60	11-Sep-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	9:42	10:19	0:37	LINE FAULT
61	11-Sep-19	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	10:32	12:13	1:41	NFBC ISSUED
62	11-Sep-19	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	10:01	17:55	7:54	NFBC ISSUED
63	11-Sep-19	BAGALKOT	110	110/11KV,HV2	BEDI_110	23:30	23:59	0:29	TRANSFORMER FAULT
64	11-Sep-19	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	15:01	16:17	1:16	LINE CLEAR AVAILED
65	11-Sep-19	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KAVALWADA_110	11:33	11:41	0:08	LINE FAULT
66	11-Sep-19	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	11:11	11:54	0:43	LINE CLEAR AVAILED
67	11-Sep-19	BAGALKOT	110	SOVERIGN-TERDAL	TERDAL_110	0:00	14:22	14:22	LINE CLEAR AVAILED
68	11-Sep-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	9:36	12:29	2:53	LINE CLEAR AVAILED
69	11-Sep-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	11:16	13:19	2:03	LINE CLEAR AVAILED
70	11-Sep-19	BAGALKOT	110	SIRSI220-SIRSI 1	SIRSI_110	10:44	13:11	2:27	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
71	11-Sep-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	13:28	14:52	1:24	LINE CLEAR AVAILED
72	11-Sep-19	BAGALKOT	110	MK HUBLI220-MK HUBLI	MK HUBLI_110	11:41	13:07	1:26	LINE CLEAR AVAILED
73	11-Sep-19	BAGALKOT	110	110/11KV,HV4	KERUR	15:33	16:12	0:39	LINE CLEAR AVAILED
74	11-Sep-19	BAGALKOT	110	110/11KV,HV2	KAGAWADA_110	14:57	15:10	0:13	TRANSFORMER FAULT
75	11-Sep-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	15:37	17:39	2:01	LINE FAULT
76	11-Sep-19	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	12:35	12:40	0:04	LINE CLEAR AVAILED
77	11-Sep-19	BENGALURU	66	HV1	RR NAGAR	20:40	21:09	0:29	TRANSFORMER FAULT
78	11-Sep-19	BENGALURU	66	HV2	ATTUR YELAHANKA	12:06	12:10	0:03	LINE CLEAR AVAILED
79	11-Sep-19	BENGALURU	66	ISKON - SUBRAMANYAPURA	ISKON	16:50	16:55	0:05	LOAD CHANGEOVER
80	11-Sep-19	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	SUBRAMANYAPURA 66	15:20	15:52	0:32	LINE FAULT
81	11-Sep-19	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	17:08	17:13	0:05	LOAD CHANGEOVER
82	11-Sep-19	BENGALURU	66	HV1	BAGEPALLI	10:20	11:20	1:00	LINE CLEAR AVAILED
83	11-Sep-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL	9:31	17:58	8:26	LINE CLEAR AVAILED
84	11-Sep-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	11:09	11:28	0:19	LINE CLEAR AVAILED
85	11-Sep-19	BENGALURU	220	KIADB HARDWARE PARK 220 - BEGUR 220	KIADB HARDWARE PARK 220	17:08	17:16	0:08	LINE CLEAR AVAILED
86	11-Sep-19	BENGALURU	220	HV1	KIADB HARDWARE PARK 220	17:08	17:16	0:08	LINE CLEAR AVAILED
87	11-Sep-19	BENGALURU	220	HV2	KIADB HARDWARE PARK 220	17:08	17:16	0:08	LINE CLEAR AVAILED
88	11-Sep-19	BENGALURU	66	HV2	KYALANUR	12:17	12:21	0:03	TRANSFORMER FAULT
89	11-Sep-19	BENGALURU	66	HV2	MANCHENAHALLI	8:30	8:39	0:08	TRANSFORMER FAULT
90	11-Sep-19	BENGALURU	66	VOLVO - HOSKOTE 220	VOLVO	15:32	16:06	0:34	LINE CLEAR AVAILED
91	11-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKALLU	19:44	19:50	0:06	LOAD CHANGEOVER
92	11-Sep-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	SOMENAHALLI, PERESANDRA, MANDIKALLU	10:00	10:07	0:07	LOAD CHANGEOVER
93	11-Sep-19	GULBARGA	400	YTPS-BPS1	YTPS_400	1:59	10:24	8:25	LINE FAULT
94	11-Sep-19	GULBARGA	110	KEMBHAVI-SHAHPUR1	KEMBHAVI_110,ASKI_110, HUNSGI_110, UGARSUGAR_IPP	4:25	4:35	0:10	LINE FAULT
95	11-Sep-19	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	4:25	4:45	0:20	LINE FAULT
96	11-Sep-19	GULBARGA	110	HV2	KEMBHAVI_110	6:59	7:38	0:39	TRANSFORMER FAULT
97	11-Sep-19	GULBARGA	110	SHAHPUR220-YADGIR	YADGIR_110	3:14	3:31	0:17	LINE FAULT
98	11-Sep-19	GULBARGA	66	HV2	CHORNOOR_66	10:54	12:06	1:12	LINE CLEAR AVAILED
99	11-Sep-19	GULBARGA	110	HV2	KEMBHAVI_110	16:20	16:32	0:12	TRANSFORMER FAULT
100	11-Sep-19	GULBARGA	66	LV2	ITTAGI_220	16:15	19:00	2:45	LINE CLEAR AVAILED
101	11-Sep-19	GULBARGA	66	LV1	ITTAGI_220	16:20	16:28	0:08	LINE CLEAR AVAILED
102	11-Sep-19	GULBARGA	66	ITTAGI-KUDILIGI1	KUDILIGI_66,KOGALI_66,HANASI_66	16:50	16:57	0:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
103	11-Sep-19	GULBARGA	66	ITTAGI-HBHALLI	HAGRIBOMMANAHALLI_66,UPANAYAK ANAHALLI_66	16:51	16:56	0:05	LINE FAULT
104	11-Sep-19	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66	16:57	19:00	2:03	LINE FAULT
105	11-Sep-19	GULBARGA	66	ITTAGI-CLNMAX2	ITTAGI_220	17:35	17:40	0:05	LINE FAULT
106	11-Sep-19	GULBARGA	66	ITTAGI-CLNMAX2	ITTAGI_220	17:50	19:10	1:20	LINE FAULT
107	11-Sep-19	GULBARGA	66	ITTAGI-KUDILIGI2	CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANVEKAL_66,CHORNOOR_66	18:24	18:30	0:06	LINE FAULT
108	11-Sep-19	GULBARGA	110	DHADESUGUR-SINDHANOOR	DHADESUGUR_110	20:50	22:53	2:03	LINE FAULT
109	11-Sep-19	GULBARGA	220	HV1	KUSTAGI_220	13:04	13:16	0:12	TRANSFORMER FAULT
110	11-Sep-19	GULBARGA	110	PDHALLI-BASAI	PDHALLI_110	12:38	18:43	6:05	LINE CLEAR AVAILED
111	11-Sep-19	GULBARGA	110	SIDHANOOR-RAICHUR2	VALKAMDINNI_110,ALKOD_110,SIRWAR_110	18:00	18:30	0:30	LINE CLEAR AVAILED
112	11-Sep-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	0:00	11:25	11:25	LINE FAULT
113	11-Sep-19	HASSAN	110	HV1	MRSMSG_220	11:25	11:53	0:28	LINE CLEAR AVAILED
114	11-Sep-19	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	0:00	11:25	11:25	LINE FAULT
115	11-Sep-19	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	10:13	12:12	1:59	MAIN SUPPLY FAILURE
116	11-Sep-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	11:08	14:53	3:45	LINE CLEAR AVAILED
117	11-Sep-19	HASSAN	110	KADUR-AJAMPURA	KADUR_220	10:10	12:15	2:05	LINE CLEAR AVAILED
118	11-Sep-19	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:07	10:13	0:06	HAND TRIPPED
119	11-Sep-19	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	11:00	23:59	12:59	LINE CLEAR AVAILED
120	11-Sep-19	HASSAN	110	HV1	KUNDAPURA_110	10:04	14:07	4:03	LINE CLEAR AVAILED
121	11-Sep-19	HASSAN	110	HV2	SORABA_110	15:40	16:27	0:47	LINE CLEAR AVAILED
122	11-Sep-19	MYSORE	66	HV1	BOGADHI_66	17:59	18:15	0:16	LINE CLEAR AVAILED
123	11-Sep-19	MYSORE	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66, HONNALLY_MYS_66	18:43	18:59	0:15	LINE FAULT
124	11-Sep-19	MYSORE	66	HV1	FTS_66	10:57	12:48	1:50	LINE CLEAR AVAILED
125	11-Sep-19	MYSORE	66	HV1	HONNALLY_MYS_66	11:59	13:37	1:38	LINE CLEAR AVAILED
126	11-Sep-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66	10:00	17:22	7:21	NFBC ISSUED
127	11-Sep-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66, GAVADAGERE_66	8:37	18:06	9:28	LINE CLEAR AVAILED
128	11-Sep-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66, GAVADAGERE_66	18:10	18:13	0:03	HAND TRIPPED
129	11-Sep-19	MYSORE	220	HV3	HOOTAGALLY_220	9:00	12:51	3:50	LINE CLEAR AVAILED
130	11-Sep-19	MYSORE	66	HUNSUR-ELAVALA	ELAVALA_66, GAVADAGERE_66	10:02	18:18	8:16	NFBC ISSUED
131	11-Sep-19	MYSORE	220	HV1	KADAKOLA_220	10:04	12:47	2:43	LINE CLEAR AVAILED
132	11-Sep-19	MYSORE	220	HV2	KADAKOLA_220	12:50	14:21	1:30	LINE CLEAR AVAILED
133	11-Sep-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	6:35	6:40	0:05	LINE FAULT
134	11-Sep-19	MYSORE	66	VIJAYANAGARA-BANNIMANTAP	BANNIMANTAP_66	10:10	17:20	7:10	NFBC ISSUED
135	11-Sep-19	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	MRSMSG_220	11:59	13:42	1:42	LINE CLEAR AVAILED
136	11-Sep-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	16:43	18:59	2:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
137	11-Sep-19	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI_220	12:29	13:31	1:01	LINE CLEAR AVAILED
138	11-Sep-19	TUMKUR	110	TR-1	GUBBI_110	16:21	18:11	1:50	LINE CLEAR AVAILED
139	11-Sep-19	TUMKUR	110	TR-2	MAYASANDRA_110	12:50	14:15	1:24	LINE CLEAR AVAILED
140	11-Sep-19	TUMKUR	66	TR-1	BADAVANAHALLI_66	10:11	10:15	0:04	TRANSFORMER FAULT
141	11-Sep-19	TUMKUR	66	TR-1	CHANNAGIRI_66	10:36	15:21	4:45	LINE CLEAR AVAILED
142	11-Sep-19	TUMKUR	66	TR-2	CHANNAGIRI_66	14:05	15:36	1:30	LINE CLEAR AVAILED
143	11-Sep-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	7:53	7:59	0:06	LINE FAULT
144	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	16:30	16:45	0:14	HAND TRIPPED
145	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	19:04	19:12	0:07	HAND TRIPPED
146	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	16:37	16:45	0:08	LINE FAULT
147	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	18:59	19:12	0:12	HAND TRIPPED
148	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	16:30	16:45	0:15	HAND TRIPPED
149	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	18:59	19:12	0:12	HAND TRIPPED
150	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:30	16:45	0:15	HAND TRIPPED
151	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	18:59	19:12	0:12	HAND TRIPPED
152	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	16:30	16:44	0:14	HAND TRIPPED
153	11-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	18:59	19:12	0:13	HAND TRIPPED
154	11-Sep-19	TUMKUR	66	TR-2	HULIYURDURGA_66	8:53	9:24	0:30	LINE CLEAR AVAILED
155	11-Sep-19	TUMKUR	66	TR-2	KUNIGAL_66	2:19	2:27	0:08	TRANSFORMER FAULT
156	11-Sep-19	TUMKUR	66	TR-1	KUNIGAL_66	16:36	16:43	0:07	TRANSFORMER FAULT
157	11-Sep-19	TUMKUR	66	MADHUGIRI-SIRA-2	KALLAMBELLA_66, BUKKAPATNA_66	12:28	13:32	1:04	LINE CLEAR AVAILED
158	11-Sep-19	TUMKUR	66	TR-2(LV SIDE)	MADHUGIRI_220	12:29	13:32	1:02	LINE CLEAR AVAILED
159	11-Sep-19	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	12:28	13:34	1:06	LINE CLEAR AVAILED
160	11-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	18:13	18:27	0:13	LINE FAULT
161	11-Sep-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	7:53	8:07	0:14	LINE FAULT
162	11-Sep-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	7:53	8:07	0:14	LINE FAULT
163	11-Sep-19	TUMKUR	66	TR-2	THOVINAKERE_66	12:28	12:54	0:26	HAND TRIPPED
164	12-Sep-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	11:37	15:17	3:40	LINE CLEAR AVAILED
165	12-Sep-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	11:37	23:59	12:22	LINE CLEAR AVAILED
166	12-Sep-19	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	8:50	14:03	5:13	NFBC ISSUED
167	12-Sep-19	BAGALKOT	110	110/11KV,HV2	BEDI_110	0:00	14:12	14:12	LINE CLEAR AVAILED
168	12-Sep-19	BAGALKOT	110	BELGAUM220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	17:40	17:45	0:05	LINE FAULT
169	12-Sep-19	BAGALKOT	220	HARTI2-BIDNAL	BIDNAL_220	13:05	23:59	10:54	LINE CLEAR AVAILED
170	12-Sep-19	BAGALKOT	110	BAGEWADI220-MATTIHAL	MATTIHAL_110	16:28	16:33	0:05	LINE CLEAR AVAILED
171	12-Sep-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:10	13:22	1:12	LINE CLEAR AVAILED
172	12-Sep-19	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	6:11	8:40	2:29	TRANSFORMER FAULT
173	12-Sep-19	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	12:15	12:26	0:11	TRANSFORMER FAULT
174	12-Sep-19	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	11:02	12:41	1:39	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
175	12-Sep-19	BAGALKOT	110	NARENDRA-BELUR2	BELUR_110	12:43	13:38	0:55	LINE CLEAR AVAILED
176	12-Sep-19	BAGALKOT	110	110/11KV,HV2	MUNDARGI_110	12:28	13:18	0:50	TRANSFORMER FAULT
177	12-Sep-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	8:45	8:50	0:05	LOAD CHANGEOVER
178	12-Sep-19	BENGALURU	66	BAGEPALLI - SOMANATHAPURA	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	6:08	6:18	0:10	LINE FAULT
179	12-Sep-19	BENGALURU	66	VIDURASHWATHA - GOWRIBIDANUR 220	VIDURASHWATHA	19:15	19:30	0:15	LINE FAULT
180	12-Sep-19	BENGALURU	66	VIDURASHWATHA - BAGEPALLI	PATHPALYA, THIMAMPALLI, SOMANATHAPURA, BAGEPALLI	19:15	19:30	0:15	LINE FAULT
181	12-Sep-19	BENGALURU	66	VIDURASHWATHA - BAGEPALLI	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	10:40	10:50	0:10	LINE FAULT
182	12-Sep-19	BENGALURU	66	VIDURASHWATHA - GOWRIBIDANUR 220	VIDURASHWATHA	10:40	10:50	0:10	LINE FAULT
183	12-Sep-19	BENGALURU	66	HV1	CHAKAVELU	9:08	9:35	0:27	LINE CLEAR AVAILED
184	12-Sep-19	BENGALURU	66	HV2	CHAKAVELU	9:08	9:35	0:27	LINE CLEAR AVAILED
185	12-Sep-19	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE	9:16	17:00	7:43	LINE CLEAR AVAILED
186	12-Sep-19	BENGALURU	66	YENIGADALE - CHELUR	CHELUR, CHAKAVELU	9:10	9:15	0:05	LOAD CHANGEOVER
187	12-Sep-19	BENGALURU	66	YENIGADALE - CHELUR	CHELUR, CHAKAVELU	19:15	19:20	0:05	LOAD CHANGEOVER
188	12-Sep-19	BENGALURU	66	HONNIGANAHALLI - KANAKAPURA 220	HONNIGANAHALLI, HALAGUR	17:15	18:10	0:55	LINE FAULT
189	12-Sep-19	BENGALURU	66	HV1	HONNIGANAHALLI	17:15	18:15	1:00	TRANSFORMER FAULT
190	12-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKALLU	18:00	18:10	0:10	LOAD CHANGEOVER
191	12-Sep-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	SOMENAHALLI, PERESANDRA, MANDIKALLU	9:45	9:50	0:05	LOAD CHANGEOVER
192	12-Sep-19	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	8:10	8:15	0:05	LOAD CHANGEOVER
193	12-Sep-19	BENGALURU	66	ITI - HEBBAL	BANASWADI	16:10	16:35	0:25	LINE FAULT
194	12-Sep-19	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	8:40	8:50	0:10	LOAD CHANGEOVER
195	12-Sep-19	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	22:30	22:40	0:10	LOAD CHANGEOVER
196	12-Sep-19	BENGALURU	66	KHB - SRS PEENYA 220	KHB	9:09	9:10	0:01	LOAD CHANGEOVER
197	12-Sep-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	18:58	19:05	0:07	LOAD CHANGEOVER
198	12-Sep-19	BENGALURU	66	TK HALLI 220 - BWSSB 2 (EHT)	BWSSB 2 (EHT)	17:24	17:55	0:31	LINE FAULT
199	12-Sep-19	BENGALURU	66	HV1	AREHALLI	11:31	12:39	1:07	LINE CLEAR AVAILED
200	12-Sep-19	BENGALURU	66	HV3	YERANDANAHALLI 2200	8:36	9:31	0:54	LOAD CHANGEOVER
201	12-Sep-19	BENGALURU	66	HV1	YERANDANAHALLI 2200	8:23	8:27	0:04	LOAD CHANGEOVER
202	12-Sep-19	BENGALURU	66	HV2	YERANDANAHALLI 2200	8:15	8:22	0:07	LOAD CHANGEOVER
203	12-Sep-19	GULBARGA	400	YTPS-BPS1	YTPS_400	2:53	10:04	7:11	LINE FAULT
204	12-Sep-19	GULBARGA	220	HV2	SHAHPUR_220	13:09	15:47	2:38	LINE CLEAR AVAILED
205	12-Sep-19	GULBARGA	110	HV1	HANUMANAL_110	13:40	14:20	0:40	TRANSFORMER FAULT
206	12-Sep-19	GULBARGA	110	HV2	DHADESUGUR_110	10:00	10:10	0:10	LINE CLEAR AVAILED
207	12-Sep-19	GULBARGA	110	HV2	DHADESUGUR_110	10:59	11:10	0:11	TRANSFORMER FAULT
208	12-Sep-19	GULBARGA	110	HV2	DHADESUGUR_110	14:54	14:59	0:05	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
209	12-Sep-19	GULBARGA	110	JANAWADA-SANTHAPUR	JANAWADA_110	4:27	4:31	0:04	LINE FAULT
210	12-Sep-19	GULBARGA	110	JANAWADA-SANTHAPUR	JANAWADA_110	6:44	6:46	0:02	LINE FAULT
211	12-Sep-19	GULBARGA	110	JANAWADA-SANTHAPUR	JANAWADA_110	14:10	14:15	0:05	LINE FAULT
212	12-Sep-19	GULBARGA	110	HV2	KEMBHAVI_110	5:48	6:10	0:22	TRANSFORMER FAULT
213	12-Sep-19	GULBARGA	110	HV2	KEMBHAVI_110	7:10	8:24	1:14	LINE CLEAR AVAILED
214	12-Sep-19	GULBARGA	110	HV3	KEMBHAVI_110	8:10	14:25	6:15	LINE CLEAR AVAILED
215	12-Sep-19	GULBARGA	110	HV2	KEMBHAVI_110	9:10	13:43	4:33	LINE CLEAR AVAILED
216	12-Sep-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	10:10	12:28	2:18	LINE FAULT
217	12-Sep-19	GULBARGA	110	MADIYAL-KAPNOOR220	MADIYAL_110, NSLSUGARS_IPP, CHOWDAPUR_110	11:10	13:25	2:15	LINE CLEAR AVAILED
218	12-Sep-19	GULBARGA	110	MADIYAL-NSLSUGARS_IPP	NSLSUGARS_IPP	12:10	13:35	1:25	LINE CLEAR AVAILED
219	12-Sep-19	GULBARGA	110	HV2	KUSTAGI_220	6:10	6:17	0:07	LINE CLEAR AVAILED
220	12-Sep-19	GULBARGA	110	HV4	KUSTAGI_220	12:22	13:07	0:45	LINE CLEAR AVAILED
221	12-Sep-19	GULBARGA	110	SIDHANOOR-RAICHUR1	VALKAMDINNI_110,ALKOD_110,SIRWAR_110	23:30	23:45	0:15	LINE FAULT
222	12-Sep-19	GULBARGA	110	SIDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	23:30	23:50	0:20	LINE FAULT
223	12-Sep-19	GULBARGA	110	SIDHANOOR-PGLR_WIND_IPP	SIDHANOOR_220	23:30	23:50	0:20	LINE FAULT
224	12-Sep-19	GULBARGA	110	SIDHANOOR-SINDHANOOR1	MUDDAPUR_110,MASKI_110	23:50	23:51	0:01	LINE FAULT
225	12-Sep-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSLSUGARS_IPP, CHOWDAPUR_110	18:33	18:38	0:05	LINE FAULT
226	12-Sep-19	GULBARGA	110	HV2	DHADESUGUR_110	5:49	6:02	0:13	TRANSFORMER FAULT
227	12-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:25	6:25	LINE CLEAR AVAILED
228	12-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:43	23:59	2:16	LINE CLEAR AVAILED
229	12-Sep-19	HASSAN	220	HV3	KEMAR_220	10:25	10:30	0:05	LINE CLEAR AVAILED
230	12-Sep-19	HASSAN	110	LV3	KEMAR_220	10:25	10:30	0:05	LINE CLEAR AVAILED
231	12-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	14:02	14:58	0:56	HAND TRIPPED
232	12-Sep-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	1:52	15:24	13:32	LINE FAULT
233	12-Sep-19	HASSAN	110	HV3	GURUVAYANAKERE_110	10:16	14:23	4:07	LINE CLEAR AVAILED
234	12-Sep-19	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	4:11	4:30	0:19	LINE FAULT
235	12-Sep-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:43	15:43	3:00	LINE FAULT
236	12-Sep-19	HASSAN	66	HV1	MALLAPURA_66	10:16	17:26	7:10	LINE CLEAR AVAILED
237	12-Sep-19	HASSAN	66	HV2	MALLAPURA_66	10:16	17:26	7:10	LINE CLEAR AVAILED
238	12-Sep-19	HASSAN	66	MALLAPUR-SHIMOGA	MALLAPURA_66	10:16	17:25	7:09	LINE CLEAR AVAILED
239	12-Sep-19	HASSAN	66	MOSALEH-BIOMASS	MOSALEHOSAHALLY_66	12:34	12:40	0:06	LINE CLEAR AVAILED
240	12-Sep-19	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLY_66	12:34	12:40	0:06	LINE CLEAR AVAILED
241	12-Sep-19	HASSAN	66	HV1	MOSALEHOSAHALLY_66	12:34	12:41	0:07	LINE CLEAR AVAILED
242	12-Sep-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	11:36	13:32	1:56	LINE CLEAR AVAILED
243	12-Sep-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	14:45	15:25	0:40	LINE CLEAR AVAILED
244	12-Sep-19	MYSORE	66	HV2	ADDIHALLI_66	12:00	12:20	0:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
245	12-Sep-19	MYSORE	66	HV1	COWDALLI_66	10:44	14:12	3:28	LINE CLEAR AVAILED
246	12-Sep-19	MYSORE	66	HV2	COWDALLI_66	12:40	14:05	1:25	LINE CLEAR AVAILED
247	12-Sep-19	MYSORE	66	DEVNUR(MYS)-RAJEEV NAGARA	RAJEEVNAGARA_66	10:16	15:28	5:11	NFBC ISSUED
248	12-Sep-19	MYSORE	66	FTS-RAJEEV NAGARA	RAJEEVNAGARA_66	10:06	15:35	5:29	NFBC ISSUED
249	12-Sep-19	MYSORE	66	HALAGURU-HONAGANAHALLI	HALAGUR_66	18:01	18:11	0:10	HAND TRIPPED
250	12-Sep-19	MYSORE	66	JYOTHINAGARA-DK MAIDANA	DKMAIDANA_66	10:06	17:38	7:31	NFBC ISSUED
251	12-Sep-19	MYSORE	66	KADAKOLA-DK MAIDANA	DKMAIDANA_66	10:10	17:40	7:29	LINE CLEAR AVAILED
252	12-Sep-19	MYSORE	66	KHB STATION-BILIKERE	DMG_HALLI_66	10:00	17:00	7:00	NFBC ISSUED
253	12-Sep-19	MYSORE	66	KHB STATION-HOOTAGALLY	KHBCOLONY_66	10:00	17:15	7:15	LINE CLEAR AVAILED
254	12-Sep-19	MYSORE	66	HV1	KIRUGAVALU_66	10:46	17:40	6:54	LINE CLEAR AVAILED
255	12-Sep-19	MYSORE	66	HV2	KIRUGAVALU_66	10:46	17:40	6:54	LINE CLEAR AVAILED
256	12-Sep-19	MYSORE	66	HV3	KUSHALANAGARA_66	12:55	13:10	0:14	LINE CLEAR AVAILED
257	12-Sep-19	MYSORE	66	MADHUVANAHALLI-MAMABALLI	MAMBALLI_66, YELANDUR_66	15:01	15:06	0:05	LINE FAULT
258	12-Sep-19	TUMKUR	220	GUTUR 66-DAVANGERE SRS-1	GUTUR_66	15:39	17:28	1:48	LINE CLEAR AVAILED
259	12-Sep-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	17:49	23:47	5:58	LINE CLEAR AVAILED
260	12-Sep-19	TUMKUR	110	TR-1	GUBBI_110	3:12	3:19	0:06	TRANSFORMER FAULT
261	12-Sep-19	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	10:39	11:57	1:18	LINE CLEAR AVAILED
262	12-Sep-19	TUMKUR	66	ANCHEPALYA 220kv- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	14:03	14:25	0:21	LINE FAULT
263	12-Sep-19	TUMKUR	66	TR-1& TR-2	BALENAHALLI_66	10:25	20:32	10:06	LINE CLEAR AVAILED
264	12-Sep-19	TUMKUR	66	TR-1 & TR-2	BELADARA_66	9:30	15:07	5:36	LINE CLEAR AVAILED
265	12-Sep-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	17:19	17:31	0:12	LINE FAULT
266	12-Sep-19	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:52	19:20	0:28	LINE FAULT
267	12-Sep-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	14:39	14:45	0:05	HAND TRIPPED
268	12-Sep-19	TUMKUR	66	TR-1	DYAVARANAHALLI_66	14:39	15:23	0:43	HAND TRIPPED
269	12-Sep-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	14:23	14:30	0:07	LINE FAULT
270	12-Sep-19	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	17:19	17:40	0:20	LINE FAULT
271	12-Sep-19	TUMKUR	66	HIREGUNTANUR- SIRIGERE	SIRIGERE_66, BRAHMASAGARA_IPP_66	17:19	17:47	0:28	LINE FAULT
272	12-Sep-19	TUMKUR	66	TR-1	HIRIYUR_66	13:01	13:23	0:21	LINE CLEAR AVAILED
273	12-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	16:06	16:10	0:03	HAND TRIPPED
274	12-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	17:49	18:42	0:53	HAND TRIPPED
275	12-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	18:32	18:40	0:07	HAND TRIPPED
276	12-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	17:48	18:39	0:50	HAND TRIPPED
277	12-Sep-19	TUMKUR	66	TR-2	HOLAVINAHALLY_66	12:31	13:43	1:11	LINE CLEAR AVAILED
278	12-Sep-19	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66	10:41	11:59	1:17	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
279	12-Sep-19	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	10:41	11:59	1:17	LINE CLEAR AVAILED
280	12-Sep-19	TUMKUR	66	TR-2	HULIYURDURGA_66	10:41	13:23	2:41	LINE CLEAR AVAILED
281	12-Sep-19	TUMKUR	66	TR-2	KUKKAWADA_66	16:56	17:28	0:31	TRANSFORMER FAULT
282	12-Sep-19	TUMKUR	66	TR-2	MAVINAKATTE_66	13:12	18:47	5:35	LINE CLEAR AVAILED
283	12-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	12:14	14:08	1:54	LINE CLEAR AVAILED
284	12-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	17:27	18:00	0:32	HAND TRIPPED
285	12-Sep-19	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	16:53	17:54	1:01	LINE CLEAR AVAILED
286	12-Sep-19	TUMKUR	66	TR-1	SAVALANGA_66	16:53	17:56	1:02	LINE CLEAR AVAILED
287	12-Sep-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	14:23	14:33	0:10	LINE FAULT
288	12-Sep-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	14:23	14:33	0:10	LINE FAULT
289	13-Sep-19	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	0:00	15:24	15:24	LINE CLEAR AVAILED
290	13-Sep-19	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	14:06	14:59	0:53	LINE CLEAR AVAILED
291	13-Sep-19	BAGALKOT	110	110/11KV,HV2	DAVALESHWAR_110	10:33	10:45	0:12	HAND TRIPPED
292	13-Sep-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	13:07	14:17	1:10	LINE CLEAR AVAILED
293	13-Sep-19	BAGALKOT	110	110/33KV,HV3	GOKAK_110	14:20	14:42	0:22	LINE CLEAR AVAILED
294	13-Sep-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, ALSANGI_33, DHULAKED_33, NEVARGI_33	8:16	8:21	0:05	TRANSFORMER FAULT
295	13-Sep-19	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	0:14	0:49	0:35	TRANSFORMER FAULT
296	13-Sep-19	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	8:20	9:04	0:44	LINE CLEAR AVAILED
297	13-Sep-19	BAGALKOT	110	SHIRGUPPI-BILAGI	BILAGI_110	6:30	6:33	0:03	LINE FAULT
298	13-Sep-19	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	5:20	6:04	0:44	LINE FAULT
299	13-Sep-19	BAGALKOT	110	110/11KV,HV1	LAKAMANAHALLI_110	10:06	12:36	2:30	LINE CLEAR AVAILED
300	13-Sep-19	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	10:07	16:54	6:47	LINE CLEAR AVAILED
301	13-Sep-19	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,HALLAVAR_33KV	13:08	13:27	0:19	LINE CLEAR AVAILED
302	13-Sep-19	BAGALKOT	110	110/11KV,HV1	KUDUCHI_110	1:30	23:59	22:29	TRANSFORMER FAULT
303	13-Sep-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	8:19	8:38	0:19	LINE FAULT
304	13-Sep-19	BENGALURU	66	KHB - YELAHANKA 220	KHB	6:07	6:15	0:08	LOAD CHANGEOVER
305	13-Sep-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	11:13	11:25	0:11	LOAD CHANGEOVER
306	13-Sep-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	17:01	17:10	0:09	LOAD CHANGEOVER
307	13-Sep-19	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	14:31	14:59	0:27	LINE FAULT
308	13-Sep-19	BENGALURU	66	HV2	NANDINI LAYOUT	9:22	9:25	0:02	LINE CLEAR AVAILED
309	13-Sep-19	BENGALURU	66	HV2	REMCO	11:09	11:26	0:16	LOAD CHANGEOVER
310	13-Sep-19	BENGALURU	66	HV2	REMCO	17:02	17:12	0:10	LOAD CHANGEOVER
311	13-Sep-19	BENGALURU	66	HV1	KUMBALAGODU	14:05	14:10	0:05	LOAD CHANGEOVER
312	13-Sep-19	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	12:48	13:23	0:34	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
313	13-Sep-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	13:19	13:23	0:04	LINE FAULT
314	13-Sep-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:39	17:42	1:02	LINE CLEAR AVAILED
315	13-Sep-19	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	6:10	6:35	0:25	LOAD CHANGEOVER
316	13-Sep-19	BENGALURU	66	HBR LAYOUT - MANYATA TECH PARK 220	HBR LAYOUT	12:55	13:55	1:00	LOAD CHANGEOVER
317	13-Sep-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	SOMENAHALLI, PERESANDRA, MANDIKALLU	9:50	9:58	0:08	LOAD CHANGEOVER
318	13-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKALLU	18:00	18:05	0:05	LOAD CHANGEOVER
319	13-Sep-19	GULBARGA	400	YTPS-BPS1	YTPS_400	2:49	23:59	21:10	LINE FAULT
320	13-Sep-19	GULBARGA	220	HV2	KAPNOOR_220	13:43	19:03	5:20	LINE CLEAR AVAILED
321	13-Sep-19	GULBARGA	110	BETAGERA-KESHAVCEMENT_SLR	BETAGERA_110	5:20	5:27	0:07	LINE FAULT
322	13-Sep-19	GULBARGA	110	HANUMASAGAR-KUSTAGI	HANUMASAGAR_110, HANUMANAL_110, HIREGONNAGAR_110	12:15	12:30	0:15	MAIN SUPPLY FAILURE
323	13-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	15:36	15:43	0:07	TRANSFORMER FAULT
324	13-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR	VICATSAGAR_IPP	1:12	1:25	0:13	LINE FAULT
325	13-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR	VICATSAGAR_IPP	2:14	2:35	0:21	LINE FAULT
326	13-Sep-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:35	19:43	0:08	LINE FAULT
327	13-Sep-19	GULBARGA	66	HV1	CHORNOOR_66	14:13	14:25	0:12	TRANSFORMER FAULT
328	13-Sep-19	GULBARGA	66	HV1	HAMPASAGAR_66	13:28	13:45	0:17	LINE CLEAR AVAILED
329	13-Sep-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	5:22	5:36	0:14	LINE FAULT
330	13-Sep-19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	5:22	5:36	0:14	LINE FAULT
331	13-Sep-19	GULBARGA	66	LV1	ITTAGI_220	5:22	5:55	0:33	TRANSFORMER FAULT
332	13-Sep-19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP, RENEWSOLAR2_IPP	ITTAGI_220	12:09	12:14	0:05	HAND TRIPPED
333	13-Sep-19	GULBARGA	66	ITTAGI-CLEANMAX1_IPP, CLEANMAX2_IPP	ITTAGI_220	14:58	15:03	0:05	LINE FAULT
334	13-Sep-19	GULBARGA	66	ITTAGI-CLEANMAX1_IPP, CLEANMAX2_IPP	ITTAGI_220	15:15	15:33	0:18	LINE FAULT
335	13-Sep-19	GULBARGA	66	ITTAGI-RENEWSOLAR1&2	ITTAGI_220	18:40	23:28	4:48	LINE CLEAR AVAILED
336	13-Sep-19	GULBARGA	66	HV2	HAGRIBOMMANAHALLI_66	11:01	11:20	0:19	LINE CLEAR AVAILED
337	13-Sep-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	20:13	20:23	0:10	LINE FAULT
338	13-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	10:11	10:11	LINE CLEAR AVAILED
339	13-Sep-19	HASSAN	400	UPCLHASSAN1	upcl_gen	21:43	23:59	2:16	LINE CLEAR AVAILED
340	13-Sep-19	HASSAN	220	MRSSHM-VARAHI1	MRSMG_220	9:46	12:35	2:49	LINE CLEAR AVAILED
341	13-Sep-19	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	9:46	12:36	2:50	LINE CLEAR AVAILED
342	13-Sep-19	HASSAN	110	HV2	PUTTUR_110	9:25	12:55	3:30	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
343	13-Sep-19	HASSAN	110	HV3	BANTWAL_110	11:03	11:37	0:34	LINE CLEAR AVAILED
344	13-Sep-19	HASSAN	110	HV2	GANDASI_110	12:39	13:12	0:33	HAND TRIPPED
345	13-Sep-19	HASSAN	110	HV2	GANDASI_110	13:12	13:31	0:19	HAND TRIPPED
346	13-Sep-19	HASSAN	110	HV2	GANDASI_110	14:03	15:09	1:06	LINE CLEAR AVAILED
347	13-Sep-19	HASSAN	110	HV2	GANDASI_110	16:01	16:14	0:13	HAND TRIPPED
348	13-Sep-19	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	0:00	11:02	11:02	LINE CLEAR AVAILED
349	13-Sep-19	HASSAN	66	HV1	BAGUR_66	14:28	17:27	2:59	TRANSFORMER FAULT
350	13-Sep-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	17:45	23:59	6:14	LINE FAULT
351	13-Sep-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:50	19:01	0:11	LINE FAULT
352	13-Sep-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	19:03	19:10	0:07	MAIN SUPPLY FAILURE
353	13-Sep-19	HASSAN	66	HV1	HOLALUR_66	11:31	19:00	7:29	LINE CLEAR AVAILED
354	13-Sep-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	23:49	23:59	0:10	LINE CLEAR AVAILED
355	13-Sep-19	HASSAN	66	SAKALE-IPCL1	SAKLESHAPURA_66	18:30	18:41	0:11	HAND TRIPPED
356	13-Sep-19	HASSAN	66	SAKALE-IIPCL2	SAKLESHAPURA_66	18:30	18:41	0:11	HAND TRIPPED
357	13-Sep-19	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	6:26	10:03	3:37	LINE FAULT
358	13-Sep-19	MYSORE	66	DATAGALLI-RK NAGARA	RKNAGARA_66	10:00	17:52	7:52	LINE CLEAR AVAILED
359	13-Sep-19	MYSORE	66	HV1	DKMAIDANA_66	13:10	13:56	0:45	LINE CLEAR AVAILED
360	13-Sep-19	MYSORE	66	HV2	DKMAIDANA_66	12:02	13:09	1:06	LINE CLEAR AVAILED
361	13-Sep-19	MYSORE	66	HV1	DUNDANAHALLI_66	9:40	17:00	7:20	LINE CLEAR AVAILED
362	13-Sep-19	MYSORE	66	HV2	DUNDANAHALLI_66	9:40	17:03	7:22	LINE CLEAR AVAILED
363	13-Sep-19	MYSORE	66	HV1	ELAVALA_66	8:57	9:10	0:13	TRANSFORMER FAULT
364	13-Sep-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66	11:26	13:19	1:52	LINE CLEAR AVAILED
365	13-Sep-19	MYSORE	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66	9:21	17:35	8:14	LINE CLEAR AVAILED
366	13-Sep-19	MYSORE	66	HOOTAGALLI-VIJAYANAGARA	VIJAYANAGRAMYS_66	12:30	16:50	4:20	NFBC ISSUED
367	13-Sep-19	MYSORE	66	HV1	KOPPA_66	15:09	15:31	0:21	HAND TRIPPED
368	13-Sep-19	MYSORE	66	HV2	KOPPA_66	15:01	15:03	0:02	HAND TRIPPED
369	13-Sep-19	MYSORE	66	KR NAGARA-MYSORE 1	MIRLE_66	7:26	7:36	0:10	LINE FAULT
370	13-Sep-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66	7:26	7:35	0:08	LINE FAULT
371	13-Sep-19	MYSORE	66	HV4	KUSHALNAGARA_220	10:22	10:47	0:25	LINE CLEAR AVAILED
372	13-Sep-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66	10:35	12:52	2:17	NFBC ISSUED
373	13-Sep-19	MYSORE	66	HV2	SANTHESARAGUR_66	12:53	13:12	0:18	LINE CLEAR AVAILED
374	13-Sep-19	MYSORE	66	HV1	SFCSHIVA_66	15:44	16:08	0:24	LINE CLEAR AVAILED
375	13-Sep-19	MYSORE	66	HV3	SFCSHIVA_66	17:11	18:37	1:26	LINE CLEAR AVAILED
376	13-Sep-19	MYSORE	66	HV1	VAJAMANGALA_220	10:06	18:15	8:08	LINE CLEAR AVAILED
377	13-Sep-19	MYSORE	66	HV2	VAJAMANGALA_220	10:07	18:16	8:09	LINE CLEAR AVAILED
378	13-Sep-19	TUMKUR	110	TR-1	GUBBI_110	10:17	10:46	0:28	LINE CLEAR AVAILED
379	13-Sep-19	TUMKUR	110	TR-1	GUBBI_110	12:13	12:28	0:15	LINE CLEAR AVAILED
380	13-Sep-19	TUMKUR	110	TR-1	KADABA_110	14:10	15:47	1:37	LINE CLEAR AVAILED
381	13-Sep-19	TUMKUR	110	TR-1	SAMPIGE_110	10:10	10:55	0:45	LINE CLEAR AVAILED
382	13-Sep-19	TUMKUR	110	TR-2	SAMPIGE_110	10:10	10:56	0:45	LINE CLEAR AVAILED
383	13-Sep-19	TUMKUR	66	TR-1	BALENAHALLI_66	12:46	15:21	2:34	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
384	13-Sep-19	TUMKUR	66	TR-2	BALENAHALLI_66	15:21	19:12	3:51	LINE CLEAR AVAILED
385	13-Sep-19	TUMKUR	66	TR-1	CHANNAGIRI_66	10:07	10:15	0:07	TRANSFORMER FAULT
386	13-Sep-19	TUMKUR	66	TR-2	DAVANAGERE_66	15:48	15:52	0:04	TRANSFORMER FAULT
387	13-Sep-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	14:58	15:14	0:15	LINE FAULT
388	13-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	7:23	7:37	0:13	HAND TRIPPED
389	13-Sep-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:29	6:41	0:12	LINE FAULT
390	13-Sep-19	TUMKUR	66	JAVAGONDANAHALLI-HIRIYUR	JAVAGONDANAHALLI_66	11:50	16:59	5:09	LINE CLEAR AVAILED
391	13-Sep-19	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	0:18	2:39	2:20	LINE FAULT
392	13-Sep-19	TUMKUR	66	TR-1	MYLANAHALLI_66	12:44	13:11	0:27	HAND TRIPPED
393	13-Sep-19	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	4:24	4:48	0:23	LINE FAULT
394	13-Sep-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	18:45	18:51	0:05	LINE FAULT
395	13-Sep-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	7:42	8:00	0:18	MAIN SUPPLY FAILURE
396	13-Sep-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	14:24	14:26	0:02	LINE CLEAR AVAILED
397	13-Sep-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	14:20	14:29	0:09	LINE CLEAR AVAILED
398	13-Sep-19	TUMKUR	66	TAVAREKERE (C)- GOPPENAHALLI	TAVAREKERE(C)_66	13:51	14:26	0:35	LINE CLEAR AVAILED
399	14-Sep-19	BAGALKOT	110	AINAPUR-ATHANI SUGARS	ATHANI_110	4:41	4:58	0:17	LINE FAULT
400	14-Sep-19	BAGALKOT	110	SUPA 1&2 -AMBEWADI	AMBEWADI_220	16:14	18:24	2:10	LINE CLEAR AVAILED
401	14-Sep-19	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	0:00	6:29	6:29	LINE CLEAR AVAILED
402	14-Sep-19	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	4:42	5:17	0:35	LINE FAULT
403	14-Sep-19	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	18:52	19:20	0:28	LINE FAULT
404	14-Sep-19	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110,KERUR_33,KARUTI_33	18:50	19:24	0:34	TRANSFORMER FAULT
405	14-Sep-19	BAGALKOT	110	110/11KV,HV1	CHIKKODI_110	18:50	19:15	0:25	TRANSFORMER FAULT
406	14-Sep-19	BAGALKOT	110	GHATAPRABHA220-P G HUNSYAL	P G HUNSYAL_110	1:18	1:30	0:12	LINE FAULT
407	14-Sep-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	10:36	18:50	8:14	LINE CLEAR AVAILED
408	14-Sep-19	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	10:03	12:01	1:58	LINE CLEAR AVAILED
409	14-Sep-19	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	13:33	17:31	3:58	LINE FAULT
410	14-Sep-19	BAGALKOT	110	GAMESH-KULIGOD	KULIGOD_110	1:44	1:46	0:02	HAND TRIPPED
411	14-Sep-19	BAGALKOT	220	GADAG-BAGALKOT1&2	GADAG_220	5:56	23:59	18:03	LINE CLEAR AVAILED
412	14-Sep-19	BAGALKOT	110	PG HUNSHYAL-MUDALAGI	MUDALGI_110	1:18	1:30	0:12	MAIN SUPPLY FAILURE
413	14-Sep-19	BAGALKOT	110	SHIRAGUPI SUGAR-KAGAWAD	KAGAWADA_110	4:51	4:57	0:06	LINE FAULT
414	14-Sep-19	BAGALKOT	110	110/33KV,HV3	MUDHOL_110,RATNA CEMENT_33KV	18:22	18:28	0:06	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
415	14-Sep-19	BENGALURU	66	EPIP 220 - CHANDAPURA	SHAMRAJ TECH PARK, KACHMARANAHALLI, BWSSB (EHT)	14:15	14:20	0:05	LOAD CHANGEOVER
416	14-Sep-19	BENGALURU	66	ABBIGERE - DG 3	ABBIGERE	20:54	21:14	0:20	LINE CLEAR AVAILED
417	14-Sep-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	6:51	7:24	0:33	LINE FAULT
418	14-Sep-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	16:02	16:24	0:21	LINE FAULT
419	14-Sep-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	23:21	23:29	0:08	LOAD CHANGEOVER
420	14-Sep-19	BENGALURU	66	POTTERY ROAD - HBR LAYOUT	POTTERY ROAD	8:23	8:25	0:02	LOAD CHANGEOVER
421	14-Sep-19	BENGALURU	66	POTTERY ROAD - HBR LAYOUT	POTTERY ROAD	17:24	17:27	0:03	LOAD CHANGEOVER
422	14-Sep-19	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	10:28	10:38	0:09	LINE FAULT
423	14-Sep-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	12:50	13:12	0:22	MAIN SUPPLY FAILURE
424	14-Sep-19	BENGALURU	66	HV2	AREHALLI	12:05	12:10	0:04	LINE CLEAR AVAILED
425	14-Sep-19	BENGALURU	66	HV2	CHAKAVELU	7:24	8:01	0:36	LINE CLEAR AVAILED
426	14-Sep-19	BENGALURU	66	CHELUR - CHINTAMANI 220	CHELUR	7:39	7:56	0:16	LINE FAULT
427	14-Sep-19	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	7:39	7:44	0:04	LINE FAULT
428	14-Sep-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL	5:39	6:10	0:30	LOAD CURTAILMENT
429	14-Sep-19	BENGALURU	66	HV2	DODDABELAVANGALA	12:00	12:07	0:06	TRANSFORMER FAULT
430	14-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	5:57	7:06	1:09	LOAD CURTAILMENT
431	14-Sep-19	BENGALURU	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI	7:55	7:56	0:01	LOAD CHANGEOVER
432	14-Sep-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGUNDI, MAASTHI	9:20	9:33	0:12	LINE FAULT
433	14-Sep-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	SOMENAHALLI, PERESANDRA, MANDIKALLU	10:00	10:10	0:10	LOAD CHANGEOVER
434	14-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKALLU	20:23	20:30	0:07	LOAD CHANGEOVER
435	14-Sep-19	BENGALURU	66	YELAHANKA 220 - LINE 4	RAILWAYS (EHT)	12:50	14:02	1:11	LINE FAULT
436	14-Sep-19	BENGALURU	66	YELAHANKA 220 - LINE 4	RAILWAYS (EHT)	18:45	19:54	1:08	LINE FAULT
437	14-Sep-19	BENGALURU	66	SAHAKARINAGARA - DG 4	SAHAKARINAGARA	12:50	13:20	0:29	MAIN SUPPLY FAILURE
438	14-Sep-19	BENGALURU	66	SAHAKARINAGARA - MANYATA TECH PARK 220	SAHAKARINAGARA	16:05	16:10	0:05	LOAD CHANGEOVER
439	14-Sep-19	BENGALURU	66	SAHAKARINAGARA - DG 4	SAHAKARINAGARA	18:45	20:15	1:29	MAIN SUPPLY FAILURE
440	14-Sep-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	5:41	5:46	0:04	LOAD CURTAILMENT
441	14-Sep-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:34	16:41	0:07	LINE FAULT
442	14-Sep-19	GULBARGA	220	HV2	KUSTAGI_220	17:35	18:45	1:10	LINE CLEAR AVAILED
443	14-Sep-19	GULBARGA	220	HV2	SHAHPUR_220	8:45	9:29	0:44	LINE CLEAR AVAILED
444	14-Sep-19	GULBARGA	220	HV1	SHAHPUR_220	9:34	10:23	0:49	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
445	14-Sep-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	20:12	20:14	0:02	LINE FAULT
446	14-Sep-19	GULBARGA	110	HALBURGA-KAMTHANA	KAMTHANA_110	23:15	23:31	0:16	LINE FAULT
447	14-Sep-19	GULBARGA	110	KUSTAGI-LINGASUGUR	KUSTAGI_220	17:28	23:59	6:31	LINE FAULT
448	14-Sep-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	13:55	16:05	2:10	LINE FAULT
449	14-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	15:18	16:57	1:39	TRANSFORMER FAULT
450	14-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	16:48	16:57	0:09	TRANSFORMER FAULT
451	14-Sep-19	GULBARGA	110	KUSTAGI-LINGASUGUR	LINGASUGUR_220	0:00	11:30	11:30	LINE FAULT
452	14-Sep-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110, KADAGANCHI_110	21:04	21:10	0:06	LINE FAULT
453	14-Sep-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	3:23	3:31	0:08	LINE FAULT
454	14-Sep-19	GULBARGA	110	HV1	KUDITINI_110	17:26	17:29	0:03	TRANSFORMER FAULT
455	14-Sep-19	GULBARGA	110	HV1	KUDITINI_110	21:31	21:34	0:03	TRANSFORMER FAULT
456	14-Sep-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110, HATTI_110	3:25	3:42	0:17	LINE FAULT
457	14-Sep-19	GULBARGA	66	KOGALI-ATRSOLAR_IPP	KOGALI_66	14:07	14:18	0:11	HAND TRIPPED
458	14-Sep-19	GULBARGA	66	ITTAGI-RENEWSOLAR1&2	ITTAGI_220	14:54	15:09	0:15	LINE CLEAR AVAILED
459	14-Sep-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:14	13:46	4:32	LINE CLEAR AVAILED
460	14-Sep-19	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	9:14	13:52	4:38	LINE CLEAR AVAILED
461	14-Sep-19	HASSAN	110	HV4	MANIPAL_110	10:14	10:22	0:08	HAND TRIPPED
462	14-Sep-19	HASSAN	110	HV4	MANIPAL_110	11:02	11:08	0:06	HAND TRIPPED
463	14-Sep-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:34	13:45	0:11	LINE FAULT
464	14-Sep-19	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	0:00	2:13	2:13	LINE FAULT
465	14-Sep-19	HASSAN	66	HV1	HOLALUR_66	10:49	11:50	1:01	LINE CLEAR AVAILED
466	14-Sep-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	0:00	2:17	2:17	LINE CLEAR AVAILED
467	14-Sep-19	HASSAN	66	HV2	RAMNATHPURA_66	14:56	15:45	0:49	TRANSFORMER FAULT
468	14-Sep-19	HASSAN	66	HV2	RAMNATHPURA_66	15:53	23:59	8:06	TRANSFORMER FAULT
469	14-Sep-19	HASSAN	66	SAKALE-IIPCL1	SAKLESHAPURA_66	21:26	23:59	2:33	LINE CLEAR AVAILED
470	14-Sep-19	HASSAN	66	SAKALE-IIPCL2	SAKLESHAPURA_66	13:44	14:29	0:45	LINE CLEAR AVAILED
471	14-Sep-19	HASSAN	66	SAKALE-IIPCL2	SAKLESHAPURA_66	21:26	23:59	2:33	LINE CLEAR AVAILED
472	14-Sep-19	HASSAN	66	HV2	SALAGAME_66	5:44	9:07	3:23	TRANSFORMER FAULT
473	14-Sep-19	HASSAN	66	SIGEBAGKDLGRE	SIGEBAGE_66	13:44	13:51	0:07	MAIN SUPPLY FAILURE
474	14-Sep-19	MYSORE	66	HV1	KOPPA_66	14:50	14:53	0:02	HAND TRIPPED
475	14-Sep-19	MYSORE	66	HV2	KOPPA_66	14:50	14:53	0:03	HAND TRIPPED
476	14-Sep-19	MYSORE	66	MANDYA-MC 2	MANDYA_66	13:05	14:45	1:40	LINE CLEAR AVAILED
477	14-Sep-19	MYSORE	66	MANDYA-MC 4	MANDYA_66	13:05	14:45	1:40	LINE CLEAR AVAILED
478	14-Sep-19	MYSORE	66	MANDYA-M2	HADLI_66, KADKOTHANAHALLI_66, MALAVALLI_66	13:05	14:47	1:42	LINE CLEAR AVAILED
479	14-Sep-19	MYSORE	66	HV1	MALAVALLI_66	11:04	15:17	4:13	LINE CLEAR AVAILED
480	14-Sep-19	MYSORE	66	HV2	MALAVALLI_66	11:04	15:18	4:13	LINE CLEAR AVAILED
481	14-Sep-19	MYSORE	66	HV2	SANTHESARAGUR_66	13:25	13:42	0:17	LINE CLEAR AVAILED
482	14-Sep-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	16:18	16:37	0:19	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
483	14-Sep-19	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	16:06	16:19	0:13	LINE CLEAR AVAILED
484	14-Sep-19	TUMKUR	66	TR-2	BENNEHALLI_66	22:00	22:05	0:04	TRANSFORMER FAULT
485	14-Sep-19	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	8:10	8:24	0:14	HAND TRIPPED
486	14-Sep-19	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	13:41	13:51	0:10	HAND TRIPPED
487	14-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	16:32	16:43	0:11	HAND TRIPPED
488	14-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	16:18	16:44	0:25	HAND TRIPPED
489	14-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	16:35	16:50	0:15	HAND TRIPPED
490	14-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:35	16:50	0:15	HAND TRIPPED
491	14-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	14:42	14:50	0:07	LINE FAULT
492	14-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	16:29	16:52	0:23	LINE FAULT
493	14-Sep-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	10:12	10:23	0:11	LINE FAULT
494	14-Sep-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	12:57	13:03	0:05	LINE FAULT
495	14-Sep-19	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	6:06	6:19	0:12	LINE FAULT
496	14-Sep-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	16:56	17:00	0:03	LINE FAULT
497	15-Sep-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI_220	AMBEWADI_220	14:18	14:31	0:13	LINE FAULT
498	15-Sep-19	BAGALKOT	220	BAGEWADI-VIJAYPUR 1	BAGEWASI_220	9:34	11:48	2:14	LINE CLEAR AVAILED
499	15-Sep-19	BAGALKOT	220	BAGEWADI-VIJAYPUR 2	BAGEWADI_220	9:34	12:23	2:49	LINE CLEAR AVAILED
500	15-Sep-19	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	9:50	11:29	1:39	LINE CLEAR AVAILED
501	15-Sep-19	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	9:51	11:43	1:52	LINE CLEAR AVAILED
502	15-Sep-19	BAGALKOT	220	BAGEWADI-FORFIVE 2	BAGEWADI_220	9:58	11:31	1:33	LINE CLEAR AVAILED
503	15-Sep-19	BAGALKOT	220	ADPH2-BAGEWADI	BAGEWADI_220	10:06	11:31	1:25	LINE CLEAR AVAILED
504	15-Sep-19	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	9:59	11:37	1:38	LINE CLEAR AVAILED
505	15-Sep-19	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	10:01	11:32	1:31	LINE CLEAR AVAILED
506	15-Sep-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	10:01	11:32	1:31	LINE CLEAR AVAILED
507	15-Sep-19	BAGALKOT	110	SUZLON-BYADAGI	BYADAGI_110	13:41	16:14	2:33	LINE CLEAR AVAILED
508	15-Sep-19	BAGALKOT	220	BIDNAL-HUBLI2	BIDNAL_220	10:23	18:19	7:56	LINE CLEAR AVAILED
509	15-Sep-19	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	10:42	23:59	13:17	LINE FAULT
510	15-Sep-19	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	16:30	17:12	0:42	LINE FAULT
511	15-Sep-19	BAGALKOT	110	BAGEWADI220-MATTIHAL	MATTIHAL_110	9:23	12:00	2:37	MAIN SUPPLY FAILURE
512	15-Sep-19	BAGALKOT	110	BAGEWADI220-MATTIHAL	MATTIHAL_110	12:50	13:00	0:10	MAIN SUPPLY FAILURE
513	15-Sep-19	BAGALKOT	110	BAGEWADI220-MATTIHAL	MATTIHAL_110	14:34	15:34	1:00	LINE FAULT
514	15-Sep-19	BAGALKOT	110	110/11KV,HV1&HV3	MATTIHAL_110	15:20	15:35	0:15	HAND TRIPPED
515	15-Sep-19	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110	15:20	15:38	0:18	HAND TRIPPED
516	15-Sep-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, ALSANGI_33, DHULAKED_33, NEVARGI_33	8:33	8:38	0:05	TRANSFORMER FAULT
517	15-Sep-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	13:57	18:22	4:25	LINE CLEAR AVAILED
518	15-Sep-19	BAGALKOT	110	SUVARNASOUDA-MACHE	MACHE_110	3:52	3:57	0:05	HAND TRIPPED
519	15-Sep-19	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	16:35	17:29	0:54	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
520	15-Sep-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	3:48	7:23	3:35	LINE CLEAR AVAILED
521	15-Sep-19	BAGALKOT	110	MAMADAPUR-TODALBAGI	TODALBAGI_110	17:17	17:39	0:22	LINE CLEAR AVAILED
522	15-Sep-19	BAGALKOT	110	110/11KV,HV1	KUDUCHI_110	0:00	13:25	13:25	LINE CLEAR AVAILED
523	15-Sep-19	BAGALKOT	110	HUBLI220-KALGATAGI	KALGATAGI_110	7:36	13:20	5:44	MAIN SUPPLY FAILURE
524	15-Sep-19	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,AMENGHAD_33,KAR ADI_33	12:28	12:37	0:09	TRANSFORMER FAULT
525	15-Sep-19	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,AMENGHAD_33,KAR ADI_33	15:07	15:16	0:09	TRANSFORMER FAULT
526	15-Sep-19	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	4:13	4:30	0:16	LOAD CHANGEOVER
527	15-Sep-19	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	9:50	10:00	0:10	LOAD CHANGEOVER
528	15-Sep-19	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	4:14	4:25	0:10	LOAD CHANGEOVER
529	15-Sep-19	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	9:45	10:05	0:20	LOAD CHANGEOVER
530	15-Sep-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	12:30	12:34	0:04	LOAD CHANGEOVER
531	15-Sep-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	4:00	4:23	0:22	LOAD CHANGEOVER
532	15-Sep-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	10:23	10:26	0:03	LOAD CHANGEOVER
533	15-Sep-19	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	10:54	12:08	1:14	LINE CLEAR AVAILED
534	15-Sep-19	BENGALURU	66	HV2	DEVARBISANAHALLI	14:19	16:17	1:58	LINE CLEAR AVAILED
535	15-Sep-19	BENGALURU	66	HV2	KADUGODI	12:26	12:50	0:24	LINE CLEAR AVAILED
536	15-Sep-19	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	1:05	1:10	0:05	LOAD CHANGEOVER
537	15-Sep-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	13:40	13:45	0:05	LOAD CHANGEOVER
538	15-Sep-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	9:56	10:01	0:04	LINE FAULT
539	15-Sep-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL	17:23	17:32	0:08	LINE FAULT
540	15-Sep-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	10:31	11:57	1:26	LINE CLEAR AVAILED
541	15-Sep-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:25	10:30	0:05	LOAD CHANGEOVER
542	15-Sep-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	11:40	11:50	0:10	LOAD CHANGEOVER
543	15-Sep-19	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	14:26	15:52	1:26	LINE CLEAR AVAILED
544	15-Sep-19	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	14:26	15:51	1:24	LINE CLEAR AVAILED
545	15-Sep-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGUNDI, MAASTHI	10:17	10:23	0:05	LINE FAULT
546	15-Sep-19	BENGALURU	66	YELAHANKA 220 - LINE 4	RAILWAYS (EHT)	6:10	8:52	2:41	LINE FAULT
547	15-Sep-19	BENGALURU	66	SAHAKARINAGARA - MANYATA TECH PARK 220	SAHAKARINAGARA	4:10	4:16	0:06	LOAD CHANGEOVER
548	15-Sep-19	GULBARGA	110	SEDAM-VICATSAGAR	VICATSAGAR_IPP	19:58	20:08	0:10	LINE FAULT
549	15-Sep-19	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	0:00	7:52	7:52	LINE CLEAR AVAILED
550	15-Sep-19	GULBARGA	220	RAICHUR-JURALA2	RAICHURSA_220	13:00	23:59	10:59	LINE FAULT
551	15-Sep-19	GULBARGA	110	SHAHPUR-KHANAPUR	SAIDAPUR_GLB_110,WADAGERA_110, KHANAPUR_GLB_110,SANNATHI_IPP, COREGREENSUGARS_IPP	2:02	2:15	0:13	LINE FAULT
552	15-Sep-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	19:54	20:42	0:48	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
553	15-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	8:56	9:03	0:07	TRANSFORMER FAULT
554	15-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	8:30	8:37	0:07	TRANSFORMER FAULT
555	15-Sep-19	GULBARGA	110	HV3	SHORAPUR_110	13:23	13:32	0:09	TRANSFORMER FAULT
556	15-Sep-19	GULBARGA	110	BHALKI-LADHA	LADHA_110, MGSSK_IPP, BSSK_IPP	18:45	18:59	0:14	LINE FAULT
557	15-Sep-19	HASSAN	110	HV1	BAIKAMPADY_110	10:31	13:12	2:41	LINE CLEAR AVAILED
558	15-Sep-19	HASSAN	110	HV2	BAIKAMPADY_110	10:31	13:22	2:51	LINE CLEAR AVAILED
559	15-Sep-19	HASSAN	110	HV4	BAIKAMPADY_110	10:31	13:19	2:48	LINE CLEAR AVAILED
560	15-Sep-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	12:47	12:59	0:12	LINE CLEAR AVAILED
561	15-Sep-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:45	11:22	0:37	MAIN SUPPLY FAILURE
562	15-Sep-19	HASSAN	110	SAGARA-ALKLA	SAGARA_110	10:39	13:40	3:01	LINE CLEAR AVAILED
563	15-Sep-19	HASSAN	110	SALATHU-BNTWAL	SALATHU_110	10:45	11:00	0:15	LINE FAULT
564	15-Sep-19	HASSAN	66	HV1	BAGUR_66	16:58	18:04	1:06	TRANSFORMER FAULT
565	15-Sep-19	HASSAN	66	HV1	HADAVANAHALLY_66	14:24	16:37	2:13	LINE CLEAR AVAILED
566	15-Sep-19	HASSAN	66	SAKALE-IIPCL1	SAKLESHAPURA_66	0:00	0:11	0:11	LINE CLEAR AVAILED
567	15-Sep-19	HASSAN	66	SAKALE-IIPCL2	SAKLESHAPURA_66	0:00	0:11	0:11	LINE CLEAR AVAILED
568	15-Sep-19	HASSAN	66	HV2	UDAYAPURA_66	17:20	18:28	1:08	TRANSFORMER FAULT
569	15-Sep-19	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	17:20	17:35	0:15	LINE FAULT
570	15-Sep-19	MYSORE	66	HV1	ELAVALA_66	7:51	8:04	0:13	TRANSFORMER FAULT
571	15-Sep-19	MYSORE	66	HV1	ELAVALA_66	9:19	9:24	0:05	TRANSFORMER FAULT
572	15-Sep-19	MYSORE	66	HV1	ELAVALA_66	11:08	11:18	0:10	TRANSFORMER FAULT
573	15-Sep-19	MYSORE	66	HEBBAL-METAGALLY	METAGALLY_66	9:52	15:23	5:31	LINE CLEAR AVAILED
574	15-Sep-19	MYSORE	66	HOOTAGALLI-HEBBAL	HEBBAL_66	10:01	15:15	5:14	NFBC ISSUED
575	15-Sep-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	0:37	0:42	0:04	LINE FAULT
576	15-Sep-19	MYSORE	66	HV2	KMDODDI_66	9:39	9:48	0:09	TRANSFORMER FAULT
577	15-Sep-19	MYSORE	66	KM DODDI-HV2	KMDODDI_66	11:51	12:15	0:24	LINE CLEAR AVAILED
578	15-Sep-19	TUMKUR	110	SAMPIGE- DODDAGUNI	SAMPIGE_110	11:01	11:55	0:53	LINE FAULT
579	15-Sep-19	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	11:20	12:20	0:59	HAND TRIPPED
580	15-Sep-19	TUMKUR	66	CHITRADURGA 220KV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	18:57	19:11	0:13	LINE FAULT
581	15-Sep-19	TUMKUR	66	CHITRADURGA 66KV- PANDARAHALLI 2	PANDARAHALLI_66	18:57	19:11	0:14	LINE FAULT
582	15-Sep-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	0:52	1:40	0:47	HAND TRIPPED
583	15-Sep-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	6:27	6:41	0:14	HAND TRIPPED
584	15-Sep-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	0:52	1:40	0:47	HAND TRIPPED
585	15-Sep-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	16:09	16:24	0:15	TRANSFORMER FAULT
586	15-Sep-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:43	1:43	1:00	LINE FAULT
587	15-Sep-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	0:52	1:40	0:47	HAND TRIPPED
588	15-Sep-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	5:08	5:18	0:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
589	15-Sep-19	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	5:53	5:58	0:05	LINE FAULT
590	15-Sep-19	TUMKUR	66	TR-1(HV SIDE)	NEELAGUNDA_220	11:28	11:36	0:07	TRANSFORMER FAULT
591	16-Sep-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	8:51	11:16	2:25	LINE CLEAR AVAILED
592	16-Sep-19	BAGALKOT	110	DKSS-CHIKKODI220	CHIKKODI_220	10:03	11:31	1:28	LINE CLEAR AVAILED
593	16-Sep-19	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110, RRB1&2_33	14:50	15:10	0:20	TRANSFORMER FAULT
594	16-Sep-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	7:27	7:32	0:05	TRANSFORMER FAULT
595	16-Sep-19	BAGALKOT	110	KADANAKOPPA-KAVALAWAD	KAVALAWAD_110	12:02	17:35	5:33	LINE CLEAR AVAILED
596	16-Sep-19	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	14:16	14:20	0:04	TRANSFORMER FAULT
597	16-Sep-19	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	11:15	12:02	0:47	LINE CLEAR AVAILED
598	16-Sep-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	12:34	17:03	4:29	LINE CLEAR AVAILED
599	16-Sep-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	12:35	17:03	4:28	LINE CLEAR AVAILED
600	16-Sep-19	BAGALKOT	110	110/11KV, HV2	MATTIHAL_110	12:53	13:04	0:11	HAND TRIPPED
601	16-Sep-19	BAGALKOT	110	BAGEWADI-MATTIHAL	MATTIHAL_110	12:49	12:59	0:10	LINE FAULT
602	16-Sep-19	BAGALKOT	110	110/11KV, HV2	KULIGOD_110	11:24	15:11	3:47	LINE CLEAR AVAILED
603	16-Sep-19	BAGALKOT	110	110/11KV, HV1	KULIGOD_110	15:11	16:09	0:58	LINE CLEAR AVAILED
604	16-Sep-19	BAGALKOT	110	110/33KV, HV3	KULIGOD_110, ALLIMATTI_33, TIGADI_33	15:11	16:09	0:58	LINE CLEAR AVAILED
605	16-Sep-19	BAGALKOT	110	SATTISUGARS-PG HUNSHYAL	PG HUNSHYAL_110	11:33	15:06	3:33	LINE CLEAR AVAILED
606	16-Sep-19	BAGALKOT	110	PG HUNSHYAL-MUDALGI (NAGNUR)	NAGNUR_110	14:35	14:51	0:16	HAND TRIPPED
607	16-Sep-19	BENGALURU	66	BAGMANE WORLD TECH PARK - HOODY 1 & 2	BAGMANE WORLD TECH PARK	12:20	13:11	0:51	LINE CLEAR AVAILED
608	16-Sep-19	BENGALURU	66	BAGMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT), BANASWADI	12:06	13:25	1:18	LINE CLEAR AVAILED
609	16-Sep-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:06	16:08	0:02	LINE FAULT
610	16-Sep-19	BENGALURU	66	HV1	KYALANUR	15:08	15:28	0:19	TRANSFORMER FAULT
611	16-Sep-19	BENGALURU	66	HV2	KYALANUR	15:08	15:28	0:19	TRANSFORMER FAULT
612	16-Sep-19	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	15:08	15:26	0:17	LINE FAULT
613	16-Sep-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	SOMENAHALLI, PERESANDRA, MANDIKALLU	9:50	9:54	0:04	LOAD CHANGEOVER
614	16-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKALLU	18:00	18:05	0:05	LOAD CHANGEOVER
615	16-Sep-19	BENGALURU	220	HV2	MITTEMARI 220	19:44	23:59	4:15	TRANSFORMER FAULT
616	16-Sep-19	BENGALURU	66	HV1	SULIBELE	12:16	13:33	1:17	LINE CLEAR AVAILED
617	16-Sep-19	BENGALURU	66	HV2	YEDUMADU	5:50	6:55	1:04	TRANSFORMER FAULT
618	16-Sep-19	BENGALURU	66	HV2	YEDUMADU	10:00	18:09	8:09	LINE CLEAR AVAILED
619	16-Sep-19	BENGALURU	66	YEDUMADU - HANUMANTHANAGARA	YEDUMADU	17:55	18:05	0:10	LINE CLEAR AVAILED
620	16-Sep-19	BENGALURU	66	HV1	GOKULA	9:46	9:50	0:04	LOAD CHANGEOVER
621	16-Sep-19	BENGALURU	66	HV2	GOKULA	11:03	11:08	0:05	LOAD CHANGEOVER
622	16-Sep-19	BENGALURU	66	HV2	GOKULA	12:06	12:08	0:02	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
623	16-Sep-19	BENGALURU	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT)	12:13	13:17	1:03	LINE CLEAR AVAILED
624	16-Sep-19	BENGALURU	66	HOODY 220 - HAL 2	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT)	12:14	13:17	1:03	LINE CLEAR AVAILED
625	16-Sep-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	14:17	17:31	3:14	LINE CLEAR AVAILED
626	16-Sep-19	GULBARGA	110	HV2	BEVOOR_110	12:25	16:55	4:30	LINE CLEAR AVAILED
627	16-Sep-19	GULBARGA	110	HV3	BEVOOR_110	13:38	13:48	0:10	LINE CLEAR AVAILED
628	16-Sep-19	GULBARGA	66	HV1	HAGRIBOMMANAHALLI_66	8:35	10:50	2:15	LINE CLEAR AVAILED
629	16-Sep-19	GULBARGA	66	HV2	HAGRIBOMMANAHALLI_66	9:10	10:50	1:40	LINE CLEAR AVAILED
630	16-Sep-19	GULBARGA	66	HV3	HAGRIBOMMANAHALLI_66	9:10	10:50	1:40	LINE CLEAR AVAILED
631	16-Sep-19	GULBARGA	66	JANAWADA-SANTHAPUR	SANTHAPUR_110	1:01	1:07	0:06	LINE FAULT
632	16-Sep-19	GULBARGA	220	SHAHPUR-SEDAM	SHAHPUR_220	12:48	13:15	0:27	LINE FAULT
633	16-Sep-19	GULBARGA	110	SIDHANOOR-TURVIHAL	TURVIHAL_110	4:35	4:50	0:15	LINE FAULT
634	16-Sep-19	GULBARGA	110	HV3	SHORAPUR_110	13:50	13:58	0:08	TRANSFORMER FAULT
635	16-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	23:22	23:28	0:06	TRANSFORMER FAULT
636	16-Sep-19	GULBARGA	66	MUNIRABAD220-MSDLINE	HANASI_66	18:51	23:59	5:08	LINE FAULT
637	16-Sep-19	GULBARGA	110	STARMETALLIC-MUNIRABAD220	STARMETALLIC_IPP	19:07	19:15	0:08	LINE FAULT
638	16-Sep-19	GULBARGA	110	HALBURGA220-CHIDRI1	KAMTHANA_110, HABSIKOTE_110	1:17	1:27	0:10	LINE FAULT
639	16-Sep-19	GULBARGA	110	HALBURGA220-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	1:04	1:12	0:08	LINE FAULT
640	16-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	9:34	9:34	LINE CLEAR AVAILED
641	16-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:05	23:59	1:54	LINE CLEAR AVAILED
642	16-Sep-19	HASSAN	220	VARAHI1	MRSSHM	9:14	13:46	4:32	LINE CLEAR AVAILED
643	16-Sep-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	7:51	9:11	1:20	LINE FAULT
644	16-Sep-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:13	9:20	0:07	LINE FAULT
645	16-Sep-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	11:34	14:00	2:26	LINE CLEAR AVAILED
646	16-Sep-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	11:34	23:59	12:25	NFBC ISSUED
647	16-Sep-19	HASSAN	110	HV1	PUTTUR_110	9:22	12:58	3:36	LINE CLEAR AVAILED
648	16-Sep-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	11:09	13:01	1:52	NFBC ISSUED
649	16-Sep-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:41	12:52	1:11	LINE CLEAR AVAILED
650	16-Sep-19	HASSAN	66	HV1	HARIHARAPURA_66	12:31	12:59	0:28	MAIN SUPPLY FAILURE
651	16-Sep-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	12:30	12:53	0:23	LINE FAULT
652	16-Sep-19	HASSAN	66	HV2	RAMNATHPURA_66	0:00	15:28	15:28	TRANSFORMER FAULT
653	16-Sep-19	HASSAN	66	HV2	RAMNATHPURA_66	16:27	16:40	0:13	TRANSFORMER FAULT
654	16-Sep-19	HASSAN	66	HV2	RAMNATHPURA_66	16:59	17:14	0:15	TRANSFORMER FAULT
655	16-Sep-19	HASSAN	66	HV1	SAKLESHPURA_66	14:04	14:39	0:35	LINE CLEAR AVAILED
656	16-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	9:34	9:34	LINE CLEAR AVAILED
657	16-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:05	23:59	1:54	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
658	16-Sep-19	HASSAN	220	VARAHI1	MRSSHM	9:14	13:46	4:32	LINE CLEAR AVAILED
659	16-Sep-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	7:51	9:11	1:20	LINE FAULT
660	16-Sep-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:13	9:20	0:07	LINE FAULT
661	16-Sep-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	11:34	14:00	2:26	LINE CLEAR AVAILED
662	16-Sep-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	11:34	23:59	12:25	NFBC ISSUED
663	16-Sep-19	HASSAN	110	HV1	PUTTUR_110	9:22	12:58	3:36	LINE CLEAR AVAILED
664	16-Sep-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	11:09	13:01	1:52	NFBC ISSUED
665	16-Sep-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:41	12:52	1:11	LINE CLEAR AVAILED
666	16-Sep-19	HASSAN	66	HV1	HARIHARAPURA_66	12:31	12:59	0:28	MAIN SUPPLY FAILURE
667	16-Sep-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	12:30	12:53	0:23	LINE FAULT
668	16-Sep-19	HASSAN	66	HV2	RAMNATHPURA_66	0:00	15:28	15:28	TRANSFORMER FAULT
669	16-Sep-19	HASSAN	66	HV2	RAMNATHPURA_66	16:27	16:40	0:13	TRANSFORMER FAULT
670	16-Sep-19	HASSAN	66	HV2	RAMNATHPURA_66	16:59	17:14	0:15	TRANSFORMER FAULT
671	16-Sep-19	HASSAN	66	HV1	SAKLESHPURA_66	14:04	14:39	0:35	LINE CLEAR AVAILED
672	16-Sep-19	MYSORE	66	HV1	ELAVALA_66	13:52	14:00	0:08	TRANSFORMER FAULT
673	16-Sep-19	MYSORE	66	HV1	HUNSUR_66	12:14	14:13	1:59	LINE CLEAR AVAILED
674	16-Sep-19	MYSORE	66	HV2	HUNSUR_66	14:13	15:32	1:18	LINE CLEAR AVAILED
675	16-Sep-19	MYSORE	66	HV2	JAIPUR_66	11:07	11:22	0:15	LINE CLEAR AVAILED
676	16-Sep-19	MYSORE	66	HV1	JAIPUR_66	11:25	13:05	1:40	LINE CLEAR AVAILED
677	16-Sep-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	0:15	0:23	0:07	LINE FAULT
678	16-Sep-19	MYSORE	66	HV1	MALAVALLI_66	10:26	10:31	0:04	TRANSFORMER FAULT
679	16-Sep-19	MYSORE	66	HV2	MALAVALLI_66	10:26	10:31	0:04	TRANSFORMER FAULT
680	16-Sep-19	MYSORE	66	HV1	MYSORESOUTH_66	9:24	16:42	7:18	LINE CLEAR AVAILED
681	16-Sep-19	MYSORE	66	MYSORE SOUTH-HV2	MYSORESOUTH_66	10:37	16:39	6:02	LINE CLEAR AVAILED
682	16-Sep-19	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	10:10	12:23	2:12	LINE CLEAR AVAILED
683	16-Sep-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	10:42	13:37	2:55	LINE CLEAR AVAILED
684	16-Sep-19	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	10:10	12:24	2:14	LINE CLEAR AVAILED
685	16-Sep-19	TUMKUR	66	TR-2	BEVINAHALLI_66	12:08	12:22	0:13	TRANSFORMER FAULT
686	16-Sep-19	TUMKUR	66	TR-1	CHANNAGIRI_66	13:40	13:44	0:03	LINE CLEAR AVAILED
687	16-Sep-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	21:02	21:20	0:17	LINE FAULT
688	16-Sep-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	21:01	21:23	0:21	LINE FAULT
689	16-Sep-19	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	6:58	8:58	2:00	MAIN SUPPLY FAILURE
690	16-Sep-19	TUMKUR	66	TR-2	DEVARAHALLI_66	6:58	8:58	2:00	MAIN SUPPLY FAILURE
691	16-Sep-19	TUMKUR	66	HIREGUNTANUR- SIRIGERE	SIRIGERE_66, BRAHMASAGARA_IPP_66	15:35	15:57	0:22	LINE FAULT
692	16-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:35	10:42	0:06	HAND TRIPPED
693	16-Sep-19	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66	9:11	13:20	4:08	LINE CLEAR AVAILED
694	16-Sep-19	TUMKUR	66	TR-1	KORA_66	11:46	14:13	2:26	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
695	16-Sep-19	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	22:57	23:08	0:10	LINE FAULT
696	16-Sep-19	TUMKUR	66	TR-2	NITRAHALLI_66	21:35	21:40	0:05	TRANSFORMER FAULT