

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:26.05.2020 TO 01.06.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	26-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	26-May-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE OPEN, LINE CLEAR AVAILED
3	26-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	14:26 (14.05.2020)			LINE OPEN, LINE CLEAR AVAILED
4	26-May-2020	BAGALKOT	110	BIJAPUR220- BIJAPUR CITY	NO STATION EFFECTED BIJAPUR CITY_110	12:50 (16.05.2020)	01:07 (26.05.2020)	12:17hrs	LINE CHARGED
5	26-May-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LINE OPEN, LINE CLEAR AVAILED
6	26-May-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LINE OPEN, LINE CLEAR AVAILED
7	26-May-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LINE OPEN, LINE CLEAR AVAILED
8	26-May-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	16:45 (21.05.2020)	10:12 (26.05.2020)	17:27hrs	LINE CHARGED
9	26-May-2020	BAGALKOT	220	RANEENNUR- BALLIGAVI(SHIRALKOPPA)	NO STATION EFFECTED RANEENNUR_220	8:33 (23.5.2020)	10:58 (26.05.2020)	2:25hrs	LINE CHARGED
10	26-May-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
11	26-May-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)- GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)			LINE OPEN, LINE CLEAR AVAILED
12	26-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	9:39 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
13	26-May-2020	BAGALKOT	110	SUZLON3(1)-DAMBAL	NO STATION EFFECTED DAMBAL_110	22:59 (25.05.2020)	18:10 (26.05.2020)	19:11hrs	LINE CHARGED
14	26-May-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
15	26-May-2020	BAGALKOT	220	RAVI URJA1(KAKAMARI)-ATHANI	ATHANI_220	22:58			LINE OPEN, LINE CLEAR AVAILED
16	26-May-2020	BAGALKOT	220	220/110KV,HV2,LV2	BIJAPUR_220	12:11	13:27	1:16	LINE CLEAR AVAILED
17	26-May-2020	BAGALKOT	110	SUZLON2-DAMBAL	DAMBAL_110	15:24	18:10	2:46	NFBC ISSUED
18	26-May-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	GOPPANAKOPPA_110	17:16 (26.05.2020)			LINE OPEN, LINE CLEAR AVAILED
19	26-May-2020	BAGALKOT	220	DHINI1-GADAG	GADAG_220	0:53	11:40	10:47	LINE FAULT
20	26-May-2020	BAGALKOT	220	DHINI2-GADAG	GADAG_220	8:26	11:41	3:15	LINE CLEAR AVAILED
21	26-May-2020	BAGALKOT	110	INDI-LACHYAN-HIREBEVANUR	HIREBEVANUR_110	20:48	21:17	0:29	LINE FAULT
22	26-May-2020	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	15:33	18:07	2:34	LINE CLEAR AVAILED
23	26-May-2020	BAGALKOT	110	NARENDRA220- MRUTHYUNJAYANAGAR	MRUTHYUNJAYANAGAR_110	10:12	15:50	5:38	LINE CLEAR AVAILED
24	26-May-2020	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	12:03	12:18	0:15	LINE CLEAR AVAILED
25	26-May-2020	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	7:07	7:42	0:35	LINE CLEAR AVAILED
26	26-May-2020	BAGALKOT	220	220/110KV,HV2,LV2	NARENDRA_220	10:20	15:42	5:22	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
27	26-May-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	14:59 (26.05.2020)			LINE OPEN, LINE CLEAR AVAILED
28	26-May-2020	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	10:53 (26.05.2020)			LINE OPEN, LINE CLEAR AVAILED
29	26-May-2020	BAGALKOT	110	RANEENNUR-GUTTAL(AREMALLAPUR)	GUTTAL_110	10:54 (26.05.2020)			LINE OPEN, LINE CLEAR AVAILED
30	26-May-2020	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	14:34	17:40	3:06	LINE FAULT
31	26-May-2020	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	14:34	17:33	2:59	LINE FAULT
32	26-May-2020	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	21:54 (26.05.2020)			LINE OPEN, LINE FAULT
33	26-May-2020	BAGALKOT	110	220/110KV,LV1,LV2	KARWAR_220	15:41	17:51	2:10	MAIN SUPPLY FAILURE
34	26-May-2020	BAGALKOT	110	SOLARIS(BINAGA)-KARWAR	BINAGA_110	15:41	17:05	1:24	MAIN SUPPLY FAILURE
35	26-May-2020	BAGALKOT	110	KARWAR-ARGA	ARGA_110	17:51	17:58	0:07	HAND TRIPPED
36	26-May-2020	BAGALKOT	110	KARWAR-ARGA	ARGA_110	19:42 (26.05.2020)			LINE OPEN, LINE CLEAR AVAILED
37	26-May-2020	BAGALKOT	220	220/110,HV1	SIRSI_220,SIRSI_110,UMMACH AGI, SIDDAPUR_110,CHANDRAGUTTI_110	3:02	3:22	0:20	TRANSFORMER FAULT
38	26-May-2020	BAGALKOT	220	SHARAVATHY 2-SIRSI 220	SIRSI_220	3:02	17:52	14:50	LINE FAULT
39	26-May-2020	BAGALKOT	110	SIRSI220-SIRSI	SIRSI_110	3:02	3:30	0:28	LINE FAULT
40	26-May-2020	BAGALKOT	110	110/11KV,HV2,HV1	SIRSI_110	3:03	3:21	0:18	HAND TRIPPED
41	26-May-2020	BAGALKOT	110	SIRSI-KUMATA 1	SIRSI_110	3:20	8:10	4:50	LINE FAULT
42	26-May-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	19:49	20:27	0:38	MAIN SUPPLY FAILURE
43	26-May-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	19:49	20:32	0:42	MAIN SUPPLY FAILURE
44	26-May-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	19:49	20:10	0:20	MAIN SUPPLY FAILURE
45	26-May-2020	BENGALURU	66	HV1	SARJAPURA 220	19:49	20:30	0:40	MAIN SUPPLY FAILURE
46	26-May-2020	BENGALURU	66	HV2	SARJAPURA 220	19:49	20:30	0:40	MAIN SUPPLY FAILURE
47	26-May-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	21:42	21:44	0:02	LOAD CHANGE OVER
48	26-May-2020	BENGALURU	66	HV1	SARJAPURA 220	21:42	21:44	0:02	LOAD CHANGE OVER
49	26-May-2020	BENGALURU	66	HV2	SARJAPURA 220	21:42	21:44	0:02	LOAD CHANGE OVER
50	26-May-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	21:42	21:46	0:04	LOAD CHANGE OVER
51	26-May-2020	BENGALURU	66	POTTERY ROAD - HEBBAL 220	POTTERY ROAD	22:02	22:06	0:04	LOAD CHANGE OVER
52	26-May-2020	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	18:10	18:50	0:40	LINE FAULT
53	26-May-2020	BENGALURU	66	MANYATHA 220 - HOSKOTE 1	MANYATHA 66	17:39	18:05	0:25	MAIN SUPPLY FAILURE
54	26-May-2020	BENGALURU	66	MANYATHA 220 - HOSKOTE 2	SHOBHA CITY	17:39	18:05	0:25	MAIN SUPPLY FAILURE
55	26-May-2020	BENGALURU	66	MANYATHA 220 - PEENYA 2	SAHAKARINAGAR	17:39	18:05	0:25	MAIN SUPPLY FAILURE
56	26-May-2020	BENGALURU	66	HV1	MANYATHA 220	17:39	18:05	0:25	MAIN SUPPLY FAILURE
57	26-May-2020	BENGALURU	66	HV2	MANYATHA 220	17:39	18:05	0:25	MAIN SUPPLY FAILURE
58	26-May-2020	BENGALURU	66	HV3	MANYATHA 220	17:39	18:05	0:25	MAIN SUPPLY FAILURE
59	26-May-2020	BENGALURU	66	HV4	MANYATHA 220	17:39	18:05	0:25	MAIN SUPPLY FAILURE
60	26-May-2020	BENGALURU	220	HV1	MANYATHA 220	17:39	18:05	0:25	MAIN SUPPLY FAILURE
61	26-May-2020	BENGALURU	220	HV2	MANYATHA 220	17:39	18:05	0:25	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
62	26-May-2020	BENGALURU	220	MALUR 220 - KOLAR 3	SARJAPURA 220, VIKASTECH PARK 220	19:49	21:30	1:41	LINE FAULT
63	26-May-2020	BENGALURU	66	KORMANGALA 220 - ADUGODI 1	NO STATION AFFECTED	18:06	21:25	3:19	LINE FAULT
64	26-May-2020	BENGALURU	66	KORMANGALA 220 - ADUGODI 1	AMARJYOTHI	18:02	19:10	1:07	LINE FAULT
65	26-May-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	19:22	22:37	3:15	MAIN SUPPLY FAILURE
66	26-May-2020	BENGALURU	66	ITI 66 - HOODY 1	ITI 66	17:43	21:53	4:09	LINE FAULT
67	26-May-2020	BENGALURU	66	ITI 66 - HOODY 1	ITI 66	23:10	23:36	0:26	LINE FAULT
68	26-May-2020	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	20:37	21:10	0:32	MAIN SUPPLY FAILURE
69	26-May-2020	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	20:37	22:08	1:30	MAIN SUPPLY FAILURE
70	26-May-2020	BENGALURU	66	ITI 220 - ITI 66	ITI 66	20:37	22:08	1:30	MAIN SUPPLY FAILURE
71	26-May-2020	BENGALURU	66	ITI 220 - BANASWADI	BANASWADI	20:37	22:08	1:30	MAIN SUPPLY FAILURE
72	26-May-2020	BENGALURU	220	HV1	ITI 220	20:37	22:08	1:30	TRANSFORMER FAULT
73	26-May-2020	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	17:39	17:49	0:09	MAIN SUPPLY FAILURE
74	26-May-2020	BENGALURU	66	HEBBAL 220 - C STATION 1 & 2	C STATION	17:39	17:49	0:09	MAIN SUPPLY FAILURE
75	26-May-2020	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	17:39	17:49	0:09	MAIN SUPPLY FAILURE
76	26-May-2020	BENGALURU	66	HEBBAL 220 - IISC	IISC	17:39	17:49	0:09	MAIN SUPPLY FAILURE
77	26-May-2020	BENGALURU	66	AUSTIN TOWN - KORMANGALA	AUSTIN TOWN	15:56	16:06	0:10	LOAD CHANGE OVER
78	26-May-2020	BENGALURU	66	AUSTIN TOWN - EDC 220	AUSTIN TOWN	16:09	16:10	0:01	LOAD CHANGE OVER
79	26-May-2020	BENGALURU	66	CB PURA I/A - CB PURA URBAN	CB PURA URBAN	16:43	16:53	0:10	LINE FAULT
80	26-May-2020	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	17:55	18:45	0:49	LINE FAULT
81	26-May-2020	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	17:55	18:55	0:59	LINE FAULT
82	26-May-2020	BENGALURU	66	HOODY 220 - ITI	ITI	17:43	22:43	4:59	LINE FAULT
83	26-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	17:43	18:28	0:44	LINE FAULT
84	26-May-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	18:56	19:11	0:15	LINE FAULT
85	26-May-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	19:22	19:58	0:36	MAIN SUPPLY FAILURE
86	26-May-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:43	18:47	0:04	LINE FAULT
87	26-May-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	19:22	22:37	3:15	MAIN SUPPLY FAILURE
88	26-May-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	19:22	19:58	0:36	MAIN SUPPLY FAILURE
89	26-May-2020	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	18:11	18:52	0:41	LINE FAULT
90	26-May-2020	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	19:16	19:25	0:09	LINE FAULT
91	26-May-2020	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	13:42	14:11	0:29	LINE CLEAR AVAILED
92	26-May-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	19:16	19:24	0:07	LINE FAULT
93	26-May-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	19:49	20:32	0:42	MAIN SUPPLY FAILURE
94	26-May-2020	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	18:09	18:47	0:38	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
95	26-May-2020	BENGALURU	66	YELAHANKA 220 - LINE4	SAHAKARINAGAR, RAILWAYS (EHT)	17:59	20:08	2:09	LINE FAULT
96	26-May-2020	BENGALURU	220	YELAHANKA 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 220, HEBBAL 220	17:39	19:19	1:39	LINE FAULT
97	26-May-2020	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	0:12	2:33	2:20	LINE FAULT
98	26-May-2020	BENGALURU	66	HV1	HEJJALA	21:15	21:32	0:16	TRANSFORMER FAULT
99	26-May-2020	BENGALURU	66	HV2	HEJJALA	22:59	23:03	0:04	TRANSFORMER FAULT
100	26-May-2020	BENGALURU	66	HV2	IRGAMPALLI	16:31	16:42	0:10	TRANSFORMER FAULT
101	26-May-2020	BENGALURU	66	HV1	RR NAGAR	12:44	13:42	0:58	LINE CLEAR AVAILED
102	26-May-2020	BENGALURU	66	HV2	RR NAGAR	10:57	15:32	4:35	LINE CLEAR AVAILED
103	26-May-2020	BENGALURU	66	HV1	CHANDAPURA	10:04	17:57	7:53	LINE CLEAR AVAILED
104	26-May-2020	BENGALURU	66	HV2	CHANDAPURA	10:04	17:58	7:53	LINE CLEAR AVAILED
105	26-May-2020	BENGALURU	66	HV2	TEMAGONDALU	16:44	19:12	2:27	TRANSFORMER FAULT
106	26-May-2020	BENGALURU	66	HV2	TEMAGONDALU	19:12	19:16	0:04	TRANSFORMER FAULT
107	26-May-2020	BENGALURU	66	HV1	VTG DODDI	19:11	19:44	0:32	LINE CLEAR AVAILED
108	26-May-2020	BENGALURU	66	HV1	YELAHANKA 220	15:26	15:33	0:06	TRANSFORMER FAULT
109	26-May-2020	BENGALURU	220	HV1	VIKAS TECH PARK 220	19:49	22:08	2:18	MAIN SUPPLY FAILURE
110	26-May-2020	BENGALURU	220	HV2	VIKAS TECH PARK 220	19:49	22:08	2:19	MAIN SUPPLY FAILURE
111	26-May-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	19:49	22:08	2:19	MAIN SUPPLY FAILURE
112	26-May-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	19:49	22:08	2:19	MAIN SUPPLY FAILURE
113	26-May-2020	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	19:49	22:08	2:19	MAIN SUPPLY FAILURE
114	26-May-2020	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	18:00 (26-5-2020)			LINE OPEN, LINE FAULT
115	26-May-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
116	26-May-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
117	26-May-2020	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	19:49 (26-5-2020)			LINE OPEN, LINE FAULT
118	26-May-2020	BENGALURU	66	HV1	HEJJALA	21:36 (26-5-2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
119	26-May-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
120	26-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
121	26-May-2020	GULBARGA	220	HV1	KUSTAGI_220	0:00	0:30	0:30	TRANSFORMER FAULT
122	26-May-2020	GULBARGA	110	KUSTAGI-KANAKGIRI	KUSTAGI_220	23:00	23:59	0:59	LINE CLEAR AVAILED
123	26-May-2020	GULBARGA	110	KUSTAGI-KANAKGIRI	KUSTAGI_220	0:00	2:51	2:51	LINE CLEAR AVAILED
124	26-May-2020	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	0:00	1:59	1:59	MAIN SUPPLY FAILURE
125	26-May-2020	GULBARGA	110	HV3	BETAGERA_110	17:10	17:28	0:18	LINE CLEAR AVAILED
126	26-May-2020	GULBARGA	220	RTPS-LINGASUGUR3	MALLAT_220	4:16	5:31	1:15	LINE FAULT
127	26-May-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	16:20	17:00	0:40	LINE FAULT
128	26-May-2020	GULBARGA	110	HV4	YELBURGA_110	1:46	6:48	5:02	TRANSFORMER FAULT
129	26-May-2020	GULBARGA	110	HV3	DEODURGA_110	12:29	14:51	2:22	LINE CLEAR AVAILED
130	26-May-2020	GULBARGA	110	HV3	BEVOOR_110	0:53	1:01	0:08	TRANSFORMER FAULT
131	26-May-2020	GULBARGA	110	PDHALLI-ALIPURA	PDHALLI_110	12:43			MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
132	26-May-2020	GULBARGA	110	RAICHUR-APMC1,2	APMC_110,CHICKSUGUR_110,S HAKTINAGAR_110	20:43	21:46	1:03	LINE FAULT
133	26-May-2020	GULBARGA	110	RAICHUR-SHAHAPUR1,2	GABBUR_110,DEODURGA_110, GOOGLE_110	21:05	21:52	0:47	HAND TRIPPED
134	26-May-2020	GULBARGA	110	RAICHUR-SINDHANOOR1,2	VENKATGIRI_110,GANGAVATHI _110,KARTAGI_110,SRINAGAR_ 110,KAMPLI_110,MUKUNDA_1 10,KEREHALLI_110,MALLAPUR _110	21:05	21:54	0:49	HAND TRIPPED
135	26-May-2020	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	21:05	21:55	0:50	HAND TRIPPED
136	26-May-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_1 10	21:05	21:54	0:49	HAND TRIPPED
137	26-May-2020	GULBARGA	400	YTPS-BTPS2	YTPS_400	20:50(26.5.20)			LINE OPEN, LINE FAULT
138	26-May-2020	GULBARGA	110	HV1	ALIPUR_220	19:01	22:25	3:24	TRANSFORMER FAULT
139	26-May-2020	GULBARGA	110	SHAKTINAGAR-CHICKSUGUR	SHAKTINAGAR_110	20:35	22:01	1:26	MAIN SUPPLY FAILURE
140	26-May-2020	GULBARGA	110	SHAKTINAGAR-RAICHUR BIOMASS	SHAKTINAGAR_110	20:35	22:14	1:39	LINE FAULT
141	26-May-2020	GULBARGA	110	LADHA-RENEWSOLAR	LADHA_110	18:59	22:21	3:22	LINE CLEAR AVAILED
142	26-May-2020	GULBARGA	110	HV3	BETAGERA_110	18:44	18:59	0:15	LINE CLEAR AVAILED
143	26-May-2020	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	0:05	0:15	0:15	TRANSFORMER FAULT
144	26-May-2020	GULBARGA	110	HV2	DEODURGA_110	20:13	20:32	0:19	TRANSFORMER FAULT
145	26-May-2020	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	23:56(25.05.2020)	0:05	0:09 hrs	LINE CHARGED
146	26-May-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
147	26-May-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	17:19 (21.05.2020)			LINE OPEN, LINE CLEAR AVAILED
148	26-May-2020	HASSAN	110	JOG-AMBTR2	JOG_110	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
149	26-May-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	19:47(26.05.2020)			LINE OPEN, LINE FAULT
150	26-May-2020	HASSAN	66	HV1	MAGGE_66	19:45 (26.05.2020)			MAIN SUPPLY FAILURE
151	26-May-2020	HASSAN	66	HV2	MAGGE_66	19:45 (26.05.2020)			MAIN SUPPLY FAILURE
152	26-May-2020	HASSAN	66	SAKALE-HASSAN	SAKLESHPUA_66	19:46(26.05.2020)			LINE OPEN, LINE FAULT
153	26-May-2020	HASSAN	220	HV1	ARASIKERE_220	9:41	10:32	0:51	TRANSFORMER FAULT
154	26-May-2020	HASSAN	220	HV1	ARASIKERE_220	12:22	15:02	2:40	LINE CLEAR AVAILED
155	26-May-2020	HASSAN	110	LV1	ARASIKERE_220	9:41	10:25	0:44	MAIN SUPPLY FAILURE
156	26-May-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	2:15	2:24	0:09	LINE FAULT
157	26-May-2020	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	10:57	14:27	3:30	LINE CLEAR AVAILED
158	26-May-2020	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	3:02	18:00	14:58	LINE FAULT
159	26-May-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:57	14:20	3:23	LINE CLEAR AVAILED
160	26-May-2020	HASSAN	110	HV1	HALADY_110	9:46	10:19	0:33	LINE CLEAR AVAILED
161	26-May-2020	HASSAN	110	HV2	GANDASI_110	10:28	15:40	5:12	LINE CLEAR AVAILED
162	26-May-2020	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	7:08	7:20	0:12	HAND TRIPPED
163	26-May-2020	HASSAN	110	HV1	KEMAR_220	10:57	13:05	2:08	LINE CLEAR AVAILED
164	26-May-2020	HASSAN	110	HV2	KEMAR_220	13:28	13:50	0:22	LINE CLEAR AVAILED
165	26-May-2020	HASSAN	110	HV3	MANIPAL_110	10:10	15:56	5:46	LINE CLEAR AVAILED
166	26-May-2020	HASSAN	110	HV4	MANIPAL_110	13:37	15:32	1:55	LINE CLEAR AVAILED
167	26-May-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	7:18	18:14	10:56	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
168	26-May-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	8:41	17:57	9:16	LINE CLEAR AVAILED
169	26-May-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	8:42	18:13	9:31	LINE CLEAR AVAILED
170	26-May-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	8:42	18:13	9:31	LINE CLEAR AVAILED
171	26-May-2020	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	19:36	19:52	0:16	LINE FAULT
172	26-May-2020	HASSAN	66	HASSN22-SKPURA	HASSAN_220	19:46	20:12	0:26	LINE FAULT
173	26-May-2020	HASSAN	66	KANDLI-HASSAN	KANDLI_66	19:47	20:14	0:27	LINE FAULT
174	26-May-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	10:47	13:12	2:25	LINE CLEAR AVAILED
175	26-May-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:31	10:40	0:09	HAND TRIPPED
176	26-May-2020	HASSAN	66	HV1	MAGGE_66	10:50	13:10	2:20	MAIN SUPPLY FAILURE
177	26-May-2020	HASSAN	66	HV2	MAGGE_66	10:50	13:10	2:20	MAIN SUPPLY FAILURE
178	26-May-2020	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	10:49	13:13	2:24	NFBC ISSUED
179	26-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	9:01	18:06	9:05	LINE CLEAR AVAILED
180	26-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	9:01	18:28	9:27	LINE CLEAR AVAILED
181	26-May-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	13:40	14:10	0:30	MAIN SUPPLY FAILURE
182	26-May-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	18:30	19:05	0:35	MAIN SUPPLY FAILURE
183	26-May-2020	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	13:40	14:10	0:30	MAIN SUPPLY FAILURE
184	26-May-2020	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	18:30	19:05	0:35	MAIN SUPPLY FAILURE
185	26-May-2020	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPLU_66	10:30	15:14	4:44	LINE CLEAR AVAILED
186	26-May-2020	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPLU_66	10:30	15:18	4:48	LINE CLEAR AVAILED
187	26-May-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	13:44	14:13	0:29	LINE FAULT
188	26-May-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	18:30	19:05	0:35	LINE FAULT
189	26-May-2020	MYSURU	66	HV2	COWDALLI_66	12:20	12:45	0:25	LINE CLEAR AVAILED
190	26-May-2020	MYSURU	66	CR NAGARA-DR PETE 1	NO STATIONS INTRRRUPTED	11:06	13:33	2:27	LINE CLEAR AVAILED
191	26-May-2020	MYSURU	66	CR NAGARA-DR PETE 2	NO STATIONS INTRRRUPTED	13:35	14:51	1:16	LINE CLEAR AVAILED
192	26-May-2020	MYSURU	66	HEBBANI-SATHEGALA	CHANDALLI_66 KOLLEGALA_66 PARINAMIPURA_66 SATHEGALA_66 THALAKADU_66	18:55	19:12	0:17	LINE FAULT
193	26-May-2020	MYSURU	66	HOOTAGALLY-ELAVALA	NO STATIONS INTRRRUPTED	9:55	13:55	3:59	LOAD CHANGE OVER
194	26-May-2020	MYSURU	66	HOOTAGALLY-HUNSUR	NO STATIONS INTRRRUPTED	9:55	13:55	3:59	LOAD CHANGE OVER
195	26-May-2020	MYSURU	220	HV3	HOOTAGALLY_220	10:00	13:45	3:44	LINE CLEAR AVAILED
196	26-May-2020	MYSURU	66	HV2	JYOTHINAGARA_66	13:44	13:54	0:10	LINE CLEAR AVAILED
197	26-May-2020	MYSURU	66	KADAKOLA-SARAGUR 2	DOORA_66 HULLAHALLI_66 HURA_66	2:00	2:07	0:07	LINE FAULT
198	26-May-2020	MYSURU	66	KADAKOLA-SARAGUR 2	NO STATIONS INTRRRUPTED	5:11	6:02	0:50	LINE FAULT
199	26-May-2020	MYSURU	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66	10:35	10:41	0:05	LINE FAULT
200	26-May-2020	MYSURU	66	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	19:10	19:25	0:15	LINE FAULT
201	26-May-2020	MYSURU	66	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	19:10	19:26	0:15	LINE FAULT
202	26-May-2020	MYSURU	66	KR PETE 220-KR PETE 1	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	3:32	3:47	0:14	LINE FAULT
203	26-May-2020	MYSURU	66	KR PETE 220-KR PETE 2	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	3:32	3:48	0:16	LINE FAULT
204	26-May-2020	MYSURU	66	KRISHNAPURA-ANEGOLA	ANEGOLAL_66	18:50	19:20	0:30	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
205	26-May-2020	MYSURU	66	KUSHALANAGARA 220-BETTADAPURA	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITUR_66 RAVANDUR_66	19:23	19:35	0:12	LINE FAULT
206	26-May-2020	MYSURU	66	MADHUVANAHALLY-KOLLEGALA 1	CHANDALLI_66 KOLLEGALA_66 PARINAMIPURA_66 SATHEGALA_66 THALAKADU_66	18:55	19:03	0:08	LINE FAULT
207	26-May-2020	MYSURU	66	HV1	RAMAPURA_MYS_66	11:07	13:13	2:05	LINE CLEAR AVAILED
208	26-May-2020	MYSURU	66	HV2	RAMAPURA_MYS_66	11:07	13:12	2:05	LINE CLEAR AVAILED
209	26-May-2020	MYSURU	66	HV5	SFCSHIVA_66	10:19	13:19	2:59	LINE CLEAR AVAILED
210	26-May-2020	MYSURU	66	HV1	SINDHUVALLI_66	9:48	17:38	7:50	LINE CLEAR AVAILED
211	26-May-2020	MYSURU	66	HV2	SINDHUVALLI_66	9:48	17:38	7:50	LINE CLEAR AVAILED
212	26-May-2020	MYSURU	220	TUBINAKERE-BASTIPURA	NO STATIONS INTRRUPTED	10:05	13:27	3:22	LINE CLEAR AVAILED
213	26-May-2020	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110	17:20	17:30	0:10	LINE FAULT
214	26-May-2020	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	17:20	17:40	0:19	LINE FAULT
215	26-May-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	10:44	12:28	1:43	LINE FAULT
216	26-May-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	15:44	15:56	0:11	LINE FAULT
217	26-May-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	18:00	18:36	0:36	TRANSFORMER FAULT
218	26-May-2020	TUMKUR	66	ANTHRASANAHALLI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	15:23	18:23	3:00	LINE CLEAR AVAILED
219	26-May-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	11:44	12:28	0:43	LINE CLEAR AVAILED
220	26-May-2020	TUMKUR	66	BELADARA-KORATAGERE	BELADARA_66	15:23	18:38	3:15	LINE FAULT
221	26-May-2020	TUMKUR	66	TR-2	BENNEHALLI_66	16:19	16:39	0:19	TRANSFORMER FAULT
222	26-May-2020	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	15:18	15:36	0:18	LINE FAULT
223	26-May-2020	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	19:24	19:42	0:17	LINE FAULT
224	26-May-2020	TUMKUR	66	TR-1	CHITRADURGA_66	18:50	19:15	0:24	LINE CLEAR AVAILED
225	26-May-2020	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	0:23	3:43	3:20	LINE CLEAR AVAILED
226	26-May-2020	TUMKUR	66	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	19:22	21:41	2:18	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
227	26-May-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
228	26-May-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	16:09	16:16	0:07	LINE FAULT
229	26-May-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	16:09	16:15	0:06	LINE FAULT
230	26-May-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:09	16:15	0:06	LINE FAULT
231	26-May-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	5:59	6:10	0:10	LINE FAULT
232	26-May-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	6:47	6:56	0:08	LINE FAULT
233	26-May-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	21:30	21:44	0:13	TRANSFORMER FAULT
234	26-May-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	15:41	16:50	1:09	LINE CLEAR AVAILED
235	26-May-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:32	13:37	0:04	LINE FAULT
236	26-May-2020	TUMKUR	66	KUNDUR- HONNALI	KUNDUR_66	14:47	14:50	0:03	LINE FAULT
237	26-May-2020	TUMKUR	66	TR-1	LINGDHALLI_66	8:56	9:11	0:14	TRANSFORMER FAULT
238	26-May-2020	TUMKUR	66	TR-2	LINGDHALLI_66	10:33	11:15	0:42	LINE CLEAR AVAILED
239	26-May-2020	TUMKUR	66	PAVAGADA- VENKATAPURA	VENKATAPURA_66	17:35	17:52	0:17	LINE FAULT
240	26-May-2020	TUMKUR	66	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	17:35	17:50	0:15	LINE FAULT
241	26-May-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:33	17:51	10:18	LOAD CHANGE OVER
242	26-May-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	8:05	10:16	2:11	LINE CLEAR AVAILED
243	26-May-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	18:02	18:41	0:38	MAIN SUPPLY FAILURE
244	26-May-2020	TUMKUR	66	TR-1	SAVALANGA_66	10:35	15:18	4:43	LINE CLEAR AVAILED
245	26-May-2020	TUMKUR	66	VENKATAPURA- GOWRIBIDNUR	PALLAGATTE_66,SOKKE_66,	17:35	17:56	0:21	MAIN SUPPLY FAILURE
246	26-May-2020	TUMKUR	66	TR-1	YNHOSKOTE_66	18:49	18:52	0:03	MAIN SUPPLY FAILURE
1	27-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	27-May-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE OPEN, LINE CLEAR AVAILED
3	27-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	14:26 (14.05.2020)			LINE OPEN, LINE CLEAR AVAILED
4	27-May-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LINE OPEN, LINE CLEAR AVAILED
5	27-May-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LINE OPEN, LINE CLEAR AVAILED
6	27-May-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LINE OPEN, LINE CLEAR AVAILED
7	27-May-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
8	27-May-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)- GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)			LINE OPEN, LINE CLEAR AVAILED
9	27-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	9:39 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
10	27-May-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
11	27-May-2020	BAGALKOT	220	RAVI URJA1(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI_220	22:58 (26.05.2020)	19:04 (27.05.2020)	20:06	LINE CHARGED
12	27-May-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	17:16 (26.05.2020)	9:45 (27.05.2020)	16:29	LINE CHARGED
13	27-May-2020	BAGALKOT	220	GUTTUR-RANEENNUR	NO STATION EFFECTED RANEENNUR_220	14:59 (26.05.2020)	10:10 (27.05.2020)	19:11	LINE CHARGED
14	27-May-2020	BAGALKOT	110	RANEENNUR-BYADAGI	NO STATION EFFECTED BYADAGI_110	10:53 (26.05.2020)			LINE OPEN, LINE CLEAR AVAILED
15	27-May-2020	BAGALKOT	110	RANEENNUR-GUTTAL(AREMALLAPUR)	NO STATION EFFECTED GUTTAL_110	10:54 (26.05.2020)	10:30 (27.05.2020)	23:36	LINE CHARGED
16	27-May-2020	BAGALKOT	220	KADRA2-KARWAR	NO STATION EFFECTED KARWAR_220	21:54 (26.05.2020)	19:42 (27.05.2020)	21:48	LINE CHARGED
17	27-May-2020	BAGALKOT	110	KARWAR-ARGA	NO STATION EFFECTED ARGA_110	19:42 (26.05.2020)	14:00 (27.05.2020)	18:18	LINE CHARGED
18	27-May-2020	BAGALKOT	220	RAVI URJA2(KAKAMARI)-ATHANI	ATHANI_220	15:12	19:05	3:53	NFBC ISSUED
19	27-May-2020	BAGALKOT	110	AMBEWADI-(NK2)KAVALWADA	KAVALWADA_110	8:37	8:46	0:09	HAND TRIPPED
20	27-May-2020	BAGALKOT	110	KN SOLAR-ATHARGA	ATHARGA_110	15:55	16:11	0:16	HAND TRIPPED
21	27-May-2020	BAGALKOT	110	KN SOLAR-ATHARGA	ATHARGA_110	16:04	18:33	2:29	LINE FAULT
22	27-May-2020	BAGALKOT	110	ATHARGA-DEVAR HIPPARGI	DEVARGA HIPPARGI_110	15:45	16:05	0:20	HAND TRIPPED
23	27-May-2020	BAGALKOT	110	110/11KV,HV1,HV2	ATHARGA_110	15:45	15:55	0:10	HAND TRIPPED
24	27-May-2020	BAGALKOT	220	FORTUNE FIVE2-BAGEWADI	BAGEWADI_220	9:04	19:38	10:34	LINE CLEAR AVAILED
25	27-May-2020	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND_110	9:44	17:09	7:25	LINE CLEAR AVAILED
26	27-May-2020	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	10:03	13:56	3:53	LINE CLEAR AVAILED
27	27-May-2020	BAGALKOT	110	110/11KV,HV2	DAMBAL_110	10:03	13:56	3:53	LINE CLEAR AVAILED
28	27-May-2020	BAGALKOT	110	110/11KV,HV1	GADAG_110	13:01	13:13	0:12	TRANSFORMER FAULT
29	27-May-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	15:07 (27.05.2020)			LINE OPEN, LINE CLEAR AVAILED
30	27-May-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	15:07	15:55	0:48	LINE CLEAR AVAILED
31	27-May-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	19:10	19:11	0:01	HAND TRIPPED
32	27-May-2020	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110,ALAGAWADI_33	20:18	20:57	0:39	TRANSFORMER FAULT
33	27-May-2020	BAGALKOT	110	INDI-LACHYAN-HIREBEVANUR	HIREBEVANUR_110	17:49	18:07	0:18	LINE FAULT
34	27-May-2020	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,KARADI_33,A MINAGAD_33,MYTRA SOLAR_33	8:49	8:54	0:05	TRANSFORMER FAULT
35	27-May-2020	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	14:17	19:41	5:24	LINE CLEAR AVAILED
36	27-May-2020	BAGALKOT	110	SOLARIS(BINAGA)-KARWAR	BINAGA_110	10:16	14:43	4:27	LINE CLEAR AVAILED
37	27-May-2020	BAGALKOT	110	220/110KV,LV1,LV2	KARWAR_220	14:17	19:44	5:27	LINE CLEAR AVAILED
38	27-May-2020	BAGALKOT	110	NARENDRA-MRUTHYUNJAYANAGAR	MRUTHYUNJAYANAGAR_110	9:45	15:06	5:21	LINE CLEAR AVAILED
39	27-May-2020	BAGALKOT	110	110/11KV,HV2	MUDEBIHAL_110	15:36	16:15	0:39	LINE CLEAR AVAILED
40	27-May-2020	BAGALKOT	220	220/110KV,HV2,LV2	NARENDRA_220	9:49	15:02	5:13	LINE CLEAR AVAILED
41	27-May-2020	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	19:42	19:56	0:14	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
42	27-May-2020	BAGALKOT	220	220/110KV, HV1	SIRSI_220	18:15	18:20	0:05	HAND TRIPPED
43	27-May-2020	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	8:37	8:50	0:13	HAND TRIPPED
44	27-May-2020	BAGALKOT	110	HUBLI220-PH COMPOUND	PH COMPOUND_110	10:58	16:49	5:51	LINE CLEAR AVAILED
45	27-May-2020	BAGALKOT	220	RANEBENNUR-BALLIGAVI(SHIRALKOPPA)	RANEBENNUR_220	10:10	14:40	4:30	LINE CLEAR AVAILED
46	27-May-2020	BAGALKOT	220	GUTTUR-RANEBENNUR	NO STATION EFFECTED RANEBENNUR_220	14:40 (27.05.2020)			LINE OPEN, LINE CLEAR AVAILED
47	27-May-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	19:43	20:19	0:35	LINE FAULT
48	27-May-2020	BENGALURU	66	TUBUGERE - AFTL SOLAR IPP	NO STATION AFFECTED	19:36	19:58	0:22	LINE FAULT
49	27-May-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:20	12:45	0:24	LINE CLEAR AVAILED
50	27-May-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	1:45	2:02	0:17	LINE FAULT
51	27-May-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	21:25	21:47	0:22	LINE FAULT
52	27-May-2020	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	6:17	12:55	6:38	LINE FAULT
53	27-May-2020	BENGALURU	66	JAYADEVA - NIMHANS 220	YAYADEVA	16:14	16:24	0:10	LINE FAULT
54	27-May-2020	BENGALURU	66	HV1	HOSPALYA CIRCLE	12:14	12:25	0:10	TRANSFORMER FAULT
55	27-May-2020	BENGALURU	66	HV2	POTTERY ROAD	13:58	15:33	1:35	LINE CLEAR AVAILED
56	27-May-2020	BENGALURU	66	HV1	POTTERY ROAD	10:05	10:10	0:04	LINE CLEAR AVAILED
57	27-May-2020	BENGALURU	66	ADUGODI - HSR LAYOUT 1 & 2	ADUGODI, BOSCH (EHT)	7:15	7:21	0:06	MAIN SUPPLY FAILURE
58	27-May-2020	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	6:08	6:10	0:02	LOAD CHANGE OVER
59	27-May-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-1	16:03	16:21	0:18	TRANSFORMER FAULT
60	27-May-2020	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	9:30	9:40	0:10	LOAD CHANGE OVER
61	27-May-2020	BENGALURU	66	GOLF LINK - KORAMANGALA	GOLF LINK	16:20	16:25	0:05	LOAD CHANGE OVER
62	27-May-2020	BENGALURU	66	HV1	HAL 220	9:37	12:43	3:06	LINE CLEAR AVAILED
63	27-May-2020	BENGALURU	66	HAL 220 - ADUGODI 2	AMAR JYOTHI	12:54	12:58	0:04	LINE CLEAR AVAILED
64	27-May-2020	BENGALURU	66	HAL 220 - ADUGODI 2	AMAR JYOTHI	13:00	13:08	0:08	LINE CLEAR AVAILED
65	27-May-2020	BENGALURU	66	HAL 220 - ADUGODI 2	AMAR JYOTHI	13:11	13:15	0:04	LINE FAULT
66	27-May-2020	BENGALURU	66	HAL 220 - ADUGODI 2	AMAR JYOTHI	13:19	13:25	0:06	LINE FAULT
67	27-May-2020	BENGALURU	66	HEBBAL 220 - MATHIKERE	NO STATION AFFECTED	15:56	17:10	1:14	LINE FAULT
68	27-May-2020	BENGALURU	66	HV2	HEJJALA	13:10	13:16	0:06	TRANSFORMER FAULT
69	27-May-2020	BENGALURU	66	ITI 220 - BANASAWADI	BANASAWADI	12:50	12:51	0:01	LOAD CHANGE OVER
70	27-May-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	21:05	21:24	0:19	LINE FAULT
71	27-May-2020	BENGALURU	66	HV1	KUMBALAGODU	17:49	17:59	0:10	TRANSFORMER FAULT
72	27-May-2020	BENGALURU	66	HV1	SOLADEVANAHALLI	22:07	22:26	0:19	LINE CLEAR AVAILED
73	27-May-2020	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	17:40	17:50	0:10	LINE FAULT
74	27-May-2020	BENGALURU	66	HV2	CHAKAVELU	19:53	20:04	0:11	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
75	27-May-2020	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	6:25	6:35	0:10	LOAD CHANGE OVER
76	27-May-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	19:44	20:00	0:16	MAIN SUPPLY FAILURE
77	27-May-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	15:47	16:30	0:43	MAIN SUPPLY FAILURE
78	27-May-2020	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 1	NO STATIONS AFFECTED	19:11	19:35	0:24	LINE FAULT
79	27-May-2020	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	15:45	15:55	0:10	MAIN SUPPLY FAILURE
80	27-May-2020	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	19:45	20:00	0:15	MAIN SUPPLY FAILURE
81	27-May-2020	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA, ADUGODI	7:07	7:18	0:11	LINE FAULT
82	27-May-2020	BENGALURU	66	HV2	BAIRKUR	18:05	19:30	1:25	TRANSFORMER FAULT
83	27-May-2020	BENGALURU	66	HV1	BAIRKUR	18:10	19:35	1:25	LINE CLEAR AVAILED
84	27-May-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	21:47 (27-5-2020)			LINE OPEN, LINE FAULT
85	27-May-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
86	27-May-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
87	27-May-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
88	27-May-2020	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	19:49 (26-5-2020)	15:27	19:37	LINE CHARGED
89	27-May-2020	BENGALURU	66	HV1	HEJJALA	21:36 (26-5-2020)	10:53	13:16	LINE CHARGED
90	27-May-2020	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	18:00 (26-5-2020)	11:25	17:25	LINE CHARGED
91	27-May-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
92	27-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
93	27-May-2020	GULBARGA	220	RTPS-SHAHPUR1	SHAHPUR_220	13:41	14:34	0:15	LINE FAULT
94	27-May-2020	GULBARGA	220	RTPS-SHAHPUR2	SHAHPUR_220	14:47	14:52	0:15	LINE FAULT
95	27-May-2020	GULBARGA	110	PDHALLI-ALIPURA	PDHALLI_110	12:43(26.5.2020)			MAIN SUPPLY FAILURE
96	27-May-2020	GULBARGA	110	LADHA-RENEWSOLAR	LADHA_110	19:18	23:27	4:09	LINE CLEAR AVAILED
97	27-May-2020	GULBARGA	400	YTPS-BTPS2	YTPS_400	20:50(26.5.20)			LINE OPEN, LINE FAULT
98	27-May-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
99	27-May-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	17:19 (21.05.2020)			LINE OPEN, LINE CLEAR AVAILED
100	27-May-2020	HASSAN	110	JOG-AMBTR2	STATION NOT AFFECTED	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
101	27-May-2020	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	19:47(26.05.2020)	4:48	9:01hrs	LINE CHARGED
102	27-May-2020	HASSAN	66	HV1	MAGGE_66	19:45 (26.05.2020)	4:55	9:1hrs	LINE CHARGED
103	27-May-2020	HASSAN	66	HV2	MAGGE_66	19:45 (26.05.2020)	4:55	9:1hrs	LINE CHARGED
104	27-May-2020	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	19:46(26.05.2020)	4:53	9:07hrs	LINE CHARGED
105	27-May-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:01	13:30	3:29	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
106	27-May-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:26	14:10	1:44	LINE FAULT
107	27-May-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	12:26	14:10	1:44	LINE FAULT
108	27-May-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:02	13:30	3:28	LINE CLEAR AVAILED
109	27-May-2020	HASSAN	110	MRSSHM-SS2	MRSMSG_220	12:30	16:51	4:21	LINE CLEAR AVAILED
110	27-May-2020	HASSAN	110	ANANDA-SHIMOGA	ANANDPURA_110	12:30	16:52	4:22	LINE CLEAR AVAILED
111	27-May-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	9:59	14:30	4:31	LINE CLEAR AVAILED
112	27-May-2020	HASSAN	110	HV1	KONAJE_110	10:09	12:50	2:41	LINE CLEAR AVAILED
113	27-May-2020	HASSAN	66	HV1	CHIKMAGALUR_66	10:30	14:52	4:22	LINE CLEAR AVAILED
114	27-May-2020	HASSAN	66	HV2	CHIKMAGALUR_66	10:30	14:52	4:22	LINE CLEAR AVAILED
115	27-May-2020	HASSAN	66	CRPATNA2-MATTANAVILE	CRPATNA_220	10:42	15:03	4:21	LINE CLEAR AVAILED
116	27-May-2020	HASSAN	66	CRPATNA2-SBELAGOLA	CRPATNA_220	9:54	15:03	5:09	LINE CLEAR AVAILED
117	27-May-2020	HASSAN	66	HV1	GANGUR_66	18:58	20:11	1:13	TRANSFORMER FAULT
118	27-May-2020	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	10:46	10:55	0:09	LINE FAULT
119	27-May-2020	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	16:31	16:40	0:09	LINE FAULT
120	27-May-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	9:59	14:46	4:47	LINE CLEAR AVAILED
121	27-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:01	17:01	8:00	LINE CLEAR AVAILED
122	27-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:01	17:20	8:19	LINE CLEAR AVAILED
123	27-May-2020	MYSURU	66	DK MAIDANA-KADKOLA	NO STATIONS EFFECTED	12:18 (27.05.2020)			LINE OPEN,LOAD CHANGE OVER
124	27-May-2020	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	13:42 (27.05.2020)			LINE OPEN, LINE CLEAR AVAILED
125	27-May-2020	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	19:07	20:05	0:58	LINE FAULT
126	27-May-2020	MYSURU	220	CR NAGARA-MADHUVANAHALLI 1	NO STATIONS EFFECTED	11:49	16:37	4:48	NFBC ISSUED
127	27-May-2020	MYSURU	220	CR NAGARA-MADHUVANAHALLI 2	NO STATIONS EFFECTED	16:43	17:44	1:00	NFBC ISSUED
128	27-May-2020	MYSURU	66	DUNDANAHALLI-HULIYURDURGA	NO STATIONS EFFECTED	8:35	16:00	7:25	LOAD CHANGE OVER
129	27-May-2020	MYSURU	66	HV1	DUNDANAHALLI_66	7:56	8:06	0:10	MAIN SUPPLY FAILURE
130	27-May-2020	MYSURU	66	HV1	DUNDANAHALLI_66	15:55	16:57	1:02	LINE CLEAR AVAILED
131	27-May-2020	MYSURU	66	HV2	DUNDANAHALLI_66	9:52	16:05	6:13	LINE CLEAR AVAILED
132	27-May-2020	MYSURU	66	HAMPAPURA-BASARALU	KOPPA_66,BASARALU_66, BESAGARAHALLI_66 & DUNDANAHALLI_66	17:53	18:11	0:18	LINE FAULT
133	27-May-2020	MYSURU	66	HD KOTE-TARAKA	NO STATIONS EFFECTED	11:05	17:24	6:19	LINE CLEAR AVAILED
134	27-May-2020	MYSURU	66	HV2	HOOTAGALLY_220	18:59	20:04	1:04	TRANSFORMER FAULT
135	27-May-2020	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	12:19	15:40	3:21	LOAD CHANGE OVER
136	27-May-2020	MYSURU	220	KADAKOLA-HV1	NO STATIONS EFFECTED	14:23	14:29	0:06	LINE CLEAR AVAILED
137	27-May-2020	MYSURU	66	HV2	KOPPA_66	12:08	12:41	0:32	LINE CLEAR AVAILED
138	27-May-2020	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	13:20	13:25	0:05	LINE FAULT
139	27-May-2020	MYSURU	220	MADHUVANAHALLI-HEBBANI-1	NO STATIONS EFFECTED	9:41	10:56	1:15	LINE CLEAR AVAILED
140	27-May-2020	MYSURU	220	MADHUVANAHALLI-HEBBANI-2	NO STATIONS EFFECTED	11:02	14:06	3:04	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
141	27-May-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	KESLAGERE_66, ADDIHALLI_66, HARADANAHALLI_66, BGNAGARA_66, ADICHUNCHANAGIRI_66 & VADERALLI_66	18:24	18:55	0:31	LINE FAULT
142	27-May-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	KESLAGERE_66, ADDIHALLI_66, HARADANAHALLI_66, BGNAGARA_66, ADICHUNCHANAGIRI_66 & VADERALLI_66	19:31	19:34	0:03	LINE FAULT
143	27-May-2020	MYSURU	220	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	18:23	19:06	0:43	LINE FAULT
144	27-May-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE FAULT
145	27-May-2020	TUMKUR	110	BIDARE- NITTUR	BIDARE_110	12:19	12:27	0:08	LINE CLEAR AVAILED
146	27-May-2020	TUMKUR	110	TR-1	MAYASANDRA_110	17:40	20:45	3:04	LINE CLEAR AVAILED
147	27-May-2020	TUMKUR	110	TR-2	MAYASANDRA_110	17:40	20:44	3:03	LINE CLEAR AVAILED
148	27-May-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	16:58	19:03	2:04	LINE CLEAR AVAILED
149	27-May-2020	TUMKUR	110	TR-2	NITTUR_220	6:49	7:20	0:31	LINE CLEAR AVAILED
150	27-May-2020	TUMKUR	110	TR-1	TURUVEKERE_110	18:39	19:16	0:37	TRANSFORMER FAULT
151	27-May-2020	TUMKUR	110	TR-1	TURUVEKERE_110	19:29	20:15	0:46	TRANSFORMER FAULT
152	27-May-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	17:11	17:27	0:15	TRANSFORMER FAULT
153	27-May-2020	TUMKUR	66	TR-2	CHITRADURGA_66	12:44	13:13	0:29	LINE CLEAR AVAILED
154	27-May-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	22:54	23:05	0:10	LINE FAULT
155	27-May-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:46	9:56	0:10	LINE FAULT
156	27-May-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI _66, BASAVAPATNA_66	11:46	11:51	0:05	LINE FAULT
157	27-May-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS- 1	INFOSYS-1	8:34	13:40	5:06	LINE CLEAR AVAILED
158	27-May-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,R AMAGIRI_66	10:04	10:09	0:04	LINE FAULT
159	27-May-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,R AMAGIRI_66	14:53	16:11	1:17	LINE CLEAR AVAILED
160	27-May-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	9:48	10:04	0:15	TRANSFORMER FAULT
161	27-May-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	14:51	16:03	1:11	LINE CLEAR AVAILED
162	27-May-2020	TUMKUR	66	PANDARAHALLI- SPML _WIND _IPP_66	SPML _WIND _IPP_66	9:48	10:04	0:15	LINE FAULT
163	27-May-2020	TUMKUR	66	PANDARAHALLI- SPML _WIND _IPP_66	SPML _WIND _IPP_66	14:54	16:21	1:26	LINE CLEAR AVAILED
164	27-May-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:45	18:06	10:21	LINE CLEAR AVAILED
165	27-May-2020	TUMKUR	66	TR-1	SHYLAPURA_66	15:32	15:41	0:08	TRANSFORMER FAULT
166	27-May-2020	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	6:43	8:41	1:58	LINE CLEAR AVAILED
167	27-May-2020	TUMKUR	66	TR-1	THIMMASANDRA_66	1:05	1:08	0:02	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
168	27-May-2020	TUMKUR	66	VENKATAPURA-PAVAGADA	VENKATAPUR_66	10:48	11:21	0:33	LINE FAULT
169	27-May-2020	TUMKUR	66	TR-1	VENKATAPUR_66	10:47	11:21	0:33	LINE CLEAR AVAILED
170	27-May-2020	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	VENKATAPUR_66	11:21	12:08	0:46	LINE FAULT
171	27-May-2020	TUMKUR	66	TR-1	YEDIYUR_66	7:51	8:42	0:51	TRANSFORMER FAULT
172	27-May-2020	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	13:46	15:00	1:14	LINE CLEAR AVAILED
173	27-May-2020	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	12:51	15:22	2:30	LINE CLEAR AVAILED
174	27-May-2020	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	18:21	18:23	0:02	HAND TRIPPED
175	27-May-2020	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	18:21	18:23	0:01	HAND TRIPPED
176	27-May-2020	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	18:21	18:23	0:01	HAND TRIPPED
177	27-May-2020	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	16:30	18:49	2:18	LINE CLEAR AVAILED
1	28-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	28-May-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE OPEN, LINE CLEAR AVAILED
3	28-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	14:26 (14.05.2020)			LINE OPEN, LINE CLEAR AVAILED
4	28-May-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LINE OPEN, LINE CLEAR AVAILED
5	28-May-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LINE OPEN, LINE CLEAR AVAILED
6	28-May-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LINE OPEN, LINE CLEAR AVAILED
7	28-May-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
8	28-May-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)- GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)			LINE OPEN, LINE CLEAR AVAILED
9	28-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	9:39 (25.05.2020)	10:49 (28.05.2020)	73:10hrs	LINE CHARGED
10	28-May-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
11	28-May-2020	BAGALKOT	110	RANEBENNUR-BYADAGI	NO STATION EFFECTED BYADAGI_110	10:53 (26.05.2020)			LINE OPEN, LINE CLEAR AVAILED
12	28-May-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	15:07 (27.05.2020)			LINE OPEN, LINE CLEAR AVAILED
13	28-May-2020	BAGALKOT	220	GUTTUR-RANEBENNUR	NO STATION EFFECTED RANEBENNUR_220	14:40 (27.05.2020)	6:41 (28.05.2020)	16:01	LINE CHARGED
14	28-May-2020	BAGALKOT	110	SUZLON-BYADAGI	BYADAGI_110	12:48	19:15	6:27	LINE CLEAR AVAILED
15	28-May-2020	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	10:34	16:52	6:18	LOAD CURTAILMENT
16	28-May-2020	BAGALKOT	110	GHATAPRABHA220- MUDALAGI(MANTUR)	MANTUR_110	12:48	14:06	1:18	LINE CLEAR AVAILED
17	28-May-2020	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	10:50	16:10	5:20	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
18	28-May-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	20:14	20:18	0:04	TRANSFORMER FAULT
19	28-May-2020	BAGALKOT	110	JINDAL-HUNGUND	HUNGUND_110	0:59	15:38	14:39	LINE FAULT
20	28-May-2020	BAGALKOT	110	ILKAL1&2-HUNGUND	HUNGUND_110	13:35	13:39	0:04	HAND TRIPPED
21	28-May-2020	BAGALKOT	110	ILKAL1&2-HUNGUND	HUNGUND_110	14:26	14:39	0:13	HAND TRIPPED
22	28-May-2020	BAGALKOT	110	ANANTPUR SOLAR-KONNUR	KONNUR_110	16:10	16:15	0:05	HAND TRIPPED
23	28-May-2020	BAGALKOT	110	110/11KV,HV1	KONNUR_110	10:04	16:05	6:01	LINE CLEAR AVAILED
24	28-May-2020	BAGALKOT	110	110/33KV,HV2	KONNUR_110,ENERCON WIND_33,SUREBAN_33	10:04	17:20	7:16	LINE CLEAR AVAILED
25	28-May-2020	BAGALKOT	110	SIRSI1&2-KUMTA	NO STATION EFFECTED KUMTA_110	10:54 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
26	28-May-2020	BAGALKOT	110	110/11KV,HV1	NANADI_110	9:47	13:53	4:06	LINE CLEAR AVAILED
27	28-May-2020	BAGALKOT	110	110/11KV,HV2	NANADI_110	9:47	17:28	7:41	LINE CLEAR AVAILED
28	28-May-2020	BAGALKOT	110	CHIKKODI-NANADI	NANADI_110	11:52	13:49	1:57	LINE CLEAR AVAILED
29	28-May-2020	BAGALKOT	110	DODDANNAVAR WIND-NANADI	NANADI_110	11:53	17:47	5:54	LINE CLEAR AVAILED
30	28-May-2020	BAGALKOT	110	BPCL-NARGUND	NARGUND_110	16:16	16:28	0:12	LINE CLEAR AVAILED
31	28-May-2020	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	10:02	16:06	6:04	NFBC ISSUED
32	28-May-2020	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	18:40	18:52	0:12	TRANSFORMER FAULT
33	28-May-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	NO STATION EFFECTED RANEENNUR_220	6:41			LOAD CURTAILMENT
34	28-May-2020	BAGALKOT	110	RANEENNUR-AREMALLAPUR(HONNATTI)	AREMALLAPUR_110	14:23	15:09	0:46	LINE CLEAR AVAILED
35	28-May-2020	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	14:33	14:55	0:22	LINE CLEAR AVAILED
36	28-May-2020	BAGALKOT	110	RANEENNUR-GUTTAL	GUTTAL_110	14:23	15:09	0:46	LINE CLEAR AVAILED
37	28-May-2020	BAGALKOT	110	220/110KV,LV2	RANEENNUR_220	14:34	14:45	0:11	HAND TRIPPED
38	28-May-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:04	14:08	2:04	LINE CLEAR AVAILED
39	28-May-2020	BAGALKOT	110	110/33KV,HV2	SAVALAGI_110,KALABILAGI_33, HIREPADASALAGI_33	17:49	18:32	0:43	HAND TRIPPED
40	28-May-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
41	28-May-2020	BAGALKOT	110	110/11KV ,HV1	ZALKI_110	15:04	15:07	19:11	LINE CLEAR AVAILED
42	28-May-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33,DHULK HED_33	15:12	15:15	0:03	HAND TRIPPED
43	28-May-2020	BAGALKOT	110	CHADCHAN-ZALKI	CHADCHAN_110	15:33	15:34	0:01	HAND TRIPPED
44	28-May-2020	BAGALKOT	110	110/11KV,HV1	ZALKI_110	16:22	16:25	23:36	LINE CLEAR AVAILED
45	28-May-2020	BAGALKOT	110	ZALKI-INCHAGERI	INCHAGERI_110	15:43	15:45	0:02	HAND TRIPPED
46	28-May-2020	BAGALKOT	110	110/11KV ,HV1	ZALKI_110	17:10	17:11	0:01	HAND TRIPPED
47	28-May-2020	BENGALURU	66	HV1	AMAR JYOTHI	11:25	11:35	0:10	TRANSFORMER FAULT
48	28-May-2020	BENGALURU	66	HV2	BOODIGERE	12:42	13:53	1:11	LINE CLEAR AVAILED
49	28-May-2020	BENGALURU	66	HV2	CHAKAVELU	7:55	8:00	0:05	LINE CLEAR AVAILED
50	28-May-2020	BENGALURU	66	HV2	DODDABELAVANGALA	11:28	11:48	0:20	TRANSFORMER FAULT
51	28-May-2020	BENGALURU	66	HV1	DOMMASANDRA	13:15	13:54	0:39	LINE CLEAR AVAILED
52	28-May-2020	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	23:15	23:40	0:25	MAIN SUPPLY FAILURE
53	28-May-2020	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	18:15	19:20	1:05	MAIN SUPPLY FAILURE
54	28-May-2020	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	22:50	22:58	0:08	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
55	28-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	12:20	12:25	0:05	LINE FAULT
56	28-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	18:45	19:21	0:36	LINE FAULT
57	28-May-2020	BENGALURU	220	KANAKAPURA 220 - SOMANAHALLI 220	KANAKAPURA 220	19:14	19:30	0:16	MAIN SUPPLY FAILURE
58	28-May-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	19:32	23:28	3:56	LINE FAULT
59	28-May-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	19:35	19:52	0:17	LINE FAULT
60	28-May-2020	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	17:35	18:13	0:38	LINE CLEAR AVAILED
61	28-May-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	17:51	18:15	0:24	LINE FAULT
62	28-May-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	17:13	17:22	0:09	LINE FAULT
63	28-May-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	17:35	18:12	0:37	LINE CLEAR AVAILED
64	28-May-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:35	19:15	1:40	LINE FAULT
65	28-May-2020	BENGALURU	220	HV3	KOLAR 220	17:35	18:08	0:33	TRANSFORMER FAULT
66	28-May-2020	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	17:35	18:11	0:36	LINE CLEAR AVAILED
67	28-May-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	18:10	18:57	0:47	MAIN SUPPLY FAILURE
68	28-May-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	17:41	18:55	1:14	LINE FAULT
69	28-May-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	22:17	23:59	1:42	LINE FAULT
70	28-May-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	12:22	12:25	0:03	LINE CLEAR AVAILED
71	28-May-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	22:17	23:50	1:33	LINE FAULT
72	28-May-2020	BENGALURU	220	MALUR 220 - SOMANAHALLI 1	SARJAPURA 220, VIKAS TECH PARK 220	18:15	19:14	0:59	LINE FAULT
73	28-May-2020	BENGALURU	66	HV2	KYALANUR	19:10	19:15	0:05	TRANSFORMER FAULT
74	28-May-2020	BENGALURU	220	HV2	MALUR 220	22:17	23:50	1:33	TRANSFORMER FAULT
75	28-May-2020	BENGALURU	220	LV2	MALUR 220	22:17	23:53	1:36	TRANSFORMER FAULT
76	28-May-2020	BENGALURU	66	HV2	NANGALI	19:10	19:15	0:05	TRANSFORMER FAULT
77	28-May-2020	BENGALURU	66	HV1	PATH PALYA	15:57	16:09	0:12	LINE CLEAR AVAILED
78	28-May-2020	BENGALURU	66	HV1	RR NAGAR	11:33	13:15	1:41	LINE CLEAR AVAILED
79	28-May-2020	BENGALURU	66	HV1	RR NAGAR	16:28	17:02	0:33	LINE CLEAR AVAILED
80	28-May-2020	BENGALURU	66	HV2	TK HALLI 220	21:49	22:43	0:54	TRANSFORMER FAULT
81	28-May-2020	BENGALURU	66	HV1	VIJAYANAGARA	12:08	12:55	0:47	LINE CLEAR AVAILED
82	28-May-2020	BENGALURU	66	HV2	VIJAYANAGARA	12:56	13:36	0:39	LINE CLEAR AVAILED
83	28-May-2020	BENGALURU	220	HV1	VIKAS TECH PARK 220	18:14	19:30	1:15	MAIN SUPPLY FAILURE
84	28-May-2020	BENGALURU	220	HV2	VIKAS TECH PARK 220	18:14	19:31	1:17	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
85	28-May-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	17:17	17:37	0:19	LINE FAULT
86	28-May-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	17:50	18:20	0:30	LINE FAULT
87	28-May-2020	BENGALURU	66	MAASTHI - ADANI SOLAR (IPP)	NO STATION AFFECTED	17:30	17:53	0:22	LINE FAULT
88	28-May-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:21	12:24	0:02	LINE CLEAR AVAILED
89	28-May-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:16	19:03	0:47	LINE FAULT
90	28-May-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	22:25	23:59	1:34	MAIN SUPPLY FAILURE
91	28-May-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	6:50	6:52	0:02	LOAD CHANGE OVER
92	28-May-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:47	10:49	0:01	LOAD CHANGE OVER
93	28-May-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	18:14	19:17	1:03	MAIN SUPPLY FAILURE
94	28-May-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	18:14	22:12	3:57	MAIN SUPPLY FAILURE
95	28-May-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	18:14	19:15	1:01	MAIN SUPPLY FAILURE
96	28-May-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:18	19:18	1:00	MAIN SUPPLY FAILURE
97	28-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:19	21:28	1:08	LINE FAULT
98	28-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:23	20:59	0:36	LINE FAULT
99	28-May-2020	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	6:27	6:48	0:20	LINE FAULT
100	28-May-2020	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	11:23	12:31	1:07	LINE FAULT
101	28-May-2020	BENGALURU	66	HBR LAYOUT - ITI	HBR LAYOUT	13:20	13:26	0:06	LOAD CHANGE OVER
102	28-May-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	21:47 (27-5-2020)	10:45	12:57hrs	LINE CHARGED
103	28-May-2020	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	22:58 (28-5-2020)			LINE OPEN, LINE FAULT
104	28-May-2020	BENGALURU	66	HV1	KONDASPURA	20:12 (28-5-2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
105	28-May-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
106	28-May-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
107	28-May-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
108	28-May-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
109	28-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
110	28-May-2020	GULBARGA	400	YTPS-BPS2	YTPS_400	20:50(26.5.20)	14:50	41:18hrs	LINE CHARGED
111	28-May-2020	GULBARGA	220	LINGAPUR-GADAG1	LINGAPUR_220	9:31	13:52	4:21	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
112	28-May-2020	GULBARGA	220	HV1	HALBURGA_220	19:40	19:52	0:12	TRANSFORMER FAULT
113	28-May-2020	GULBARGA	220	LV1	HALBURGA_220	19:40	19:52	0:12	TRANSFORMER FAULT
114	28-May-2020	GULBARGA	110	PDHALLI-ALIPURA	PDHALLI_110	12:43(26.5.2020)	18:22	53:39hrs	LINE CHARGED
115	28-May-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
116	28-May-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	17:19 (21.05.2020)			LINE OPEN, LINE CLEAR AVAILED
117	28-May-2020	HASSAN	110	JOG-AMBTR2	STATION NOT AFFECTED	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
118	28-May-2020	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	12:41	14:01	1:20	LINE CLEAR AVAILED
119	28-May-2020	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	11:26	11:36	0:10	LINE FAULT
120	28-May-2020	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	12:42	14:04	1:22	LINE CLEAR AVAILED
121	28-May-2020	HASSAN	110	HV2	BAIKAMPADY_110	10:11	13:50	3:39	TRANSFORMER FAULT
122	28-May-2020	HASSAN	110	HV1	BANTWAL_110	18:07	18:13	0:06	TRANSFORMER FAULT
123	28-May-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	6:23	12:33	6:10	LINE CLEAR AVAILED
124	28-May-2020	HASSAN	110	HV1	GURUVAYANAKERE_110	10:47	14:57	4:10	LINE CLEAR AVAILED
125	28-May-2020	HASSAN	110	HV2	GURUVAYANAKERE_110	12:43	15:51	3:08	LINE CLEAR AVAILED
126	28-May-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	12:40	14:01	1:21	NFBC ISSUED
127	28-May-2020	HASSAN	110	JOG-JLT3	mghe_jog	10:01	12:00	1:59	LINE CLEAR AVAILED
128	28-May-2020	HASSAN	110	HV1	JOG_110	10:56	11:55	0:59	LINE CLEAR AVAILED
129	28-May-2020	HASSAN	110	HV2	JOG_110	10:56	11:56	1:00	LINE CLEAR AVAILED
130	28-May-2020	HASSAN	110	HV2	JOG_110	16:31	17:48	1:17	LINE CLEAR AVAILED
131	28-May-2020	HASSAN	110	JOG110-LPH	JOG_110	10:07	11:57	1:50	LINE CLEAR AVAILED
132	28-May-2020	HASSAN	110	JOG110-MGHE	JOG_110	10:05	12:00	1:55	LINE CLEAR AVAILED
133	28-May-2020	HASSAN	66	HV1	DUDDA_66	12:49	14:08	1:19	LINE CLEAR AVAILED
134	28-May-2020	HASSAN	66	HV1	GANGUR_110	9:27	13:02	3:35	LINE CLEAR AVAILED
135	28-May-2020	HASSAN	66	HV2	MAGGE_66	10:09	11:02	0:53	LINE CLEAR AVAILED
136	28-May-2020	HASSAN	66	HV1	SAKLESH PURA_66	0:36	0:46	0:10	TRANSFORMER FAULT
137	28-May-2020	HASSAN	66	HV1	SAKLESH PURA_66	1:10	1:20	0:10	TRANSFORMER FAULT
138	28-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:01	17:25	8:24	LINE CLEAR AVAILED
139	28-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:01	17:25	8:24	LINE CLEAR AVAILED
140	28-May-2020	MYSURU	66	DK MAIDANA-KADKOLA	NO STATIONS EFFECTED	12:18 (27.05.2020)	7:48	19:30 HRS	LINE CHARGED
141	28-May-2020	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	13:42 (27.05.2020)	14:00	24:18 HRS	LINE CHARGED
142	28-May-2020	MYSURU	66	HV2	BILIKERE_66	11:00	13:49	2:49	LINE CLEAR AVAILED
143	28-May-2020	MYSURU	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	23:59 (28.05.20)			LINE OPEN, LINE FAULT
144	28-May-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	7:48	9:51	2:03	LOAD CHANGE OVER
145	28-May-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN,LOAD CHANGE OVER
146	28-May-2020	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	5:27	5:31	0:03	LINE FAULT
147	28-May-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	5:27	5:31	0:03	LINE FAULT
148	28-May-2020	MYSURU	220	HOOTAGALLI-BASTIPURA 1	NO STATIONS EFFECTED	9:58	12:56	2:58	LINE CLEAR AVAILED
149	28-May-2020	MYSURU	220	HOOTAGALLI-BASTIPURA 2	NO STATIONS EFFECTED	13:03	14:34	1:31	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
150	28-May-2020	MYSURU	66	HOOTAGALLI-DATTAGALLI	NO STATIONS EFFECTED	10:31	14:38	4:06	LOAD CHANGE OVER
151	28-May-2020	MYSURU	66	HOOTAGALLI-HUNSUR	NO STATIONS EFFECTED	5:52	6:04	0:11	LINE FAULT
152	28-May-2020	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	9:46	17:14	7:28	NFBC ISSUED
153	28-May-2020	MYSURU	66	HV1	KIRUGAVALU_66	12:10	12:27	0:16	HAND TRIPPED
154	28-May-2020	MYSURU	66	HV2	KIRUGAVALU_66	11:59	12:05	0:06	HAND TRIPPED
155	28-May-2020	MYSURU	66	KIRUGAVLU-MALIYUR	KIRUGAVALU_66 VADKEPURA_66	14:40	14:47	0:06	LINE FAULT
156	28-May-2020	MYSURU	66	KM DODDI-MANDYA	KIADBMANDYA_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	20:19	21:05	0:46	LINE FAULT
157	28-May-2020	MYSURU	66	HV1	KRNAGARA_66	13:33	14:45	1:12	LINE CLEAR AVAILED
158	28-May-2020	MYSURU	66	HV2	KRNAGARA_66	12:05	13:39	1:34	LINE CLEAR AVAILED
159	28-May-2020	MYSURU	66	MADHUVANAHALLY-KOLLEGALA 1	NO STATIONS EFFECTED	17:31	17:38	0:06	LINE FAULT
160	28-May-2020	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	20:14	20:49	0:35	LINE FAULT
161	28-May-2020	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	21:01	21:04	0:03	HAND TRIPPED
	28-May-2020	MYSURU	66	HV5	SFCSHIVA_66	20:46	21:31	0:45	TRANSFORMER FAULT
	28-May-2020	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	14:40	14:46	0:05	LINE FAULT
	28-May-2020	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	21:46	21:50	0:03	LINE FAULT
	28-May-2020	MYSURU	66	HV1	THANDYA_66	8:35	10:27	1:52	LINE CLEAR AVAILED
	28-May-2020	MYSURU	66	VAJMANGALA-JYOTHINAGARA	NO STATIONS EFFECTED	10:47	17:25	6:38	LINE CLEAR AVAILED
	28-May-2020	MYSURU	66	VAJMANGALA-DEVNUR(MYS)	DEVANOORMYS_66	10:43	17:57	7:14	LINE CLEAR AVAILED
8	28-May-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)	-	-	LINE FAULT
9	28-May-2020	TUMKUR	66	TR-2	KORATAGERE_66	15:52:51(28.05.2020)	-	-	TRANSFORMER FAULT
10	28-May-2020	TUMKUR	220	TR-1(HV SIDE)	HIRIYUR_220	17:26	18:18	0:51	LINE CLEAR AVAILED
11	28-May-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	6:26	7:41	1:15	LINE CLEAR AVAILED
12	28-May-2020	TUMKUR	66	TR-1	KORATAGERE_66	15:53	16:10	0:17	LINE CLEAR AVAILED
13	28-May-2020	TUMKUR	66	ANCHEPALYA 220kv-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	10:20	13:05	2:44	LINE CLEAR AVAILED
14	28-May-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	13:12	17:55	4:43	LINE CLEAR AVAILED
15	28-May-2020	TUMKUR	66	BENKIKERE-NALLUR	BENKIKERE_66	14:02	17:47	3:44	MAIN SUPPLY FAILURE
16	28-May-2020	TUMKUR	66	TR-1	BENKIKERE_66	14:02	17:47	3:44	MAIN SUPPLY FAILURE
17	28-May-2020	TUMKUR	66	TR-2	BENKIKERE_66	14:02	17:47	3:44	MAIN SUPPLY FAILURE
18	28-May-2020	TUMKUR	66	CHANNAGIRI-LINGDHLI	CHANNAGIRI_66	12:15	18:36	6:20	MAIN SUPPLY FAILURE
19	28-May-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	8:58	9:02	0:04	HAND TRIPPED
20	28-May-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:02	14:35	2:33	LINE CLEAR AVAILED
21	28-May-2020	TUMKUR	66	GUTUR 66-DAVANGERE SRS	GUTUR_66	12:04	14:38	2:34	LINE CLEAR AVAILED
22	28-May-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	7:48	10:56	3:08	LINE CLEAR AVAILED
23	28-May-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	18:21	18:33	0:11	HAND TRIPPED
24	28-May-2020	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	0:23	0:43	0:20	MAIN SUPPLY FAILURE
25	28-May-2020	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	17:26	18:19	0:52	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
26	28-May-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	10:36	10:42	0:06	LINE FAULT
27	28-May-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	12:10	17:07	4:56	LINE CLEAR AVAILED
28	28-May-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	12:10	17:07	4:56	LINE CLEAR AVAILED
29	28-May-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	4:45	4:53	0:07	TRANSFORMER FAULT
30	28-May-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:03	12:09	0:06	LINE FAULT
31	28-May-2020	TUMKUR	66	KUNDUR- RSOLAR	RENEW WIND ENERGY_IPP_66	2:12	2:45	0:33	LINE FAULT
32	28-May-2020	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	18:59	19:17	0:18	LINE FAULT
33	28-May-2020	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	6:44	9:16	2:32	LINE CLEAR AVAILED
1	29-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	29-May-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)			LINE OPEN, LINE CLEAR AVAILED
3	29-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	14:26 (14.05.2020)	7:50 (29.05.2020)	353:24hrs	LINE CHARGED
4	29-May-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
5	29-May-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
6	29-May-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
7	29-May-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
8	29-May-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)-GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)			LINE OPEN, LINE CLEAR AVAILED
9	29-May-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
10	29-May-2020	BAGALKOT	110	RANEBENNUR-BYADAGI	NO STATION EFFECTED BYADAGI_110	10:53 (26.05.2020)	20:09 (29.05.2020)	81:16hrs	LINE CHARGED
11	29-May-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	15:07 (27.05.2020)			LINE OPEN, LINE CLEAR AVAILED
12	29-May-2020	BAGALKOT	110	SIRSI1&2-KUMTA	NO STATION EFFECTED KUMTA_110	10:54 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
13	29-May-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEBENNUR	NO STATION EFFECTED RANEBENNUR_220	6:41			LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
14	29-May-2020	BAGALKOT	110	RATTIHALI-HIREKERUR	RATTIHALI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
15	29-May-2020	BAGALKOT	110	BAGALKOT(SIGIKERI)-ACHANUR	ACHANUR_110	7:10	19:22	12:12	MAIN SUPPLY FAILURE
16	29-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
17	29-May-2020	BAGALKOT	110	110/11KV,HV2	ACHANUR_110	7:55	10:40	2:45	LINE CLEAR AVAILED
18	29-May-2020	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	11:02	13:12	2:10	LINE CLEAR AVAILED
19	29-May-2020	BAGALKOT	220	220/110KV,HV1.LV1	BAGALKOT_220	7:33	19:04	11:31	LINE CLEAR AVAILED
20	29-May-2020	BAGALKOT	220	220/110KV,HV2.LV2	BAGALKOT_220,GULEDAGUDD A_110,KERUR_110,RAMADURG A_110,NEERABUDIHAL_110,KA LADAGI_110	7:35	19:18	11:43	LINE CLEAR AVAILED
21	29-May-2020	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	7:02	19:16	12:14	LINE CLEAR AVAILED
22	29-May-2020	BAGALKOT	110	BAGALKOT220-LOKAPUR	LOKAPUR_110	7:11	19:18	12:07	LINE CLEAR AVAILED
23	29-May-2020	BAGALKOT	220	ADPH1&2-BAGALKOT	BAGALKOT_220	7:37	18:50	11:13	LINE CLEAR AVAILED
24	29-May-2020	BAGALKOT	220	GADAG1-BAGALKOT	BAGALKOT_220	7:41	18:40	10:59	LINE CLEAR AVAILED
25	29-May-2020	BAGALKOT	220	GADAG2-BAGALKOT	BAGALKOT_220	7:41	18:45	11:04	LINE CLEAR AVAILED
26	29-May-2020	BAGALKOT	110	110/11KV.HV1	BAGALKOT_220	7:35	18:55	11:20	LINE CLEAR AVAILED
27	29-May-2020	BAGALKOT	110	110/33KV,HV3	BAGALKOT_220,KATAGERI_33, GADDANAKERI_33	7:03	19:20	12:17	LINE CLEAR AVAILED
28	29-May-2020	BAGALKOT	110	BAGALKOT220-BAGALKOT	BAGALKOT_110	7:06	19:14	12:08	LINE CLEAR AVAILED
29	29-May-2020	BAGALKOT	110	BAGALKOT220-NAVANAGAR	NAVANAGAR(B)_110	7:02	19:35	12:33	LINE CLEAR AVAILED
30	29-May-2020	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	7:10	8:10	1:00	LINE CLEAR AVAILED
31	29-May-2020	BAGALKOT	110	SUZLON-BYADAGI	BYADAGI_110	7:10	8:10	1:00	LINE CLEAR AVAILED
32	29-May-2020	BAGALKOT	220	CHIKKODI-KUDUCHI	KUDUCHI_220	10:33	15:01	4:28	LOAD CURTAILMENT
33	29-May-2020	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	9:48	17:25	7:37	NFBC ISSUED
34	29-May-2020	BAGALKOT	110	110/11KV,HV1	HIDIKAL DAM_110	9:43	16:53	7:10	LINE CLEAR AVAILED
35	29-May-2020	BAGALKOT	110	110/33KV,HV1	JAMAKHANKI_110,HIPPARGI_3 3	11:30	11:55	0:25	LINE CLEAR AVAILED
36	29-May-2020	BAGALKOT	110	110/33KV,HV2	JAMAKHANKI_110,HIPPARGI_3 3	11:55	12:35	0:40	LINE CLEAR AVAILED
37	29-May-2020	BAGALKOT	110	110/11KV,HV1(HV2A)	JAMKHANDI_110	12:37	13:35	0:58	LINE CLEAR AVAILED
38	29-May-2020	BAGALKOT	110	110/11KV,HV3	JAMKHANDI_110	13:40	13:57	0:17	LINE CLEAR AVAILED
39	29-May-2020	BAGALKOT	110	110/11KV,HV1(HV1A)	JAMKHANDI_110	15:47	16:04	0:17	LINE CLEAR AVAILED
40	29-May-2020	BAGALKOT	110	110/11KV,HV1(HV2A)	JAMKHANDI_110	16:04	16:41	0:37	LINE CLEAR AVAILED
41	29-May-2020	BAGALKOT	110	110/11KV,HV1(HV2A)	JAMKHANDI_110	19:10	19:15	0:05	TRANSFORMER FAULT
42	29-May-2020	BAGALKOT	110	110/11KV,HV1,HV3	LOKAPUR_110	9:23	15:11	5:48	LINE CLEAR AVAILED
43	29-May-2020	BAGALKOT	110	110/11KV,HV2	LOKAPUR_110	10:50	12:10	1:20	LINE CLEAR AVAILED
44	29-May-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
45	29-May-2020	BAGALKOT	110	MAREGUDDI-MUNDUGANUR	MUNDUGANUR_110	4:41	4:51	0:10	LINE FAULT
46	29-May-2020	BAGALKOT	110	PG HUNSHYAL-MUDALAGI	MUDALAGI_110	3:17	3:30	0:13	LINE FAULT
47	29-May-2020	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	7:07	7:15	0:08	HAND TRIPPED
48	29-May-2020	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	10:41	17:48	7:07	LINE CLEAR AVAILED
49	29-May-2020	BAGALKOT	110	BADAMI-HIREHAL	NO STATION EFFECTED HIREHAL_110	7:49 (29.05.2020)			LINE CLEAR AVAILED
50	29-May-2020	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	8:58	11:43	2:45	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
51	29-May-2020	BAGALKOT	110	SOUDATTI-NARGUND(RAMDURGA1)	RAMDURGA_110	18:37	19:38	1:01	LINE FAULT
52	29-May-2020	BAGALKOT	110	110/11KV,HV1&2	SALAHALLI	9:04	13:15	4:11	LINE CLEAR AVAILED
53	29-May-2020	BAGALKOT	110	110/11KV,HV4	KERUR_110	7:13	13:49	6:36	LINE CLEAR AVAILED
54	29-May-2020	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	9:43	14:38	4:55	LINE CLEAR AVAILED
55	29-May-2020	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	7:21	17:25	10:04	LINE CLEAR AVAILED
56	29-May-2020	BAGALKOT	110	VAJRAMATTI-MALLIGERI	MALLIGERI_110	19:36	19:45	0:09	HAND TRIPPED
57	29-May-2020	BAGALKOT	110	VAJRAMATTI-KATARAKI	KATARAKI_110	19:36	19:50	0:14	HAND TRIPPED
58	29-May-2020	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA,ADUGODI,BOSCH(EHT)	6:03	6:16	0:13	LINE FAULT
59	29-May-2020	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	17:58	18:39	0:41	MAIN SUPPLY FAILURE
60	29-May-2020	BENGALURU	66	HV2	BRINDAVANA	12:22	12:26	0:04	LINE CLEAR AVAILED
61	29-May-2020	BENGALURU	66	CHELUR - YENNIGADALE	CHELUR	8:07	8:30	0:23	LINE CLEAR AVAILED
62	29-May-2020	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A	10:46	10:55	0:09	LINE CLEAR AVAILED
63	29-May-2020	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	10:46	10:54	0:08	LINE CLEAR AVAILED
64	29-May-2020	BENGALURU	66	HV2	CHIKKABALLAPURA I/A	10:03	10:56	0:53	LINE CLEAR AVAILED
65	29-May-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	15:24	15:30	0:06	LINE FAULT
66	29-May-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:13	17:30	0:17	LINE FAULT
67	29-May-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	17:14	17:30	0:16	LINE FAULT
68	29-May-2020	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	0:35	0:45	0:10	LINE CLEAR AVAILED
69	29-May-2020	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	1:15	1:22	0:07	LOAD CHANGE OVER
70	29-May-2020	BENGALURU	220	HOSKOTE 220 - KIADB DEVANAHALLI HARDWARE PARK	HOSKOTE 220	0:35	1:03	0:28	MAIN SUPPLY FAILURE
71	29-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	0:35	1:11	0:36	LINE CLEAR AVAILED
72	29-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	0:35	1:07	0:32	LINE CLEAR AVAILED
73	29-May-2020	BENGALURU	66	HOSKOTE 220 - PILAGUMPA	PILAGUMPA	0:35	1:11	0:36	LINE CLEAR AVAILED
74	29-May-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	0:35	1:08	0:33	LINE CLEAR AVAILED
75	29-May-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	0:35	1:10	0:35	LINE CLEAR AVAILED
76	29-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	16:43	17:34	0:51	LINE FAULT
77	29-May-2020	BENGALURU	66	HOSKOTE 220 - BIAL(EHT)	NO STATION AFFECTED	17:12	20:00	2:48	LINE FAULT
78	29-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	17:36	20:48	3:12	LINE FAULT
79	29-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	20:48	21:03	0:15	LINE FAULT
80	29-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	23:15	23:25	0:10	LINE CLEAR AVAILED
81	29-May-2020	BENGALURU	66	HV1	IISc	17:25	17:32	0:07	LINE CLEAR AVAILED
82	29-May-2020	BENGALURU	66	AVANI - MULBAGAL	MULBAGAL	12:05	12:25	0:20	LINE FAULT
83	29-May-2020	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	6:52	7:01	0:08	LINE FAULT
84	29-May-2020	BENGALURU	220	YELAHANKA 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 220, HEBBAL 220	16:50	19:02	2:11	LINE FAULT
85	29-May-2020	BENGALURU	66	MANYATHA 220 - HOSKOTE 1	MANYATHA 66	16:50	17:15	0:24	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
86	29-May-2020	BENGALURU	66	MANYATHA 220 - HOSKOTE 2	SHOBHA CITY	16:50	17:15	0:24	MAIN SUPPLY FAILURE
87	29-May-2020	BENGALURU	66	HV1	MANYATHA TECH PARK 220	16:50	17:15	0:24	MAIN SUPPLY FAILURE
88	29-May-2020	BENGALURU	66	MANYATHA 220 - PEENYA 2	SAHAKARINAGAR	16:50	17:15	0:24	MAIN SUPPLY FAILURE
89	29-May-2020	BENGALURU	66	HV2	MANYATHA TECH PARK 220	16:50	17:15	0:24	MAIN SUPPLY FAILURE
90	29-May-2020	BENGALURU	66	HV3	MANYATHA TECH PARK 220	16:50	17:15	0:24	MAIN SUPPLY FAILURE
91	29-May-2020	BENGALURU	66	HV4	MANYATHA TECH PARK 220	16:50	17:15	0:24	MAIN SUPPLY FAILURE
92	29-May-2020	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	16:50	17:19	0:28	MAIN SUPPLY FAILURE
93	29-May-2020	BENGALURU	66	HEBBAL 220 - IISC	IISC	16:50	17:20	0:30	MAIN SUPPLY FAILURE
94	29-May-2020	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	16:50	17:23	0:32	MAIN SUPPLY FAILURE
95	29-May-2020	BENGALURU	66	HEBBAL 220 - C STATION 2	C STATION	16:50	17:23	0:32	MAIN SUPPLY FAILURE
96	29-May-2020	BENGALURU	66	HV1	TK HALLI 220	9:21	9:52	0:31	LINE CLEAR AVOIDED
97	29-May-2020	BENGALURU	66	HV1	SURYANAGAR	9:59	10:19	0:20	LINE CLEAR AVOIDED
98	29-May-2020	BENGALURU	66	HV1	SURYANAGAR	13:05	14:06	1:00	TRANSFORMER FAULT
99	29-May-2020	BENGALURU	66	HV2	SARJAPURA 220	9:37	9:43	0:05	TRANSFORMER FAULT
100	29-May-2020	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	0:31	0:43	0:11	LINE FAULT
101	29-May-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	0:31	0:38	0:06	LINE FAULT
102	29-May-2020	BENGALURU	66	HV2	NANDINI LAYOUT	8:57	14:58	6:00	LINE CLEAR AVOIDED
103	29-May-2020	BENGALURU	66	HV2	YEDUMADU	20:18	20:35	0:16	TRANSFORMER FAULT
104	29-May-2020	BENGALURU	400	NELAMANGALA 400 - GOOTY A	NO STATION AFFECTED	0:31	6:56	6:25	LINE FAULT
105	29-May-2020	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 4	NO STATION AFFECTED	17:33	19:54	2:20	LINE FAULT
106	29-May-2020	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	17:59	19:23	1:24	LINE FAULT
107	29-May-2020	BENGALURU	66	VIDYANAGAR - SAHAKARINAGAR	HENNUR CROSS	16:41	18:05	1:23	LINE FAULT
108	29-May-2020	BENGALURU	66	TELECOM LAYOUT - NRS 1	TELECOM LAYOUT	12:37	12:49	0:12	LOAD CHANGE OVER
109	29-May-2020	BENGALURU	66	TELECOM LAYOUT - NRS 2	TELECOM LAYOUT	16:40	16:52	0:12	LOAD CHANGE OVER
110	29-May-2020	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	MANYATHA TECH PARK 220, HEBBAL 220	16:49	17:15	0:26	LINE FAULT
111	29-May-2020	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	18:35	19:28	0:53	LINE FAULT
112	29-May-2020	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - SHELL (EHT)	SHELL (EHT)	0:30	1:03	0:33	MAIN SUPPLY FAILURE
113	29-May-2020	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - BHP (EHT)	BHP (EHT)	0:30	1:03	0:33	MAIN SUPPLY FAILURE
114	29-May-2020	BENGALURU	66	HV1	DEVANAHALLI HARDWARE PARK 220	0:30	1:03	0:33	MAIN SUPPLY FAILURE
115	29-May-2020	BENGALURU	220	DEVANAHALLI HARDWARE PARK 220 - BIAL 220	DEVANAHALLI HARDWARE PARK 220, HOSKOTE 220	0:30	1:02	0:32	LINE CLEAR AVOIDED
116	29-May-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	15:23	15:53	0:30	LINE CLEAR AVOIDED
117	29-May-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	14:01	14:06	0:05	LOAD CHANGE OVER
118	29-May-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	15:23	15:56	0:33	LINE CLEAR AVOIDED
119	29-May-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	14:01	14:06	0:05	LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
120	29-May-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	17:03	22:58	5:54	LINE FAULT
121	29-May-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:23	15:56	0:33	LINE CLEAR AVAILED
122	29-May-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	14:01	14:06	0:05	LINE CLEAR AVAILED
123	29-May-2020	BENGALURU	66	HV2	TEMAGONDALU	1:01	2:48	1:46	TRANSFORMER FAULT
124	29-May-2020	BENGALURU	66	HV2	TEMAGONDALU	2:48	2:56	0:08	TRANSFORMER FAULT
125	29-May-2020	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	22:58 (28-5-2020)	0:13:55	3:27hrs	LINE CHARGED
126	29-May-2020	BENGALURU	66	HV1	KONDASPURA	20:12 (28-5-2020)	14:47:29	18:34hrs	TRANSFORMER CHARGED
127	29-May-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
128	29-May-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
129	29-May-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
130	29-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	23:25:00(29.5.20)			LINE OPEN, LINE FAULT
131	29-May-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
132	29-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
133	29-May-2020	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110, KUDITINI_110, KURUGOD_110,KAMALAPUR_110, METRI_110, RBNS SUGARS	5:47	5:56	0:09	LINE FAULT
134	29-May-2020	GULBARGA	110	HV3	BETAGERA_110	4:00(29.5.20)			LINE CLEAR AVAILED
135	29-May-2020	GULBARGA	110	HV2	DEODURGA_110	9:16	9:25	0:09	TRANSFORMER FAULT
136	29-May-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	8:57	9:00	0:03	LINE FAULT
137	29-May-2020	GULBARGA	110	SINDHANOOR220-RAICHUR1	SINDHANOOR_110	10:06	13:37	3:31	LINE CLEAR AVAILED
138	29-May-2020	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKAGIRI_110, GANADAL_110	5:53	9:28	3:35	LINE CLEAR AVAILED
139	29-May-2020	GULBARGA	110	HUMNABAD-MANAEGHELI	MANAEGHELI_110	16:40	16:54	0:14	LINE FAULT
140	29-May-2020	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	17:00	17:04	0:04	LINE CLEAR AVAILED
141	29-May-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
142	29-May-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	17:19 (21.05.2020)			LINE OPEN, LINE CLEAR AVAILED
143	29-May-2020	HASSAN	110	JOG-AMBT2	STATION NOT AFFECTED	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
144	29-May-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	20:51(29.05.2020)			LINE CLEAR AVAILED
145	29-May-2020	HASSAN	110	HV2	KADUR_220	9:55	11:01	1:06	LINE CLEAR AVAILED
146	29-May-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:14	12:41	1:27	LINE CLEAR AVAILED
147	29-May-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:15	11:43	2:28	LINE CLEAR AVAILED
148	29-May-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:14	12:41	1:27	LINE CLEAR AVAILED
149	29-May-2020	HASSAN	110	HV1	BAIKAMPADI_110	12:16	13:29	1:13	LINE CLEAR AVAILED
150	29-May-2020	HASSAN	110	HV2	ESSUR_110	3:06	3:14	0:08	TRANSFORMER FAULT
151	29-May-2020	HASSAN	110	HV2	NAVUNDA_110	12:48	13:51	1:03	LINE CLEAR AVAILED
152	29-May-2020	HASSAN	110	HV1	SALATHUR_110	15:51	18:18	2:27	LINE CLEAR AVAILED
153	29-May-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:10	14:32	3:22	LINE CLEAR AVAILED
154	29-May-2020	HASSAN	66	HV1	MAGGE_66	11:13	14:35	3:22	MAIN SUPPLY FAILURE
155	29-May-2020	HASSAN	66	HV2	MAGGE_66	11:13	14:35	3:22	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
156	29-May-2020	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	11:12	14:32	3:20	NFBC ISSUED
157	29-May-2020	HASSAN	66	IPCL1	SAKLESH PURA_66	9:01	19:21	10:20	LINE CLEAR AVAILED
158	29-May-2020	HASSAN	66	IPCL2	SAKLESH PURA_66	9:01	19:21	10:20	LINE CLEAR AVAILED
159	29-May-2020	MYSURU	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	23:59 (28.05.20)	0:10	00:10 HRS	LINE CHARGED
160	29-May-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN,LOAD CHANGE OVER
161	29-May-2020	MYSURU	66	BANNUR-SFC	BANNUR_66	10:24	18:10	7:45	NFBC ISSUED
162	29-May-2020	MYSURU	66	BANNUR-VAJMANGALA	BANNUR_66	10:20	18:10	7:49	NFBC ISSUED
163	29-May-2020	MYSURU	66	BOGADHI-HOOTAGALLI	BOGADHI_66	11:11	17:35	6:24	LINE CLEAR AVAILED
164	29-May-2020	MYSURU	66	BOGADHI-MYSORE SOUTH	BOGADHI_66	11:29	17:45	6:15	LINE CLEAR AVAILED
165	29-May-2020	MYSURU	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 ,MARTAH ALLI_66	6:13	7:56	1:42	NFBC ISSUED
166	29-May-2020	MYSURU	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	8:01	8:05	0:04	LINE FAULT
167	29-May-2020	MYSURU	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	10:28	17:09	6:41	NFBC ISSUED
168	29-May-2020	MYSURU	66	HV2	HDKOTE_66	7:36	7:45	0:09	HAND TRIPPED
169	29-May-2020	MYSURU	66	HV2	HDKOTE_66	10:42	10:43	0:01	HAND TRIPPED
170	29-May-2020	MYSURU	66	HV2	HDKOTE_66	15:45	16:00	0:15	HAND TRIPPED
171	29-May-2020	MYSURU	66	HV2	HONNALLY_MYS_66	13:17	19:15	5:58	LINE CLEAR AVAILED
172	29-May-2020	MYSURU	66	HOOTAGALLY-BOGADHI	NO STATIONS EFFECTED	10:55	17:22	6:27	LINE CLEAR AVAILED
173	29-May-2020	MYSURU	66	HOOTAGALLY-DATAGALLI	DATTAGALLY_66, RKNAGARA_66, MANTAGALLY_66	8:39	9:03	0:23	LINE FAULT
174	29-May-2020	MYSURU	66	HV1	PANDAVAPURA_66	16:19	16:33	0:13	LINE CLEAR AVAILED
175	29-May-2020	MYSURU	66	HV1	SHIVALLY_66	13:12	13:24	0:11	LINE CLEAR AVAILED
176	29-May-2020	MYSURU	66	TALKADU-ADANI	NO STATIONS EFFECTED	0:17	0:22	0:05	LINE FAULT
177	29-May-2020	MYSURU	66	VAJMANGALA-KADAKOLA 1	MARADIHUNDI_66,AYRALLI_66	5:28	5:45	0:16	LINE FAULT
178	29-May-2020	TUMKUR	220	PAVAGADA220-MADHUGIRI 2	PAVAGADA_220	8:40:04 PM(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
179	29-May-2020	TUMKUR	220	PAVAGADA-GREENKO	GREENKO_IPP_220	20:39	21:03	0:24	LINE FAULT
180	29-May-2020	TUMKUR	220	TR-1	PAVAGADA_220	21:59	22:08	0:09	TRANSFORMER FAULT
181	29-May-2020	TUMKUR	220	TR-2	PAVAGADA_220	21:59	22:46	0:47	TRANSFORMER FAULT
182	29-May-2020	TUMKUR	110	TR-1	TURUVEKERE_110	22:44	23:17	0:33	TRANSFORMER FAULT
183	29-May-2020	TUMKUR	110	TR-1	MAYASANDRA_110	19:49	22:37	2:48	TRANSFORMER FAULT
184	29-May-2020	TUMKUR	110	TR-2	MAYASANDRA_110	19:32	22:36	3:04	TRANSFORMER FAULT
185	29-May-2020	TUMKUR	110	TR-1	TALKERE_110	12:37	14:07	1:29	LINE CLEAR AVAILED
186	29-May-2020	TUMKUR	110	TALKERE110-KBCROSS220	TALKERE_110	12:39	14:07	1:27	LINE CLEAR AVAILED
187	29-May-2020	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	18:39	19:51	1:11	LINE FAULT
188	29-May-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	12:36	13:15	0:39	LINE CLEAR AVAILED
189	29-May-2020	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	12:15	13:59	1:43	LINE CLEAR AVAILED
190	29-May-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	6:58	7:08	0:10	LINE FAULT
191	29-May-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	7:13	7:33	0:20	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
192	29-May-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	8:13	8:24	0:10	LINE FAULT
193	29-May-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:10	17:52	6:41	LINE CLEAR AVAILED
194	29-May-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
195	29-May-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	18:06	18:16	0:10	LINE FAULT
196	29-May-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	10:43	10:53	0:09	LINE FAULT
197	29-May-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	20:56	21:04	0:08	TRANSFORMER FAULT
198	29-May-2020	TUMKUR	66	TR-2	KORATAGERE_66	15:52:51(28.05.2020)	19:29	27:36hrs	TRANSFORMER CHARGED
199	29-May-2020	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	19:50	20:20	0:30	LINE FAULT
200	29-May-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	11:51	12:21	0:29	HAND TRIPPED
201	29-May-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	13:19	13:28	0:09	LINE FAULT
202	29-May-2020	TUMKUR	66	NEELAGUNDA 220kv- HULUVAGALU	HALUVAGALU_66	5:24	5:38	0:14	LINE FAULT
203	29-May-2020	TUMKUR	66	NEELAGUNDA 220kv-TELAGE	TELAGE_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	11:03	11:13	0:09	LINE FAULT
204	29-May-2020	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	21:22	22:09	0:46	TRANSFORMER FAULT
205	29-May-2020	TUMKUR	66	TR-2(HV SIDE)	PAVAGADA_220	21:59	22:15	0:16	TRANSFORMER FAULT
206	29-May-2020	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66, YNHOSKOTE_66, LINGDHALLI_66, MANGALWADA_66	21:26	21:59	0:33	LINE FAULT
207	29-May-2020	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66, YNHOSKOTE_66, LINGDHALLI_66, MANGALWADA_66	22:11	22:25	0:14	LINE FAULT
208	29-May-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI(PR PURA)	RANGENAHALLI_66	23:47	23:56	0:09	LINE FAULT
209	29-May-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI(PR PURA)	RANGENAHALLI_66	7:13	17:49	10:36	LINE CLEAR AVAILED
210	29-May-2020	TUMKUR	66	TR-2	TELAGE_66	10:34	11:24	0:50	LINE CLEAR AVAILED
1	30-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	30-May-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	7:36 (10.05.2020)	10:05 (30.05.2020)	482:29hrs	LINE CHARGED
3	30-May-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
4	30-May-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
5	30-May-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
6	30-May-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
7	30-May-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)- GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)			LINE OPEN, LINE CLEAR AVAILED
8	30-May-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
9	30-May-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	15:07 (27.05.2020)	9:36 (30.05.2020)	66:29hrs	LINE CHARGED
10	30-May-2020	BAGALKOT	110	SIRSI1&2-KUMTA	NO STATION EFFECTED KUMTA_110	10:54 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
11	30-May-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)- RANEENNUR	NO STATION EFFECTED RANEENNUR_220	6:41 (28.05.2020)	14:30 (30.05.2020)	55:49hrs	LINE CHARGED
12	30-May-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
13	30-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
14	30-May-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
15	30-May-2020	BAGALKOT	110	BADAMI-HIREHAL	NO STATION EFFECTED HIREHAL_110	7:49 (29.05.2020)			LINE CLEAR AVAILED
16	30-May-2020	BAGALKOT	110	110/11KV,HV1	ANKALI_110	10:00	14:14	4:14	LINE CLEAR AVAILED
17	30-May-2020	BAGALKOT	110	110/11KV,HV2	ANKALI_110	10:00	14:39	4:39	LINE CLEAR AVAILED
18	30-May-2020	BAGALKOT	110	110/33KV,HV3	ANKALI_110,NANDIKURALI_33	9:26	14:38	5:12	LINE CLEAR AVAILED
19	30-May-2020	BAGALKOT	110	110/33KV,HV4	ANKALI_110,KOTWADI_33,SHR AGUPPI_110	10:05	14:40	4:35	LINE CLEAR AVAILED
20	30-May-2020	BAGALKOT	110	AB SOLAR-BELLATTI	BELLATTI_110	15:15	16:14	0:59	MAIN SUPPLY FAILURE
21	30-May-2020	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	15:15	16:15	1:00	MAIN SUPPLY FAILURE
22	30-May-2020	BAGALKOT	220	220/110KV,HV1,LV1	BIDNAL_220	10:14	17:42	7:28	LINE CLEAR AVAILED
23	30-May-2020	BAGALKOT	110	BIDNAL-GADAGROAD	GADAGROAD_110	9:41	18:25	8:44	LINE CLEAR AVAILED
24	30-May-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	9:54	18:16	8:22	LINE CLEAR AVAILED
25	30-May-2020	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND_110	10:04	18:35	8:31	LINE CLEAR AVAILED
26	30-May-2020	BAGALKOT	110	BIDNAL-HUBLI2	BIDNAL_220	10:13	17:48	7:35	LINE CLEAR AVAILED
27	30-May-2020	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	10:01	18:18	8:17	LINE CLEAR AVAILED
28	30-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	6:58 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
29	30-May-2020	BAGALKOT	110	SUZLON-BYADAGI	BYADAGI_110	8:50	16:53	8:03	LINE CLEAR AVAILED
30	30-May-2020	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	11:28	14:13	2:45	LINE CLEAR AVAILED
31	30-May-2020	BAGALKOT	110	CHIKKODI-ANKALI	ANKALI_110	10:14	12:21	2:07	LINE CLEAR AVAILED
32	30-May-2020	BAGALKOT	110	BIJAPUR220-ENERCON	BIJAPUR_220	18:48	18:53	0:05	LINE FAULT
33	30-May-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	18:20 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
34	30-May-2020	BAGALKOT	110	110/11KV,HV1&2	GHATAPRABHA_110	9:26	10:13	0:47	HAND TRIPPED
35	30-May-2020	BAGALKOT	110	110/33KV,HV3&HV4	GHATAPRABHA_110	9:26	10:15	0:49	HAND TRIPPED
36	30-May-2020	BAGALKOT	110	110/33KV,HV5	GHATAPRABHA_110	9:51	10:13	0:22	HAND TRIPPED
37	30-May-2020	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA	GHATAPRABHA_110	9:30	10:25	0:55	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
38	30-May-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
39	30-May-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	21:01	21:02	0:01	TRANSFORMER FAULT
40	30-May-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	10:10	14:21	4:11	LINE CLEAR AVAILED
41	30-May-2020	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,MYTRA SOLAR_33,KARADI_33,AMINAG AD_33	6:39	6:46	0:07	TRANSFORMER FAULT
42	30-May-2020	BAGALKOT	110	110/11KV,HV2	HUNAGUND_110,MYTRA SOLAR_33,KARADI_33,AMINAG AD_34	7:36	8:21	0:45	TRANSFORMER FAULT
43	30-May-2020	BAGALKOT	110	110/11KV,HV2(HV2A)	JAMAKHANDI_110	20:05	20:15	0:10	TRANSFORMER FAULT
44	30-May-2020	BAGALKOT	220	220/110KV ,HV1 & LV1	VAJRAMATTI_220	17:10	17:36	0:26	LINE CLEAR AVAILED
45	30-May-2020	BAGALKOT	110	220/110KV , LV1	VAJRAMATTI_220	17:10	17:38	0:28	LINE CLEAR AVAILED
46	30-May-2020	BAGALKOT	110	110/11KV,HV2	TIKOT_110	9:23	9:29	0:06	TRANSFORMER FAULT
47	30-May-2020	BAGALKOT	220	HUBLI-SIRSI 1	HUBLI_220	14:23	22:18	7:55	LINE FAULT
48	30-May-2020	BAGALKOT	220	HUBLI-SIRSI 2	HUBLI_220	14:23	22:18	7:55	LINE FAULT
49	30-May-2020	BAGALKOT	110	SIRSI-KUMATA 1	SIRSI_110	13:20	16:55	3:35	LINE FAULT
50	30-May-2020	BAGALKOT	110	SIRSI-KUMATA 2	SIRSI_110	16:02	17:14	1:12	NFBC ISSUED
51	30-May-2020	BAGALKOT	220	SOUDATTI-MAHALINGPUR	SOUDATTI_220	7:33	11:40	4:07	LINE CLEAR AVAILED
52	30-May-2020	BAGALKOT	110	BIDNAL-NAVAGUND	NAVALAGUND_110	10:29	18:34	8:05	LINE CLEAR AVAILED
53	30-May-2020	BAGALKOT	220	NARENDRA-AMBEWADI 1	NARENDRA_220	14:06	18:37	4:31	LINE FAULT
54	30-May-2020	BAGALKOT	110	BIDNAL -NARAGUND	NARAGUND_110	10:00	10:15	0:15	MAIN SUPPLY FAILURE
55	30-May-2020	BAGALKOT	110	BIDNAL -NARAGUND	NARAGUND_110	18:20	18:25	0:05	HAND TRIPPED
56	30-May-2020	BAGALKOT	220	KARWAR -KADRA 1	KARWAR_220	9:50	18:04	8:14	LINE CLEAR AVAILED
57	30-May-2020	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	15:00	15:48	0:48	HAND TRIPPED
58	30-May-2020	BAGALKOT	110	110/11KV,HV2	LAXMESHWAR_110	14:59	15:48	0:49	HAND TRIPPED
59	30-May-2020	BAGALKOT	110	110/33V,HV3	LAXMESHWAR_110,MMCL_33, SSM_33	15:00	15:48	0:48	HAND TRIPPED
60	30-May-2020	BAGALKOT	110	GADAG-LAXMESHWAR	LAXMESHWAR_110	15:00	15:48	0:48	HAND TRIPPED
61	30-May-2020	BAGALKOT	110	SHIRAHATTI-LAXMESHWAR	LAXMESHWAR_110	15:00	15:48	0:48	HAND TRIPPED
62	30-May-2020	BAGALKOT	110	LAXMESHWAR-BELATTI	LAXMESHWAR_110	15:00	15:53	0:53	HAND TRIPPED
63	30-May-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	12:54	13:36	0:41	MAIN SUPPLY FAILURE
64	30-May-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	12:54	14:16	1:21	MAIN SUPPLY FAILURE
65	30-May-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	12:54	14:15	1:20	MAIN SUPPLY FAILURE
66	30-May-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	12:54	14:16	1:21	MAIN SUPPLY FAILURE
67	30-May-2020	BENGALURU	220	YARANDANAHALLI 220 - SOMANAHALLI 220	YERANDANAHALLI 220	12:54	13:36	0:41	MAIN SUPPLY FAILURE
68	30-May-2020	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	12:54	13:52	0:57	MAIN SUPPLY FAILURE
69	30-May-2020	BENGALURU	220	HV2	YERANDANAHALLI 220	12:54	13:37	0:42	MAIN SUPPLY FAILURE
70	30-May-2020	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	5:53	5:54	0:01	LOAD CHANGE OVER
71	30-May-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	BAGEPALLI	11:20	12:25	1:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
72	30-May-2020	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	12:54	13:19	0:24	LINE FAULT
73	30-May-2020	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	18:30	21:10	2:39	LINE FAULT
74	30-May-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KK DODDI	10:37	13:27	2:50	LINE CLEAR AVAILED
75	30-May-2020	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	10:01	10:20	0:19	LINE FAULT
76	30-May-2020	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	19:24	19:37	0:12	LINE FAULT
77	30-May-2020	BENGALURU	66	HV2	YEDUMADU	14:16	14:25	0:09	TRANSFORMER FAULT
78	30-May-2020	BENGALURU	66	HV2	YEDUMADU	14:52	14:56	0:03	LINE CLEAR AVAILED
79	30-May-2020	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	18:40	19:50	1:10	LINE FAULT
80	30-May-2020	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, CESSNA (EHT)	20:33	20:43	0:10	LOAD CHANGE OVER
81	30-May-2020	BENGALURU	66	KADUBISANAHALLI - CESSNA PARK	KADUBISANAHALLI, CESSNA (EHT)	22:07	22:15	0:08	LOAD CHANGE OVER
82	30-May-2020	BENGALURU	400	NELAMANGALA 400 - MYSORE 2	NO STATION AFFECTED	2:17	7:44	5:26	LINE FAULT
83	30-May-2020	BENGALURU	66	HV1	KONDASPURA	11:29	12:10	0:40	LINE CLEAR AVAILED
84	30-May-2020	BENGALURU	66	HV2	RR NAGAR	10:00	18:35	8:35	LINE CLEAR AVAILED
85	30-May-2020	BENGALURU	66	GANJIGUNTE - PALLICHERLU	PALLICHERLU	7:10	7:20	0:10	LINE FAULT
86	30-May-2020	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	8:49	9:00	0:11	LINE CLEAR AVAILED
87	30-May-2020	BENGALURU	66	HV1	BANGARPETE	17:11	17:18	0:07	TRANSFORMER FAULT
88	30-May-2020	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	12:55	13:22	0:27	LOAD CHANGE OVER
89	30-May-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	12:03	12:08	0:05	LINE FAULT
90	30-May-2020	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	8:25	8:30	0:05	LOAD CHANGE OVER
91	30-May-2020	BENGALURU	66	HV1	GOLF LINK	11:45	11:55	0:10	LINE CLEAR AVAILED
92	30-May-2020	BENGALURU	220	HOODY 400 - HAL 2	NO STATION AFFECTED	18:32	23:49	5:17	LINE FAULT
93	30-May-2020	BENGALURU	220	HOODY 400 - HAL 1	NO STATION AFFECTED	21:23	23:48	2:25	LINE CLEAR AVAILED
94	30-May-2020	BENGALURU	66	HV2	HOSUR RAMAPURA	11:03	11:13	0:10	TRANSFORMER FAULT
95	30-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	23:25(29-5-2020)	0:43	1:18Hrs	LINE CHARGED
96	30-May-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
97	30-May-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
98	30-May-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
99	30-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	23:25(29-5-2020)			LINE OPEN, LINE FAULT
100	30-May-2020	BENGALURU	66	HV1	KUMBALAGODU	23:55 (29-5-2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
101	30-May-2020	BENGALURU	66	HV1	KUMBALAGODU	23:55 (29-5-2020)	0:04	0:09	TRANSFORMER CHARGED
102	30-May-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
103	30-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
104	30-May-2020	GULBARGA	110	HV2	HATTI_110	8:09	8:18	0:09	TRANSFORMER FAULT
105	30-May-2020	GULBARGA	110	HV1	MASKI_110	12:02	12:20	0:18	LINE CLEAR AVAILED
106	30-May-2020	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	4:09	4:20	0:11	LINE FAULT
107	30-May-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	4:30	4:39	0:09	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
108	30-May-2020	GULBARGA	110	HV3	BETAGERA_110	4:00(29.5.2020)	6:00	26:00HRS	TRANSFORMER CHARGED
109	30-May-2020	GULBARGA	110	HV3	BETAGERA_110	13:10	13:25	0:15	LINE CLEAR AVAILED
110	30-May-2020	GULBARGA	110	HV1	BETAGERA_110	12:25	13:25	1:00	LINE CLEAR AVAILED
111	30-May-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	20:11	20:27	0:16	LINE FAULT
112	30-May-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
113	30-May-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	17:19 (21.05.2020)			LINE OPEN, LINE CLEAR AVAILED
114	30-May-2020	HASSAN	110	JOG-AMBTR2	STATION NOT AFFECTED	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
115	30-May-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	20:51(29.05.2020)	9:16	12:65hrs	LINE CHARGED
116	30-May-2020	HASSAN	220	HASSN22-NITTUR	HASSAN_220	15:57	16:59	1:02	LINE CLEAR AVAILED
117	30-May-2020	HASSAN	66	HASSN22-SKP2	HASSAN_220	7:06	7:26	0:20	LINE FAULT
118	30-May-2020	HASSAN	66	HASSN22-HSN66	HASSAN_220	17:01	17:05	0:04	HAND TRIPPED
119	30-May-2020	HASSAN	66	HASSN22-HSN66	HASSAN_220	15:42	15:50	0:08	HAND TRIPPED
120	30-May-2020	HASSAN	66	HASSN22-HSN66	HASSAN_220	17:01	17:05	0:04	HAND TRIPPED
121	30-May-2020	HASSAN	66	HASSN22-UDDUR	HASSAN_220	17:10	17:15	0:05	HAND TRIPPED
122	30-May-2020	HASSAN	66	HASSN22-SUZLON	HASSAN_220	17:10	17:15	0:05	HAND TRIPPED
123	30-May-2020	HASSAN	66	HASSN22-BELUR	HASSAN_220	15:57	16:59	1:02	LINE CLEAR AVAILED
124	30-May-2020	HASSAN	66	HASSN22-UDDUR	HASSAN_220	17:10	17:15	0:05	HAND TRIPPED
125	30-May-2020	HASSAN	66	HASSN22-SUZLON	HASSAN_220	17:10	17:15	0:05	HAND TRIPPED
126	30-May-2020	HASSAN	66	HV2	HASSAN_220	15:57	16:59	1:02	LINE CLEAR AVAILED
127	30-May-2020	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:39	12:23	1:44	LINE CLEAR AVAILED
128	30-May-2020	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	11:41	13:13	1:32	LINE CLEAR AVAILED
129	30-May-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	11:41	13:00	1:19	NFBC ISSUED
130	30-May-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:30	13:18	2:48	LINE CLEAR AVAILED
131	30-May-2020	HASSAN	66	HV2	BAGUR_66	1:01	2:40	1:39	TRANSFORMER FAULT
132	30-May-2020	HASSAN	66	HV1	BELUR_66	6:27	11:15	4:48	TRANSFORMER FAULT
133	30-May-2020	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	7:50	7:59	0:09	LINE FAULT
134	30-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:02	17:25	8:23	LINE CLEAR AVAILED
135	30-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:02	17:25	8:23	LINE CLEAR AVAILED
136	30-May-2020	HASSAN	66	HV1	SALAGAME_66	16:00	16:20	0:20	MAIN SUPPLY FAILURE
137	30-May-2020	HASSAN	66	HV1	SALAGAME_66	17:15	17:20	0:05	MAIN SUPPLY FAILURE
138	30-May-2020	HASSAN	66	HV2	UDAYAPURA_66	9:32	9:38	0:06	TRANSFORMER FAULT
139	30-May-2020	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	11:34	13:29	1:55	LINE CLEAR AVAILED
140	30-May-2020	HASSAN	110	HOSNGD-HULIKAL	HOSANGADI_110	10:18	11:34	1:16	LINE CLEAR AVAILED
141	30-May-2020	HASSAN	110	HOSNGD-HULIKAL	HOSANGADI_110	13:30	13:48	0:18	HAND TRIPPED
142	30-May-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN,LOAD CHANGE OVER
143	30-May-2020	MYSURU	66	CHIKAMANDYA-HAMAPURA	BASARALU_66 BESAGARAHALLI_66 KOPPA_66 HAMPAPURA_66	9:36	9:41	0:04	LINE FAULT
144	30-May-2020	MYSURU	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	13:43	13:50	0:06	LINE FAULT
145	30-May-2020	MYSURU	66	HV1	DODDABYADARAHALLI_66	11:40	11:52	0:12	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
146	30-May-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	23:19	23:30	0:11	LINE FAULT
147	30-May-2020	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	23:19	23:32	0:12	LINE FAULT
148	30-May-2020	MYSURU	66	HV2	HONNALLY_MYS_66	11:00	18:09	7:08	LINE CLEAR AVAILED
149	30-May-2020	MYSURU	66	HOOTAGALLY-ELWALA	NO STATIONS EFFECTED	10:47	11:37	0:50	LOAD CHANGE OVER
150	30-May-2020	MYSURU	220	HV3	HOOTAGALLY_220	10:37	11:02	0:24	TRANSFORMER FAULT
151	30-May-2020	MYSURU	66	KADAKOLA-RK NAGARA	NO STATIONS EFFECTED	11:17	13:01	1:43	LINE CLEAR AVAILED
152	30-May-2020	MYSURU	66	KIADB MANDYA-MANDYA-TK HALLI	KIADBMANDYA_66	10:14	13:27	3:13	LOAD CHANGE OVER
153	30-May-2020	MYSURU	66	KIADB MANDYA-MADDUR	NO STATIONS EFFECTED	11:26	11:38	0:12	HAND TRIPPED
154	30-May-2020	MYSURU	66	HV2	KMDODDI_66	9:01	15:13	6:11	LINE CLEAR AVAILED
155	30-May-2020	MYSURU	66	KM DODDI-MANDYA	NO STATIONS EFFECTED	10:40	13:29	2:49	NFBC ISSUED
156	30-May-2020	MYSURU	66	KUSHALNAGARA 220-PERIPATNA-1	NO STATIONS EFFECTED	12:00	14:34	2:34	LINE CLEAR AVAILED
157	30-May-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	17:36	17:41	0:04	LINE FAULT
158	30-May-2020	MYSURU	220	MADHUVANAHALLI-WARD SOLAR	NO STATIONS EFFECTED	3:23	4:51	1:27	LINE FAULT
159	30-May-2020	MYSURU	66	KADAKOLA-MYS(SOUTH)	NO STATIONS EFFECTED	10:04	13:03	2:58	LINE CLEAR AVAILED
160	30-May-2020	MYSURU	66	HV5	SFCSHIVA_66	10:23	12:13	1:49	LINE CLEAR AVAILED
161	30-May-2020	MYSURU	66	HV1	SINDHUVALLI_66	18:04	18:31	0:26	LINE CLEAR AVAILED
162	30-May-2020	TUMKUR	220	PAVAGADA220-MADHUGIRI 2	PAVAGADA_220	22:40 (29.05.2020)	5:53:00	9:23hrs	LINE CHARGED
163	30-May-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:27(26.05.20)	-	-	LINE OPEN, LINE FAULT
164	30-May-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	9:40	13:30	3:50:59	LINE CLEAR AVAILED
165	30-May-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	13:52	13:54	0:01	TRANSFORMER FAULT
166	30-May-2020	TUMKUR	66	CHITRADURGA 220KV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	0:23	1:03	0:40	LINE FAULT
167	30-May-2020	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	8:04	9:32	1:27	LINE CLEAR AVAILED
168	30-May-2020	TUMKUR	66	TR-2	DAVANAGERE_66	13:46	14:23	0:36	LINE CLEAR AVAILED
169	30-May-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:20	11:31	0:10	LINE FAULT
170	30-May-2020	TUMKUR	66	TR-1	GARAGA_66	6:00	6:40	0:40	TRANSFORMER FAULT
171	30-May-2020	TUMKUR	66	TR-2	HALUVAGALU_66	1:23	1:57	0:34	TRANSFORMER FAULT
172	30-May-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	5:45	5:55	0:10	TRANSFORMER FAULT
173	30-May-2020	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	0:27	0:53	0:26	LINE FAULT
174	30-May-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	6:20	6:24	0:04	TRANSFORMER FAULT
175	30-May-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	9:31	9:38	0:07	TRANSFORMER FAULT
176	30-May-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	14:06	14:12	0:05	TRANSFORMER FAULT
177	30-May-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:21	12:34	0:12	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
178	30-May-2020	TUMKUR	66	TR-2	KOLALA_66	12:31	16:49	4:17	LINE CLEAR AVAILED
179	30-May-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:16	12:31	0:14	LINE FAULT
180	30-May-2020	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	12:46	19:25	6:38	LINE CLEAR AVAILED
181	30-May-2020	TUMKUR	66	TR-2	MATHOD_66	9:30	9:37	0:07	TRANSFORMER FAULT
182	30-May-2020	TUMKUR	66	NEELAGUNDA 220KV-TELADI	TELADI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	12:43	13:01	0:18	HAND TRIPPED
183	30-May-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,R AMAGIRI_66	12:05	12:12	0:06	LINE FAULT
184	30-May-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,R AMAGIRI_66	15:40	15:56	0:15	LINE FAULT
185	30-May-2020	TUMKUR	220	TR-1 & 2	PAVAGADA_220	8:59	9:25	0:25	TRANSFORMER FAULT
186	30-May-2020	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	1:54	5:20	3:25	MAIN SUPPLY FAILURE
187	30-May-2020	TUMKUR	66	TR-1	RANGENAHALLI_66	15:20	16:47	1:27	LINE CLEAR AVAILED
188	30-May-2020	TUMKUR	66	TR-2	RANGENAHALLI_66	12:08	15:15	3:06	LINE CLEAR AVAILED
189	30-May-2020	TUMKUR	66	SHYLA PURA- MADHUGIRI	SHYLA PURA_66	8:59	9:30	0:30	MAIN SUPPLY FAILURE
190	30-May-2020	TUMKUR	66	SHYLA PURA- MADHUGIRI	SHYLA PURA_66	18:01	18:10	0:08	MAIN SUPPLY FAILURE
191	30-May-2020	TUMKUR	66	SHYLA PURA-PR PURA	SHYLA PURA_66	8:13	8:59	0:46	LINE FAULT
192	30-May-2020	TUMKUR	66	SHYLA PURA-PR PURA	SHYLA PURA_66	9:30	13:45	4:14	MAIN SUPPLY FAILURE
193	30-May-2020	TUMKUR	66	TR-1	BIDARE_110	12:00	12:32	0:32	LINE CLEAR AVAILED
194	30-May-2020	TUMKUR	66	SAMPIGE- DODDAGUNI	SAMPIGE_110	0:57	1:41	0:43	HAND TRIPPED
195	30-May-2020	TUMKUR	66	TR-2	SAMPIGE_110	0:03	16:25	16:22	TRANSFORMER FAULT
196	30-May-2020	TUMKUR	66	TR-2	SAMPIGE_110	16:26	16:34	0:08	TRANSFORMER FAULT
197	30-May-2020	TUMKUR	66	TR-1	BANUVALLI_66	12:18	12:38	0:20	LINE CLEAR AVAILED
198	30-May-2020	TUMKUR	66	TR-1	DYAVARANAHALLI_66	1:30	3:30	2:00	TRANSFORMER FAULT
199	30-May-2020	TUMKUR	66	DYAVARANAHALLI-THALLAK	DYAVARANAHALLI_66	1:30	3:30	2:00	LINE FAULT
200	30-May-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	1:30	3:30	2:00	LINE FAULT
201	30-May-2020	TUMKUR	66	TR-1 & 2	DYAVARANAHALLI_66	10:20	10:40	0:20	LINE CLEAR AVAILED
202	30-May-2020	TUMKUR	66	TR-2	DYAVARANAHALLI_66	11:20	11:40	0:20	LINE CLEAR AVAILED
203	30-May-2020	TUMKUR	66	TR-2	THIMMASANDRA_66	7:26	7:30	0:03	TRANSFORMER FAULT
204	31-May-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
205	31-May-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
206	31-May-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
207	31-May-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
208	31-May-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
209	31-May-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)- GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
210	31-May-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
211	31-May-2020	BAGALKOT	110	SIRSI1&2-KUMTA	NO STATION EFFECTED KUMTA_110	10:54 (28.05.2020)	8:18 (31.05.2020)	69:24hrs	LINE CHARGED
212	31-May-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
213	31-May-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
214	31-May-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
215	31-May-2020	BAGALKOT	110	BADAMI-HIREHAL	NO STATION EFFECTED HIREHAL_110	7:49 (29.05.2020)			LINE CLEAR AVAILED
216	31-May-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	6:58 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
217	31-May-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	18:20 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
218	31-May-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
219	31-May-2020	BAGALKOT	220	RAVIURJA1(KAKAMARI)-ATHANI	ATHANI_220	11:11	15:53	4:42	LINE CLEAR AVAILED
220	31-May-2020	BAGALKOT	220	RAVIURJA1(KAKAMARI)-ATHANI	ATHANI_220	16:31	18:07	1:36	LINE FAULT
221	31-May-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	ATHANI_220	16:31	17:43	1:12	LINE FAULT
222	31-May-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	ATHANI_220	17:49 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
223	31-May-2020	BAGALKOT	110	110/11KV,HV1	ATHANI_220	16:35	17:02	0:27	HAND TRIPPED
224	31-May-2020	BAGALKOT	110	ANKOLA-KUMTA2	KUMTA_110	0:17	8:51	8:34	LINE FAULT
225	31-May-2020	BAGALKOT	220	220/110KV,HV1,LV1	BAGALKOT_220	6:44	8:21	1:37	LINE CLEAR AVAILED
226	31-May-2020	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	17:04 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
227	31-May-2020	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	6:42	8:44	2:02	LINE CLEAR AVAILED
228	31-May-2020	BAGALKOT	110	NARENDRA2-BELUR 2	BELUR_110	16:54 (31.05.2020)			LINE OPEN, LINE FAULT
229	31-May-2020	BAGALKOT	110	BAGEWADI-RAMPUR(NIDAGUNDI)	NIDAGUNDI_110	14:01	14:08	0:07	LINE FAULT
230	31-May-2020	BAGALKOT	110	BAGEWADI-SINDAGI	SINDAGI_110	18:09	18:35	0:26	LINE FAULT
231	31-May-2020	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	10:44	14:35	3:51	LINE CLEAR AVAILED
232	31-May-2020	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	10:16	14:32	4:16	LINE CLEAR AVAILED
233	31-May-2020	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	8:27	13:25	4:58	LINE CLEAR AVAILED
234	31-May-2020	BAGALKOT	110	BIJAPUR220-BIJAPUR CITY	BIJAPUR_220	21:09	21:21	0:12	LINE FAULT
235	31-May-2020	BAGALKOT	110	110/11KV,HV1(HV5)	GHATAPRABHA_110	1:07	1:14	0:07	TRANSFORMER FAULT
236	31-May-2020	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	14:43	15:07	0:24	LINE FAULT
237	31-May-2020	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	15:10 (31.05.2020)			LINE OPEN, LINE FAULT
238	31-May-2020	BAGALKOT	110	HIDIKAL-ITNAL	HIDIKAL_110	9:01	9:14	0:13	HAND TRIPPED
239	31-May-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	9:01	9:15	0:14	HAND TRIPPED
240	31-May-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	15:46	15:53	0:07	HAND TRIPPED
241	31-May-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	20:44	20:46	0:02	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
242	31-May-2020	BAGALKOT	110	110/33KV,HV1	KALADAGI_110,BANTNUR_33,K ATWAL_33	14:55	15:00	0:05	TRANSFORMER FAULT
243	31-May-2020	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	15:00	15:10	0:10	TRANSFORMER FAULT
244	31-May-2020	BAGALKOT	110	MAHALINGAPUR(NAVALGI)- JAMAKHANDI	JAMKHANDI_110	16:50 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
245	31-May-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110,NEVARGI_33,DHULK HED,HALSANGI_33	12:04	12:11	0:07	TRANSFORMER FAULT
246	31-May-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110,NEVARGI_33,DHULK HED,HALSANGI_33	18:43	18:58	0:15	TRANSFORMER FAULT
247	31-May-2020	BAGALKOT	110	110/33KV,HV3	TIKOT_110	8:20	8:25	0:05	TRANSFORMER FAULT
248	31-May-2020	BAGALKOT	220	HUBLI - BIDANAL	HUBLI_220	10:17	14:33	4:16	LINE CLEAR AVAILED
249	31-May-2020	BAGALKOT	110	SIRSI-KUMATA 1 & KUMATA 2	SIRSI_110	0:32	1:32	1:00	LINE FAULT
250	31-May-2020	BAGALKOT	110	SIRSI-KUMATA 2	SIRSI_110	11:41	18:35	6:54	NFBC ISSUED
251	31-May-2020	BAGALKOT	110	SIRSI-KUMATA 1	SIRSI_110	9:50	18:35	8:45	NFBC ISSUED
252	31-May-2020	BAGALKOT	110	JAMAKHANDI - SHIROL	SHIROL_110	16:35	16:47	0:12	HAND TRIPPED
253	31-May-2020	BAGALKOT	220	SOUDATTI-MAHALINGPUR	SOUDATTI_220	7:19	11:10	3:51	LINE CLEAR AVAILED
254	31-May-2020	BAGALKOT	110	RON -GAMESH	RON_110,GAMESH_IPP	15:48	17:48	2:00	LINE FAULT
255	31-May-2020	BAGALKOT	110	NAVAGUND-KONNUR	KONNUR_110	13:39	13:52	0:13	LINE FAULT
256	31-May-2020	BAGALKOT	110	NARENDRA220-BELUR 2	BELUR_110	16:45 (31.05.2020)			LINE OPEN, LINE FAULT
257	31-May-2020	BAGALKOT	110	NARGUND-BPCL	NARGUND_110,BPCL_IPP	13:14	14:31	1:17	LINE CLEAR AVAILED
258	31-May-2020	BAGALKOT	110	MUKARTIHAL-MATRIX	MUKARTIHAL_110,MATRIX_IPP	10:01	16:46	6:45	LINE CLEAR AVAILED
259	31-May-2020	BAGALKOT	220	220/110KV,HV1	MK HUBLI_220	11:04	12:49	1:45	LINE CLEAR AVAILED
260	31-May-2020	BAGALKOT	220	220/110KV,HV2	MK HUBLI_220	9:14	10:57	1:43	LINE CLEAR AVAILED
261	31-May-2020	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	10:59	12:50	1:51	LINE CLEAR AVAILED
262	31-May-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	9:07	10:58	1:51	LINE CLEAR AVAILED
263	31-May-2020	BAGALKOT	110	MKHUBLI 220-HIREBAGEWADI	HIREBAGEWADI_110	5:34	6:04	0:30	LINE FAULT
264	31-May-2020	BAGALKOT	110	MKHUBLI 220-KITTUR	KITTUR_110	13:35	14:12	0:37	LINE FAULT
265	31-May-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	13:44	16:12	2:28	LINE CLEAR AVAILED
266	31-May-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	19:42 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
267	31-May-2020	BAGALKOT	110	MAHALINGPUR-BANAHATTI	BANAHATTI_110	18:14	18:28	0:14	LINE FAULT
268	31-May-2020	BAGALKOT	110	KUMATA -SIRSI 1	KUMATA_110	11:50 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
269	31-May-2020	BAGALKOT	110	KUMATA -SIRSI 2	KUMATA_110	11:52 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
270	31-May-2020	BAGALKOT	110	110/33KV,HV2	KUDCHI_110, YELPHARATTI_110	20:07	20:46	0:39	TRANSFORMER FAULT
271	31-May-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)- RANEENNUR	NO STATION EFFECTED RANEENNUR_220	8:37 (31.05.2020)			LOAD CURTAILMENT
272	31-May-2020	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	18:05	18:12	0:07	LOAD CHANGE OVER
273	31-May-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:01	10:13	0:11	MAIN SUPPLY FAILURE
274	31-May-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:53	15:06	0:13	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
275	31-May-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	10:02	10:10	0:07	LINE CLEAR AVAILED
276	31-May-2020	BENGALURU	66	HV2	SOMAYAJJANAHALLI	9:40	10:08	0:28	TRANSFORMER FAULT
277	31-May-2020	BENGALURU	220	HV1	VIKAS TECH PARK 220	10:02	10:30	0:28	MAIN SUPPLY FAILURE
278	31-May-2020	BENGALURU	220	HV2	VIKAS TECH PARK 220	10:02	10:30	0:28	MAIN SUPPLY FAILURE
279	31-May-2020	BENGALURU	66	ADUGODI - JAKKASANDRA	ADUGODI	6:07	6:15	0:08	MAIN SUPPLY FAILURE
280	31-May-2020	BENGALURU	66	HV1	KAMASAMUDRA	9:15	9:50	0:35	TRANSFORMER FAULT
281	31-May-2020	BENGALURU	66	IRGAMPALLI - CHINTAMANI 220	IRGAMPALLI	17:22	17:36	0:13	LINE FAULT
282	31-May-2020	BENGALURU	66	KADUBISANAHALLI - BAGHMANE WORLD TECH PARK	KADUBISANAHALLI, CESSNA (EHT)	8:50	8:55	0:05	LOAD CHANGE OVER
283	31-May-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:39	16:50	0:11	LINE FAULT
284	31-May-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	7:47	9:39	1:52	LINE CLEAR AVAILED
285	31-May-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	15:51	17:03	1:11	LINE CLEAR AVAILED
286	31-May-2020	BENGALURU	66	HV1	M GOLLAHALLI	17:20	19:20	2:00	TRANSFORMER FAULT
287	31-May-2020	BENGALURU	66	HV2	BOODIGERE	11:03	12:51	1:48	TRANSFORMER FAULT
288	31-May-2020	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	7:47	9:34	1:47	LINE CLEAR AVAILED
289	31-May-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	9:53	10:09	0:16	LOAD CHANGE OVER
290	31-May-2020	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	15:01	15:03	0:02	LOAD CHANGE OVER
291	31-May-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	5:28	5:36	0:08	LINE FAULT
292	31-May-2020	BENGALURU	66	GOLF LINK - HSR LAYOUT 220	GOLF LINK	9:25	9:35	0:10	LOAD CHANGE OVER
293	31-May-2020	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	8:25	8:30	0:05	LOAD CHANGE OVER
294	31-May-2020	BENGALURU	66	HANUMANTHNAGAR - YEDUMADU	YEDUMADU	14:34	14:46	0:12	LINE FAULT
295	31-May-2020	BENGALURU	66	HANUMANTHNAGAR - YEDUMADU	YEDUMADU	14:46	16:50	2:04	LINE FAULT
296	31-May-2020	BENGALURU	66	HANUMANTHNAGAR - YEDUMADU	YEDUMADU	16:50	17:50	1:00	LINE CLEAR AVAILED
297	31-May-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
298	31-May-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
299	31-May-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
300	31-May-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	23:25(29-5-2020)			LINE OPEN, LINE FAULT
301	31-May-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
302	31-May-2020	GULBARGA	220	KAPNOOR-HUMNABAD2	KAPNOOR_220	17:18	18:30	1:12	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
303	31-May-2020	GULBARGA	220	KAPNOOR-SHAHABAD	NO STATION AFFECTED	17:15(17.4.2020)	18:31	337:16HRS	LINE CHARGED
304	31-May-2020	GULBARGA	220	HV1	KUSHTAGI_220	20:23	20:53	0:30	TRANSFORMER FAULT
305	31-May-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	17:28	18:08	0:40	LINE FAULT
306	31-May-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	18:08(31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
307	31-May-2020	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	17:00	18:55	1:55	LINE CLEAR AVAILED
308	31-May-2020	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	17:00	18:30	1:30	LINE CLEAR AVAILED
309	31-May-2020	GULBARGA	220	HUMNABAD-KAPNOOR2	HUMNABAD_220	17:17	18:30	1:13	LINE CLEAR AVAILED
310	31-May-2020	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	13:31	19:49	6:18	LINE FAULT
311	31-May-2020	GULBARGA	220	LINGAPUR-JVSL2	LINGAPUR_220	15:05	19:44	4:39	LINE FAULT
312	31-May-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	5:07	5:28	0:21	LINE FAULT
313	31-May-2020	GULBARGA	110	HV1	MALLAT_220	8:52	9:07	0:15	TRANSFORMER FAULT
314	31-May-2020	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	20:30	20:58	0:28	MAIN SUPPLY FAILURE
315	31-May-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	4:06	4:13	0:07	LINE FAULT
316	31-May-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	23:43	23:56	0:13	LINE FAULT
317	31-May-2020	GULBARGA	110	SINDHANOOR-SIRUGUPPA	SIRUGUPPA_110, TEKKALKOTE_110, DHAHDESUGUR_110, NSL SUGARS_IPP	23:44	23:58	0:14	LINE FAULT
318	31-May-2020	GULBARGA	110	HV2	SHORAPUR_110	18:35	18:47	0:12	TRANSFORMER FAULT
319	31-May-2020	GULBARGA	110	HV2	DEODURGA_110	16:28	16:40	0:12	TRANSFORMER FAULT
320	31-May-2020	GULBARGA	110	HV2	KEMBHAVI_110	16:09	16:16	0:07	TRANSFORMER FAULT
321	31-May-2020	GULBARGA	110	HV3	KEMBHAVI_110	16:30	16:35	0:05	TRANSFORMER FAULT
322	31-May-2020	GULBARGA	110	HV2	HATTI_110	21:49	21:55	0:06	TRANSFORMER FAULT
323	31-May-2020	GULBARGA	110	HV4	KUSHTAGI_220	21:04	23:59	2:55	TRANSFORMER FAULT
324	31-May-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREEN_IPP,NALWAR_110	18:53	19:40	0:47	LINE FAULT
325	31-May-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREEN_IPP,NALWAR_110	19:40	21:05	1:25	LINE CLEAR AVAILED
326	31-May-2020	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	17:25	17:30	0:05	LINE FAULT
327	31-May-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
328	31-May-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	17:19 (21.05.2020)			LINE OPEN, LINE CLEAR AVAILED
329	31-May-2020	HASSAN	110	JOG-AMBTR2	STATION NOT AFFECTED	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
330	31-May-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	3:50 (31.05.2020)			LINE OPEN, LINE FAULT
331	31-May-2020	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	3:50 (31.05.2020)			LINE OPEN, LINE FAULT
332	31-May-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	14:36(31.05.2020)			LINE CLEAR AVAILED
333	31-May-2020	HASSAN	66	HASSN22-HN PURA	HASSAN_220	16:05	20:58	4:53	LINE FAULT
334	31-May-2020	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	23:48	23:49	0:01	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
335	31-May-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	6:18	12:56	6:38	LINE FAULT
336	31-May-2020	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	6:13	12:55	6:42	LINE FAULT
337	31-May-2020	HASSAN	110	HV2	HALADY_110	8:14	8:34	0:20	TRANSFORMER FAULT
338	31-May-2020	HASSAN	110	HV2	HALADY_110	19:41	20:08	0:27	LINE CLEAR AVAILED
339	31-May-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	23:45	23:52	0:07	MAIN SUPPLY FAILURE
340	31-May-2020	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	23:45	23:51	0:06	MAIN SUPPLY FAILURE
341	31-May-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	23:45	23:52	0:07	MAIN SUPPLY FAILURE
342	31-May-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	7:52	8:06	0:14	LINE FAULT
343	31-May-2020	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	17:03	17:32	0:29	LINE FAULT
344	31-May-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	9:00	16:54	7:54	LINE CLEAR AVAILED
345	31-May-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	9:00	16:54	7:54	LINE CLEAR AVAILED
346	31-May-2020	HASSAN	66	HV1	SAKLESHPURA_66	3:26	3:35	0:09	TRANSFORMER FAULT
347	31-May-2020	HASSAN	110	HV2	HOSANGADI_110	15:16	19:38	4:22	TRANSFORMER FAULT
348	31-May-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN,LOAD CHANGE OVER
349	31-May-2020	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	16:59	17:00	0:01	LINE FAULT
350	31-May-2020	MYSURU	66	HV2	DEVANOORNGUDU_66	22:21	22:30	0:08	TRANSFORMER FAULT
351	31-May-2020	MYSURU	66	HV2	HAMPAPURA_66	18:16	18:49	0:33	LINE CLEAR AVAILED
352	31-May-2020	MYSURU	66	HONNALLY-ATTIGULIPURA	ATTIGULIPURA_66	7:33	7:50	0:16	LINE FAULT
353	31-May-2020	MYSURU	66	HOOTAGALLI-BEML	NO STATIONS EFFECTED	10:02	13:40	3:37	LINE CLEAR AVAILED
354	31-May-2020	MYSURU	66	METAGALLY-HEBBAL	HEBBAL_66 METAGALLY_66	10:01	16:29	6:28	LINE CLEAR AVAILED
355	31-May-2020	MYSURU	66	NANJANGUDU -BEGUR	NO STATIONS EFFECTED	9:29	17:36	8:07	LINE CLEAR AVAILED
356	31-May-2020	MYSURU	66	NANJANGUDU -KADAKOLA 1	NANJANGUDU_66	9:29	17:26	7:56	LINE CLEAR AVAILED
357	31-May-2020	MYSURU	66	NANJANGUDU -KADAKOLA 2	THANDYA_66	9:29	17:26	7:56	LINE CLEAR AVAILED
358	31-May-2020	MYSURU	66	HV1	SANIVARASANTHE_66	1:34	1:38	0:04	TRANSFORMER FAULT
359	31-May-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66	10:16	13:51	3:35	LINE CLEAR AVAILED
360	31-May-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)	-	-	LINE OPEN, LINE FAULT
361	31-May-2020	TUMKUR	66	ANCHEPALYA 220kv-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	11:51	12:23	0:32	LINE CLEAR AVAILED
362	31-May-2020	TUMKUR	66	ANCHEPALYA 220kv-HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	10:20	12:07	1:46	LINE CLEAR AVAILED
363	31-May-2020	TUMKUR	66	ANCHEPALYA 220kv-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	11:03	11:17	0:13	LINE CLEAR AVAILED
364	31-May-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	8:07	8:24	0:16	TRANSFORMER FAULT
365	31-May-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	19:04	19:06	0:01	TRANSFORMER FAULT
366	31-May-2020	TUMKUR	66	TR-2	CHITRADURGA_220	11:21	13:26	2:05	LINE CLEAR AVAILED
367	31-May-2020	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	16:23	16:43	0:19	LINE FAULT
368	31-May-2020	TUMKUR	66	TR-3	HARIYABBE_66	16:22	16:29	0:07	TRANSFORMER FAULT
369	31-May-2020	TUMKUR	66	KUNDUR- RSOLAR	RENEW WIND ENERGY_IPP_66	16:42	17:26	0:43	HAND TRIPPED
370	31-May-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,R AMAGIRI_66	11:05	11:14	0:09	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
371	31-May-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,R AMAGIRI_66	11:15	11:26	0:11	LINE FAULT
372	31-May-2020	TUMKUR	66	TR-2	HINDASGHATTA_66	18:25	19:05	0:40	TRANSFORMER FAULT
373	31-May-2020	TUMKUR	66	TR-2	HINDASGHATTA_66	19:55	20:15	0:20	TRANSFORMER FAULT
374	31-May-2020	TUMKUR	66	TR-2	HINDASGHATTA_66	22:02	22:17	0:15	TRANSFORMER FAULT
375	31-May-2020	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	17:44	18:08	0:24	LINE FAULT
376	31-May-2020	TUMKUR	66	PAVAGADA 66- PAVAGADA 220	PAVAGADA_66	17:44	18:08	0:24	LINE FAULT
377	31-May-2020	TUMKUR	66	PAVAGADA 66- PAVAGADA 220	PAVAGADA_66	18:08	18:22	0:13	LINE FAULT
378	31-May-2020	TUMKUR	66	TR-2	THOVINAKERE_66	9:14	9:43	0:28	LINE CLEAR AVAILED
1	1-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	1-Jun-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
3	1-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
4	1-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
5	1-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
6	1-Jun-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)- GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)			LINE OPEN, LINE CLEAR AVAILED
7	1-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
8	1-Jun-2020	BAGALKOT	110	RATTIHALI-HIREKERUR	RATTIHALI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
9	1-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
10	1-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
11	1-Jun-2020	BAGALKOT	110	BADAMI-HIREHAL	NO STATION EFFECTED HIREHAL_110	7:49 (29.05.2020)	12:20 (01.06.2020)	76:31hrs	LINE CHARGED
12	1-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	6:58 (30.05.2020)	18:15 (01.06.2020)	59:17hrs	LINE CHARGED
13	1-Jun-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	18:20 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
14	1-Jun-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
15	1-Jun-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	ATHANI_220	17:49 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
16	1-Jun-2020	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	17:04 (31.05.2020)	10:13 (01.06.2020)	11:09:00	LINE CHARGED
17	1-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	15:10 (31.05.2020)	8:50 (01.06.2020)	17:00hrs	LINE CHARGED
18	1-Jun-2020	BAGALKOT	110	MAHALINGAPUR(NAVALGI)- JAMAKHANDI	JAMKHANDI_110	16:50 (31.05.2020)	12:40 (01.06.2020)	19:50hrs	LINE CHARGED
19	1-Jun-2020	BAGALKOT	110	NARENDRA220-BELUR 2	BELUR_110	16:45 (31.05.2020)	11:58 (01.06.2020)	19:04hrs	LINE CHARGED
20	1-Jun-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	19:42 (31.05.2020)	10:44 (01.06.2020)	15:02hrs	LINE CHARGED
21	1-Jun-2020	BAGALKOT	110	KUMATA -SIRSI 1	KUMATA_110	11:50 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
22	1-Jun-2020	BAGALKOT	110	KUMATA -SIRSI 2	KUMATA_110	11:52 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
23	1-Jun-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)- RANEENNUR	NO STATION EFFECTED RANEENNUR_220	8:37 (31.05.2020)			LOAD CURTAILMENT
24	1-Jun-2020	BAGALKOT	110	BIJAPUR 220-BIJAPUR	BIJAPUR_110	10:41	10:56	0:15	LINE CLEAR AVAILED
25	1-Jun-2020	BAGALKOT	220	ALAMATT 1-BAGALKOT	BAGALKOT_220	9:45 (01.06.2020)			LINE OPEN, LINE FAULT
26	1-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	23:06 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
27	1-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	17:54	18:28	0:34	LINE FAULT
28	1-Jun-2020	BAGALKOT	220	BELGAUM-NARENDRA 2	BELGAUM_220	17:54	18:28	0:34	LINE FAULT
29	1-Jun-2020	BAGALKOT	220	220/110KV,HV 2 &LV 2	CHIKKODI_220	6:02	8:21	2:19	TRANSFORMER FAULT
30	1-Jun-2020	BAGALKOT	220	220/110KV,HV 2 &LV 2	CHIKKODI_220	10:23	15:24	5:01	TRANSFORMER FAULT
31	1-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	14:19	15:44	1:25	LINE CLEAR AVAILED
32	1-Jun-2020	BAGALKOT	110	HIREHAL-RON	HIREHAL_110	12:53	16:31	3:38	LINE CLEAR AVAILED
33	1-Jun-2020	BAGALKOT	110	ITANAL-RAIBAG 2	ITANAL_110	19:53	20:00	0:07	LINE FAULT
34	1-Jun-2020	BAGALKOT	110	ITANAL-BORUKHA	ITANAL_110	19:53	22:42	2:49	LINE FAULT
35	1-Jun-2020	BAGALKOT	110	110/33KV,HV1&2	JAMAKHANDI_110 & HIPPARAGI_33	6:53	8:57	2:04	LINE CLEAR AVAILED
36	1-Jun-2020	BAGALKOT	110	110/11KV ,HV1	YELPHARATTI_110	14:05	14:31	0:26	LINE CLEAR AVAILED
37	1-Jun-2020	BAGALKOT	220	VAJRAMATTI-KAVATAGI LIS	VAJRAMATTI_220,KAVATAGI_ LIS	16:22	17:15	0:53	LINE FAULT
38	1-Jun-2020	BAGALKOT	220	VAJRAMATTI-MAHALINGPUR 1	VAJRAMATTI_220	17:56 (01.06.2020)			LINE OPEN, LINE FAULT
39	1-Jun-2020	BAGALKOT	110	110/11KV,HV2	TIKOT_110	18:22	18:28	0:06	TRANSFORMER FAULT
40	1-Jun-2020	BAGALKOT	220	HUBLI-SIRSI 1	HUBLI_220	10:48	12:18	1:30	LINE FAULT
41	1-Jun-2020	BAGALKOT	110	NAVALGUND-KONNUR	NAVALGUND_110	13:55	15:27	1:32	NFBC ISSUED
42	1-Jun-2020	BAGALKOT	110	PG HUNSYAL-NAGANUR	NAGANUR_110,MUDALAGI_11 O,KULIGOD_110	1:27	1:37	0:10	LINE FAULT
43	1-Jun-2020	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	8:47	11:56	3:09	LINE CLEAR AVAILED
44	1-Jun-2020	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	21:35	23:26	1:51	TRANSFORMER FAULT
45	1-Jun-2020	BAGALKOT	110	MK HUBLI 220-MK HUBLI 2(KITTUR)	MK HUBLI_110	15:53	16:08	0:15	LINE CLEAR AVAILED
46	1-Jun-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	17:12	18:35	1:23	LINE CLEAR AVAILED
47	1-Jun-2020	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	17:13	20:18	3:05	LINE CLEAR AVAILED
48	1-Jun-2020	BAGALKOT	110	MK HUBLI-KITTUR	KITTUR_110	15:48	16:09	0:21	LINE CLEAR AVAILED
49	1-Jun-2020	BAGALKOT	110	110/11,HV1	LAXMESHVAR_110	15:42	16:02	0:20	LINE CLEAR AVAILED
50	1-Jun-2020	BAGALKOT	110	110/11,HV2	LAXMESHVAR_110	16:10	16:30	0:20	LINE CLEAR AVAILED
51	1-Jun-2020	BAGALKOT	110	110/11KV,HV 1	YELPARAHATTI_110	14:05	14:31	0:26	HAND TRIPPED
52	1-Jun-2020	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	19:25	19:26	0:01	TRANSFORMER FAULT
53	1-Jun-2020	BENGALURU	66	HV1	ATTIBELE	13:12	13:34	0:22	LINE CLEAR AVAILED
54	1-Jun-2020	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	20:40	20:55	0:15	LOAD CURTAILMENT
55	1-Jun-2020	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	23:35	23:40	0:05	LOAD CURTAILMENT
56	1-Jun-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	20:28	20:34	0:06	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
57	1-Jun-2020	BENGALURU	66	KEMPAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	20:34	22:05	1:31	LINE FAULT
58	1-Jun-2020	BENGALURU	66	KEMPAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	22:05	23:00	0:55	LINE CLEAR AVAILED
59	1-Jun-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	12:47	12:52	0:05	LINE FAULT
60	1-Jun-2020	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 2	NO STATION AFFECTED	18:05	18:56	0:51	LINE FAULT
61	1-Jun-2020	BENGALURU	66	YELAHANKA 220 - KANASWADI	KANASWADI	5:50	6:12	0:22	LINE FAULT
62	1-Jun-2020	BENGALURU	220	HV1	TK HALLI	12:17	12:49	0:32	LINE CLEAR AVAILED
63	1-Jun-2020	BENGALURU	220	HV2	TK HALLI	12:50	13:05	0:15	LINE CLEAR AVAILED
64	1-Jun-2020	BENGALURU	66	HV2	SOLDEVANAHALLI	13:21	13:22	0:01	LINE CLEAR AVAILED
65	1-Jun-2020	BENGALURU	66	HV1	SOLDEVANAHALLI	11:05	11:10	0:05	LINE CLEAR AVAILED
66	1-Jun-2020	BENGALURU	66	HV2	RR NAGAR	14:35	14:46	0:11	LINE CLEAR AVAILED
67	1-Jun-2020	BENGALURU	66	SOLDEVANAHALLI - YELAHANKA 220	SOLDEVANAHALLI	15:10	15:15	0:05	LOAD CHANGE OVER
68	1-Jun-2020	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	15:58	16:03	0:05	LOAD CHANGE OVER
69	1-Jun-2020	BENGALURU	66	HV1	RR NAGAR	11:11 (1-6-2020)			LINE CLEAR AVAILED
70	1-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
71	1-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
72	1-Jun-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
73	1-Jun-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	23:25:00(29/05/2020)			LINE OPEN, LINE FAULT
74	1-Jun-2020	GULBARGA	400	JSWL-GUTTUR	JSWL_400	3:01(1.6.2020)	16:50(2.6.2020)		LINE OPEN, LINE FAULT
75	1-Jun-2020	GULBARGA	400	YTPS-BPS1	YTPS_400	21:16(1.6.2020)			LINE OPEN, LINE CLEAR AVAILED
76	1-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
77	1-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	10:05(1.6.2020)			NFBC ISSUED
78	1-Jun-2020	GULBARGA	220	HV1	KUSHTAGI_220	20:32	20:52	0:20	TRANSFORMER FAULT
79	1-Jun-2020	GULBARGA	220	HV1	KUSHTAGI_220	23:22	23:55	0:33	TRANSFORMER FAULT
80	1-Jun-2020	GULBARGA	220	ALIPUR-GOOTY1	ALIPUR_220	21:31	22:35	1:04	LINE FAULT
81	1-Jun-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	18:08(31.05.2020)	12:27	18:19HRS	LINE CHARGED
82	1-Jun-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	3:36	4:12	0:36	LINE FAULT
83	1-Jun-2020	GULBARGA	220	JSWL-LINGAPUR2	JSWVL_220	18:57	22:40	3:43	LINE FAULT
84	1-Jun-2020	GULBARGA	220	ITTAGI-NEELANGUNDA	NEELANGUNDA_220	18:25(1.6.2020)			LINE FAULT
85	1-Jun-2020	GULBARGA	220	HV2	ITTAGGI_220	18:25	18:33	0:08	TRANSFORMER FAULT
86	1-Jun-2020	GULBARGA	220	HV2	HUMNABAD_220	11:58	12:15	0:17	TRANSFORMER FAULT
87	1-Jun-2020	GULBARGA	220	HV2	HUMNABAD_220	12:18	14:18	2:00	LINE CLEAR AVAILED
88	1-Jun-2020	GULBARGA	110	HUMNABAD-MANNAEKHELI	MANAEKHELI_110	12:02	12:25	0:23	LINE FAULT
89	1-Jun-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	23:45(31.05.2020)	0:14	0:29 HRS	LINE CHARGED
90	1-Jun-2020	GULBARGA	110	HV4	KUSHTAGI_220	0:00	0:42	0:42	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
91	1-Jun-2020	GULBARGA	110	HV4	KUSHTAGI_220	0:42	14:30	13:48	LINE CLEAR AVAILED
92	1-Jun-2020	GULBARGA	110	HV4	KUSHTAGI_220	16:24	16:33	0:09	LINE CLEAR AVAILED
93	1-Jun-2020	GULBARGA	110	CHITAGUPPA-HUMNABAD	CHITAGUPPA_110	12:00	12:10	0:10	MAIN SUPPLY FAILURE
94	1-Jun-2020	GULBARGA	110	CHITAGUPPA-HUMNABAD	CHITAGUPPA_110	13:35	13:40	0:05	MAIN SUPPLY FAILURE
95	1-Jun-2020	GULBARGA	110	HV2	DEODURGA_110	12:45	12:55	0:10	TRANSFORMER FAULT
96	1-Jun-2020	GULBARGA	110	HV2	DEODURGA_110	12:28	12:43	0:15	TRANSFORMER FAULT
97	1-Jun-2020	GULBARGA	110	PDHALLI-CLNSLR	PD_HALLI_110	10:46	10:57	0:11	LOAD CURTAILMENT
98	1-Jun-2020	GULBARGA	110	HV1	KUDITINI	13:55	14:08	0:13	LINE CLEAR AVAILED
99	1-Jun-2020	GULBARGA	110	HV2	SINDHANOOR_110	9:51	9:56	0:05	TRANSFORMER FAULT
100	1-Jun-2020	GULBARGA	110	HV2	YELBURGA_110	12:32	12:42	0:10	TRANSFORMER FAULT
101	1-Jun-2020	GULBARGA	110	HV1	MADIYAL	17:05	17:16	0:11	TRANSFORMER FAULT
102	1-Jun-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	18:45	18:50	0:05	MAIN SUPPLY FAILURE
103	1-Jun-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	22:43	22:57	0:14	LINE FAULT
104	1-Jun-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_I PP	19:50	19:58	0:08	LINE FAULT
105	1-Jun-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	2:09	2:32	0:23	LINE FAULT
106	1-Jun-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	2:55	3:08	0:13	LINE FAULT
107	1-Jun-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110, MUDDAPUR_110	22:42	22:53	0:11	LINE FAULT
108	1-Jun-2020	GULBARGA	110	SINDHANOOR-SIRUGUPPA	SIRUGUPPA_110, TEKKALKOTE_110, DHAHDESUGUR_110, NSL SUGARS_IPP	0:15	0:47	0:32	LINE CLEAR AVAILED
109	1-Jun-2020	GULBARGA	110	SINDHANOOR-SIRUGUPPA	SIRUGUPPA_110, TEKKALKOTE_110, DHAHDESUGUR_110, NSL SUGARS_IPP	3:45	4:00	0:15	LINE FAULT
110	1-Jun-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	23:17	23:34	0:17	LINE FAULT
111	1-Jun-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	4:34	4:49	0:15	LINE FAULT
112	1-Jun-2020	GULBARGA	110	HV2	SHAKTINAGAR_110	10:59	12:38	1:39	LINE CLEAR AVAILED
113	1-Jun-2020	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	6:39	7:11	0:32	LINE FAULT
114	1-Jun-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	21:39	21:51	0:12	LINE FAULT
115	1-Jun-2020	GULBARGA	66	ITTAGI-KUDLIGI1&2	KUDLIGI_66,KOGALI_66,HANAS I_66,CJHALLI_66,GUDEKOTE_66,CHORNOOR_66,HOSAHALI_66,BANVEKAL_66	11:55	12:05	0:10	LINE FAULT
116	1-Jun-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	4:25	4:49	0:24	LINE FAULT
117	1-Jun-2020	GULBARGA	220	SEDAM-SHRECEMENT_IPP	SEDAM_220	10:34	12:58	2:24	LINE CLEAR AVAILED
118	1-Jun-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	17:19 (21.05.2020)	12:54	259:34 hrs	LINE CHARGED
119	1-Jun-2020	HASSAN	66	BHADRA-SHMG 1	bhadra_gen	14:36(31.05.2020)	11:53	21.17hrs	LINE CHARGED
120	1-Jun-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
121	1-Jun-2020	HASSAN	110	JOG-AMBTR2	STATION NOT AFFECTED	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
122	1-Jun-2020	HASSAN	220	GERSOPA-TALGUPA1	STATION NOT AFFECTED	3:50 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
123	1-Jun-2020	HASSAN	220	MRSSHM-STRP1	STATION NOT AFFECTED	3:50 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
124	1-Jun-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
125	1-Jun-2020	HASSAN	110	HV1	NANDIKUR_110	23:02 (01.06.2020)			MAIN SUPPLY FAILURE
126	1-Jun-2020	HASSAN	220	HV1	KEMAR_220	10:53	11:55	1:02	LINE CLEAR AVAILED
127	1-Jun-2020	HASSAN	220	HV2	KEMAR_220	11:54	11:56	0:02	HAND TRIPPED
128	1-Jun-2020	HASSAN	220	HV3	KEMAR_220	12:00	12:03	0:03	HAND TRIPPED
129	1-Jun-2020	HASSAN	110	HV1	KEMAR_220	12:28	19:46	7:18	LINE CLEAR AVAILED
130	1-Jun-2020	HASSAN	110	HV2	KEMAR_220	12:28	12:41	0:13	HAND TRIPPED
131	1-Jun-2020	HASSAN	110	LV1	KEMAR_220	10:53	11:55	1:02	LINE CLEAR AVAILED
132	1-Jun-2020	HASSAN	110	LV2	KEMAR_220	11:54	11:56	0:02	HAND TRIPPED
133	1-Jun-2020	HASSAN	110	LV3	KEMAR_220	12:00	12:03	0:03	HAND TRIPPED
134	1-Jun-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:57	17:13	3:16	LINE CLEAR AVAILED
135	1-Jun-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	8:25	12:38	4:13	LINE CLEAR AVAILED
136	1-Jun-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	10:03	11:54	1:51	LINE CLEAR AVAILED
137	1-Jun-2020	HASSAN	110	HV2	MSEZ_220	23:30	23:49	0:19	TRANSFORMER FAULT
138	1-Jun-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:56	17:13	3:17	LINE CLEAR AVAILED
139	1-Jun-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	8:26	12:38	4:12	LINE CLEAR AVAILED
140	1-Jun-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	8:37	18:20	9:43	LINE CLEAR AVAILED
141	1-Jun-2020	HASSAN	66	HIREMAN-RDL	HIREMANGALUR_66	7:35	17:48	10:13	LINE CLEAR AVAILED
142	1-Jun-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_110	14:06	15:41	1:35	NFBC ISSUED
143	1-Jun-2020	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_110	11:55	14:59	3:04	MAIN SUPPLY FAILURE
144	1-Jun-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	10:13	18:37	8:24	LINE CLEAR AVAILED
145	1-Jun-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	10:13	18:37	8:24	LINE CLEAR AVAILED
146	1-Jun-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	11:56	14:53	2:57	LINE FAULT
147	1-Jun-2020	HASSAN	66	HV2	KIADB_66	18:53	19:02	0:09	LINE CLEAR AVAILED
148	1-Jun-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN,LOAD CHANGE OVER
149	1-Jun-2020	MYSURU	66	HONNALLY-ATTIGULIPURA	ATTIGULIPURA_66	15:12	15:40	0:27	LINE FAULT
150	1-Jun-2020	MYSURU	66	HV1	KADAKOLA_220	11:07	14:05	2:58	LINE CLEAR AVAILED
151	1-Jun-2020	MYSURU	66	HV2	KADAKOLA_220	11:07	11:35	0:28	LINE CLEAR AVAILED
152	1-Jun-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	5:59	6:05	0:05	LINE FAULT
153	1-Jun-2020	MYSURU	66	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	12:43	12:50	0:07	LINE FAULT
154	1-Jun-2020	MYSURU	66	HV1	TARIPURA_66	11:32	12:11	0:39	LINE CLEAR AVAILED
155	1-Jun-2020	MYSURU	66	TARIPURA-MHS	NO STATIONS EFFECTED	11:32	12:11	0:39	LINE CLEAR AVAILED
156	1-Jun-2020	MYSURU	66	HV2	BGNAGARA_66	14:25	15:55	1:30	LINE CLEAR AVAILED
157	1-Jun-2020	MYSURU	66	HV1	VADERALLI_66	11:00	13:10	2:10	LINE CLEAR AVAILED
158	1-Jun-2020	MYSURU	66	HV1	KRPET_66	12:17	13:05	0:48	LINE CLEAR AVAILED
159	1-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE FAULT
160	1-Jun-2020	TUMKUR	220	NEELAGUNDA220KV- ITTAGI 220kV	NEELAGUNDA_220	18:22:40(01.06.2020)			LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
161	1-Jun-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:06	14:28	2:21	LINE CLEAR AVAILED
162	1-Jun-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	0:14	1:05	0:51	LINE FAULT
163	1-Jun-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:45	15:45	4:59	LINE CLEAR AVAILED
164	1-Jun-2020	TUMKUR	110	TR-2	NITTUR_220	14:16	14:25	0:09	LINE CLEAR AVAILED
165	1-Jun-2020	TUMKUR	110	TR-1	SAMPIGE_110	16:06	16:25	0:19	TRANSFORMER FAULT
166	1-Jun-2020	TUMKUR	66	ANTHRASANAHALLI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	19:00	19:23	0:22	LINE FAULT
167	1-Jun-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	19:21	19:24	0:02	HAND TRIPPED
168	1-Jun-2020	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:02	17:33	0:31	LINE FAULT
169	1-Jun-2020	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:52	19:08	0:15	LINE FAULT
170	1-Jun-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:27	11:39	0:11	LINE FAULT
171	1-Jun-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	19:02	19:23	0:20	LINE FAULT
172	1-Jun-2020	TUMKUR	66	TR-1	GARAGA_66	10:24	12:42	2:17	LINE CLEAR AVAILED
173	1-Jun-2020	TUMKUR	66	TR-1	GARAGA_66	16:30	18:28	1:58	LINE CLEAR AVAILED
174	1-Jun-2020	TUMKUR	66	TR-2	GARAGA_66	12:42	15:50	3:08	LINE CLEAR AVAILED
175	1-Jun-2020	TUMKUR	66	TR-1	HALUVAGALU_66	14:01	14:21	0:19	TRANSFORMER FAULT
176	1-Jun-2020	TUMKUR	66	HANAGAL- B G KERE 1	BGKERE_66,GUDEKOTE_66	19:25	19:35	0:10	HAND TRIPPED
177	1-Jun-2020	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	16:32	16:55	0:22	LINE FAULT
178	1-Jun-2020	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:28	11:39	0:11	LINE FAULT
179	1-Jun-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	16:15	16:29	0:14	LINE FAULT
180	1-Jun-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	11:42	12:16	0:33	LINE CLEAR AVAILED
181	1-Jun-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:02	13:14	0:11	LINE FAULT
182	1-Jun-2020	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:21	13:38	0:16	LINE FAULT
183	1-Jun-2020	TUMKUR	66	TR-1	KATTIGE_66	15:05	15:54	0:49	LINE CLEAR AVAILED
184	1-Jun-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:11	8:24	0:12	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
185	1-Jun-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:14	14:22	0:08	LINE FAULT
186	1-Jun-2020	TUMKUR	66	TR-2	MANGALWADA_66	14:05	14:09	0:04	TRANSFORMER FAULT
187	1-Jun-2020	TUMKUR	66	NEELAGUNDA220kV-HARPANAHALLI-1	HARAPPANAHALLI_66	7:49	8:27	0:37	LINE FAULT
188	1-Jun-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	7:46	11:25	3:38	TRANSFORMER FAULT
189	1-Jun-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,R AMAGIRI_66	15:42	15:59	0:17	LINE FAULT
190	1-Jun-2020	TUMKUR	66	TR-1	PAVAGADA_220	1:26	1:29	0:03	TRANSFORMER FAULT
191	1-Jun-2020	TUMKUR	66	TR-1	PAVAGADA_220	18:14	18:56	0:42	TRANSFORMER FAULT
192	1-Jun-2020	TUMKUR	66	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	18:36	18:45	0:09	LINE FAULT
193	1-Jun-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	13:15	17:15	4:00	LINE CLEAR AVAILED
194	1-Jun-2020	TUMKUR	66	SIRA- BUKKAPATNA	SIRA_66	13:43	14:31	0:47	LINE FAULT
195	1-Jun-2020	TUMKUR	66	UCHANGIDURGA-I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	17:03	17:15	0:11	LINE FAULT