

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 27.11.2018 to 03.12.2018

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	27-Nov-18	BAGALKOT	110	BELLATTI - ENERCON 2	BELLATTI_110	11:55	13:03	1:08	LINE CLEAR AVAILED
2	27-Nov-18	BAGALKOT	110	GADAG ROAD -GOANAKOPPA	GADAG ROAD_110	11:28	11:32	0:04	HAND TRIPPED
3	27-Nov-18	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJANAGR	MRUTYUNJAYANAGAR_110	11:32	12:52	1:20	HAND TRIPPED
4	27-Nov-18	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJANAGR 2	MRUTYUNJAYANAGAR_110	11:35	12:52	1:17	HAND TRIPPED
5	27-Nov-18	BAGALKOT	110	GAOPANAKOPPA-GADAG ROAD	GADAG ROAD_110	12:52	12:57	0:05	HAND TRIPPED
6	27-Nov-18	BAGALKOT	110	NARENDRA-KUD DHARAWAD_110	KUD DHARAWAD_110	11:20	13:00	1:40	HAND TRIPPED
7	27-Nov-18	BAGALKOT	110	MALAGAHN- MANALI SUGARS	MALAGAHAN_110	1:03	1:09	0:06	LINE FAULT
8	27-Nov-18	BAGALKOT	110	NARAGUND -BPCL	NARAGUND_110_110	12:11	16:22	4:11	HAND TRIPPED
9	27-Nov-18	BAGALKOT	110	TARIHAL-NAVANAGAR(H)	NAVANAGAR(H)_109	10:51	10:58	0:07	HAND TRIPPED
10	27-Nov-18	BAGALKOT	110	TARIHAL-NAVANAGAR(H)	NAVANAGAR(H)_110	13:08	13:18	0:10	HAND TRIPPED
11	27-Nov-18	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	17:41	17:45	0:04	HAND TRIPPED
12	27-Nov-18	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	10:39	13:31	2:52	NBFC ISSUED
13	27-Nov-18	BAGALKOT	110	SIRSI-KUMATA 1&2	KUMATA_110	10:04	21:00	10:56	HAND TRIPPED
14	27-Nov-18	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	15:04	15:21	0:17	TRANSFORMER FAULT
15	27-Nov-18	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	VAJRAMATTI_220	12:34	12:37	0:03	LINE FAULT
16	27-Nov-18	BAGALKOT	220	220/110KV,HV-1&LV-1	NARENDRA_110	11:41	12:47	1:06	HAND TRIPPED
17	27-Nov-18	BANGALORE	66	HV1	BAIRAKUR	11:40	12:00	0:20	LINE CLEAR AVAILED
18	27-Nov-18	BANGALORE	66	HV2	BAIRAKUR	13:35	13:50	0:15	LINE CLEAR AVAILED
19	27-Nov-18	BANGALORE	66	HV1	CHAKAVELU	14:17	15:00	0:42	LINE CLEAR AVAILED
20	27-Nov-18	BANGALORE	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	15:03	16:38	1:34	LINE FAULT
21	27-Nov-18	BANGALORE	66	KG - BEML (EHT)	BEML (EHT)	13:12	13:18	0:06	LINE FAULT
22	27-Nov-18	BANGALORE	66	HV2	KOLAR 220	14:50	15:55	1:05	LINE CLEAR AVAILED
23	27-Nov-18	BANGALORE	66	HV2	KUNDANA	15:01	15:38	0:37	LINE CLEAR AVAILED
24	27-Nov-18	BANGALORE	66	RANGANDODDI - KANAKAPURA 220	RANGANDODDI	10:01	18:13	8:11	LINE CLEAR AVAILED
25	27-Nov-18	BANGALORE	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	10:05	18:37	8:32	LINE CLEAR AVAILED
26	27-Nov-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	10:01	12:35	2:33	MAIN SUPPLY FAILURE
27	27-Nov-18	BANGALORE	66	YEDUMADU - KANAKAPURA 220	YEDUMADU	10:03	11:20	1:16	MAIN SUPPLY FAILURE
28	27-Nov-18	BANGALORE	66	HANUMANTHNAGAR - YEDUMADU	CHATRA, MARALWADI, HANUMANTHNAGAR, GODUR	10:03	11:30	1:26	MAIN SUPPLY FAILURE
29	27-Nov-18	BANGALORE	220	KANAKAPURA 220 - SOMANAHALLI 220	KANAKAPURA 220	10:00	17:30	7:30	LINE CLEAR AVAILED
30	27-Nov-18	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	10:01	18:37	8:36	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
31	27-Nov-18	BANGALORE	66	HV1	HAL 220	15:12	15:40	0:27	LINE CLEAR AVAILED
32	27-Nov-18	BANGALORE	66	APPEAREL PARK - KIADB DB PURA 220	APPEAREL PARK	13:58	14:21	0:22	LINE CLEAR AVAILED
33	27-Nov-18	BANGALORE	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	1:54	2:03	0:09	LINE FAULT
34	27-Nov-18	BANGALORE	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	5:30	5:35	0:05	LINE FAULT
35	27-Nov-18	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	2:03	2:12	0:09	LINE FAULT
36	27-Nov-18	BANGALORE	66	HV2	KANAKAPURA 66	21:52	21:55	0:03	TRANSFORMER FAULT
37	27-Nov-18	BANGALORE	66	HV2	KUMBALAGODU	13:14	14:03	0:49	LINE CLEAR AVAILED
38	27-Nov-18	BANGALORE	66	HONNIGANAHALLI - KANAKAPURA 220	HONNIGANAHALLI, DODDALAHALLI, HALAGURU	10:00	10:15	0:15	LOAD CHANGEOVER
39	27-Nov-18	BANGALORE	66	HV1	AGALAKOTE	15:12	15:15	0:03	LINE CLEAR AVAILED
40	27-Nov-18	BANGALORE	66	HV2	AGALAKOTE	13:10	15:10	2:00	LINE CLEAR AVAILED
41	27-Nov-18	GULBARGA	220	LINGAPUR-BTPS	BTPS_400	9:15	15:06	5:51	LINE CLEAR AVAILED
42	27-Nov-18	GULBARGA	220	HV1	ALIPUR_220	10:51	20:55	10:04	LINE CLEAR AVAILED
43	27-Nov-18	GULBARGA	220	HV2	ALIPUR_220	10:58	18:34	7:36	LINE CLEAR AVAILED
44	27-Nov-18	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	11:04	18:45	7:41	LINE CLEAR AVAILED
45	27-Nov-18	GULBARGA	220	ALIPUR-GOOTY	NEELAGUNDA_220	11:09	20:55	9:46	LINE CLEAR AVAILED
46	27-Nov-18	GULBARGA	110	HV2	HATTI_110	14:39	14:44	0:05	TRANSFORMER FAULT
47	27-Nov-18	GULBARGA	110	HV2	GULBARGA UNIVERSITY_110	14:05	14:50	0:45	LINE CLEAR AVAILED
48	27-Nov-18	GULBARGA	110	HV1	GULBARGA UNIVERSITY_110	14:52	15:02	0:10	LINE CLEAR AVAILED
49	27-Nov-18	GULBARGA	110	HV3	GULBARGA UNIVERSITY_110	15:15	15:45	0:30	LINE CLEAR AVAILED
50	27-Nov-18	GULBARGA	110	HV1	SIRWAR_110	14:59	15:30	0:31	LINE CLEAR AVAILED
51	27-Nov-18	GULBARGA	110	HV1,HV2	ALIPUR_220	10:41	19:19	8:38	LINE CLEAR AVAILED
52	27-Nov-18	GULBARGA	110	ALIPUR-BELLARY NORTH,BELLARY SOUTH,MUNIRABAD	PD_HALLI_110,SOMASAMUDRA_110, MOKA_110,BELLARYNORTH_110,BELL ARYSOUTH_110,HALKUNDI_110,KUDIT INI_110,KURUGOD_110,TORANGALLU _110,KAMALAPUR_110,METRI_110	10:46	19:16	8:30	LINE CLEAR AVAILED
53	27-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	17:01	17:03	0:02	LINE CLEAR AVAILED
54	27-Nov-18	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	1:13	1:17	0:04	LINE FAULT
55	27-Nov-18	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	2:30	3:45	1:15	LINE FAULT
56	27-Nov-18	GULBARGA	66	HV2	TAMBRAHALLI_66	9:08	10:01	0:53	LINE CLEAR AVAILED
57	27-Nov-18	GULBARGA	66	HV1	HANASI_66	10:59	11:18	0:19	LINE CLEAR AVAILED
58	27-Nov-18	GULBARGA	66	HV1	KOTTUR_66	8:27	8:42	0:15	TRANSFORMER FAULT
59	27-Nov-18	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	12:37	12:51	0:14	HAND TRIPPED
60	27-Nov-18	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	12:56	13:08	0:12	HAND TRIPPED
61	27-Nov-18	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	12:38	12:57	0:19	HAND TRIPPED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
62	27-Nov-18	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:00	13:05	0:05	HAND TRIPPED
63	27-Nov-18	HASSAN	220	HV1	KEMAR_220	11:04	13:18	2:14	LINE CLEAR AVAILED
64	27-Nov-18	HASSAN	110	LV1	KEMAR_220	11:04	13:19	2:15	LINE CLEAR AVAILED
65	27-Nov-18	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:37	13:07	0:30	HAND TRIPPED
66	27-Nov-18	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:20	12:26	2:06	LINE CLEAR AVAILED
67	27-Nov-18	HASSAN	110	MRSSHM-SS2	MRSMSG_220	10:46	10:48	0:02	HAND TRIPPED
68	27-Nov-18	HASSAN	110	MRSSHM-SS2	MRSMSG_220	20:09	20:18	0:09	HAND TRIPPED
69	27-Nov-18	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:37	13:07	0:30	LINE CLEAR AVAILED
70	27-Nov-18	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	12:39	13:05	0:26	LINE CLEAR AVAILED
71	27-Nov-18	HASSAN	110	HV1	HALADY_110	14:05	15:41	1:36	LINE CLEAR AVAILED
72	27-Nov-18	HASSAN	110	HV1	ANANDAPURA_110	10:15	18:22	8:07	LINE CLEAR AVAILED
73	27-Nov-18	HASSAN	110	HV2	ANANDAPURA_110	10:15	18:28	8:13	LINE CLEAR AVAILED
74	27-Nov-18	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	10:28	18:21	7:53	LINE CLEAR AVAILED
75	27-Nov-18	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	10:28	20:19	9:51	LINE CLEAR AVAILED
76	27-Nov-18	HASSAN	110	ESSUR-BELIGAVI	ESSUR_110	10:45	15:40	4:55	LINE CLEAR AVAILED
77	27-Nov-18	HASSAN	110	HV1	ESSUR_110	10:44	15:40	4:56	LINE CLEAR AVAILED
78	27-Nov-18	HASSAN	110	HV2	ESSUR_110	10:45	18:14	7:29	LINE CLEAR AVAILED
79	27-Nov-18	HASSAN	110	HV2	HIRIYADKA_110	10:19	11:31	1:12	LINE CLEAR AVAILED
80	27-Nov-18	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	11:16	13:47	2:31	LINE CLEAR AVAILED
81	27-Nov-18	HASSAN	110	HV1	KALLUSADARAHALLI_110	13:50	13:55	0:05	HAND TRIPPED
82	27-Nov-18	HASSAN	110	HV3	KAVOOR_220	3:32	4:41	1:09	TRANSFORMER FAULT
83	27-Nov-18	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:50	10:55	0:05	HAND TRIPPED
84	27-Nov-18	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	13:58	14:01	0:03	HAND TRIPPED
85	27-Nov-18	HASSAN	110	HV2	MSEZ_220	10:11	16:53	6:42	LINE CLEAR AVAILED
86	27-Nov-18	HASSAN	66	HV1	DODDAKADANUR_66	14:12	14:35	0:23	LINE CLEAR AVAILED
87	27-Nov-18	HASSAN	66	HV1	HARIHARAPURA_66	16:34	16:57	0:23	LINE CLEAR AVAILED
88	27-Nov-18	HASSAN	66	HV1	HASSAN_66	6:10	6:18	0:08	TRANSFORMER FAULT
89	27-Nov-18	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:27	17:43	8:16	LINE CLEAR AVAILED
90	27-Nov-18	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	18:33	18:43	0:10	LINE FAULT
91	27-Nov-18	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	18:46	20:46	2:00	HAND TRIPPED
92	27-Nov-18	HASSAN	66	SAKALE-IPCL2	SAKALESHUPURA_66	2:25	2:39	0:14	LINE FAULT
93	27-Nov-18	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	18:43	19:19	0:36	LINE FAULT
94	27-Nov-18	MYSORE	66	HV2	BGNAGARA_66	22:56	23:06	0:10	TRANSFORMER FAULT
95	27-Nov-18	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	3:17	3:22	0:04	LINE FAULT
96	27-Nov-18	MYSORE	66	MADHUVANAHALLI-YELANDUR	YELANDUR_66	3:16	3:24	0:07	LINE FAULT
97	27-Nov-18	MYSORE	66	HV1	K_HONNALGERE_66	10:38	12:14	1:35	LINE CLEAR AVAILED
98	27-Nov-18	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	22:52	22:58	0:06	LINE FAULT
99	27-Nov-18	MYSORE	66	HV2	RAMAPURA_MYS_66	11:55	18:00	6:05	LINE CLEAR AVAILED
100	27-Nov-18	MYSORE	66	HV1	RAMAPURA_MYS_66	11:54	18:02	6:08	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
101	27-Nov-18	MYSORE	66	HV1	SANTHESARAGUR_66	12:37	13:22	0:45	HAND TRIPPED
102	27-Nov-18	MYSORE	66	HV1	SANTHESARAGUR_66	13:29	13:35	0:06	HAND TRIPPED
103	27-Nov-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	6:37	6:50	0:13	LINE FAULT
104	27-Nov-18	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	10:40	12:05	1:24	LINE CLEAR AVAILED
105	27-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:40	11:11	0:30	HAND TRIPPED
106	27-Nov-18	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	10:40	12:05	1:25	HAND TRIPPED
107	27-Nov-18	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR	YEDIYUR_66	9:24	9:32	0:08	LINE FAULT
108	27-Nov-18	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:12	14:57	3:45	LINE CLEAR AVAILED
109	27-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	9:30	17:01	7:31	MAIN SUPPLY FAILURE
110	27-Nov-18	TUMKUR	66	TR-1	DEVARAHALLI_66	9:30	17:01	7:31	MAIN SUPPLY FAILURE
111	27-Nov-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:37	10:50	0:12	LINE FAULT
112	27-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:47	17:39	8:52	HAND TRIPPED
113	27-Nov-18	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	3:35	4:00	0:25	LINE FAULT
114	27-Nov-18	TUMKUR	66	HANAGAL- RAMPURA	NAGASAMUDRA_66, RAMPURA_66	3:45	3:59	0:13	LINE FAULT
115	27-Nov-18	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:23	16:52	7:29	LINE CLEAR AVAILED
116	27-Nov-18	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	17:34	17:46	0:11	LINE FAULT
117	27-Nov-18	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:18	18:33	0:14	LINE FAULT
118	27-Nov-18	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	19:03	19:17	0:14	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
119	27-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:54	10:01	0:07	LINE FAULT
120	27-Nov-18	TUMKUR	66	MADANAYAKANAHALLI-TURUVANUR	TURUVANUR_66, JAGALUR_66,SOKKE_66	15:02	15:09	0:07	LINE CLEAR AVAILED
121	27-Nov-18	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66, RAMPURA_66	3:05	3:59	0:54	LINE FAULT
122	27-Nov-18	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA- HANAGAL	3:05	4:10	1:05	LINE FAULT
123	27-Nov-18	TUMKUR	66	TR-1	RAMPURA_66	3:05	4:10	1:05	MAIN SUPPLY FAILURE
124	27-Nov-18	TUMKUR	66	SOKKE- JAGALUR	SOKKE_66	11:53	11:58	0:04	HAND TRIPPED
125	27-Nov-18	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:22	13:26	3:03	LINE FAULT
126	28-Nov-18	BAGALKOT	110	110/11KV,HV-1	ACHANUR_110	12:00	12:58	0:58	HAND TRIPPED
127	28-Nov-18	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	11:52	11:55	0:03	HAND TRIPPED
128	28-Nov-18	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	12:56	12:59	0:03	HAND TRIPPED
129	28-Nov-18	BAGALKOT	220	BIDNAL-HUBLI3	BIDNAL_220	11:25	14:24	2:59	NBFC ISSUED
130	28-Nov-18	BAGALKOT	220	BIJAPUR-BAGEWADI2	BIJAPUR_220	16:41	16:56	0:15	HAND TRIPPED
131	28-Nov-18	BAGALKOT	220	BIJAPUR-VAISHALI2	BIJAPUR_220	16:44	16:56	0:12	HAND TRIPPED
132	28-Nov-18	BAGALKOT	220	BIJAPUR -INDI2	BIJAPUR_220	16:50	16:56	0:06	HAND TRIPPED
133	28-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	4:08	10:01	5:53	HAND TRIPPED
134	28-Nov-18	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	2:57	8:40	5:43	LINE FAULT
135	28-Nov-18	BAGALKOT	220	220/110KV,HV-1&LV-1	GHATAPRABHA_220	13:16	14:58	1:42	LINE CLEAR AVAILED
136	28-Nov-18	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	10:56	17:03	6:07	HAND TRIPPED
137	28-Nov-18	BAGALKOT	110	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	10:41	17:49	7:08	HAND TRIPPED
138	28-Nov-18	BAGALKOT	110	110/11KV,HV-1	JAMBAGI_110	12:32	12:36	0:04	HAND TRIPPED
139	28-Nov-18	BAGALKOT	110	110/33KV, HV3	ZALKI_110	14:08	14:48	0:40	LINE CLEAR AVAILED
140	28-Nov-18	BAGALKOT	110	110/33KV, HV2	UTTUR_110	16:08	16:15	0:07	TRANSFORMER FAULT
141	28-Nov-18	BAGALKOT	110	110/33KV, HV2	UTTUR_110	18:35	19:08	0:33	LINE CLEAR AVAILED
142	28-Nov-18	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	11:50	12:56	1:06	LINE CLEAR AVAILED
143	28-Nov-18	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	16:12	16:25	0:13	HAND TRIPPED
144	28-Nov-18	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	11:02	16:14	5:12	LINE CLEAR AVAILED
145	28-Nov-18	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	11:47	13:05	1:18	LINE CLEAR AVAILED
146	28-Nov-18	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	18:54	18:58	0:04	TRANSFORMER FAULT
147	28-Nov-18	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	9:41	13:03	3:22	LINE CLEAR AVAILED
148	28-Nov-18	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	13:58	15:04	1:06	LINE CLEAR AVAILED
149	28-Nov-18	BAGALKOT	110	220/110KV, LV3	MAHALINGAPUR_220,HIDIKAL_110	11:05	17:01	5:56	LINE CLEAR AVAILED
150	28-Nov-18	BANGALORE	66	HANUMANTHNAGAR - YEDUMADU	HANUMANTHNAGAR, CHATRA, MARALWADI	1:06	1:13	0:06	LOAD CHANGE OVER
151	28-Nov-18	BANGALORE	66	HV1	NAGANATHPURA 220	10:06	10:23	0:17	TRANSFORMER FAULT
152	28-Nov-18	BANGALORE	66	HV1	NGEF	12:04	13:54	1:50	LINE CLEAR AVAILED
153	28-Nov-18	BANGALORE	66	HV1	NGEF	15:23	16:51	1:28	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
154	28-Nov-18	BANGALORE	66	HV1	VIJAYANAGARA	13:24	13:39	0:14	LINE CLEAR AVAILED
155	28-Nov-18	BANGALORE	66	BAGMANE TECH PARK - HAL 220	BAGMANE TECH PARK	15:54	16:06	0:12	LINE CLEAR AVAILED
156	28-Nov-18	BANGALORE	66	HV2	AGALAKOTE	10:00	12:01	2:01	LINE CLEAR AVAILED
157	28-Nov-18	BANGALORE	66	HV1	AGALAKOTE	12:15	13:25	1:10	LINE CLEAR AVAILED
158	28-Nov-18	BANGALORE	66	AGALAKOTE - MATHIKERE	MATHIKERE	15:34	16:21	0:47	LINE CLEAR AVAILED
159	28-Nov-18	BANGALORE	66	HV2	BAIRAKURU	6:19	7:00	0:40	TRANSFORMER FAULT
160	28-Nov-18	BANGALORE	66	HV1	BAIRAKURU	13:02	13:46	0:44	LINE CLEAR AVAILED
161	28-Nov-18	BANGALORE	66	HV2	CHANNAPATNA	17:58	18:03	0:04	LINE CLEAR AVAILED
162	28-Nov-18	BANGALORE	220	HV2	CB PURA URBAN	15:06	15:36	0:30	LINE CLEAR AVAILED
163	28-Nov-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	14:59	15:17	0:17	LINE FAULT
164	28-Nov-18	BANGALORE	66	HV1	CHAKAVELU	9:17	9:20	0:02	LINE CLEAR AVAILED
165	28-Nov-18	BANGALORE	66	THIMAMPALLI - BAGEPALLI	THIMAMPALLI	6:49	7:10	0:21	LINE FAULT
166	28-Nov-18	BANGALORE	66	THIMAMPALLI - BAGEPALLI	THIMAMPALLI	10:17	10:32	0:14	LINE FAULT
167	28-Nov-18	BANGALORE	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI	1:15	1:23	0:08	LOAD CHANGEOVER
168	28-Nov-18	BANGALORE	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI	0:45	0:55	0:10	MAIN SUPPLY FAILURE
169	28-Nov-18	GULBARGA	110	HV1	BISIHALLI_110	6:34	6:45	0:11	LINE CLEAR AVAILED
170	28-Nov-18	GULBARGA	110	HV3	HANUMASAGAR_110	12:10	12:40	0:30	LINE CLEAR AVAILED
171	28-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	15:49	15:58	0:09	LINE CLEAR AVAILED
172	28-Nov-18	GULBARGA	110	HV3	HATTI_110	15:13	17:05	1:52	LINE CLEAR AVAILED
173	28-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	16:23	17:19	0:56	LINE FAULT
174	28-Nov-18	GULBARGA	110	SINDHANOOR-SIRIGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DH ADESUGUR_110,NSL SUGAR_IPP	16:57	17:17	0:20	LINE FAULT
175	28-Nov-18	GULBARGA	110	RAICHUR-SIDHANOOR2	RAICHUR_220	20:50	20:55	0:05	LINE FAULT
176	28-Nov-18	GULBARGA	110	RAICHUR-SIDHANOOR2	RAICHUR_220	21:33	21:38	0:05	LINE FAULT
177	28-Nov-18	GULBARGA	110	RAICHUR-SIDHANOOR2	RAICHUR_220	22:40	22:45	0:05	LINE FAULT
178	28-Nov-18	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	10:30	14:30	4:00	LINE CLEAR AVAILED
179	28-Nov-18	HASSAN	110	HV2	NAVUNDA_110	10:06	17:15	7:09	LINE CLEAR AVAILED
180	28-Nov-18	HASSAN	110	HV2	NERALAKERE_110	16:02	16:06	0:04	LINE CLEAR AVAILED
181	28-Nov-18	HASSAN	110	HV2	SORABA_110	11:50	12:01	0:11	LINE CLEAR AVAILED
182	28-Nov-18	HASSAN	110	HV1	SHIVAPURA_110	12:44	13:58	1:14	LINE CLEAR AVAILED
183	28-Nov-18	HASSAN	66	HASSN22-BELUR	HASSAN_220	18:08	18:15	0:07	HAND TRIPPED
184	28-Nov-18	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	18:07	18:13	0:06	HAND TRIPPED
185	28-Nov-18	HASSAN	66	HV2	ARAKALGUD_66	11:44	13:05	1:21	LINE CLEAR AVAILED
186	28-Nov-18	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	5:40	5:57	0:17	HAND TRIPPED
187	28-Nov-18	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:13	10:10	1:57	LINE CLEAR AVAILED
188	28-Nov-18	HASSAN	66	HV1	MATTNIVILE_66	6:05	6:15	0:10	TRANSFORMER FAULT
189	28-Nov-18	HASSAN	66	HV2	MATTNIVILE_66	9:42	9:47	0:05	TRANSFORMER FAULT
190	28-Nov-18	HASSAN	66	HV1	RAMNATHPURA_66	9:00	17:52	8:52	LINE CLEAR AVAILED
191	28-Nov-18	HASSAN	66	HV2	RAMNATHPURA_66	9:00	18:28	9:28	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
192	28-Nov-18	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	18:08	18:19	0:11	HAND TRIPPED
193	28-Nov-18	MYSORE	66	HV1	BGPURA_66	11:10	11:14	0:04	TRANSFORMER FAULT
194	28-Nov-18	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	13:57	14:08	0:10	LINE FAULT
195	28-Nov-18	MYSORE	66	HV1	KIADBMANDYA_66	10:40	12:19	1:39	LINE CLEAR AVAILED
196	28-Nov-18	MYSORE	66	HV1	KRNAGARA_66	2:55	3:03	0:07	HAND TRIPPED
197	28-Nov-18	MYSORE	66	HV2	KRNAGARA_66	2:55	3:00	0:04	HAND TRIPPED
198	28-Nov-18	MYSORE	66	MADHUVANAHALLI-YALANDUR	YELANDUR_66	13:57	14:03	0:05	LINE FAULT
199	28-Nov-18	TUMKUR	220	TR-1 &TR-2,TR-3(HV SIDE)	ANTHRASANAHALLI_220	13:12	14:08	0:55	LINE CLEAR AVAILED
200	28-Nov-18	TUMKUR	220	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	13:05	13:34	0:28	HAND TRIPPED
201	28-Nov-18	TUMKUR	110	TR-1(HV SIDE)	HUNSEGHATTA_110,	17:04	18:11	1:06	LINE CLEAR AVAILED
202	28-Nov-18	TUMKUR	110	KB CROSS 220kv- SHIMOGA	HUNSEGHATTA_110,	17:08	18:11	1:03	LINE CLEAR AVAILED
203	28-Nov-18	TUMKUR	66	ANCHEPALYA 220kv- KUNIGAL	KUNIGAL_66	16:44	17:45	1:00	LINE CLEAR AVAILED
204	28-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	13:12	14:08	0:55	LINE CLEAR AVAILED
205	28-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	7:22	10:13	2:50	LINE FAULT
206	28-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	13:12	17:25	4:12	HAND TRIPPED
207	28-Nov-18	TUMKUR	66	TR-2(HV2)	ANTHRASANAHALLI_220	13:12	14:08	0:55	LINE CLEAR AVAILED
208	28-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	13:12	14:08	0:55	LINE CLEAR AVAILED
209	28-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	13:12	14:08	0:55	LINE CLEAR AVAILED
210	28-Nov-18	TUMKUR	66	TR-1 &TR-2,TR-3(LV SIDE)	ANTHRASANAHALLI_220	13:12	14:08	0:55	LINE CLEAR AVAILED
211	28-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	13:12	15:15	2:03	LINE CLEAR AVAILED
212	28-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	13:12	14:08	0:55	LINE CLEAR AVAILED
213	28-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	15:38	15:56	0:17	LINE FAULT
214	28-Nov-18	TUMKUR	66	CHITRADURGA 220kv- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	12:03	13:29	1:25	LINE CLEAR AVAILED
215	28-Nov-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	10:08	10:40	0:32	MAIN SUPPLY FAILURE
216	28-Nov-18	TUMKUR	66	TR-1	DEVARAHALLI_66	10:08	10:40	0:32	MAIN SUPPLY FAILURE
217	28-Nov-18	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:08	15:15	0:07	HAND TRIPPED
218	28-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:47	17:39	8:52	HAND TRIPPED
219	28-Nov-18	TUMKUR	66	TR-1	HARAPPANAHALLI_66	12:48	12:54	0:05	TRANSFORMER FAULT
220	28-Nov-18	TUMKUR	66	TR-1	HIREGUNTANUR_66	15:40	16:58	1:17	LINE CLEAR AVAILED
221	28-Nov-18	TUMKUR	66	TR-2	HONNALI_66	17:06	17:13	0:06	TRANSFORMER FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
222	28-Nov-18	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	4:16	4:37	0:21	LINE FAULT
223	28-Nov-18	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	4:38	4:52	0:14	LINE FAULT
224	28-Nov-18	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	14:19	14:35	0:15	LINE FAULT
225	28-Nov-18	TUMKUR	66	TR-1	KATTIGE_66	22:00	22:07	0:07	TRANSFORMER FAULT
226	28-Nov-18	TUMKUR	66	TR-1	MATHOD_66	10:12	10:14	0:01	TRANSFORMER FAULT
227	28-Nov-18	TUMKUR	66	NAGALAMADIKE-SUNDARRAJASOLAR_IPP_66	SUNDARRAJASOLAR_IPP_66	12:36	12:42	0:05	HAND TRIPPED
228	28-Nov-18	TUMKUR	66	TR-1	RANGANATHAPURA_66	15:02	17:18	2:15	LINE CLEAR AVAILED
229	28-Nov-18	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:25	14:12	4:47	LINE FAULT
230	28-Nov-18	TUMKUR	66	THALLAK 220KV- CHALLAKERE	CHALLAKERE_66, SANIKERE_66	12:02	13:15	1:13	LINE CLEAR AVAILED
231	28-Nov-18	TUMKUR	66	THALLAK 220KV- DIAMOND IPP 1	DIAMOND_IPP_66	18:10	22:14	4:03	LINE CLEAR AVAILED
232	28-Nov-18	TUMKUR	66	THALLAK 220KV- DIAMOND IPP 2	DIAMOND_IPP_66	18:10	22:14	4:03	LINE CLEAR AVAILED
233	28-Nov-18	TUMKUR	66	TR-1	UCHCHANGIDURGA_66	11:36	13:23	1:46	LINE CLEAR AVAILED
234	28-Nov-18	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	17:57	22:48	4:51	LINE CLEAR AVAILED
235	29-Nov-18	BAGALKOT	110	ANKALAGI-HIDIKAL	HIDIKAL_110	10:36	16:22	5:46	NBFC ISSUED
236	29-Nov-18	BAGALKOT	110	BANAHATTI-JAMAKHANDI	JAMAKHANDI_110	12:27	12:42	0:15	LINE FAULT
237	29-Nov-18	BAGALKOT	110	110/11KV,HV-1	BILAGI_110	11:07	11:25	0:18	HAND TRIPPED
238	29-Nov-18	BAGALKOT	110	110/11KV,HV-2	BIJAPUR CITY_110	6:05	6:16	0:11	TRANSFORMER FAULT
239	29-Nov-18	BAGALKOT	110	110/33KV, HV2	UTTUR_110	11:07	11:47	0:40	LINE CLEAR AVAILED
240	29-Nov-18	BAGALKOT	110	110/33KV, HV2	UTTUR_110	16:44	18:39	1:55	LINE CLEAR AVAILED
241	29-Nov-18	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	19:46	19:51	0:05	TRANSFORMER FAULT
242	29-Nov-18	BAGALKOT	110	110/11KV, HV1	MUNDARGI_110	15:40	15:55	0:15	LINE CLEAR AVAILED
243	29-Nov-18	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	10:38	13:59	3:21	LINE CLEAR AVAILED
244	29-Nov-18	BAGALKOT	110	220/110KV,LV2	MKHUBLI_220	10:12	18:35	8:23	LINE CLEAR AVAILED
245	29-Nov-18	BAGALKOT	110	MKHUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	12:19	17:05	4:46	LINE CLEAR AVAILED
246	29-Nov-18	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	11:19	11:27	0:08	TRANSFORMER FAULT
247	29-Nov-18	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220,HIDIKAL_110	12:03	18:33	6:30	LINE CLEAR AVAILED
248	29-Nov-18	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	12:02	18:33	6:31	LINE CLEAR AVAILED
249	29-Nov-18	BAGALKOT	220	CHIKKODI2-BELGAUM	BELGAUM_220	0:00	19:50	19:50	LINE CLEAR AVAILED
250	29-Nov-18	BAGALKOT	220	BAGEWADI-BIJAPUR2	BAGEWADI_220	13:25	18:30	5:05	LINE FAULT
251	29-Nov-18	BAGALKOT	220	ALAMATTI2-BAGEWADI	BAGEWADI_220	10:57	15:55	4:58	LINE CLEAR AVAILED
252	29-Nov-18	BANGALORE	66	HV2	HSR LAYOUT 220	7:24	9:11	1:47	TRANSFORMER FAULT
253	29-Nov-18	BANGALORE	66	HV2	ITI	11:09	11:57	0:47	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
254	29-Nov-18	BANGALORE	66	HV2	NGEF	12:26	13:51	1:24	LINE CLEAR AVAILED
255	29-Nov-18	BANGALORE	66	HV2	SOUTH CITY	5:54	10:44	4:49	TRANSFORMER FAULT
256	29-Nov-18	BANGALORE	66	TELECOM LAYOUT - NRS 2	TELECOM LAYOUT	14:41	15:42	1:01	LINE CLEAR AVAILED
257	29-Nov-18	BANGALORE	66	TELECOM LAYOUT - NRS 2	TELECOM LAYOUT	16:42	16:50	0:08	LINE CLEAR AVAILED
258	29-Nov-18	BANGALORE	66	HV2	TK HALLI 220	16:58	17:07	0:09	LINE CLEAR AVAILED
259	29-Nov-18	BANGALORE	66	HV1	KIADB DB PURA 220	7:51	8:12	0:21	TRANSFORMER FAULT
260	29-Nov-18	BANGALORE	66	HV1	KANAKAPURA 66	7:00	7:05	0:05	TRANSFORMER FAULT
261	29-Nov-18	BANGALORE	66	HV1	MANCHENAHALLI	14:45	17:00	2:15	LINE CLEAR AVAILED
262	29-Nov-18	BANGALORE	66	HV1	MANCHENAHALLI	11:22	11:30	0:07	LINE CLEAR AVAILED
263	29-Nov-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	11:15	12:36	1:20	LINE CLEAR AVAILED
264	29-Nov-18	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:15	12:36	1:20	LINE CLEAR AVAILED
265	29-Nov-18	GULBARGA	400	BPS-YTPS-2	YTPS_400	11:30	14:20	2:50	LINE CLEAR AVAILED
266	29-Nov-18	GULBARGA	110	RAICHBUR220-SINDHANOOR1	SIRWAR_110,VALKAMDINNI_110,ALKO D_110,BYAGAWAT_110	1:50	2:05	0:15	LINE FAULT
267	29-Nov-18	GULBARGA	110	RAICHBUR220-SINDHANOOR1	SIRWAR_110,VALKAMDINNI_110,ALKO D_110,BYAGAWAT_110	3:06	4:40	1:34	LINE FAULT
268	29-Nov-18	GULBARGA	110	RAICHBUR220-SINDHANOOR1	SIRWAR_110,VALKAMDINNI_110,ALKO D_110,BYAGAWAT_110	12:38	12:48	0:10	LINE CLEAR AVAILED
269	29-Nov-18	GULBARGA	110	HV4	ALAND_110	12:56	14:19	1:23	LINE CLEAR AVAILED
270	29-Nov-18	GULBARGA	110	HV2	KUSTAGI_220	11:32	11:39	0:07	LINE CLEAR AVAILED
271	29-Nov-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	17:57	17:57	LINE CLEAR AVAILED
272	29-Nov-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:11	23:59	0:48	HAND TRIPPED
273	29-Nov-18	HASSAN	220	UPCL-KEMAR2	upcl_gen	12:42	23:59	11:17	LINE CLEAR AVAILED
274	29-Nov-18	HASSAN	220	KEMAR-UPCL2	KEMAR_220	12:42	23:59	11:17	LINE CLEAR AVAILED
275	29-Nov-18	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	0:00	19:55	19:55	LINE CLEAR AVAILED
276	29-Nov-18	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	20:05	23:21	3:16	LINE FAULT
277	29-Nov-18	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	0:00	19:55	19:55	LINE CLEAR AVAILED
278	29-Nov-18	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	20:05	23:22	3:17	LINE FAULT
279	29-Nov-18	HASSAN	110	HV1	HOSANGADI_110	10:28	14:03	3:35	LINE CLEAR AVAILED
280	29-Nov-18	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	9:37	18:12	8:35	LINE CLEAR AVAILED
281	29-Nov-18	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	9:37	18:12	8:35	LINE CLEAR AVAILED
282	29-Nov-18	HASSAN	110	HV1	PUTTUR_110	10:07	12:20	2:13	LINE CLEAR AVAILED
283	29-Nov-18	HASSAN	110	HV2	PUTTUR_110	12:20	14:00	1:40	LINE CLEAR AVAILED
284	29-Nov-18	HASSAN	110	HV4	PUTTUR_110	14:08	16:14	2:06	LINE CLEAR AVAILED
285	29-Nov-18	HASSAN	66	HV2	MATTANAVILE_66	13:30	13:52	0:22	LINE CLEAR AVAILED
286	29-Nov-18	MYSORE	66	HV1	HANGLA_66	12:30	13:38	1:07	LINE CLEAR AVAILED
287	29-Nov-18	MYSORE	66	HV2	HANGLA_66	12:30	13:38	1:07	LINE CLEAR AVAILED
288	29-Nov-18	MYSORE	66	THANDYA-NANJANGUD	THANDYA_66	15:25	17:25	2:00	NBFC ISSUED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
289	29-Nov-18	MYSORE	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	11:03	11:10	0:06	LINE FAULT
290	29-Nov-18	MYSORE	66	MYSORE SOUTH-KADAKOLA	MYSORESOUTH_66	10:56	11:30	0:33	LINE CLEAR AVAILED
291	29-Nov-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	8:04	10:46	2:41	LINE CLEAR AVAILED
292	29-Nov-18	MYSORE	66	HV1	VAJAMANGALA_220	12:42	14:02	1:20	LINE CLEAR AVAILED
293	29-Nov-18	MYSORE	66	HV2	VAJAMANGALA_220	12:42	14:02	1:20	LINE CLEAR AVAILED
294	29-Nov-18	TUMKUR	220	TR-1 & TR-2	ANCHEPALYA_220	23:17	23:46	0:29	TRANSFORMER FAULT
295	29-Nov-18	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2	ANCHEPALYA_220	23:17	23:45	0:28	LINE FAULT
296	29-Nov-18	TUMKUR	220	TR-1(HV SIDE)	ANTHRASANAHALLI_220	17:06	17:53	0:47	LINE CLEAR AVAILED
297	29-Nov-18	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	10:16	14:18	4:01	LINE CLEAR AVAILED
298	29-Nov-18	TUMKUR	110	TR-1	TURUVEKERE_110	5:47	6:55	1:07	MAIN SUPPLY FAILURE
299	29-Nov-18	TUMKUR	110	TR-1	TURUVEKERE_110	12:37	14:33	1:56	LINE CLEAR AVAILED
300	29-Nov-18	TUMKUR	110	TR-2	TURUVEKERE_110	13:38	14:30	0:51	LINE CLEAR AVAILED
301	29-Nov-18	TUMKUR	110	TURUVEKERE_110-KBCROSS_220	KBCROSS_220	13:53	14:29	0:36	LINE CLEAR AVAILED
302	29-Nov-18	TUMKUR	110	TR-1(HV SIDE)	HUNSEGHATTA_110,	12:14	12:48	0:33	LINE CLEAR AVAILED
303	29-Nov-18	TUMKUR	110	HUNSEGHATTA_110-KBCROSS_220	HUNSEGHATTA_110,	12:15	12:48	0:32	LINE CLEAR AVAILED
304	29-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	23:35	23:55	0:19	HAND TRIPPED
305	29-Nov-18	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	23:36	23:55	0:19	HAND TRIPPED
306	29-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	22:54	23:54	1:00	HAND TRIPPED
307	29-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	23:36	23:55	0:19	HAND TRIPPED
308	29-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	23:35	23:55	0:19	HAND TRIPPED
309	29-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	23:36	23:56	0:19	HAND TRIPPED
310	29-Nov-18	TUMKUR	66	TR-1	ANCHEPALYA_220	23:36	23:53	0:17	HAND TRIPPED
311	29-Nov-18	TUMKUR	66	TR-2	ANCHEPALYA_220	23:17	23:49	0:31	HAND TRIPPED
312	29-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	23:17	23:52	0:35	LINE FAULT
313	29-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66	23:36	23:55	0:19	HAND TRIPPED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
314	29-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:24	15:26	4:01	LINE FAULT
315	29-Nov-18	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	17:04	17:54	0:49	LINE CLEAR AVAILED
316	29-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:24	17:53	9:28	HAND TRIPPED
317	29-Nov-18	TUMKUR	66	TR-2	HALURAMESHWARA_66	12:47	13:19	0:31	LINE CLEAR AVAILED
318	29-Nov-18	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	10:11	10:24	0:12	LINE FAULT
319	29-Nov-18	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:42	19:09	0:27	LINE CLEAR AVAILED
320	29-Nov-18	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	10:15	14:20	4:04	LINE CLEAR AVAILED
321	29-Nov-18	TUMKUR	66	YEDIYUR- BG NAGARA	BGNAGARA_66	8:33	10:41	2:08	HAND TRIPPED
322	30-Nov-18	BAGALKOT	110	110/33KV,HV-2	ANKALAGI_110	10:34	10:36	0:02	HAND TRIPPED
323	30-Nov-18	BAGALKOT	110	110/11KV,HV-1	ATHANI_220	8:21	10:58	2:37	HAND TRIPPED
324	30-Nov-18	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	6:23	10:29	4:06	LINE FAULT
325	30-Nov-18	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	17:57	18:26	0:29	LINE FAULT
326	30-Nov-18	BAGALKOT	220	BAGEWADI-BIJAPUR 1	BAGEWADI_220	17:57	19:18	1:21	LINE FAULT
327	30-Nov-18	BAGALKOT	220	BAGEWADI-BIJAPUR 2	BAGEWADI_220	17:57	18:20	0:23	LINE FAULT
328	30-Nov-18	BAGALKOT	220	BAGEWADI-ADPH 2	BAGEWADI_220	17:57	18:05	0:08	LINE FAULT
329	30-Nov-18	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	17:57	18:27	0:30	LINE FAULT
330	30-Nov-18	BAGALKOT	220	BAGEWADI-FORTUNE 1&2	BAGEWADI_220	17:57	18:14	0:17	LINE FAULT
331	30-Nov-18	BAGALKOT	110	BAGEWADI-RAMPUR(NIDAGUNDI)	NIDAGUNDI_110	6:25	7:12	0:47	HAND TRIPPED
332	30-Nov-18	BAGALKOT	110	BAGEWADI-ACHANUR(MUDDEBIHAL)	MUDDEBIHAL_110	6:25	6:58	0:33	HAND TRIPPED
333	30-Nov-18	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	6:53	7:14	0:21	HAND TRIPPED
334	30-Nov-18	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	17:57	18:05	0:08	LINE FAULT
335	30-Nov-18	BAGALKOT	110	BAGEWADI-RAMPUR(NIDAGUNDI)	NIDAGUNDI_110	17:57	18:21	0:24	LINE FAULT
336	30-Nov-18	BAGALKOT	110	BAGEWADI-RAMPUR(NIDAGUNDI)	NIDAGUNDI_110	17:57	18:21	0:24	LINE FAULT
337	30-Nov-18	BAGALKOT	110	BAGEWADI-ACHANUR(MUDDEBIHAL)	MUDDEBIHAL_110	17:57	18:21	0:24	LINE FAULT
338	30-Nov-18	BAGALKOT	110	110/11KV,HV-1	KALADAGI_110	11:53	14:19	2:26	HAND TRIPPED
339	30-Nov-18	BAGALKOT	110	110/11KV,HV-1	KUMATA_110	8:22	9:04	0:42	HAND TRIPPED
340	30-Nov-18	BAGALKOT	110	SIRIS220-UMMACHAGI	UMMACHAGI_110	9:49	9:57	0:08	LINE FAULT
341	30-Nov-18	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	9:49	10:11	0:22	LINE FAULT
342	30-Nov-18	BAGALKOT	110	UGAR SUGAR-UGARKHUD	UGARKHUD_110	20:13	20:57	0:44	HAND TRIPPED
343	30-Nov-18	BAGALKOT	110	110/33KV, HV3	SATTI_110	12:25	13:10	0:45	LINE CLEAR AVAILED
344	30-Nov-18	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	12:24	15:40	3:16	LINE CLEAR AVAILED
345	30-Nov-18	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	4:07	4:13	0:06	TRANSFORMER FAULT
346	30-Nov-18	BAGALKOT	110	NARENDRA220-MRUTHYUNJAY NAGAR2	MRUTHYUNJAY NAGAR_110	6:28	6:54	0:26	HAND TRIPPED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
347	30-Nov-18	BAGALKOT	110	110/11KV,HV2	MUNDAGOD_110	11:07	11:35	0:28	LINE CLEAR AVAILED
348	30-Nov-18	BAGALKOT	110	BALAJI SUGAR-MUDDEBIHAL	MUDDEBIHAL_110	6:25	7:03	0:38	MAIN SUPPLY FAILURE
349	30-Nov-18	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPPANAKOPPA1&2	GOPPANAKOPPA_110	6:23	6:26	0:03	MAIN SUPPLY FAILURE
350	30-Nov-18	BAGALKOT	110	110/33KV, HV2	MATTIHAL_110	11:55	12:02	0:07	LINE CLEAR AVAILED
351	30-Nov-18	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	14:16	15:19	1:03	LINE CLEAR AVAILED
352	30-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	16:21	23:59	7:38	LINE CLEAR AVAILED
353	30-Nov-18	BANGALORE	66	HV1	SOMAYAJANAHALLI	15:00	15:11	0:11	TRANSFORMER FAULT
354	30-Nov-18	BANGALORE	66	HV1	SOMAYAJANAHALLI	15:11	16:30	1:18	TRANSFORMER FAULT
355	30-Nov-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	1:59	2:09	0:10	LINE FAULT
356	30-Nov-18	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	5:45	5:51	0:06	LINE FAULT
357	30-Nov-18	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	2:02	2:13	0:10	LINE FAULT
358	30-Nov-18	BANGALORE	66	HV1	ANDERSONPET	2:02	2:15	0:12	TRANSFORMER FAULT
359	30-Nov-18	BANGALORE	220	HV1	A STATION 220	4:22	5:12	0:50	TRANSFORMER FAULT
360	30-Nov-18	BANGALORE	220	LV1	A STATION 220	4:22	5:12	0:50	TRANSFORMER FAULT
361	30-Nov-18	BANGALORE	66	BG ROAD - SOMANAHALLI 220	BG ROAD, JIGANI LINK ROAD	7:15	7:19	0:04	LINE FAULT
362	30-Nov-18	BANGALORE	66	HV2	KADUBISANAHALLI	11:58	12:08	0:10	TRANSFORMER FAULT
363	30-Nov-18	BANGALORE	66	VICTORIA - NRS 220	VICTORIA	18:14	18:22	0:08	LINE FAULT
364	30-Nov-18	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	6:55	7:14	0:19	LINE FAULT
365	30-Nov-18	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	8:35	8:44	0:09	LINE CLEAR AVAILED
366	30-Nov-18	GULBARGA	220	ALIPUR-RAGALPADU	ALIPUR_220	8:35	9:24	0:49	LINE CLEAR AVAILED
367	30-Nov-18	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARAGUTTI_110	12:02	13:27	1:25	LINE CLEAR AVAILED
368	30-Nov-18	GULBARGA	110	RAICHUR220-SINDHANOOR1	SIRWAR_110,VALKAMDINI_110,ALKOD_110,BYAGWAT_110	0:00	9:05	9:05	LINE FAULT
369	30-Nov-18	GULBARGA	110	HV1	RAJESHWAR_110	12:22	13:40	1:18	LINE CLEAR AVAILED
370	30-Nov-18	GULBARGA	66	HV1	GUDEKOTE_110	9:07	9:58	0:51	LINE CLEAR AVAILED
371	30-Nov-18	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALLI_66,GIRYAPUR_66,MA NGALA_66,SOVENHALLI_66,TUNGABH ADRA_66	3:25	3:29	0:04	LINE FAULT
372	30-Nov-18	GULBARGA	66	LV1,LV2	ITTAGI_220	6:40	6:55	0:15	TRANSFORMER FAULT
373	30-Nov-18	GULBARGA	66	ITTAGGI-HIREHADAGALLI	HIREHADAGALLI_66,GIRYAPUR_66,MA NGALA_66,SOVENHALLI_66,TUNGABH ADRA_66	12:05	14:19	2:14	LINE CLEAR AVAILED
374	30-Nov-18	GULBARGA	66	HV1	HAMPASAGAR_66	11:20	11:25	0:05	TRANSFORMER FAULT
375	30-Nov-18	HASSAN	400	UPCL-HASSAN2	UPCL_GEN	0:00	17:45	17:45	HAND TRIPPED
376	30-Nov-18	HASSAN	400	UPCL-HASSAN2	UPCL_GEN	21:08	23:59	2:51	HAND TRIPPED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
377	30-Nov-18	HASSAN	220	HV1	MRSMSG_220	12:14	12:42	0:28	LINE CLEAR AVAILED
378	30-Nov-18	HASSAN	220	SHRAVITY-SIRISI 2	SHARAVATY_GEN	12:24	15:40	3:16	LINE CLEAR AVAILED
379	30-Nov-18	HASSAN	110	LV1	MRSMSG_220	12:14	12:42	0:28	LINE CLEAR AVAILED
380	30-Nov-18	HASSAN	110	HV1	HALADY_110	12:15	14:23	2:08	LINE CLEAR AVAILED
381	30-Nov-18	HASSAN	110	HV2	HALADY_110	12:15	15:22	3:07	LINE CLEAR AVAILED
382	30-Nov-18	HASSAN	110	HV2	HALADY_110	15:28	16:30	1:02	HAND TRIPPED
383	30-Nov-18	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	10:20	13:23	3:03	LINE CLEAR AVAILED
384	30-Nov-18	HASSAN	110	HV2	KONAJE_110	10:36	14:23	3:47	LINE CLEAR AVAILED
385	30-Nov-18	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:40	10:43	0:03	HAND TRIPPED
386	30-Nov-18	HASSAN	110	KMOODAB-EMAR	MOODABIDRE_110	10:43	12:16	1:33	LINE CLEAR AVAILED
387	30-Nov-18	HASSAN	110	MOODABSOHAM1	MOODABIDRE_110	8:36	13:26	4:50	LINE CLEAR AVAILED
388	30-Nov-18	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	8:36	13:26	4:50	LINE CLEAR AVAILED
389	30-Nov-18	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	12:39	12:52	0:13	LINE FAULT
390	30-Nov-18	MYSORE	66	HV1	DODDINADUVADI_66	11:12	11:19	0:07	LINE CLEAR AVAILED
391	30-Nov-18	MYSORE	66	HV2	DODDINADUVADI_66	10:46	11:06	0:19	LINE CLEAR AVAILED
392	30-Nov-18	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 K_HONNALGERE_66	12:31	12:36	0:04	LINE FAULT
393	30-Nov-18	MYSORE	66	PERIYAPATNA-HANAGUDU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	16:09	16:17	0:07	LINE FAULT
394	30-Nov-18	MYSORE	66	SB HALLI-HUYGONAHALLI	SANTHEBACHALLI_66	16:00	17:50	1:50	HAND TRIPPED
395	30-Nov-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	14:41	16:07	1:25	LINE CLEAR AVAILED
396	30-Nov-18	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	13:07	13:21	0:13	LINE FAULT
397	30-Nov-18	TUMKUR	220	MADHUGIRI 220kV- GBDNR	MADHUGIRI 220kV	10:06	11:52	1:45	LINE CLEAR AVAILED
398	30-Nov-18	TUMKUR	220	MADHU220_PVGD1	MADHUGIRI 220kV	10:07	11:57	1:49	LINE CLEAR AVAILED
399	30-Nov-18	TUMKUR	220	MADHU220_PVGD2	MADHUGIRI 220kV	10:07	11:58	1:51	LINE CLEAR AVAILED
400	30-Nov-18	TUMKUR	110	TR-1(HV SIDE)	HUNSEGHATTA_110,	16:08	16:46	0:37	LINE CLEAR AVAILED
401	30-Nov-18	TUMKUR	110	HUNSEGHATTA_110-KBCROSS_220	HUNSEGHATTA_110,	16:10	17:46	1:35	LINE CLEAR AVAILED
402	30-Nov-18	TUMKUR	66	CHIKKABANAGERE-HARIYABBE	CHIKKABANAGERE_66	16:15	17:00	0:45	LINE CLEAR AVAILED
403	30-Nov-18	TUMKUR	66	TR-1	CHIKKABANAGERE_66	13:18	17:42	4:24	LINE CLEAR AVAILED
404	30-Nov-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:25	17:33	9:07	HAND TRIPPED
405	30-Nov-18	TUMKUR	66	HARAPPANAHALLI_66-_ITTAGI	HARAPPANAHALLI_66	10:59	13:32	2:33	LINE CLEAR AVAILED
406	30-Nov-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	7:07	12:16	5:09	LINE FAULT
407	30-Nov-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	6:33	6:44	0:10	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
408	30-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:36	10:54	4:18	LINE FAULT
409	30-Nov-18	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	9:46	10:53	1:06	LINE CLEAR AVAILED
410	30-Nov-18	TUMKUR	66	I D HALLI- KODIGENAHALLI	KODIGENAHALLI_66	17:00	17:21	0:20	LINE CLEAR AVAILED
411	30-Nov-18	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	17:01	17:23	0:21	HAND TRIPPED
412	30-Nov-18	TUMKUR	66	MADHUGIRI 220kV- KALLAMBELLA_66	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	13:38	13:47	0:09	LINE FAULT
413	30-Nov-18	TUMKUR	66	TR-2	NAYAKANHATTI_66	7:21	7:39	0:18	TRANSFORMER FAULT
414	30-Nov-18	TUMKUR	66	SHYLA PURA- MADHUGIRI	SHYLA PURA_66, YNHOSKOTE_66, MANGALWADA_66	18:02	18:07	0:04	HAND TRIPPED
415	30-Nov-18	TUMKUR	66	TR-1 & TR-2	TAVAREKERE(C)_66	7:57	8:50	0:52	HAND TRIPPED
416	30-Nov-18	TUMKUR	66	TAVAREKERE (C)- GOPPENAHALLI	TAVAREKERE(C)_66	7:57	8:48	0:51	HAND TRIPPED
417	1-Dec-18	BAGALKOT	220	HIREBENDIGERI1-BIDNAL	BIDNAL_220	20:20	23:59	3:39	LINE FAULT
418	1-Dec-18	BAGALKOT	220	HIREBENDIGERI2-BIDNAL	BIDNAL_220	20:20	23:59	3:39	LINE FAULT
419	1-Dec-18	BAGALKOT	110	SUVARNA SOUDA-MACHE	MACHE_110	17:06	17:59	0:53	HAND TRIPPED
420	1-Dec-18	BAGALKOT	110	VAJRAMATTI 220- MANTUR1	MANTUR_110	11:51	13:49	1:58	LINE CLEAR AVAILED
421	1-Dec-18	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	5:42	5:59	0:17	LINE FAULT
422	1-Dec-18	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL	7:21	8:37	1:16	LINE CLEAR AVAILED
423	1-Dec-18	BANGALORE	66	HV2	DODDABELAVANGALA	22:53	23:01	0:08	TRANSFORMER FAULT
424	1-Dec-18	BANGALORE	66	HV2	KANAKAPURA 66	11:47	12:58	1:11	LINE CLEAR AVAILED
425	1-Dec-18	BANGALORE	66	HV1	KANAKAPURA 66	9:36	9:40	0:04	LOAD CHANGE OVER
426	1-Dec-18	BANGALORE	66	HV1	KANAKAPURA 66	22:15	22:19	0:04	TRANSFORMER FAULT
427	1-Dec-18	BANGALORE	66	HV1	KANAKAPURA 66	22:33	22:35	0:02	TRANSFORMER FAULT
428	1-Dec-18	BANGALORE	66	HV2	SARJAPURA	9:10	9:18	0:08	LINE CLEAR AVAILED
429	1-Dec-18	BANGALORE	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	9:28	9:33	0:05	LOAD CHANGE OVER
430	1-Dec-18	BANGALORE	66	AMAR JYOTHI - HAL ADUGODI 1	AMAR JYOTHI	13:10	14:00	0:50	LINE FAULT
431	1-Dec-18	BANGALORE	66	GOLF LINKS - ADUGODI 2	GOLF LINKS	11:50	12:00	0:10	LOAD CHANGE OVER
432	1-Dec-18	BANGALORE	66	GOLF LINKS - ADUGODI 1	GOLF LINKS	15:10	15:15	0:05	LOAD CHANGE OVER
433	1-Dec-18	BANGALORE	66	HV1	AMAR JYOTHI	10:30	10:38	0:07	LOAD CHANGE OVER
434	1-Dec-18	BANGALORE	66	HV2	AMAR JYOTHI	13:10	14:05	0:55	MAIN SUPPLY FAILURE
435	1-Dec-18	BANGALORE	66	HV1	ANJANAPURA	11:55	12:00	0:04	TRANSFORMER FAULT
436	1-Dec-18	BANGALORE	66	HV1	ANJANAPURA	12:56	14:42	1:46	LINE CLEAR AVAILED
437	1-Dec-18	BANGALORE	66	HV1	AUSTIN TOWN	12:58	13:10	0:12	LOAD CHANGE OVER
438	1-Dec-18	BANGALORE	66	HV2	AUSTIN TOWN	11:21	11:31	0:09	LOAD CHANGE OVER
439	1-Dec-18	BANGALORE	66	ELECTRONIC CITY - YARENDANAHALLI	ELECTRONIC CITY, INFOSYS(EHT)	8:45	8:59	0:13	LOAD CHANGE OVER

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
440	1-Dec-18	BANGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY PH 2 SEC 1	ELECTRONIC CITY, INFOSYS(EHT)	17:54	18:02	0:07	LOAD CHANGEOVER
441	1-Dec-18	BANGALORE	66	SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA	10:23	10:28	0:05	LOAD CHANGEOVER
442	1-Dec-18	BANGALORE	66	HV1	TELECOM LAYOUT	14:20	15:13	0:53	LINE CLEAR AVAILED
443	1-Dec-18	BANGALORE	66	TELECOM LAYOUT - NRS 1	TELECOM LAYOUT	14:20	15:13	0:53	LINE CLEAR AVAILED
444	1-Dec-18	BANGALORE	66	TK HALLI 220 - IGGALUR	IGGALURU, AKKURMOLE	1:27	1:41	0:14	LINE FAULT
445	1-Dec-18	BANGALORE	66	VICTORIA - NRS 220	VICTORIA	14:09	14:17	0:07	LOAD CHANGEOVER
446	1-Dec-18	BANGALORE	66	HV1	YARENDANAHALLI 220	8:47	9:00	0:12	LOAD CHANGEOVER
447	1-Dec-18	BANGALORE	66	HV2	YARENDANAHALLI 220	8:47	9:00	0:12	LOAD CHANGEOVER
448	1-Dec-18	BANGALORE	66	HV3	YARENDANAHALLI 220	8:47	9:00	0:12	LOAD CHANGEOVER
449	1-Dec-18	BANGALORE	66	HV1	YARENDANAHALLI 220	17:34	17:43	0:09	LOAD CHANGEOVER
450	1-Dec-18	BANGALORE	66	HV3	YARENDANAHALLI 220	17:34	17:43	0:09	LOAD CHANGEOVER
451	1-Dec-18	BANGALORE	66	HV2	YARENDANAHALLI 220	17:38	17:48	0:10	LOAD CHANGEOVER
452	1-Dec-18	GULBARGA	220	ITTAGI-HARKANAL	ITTAGI_220	11:30	11:40	0:10	LINE FAULT
453	1-Dec-18	GULBARGA	110	HALBARGA-CHIDRI	CHIDRI_110	11:30	12:51	1:21	LINE CLEAR AVAILED
454	1-Dec-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGRAGOAN_110, DIGGI_110	11:54	12:02	0:08	LINE FAULT
455	1-Dec-18	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110	11:54	12:12	0:18	LINE FAULT
456	1-Dec-18	GULBARGA	110	HV1	HALBARGA_220	15:17	15:32	0:15	LINE CLEAR AVAILED
457	1-Dec-18	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	8:07	8:12	0:05	LINE FAULT
458	1-Dec-18	GULBARGA	110	SINDHANOOR-SIRIGUPPA	TEKKALAKOTE_110,DHADESUGUR_110 ,SIRIGUPPA_110,NSL SUGUR_IPP	16:10	16:30	0:20	LINE FAULT
459	1-Dec-18	GULBARGA	110	HV1	KOTTUR_110	12:21	13:10	0:49	LINE CLEAR AVAILED
460	1-Dec-18	GULBARGA	110	HV1	KAVITHAL_110	21:05	21:10	0:05	TRANSFORMER FAULT
461	1-Dec-18	GULBARGA	110	HV1	KAVITHAL_110	21:15	21:20	0:05	TRANSFORMER FAULT
462	1-Dec-18	GULBARGA	66	ITTAGI-RENEWSLR1,2	ITTAGI_220	13:30	14:00	0:30	LINE CLEAR AVAILED
463	1-Dec-18	GULBARGA	66	ITTAGI-CLNMAX1,2	ITTAGI_220	17:18	17:21	0:03	LINE CLEAR AVAILED
464	1-Dec-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	8:09	8:09	HAND TRIPPED
465	1-Dec-18	HASSAN	220	HV1	MSEZ_220	9:59	13:51	3:52	LINE CLEAR AVAILED
466	1-Dec-18	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	17:33	23:59	6:26	LINE CLEAR AVAILED
467	1-Dec-18	HASSAN	110	LV1	MSEZ_220	9:59	13:52	3:53	LINE CLEAR AVAILED
468	1-Dec-18	HASSAN	110	HV2	ANANDAPURA_110	14:37	18:29	3:52	LINE CLEAR AVAILED
469	1-Dec-18	HASSAN	66	HV1	ALDUR_66	13:04	13:16	0:12	HAND TRIPPED
470	1-Dec-18	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:28	15:36	0:08	LINE FAULT
471	1-Dec-18	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	6:39	6:54	0:15	LINE FAULT
472	1-Dec-18	HASSAN	66	HV1	HOLALUR_66	14:05	14:34	0:29	LINE CLEAR AVAILED
473	1-Dec-18	HASSAN	66	HV1	TAVARECHENAHALLI_66	12:50	13:15	0:25	TRANSFORMER FAULT
474	1-Dec-18	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	11:39	11:50	0:11	LINE FAULT
475	1-Dec-18	MYSORE	66	HV1	KOPPA_66	8:57	9:04	0:06	HAND TRIPPED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
476	1-Dec-18	MYSORE	66	KOPPA 66-HV2	KOPPA_66	8:57	9:04	0:06	HAND TRIPPED
477	1-Dec-18	MYSORE	66	KR PETE-HUYGONALLI 1	KRPET_66 KIKKERI_66 AKKIHBBAL_66	11:55	12:05	0:10	HAND TRIPPED
478	1-Dec-18	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 G MALLIGERE_66, GUDDENAHALLI_66, BOGADHI MANDYA_66 & NAGAMANGALA_66	8:08	8:13	0:05	LINE FAULT
479	1-Dec-18	MYSORE	66	HV2	SANTHESARAGUR_66	11:47	11:50	0:02	TRANSFORMER FAULT
480	1-Dec-18	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI 220kV	13:30	14:07	0:36	LINE CLEAR AVAILED
481	1-Dec-18	TUMKUR	110	TR-1	TURUVEKERE_110	0:50	1:03	0:12	TRANSFORMER FAULT
482	1-Dec-18	TUMKUR	110	TR-1	DODDAGUNI_110	12:00	13:08	1:08	LINE CLEAR AVAILED
483	1-Dec-18	TUMKUR	110	TR-1	GUBBI_110	4:04	4:11	0:07	TRANSFORMER FAULT
484	1-Dec-18	TUMKUR	110	TR-1(HV SIDE)	HUNSEGHATTA_110,	11:00	13:32	2:31	HAND TRIPPED
485	1-Dec-18	TUMKUR	110	HUNSEGHATTA_11-KBCROSS_66	HUNSEGHATTA_110,	14:24	14:40	0:15	LINE CLEAR AVAILED
486	1-Dec-18	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:11	6:27	0:15	LINE FAULT
487	1-Dec-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:57	15:13	0:15	LINE FAULT
488	1-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:32	17:54	9:22	HAND TRIPPED
489	1-Dec-18	TUMKUR	66	TR-2	HONNALI_66	17:02	17:14	0:12	TRANSFORMER FAULT
490	1-Dec-18	TUMKUR	66	TR-1	LINGADAHALLI_TMK2_66	7:05	7:07	0:02	TRANSFORMER FAULT
491	1-Dec-18	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI 220kV	13:30	14:07	0:36	LINE CLEAR AVAILED
492	1-Dec-18	TUMKUR	66	TR-2	NAYAKANAHATTI_66	13:44	13:50	0:05	TRANSFORMER FAULT
493	1-Dec-18	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR	18:07	18:49	0:41	LINE CLEAR AVAILED
494	1-Dec-18	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	6:13	6:17	0:04	HAND TRIPPED
495	1-Dec-18	TUMKUR	66	TR-1 & TR-2	SIRA_66,	10:13	10:42	0:28	LINE CLEAR AVAILED
496	1-Dec-18	TUMKUR	66	TR-1 & TR-2	SIRA_66,	12:30	12:58	0:27	LINE CLEAR AVAILED
497	2-Dec-18	BAGALKOT	110	110/11KV,HV2	BHUTHNAL_110	15:42	18:22	2:40	MAIN SUPPLY FAILURE
498	2-Dec-18	BAGALKOT	110	110/11KV,HV2	SUVARNA SOUDA_110	16:40	16:51	0:11	HAND TRIPPED
499	2-Dec-18	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	11:05	12:57	1:52	HAND TRIPPED
500	2-Dec-18	BAGALKOT	110	110/11KV,HV4	GADAG_110	12:59	13:31	0:32	HAND TRIPPED
501	2-Dec-18	BAGALKOT	110	110/33KV HV1&2,110/11KV HV4	BELGAUM_110	10:20	16:58	6:38	MAIN SUPPLY FAILURE

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
502	2-Dec-18	BAGALKOT	220	220/110 KV,HV2 & LV 2	NARENDRA_220,KUD DHARWAD_110,LAKAMANHALLI_110	21:34	22:30	0:56	HAND TRIPPED
503	2-Dec-18	BAGALKOT	220	220/110KV,HV1	BIJAPUR_220	17:10	18:13	1:03	LINE CLEAR AVAILED
504	2-Dec-18	BAGALKOT	110	220/110KV, LV1&LV2	BIJAPUR_220	15:47	18:54	3:07	LINE CLEAR AVAILED
505	2-Dec-18	BAGALKOT	110	220/110KV, LV1&LV2	BELGAUM_220	10:18	16:59	6:41	LINE CLEAR AVAILED
506	2-Dec-18	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	10:18	17:40	7:22	HAND TRIPPED
507	2-Dec-18	BAGALKOT	110	BELGAUM220-BELGAUM110	BELGAUM_110	10:10	16:55	6:45	HAND TRIPPED
508	2-Dec-18	BAGALKOT	110	BELGAUM220-HUKKERI	HUKKERI_110	9:57	18:04	8:07	HAND TRIPPED
509	2-Dec-18	BAGALKOT	110	BELGAUM220-KANABARGI	KANABARGI_110	10:01	16:58	6:57	HAND TRIPPED
510	2-Dec-18	BAGALKOT	110	BELGAUM-MACHE	MACHE_110	10:17	16:57	6:40	MAIN SUPPLY FAILURE
511	2-Dec-18	BAGALKOT	220	BIJAPUR1&2-BAGEWADI	BAGEWADI_220	14:38	18:49	4:11	NBFC ISSUED
512	2-Dec-18	BAGALKOT	110	BIJAPUR-BAGEWADI	BAGEWADI_220	16:02	19:13	3:11	LINE CLEAR AVAILED
513	2-Dec-18	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	10:10	16:44	6:34	LINE CLEAR AVAILED
514	2-Dec-18	BAGALKOT	220	HIREBENDIGERI2-BIDNAL	BIDNAL_220	0:00	11:16	11:16	LINE CLEAR AVAILED
515	2-Dec-18	BAGALKOT	110	KUDACHI 220-TERADAL	TERADAL_110	13:04	13:05	0:01	LINE FAULT
516	2-Dec-18	BAGALKOT	110	TARIHAL-NAVNAGAR(H)	NAVANAGAR(H)_110	21:03	22:00	0:57	HAND TRIPPED
517	2-Dec-18	BAGALKOT	220	VAISHALI1&2-BIJAPUR	BIJAPUR_220	15:55	19:06	3:11	LINE CLEAR AVAILED
518	2-Dec-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	19:08	19:13	0:05	LINE FAULT
519	2-Dec-18	BANGALORE	66	GANJIGUNTE - CHINTAMANI 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	19:08	19:15	0:07	LINE FAULT
520	2-Dec-18	BANGALORE	66	HV2	HONNIGANAHALLI	19:37	19:55	0:18	TRANSFORMER FAULT
521	2-Dec-18	BANGALORE	66	KOLAR 220 - NANAGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	4:56	5:19	0:23	LINE FAULT
522	2-Dec-18	BANGALORE	66	KOLAR 220-NARASAPURA 1	NARASAPURA	11:56	14:12	2:16	LINE CLEAR AVAILED
523	2-Dec-18	BANGALORE	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	5:17	5:20	0:03	MAIN SUPPLY FAILURE
524	2-Dec-18	BANGALORE	66	RMV - SRS PEENYA 220	RMV, TATA INSTITUTE(EHT)	5:41	5:45	0:04	LOAD CHANGE OVER
525	2-Dec-18	BANGALORE	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE(EHT)	9:50	10:00	0:10	LOAD CHANGE OVER
526	2-Dec-18	BANGALORE	66	HV2	VIJAYANAGAR	7:20	7:42	0:22	LOAD CHANGE OVER
527	2-Dec-18	BANGALORE	66	HV2	VIJAYANAGAR	11:25	11:30	0:05	LOAD CHANGE OVER
528	2-Dec-18	BANGALORE	66	HV2	VIJAYANAGAR	14:26	14:34	0:08	LOAD CHANGE OVER
529	2-Dec-18	BANGALORE	66	VRISHABHAVATHI- NRS	CHANDRA LAYOUT	7:20	9:30	2:10	LINE FAULT
530	2-Dec-18	BANGALORE	66	CHANDRA LAYOUT - NRS	CHANDRA LAYOUT	9:30	10:20	0:50	LINE FAULT
531	2-Dec-18	BANGALORE	66	HV2	C STATION	11:21	13:33	2:11	LINE CLEAR AVAILED
532	2-Dec-18	BANGALORE	66	GOKULA - SRS PEENYA 220	GOKULA	5:46	6:01	0:15	LOAD CHANGE OVER
533	2-Dec-18	BANGALORE	66	GOKULA - HEBBAL 220	GOKULA	9:45	9:59	0:14	LOAD CHANGE OVER

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
534	2-Dec-18	BANGALORE	66	MATHIKERE- SRS PEENYA 220	MATHIKERE	5:45	5:50	0:05	LOAD CHANGEOVER
535	2-Dec-18	BANGALORE	66	MATHIKERE- HEBBAL 220	MATHIKERE	9:59	10:04	0:05	LOAD CHANGEOVER
536	2-Dec-18	BANGALORE	66	NRS - REMCO MY 2	VIJAYANAGAR	8:34	9:32	0:58	LINE CLEAR AVAILED
537	2-Dec-18	BANGALORE	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	5:35	5:45	0:10	LOAD CHANGEOVER
538	2-Dec-18	BANGALORE	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	10:10	10:15	0:05	LOAD CHANGEOVER
539	2-Dec-18	BANGALORE	66	HV1	SOUTH CITY	13:10	13:15	0:05	LOAD CHANGEOVER
540	2-Dec-18	BANGALORE	66	HV1	SOUTH CITY	10:05	10:10	0:05	LOAD CHANGEOVER
541	2-Dec-18	BANGALORE	66	SRS PEENYA 220 - DG 2	ALUR, NELAMANGALA 66	7:20	8:05	0:45	LINE CLEAR AVAILED
542	2-Dec-18	BANGALORE	66	HV1	TELECOM LAYOUT	13:56	14:27	0:30	LINE CLEAR AVAILED
543	2-Dec-18	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	13:14	17:42	4:28	LINE CLEAR AVAILED
544	2-Dec-18	GULBARGA	110	HV2	SIRIGUPPA_110	22:57	23:59	1:02	LINE CLEAR AVAILED
545	2-Dec-18	GULBARGA	110	HV2	SIRIGUPPA_110	0:00	2:22	2:22	LINE CLEAR AVAILED
546	2-Dec-18	GULBARGA	110	WADAGERA-KHANAPUR	WADAGERA_110	5:00	5:06	0:06	LINE FAULT
547	2-Dec-18	GULBARGA	110	HV3	TAMBRAHALLI_110	12:05	14:00	1:55	LINE CLEAR AVAILED
548	2-Dec-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGRAGOAN_110, DIGGI_110	3:27	3:35	0:08	LINE FAULT
549	2-Dec-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGRAGOAN_110, DIGGI_110	4:37	4:49	0:12	LINE FAULT
550	2-Dec-18	GULBARGA	110	HV2	BETAGERA_110	15:58	16:02	0:04	TRANSFORMER FAULT
551	2-Dec-18	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	20:06	20:18	0:12	LINE FAULT
552	2-Dec-18	GULBARGA	66	HV1	TAMBRAHALLI_66	6:15	6:25	0:10	TRANSFORMER FAULT
553	2-Dec-18	GULBARGA	66	MUNIRABAD220-MSDLINE	HANASI_66	10:43	10:52	0:09	LINE FAULT
554	2-Dec-18	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:25	23:59	0:34	LINE CLEAR AVAILED
555	2-Dec-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	5:53	18:00	12:07	LINE CLEAR AVAILED
556	2-Dec-18	HASSAN	110	HV4	BAIKAMPADY_110	9:58	12:02	2:04	LINE CLEAR AVAILED
557	2-Dec-18	HASSAN	110	HV4	MRSMSG_220	15:12	16:07	0:55	TRANSFORMER FAULT
558	2-Dec-18	HASSAN	66	LV4	MRSMSG_220	15:12	16:14	1:02	TRANSFORMER FAULT
559	2-Dec-18	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	6:57	7:15	0:18	LINE FAULT
560	2-Dec-18	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	7:20	7:34	0:14	LINE FAULT
561	2-Dec-18	HASSAN	66	HV1	HARIHARPURA_66	16:29	17:05	0:36	TRANSFORMER FAULT
562	2-Dec-18	HASSAN	66	HNPR2-MYSOR1	HOLENARSIPURA_220	12:48	12:54	0:06	LINE FAULT
563	2-Dec-18	HASSAN	66	HNPR2-MYSOR1	HOLENARSIPURA_220	18:00	18:21	0:21	LINE FAULT
564	2-Dec-18	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	13:28	13:35	0:07	LINE CLEAR AVAILED
565	2-Dec-18	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	16:20	17:50	1:30	LINE CLEAR AVAILED
566	2-Dec-18	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	13:22	13:31	0:09	LINE FAULT
567	2-Dec-18	MYSORE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	4:09	4:20	0:10	LINE FAULT
568	2-Dec-18	MYSORE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	5:09	5:15	0:05	LINE FAULT
569	2-Dec-18	MYSORE	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66 THANDYA_66	10:05	19:13	9:08	HAND TRIPPED
570	2-Dec-18	MYSORE	66	KADAKOLA-NANJANGUDU 2	NANJANGUDU_66 THANDYA_66	10:03	19:12	9:09	HAND TRIPPED
571	2-Dec-18	TUMKUR	110	TR-3	AMMASANDRA_110	18:47	19:13	0:25	TRANSFORMER FAULT
572	2-Dec-18	TUMKUR	110	TR-1	GUBBI_110	0:12	0:15	0:02	TRANSFORMER FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
573	2-Dec-18	TUMKUR	110	HUNSEGHATTA_11-KBCROSS_66	HUNSEGHATTA_110,	9:14	9:40	0:25	HAND TRIPPED
574	2-Dec-18	TUMKUR	66	TR-1	BAGUR_TMK_66	7:01	7:38	0:37	TRANSFORMER FAULT
575	2-Dec-18	TUMKUR	66	TR-1	BAGUR_TMK_66	9:37	9:57	0:19	TRANSFORMER FAULT
576	2-Dec-18	TUMKUR	66	TR-1	BAGUR_TMK_66	10:08	10:58	0:50	TRANSFORMER FAULT
577	2-Dec-18	TUMKUR	66	TR-1	CHITRADURGA_220	10:40	14:17	3:36	HAND TRIPPED
578	2-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:09	17:48	9:39	HAND TRIPPED
579	2-Dec-18	TUMKUR	66	TR-1	HARAPPANAHALLI_66	19:19	20:08	0:49	TRANSFORMER FAULT
580	2-Dec-18	TUMKUR	66	MADHUGIRI 220KV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	10:01	12:12	2:11	LINE CLEAR AVAILED
581	2-Dec-18	TUMKUR	66	MADHUGIRI 66kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	9:50	12:17	2:27	LINE CLEAR AVAILED
582	2-Dec-18	TUMKUR	66	MADHUGIRI 66kv- BADAVANAHALLI	BADAVANAHALLI_66	9:50	12:18	2:28	LINE CLEAR AVAILED
583	2-Dec-18	TUMKUR	66	MADHUGIRI 66kv- BADAVANAHALLI	BADAVANAHALLI_66	15:24	15:27	0:02	LINE FAULT
584	2-Dec-18	TUMKUR	66	TR-1 & TR-2	MADHUGIRI_66	9:51	12:18	2:26	TRANSFORMER FAULT
585	2-Dec-18	TUMKUR	66	TR-1	NAGALMADIKE_66	15:05	16:19	1:14	TRANSFORMER FAULT
586	2-Dec-18	TUMKUR	66	TR-2	NAGALMADIKE_66	12:25	13:10	0:45	TRANSFORMER FAULT
587	3-Dec-18	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	10:44	11:39	0:55	HAND TRIPPED
588	3-Dec-18	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	12:34	14:22	1:48	LINE CLEAR AVAILED
589	3-Dec-18	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	13:25	15:05	1:40	MAIN SUPPLY FAILURE
590	3-Dec-18	BAGALKOT	220	BELGAUM 1-CHIKKODI	CHIKKODI_220	17:11	17:50	0:39	NBFC ISSUED
591	3-Dec-18	BAGALKOT	220	CHIKKODI 1-BELGAUM	BELGAUM_220	0:00	17:50	17:50	LINE CLEAR AVAILED
592	3-Dec-18	BAGALKOT	110	ENERCON 1-DAMBAL	DAMBAL_110	11:41	17:12	5:31	LINE CLEAR AVAILED
593	3-Dec-18	BAGALKOT	110	110/33KV,HV3	GOPANAKOPPA_110	11:49	12:26	0:37	TRANSFORMER FAULT
594	3-Dec-18	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110	11:49	12:09	0:20	TRANSFORMER FAULT
595	3-Dec-18	BAGALKOT	110	110/33KV,HV3	GOPANAKOPPA_110	12:28	13:29	1:01	TRANSFORMER FAULT
596	3-Dec-18	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110	13:31	13:39	0:08	TRANSFORMER FAULT
597	3-Dec-18	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	0:50	2:30	1:40	TRANSFORMER FAULT
598	3-Dec-18	BAGALKOT	110	MAHALINGAPUR220-GSML1&2	MAHALINGAPUR_220	1:50	12:10	10:20	HAND TRIPPED
599	3-Dec-18	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	1:42	2:06	0:24	HAND TRIPPED
600	3-Dec-18	BAGALKOT	110	110/33KV,HV3	ZALKI_110	22:01	22:09	0:08	TRANSFORMER FAULT
601	3-Dec-18	BAGALKOT	110	RANNABELAGALI-UTTUR	UTTUR_110	1:58	13:42	11:44	LINE FAULT
602	3-Dec-18	BAGALKOT	110	RANNABELAGALI-UTTUR	UTTUR_110	13:44	23:59	10:15	HAND TRIPPED
603	3-Dec-18	BAGALKOT	110	UMMACHAGI-SIRSI	SIRSI_110	15:24	23:59	8:35	LINE FAULT
604	3-Dec-18	BAGALKOT	110	HUBLI 220-RAMANKOPPA	RAMANKOPPA_110	10:53	15:40	4:47	LINE CLEAR AVAILED
605	3-Dec-18	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	13:00	13:26	0:26	HAND TRIPPED
606	3-Dec-18	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	10:15	12:35	2:20	LINE CLEAR AVAILED
607	3-Dec-18	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	MUDHOL_110	0:00	1:56	1:56	HAND TRIPPED
608	3-Dec-18	BAGALKOT	110	RANNABELAGALI-MUDHOL	MUDHOL_110	2:01	11:28	9:27	HAND TRIPPED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
609	3-Dec-18	BANGALORE	66	HV1	BOODIGERE	12:04	12:09	0:05	TRANSFORMER FAULT
610	3-Dec-18	BANGALORE	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	11:28	11:31	0:02	LINE CLEAR AVAILED
611	3-Dec-18	BANGALORE	66	HV1	CHAKAVELU	14:06	14:10	0:03	LINE CLEAR AVAILED
612	3-Dec-18	BANGALORE	66	HV1	CHAKAVELU	18:10	18:23	0:13	TRANSFORMER FAULT
613	3-Dec-18	BANGALORE	66	HV1	DEVANAHALLI	14:38	14:43	0:04	TRANSFORMER FAULT
614	3-Dec-18	BANGALORE	66	YEDUMADU - HANUMANTHNAGARA	YEDUMADU	10:23	10:37	0:14	LOAD CHANGEOVER
615	3-Dec-18	BANGALORE	66	HV2	GOWRIBIANUR 220	15:10	15:30	0:20	TRANSFORMER FAULT
616	3-Dec-18	BANGALORE	66	HV1	HEBBAL 220	14:02	15:45	1:43	LINE CLEAR AVAILED
617	3-Dec-18	BANGALORE	66	HV2	SHOBHA APARTMENT	14:26	14:35	0:08	LINE CLEAR AVAILED
618	3-Dec-18	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	17:16	17:46	0:29	LINE FAULT
619	3-Dec-18	BANGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	6:42	6:46	0:04	LOAD CHANGEOVER
620	3-Dec-18	BANGALORE	66	POTTERY ROAD - HEBBAL 220	POTTERY ROAD	17:46	18:08	0:21	LOAD CHANGEOVER
621	3-Dec-18	BANGALORE	66	HOODY 220 - ITI	ITI, BANASWADI	12:18	15:19	3:01	LINE CLEAR AVAILED
622	3-Dec-18	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	14:04	16:16	2:12	LINE FAULT
623	3-Dec-18	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	14:04	14:33	0:29	MAIN SUPPLY FAILURE
624	3-Dec-18	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	16:14	16:34	0:19	LINE CLEAR AVAILED
625	3-Dec-18	BANGALORE	220	HV2	HOODY 220	14:04	15:00	0:55	TRANSFORMER FAULT
626	3-Dec-18	BANGALORE	220	HV3	HOODY 220	14:04	14:55	0:50	TRANSFORMER FAULT
627	3-Dec-18	BANGALORE	66	HOODY 220 - HAL 1 & 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	14:04	15:04	1:00	MAIN SUPPLY FAILURE
628	3-Dec-18	BANGALORE	66	HV2	HOODY 220	14:04	15:02	0:58	MAIN SUPPLY FAILURE
629	3-Dec-18	GULBARGA	110	HV2	KAMPLI_110	10:13	10:32	0:19	TRANSFORMER FAULT
630	3-Dec-18	GULBARGA	110	HV1	KAVITAL_110	10:46	11:08	0:22	LINE CLEAR AVAILED
631	3-Dec-18	GULBARGA	110	KOLHAR-SHAHI_SOLAR_IPP	KOLHAR_110	11:25	11:35	0:10	LINE CLEAR AVAILED
632	3-Dec-18	GULBARGA	110	KOLHAR-SHAHI_SOLAR_IPP	KOLHAR_110	12:10	12:15	0:05	LINE CLEAR AVAILED
633	3-Dec-18	GULBARGA	110	KOLHAR-SHAHI_SOLAR_IPP	KOLHAR_110	12:20	12:25	0:05	LINE CLEAR AVAILED
634	3-Dec-18	GULBARGA	110	KOLHAR-SHAHI_SOLAR_IPP	KOLHAR_110	12:50	12:55	0:05	LINE CLEAR AVAILED
635	3-Dec-18	GULBARGA	110	JANAWADA_SANTHAPUR	SANTHAPUR_110	6:08	6:21	0:13	LINE FAULT
636	3-Dec-18	GULBARGA	110	HV1	BETAGERA_110	13:45	14:45	1:00	LINE CLEAR AVAILED
637	3-Dec-18	GULBARGA	110	HV1	BETAGERA_110	14:50	15:25	0:35	LINE CLEAR AVAILED
638	3-Dec-18	GULBARGA	110	BETAGERA-KSHVCMNT_SLR	BETAGERA_110	15:46	17:35	1:49	LINE CLEAR AVAILED
639	3-Dec-18	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	20:55	21:00	0:05	LINE FAULT
640	3-Dec-18	GULBARGA	66	ITTAGI-HIRHADAGALLI	HIREHADAGALLI_66	17:49	17:52	0:03	LINE FAULT
641	3-Dec-18	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	0:00	15:57	15:57	LINE CLEAR AVAILED
642	3-Dec-18	HASSAN	220	UPCL-KEMAR2	UPCL_GEN	0:00	10:45	10:45	LINE CLEAR AVAILED
643	3-Dec-18	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	16:00	22:32	6:32	LINE FAULT
644	3-Dec-18	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	12:50	12:57	0:07	LINE FAULT
645	3-Dec-18	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	12:50	16:18	3:28	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
646	3-Dec-18	HASSAN	66	HV1	MALLAPURA_66	14:10	14:59	0:49	LINE CLEAR AVAILED
647	3-Dec-18	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 G MALLIGERE_66, GUDDENAHALLI_66, BOGADHI MANDYA_66 & NAGAMANGALA_66	8:43	8:53	0:09	LINE FAULT
648	3-Dec-18	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66,GAMANAHALLY_66, TARIPURA_66	2:11	2:18	0:06	LINE FAULT
649	3-Dec-18	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66,GAMANAHALLY_66, TARIPURA_66	20:13	20:22	0:09	LINE FAULT
650	3-Dec-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66, BASARALU_66, ADICHUNCHANAGIRI_66, ADDIHALLI_66, HARADANAHALLI(JAK)_66 ,BGNAGARA_66 ,VADERALLI_66	6:47	6:56	0:08	LINE FAULT
651	3-Dec-18	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2	ANCHEPALYA_220	11:24	11:43	0:19	HAND TRIPPED
652	3-Dec-18	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 1	MADHUGIRI 220kV	12:43	15:24	2:40	LINE CLEAR AVAILED
653	3-Dec-18	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 2	MADHUGIRI 220kV	12:43	15:25	2:41	LINE CLEAR AVAILED
654	3-Dec-18	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66	16:08	16:16	0:07	LINE FAULT
655	3-Dec-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:58	11:10	0:11	LINE FAULT
656	3-Dec-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:06	16:26	0:20	HAND TRIPPED
657	3-Dec-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:06	16:28	0:21	HAND TRIPPED
658	3-Dec-18	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJHALLI_66	16:06	16:27	0:21	HAND TRIPPED
659	3-Dec-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:27	17:20	0:53	HAND TRIPPED
660	3-Dec-18	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	16:07	16:28	0:21	HAND TRIPPED
661	3-Dec-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:32	17:47	9:14	HAND TRIPPED
662	3-Dec-18	TUMKUR	66	TR-1	HALUVAGALU_66	12:03	12:53	0:49	LINE CLEAR AVAILED
663	3-Dec-18	TUMKUR	66	NEELAGUNDA 220kV-HARAPPANAHALLI	HARAPPANAHALLI_66	6:17	7:21	1:03	LINE FAULT
664	3-Dec-18	TUMKUR	66	TR-1	HONNALI_66	11:48	12:00	0:11	LINE CLEAR AVAILED