

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 21.06.22 TO 27.06.22

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	21-Jun-22	BAGALKOT	110	110/11 KV, HV1	KIDB BIJAPUR_110	14:25	14:30	0:05	TRANSFORMER FAULT
2	21-Jun-22	BAGALKOT	110	110/11KV, HV1	HALIYAL(ATHN)_110	8:01	15:02	7:01	LINE CLEAR AVAILED
3	21-Jun-22	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	15:27	16:25	0:58	LINE CLEAR AVAILED
4	21-Jun-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MANTUR_110	14:40	15:05	0:25	LINE CLEAR AVAILED
5	21-Jun-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKHOD_220	13:20	16:25	3:05	LINE CLEAR AVAILED
6	21-Jun-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED RAMADURGA_110	15:30	16:10	0:40	LINE CLEAR AVAILED
7	21-Jun-22	BAGALKOT	110	110/11KV, HV2	HALIYAL(ATHN)_110	8:01	15:02	7:01	LINE CLEAR AVAILED
8	21-Jun-22	BAGALKOT	110	110/11KV,HV1	TILUVALI_110	11:39	17:13	5:34	LINE CLEAR AVAILED
9	21-Jun-22	BAGALKOT	110	110/11KV,HV1	TILUVALI_110	17:33	19:00	1:27	TRANSFORMER FAULT
10	21-Jun-22	BAGALKOT	110	110/11KV,HV2	KUDUCHI_110	17:20	17:26	0:06	LINE CLEAR AVAILED
11	21-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
12	21-Jun-22	BAGALKOT	110	110/11KV,HV3(HV2)	MUDHOL_110	14:12	14:29	0:17	LINE CLEAR AVAILED
13	21-Jun-22	BAGALKOT	110	110/33KV, HV3	HOSARATTI_33 GUTTAL_110	10:31	11:59	1:28	LINE CLEAR AVAILED
14	21-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
15	21-Jun-22	BAGALKOT	110	110/33KV, HV3, & HV4	KUSUGAL_33 KMC_33 STATION NOT AFFECTED GOPANAKOPPA_110	10:00	16:38	6:38	LINE CLEAR AVAILED
16	21-Jun-22	BAGALKOT	110	110/33KV,HV3	SHIGGOAN_110	11:50	12:00	0:10	TRANSFORMER FAULT
17	21-Jun-22	BAGALKOT	110	ALMELU-JAMAKHANDI	ALMELU_111	14:22	15:13	0:51	LINE FAULT
18	21-Jun-22	BAGALKOT	110	ALMELU-KPRSUGAR	ALMELU_110	14:22	14:37	0:15	LINE FAULT
19	21-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
20	21-Jun-22	BAGALKOT	110	BELGAUM220-VADAGOAN	STATION NOT AFFECTED VADAGOAN_110	5:38	8:37	2:59	LINE CLEAR AVAILED
21	21-Jun-22	BAGALKOT	110	BJCTY(TIKOTA)-TIKKOTA	TIKOTA_110	4:55	17:10	12:15	NFBC ISSUED
22	21-Jun-22	BAGALKOT	110	GADAG220-DAMBAL	DAMBAL_110	11:06	15:06	4:00	LINE CLEAR AVAILED
23	21-Jun-22	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTED HUBLI_220	11:37 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
24	21-Jun-22	BAGALKOT	110	KAWALWADA- NK-2	KAWALWADA_110	13:40	13:47	0:07	MAIN SUPPLY FAILURE
25	21-Jun-22	BAGALKOT	110	KONNUR-ANTSLR	KONNUR_110	14:22	14:26	0:04	LINE FAULT
26	21-Jun-22	BAGALKOT	110	KUDUCHI220-UGAR KHUD(KUDUCHI)	KUDUCHI_220	9:24	17:08	7:44	LINE CLEAR AVAILED
27	21-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
28	21-Jun-22	BAGALKOT	110	TAKKALAKI-KNS SOLAR	TAKKALAKI_110	10:22	17:15	6:53	LINE CLEAR AVAILED
29	21-Jun-22	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	10:22	17:12	6:50	LINE CLEAR AVAILED
30	21-Jun-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	10:22	17:14	6:52	LINE CLEAR AVAILED
31	21-Jun-22	BAGALKOT	110	TAKKALAKI-WARADA SOLAR	TAKKALAKI_110	10:22	17:17	6:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
32	21-Jun-22	BAGALKOT	110	TIKOTA-BHUTNAL	STATION NOT AFFECTED TIKOTA_110	10:35	17:13	6:38	NFBC ISSUED
33	21-Jun-22	BAGALKOT	110	VAJRAMATTI220-MELLIGERI	MELLIGERI_110	10:34	10:48	0:14	HAND TRIPPED
34	21-Jun-22	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	10:34	10:46	0:12	HAND TRIPPED
35	21-Jun-22	BAGALKOT	220	220/110KV, HV1,LV1	STATION NOT AFFECTED GADAG_220	12:30	19:42	7:12	LINE CLEAR AVAILED
36	21-Jun-22	BAGALKOT	220	BIDNAL-HUBLI1	STATION NOT AFFECTED BIDNAL_220	15:30	17:45	2:15	NFBC ISSUED
37	21-Jun-22	BAGALKOT	220	BIDNAL-HUBLI3(HUBLI2)	STATION NOT AFFECTED BIDNAL_220	10:49	12:46	1:57	NFBC ISSUED
38	21-Jun-22	BAGALKOT	220	HAVERI-GUTUR1	STATION NOT AFFECTED HAVERI_220	15:38	15:50	0:12	LINE CLEAR AVAILED
39	21-Jun-22	BAGALKOT	220	HAVERI-GUTUR2	STATION NOT AFFECTED HAVERI_220	16:12	17:57	1:45	LINE CLEAR AVAILED
40	21-Jun-22	BAGALKOT	220	HAVERI-NARENDRA	STATION NOT AFFECTED HAVERI_220	15:52	16:02	0:10	LINE CLEAR AVAILED
41	21-Jun-22	BAGALKOT	220	HUBLI-BIDNAL-1	STATION NOT AFFECTED HUBLI_220	15:30	17:43	2:13	LINE CLEAR AVAILED
42	21-Jun-22	BAGALKOT	220	HUBLI-BIDNAL-2	STATION NOT AFFECTED HUBLI_220	10:56	14:21	3:25	LINE CLEAR AVAILED
43	21-Jun-22	BAGALKOT	220	HUBLI-NAGJHARI-2	STATION NOT AFFECTED HUBLI_220	11:04	13:38	2:34	LINE CLEAR AVAILED
44	21-Jun-22	BAGALKOT	220	HUBLI-NAGJHARI-3	STATION NOT AFFECTED HUBLI_220	13:09	13:40	0:31	HAND TRIPPED
45	21-Jun-22	BAGALKOT	220	HUBLI-SIRSI-1	STATION NOT AFFECTED HUBLI_220	10:30 (21.06.2022)			LINE OPEN:LINE CLEAR AVAILED
46	21-Jun-22	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:05 (15.06.2022)			LINE OPEN:LINE CLEAR AVAILED
47	21-Jun-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
48	21-Jun-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)			LINE OPEN:LINE CLEAR AVAILED
49	21-Jun-22	BAGALKOT	220	VAJRAMATTI- KUDAGI-II	STATION NOT AFFECTED VAJRAMATTI_220	3:05	3:06	0:01	LINE FAULT
50	21-Jun-22	BENGALURU	66	BIAL BEGUR 220 - BOODIGERE	BOODIGERE	9:44	10:05	0:21	LINE FAULT
51	21-Jun-22	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	22:09	22:13	0:04	LOAD CHANGE OVER
52	21-Jun-22	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	23:39(20/06/2022)	00:12(21/06/2022)	00:33HRS	LINE CHARGED
53	21-Jun-22	BENGALURU	66	HOODY 220 - HP(EHT)	HP(EHT)	23:39(20/06/2022)	00:15(21/06/2022)	00:36HRS	LINE CHARGED
54	21-Jun-22	BENGALURU	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	23:39(20/06/2022)	00:20(21/06/2022)	00:41HRS	LINE CHARGED
55	21-Jun-22	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR	NO STATION AFFECTED	12:35	17:20	4:44	LINE CLEAR AVAILED
56	21-Jun-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:41	12:14	0:33	LINE FAULT
57	21-Jun-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	11:41	12:20	0:39	LINE FAULT
58	21-Jun-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	11:41	12:42	1:01	LINE FAULT
59	21-Jun-22	BENGALURU	66	HV1	BYRAPATNA	15:15	15:25	0:10	LINE CLEAR AVAILED
60	21-Jun-22	BENGALURU	66	HV1	GLOBAL TECH PARK	10:36	10:37	0:01	LINE CLEAR AVAILED
61	21-Jun-22	BENGALURU	66	HV1	GUDEMARAMAHALLI	10:49	10:55	0:05	LINE CLEAR AVAILED
62	21-Jun-22	BENGALURU	66	HV1	HUKUNDA	16:22	16:33	0:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
63	21-Jun-22	BENGALURU	66	HV1	HUKUNDA	16:35	16:43	0:07	LINE CLEAR AVAILED
64	21-Jun-22	BENGALURU	66	HV1	MALLASANDRA	11:05	11:22	0:17	LINE CLEAR AVAILED
65	21-Jun-22	BENGALURU	66	HV1	NRS 220	10:53	10:55	0:02	LINE CLEAR AVAILED
66	21-Jun-22	BENGALURU	66	HV1	TUBUGERE	11:25	11:30	0:05	LINE CLEAR AVAILED
67	21-Jun-22	BENGALURU	66	HV1	VIJAYANAGARA	22:20	22:32	0:12	LOAD CHANGE OVER
68	21-Jun-22	BENGALURU	66	HV2	BOODIGERE	12:25	13:25	1:00	TRANSFORMER FAULT
69	21-Jun-22	BENGALURU	66	HV2	GANJIGUNTE	13:20	13:26	0:06	TRANSFORMER FAULT
70	21-Jun-22	BENGALURU	66	HV2	GLOBAL TECH PARK	12:20	12:23	0:03	LINE CLEAR AVAILED
71	21-Jun-22	BENGALURU	66	HV2	GODUR	13:26	14:19	0:53	LINE CLEAR AVAILED
72	21-Jun-22	BENGALURU	66	HV2	MALLASANDRA	11:24	11:50	0:25	LINE CLEAR AVAILED
73	21-Jun-22	BENGALURU	66	HV2	MANYATHA TECH PARK 220	9:21	9:23	0:02	LINE CLEAR AVAILED
74	21-Jun-22	BENGALURU	66	HV2	MANYATHA TECH PARK 220	16:05	16:06	0:01	LOAD CHANGE OVER
75	21-Jun-22	BENGALURU	66	HV2	VIJAYANAGARA	22:20	22:32	0:12	LOAD CHANGE OVER
76	21-Jun-22	BENGALURU	66	HV2	YEDUMADU	3:08	3:30	0:22	TRANSFORMER FAULT
77	21-Jun-22	BENGALURU	66	HV2	YEDUMADU	2:25	2:30	0:05	TRANSFORMER FAULT
78	21-Jun-22	BENGALURU	66	HV3	MANYATHA TECH PARK 220	9:21	9:23	0:02	LINE CLEAR AVAILED
79	21-Jun-22	BENGALURU	66	HV3	MANYATHA TECH PARK 220	16:05	16:06	0:01	LOAD CHANGE OVER
80	21-Jun-22	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT)	HIMAT SINGHA FACTORY (EHT)	10:43(20-6-2022)	19:39(21/06/2022)	32:56HRS	LINE CHARGED
81	21-Jun-22	BENGALURU	66	MAASTHI - MALUR 220	MAASTHI	17:00	17:15	0:15	LINE CLEAR AVAILED
82	21-Jun-22	BENGALURU	66	SIDDLAGHATTA - CHINTAMANI 220	SIDDLAGHATTA	11:03	11:09	0:06	LOAD CHANGE OVER
83	21-Jun-22	BENGALURU	66	SIDDLAGHATTA - MELUR	SIDDLAGHATTA	18:24	18:28	0:04	LOAD CHANGE OVER
84	21-Jun-22	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	13:50	13:55	0:05	LINE FAULT
85	21-Jun-22	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	13:50	13:55	0:05	LINE FAULT
86	21-Jun-22	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	15:13:00(18/06/2022)			LINE OPEN: LINE FAULT
87	21-Jun-22	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	2:06	2:25	0:18	LINE FAULT
88	21-Jun-22	BENGALURU	66	YEDUMADU - HANUMANTHNAGAR	YEDUMADU	2:25	2:29	0:04	LINE FAULT
89	21-Jun-22	BENGALURU	66	YEDUMADU - HANUMANTHNAGAR	YEDUMADU	3:08	3:10	0:02	LINE FAULT
90	21-Jun-22	BENGALURU	220	HV1	KIADB DB PURA 220	14:48	16:00	1:12	LINE CLEAR AVAILED
91	21-Jun-22	BENGALURU	220	HV2	HOSKOTE 220	11:41	14:21	2:40	TRANSFORMER FAULT
92	21-Jun-22	BENGALURU	220	KIADB HARDWARE PARK 220 - BIAL BEGUR 1	NO STATION AFFECTED	14:57	17:18	2:20	LINE CLEAR AVAILED
93	21-Jun-22	BENGALURU	220	LV2	HOODY 220	23:39(20/06/2022)	1:11(21/06/2022)	1:32HRS	TRANSFORMER CHARGED
94	21-Jun-22	BENGALURU	220	LV2	HOSKOTE 220	11:41	14:45	3:04	TRANSFORMER FAULT
95	21-Jun-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	20:50	20:55	0:05	MAIN SUPPLY FAILURE
96	21-Jun-22	GULBARGA	110	HV1	GULBARGA UNIVERCITY_110	11:20	12:25	1:05	LINE CLEAR AVAILED
97	21-Jun-22	GULBARGA	110	HV2	KUSTAGI_220	21:18	22:23	1:05	TRANSFORMER FAULT
98	21-Jun-22	GULBARGA	110	HV2	KUSTAGI_220	22:28	22:30	0:02	TRANSFORMER FAULT
99	21-Jun-22	GULBARGA	110	HV2	KUSTAGI_220	22:32	22:43	0:11	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
100	21-Jun-22	GULBARGA	110	HV2	SHAHAPUR_220	17:11	17:30	0:19	TRANSFORMER FAULT
101	21-Jun-22	GULBARGA	110	HV2	MYLAR_110	13:35	13:45	0:10	LINE CLEAR AVAILED
102	21-Jun-22	GULBARGA	110	HV2	UJJANI_66	13:34	13:41	0:07	TRANSFORMER FAULT
103	21-Jun-22	GULBARGA	110	HV2	UJJANI_66	16:39	16:45	0:06	TRANSFORMER FAULT
104	21-Jun-22	GULBARGA	110	KAPNOOR-HUMNABAD_1	MAHAGOAN_110,MARGUTTI_110	1:50	2:43	0:53	LINE FAULT
105	21-Jun-22	GULBARGA	110	KAPNOOR-HUMNABAD_1	MAHAGOAN_110,MARGUTTI_110	11:53	17:31	5:38	LINE CLEAR AVAILED
106	21-Jun-22	GULBARGA	110	KUSTAGI-ILKAL_1	ILKAL_110	15:17	15:33	0:16	LINE FAULT
107	21-Jun-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	18:36	18:44	0:08	LINE FAULT
108	21-Jun-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	22:32	22:40	0:08	LINE FAULT
109	21-Jun-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	23:01	23:09	0:08	LINE FAULT
110	21-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	5:00	5:05	0:05	LINE FAULT
111	21-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	20:10	21:00	0:50	LINE FAULT
112	21-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	21:50	22:15	0:25	LINE FAULT
113	21-Jun-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	VICAT SAGAR_IPP	1:10	1:25	0:15	LINE FAULT
114	21-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
115	21-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
116	21-Jun-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	22:20	22:24	0:04	LINE FAULT
117	21-Jun-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	20:45	20:52	0:07	LINE FAULT
118	21-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP,C OREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
119	21-Jun-22	GULBARGA	110	YERADONA-BENNUR	BENNUR_110	3:20	3:45	0:25	LINE FAULT
120	21-Jun-22	GULBARGA	110	YERADONA-BENNUR	BENNUR_110	23:05	23:20	0:15	LINE FAULT
121	21-Jun-22	GULBARGA	110	YERADONA-SINDHNOOR	SINDHNOOR_110	4:10	4:20	0:10	LINE FAULT
122	21-Jun-22	GULBARGA	220	HUMNABAD-HALBARGA 2	HALBARGA_220	7:40	9:25	1:45	LINE CLEAR AVAILED
123	21-Jun-22	GULBARGA	220	HUMNABAD-KAPNOOR 2	KAPNOOR_220	7:40	9:25	1:45	LINE CLEAR AVAILED
124	21-Jun-22	GULBARGA	220	HUMNABAD-SEDUM 2	SEDAM_220	7:40	9:20	1:40	LINE CLEAR AVAILED
125	21-Jun-22	GULBARGA	220	HV1	ITTAGI_220	12:50	12:57	0:07	TRANSFORMER FAULT
126	21-Jun-22	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
127	21-Jun-22	GULBARGA	220	HV2	HUMNABAD_220	20:55(20/06/2022)	09:28(21/06/2022)	12:33HRS	TRANSFORMER CHARGED
128	21-Jun-22	GULBARGA	220	HV2	ITTAGI_220	12:50	12:57	0:07	TRANSFORMER FAULT
129	21-Jun-22	GULBARGA	220	HV2	KAPNOOR_220	1:50	2:15	0:25	TRANSFORMER FAULT
130	21-Jun-22	GULBARGA	220	LINGSUGUR-BAGEWADI1 & 2	LINGSUGUR_220	10:04	13:41	3:37	LINE CLEAR AVAILED
131	21-Jun-22	GULBARGA	220	LINGSUGUR-SHAHAPUR	LINGSUGUR_220	12:40	13:37	0:57	LINE FAULT
132	21-Jun-22	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	12:32	12:35	0:03	LINE FAULT
133	21-Jun-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	0:21	0:35	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
134	21-Jun-22	GULBARGA	220	RAICHUR-JURALA 1 & 2 (IDLE LINE)	JURALA_IPP	10:42	18:07	7:25	LINE CLEAR AVAILED
135	21-Jun-22	GULBARGA	220	SEDAM-RTPS_2	SEDAM_220	17:05	17:32	0:27	LINE CLEAR AVAILED
136	21-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN: LINE FAULT
137	21-Jun-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	21:39 (21.06.2022)			LINE OPEN:LINE CLEAR AVAILED
138	21-Jun-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
139	21-Jun-22	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:09	14:32	3:23	LINE CLEAR AVAILED
140	21-Jun-22	HASSAN	66	BALEHN-ALDUR	BALEHONNUR_66	11:09	14:32	3:23	NFBC ISSUED
141	21-Jun-22	HASSAN	66	BYCHAN-HNPURA	BYACHANAHALLY_66	9:40	12:46	3:06	LINE CLEAR AVAILED
142	21-Jun-22	HASSAN	66	HNPR2-BANDISHTLY	HNPURA_220	10:35	12:05	1:30	LINE CLEAR AVAILED
143	21-Jun-22	HASSAN	66	HV1	BAGUR_66	12:25	13:37	1:12	LINE CLEAR AVAILED
144	21-Jun-22	HASSAN	66	HV1	BYACHANAHALLY_66	9:40	12:46	3:06	LINE CLEAR AVAILED
145	21-Jun-22	HASSAN	66	HV2	BAGUR_66	12:25	13:37	1:12	LINE CLEAR AVAILED
146	21-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
147	21-Jun-22	HASSAN	66	SHANTI-RMSWRNGR	SHANTHIGRAMA_66	15:15	17:32	2:17	LINE CLEAR AVAILED
148	21-Jun-22	HASSAN	110	BAIKAMP-KAVOOR	BAIKAMPADY_110	6:52	7:07	0:15	MAIN SUPPLY FAILURE
149	21-Jun-22	HASSAN	110	HV1	BARANGI_110	6:57	7:05	0:08	HAND TRIPPED
150	21-Jun-22	HASSAN	110	HV1	KULASHEKARA_110	11:18	11:25	0:07	TRANSFORMER FAULT
151	21-Jun-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
152	21-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
153	21-Jun-22	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	6:50	7:05	0:15	LINE FAULT
154	21-Jun-22	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	9:40	17:49	8:09	LINE CLEAR AVAILED
155	21-Jun-22	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	11:18	11:31	0:13	LINE FAULT
156	21-Jun-22	HASSAN	110	KULASH-KERKNJ	KULASHEKARA_110	11:18	11:31	0:13	LINE FAULT
157	21-Jun-22	HASSAN	110	LV2	KAVOOR_220	9:40	17:49	8:09	LINE CLEAR AVAILED
158	21-Jun-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_20	9:55	21:16	11:21	LINE CLEAR AVAILED
159	21-Jun-22	HASSAN	220	HV2	KAVOOR_220	9:40	17:49	8:09	LINE CLEAR AVAILED
160	21-Jun-22	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	14:35	15:04	0:29	LINE CLEAR AVAILED
161	21-Jun-22	HASSAN	220	KEMAR-KAVOOR	KEMAR_220	14:03	15:04	1:01	LINE CLEAR AVAILED
162	21-Jun-22	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	13:02	13:37	0:35	LINE CLEAR AVAILED
163	21-Jun-22	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	13:39	14:10	0:31	LINE CLEAR AVAILED
164	21-Jun-22	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	13:39	14:10	0:31	LINE CLEAR AVAILED
165	21-Jun-22	HASSAN	220	KEMAR-UPCL2	KEMAR_220	10:22	17:48	7:26	NFBC ISSUED
166	21-Jun-22	HASSAN	220	MRSSHM-STRP	MRSMSG_220	10:20	14:36	4:16	LINE CLEAR AVAILED
167	21-Jun-22	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	13:02	13:37	0:35	NFBC ISSUED
168	21-Jun-22	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	13:39	14:10	0:31	NFBC ISSUED
169	21-Jun-22	HASSAN	220	UPCL-KEMAR2	gen_upcl	10:22	17:48	7:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
170	21-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
171	21-Jun-22	MYSORE	66	C R NAGARA-BADANAGUPPE 2	BADANAGUPPE_66	5:34	5:52	0:18	LINE FAULT
172	21-Jun-22	MYSORE	66	C R NAGARA-KOLLEGALA	NO STATIONS EFFECTED	11:00	13:07	2:07	LINE CLEAR AVAILED
173	21-Jun-22	MYSORE	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN:LINE CLEAR AVAILED
174	21-Jun-22	MYSORE	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
175	21-Jun-22	MYSORE	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
176	21-Jun-22	MYSORE	66	HOOTAGLLY-DATTAGALLY	NO STATIONS EFFECTED	11:29	11:39	0:10	HAND TRIPPED
177	21-Jun-22	MYSORE	66	HV1	BG NAGARA_66	10:53	13:35	2:42	LINE CLEAR AVAILED
178	21-Jun-22	MYSORE	66	HV2	BG NAGARA_66	13:38	16:10	2:31	LINE CLEAR AVAILED
179	21-Jun-22	MYSORE	66	HV2	GAMANAHALLY_66	20:45	21:00	0:15	LINE CLEAR AVAILED
180	21-Jun-22	MYSORE	66	HV2	KOLKARANADODDI_66	10:30	11:25	0:55	LINE CLEAR AVAILED
181	21-Jun-22	MYSORE	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
182	21-Jun-22	MYSORE	66	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	11:11	13:18	2:06	LINE CLEAR AVAILED
183	21-Jun-22	MYSORE	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	10:15:21 (20.06.2022)	13:15:00 (21.06.2022)	26:59 hrs	LINE CHARGED
184	21-Jun-22	MYSORE	66	MUGUR-THAYURU	NO STATIONS EFFECTED	9:40:00 (20.06.2022)			LINE OPEN:LINE CLEAR AVAILED
185	21-Jun-22	MYSORE	66	SANTHESARGUR-KADAKOLA1	YEREHALLI HANDPOSR_66 HD KOTE_66 ANATARSANTE_66	5:41	5:52	0:11	LINE FAULT
186	21-Jun-22	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	11:06	11:17	0:10	LINE FAULT
187	21-Jun-22	TUMKUR	66	BALENAHALLI-CHALKERE	CHALKERE_66	10:04	14:42	4:38	NFBC ISSUED
188	21-Jun-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	19:07	19:25	0:17	LINE FAULT
189	21-Jun-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	20:25	20:35	0:10	LINE FAULT
190	21-Jun-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	15:00	15:11	0:10	LINE FAULT
191	21-Jun-22	TUMKUR	66	GULIGENAHALLI- (MADHUGIRI JSIRA_220	GULIGENAHALLI_66	13:00	14:10	1:10	LINE CLEAR AVAILED
192	21-Jun-22	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:41	17:32	0:50	LINE CLEAR AVAILED
193	21-Jun-22	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	20:07	20:14	0:07	LINE FAULT
194	21-Jun-22	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	19:08	19:16	0:07	LINE FAULT
195	21-Jun-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	15:36	15:47	0:11	LINE FAULT
196	21-Jun-22	TUMKUR	66	PKOTE-AZURE SOLAR	AZURE SOLAR_66	16:44	17:11	0:27	MAIN SUPPLY FAILURE
197	21-Jun-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	16:44	17:11	0:27	MAIN SUPPLY FAILURE
198	21-Jun-22	TUMKUR	66	PKOTE-HARIYABBE	PKOTE_66	16:36	17:06	0:29	MAIN SUPPLY FAILURE
199	21-Jun-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	16:44	17:11	0:27	MAIN SUPPLY FAILURE
200	21-Jun-22	TUMKUR	66	TR-1	ANTHARASANAHALI_220	15:36	16:27	0:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
201	21-Jun-22	TUMKUR	66	TR-1	GULIGENAHALLI_66	13:00	14:13	1:13	LINE CLEAR AVAIED
202	21-Jun-22	TUMKUR	66	TR-1	KATRIKIHAI_66	14:30	14:31	0:01	TRANSFORMER FAULT
203	21-Jun-22	TUMKUR	66	TR-1	SANTEMNAVATTUR_66	4:34	4:44	0:09	TRANSFORMER FAULT
204	21-Jun-22	TUMKUR	66	TR-1	SANTEMNAVATTUR_66	13:36	14:07	0:31	LINE CLEAR AVAIED
205	21-Jun-22	TUMKUR	66	TR-2	ANTHARASANAHALI_220	10:39	15:28	4:48	LINE CLEAR AVAIED
206	21-Jun-22	TUMKUR	66	TR-2	GULIGENAHALLI_66	13:00	14:13	1:13	LINE CLEAR AVAIED
207	21-Jun-22	TUMKUR	66	TR-2	HALURAMESWARA_66	2:02	2:19	0:17	TRANSFORMER FAULT
208	21-Jun-22	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	11:35	11:49	0:14	TRANSFORMER FAULT
209	21-Jun-22	TUMKUR	66	TR-2	MALEBENNUR_66	17:01	17:18	0:16	LINE CLEAR AVAIED
210	21-Jun-22	TUMKUR	66	TR-2(LV-2)	ANCHEPALYA_220	14:18	16:52	2:34	LINE CLEAR AVAIED
211	21-Jun-22	TUMKUR	110	K G TEMPLE-UNGRDLI	KGTEMPLE_110	11:35	12:28	0:52	LINE CLEAR AVAIED
212	21-Jun-22	TUMKUR	110	TR-1	KATRIKEHAL_110	4:10	4:20	0:10	MAIN SUPPLY FAILURE
213	21-Jun-22	TUMKUR	110	TR-1	KB CROSS_220	12:02	17:26	5:24	LINE CLEAR AVAIED
214	21-Jun-22	TUMKUR	220	TR-3	HIRIYUR_220	16:07	16:46	0:39	TRANSFORMER FAULT
1	22-Jun-22	BAGALKOT	110	110/11KV, HV1	TILUVALI_110	21:49	22:14	0:25	LINE CLEAR AVAIED
2	22-Jun-22	BAGALKOT	110	110/11KV, HV1	BISANAL_110	8:30	15:55	7:25	LINE CLEAR AVAIED
3	22-Jun-22	BAGALKOT	110	110/11KV, HV1	BILAGI_110	8:30	16:50	8:20	LINE CLEAR AVAIED
4	22-Jun-22	BAGALKOT	110	110/11KV, HV1	GIRASAGAR_110	08:25	16:55	8:30	LINE CLEAR AVAIED
5	22-Jun-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILUVALLI_110	21:35	22:14	0:39	TRANSFORMER FAULT
6	22-Jun-22	BAGALKOT	110	110/11KV, HV2	ZALKI_110	13:33	14:09	0:36	HAND TRIPPED
7	22-Jun-22	BAGALKOT	110	110/11KV, HV2	ZALKI_110	15:19	16:31	1:12	LINE CLEAR AVAIED
8	22-Jun-22	BAGALKOT	110	110/11KV, HV2	BILAGI_110	08:30	16:50	8:20	LINE CLEAR AVAIED
9	22-Jun-22	BAGALKOT	110	110/11KV, HV2	GIRASAGAR_110	08:25	16:55	8:30	LINE CLEAR AVAIED
10	22-Jun-22	BAGALKOT	110	110/11KV,HV1	KUDUCHI_220	7:55	8:04	0:09	TRANSFORMER FAULT
11	22-Jun-22	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	18:10	18:20	0:10	LINE CLEAR AVAIED
12	22-Jun-22	BAGALKOT	110	110/11KV,HV1	MALGHAN(S)_110	12:29	13:02	0:33	LINE CLEAR AVAIED
13	22-Jun-22	BAGALKOT	110	110/11KV,HV1	SULTANPUR_110	18:37	18:39	0:02	TRANSFORMER FAULT
14	22-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
15	22-Jun-22	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	18:03	18:10	0:07	LINE CLEAR AVAIED
16	22-Jun-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(S)_110	13:17	15:13	1:56	LINE CLEAR AVAIED
17	22-Jun-22	BAGALKOT	110	110/33KV, HV2	TEGGI_33, GULABAL LIS_33 BISANAL_110	8:30	16:55	8:25	LINE CLEAR AVAIED
18	22-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
19	22-Jun-22	BAGALKOT	110	110/33KV,HV3	LINGADAHALLI LIS_33,DEVARA GENNUR_33 MAMADAPUR(B)_110	18:10	18:20	0:10	LINE CLEAR AVAIED
20	22-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAIED
21	22-Jun-22	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	10:38	16:44	6:06	NFBC ISSUED
22	22-Jun-22	BAGALKOT	110	ATHARGA-KN SOLAR	ATHARGA_110	5:46	6:53	1:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
23	22-Jun-22	BAGALKOT	110	BABLESHWAR-MAMADAPUR	STATION NOT AFFECTED BABLESHWAR_110	10:39	18:49	8:10	LINE CLEAR AVAILED
24	22-Jun-22	BAGALKOT	110	DADDI-HONAGA	DADDI_110	3:44	3:51	0:07	LINE FAULT
25	22-Jun-22	BAGALKOT	110	DEVARA GENNUR -SHIRBUR	SHIRBUR_110	3:08	3:22	0:14	LINE FAULT
26	22-Jun-22	BAGALKOT	110	DEVARA GENNUR -SHIRBUR	SHIRBUR_110	10:17	19:21	9:04	LINE CLEAR AVAILED
27	22-Jun-22	BAGALKOT	110	DEVARA GENNUR -SHIRBUR	SHIRBUR_110	19:53	20:02	0:09	LINE FAULT
28	22-Jun-22	BAGALKOT	110	GHATAPRABHA220- MUDALAGI(MANTUR(G))	MANTUR(G)_110	15:34	17:44	2:10	LINE CLEAR AVAILED
29	22-Jun-22	BAGALKOT	110	GIRISAGAR- BILAGI SUGERS	BILAGI SUGERS_110 GIRASAGAR_110	08:25	16:55	8:30	LINE CLEAR AVAILED
30	22-Jun-22	BAGALKOT	110	HAVERI220-TILUVALLI	TILUVALLI_110	12:11	18:33	6:22	LINE CLEAR AVAILED
31	22-Jun-22	BAGALKOT	110	HAVERI-TILUVALI	TILUVALI_110	12:10	18:34	6:24	LINE CLEAR AVAILED
32	22-Jun-22	BAGALKOT	110	HIREMASALI-ATHARGA	ATHARGA_110	5:30	5:42	0:12	LINE FAULT
33	22-Jun-22	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTED HUBLI_220	11:37 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
34	22-Jun-22	BAGALKOT	110	HUBLI220-RAMANAKOPPA	RAMANAKOPPA_110	11:19	11:23	0:04	LOAD CHANGE OVER
35	22-Jun-22	BAGALKOT	110	INDI-HIREMASALI	HIREMASALI_110	5:30	5:39	0:09	LINE FAULT
36	22-Jun-22	BAGALKOT	110	KERUR-BADAMI	STATION NOT AFFECTED KERUR_110	13:40	15:35	1:55	LINE CLEAR AVAILED
37	22-Jun-22	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	STATION NOT AFFECTED KIADB BIJAPUR_110	7:18	10:16	2:58	LINE CLEAR AVAILED
38	22-Jun-22	BAGALKOT	110	KUD DHARWAD-LAKAMANAHALLI	STATION NOT AFFECTED KUD DHARWAD_110	13:16	15:05	1:49	LINE CLEAR AVAILED
39	22-Jun-22	BAGALKOT	110	KUD DHARWAD-LAKAMANAHALLI	KUD DHARWAD_110	13:20	15:05	1:45	NFBC ISSUED
40	22-Jun-22	BAGALKOT	110	KUDUCHI-TERDAL(MORAB)	MORAB_110	10:06	18:09	8:03	LINE CLEAR AVAILED
41	22-Jun-22	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	13:00	17:49	4:49	LINE CLEAR AVAILED
42	22-Jun-22	BAGALKOT	110	MAMADAPUR-BABLESHWAR	MAMADAPUR(B)_110	18:10	18:43	0:33	LINE CLEAR AVAILED
43	22-Jun-22	BAGALKOT	110	MAMADAPUR-BAGEWADI1	MAMADAPUR(B)_110	18:09	18:19	0:10	LINE CLEAR AVAILED
44	22-Jun-22	BAGALKOT	110	MAMADAPUR-BAGEWADI2	MAMADAPUR(B)_110	11:10	18:10	7:00	LINE CLEAR AVAILED
45	22-Jun-22	BAGALKOT	110	MAMADAPUR-BELGAUM SOLAR	MAMADAPUR(B)_110	11:25	19:28	8:03	LINE CLEAR AVAILED
46	22-Jun-22	BAGALKOT	110	MAMADAPUR-DEVARA GENNUR	DEVARA GENNUR_110	3:08	3:18	0:10	LINE FAULT
47	22-Jun-22	BAGALKOT	110	MAMADAPUR-DEVARA GENNUR	DEVARA GENNUR_110	10:17	19:19	9:02	LINE CLEAR AVAILED
48	22-Jun-22	BAGALKOT	110	MAMADAPUR-DEVARA GENNUR	DEVARA GENNUR_110	19:53	20:02	0:09	LINE FAULT
49	22-Jun-22	BAGALKOT	110	MAMADAPUR-SHIRBUR(DEVARA GENNUR)	MAMADAPUR(B)_110	18:09	19:19	1:10	LINE CLEAR AVAILED
50	22-Jun-22	BAGALKOT	110	MAMADAPUR-TODALBAGI	MAMADAPUR(B)_110	18:09	18:33	0:24	LINE CLEAR AVAILED
51	22-Jun-22	BAGALKOT	110	NARENDRA220-TADASINAKOPPA	TADASINAKOPPA_110	10:40	16:56	6:16	NFBC ISSUED
52	22-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
53	22-Jun-22	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	12:49	13:03	0:14	HAND TRIPPED
54	22-Jun-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	10:17	10:18	0:01	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
55	22-Jun-22	BAGALKOT	110	TAKKALAKI-TORVI	TAKKALAKI_110	10:15	10:17	0:02	HAND TRIPPED
56	22-Jun-22	BAGALKOT	110	TODALABAGI-JAMKHANDI	TODALABAGI_110 JAMKHANDI_110	19:53	20:14	0:21	LINE FAULT
57	22-Jun-22	BAGALKOT	110	VAJJRAMATTI220-BILAGI (SHIRAGUPPI)	BILAGI_110 GIRISAGAR_110 BISNAL_110	8:32	11:40	3:08	LINE CLEAR AVAILED
58	22-Jun-22	BAGALKOT	110	VAJJRAMATTI-BILAGI	BILAGI_110	8:33	11:40	3:07	LINE CLEAR AVAILED
59	22-Jun-22	BAGALKOT	220	220/110KV, HV2,LV2	STATION NOT AFFECTED RANEENNUR_220	12:04	16:27	4:23	LINE CLEAR AVAILED
60	22-Jun-22	BAGALKOT	220	220/110KV,HV2,LV2	RANEENNUR_220	12:04	16:27	4:23	LINE CLEAR AVAILED
61	22-Jun-22	BAGALKOT	220	BIDNAL-HUBLI2	STATION NOT AFFECTED BIDNAL_220	10:37	14:47	4:10	NFBC ISSUED
62	22-Jun-22	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	15:46	18:02	2:16	LINE CLEAR AVAILED
63	22-Jun-22	BAGALKOT	220	HAVERI-GUTTUR-1	STATION NOT AFFECTED HAVERI_220	15:46	18:02	2:16	LINE CLEAR AVAILED
64	22-Jun-22	BAGALKOT	220	HUBLI-BIDNAL-2	STATION NOT AFFECTED HUBLI_220	10:37	14:27	3:50	LINE CLEAR AVAILED
65	22-Jun-22	BAGALKOT	220	HUBLI-SIRSI-1	STATION NOT AFFECTED HUBLI_220	10:30 (21.06.2022)	12:10 (22.06.2022)	25:40 hrs	LINE CHARGED
66	22-Jun-22	BAGALKOT	220	HUBLI-SIRSI-2	STATION NOT AFFECTED HUBLI_220	14:52	18:14	3:22	LINE CLEAR AVAILED
67	22-Jun-22	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:05 (15.06.2022)			LINE OPEN:LINE CLEAR AVAILED
68	22-Jun-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)	13:00 (22.06.2022)	957:34 hrs	LINE CHARGED
69	22-Jun-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:26 (13.05.2022)	12:58 (22.06.2022)	957:34 hrs	LINE CHARGED
70	22-Jun-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	17:15 (22.06.2022)			LINE OPEN:LINE CLEAR AVAILED
71	22-Jun-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	14:52 (22.06.2022)			LINE OPEN:LINE CLEAR AVAILED
72	22-Jun-22	BAGALKOT	220	SIRSI-SHARAVATHI-1	STATION NOT AFFECTED SIRSI_220	12:54	17:15	4:21	LINE CLEAR AVAILED
73	22-Jun-22	BAGALKOT	220	SIRSI-SHARAVATHI-2	STATION NOT AFFECTED SIRSI_220	12:54	17:15	4:21	LINE CLEAR AVAILED
74	22-Jun-22	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	18:35	18:40	0:05	LOAD CHANGE OVER
75	22-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	16:20	16:27	0:07	LINE FAULT
76	22-Jun-22	BENGALURU	66	HV1	KUMBALAGODU	13:20	13:22	0:02	LINE CLEAR AVAILED
77	22-Jun-22	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	11:34	11:37	0:03	LINE CLEAR AVAILED
78	22-Jun-22	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	13:04	13:10	0:06	LINE CLEAR AVAILED
79	22-Jun-22	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	16:02	16:08	0:06	LOAD CHANGE OVER
80	22-Jun-22	BENGALURU	66	HV1	HBR LAYOUT 66	10:40	10:43	0:03	LINE CLEAR AVAILED
81	22-Jun-22	BENGALURU	66	HV1	KEMBODI	12:04	13:35	1:31	LINE CLEAR AVAILED
82	22-Jun-22	BENGALURU	66	HV1	SOMENAHALLI	13:36	13:40	0:03	TRANSFORMER FAULT
83	22-Jun-22	BENGALURU	66	HV1	KEMBODI	12:04	13:35	1:30	LINE CLEAR AVAILED
84	22-Jun-22	BENGALURU	66	HV2	HBR LAYOUT 66	12:03	13:37	1:34	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
85	22-Jun-22	BENGALURU	66	HV2	ANDERSONPETE	12:15	12:30	0:15	LINE CLEAR AVAILED
86	22-Jun-22	BENGALURU	66	HV2	YEDUMADU	16:40	16:47	0:07	TRANSFORMER FAULT
87	22-Jun-22	BENGALURU	66	HV2	AGALKOTE	12:40	13:20	0:40	LINE CLEAR AVAILED
88	22-Jun-22	BENGALURU	66	HV2	BANASAWADI	17:25	18:31	1:06	LINE CLEAR AVAILED
89	22-Jun-22	BENGALURU	66	HV3	HBR LAYOUT 66	14:15	14:16	0:01	LINE CLEAR AVAILED
90	22-Jun-22	BENGALURU	66	HV3	NELAMANGALA 66	11:20	11:30	0:09	TRANSFORMER FAULT
91	22-Jun-22	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	7:48	7:51	0:03	LOAD CHANGE OVER
92	22-Jun-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	18:53	19:03	0:10	LINE FAULT
93	22-Jun-22	BENGALURU	66	KONDASPURA - HBR LAYOUT 66	KONDASPURA	15:52	16:12	0:20	LOAD CHANGE OVER
94	22-Jun-22	BENGALURU	66	KYALNUR - TALAGWARA	KYALNUR	16:50	17:00	0:10	LOAD CHANGE OVER
95	22-Jun-22	BENGALURU	66	KYALNUR - VEMGAL	KYALNUR	11:00	14:25	3:25	LINE CLEAR AVAILED
96	22-Jun-22	BENGALURU	66	LR BANDE - HBR LAYOUT 66	LR BANDE	17:18	17:22	0:04	LOAD CHANGE OVER
97	22-Jun-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI	3:23	3:34	0:10	LINE FAULT
98	22-Jun-22	BENGALURU	66	SOMENAHALLI - AFTL SOLAR IPP	NO STATION AFFECTED	3:24	3:29	0:05	LINE FAULT
99	22-Jun-22	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	15:13:00(18/06/2022)			LINE OPEN: LINE FAULT
100	22-Jun-22	BENGALURU	66	YEDUMADU - HANUMANTNAGAR	HANUMANTHNAGAR	16:40	16:52	0:12	LINE FAULT
101	22-Jun-22	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	16:40	16:44	0:04	LINE FAULT
102	22-Jun-22	GULBARGA	66	HALVAGALU-HARVI	HARVI_66	3:00	3:05	0:05	LINE FAULT
103	22-Jun-22	GULBARGA	66	HV1	HARVI_66	11:00	15:50	4:50	LINE CLEAR AVAILED
104	22-Jun-22	GULBARGA	66	HV1&HV2	UCCHANGIDURGA_66	10:10	16:10	0:25	LINE CLEAR AVAILED
105	22-Jun-22	GULBARGA	66	HV1,HV2	PUNABGHATA_66	10:15	16:50	6:35	LINE CLEAR AVAILED
106	22-Jun-22	GULBARGA	66	HV2	UJJANI_66	16:21	16:25	0:04	TRANSFORMER FAULT
107	22-Jun-22	GULBARGA	66	ITTAGI-SUZLON LINE _1_IPP	ITTAGI_220	19:09	19:26	0:17	LINE FAULT
108	22-Jun-22	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66,UCHCHANGIDU RGA_66,BILCHOD_66	14:23	14:43	0:20	LINE FAULT
109	22-Jun-22	GULBARGA	110	AURAD-SANTHAPUR	AURADA_110,DONGARAGOA_110	13:15	13:20	0:05	MAIN SUPPLY FAILURE
110	22-Jun-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_1 10,DIGGI_110	13:14	13:22	0:08	LINE FAULT
111	22-Jun-22	GULBARGA	110	HV1	HALWARTHY_220	9:17	9:32	0:15	TRANSFORMER FAULT
112	22-Jun-22	GULBARGA	110	HV1	GANGAVATI(SULEKAL)_220	17:00	18:10	1:10	LINE CLEAR AVAILED
113	22-Jun-22	GULBARGA	110	HV2	KUSTAGI_220	5:15	5:33	0:18	TRANSFORMER FAULT
114	22-Jun-22	GULBARGA	110	HV2	NALWAR_110	15:10	15:20	0:10	TRANSFORMER FAULT
115	22-Jun-22	GULBARGA	110	HV3	VALKAMDINNI_110	14:46	16:31	1:45	LINE CLEAR AVAILED
116	22-Jun-22	GULBARGA	110	HV3	CHINCHOLI_110	15:30	16:08	0:38	LINE CLEAR AVAILED
117	22-Jun-22	GULBARGA	110	MALLAPUR-KAMPLI	KAMPLI_110	19:00	19:05	0:05	LINE FAULT
118	22-Jun-22	GULBARGA	110	MUNIRABAD-SINDHANOOR_1	VENKATAGIRI_110,GANGAVATHI_ 110,DR NAGAR_110,KARATAGI_110	18:54	19:02	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
119	22-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_1	GABBUR_110	10:36	10:42	0:06	LINE CLEAR AVAILED
120	22-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_1	GABBUR_110	17:05	17:08	0:03	LINE CLEAR AVAILED
121	22-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR_2	GOOGLE_110	10:36	17:37	7:01	LINE CLEAR AVAILED
122	22-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
123	22-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
124	22-Jun-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	1:50	1:55	0:05	LINE FAULT
125	22-Jun-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	3:48	3:54	0:06	LINE FAULT
126	22-Jun-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	4:08	4:14	0:06	LINE FAULT
127	22-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP,C OREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
128	22-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110	12:20	17:57	5:37	LINE CLEAR AVAILED
129	22-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_2	NALWAR_110,JEWARGI_110	12:20	12:24	0:04	LINE CLEAR AVAILED
130	22-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_2	NALWAR_110,JEWARGI_110	17:54	18:14	0:20	LINE CLEAR AVAILED
131	22-Jun-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,KHA NAPUR_110,WADGERA_110	5:02	5:10	0:08	LINE FAULT
132	22-Jun-22	GULBARGA	110	SINDHANOOR-VALLABALLARI_110	VALLABALLARI_110,ADAVIAMERE SHWAR_110,JAWALGERA_110	8:25	13:50	5:25	LINE CLEAR AVAILED
133	22-Jun-22	GULBARGA	220	HV1	ITTAGI_220	19:09	19:15	0:06	TRANSFORMER FAULT
134	22-Jun-22	GULBARGA	220	HV1	GANGAVATI(SULEKAL)_220	12:10	14:45	2:35	LINE CLEAR AVAILED
135	22-Jun-22	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
136	22-Jun-22	GULBARGA	220	HV2	ITTAGI_220	19:09	19:15	0:06	TRANSFORMER FAULT
137	22-Jun-22	GULBARGA	220	HV2	GANGAVATI(SULEKAL)_220	15:35	16:50	1:15	LINE CLEAR AVAILED
138	22-Jun-22	GULBARGA	220	KUSTAGI-SULEKAL	SULEKAL_220	13:17	13:31	0:14	LINE FAULT
139	22-Jun-22	GULBARGA	220	LINGSUGUR-BAGEWADI1 & 2	LINGSUGUR_220	10:15	13:12	2:57	LINE CLEAR AVAILED
140	22-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN: LINE FAULT
141	22-Jun-22	GULBARGA	220	SHAHABAD-KAPNOOR	SHAHABAD_220	14:32	14:37	0:05	LINE CLEAR AVAILED
142	22-Jun-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	14:32	14:37	0:05	LINE CLEAR AVAILED
143	22-Jun-22	GULBARGA	220	SHAHAPUR-RTPS_1	SHAHAPUR_220	19:53 (22.06.2022)			LINE OPEN:LINE CLEAR AVAILED
144	22-Jun-22	GULBARGA	220	SHAHAPUR-RTPS_1	SHAHAPUR_220	18:48	19:10	0:22	LINE FAULT
145	22-Jun-22	GULBARGA	220	SHAHAPUR-RTPS_2	SHAHAPUR_220	18:48 (22.06.2022)			LINE OPEN: LINE FAULT
146	22-Jun-22	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	21:39 (21.06.2022)	7:30 (22.06.2022)	9:51 HRS	LINE CHARGED
147	22-Jun-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
148	22-Jun-22	HASSAN	66	BALEHN-ALDUR	BALEHONNUR_66	10:00	10:32	0:32	LINE FAULT
149	22-Jun-22	HASSAN	66	HNPR2-BANDISHETTIHALLY	HOLENARSIPURA_220	19:07	20:16	1:09	LINE FAULT
150	22-Jun-22	HASSAN	66	HNPR2-HASS1	HOLENARSIPURA_220	10:27	14:08	3:41	LINE CLEAR AVAIED
151	22-Jun-22	HASSAN	66	HV1	BALLUPETE_66	13:15	14:42	1:27	LINE CLEAR AVAIED
152	22-Jun-22	HASSAN	66	HV1	HOLENARSIPURA_220	10:27	14:08	3:41	LINE CLEAR AVAIED
153	22-Jun-22	HASSAN	66	HV1	MOSALEHOSAHALLI_66	11:15	12:55	1:40	LINE CLEAR AVAIED
154	22-Jun-22	HASSAN	66	HV1	YESLUR_66	14:55	15:55	1:00	MAIN SUPPLY FAILURE
155	22-Jun-22	HASSAN	66	HV1 CB	HETTUR_66	14:55	15:55	1:00	NFBC ISSUED
156	22-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAIED
157	22-Jun-22	HASSAN	66	LV2	CRPATNA_220	11:02	13:02	2:00	LINE CLEAR AVAIED
158	22-Jun-22	HASSAN	66	LV2	CRPATNA_220	11:02	13:02	2:00	LINE CLEAR AVAIED
159	22-Jun-22	HASSAN	66	YESLUR-SNVRSNT	YESLUR_66	14:55	15:55	1:00	MAIN SUPPLY FAILURE
160	22-Jun-22	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	11:45	13:45	2:00	LINE CLEAR AVAIED
161	22-Jun-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:01	12:14	0:13	HAND TRIPPED
162	22-Jun-22	HASSAN	110	ARSK2-GANDSI	ARASIKERE_220	5:35	6:06	0:31	LINE FAULT
163	22-Jun-22	HASSAN	110	HV1	MSEZ_220	9:53	19:52	9:59	LINE CLEAR AVAIED
164	22-Jun-22	HASSAN	110	HV1	MSEZ_220	11:58	18:51	6:53	LINE CLEAR AVAIED
165	22-Jun-22	HASSAN	110	HV1	MOODABIDRE_110	10:28	10:57	0:29	LINE CLEAR AVAIED
166	22-Jun-22	HASSAN	110	HV1	SHIVAPURA_110	10:45	13:55	3:10	LINE CLEAR AVAIED
167	22-Jun-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
168	22-Jun-22	HASSAN	110	HV2	ANAVATTI_110	9:50	11:03	1:13	TRANSFORMER FAULT
169	22-Jun-22	HASSAN	110	HV2	SHIVAPURA_110	10:45	13:55	3:10	LINE CLEAR AVAIED
170	22-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAIED
171	22-Jun-22	HASSAN	110	LV1	ARASIKERE_220	5:35	5:45	0:10	TRANSFORMER FAULT
172	22-Jun-22	HASSAN	110	LV2	KEMAR_220	10:16	12:12	1:56	LINE CLEAR AVAIED
173	22-Jun-22	HASSAN	110	PUTTUR-PUTTUR 2	PUTTUR_220	9:03	16:22	7:19	NFBC ISSUED
174	22-Jun-22	HASSAN	110	SAGARA-ALKLA	SAGARA_10	11:45	13:45	2:00	NFBC ISSUED
175	22-Jun-22	HASSAN	220	HV1	MSEZ_220	9:53	19:52	9:59	LINE CLEAR AVAIED
176	22-Jun-22	HASSAN	220	HV1	ARASIKERE_220	5:35	5:45	0:10	TRANSFORMER FAULT
177	22-Jun-22	HASSAN	220	HV2	KEMAR_220	10:16	12:11	1:55	LINE CLEAR AVAIED
178	22-Jun-22	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	12:52	17:15	4:23	LINE FAULT
179	22-Jun-22	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	12:52	17:15	4:23	LINE FAULT
180	22-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAIED
181	22-Jun-22	MYSURU	66	AJJIPURA-HANNUR	BANDALLI_66 COWDALLI_66 MARTHALLI_66 RAMAPURA_66 AJJIPURA_66	6:40	7:00	0:20	LINE FAULT
182	22-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN:LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
183	22-Jun-22	MYSURU	66	HADLI-HV1	HADLI_66 MALAVALLI_66	10:10	10:21	0:11	HAND TRIPPED
184	22-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
185	22-Jun-22	MYSURU	66	HEBBANI-SFC 5	NO STATIONS EFFECTED	11:47	13:12	1:25	LINE CLEAR AVAILED
186	22-Jun-22	MYSURU	66	HEBBANI-SFC 6	NO STATIONS EFFECTED	11:38	12:15	0:37	LINE CLEAR AVAILED
187	22-Jun-22	MYSURU	66	HEBBANI-SFC 7	NO STATIONS EFFECTED	12:16	12:39	0:23	LINE CLEAR AVAILED
188	22-Jun-22	MYSURU	66	HEBBANI-SFC 8	NO STATIONS EFFECTED	12:41	13:06	0:25	LINE CLEAR AVAILED
189	22-Jun-22	MYSURU	66	HEBBANI-SFC 9	NO STATIONS EFFECTED	13:08	13:30	0:22	LINE CLEAR AVAILED
190	22-Jun-22	MYSURU	66	HEBBANI-VADAKEPURA	VADAKEPURA_66 KIRUGAVALU_66 MALIYURU_66	1:08	1:20	0:12	LINE FAULT
191	22-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
192	22-Jun-22	MYSURU	66	HUNSUR-HOOTGALLY	HOSURGATE_66 BANNIKUPPE_66	20:35	20:53	0:18	LINE FAULT
193	22-Jun-22	MYSURU	66	HV1	CHUNCHANAKATTE_66	19:40	19:50	0:10	TRANSFORMER FAULT
194	22-Jun-22	MYSURU	66	HV1	CHINAKURALI_66	15:00	15:43	0:43	LINE CLEAR AVAILED
195	22-Jun-22	MYSURU	66	HV1	BEGUR_66	11:00	11:08	0:08	TRANSFORMER FAULT
196	22-Jun-22	MYSURU	66	HV2	SRIRANGAPATNA_66	11:28	14:10	2:42	LINE CLEAR AVAILED
197	22-Jun-22	MYSURU	66	HV2	GAMANAHALLY_66	16:00	17:00	1:00	LINE CLEAR AVAILED
198	22-Jun-22	MYSURU	66	HV2	MADHUVANAHLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
199	22-Jun-22	MYSURU	66	KADAKOLA-MANDAKALLI	MANDAKALLI_66	7:40	7:49	0:09	LINE FAULT
200	22-Jun-22	MYSURU	66	KADAKOLA-NANJANGUD 1	NO STATIONS EFFECTED	11:36	13:55	2:19	LINE CLEAR AVAILED
201	22-Jun-22	MYSURU	66	KADAKOLA-SARGUR2	NO STATIONS EFFECTED	13:34	15:05	1:30	LINE CLEAR AVAILED
202	22-Jun-22	MYSURU	66	KR PETE 220- MAHADESHWARAPURA	MAHADESHWARAPURA_66 G MALLIGERE_66 JAKKANAHALLY_66	19:09	19:14	0:05	LINE FAULT
203	22-Jun-22	MYSURU	66	KR PETE 220-YACHANAHALLI	NO STATIONS EFFECTED	10:33	14:03	3:30	LINE CLEAR AVAILED
204	22-Jun-22	MYSURU	66	KR PETE -HUYGONAHALLI2	NO STATIONS EFFECTED	13:30	13:38	0:07	LINE FAULT
205	22-Jun-22	MYSURU	66	KR PETE -KIKKERI	KIKKERI_66	13:30	13:38	0:07	LINE FAULT
206	22-Jun-22	MYSURU	66	MUGUR-THAYURU	NO STATIONS EFFECTED	9:40:00 (20.06.2022)			LINE OPEN:LINE CLEAR AVAILED
207	22-Jun-22	MYSURU	66	SANTHESARGUR-KADAKOLA2	CHANDRAWADI_66	5:55	6:06	0:11	LINE FAULT
208	22-Jun-22	MYSURU	66	SFCSIVA-HEBBANI6	NO STATIONS EFFECTED	1:08	1:18	0:09	LINE FAULT
209	22-Jun-22	MYSURU	66	SHANIVARSANTE-YESLOOR	YESLOOR_66 HETTUR_66	14:50	15:51	1:01	LINE CLEAR AVAILED
210	22-Jun-22	MYSURU	66	TUBINKERE-MANDYA2	NO STATIONS EFFECTED	10:26	12:20	1:54	LINE CLEAR AVAILED
211	22-Jun-22	MYSURU	66	TUBINKERE-MANDYA4	NO STATIONS EFFECTED	12:21	13:58	1:37	LINE CLEAR AVAILED
212	22-Jun-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	8:45	10:20	1:35	LINE CLEAR AVAILED
213	22-Jun-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	10:21	11:21	1:00	LINE CLEAR AVAILED
214	22-Jun-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	17:41	18:36	0:55	LINE FAULT
215	22-Jun-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGAL UR_66	14:25	14:30	0:05	MAIN SUPPLY FAILURE
216	22-Jun-22	TUMKUR	66	BRAHMASANDRA- SIRA(ANKASANDRA)	BRAHMASANDRA_66	12:27	12:37	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
217	22-Jun-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	9:47	10:17	0:29	LINE FAULT
218	22-Jun-22	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	9:29	18:11	8:42	LINE FAULT
219	22-Jun-22	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:56	10:08	0:11	LINE FAULT
220	22-Jun-22	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:15	13:34	0:18	LINE FAULT
221	22-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:00	14:12	0:12	LINE FAULT
222	22-Jun-22	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	6:06	6:24	0:17	LINE FAULT
223	22-Jun-22	TUMKUR	66	HOSAKRE66-MEDIGESHI66	HOSAKRE_66	10:47	10:57	0:10	LINE FAULT
224	22-Jun-22	TUMKUR	66	HOSAKRE66-MEDIGESHI66	HOSAKRE_66	10:47	10:57	0:10	LINE FAULT
225	22-Jun-22	TUMKUR	66	MADANAYAKANAHALLI- CHITRADURGA220	MADANAYAKANAHALLI_66	9:30	18:13	8:42	LINE FAULT
226	22-Jun-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	9:51	9:56	0:05	MAIN SUPPLY FAILURE
227	22-Jun-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	12:26	12:32	0:05	MAIN SUPPLY FAILURE
228	22-Jun-22	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	9:51	9:56	0:05	MAIN SUPPLY FAILURE
229	22-Jun-22	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	12:26	12:32	0:05	MAIN SUPPLY FAILURE
230	22-Jun-22	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	9:51	9:56	0:05	MAIN SUPPLY FAILURE
231	22-Jun-22	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	12:26	12:32	0:05	MAIN SUPPLY FAILURE
232	22-Jun-22	TUMKUR	66	TR-1	KORA_66	17:58	18:47	0:48	LINE CLEAR AVAILED
233	22-Jun-22	TUMKUR	66	TR-1	PAVAGADA_220	16:50	16:53	0:03	TRANSFORMER FAULT
234	22-Jun-22	TUMKUR	66	TR-2	HONNALLI_66	16:59	18:01	1:02	LINE CLEAR AVAILED
235	22-Jun-22	TUMKUR	66	TR-2	MADANAYAKANAHALLI_66	11:32	12:00	0:28	LINE CLEAR AVAILED
236	22-Jun-22	TUMKUR	66	TR-2	PULAMG_66	8:00	12:50	4:50	LINE CLEAR AVAILED
237	22-Jun-22	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	13:05	13:54	0:48	LINE CLEAR AVAILED
238	22-Jun-22	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:46	18:02	2:16	LINE CLEAR AVAILED
239	22-Jun-22	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	15:08	18:25	3:16	LINE CLEAR AVAILED
240	22-Jun-22	TUMKUR	220	TR-2(HV SIDE)	KIADB_220	13:03	14:13	1:10	LINE CLEAR AVAILED
241	22-Jun-22	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	7:55	8:10	0:14	TRANSFORMER FAULT
242	23-Jun-22	BAGALKOT	110	110/11KV, HV1	KANABARGI LAYOUT_110	10:19	10:26	0:07	LINE CLEAR AVAILED
243	23-Jun-22	BAGALKOT	110	110/11KV, HV1	MACHE_110	12:57	15:58	3:01	TRANSFORMER FAULT
244	23-Jun-22	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	9:39	18:54	9:15	LINE CLEAR AVAILED
245	23-Jun-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UCHAGOAN_110	19:53 (23.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
246	23-Jun-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALABAGI_110	11:33	13:00	1:27	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
247	23-Jun-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILUVALI_110	13:15	13:25	0:10	TRANSFORMER FAULT
248	23-Jun-22	BAGALKOT	110	110/11KV, HV1	SHIGGOAN_110	10:37	17:18	6:41	LINE CLEAR AVAILED
249	23-Jun-22	BAGALKOT	110	110/11KV, HV1	GANESH GUDI_110	11:27	13:00	1:33	LINE CLEAR AVAILED
250	23-Jun-22	BAGALKOT	110	110/11KV, HV1	GALATAGA_110	11:50	18:40	6:50	LINE CLEAR AVAILED
251	23-Jun-22	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	22:57	23:09	0:12	LINE CLEAR AVAILED
252	23-Jun-22	BAGALKOT	110	110/11KV, HV2	MATTIHAL_110	18:16	18:44	0:28	LINE CLEAR AVAILED
253	23-Jun-22	BAGALKOT	110	110/11KV, HV2	SHIGGOAN_110	14:01	17:15	3:14	LINE CLEAR AVAILED
254	23-Jun-22	BAGALKOT	110	110/11KV, HV2	GALATAGA_110	10:15	18:55	8:40	LINE CLEAR AVAILED
255	23-Jun-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED RATTIHALI_110	6:50	6:54	0:04	TRANSFORMER FAULT
256	23-Jun-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED RAIBAG_110	9:07	9:17	0:10	TRANSFORMER FAULT
257	23-Jun-22	BAGALKOT	110	110/11KV,HV1	HEBBALI_110	11:37	12:14	0:37	LINE CLEAR AVAILED
258	23-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
259	23-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED PG HUNSYAL_110	15:40	16:04	0:24	TRANSFORMER FAULT
260	23-Jun-22	BAGALKOT	110	110/33KV, HV2	BIDARI_33 STATION NOT AFFECTED TODALABAGI_110	18:38	18:55	0:17	HAND TRIPPED
261	23-Jun-22	BAGALKOT	110	110/33KV, HV2	GANESH GUDI_110	11:28	13:02	1:34	LINE CLEAR AVAILED
262	23-Jun-22	BAGALKOT	110	110/33KV, HV3	AMBUJA_33KV SHIGGOAN_33KV KPCL SOLAR_33KV SHIGGOAN_110	10:37	17:18	6:41	LINE CLEAR AVAILED
263	23-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
264	23-Jun-22	BAGALKOT	110	110/33KV,HV1	PALA_33,BASAPUR_33 HANAGAL_110	12:40	13:40	1:00	LINE CLEAR AVAILED
265	23-Jun-22	BAGALKOT	110	AINAPUR-ATHANI SUGARS	STATION NOT AFFECTED AINAPUR_110	6:44	6:49	0:05	HAND TRIPPED
266	23-Jun-22	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	18:39	20:01	1:22	LINE FAULT
267	23-Jun-22	BAGALKOT	110	AMBEWADI- GANESH GUDI	GANESH GUDI_110	11:25	13:40	2:15	MAIN SUPPLY FAILURE
268	23-Jun-22	BAGALKOT	110	AMBEWADI- SUPA1	STATION NOT AFFECTED AMBEWADI_220	11:27	13:41	2:14	LINE CLEAR AVAILED
269	23-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVALIED
270	23-Jun-22	BAGALKOT	110	CHIKKODI220- BHOJ	CHIKKODI_220	15:04	17:30	2:26	LINE CLEAR AVAILED
271	23-Jun-22	BAGALKOT	110	HIREHAL-MF SOLAR	STATION NOT AFFECTED HIREHAL_110	17:53	18:15	0:22	HAND TRIPPED
272	23-Jun-22	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTED HUBLI_220	11:37 (14.06.2022)			LINE OPEN:LINE CLEAR AVALIED
273	23-Jun-22	BAGALKOT	110	INDI220-HIREBEVANUR	HIREBEVANUR_110	4:24	4:34	0:10	LINE FAULT
274	23-Jun-22	BAGALKOT	110	KADANAKOPPA- KAVALWADA(AMBEWADI)	STATION NOT AFFECTED KADANAKOPPA_110	10:35	17:23	6:48	NFBC ISSUED
275	23-Jun-22	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	STATION NOT AFFECTED KIADB BIJAPUR_110	7:50	18:07	10:17	LINE CLEAR AVAILED
276	23-Jun-22	BAGALKOT	110	MK HUBLI-KITTUR	MK HBLI_110	5:30	8:25	2:55	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
277	23-Jun-22	BAGALKOT	110	NAGNUR-MUDALAGI	MUDALAGI_110	11:00	15:16	4:16	LINE CLEAR AVAILED
278	23-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
279	23-Jun-22	BAGALKOT	110	RON-HIREHAL	STATION NOT AFFECTED RON_110	17:58	21:41	3:43	LINE CLEAR AVAILED
280	23-Jun-22	BAGALKOT	110	TADASINKOPPA-KUD DHARWAD	STATION NOT AFFECTED TADASINAKOPPA_110	11:00	15:15	4:15	LINE CLEAR AVAILED
281	23-Jun-22	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	18:07	18:08	0:01	HAND TRIPPED
282	23-Jun-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	18:07	18:09	0:02	HAND TRIPPED
283	23-Jun-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED AMBEWADI_220	10:32	14:13	3:41	LINE CLEAR AVAILED
284	23-Jun-22	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:05 (15.06.2022)			LINE OPEN:LINE CLEAR AVAILED
285	23-Jun-22	BAGALKOT	220	SIRSI220-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVAILED
286	23-Jun-22	BAGALKOT	220	SIRSI220-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVAILED
287	23-Jun-22	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:26	15:46	2:25	LINE FAULT
288	23-Jun-22	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	13:34	15:54	2:20	LINE CLEAR AVAILED
289	23-Jun-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	17:15 (22.06.2022)	13:34 (23.06.2022)	20:19	LINE CHARGED
290	23-Jun-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	14:52 (22.06.2022)	13:34 (23.06.2022)	22:42	LINE CHARGED
291	23-Jun-22	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR, BIEC	15:35	15:37	0:02	LOAD CHANGE OVER
292	23-Jun-22	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR, BIEC	15:35	15:37	0:02	LOAD CHANGE OVER
293	23-Jun-22	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, BIEC	12:50	12:57	0:07	LOAD CHANGE OVER
294	23-Jun-22	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, BIEC	12:50	12:57	0:07	LOAD CHANGE OVER
295	23-Jun-22	BENGALURU	66	HV1	BTM 4TH PHASE	10:41	10:45	0:04	LINE CLEAR AVAILED
296	23-Jun-22	BENGALURU	66	HV1	KHODAYS 220	11:24	11:27	0:03	LINE CLEAR AVAILED
297	23-Jun-22	BENGALURU	66	HV1	RMV	11:46	11:49	0:03	LINE CLEAR AVAILED
298	23-Jun-22	BENGALURU	66	HV1	ANJANAPURA	13:24	13:30	0:06	LINE CLEAR AVAILED
299	23-Jun-22	BENGALURU	66	HV1	KAMASAMUDRA	20:55	22:00	1:05	TRANSFORMER FAULT
300	23-Jun-22	BENGALURU	66	HV1	PATHPALYA	15:59	16:30	0:30	LINE CLEAR AVAILED
301	23-Jun-22	BENGALURU	66	HV1	KAMASAMUDRA	20:55	22:00	1:05	TRANSFORMER FAULT
302	23-Jun-22	BENGALURU	66	HV1	PATHPALYA	15:59	16:30	0:30	LINE CLEAR AVAILED
303	23-Jun-22	BENGALURU	66	HV2	BTM 4TH PHASE	13:10	13:12	0:02	LINE CLEAR AVAILED
304	23-Jun-22	BENGALURU	66	HV2	RMV	12:58	13:02	0:04	LINE CLEAR AVAILED
305	23-Jun-22	BENGALURU	66	HV2	K&C VALLEY	4:55	5:20	0:25	TRANSFORMER FAULT
306	23-Jun-22	BENGALURU	66	HV2	SAHAKARI NAGAR	12:45	12:50	0:05	LINE CLEAR AVAILED
307	23-Jun-22	BENGALURU	66	HV2	IRGAMPALLI	13:05	13:25	0:19	TRANSFORMER FAULT
308	23-Jun-22	BENGALURU	66	HV2	IRGAMPALLI	13:05	13:25	0:19	TRANSFORMER FAULT
309	23-Jun-22	BENGALURU	66	HV3	YARANDANAHALLI 220	12:31	12:45	0:14	TRANSFORMER FAULT
310	23-Jun-22	BENGALURU	66	HV3	YARANDANAHALLI 220	12:45	14:08	1:23	LINE CLEAR AVAILED
311	23-Jun-22	BENGALURU	66	HV3	SAHAKARI NAGAR	11:05	11:12	0:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
312	23-Jun-22	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	6:31	6:34	0:03	LOAD CHANGE OVER
313	23-Jun-22	BENGALURU	66	MELUR - VIJAYPURA	MELUR	17:50	17:55	0:05	LOAD CHANGE OVER
314	23-Jun-22	BENGALURU	66	MELUR - VIJAYPURA	MELUR	17:50	17:55	0:05	LOAD CHANGE OVER
315	23-Jun-22	BENGALURU	66	MITTEMARI 220 - SADALI	SADALI	5:52	5:59	0:07	LINE FAULT
316	23-Jun-22	BENGALURU	66	MITTEMARI 220 - SADALI	SADALI	11:37	12:05	0:27	LINE CLEAR AVAILED
317	23-Jun-22	BENGALURU	66	MITTEMARI 220 - SADALI	SADALI	5:52	5:59	0:07	LINE FAULT
318	23-Jun-22	BENGALURU	66	MITTEMARI 220 - SADALI	SADALI	11:37	12:05	0:27	LINE CLEAR AVAILED
319	23-Jun-22	BENGALURU	66	SADALI - CHINTAMANI 220	SADALI	16:40	16:46	0:06	LOAD CHANGE OVER
320	23-Jun-22	BENGALURU	66	SADALI - CHINTAMANI 220	SADALI	16:40	16:46	0:06	LOAD CHANGE OVER
321	23-Jun-22	BENGALURU	66	SAHAKARI NAGAR - BYATARAYANAPURA	SAHAKARI NAGAR	15:40	15:44	0:04	LOAD CHANGE OVER
322	23-Jun-22	BENGALURU	66	SAHAKARI NAGAR - YELAHANKA 220	SAHAKARI NAGAR	14:52	14:56	0:04	LOAD CHANGE OVER
323	23-Jun-22	BENGALURU	66	SOMAYAJANAHALLI - TATA SOLAR(IPP)	NO STATION AFFECTED	4:55	5:12	0:17	LINE FAULT
324	23-Jun-22	BENGALURU	66	SOMAYAJANAHALLI - TATA SOLAR(IPP)	NO STATION AFFECTED	4:55	5:12	0:17	LINE FAULT
325	23-Jun-22	BENGALURU	66	SOMENAHALLI - AFTL SOLAR IPP	NO STATION AFFECTED	5:52	6:02	0:10	LINE FAULT
326	23-Jun-22	BENGALURU	66	SOMENAHALLI - AFTL SOLAR IPP	NO STATION AFFECTED	5:52	6:02	0:10	LINE FAULT
327	23-Jun-22	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	19:00	19:11	0:11	LINE FAULT
328	23-Jun-22	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	19:00	19:11	0:11	LINE FAULT
329	23-Jun-22	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	19:00	19:11	0:11	LINE FAULT
330	23-Jun-22	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	19:00	19:11	0:11	LINE FAULT
331	23-Jun-22	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	15:13:00(18/06/2022)			LINE OPEN: LINE FAULT
332	23-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	5:39	6:35	0:56	LINE FAULT
333	23-Jun-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	13:56	14:34	0:38	LINE CLEAR AVAILED
334	23-Jun-22	BENGALURU	66	TADIGOLU CROSS - CHINTAMANI 220	TADIGOLU CROSS, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	4:55	5:08	0:13	LINE FAULT
335	23-Jun-22	BENGALURU	66	TADIGOLU CROSS - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	4:55	5:08	0:13	LINE FAULT
336	23-Jun-22	GULBARGA	66	HV1	HANASI_66	14:35	14:50	0:15	LINE CLEAR AVAILED
337	23-Jun-22	GULBARGA	66	HV2	PUNABGHATA_66	14:00	14:05	0:05	TRANSFORMER FAULT
338	23-Jun-22	GULBARGA	66	ITTAGI-RENEW SOLAR_1	ITTAGI_220	12:44	12:53	0:09	LOAD CURTAILMENT
339	23-Jun-22	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	9:52	9:56	0:04	LINE FAULT
340	23-Jun-22	GULBARGA	66	PUNABGHATA-NEELAGUNA	PUNABGHATA_66, UCHANGIDURG A_66, BILCHOD_66	14:00	14:03	0:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
341	23-Jun-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,P D HALLI_110,BISIHALLI_110,JANAKI_IPP, BASAI STEELS ACC_IPP	5:35	5:45	0:10	LINE FAULT
342	23-Jun-22	GULBARGA	110	HV1	DUBALANGUNDI_110	22:10	22:15	0:05	TRANSFORMER FAULT
343	23-Jun-22	GULBARGA	110	HV1	DEODURGA_110	15:40	16:00	0:20	LINE CLEAR AVAILED
344	23-Jun-22	GULBARGA	110	HV2	DEODURGA_110	14:10	15:20	1:10	LINE CLEAR AVAILED
345	23-Jun-22	GULBARGA	110	HV2	YERAGERA_110	7:25	7:40	0:15	LINE CLEAR AVAILED
346	23-Jun-22	GULBARGA	110	HV2	KUSTAGI_220	14:17	14:28	0:11	TRANSFORMER FAULT
347	23-Jun-22	GULBARGA	110	HV2	KUSTAGI_220	14:35	15:15	0:40	TRANSFORMER FAULT
348	23-Jun-22	GULBARGA	110	HV2	MATAMARI_110	16:05	16:40	0:35	TRANSFORMER FAULT
349	23-Jun-22	GULBARGA	110	KUSATGI-VAJRABANDI	VAJRABANDI_110,YELBURGA_110 ,KUKNOOR_110	7:03	14:20	7:17	LINE CLEAR AVAILED
350	23-Jun-22	GULBARGA	110	KUSTAGI-TAWERGERE	TAWERGERE_110	21:13	21:26	0:13	LINE FAULT
351	23-Jun-22	GULBARGA	110	LINGASUGUR-KAREPOWER	CHAYADEVI_IPP,KAREPOWER_IPP	22:52	23:02	0:10	LINE FAULT
352	23-Jun-22	GULBARGA	110	LV1	SHAHAPUR_220	1:38	1:52	0:14	TRANSFORMER FAULT
353	23-Jun-22	GULBARGA	110	LV1	LINGSUGUR_220	22:52	22:57	0:05	TRANSFORMER FAULT
354	23-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	4:50	5:00	0:10	LINE FAULT
355	23-Jun-22	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	2:16	2:21	0:05	LINE FAULT
356	23-Jun-22	GULBARGA	110	RAICHUR-SINDHANOOR_2	KURDICROSS_110,MADLAPUR_110,MANVI_110	0:20	0:30	0:10	LINE FAULT
357	23-Jun-22	GULBARGA	110	RAICHUR-SINDHANOOR_2	KURDICROSS_110,MADLAPUR_110,MANVI_110	1:35	1:40	0:05	LINE FAULT
358	23-Jun-22	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORWAR TEMPLE_110	1:45	1:50	0:05	LINE FAULT
359	23-Jun-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	3:30	3:40	0:10	LINE FAULT
360	23-Jun-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	5:20	5:40	0:20	LINE FAULT
361	23-Jun-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110, DEVANGAON_110,RENUKA_IPP,A FZALPUR_110,KARAJAGI_110	21:12	21:22	0:10	LINE FAULT
362	23-Jun-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	16:14	17:20	1:06	LINE CLEAR AVAILED
363	23-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
364	23-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
365	23-Jun-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	23:32	23:37	0:05	LINE FAULT
366	23-Jun-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS_IPP,ASKI_110,HUNASAGI_110	2:14	2:17	0:03	LINE FAULT
367	23-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP,C OREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
368	23-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110	1:38	1:54	0:16	LINE FAULT
369	23-Jun-22	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	14:10	14:15	0:05	LOAD CURTAILMENT
370	23-Jun-22	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	14:30	14:40	0:10	LOAD CURTAILMENT
371	23-Jun-22	GULBARGA	110	YELBURGA-PARAM POOJYA_IPP	YELBURGA_110	14:12	16:29	2:17	LINE CLEAR AVAILED
372	23-Jun-22	GULBARGA	110	YELBURGA-TALAKUTAI_IPP	YELBURGA_110	9:45	15:06	5:21	LINE CLEAR AVAILED
373	23-Jun-22	GULBARGA	220	BADELADUKU-HIREMALLANHALLI_2	BADELADUKU_220	15:05	16:05	1:00	LINE CLEAR AVAILED
374	23-Jun-22	GULBARGA	220	HV1	LINGSUGUR_220	10:35	14:52	4:17	LINE CLEAR AVAILED
375	23-Jun-22	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
376	23-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN: LINE FAULT
377	23-Jun-22	GULBARGA	220	SHAHAPUR-RTPS_1	SHAHAPUR_220	19:53 (22.06.2022)	19:54 (23.06.2022)	24:01 HRS	LINE CHARGED
378	23-Jun-22	GULBARGA	220	SHAHAPUR-RTPS_2	SHAHAPUR_220	18:48 (22.06.2022)	19:19 (23.06.2022)	24:31 HRS	LINE CHARGED
379	23-Jun-22	GULBARGA	220	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	12:43	14:15	1:32	LINE CLEAR AVAILED
380	23-Jun-22	GULBARGA	220	SINDHANOOR-SULEKAL (GANGAVATHI)	SULEKAL_220 (GANGAVATHI)	10:02	12:30	2:28	LINE CLEAR AVAILED
381	23-Jun-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
382	23-Jun-22	HASSAN	66	CHIKABO-SIDPR	CHIKABOMENAHALLY_66	10:29	18:05	7:36	LINE CLEAR AVAILED
383	23-Jun-22	HASSAN	66	HAGARE-HASSAN	HAGARE_66	1:20	2:05	0:45	MAIN SUPPLY FAILURE
384	23-Jun-22	HASSAN	66	HNPR2-HASS2	HNPURA_220	10:30	12:43	2:13	LINE CLEAR AVAILED
385	23-Jun-22	HASSAN	66	HV1	HANGARAHALLY_66	13:15	13:34	0:19	HAND TRIPPED
386	23-Jun-22	HASSAN	66	HV1	HNPURA_66	11:00	11:55	0:55	HAND TRIPPED
387	23-Jun-22	HASSAN	66	HV1	MALALI_66	10:03	14:15	4:12	LINE CLEAR AVAILED
388	23-Jun-22	HASSAN	66	HV1	SAKALESH PURA_66	1:13	1:25	0:12	TRANSFORMER FAULT
389	23-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
390	23-Jun-22	HASSAN	66	HV2	KANDLI_66	15:09	15:45	0:36	LINE CLEAR AVAILED
391	23-Jun-22	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:37	13:26	2:49	LINE CLEAR AVAILED
392	23-Jun-22	HASSAN	66	MALALI-HASSAN	MALALI_66	10:37	13:26	2:49	LINE CLEAR AVAILED
393	23-Jun-22	HASSAN	66	SHANTI-KADVINKOTE	SHANTHIGRAMA_66	12:00	13:27	1:27	MAIN SUPPLY FAILURE
394	23-Jun-22	HASSAN	110	HV1	ARSIKERE_220	10:39	13:46	3:07	LINE CLEAR AVAILED
395	23-Jun-22	HASSAN	110	HV1	SORABA_110	3:00	4:10	1:10	MAIN SUPPLY FAILURE
396	23-Jun-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
397	23-Jun-22	HASSAN	110	HV2	SORABA_110	3:00	4:10	1:10	MAIN SUPPLY FAILURE
398	23-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
399	23-Jun-22	HASSAN	110	HV4	PUTTUR_220	10:07	16:12	6:05	LINE CLEAR AVAILED
400	23-Jun-22	HASSAN	110	KARKLA-HIRIYADKA	KARKALA_110	10:03	13:36	3:33	NFBC ISSUED
401	23-Jun-22	HASSAN	110	LV3	KEMAR_220	10:24	12:38	2:14	LINE CLEAR AVAILED
402	23-Jun-22	HASSAN	110	MRSSHM-BADRAVATY1	MRS MG_220	11:38	16:22	4:44	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
403	23-Jun-22	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	12:06	18:23	6:17	LINE CLEAR AVAILED
404	23-Jun-22	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	10:18	13:03	2:45	LINE CLEAR AVAILED
405	23-Jun-22	HASSAN	110	SAGARA-SORABA	SAGARA_110	16:37	17:37	1:00	LINE CLEAR AVAILED
406	23-Jun-22	HASSAN	110	SORABA-SHR220	SORABA_110	3:00	4:10	1:10	MAIN SUPPLY FAILURE
407	23-Jun-22	HASSAN	220	HGUNJE-KEMAR	HEGGUNJE_220	10:08	13:34	3:26	NFBC ISSUED
408	23-Jun-22	HASSAN	220	HV2	MSEZ_220	10:40	19:16	8:36	LINE CLEAR AVAILED
409	23-Jun-22	HASSAN	220	HV3	KEMAR_220	10:25	12:37	2:12	LINE CLEAR AVAILED
410	23-Jun-22	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	15:35	16:48	1:13	NFBC ISSUED
411	23-Jun-22	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:08	13:34	3:26	LINE CLEAR AVAILED
412	23-Jun-22	HASSAN	220	MSEZ-KEMBAJP2	MSEZ_220	15:36	16:48	1:12	LINE CLEAR AVAILED
413	23-Jun-22	HASSAN	220	SHRAVITY-SIRISI 1	gen_sharavaty	13:21	13:58	0:37	LINE FAULT
414	23-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
415	23-Jun-22	MYSURU	66	ALURSIDDAPURA-CB HALLI - ALUR SIDDAPURA	ALUR SIDDAPURA_66	10:10	18:05	7:55	LINE CLEAR AVAILED
416	23-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN:LINE CLEAR AVAILED
417	23-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
418	23-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
419	23-Jun-22	MYSURU	66	HOSURGATE-HUNSUR	HOSURGATE_66	22:30	22:40	0:10	LINE FAULT
420	23-Jun-22	MYSURU	66	HULLAHALLI-KADAKOLA	HULLAHALLI_66	10:24	18:19	7:54	LINE CLEAR AVAILED
421	23-Jun-22	MYSURU	66	HUNSUR-BANNIKUPPE	NO STATIONS EFFECTED	22:33	22:46	0:12	LINE FAULT
422	23-Jun-22	MYSURU	66	HV1	BETTADHAPURA_66	12:44	15:30	2:45	LINE CLEAR AVAILED
423	23-Jun-22	MYSURU	66	HV1	MYSORESOUTH_66	10:05	17:20	7:15	LINE CLEAR AVAILED
424	23-Jun-22	MYSURU	66	HV1	KUSHALANAGARA_66	10:35	18:18	7:43	LINE CLEAR AVAILED
425	23-Jun-22	MYSURU	66	HV1	CHUNCHUNKATTE_66	9:30	9:50	0:20	LINE CLEAR AVAILED
426	23-Jun-22	MYSURU	66	HV1	THUMBLA_66	7:30	7:40	0:10	TRANSFORMER FAULT
427	23-Jun-22	MYSURU	66	HV2	BETTADHAPURA_66	15:36	16:14	0:38	LINE CLEAR AVAILED
428	23-Jun-22	MYSURU	66	HV2	MYSORESOUTH_66	8:37	17:26	8:49	LINE CLEAR AVAILED
429	23-Jun-22	MYSURU	66	HV2	MADHUVANAHLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
430	23-Jun-22	MYSURU	66	HV3	KUSHALANAGARA_66	10:25	18:17	7:52	LINE CLEAR AVAILED
431	23-Jun-22	MYSURU	66	HV4	KUSHALANAGARA_66	10:25	17:58	7:33	LINE CLEAR AVAILED
432	23-Jun-22	MYSURU	66	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	11:46	16:21	4:35	LINE CLEAR AVAILED
433	23-Jun-22	MYSURU	66	KADAKOLKA	MYSORESOUTH_66	11:30	16:20	4:50	NFBC ISSUED
434	23-Jun-22	MYSURU	66	KUSHALANAGARA-HARANGI	NO STATIONS EFFECTED	10:40	18:18	7:38	LINE CLEAR AVAILED
435	23-Jun-22	MYSURU	66	KUSHALANAGARA-MADIKERI 1	MADIKERI_66	10:25	18:15	7:50	LINE CLEAR AVAILED
436	23-Jun-22	MYSURU	66	KUSHALANAGARA-MYSORE 1	NO STATIONS EFFECTED	10:14	18:10	7:56	LINE CLEAR AVAILED
437	23-Jun-22	MYSURU	66	KUSHALANAGARA-MYSORE 2	NO STATIONS EFFECTED	10:14	18:12	7:58	LINE CLEAR AVAILED
438	23-Jun-22	MYSURU	66	KUSHALANAGARA-PERIYAPATNA 1	NO STATIONS EFFECTED	10:19	18:13	7:54	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
439	23-Jun-22	MYSURU	66	KUSHALANAGARA-PERİYAPATNA 2	NO STATIONS EFFECTED	10:19	18:14	7:55	LINE CLEAR AVAILED
440	23-Jun-22	MYSURU	66	KUSHALANAGARA-RAMANATHAPURA 1	KANAGAL_66 ALUR SIDDAPURA_66	10:40	18:25	7:45	LINE CLEAR AVAILED
441	23-Jun-22	MYSURU	66	KUSHALANAGARA-SUNTIKOPPA	SUNTIKOPPA_66	10:25	18:15	7:50	LINE CLEAR AVAILED
442	23-Jun-22	MYSURU	66	MADIKERI-KUSHALNAGAR	MADIKERI_66	10:52	18:15	7:23	LINE CLEAR AVAILED
443	23-Jun-22	MYSURU	66	MADIKERI-SUNTHIKOPA	MADIKERI_66	10:30	18:18	7:48	LINE CLEAR AVAILED
444	23-Jun-22	MYSURU	66	MUGUR-THAYURU	NO STATIONS EFFECTED	9:40:00 (20.06.2022)			LINE OPEN:LINE CLEAR AVAILED
445	23-Jun-22	MYSURU	66	MYSORE SOUTH-KALAMANDIR	MYSORESOUTH_66	11:30	17:54	6:24	NFBC ISSUED
446	23-Jun-22	MYSURU	66	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	12:09	19:26	7:17	LINE CLEAR AVAILED
447	23-Jun-22	MYSURU	66	RK NAGARA-DATTAGALLI	RKNAGARA_66	16:01	16:14	0:12	LINE FAULT
448	23-Jun-22	MYSURU	66	RK NAGARA-KADAKOLA	RKNAGARA_66	16:14	17:02	0:47	LINE FAULT
449	23-Jun-22	MYSURU	66	SUNTIKOPPA-KUSHALNAGARA	SUNTIKOPPA_66	10:07	18:18	8:11	LINE CLEAR AVAILED
450	23-Jun-22	MYSURU	66	SUNTIKOPPA-MADIKERI	SUNTIKOPPA_66	10:30	18:25	7:55	LINE CLEAR AVAILED
451	23-Jun-22	MYSURU	220	HV1	NAGAMANGALA_220	15:10	17:17	2:07	LINE CLEAR AVAILED
452	23-Jun-22	MYSURU	220	HV1	KUSHALNAGARA_220	11:08	17:50	6:42	LINE CLEAR AVAILED
453	23-Jun-22	MYSURU	220	HV2	NAGAMANGALA_220	12:12	14:53	2:41	LINE CLEAR AVAILED
454	23-Jun-22	MYSURU	220	HV2	KUSHALNAGARA_220	11:08	17:50	6:42	LINE CLEAR AVAILED
455	23-Jun-22	MYSURU	220	KUSHALANAGARA-BASTHIPURA 1	NO STATIONS EFFECTED	16:09	17:14	1:05	LINE CLEAR AVAILED
456	23-Jun-22	MYSURU	220	KUSHALANAGARA-BASTHIPURA 2	NO STATIONS EFFECTED	16:09	17:14	1:05	LINE CLEAR AVAILED
457	23-Jun-22	MYSURU	220	NAGAMANGALA 220-ANCHEPALYA 1	NO STATIONS EFFECTED	16:45	18:19	1:34	LINE CLEAR AVAILED
458	23-Jun-22	MYSURU	220	NAGAMANGALA 220-ANCHEPALYA 2	NO STATIONS EFFECTED	10:22	16:17	5:55	LINE CLEAR AVAILED
459	23-Jun-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:00	16:40	9:40	LINE CLEAR AVAILED
460	23-Jun-22	TUMKUR	66	ANTHRASANAHALI 220KV- KORATAGERE66(C T KERE66)	CHIKKATOTALKERE	18:07	18:32	0:25	LINE FAULT
461	23-Jun-22	TUMKUR	66	BENKIKERE 220kv-MALLADIHALLI	BENKIKERE_220	2:06	4:47	2:41	MAIN SUPPLY FAILURE
462	23-Jun-22	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	20:56	21:12	0:16	LINE FAULT
463	23-Jun-22	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	8:49	17:48	8:59	LINE CLEAR AVAILED
464	23-Jun-22	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:50	14:14	0:24	LINE FAULT
465	23-Jun-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	13:30	17:51	4:21	LINE FAULT
466	23-Jun-22	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	9:25	9:55	0:30	LINE FAULT
467	23-Jun-22	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	8:05	8:58	0:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
468	23-Jun-22	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	9:25	9:55	0:30	LINE FAULT
469	23-Jun-22	TUMKUR	66	HIRIYUR 220KV-THALLAK	HIRIYUR_220	9:25	9:55	0:30	LINE FAULT
470	23-Jun-22	TUMKUR	66	HIRIYUR_220-66KV PARSHAMPURA	HIRIYUR_220	17:23	17:35	0:12	LINE FAULT
471	23-Jun-22	TUMKUR	66	HIRIYUR220-BEVINAHALLI66	BEVINAHALLI_66,JAVAGONDANA HALLI_66,DASUDI_66	9:25	9:55	0:30	LINE FAULT
472	23-Jun-22	TUMKUR	66	HIRIYUR220-MATHOD 1	MATHOD_66,HINDASGHATTA_66, KANCHIPURA_66,GARAGA_66,PA NCHANAHALLI_66,HOSADURGA_6 6	9:25	9:55	0:30	LINE FAULT
473	23-Jun-22	TUMKUR	66	HIRIYUR220-MATHOD 2&1 LINE CLUB	MATHOD_66,HINDASGHATTA_66, KANCHIPURA_66,GARAGA_66,PA NCHANAHALLI_66,HOSADURGA_6 6	9:25	9:55	0:30	LINE FAULT
474	23-Jun-22	TUMKUR	66	HIRIYURKV 220kv- SUZLON 2	SUZLON2_IPP_66	9:25	9:55	0:30	LINE FAULT
475	23-Jun-22	TUMKUR	66	HONNALI66-HONNALLI220	HONNALLI_220	2:06	2:55	0:49	MAIN SUPPLY FAILURE
476	23-Jun-22	TUMKUR	66	HONNALI66-HONNALLI220	HONNALLI_220	7:15	8:27	1:12	MAIN SUPPLY FAILURE
477	23-Jun-22	TUMKUR	66	HONNALI66-HONNALLI220	HONNALLI_220	19:37	20:06	0:29	MAIN SUPPLY FAILURE
478	23-Jun-22	TUMKUR	66	HONNALLI 220kv- BANUVALLI	HONNALLI_220	2:06	2:55	0:49	MAIN SUPPLY FAILURE
479	23-Jun-22	TUMKUR	66	HONNALLI 220kv- BANUVALLI	HONNALLI_220	7:15	8:30	1:15	MAIN SUPPLY FAILURE
480	23-Jun-22	TUMKUR	66	HONNALLI 220kv- BANUVALLI	HONNALLI_220	19:37	20:06	0:29	MAIN SUPPLY FAILURE
481	23-Jun-22	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	HONNALLI_220	2:06	3:39	1:33	MAIN SUPPLY FAILURE
482	23-Jun-22	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	HONNALLI_220	7:15	8:28	1:13	MAIN SUPPLY FAILURE
483	23-Jun-22	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	HONNALLI_220	19:37	20:08	0:31	MAIN SUPPLY FAILURE
484	23-Jun-22	TUMKUR	66	HONNALLI 220kv- KUNDUR66	HONNALLI_220	2:06	3:39	1:33	MAIN SUPPLY FAILURE
485	23-Jun-22	TUMKUR	66	HONNALLI 220kv- KUNDUR66	HONNALLI_220	7:15	8:29	1:14	MAIN SUPPLY FAILURE
486	23-Jun-22	TUMKUR	66	HONNALLI 220kv- KUNDUR66	HONNALLI_220	8:29	9:26	0:57	MAIN SUPPLY FAILURE
487	23-Jun-22	TUMKUR	66	HONNALLI 220kv- KUNDUR66	HONNALLI_220	19:37	20:32	0:55	MAIN SUPPLY FAILURE
488	23-Jun-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	HONNALLI_220	2:06	2:55	0:49	MAIN SUPPLY FAILURE
489	23-Jun-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	HONNALLI_220	7:15	8:27	1:12	MAIN SUPPLY FAILURE
490	23-Jun-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	HONNALLI_220	19:37	20:06	0:29	MAIN SUPPLY FAILURE
491	23-Jun-22	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	HONNALLI_220	2:06	3:39	1:33	MAIN SUPPLY FAILURE
492	23-Jun-22	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	HONNALLI_220	7:15	8:27	1:12	MAIN SUPPLY FAILURE
493	23-Jun-22	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	HONNALLI_220	19:37	20:08	0:31	MAIN SUPPLY FAILURE
494	23-Jun-22	TUMKUR	66	HONNALLI 220kv- SHIMOGA 220kv	HONNALLI_220	7:15	8:17	1:02	MAIN SUPPLY FAILURE
495	23-Jun-22	TUMKUR	66	TR1	HIRIYUR_66	8:50	8:55	0:05	TRANSFORMER FAULT
496	23-Jun-22	TUMKUR	66	TR1	HOLALKERE_66	16:00	16:35	0:35	LINE CLEAR AVAILED
497	23-Jun-22	TUMKUR	66	TR1	NIRAGUNDA_66	2:00	3:00	1:00	TRANSFORMER FAULT
498	23-Jun-22	TUMKUR	66	TR1	NIRAGUNDA_66	4:00	4:20	0:20	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
499	23-Jun-22	TUMKUR	66	TR1	NIRAGUNDA_66	6:40	8:50	2:10	MAIN SUPPLY FAILURE
500	23-Jun-22	TUMKUR	66	TR1	NIRAGUNDA_66	18:10	18:50	0:40	MAIN SUPPLY FAILURE
501	23-Jun-22	TUMKUR	66	TR1	NIRAGUNDA_66	19:40	20:20	0:40	MAIN SUPPLY FAILURE
502	23-Jun-22	TUMKUR	66	TR1	JIDDIGERE_66	10:15	11:30	1:15	TRANSFORMER FAULT
503	23-Jun-22	TUMKUR	66	TR1	NIDSALE	22:00	22:15	0:15	TRANSFORMER FAULT
504	23-Jun-22	TUMKUR	66	TR1 AND TR2	PDKOTE_66	6:11	6:35	0:24	MAIN SUPPLY FAILURE
505	23-Jun-22	TUMKUR	66	TR1 AND TR2	PDKOTE_66	9:20	9:55	0:35	MAIN SUPPLY FAILURE
506	23-Jun-22	TUMKUR	66	TR1 AND TR2	PDKOTE_66	17:22	17:42	0:20	MAIN SUPPLY FAILURE
507	23-Jun-22	TUMKUR	66	TR1 AND TR2	BILCHODU_66	14:00	14:05	0:05	MAIN SUPPLY FAILURE
508	23-Jun-22	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	8:50	8:55	0:05	MAIN SUPPLY FAILURE
509	23-Jun-22	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	8:55	9:30	0:35	MAIN SUPPLY FAILURE
510	23-Jun-22	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	17:35	17:50	0:15	MAIN SUPPLY FAILURE
511	23-Jun-22	TUMKUR	66	TR1 AND TR2	BHARAMAGIRI_66	9:20	9:40	0:20	MAIN SUPPLY FAILURE
512	23-Jun-22	TUMKUR	66	TR2	BILCHODU_66	12:05	12:47	0:42	TRANSFORMER FAULT
513	23-Jun-22	TUMKUR	66	TR3	HONNALI_66	14:00	16:45	2:45	LINE CLEAR AVAILED
514	23-Jun-22	TUMKUR	220	ANCHEPALLYA_220- 220_NAGAMANGALA LINE-1	ANCHEPALLYA_220	16:29	18:18	1:49	LINE CLEAR AVAILED
515	23-Jun-22	TUMKUR	220	ANCHEPALLYA_220- 220_NAGAMANGALA LINE-2	ANCHEPALLYA_220	10:28	16:16	5:48	LINE CLEAR AVAILED
516	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-BENKIKERE_66	BENKIKERE_220	19:37	20:02	0:25	MAIN SUPPLY FAILURE
517	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-HONNALI LINE 1	BENKIKERE_220	2:06	2:52	0:46	MAIN SUPPLY FAILURE
518	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-HONNALI LINE 1	BENKIKERE_220	4:27	9:40	5:13	LINE CLEAR AVAILED
519	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-HONNALI LINE 1	BENKIKERE_220	19:37	19:58	0:21	MAIN SUPPLY FAILURE
520	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-HONNALI LINE 2	BENKIKERE_220	2:06	2:52	0:46	MAIN SUPPLY FAILURE
521	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-HONNALI LINE 2	BENKIKERE_220	7:15	8:41	1:26	MAIN SUPPLY FAILURE
522	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-HOSADURGA LINE 2	BENKIKERE_220	19:37	20:02	0:25	MAIN SUPPLY FAILURE
523	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-HOSADURGA LINE 1	BENKIKERE_220	4:03	9:45	5:42	LINE FAULT
524	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-HOSADURGA LINE 1	BENKIKERE_220	19:37	20:12	0:35	MAIN SUPPLY FAILURE
525	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-MALLADIHALLI	BENKIKERE_220	7:21	8:44	1:23	MAIN SUPPLY FAILURE
526	23-Jun-22	TUMKUR	220	BENKIKERE 220kV-MALLADIHALLI	BENKIKERE_220	19:37	20:02	0:25	MAIN SUPPLY FAILURE
527	23-Jun-22	TUMKUR	220	DAVANGERE SRS- HONNALI	DAVANGERE_SRS_220	2:06	2:46	0:40	LINE FAULT
528	23-Jun-22	TUMKUR	220	DAVANGERE SRS- HONNALI	DAVANGERE_SRS_220	2:47	13:57	11:10	LINE FAULT
530	23-Jun-22	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	19:37	19:58	0:21	MAIN SUPPLY FAILURE
531	23-Jun-22	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	2:06	2:52	0:46	MAIN SUPPLY FAILURE
532	23-Jun-22	TUMKUR	220	TR1	KBCROSS_220	13:00	15:15	2:15	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
533	23-Jun-22	TUMKUR	220	TR1	HIRIYUR_220	11:35	12:10	0:35	LINE CLEAR AVAILED
534	23-Jun-22	TUMKUR	220	TR1	HIRIYUR_220	9:17	9:38	0:21	TRANSFORMER FAULT
535	23-Jun-22	TUMKUR	220	TR1(HV SIDE)	CHITRADURGA_220	20:56	21:06	0:10	TRANSFORMER FAULT
536	23-Jun-22	TUMKUR	220	TR1(LV SIDE)	CHITRADURGA_220	20:56	21:14	0:18	TRANSFORMER FAULT
537	23-Jun-22	TUMKUR	220	TR2	HIRIYUR_220	9:17	9:38	0:21	TRANSFORMER FAULT
538	23-Jun-22	TUMKUR	220	TR2	BENKIKERE_220	2:52	4:34	1:42	TRANSFORMER FAULT
539	23-Jun-22	TUMKUR	220	TR3	DAVANGERE_SRS_220	9:36	13:25	3:49	LINE CLEAR AVAILED
540	23-Jun-22	TUMKUR	400	ICT2	GUTTUR_400	11:22	14:13	2:51	LINE CLEAR AVAILED
541	24-Jun-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UCHAGOAN_110	19:53 (23.06.2022)	13:23 (24.06.2022)	17:30	TRANSFORMER CHARGED
542	24-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MANTUR(G)_110	17:26	17:36	0:10	TRANSFORMER FAULT
543	24-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MANTUR(G)_110	18:04	18:57	0:53	TRANSFORMER FAULT
544	24-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KARWAR_110	3:35	4:43	1:08	TRANSFORMER FAULT
545	24-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KAMBAGI_110	15:50	16:07	0:17	TRANSFORMER FAULT
546	24-Jun-22	BAGALKOT	110	110/11KV,HV1	UAS DHARWAD_110	10:27	18:32	8:05	LINE CLEAR AVAILED
547	24-Jun-22	BAGALKOT	110	110/11KV,HV1	TILUVALI_110	12:20	14:56	2:36	LINE CLEAR AVAILED
548	24-Jun-22	BAGALKOT	110	110/11KV,HV1	TILUVALI_110	15:39	16:23	0:44	LINE CLEAR AVAILED
549	24-Jun-22	BAGALKOT	110	110/11KV,HV1	SIRSI_220	07:04	07:20	0:16	TRANSFORMER FAULT
550	24-Jun-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED GULEDAGUDD_110	14:05	14:16	0:11	TRANSFORMER FAULT
551	24-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
552	24-Jun-22	BAGALKOT	110	110/11KV,HV2	ANKALI_110	12:05	12:55	0:50	HAND TRIPPED
553	24-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED GULEDAGUDD_110	11:30	12:34	1:04	LINE CLEAR AVAILED
554	24-Jun-22	BAGALKOT	110	110/11KV,HV2	UAS DHARWAD_110	11:34	18:07	6:33	LINE CLEAR AVAILED
555	24-Jun-22	BAGALKOT	110	110/11KV,HV2	GALATAGA_110	12:05	12:55	0:50	LINE CLEAR AVAILED
556	24-Jun-22	BAGALKOT	110	110/11KV,HV2	110KV KATAKOL	15:40	15:45	0:05	LINE CLEAR AVAILED
557	24-Jun-22	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	11:30	12:30	1:00	LINE CLEAR AVAILED
558	24-Jun-22	BAGALKOT	110	110/11KV,HV3(HV2)	STATION NOT AFFECTED RATTIHALLI_110	5:06	5:11	0:05	TRANSFORMER FAULT
559	24-Jun-22	BAGALKOT	110	110/33,HV1	BELGAUM_110	12:10	12:50	0:40	TRANSFORMER FAULT
560	24-Jun-22	BAGALKOT	110	110/33KV, HV2	YADAWAD_33KV VANTAGODI_33KV STATION NOT AFFECTED UTTUR_110	11:55	12:33	0:38	HAND TRIPPED
561	24-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
562	24-Jun-22	BAGALKOT	110	110/33KV,HV1	BELAGUM_110	12:10	13:09	0:59	LINE CLEAR AVAILED
563	24-Jun-22	BAGALKOT	110	110/33KV,HV1	TILUVALI_110	12:20	14:50	2:30	LINE CLEAR AVAILED
564	24-Jun-22	BAGALKOT	110	110/33KV,HV1	TILUVALI_110	15:50	16:45	0:55	LINE CLEAR AVAILED
565	24-Jun-22	BAGALKOT	110	110/33KV,HV1	TILUVALI_110	15:27	15:50	0:23	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
566	24-Jun-22	BAGALKOT	110	110/33KV,HV1	SAVANUR_110	14:35	14:40	0:05	TRANSFORMER FAULT
567	24-Jun-22	BAGALKOT	110	110/33KV,HV2	MURDESHWAR_110	3:48	10:53	7:05	TRANSFORMER FAULT
568	24-Jun-22	BAGALKOT	110	110/33KV,HV2	MURDESHWAR_110	12:23	13:41	1:18	LINE CLEAR AVAILED
569	24-Jun-22	BAGALKOT	110	110/33KV,HV3	NANDIKURALI_33 STATION NOT AFFECTED ANKALI_110	11:16	12:00	0:44	HAND TRIPPED
570	24-Jun-22	BAGALKOT	110	110/33KV,HV3	KALKERI_33,GOLGERIO_33 SINDAGI_110	18:26	23:04	4:38	TRANSFORMER FAULT
571	24-Jun-22	BAGALKOT	110	110/33KV,HV3	ANKALI_110	11:15	12:00	0:45	LINE CLEAR AVAILED
572	24-Jun-22	BAGALKOT	110	110/33KV,HV3	NEHRUNAGAR_110	12:10	12:50	0:40	TRANSFORMER FAULT
573	24-Jun-22	BAGALKOT	110	110/33KV,HV3	KATAKOL_33 KATAKOL_110	15:37	16:43	1:06	LINE CLEAR AVAILED
574	24-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
575	24-Jun-22	BAGALKOT	110	BELATTI_ENERCON2	LAXMESHWAR_110KV	1:55	2:22	0:27	HAND TRIPPED
576	24-Jun-22	BAGALKOT	110	BELATTI_ENERCON2	LAXMESHWAR_110KV	5:46	6:06	0:20	HAND TRIPPED
577	24-Jun-22	BAGALKOT	110	BELATTI_LAXMESHWAR	BELATTI_110KV	5:40	6:02	0:22	LINE FAULT
578	24-Jun-22	BAGALKOT	110	BIJKDB-BHUTNAL	STATION NOT AFFECTED BIJKDB_110	9:55	12:50	2:55	LINE CLEAR AVAILED
579	24-Jun-22	BAGALKOT	110	CHIKKODI-DKSSK	CHIKKODI_220	12:04	12:38	2:10	LINE CLEAR AVAILED
580	24-Jun-22	BAGALKOT	110	DAMBAL-ENERCON-1	ENERCON_110 DAMBAL_110	10:30	10:44	0:14	HAND TRIPPED
581	24-Jun-22	BAGALKOT	110	DAMBAL-SUZLON-2	SUZLON_110 DAMBAL_110	10:30	10:47	0:17	HAND TRIPPED
582	24-Jun-22	BAGALKOT	110	GADAG-LAXMESHWAR	LAXMESHWAR_110	1:52	2:12	0:20	LINE FAULT
583	24-Jun-22	BAGALKOT	110	GHATAPRABHA-GOKAK	GHATAPRABHA_220	19:14	19:21	0:12	LINE FAULT
584	24-Jun-22	BAGALKOT	110	HIDIKAL-MAHALINGAPUR	HIDIKAL_110	4:29	12:06	7:37	LINE CLEAR AVAILED
585	24-Jun-22	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTED HUBLI_220	11:37 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
586	24-Jun-22	BAGALKOT	110	JAMBAGI_MUDHOL	STATION NOT AFFECTED JAMBAGI_110	12:29	13:06	0:37	HAND TRIPPED
587	24-Jun-22	BAGALKOT	110	KAMBAGI-MAMADAPUR	KAMBAGI_110	14:00	14:39	0:39	LINE FAULT
588	24-Jun-22	BAGALKOT	110	KUMATA-SIRSI	SIRSI_110	11:37	14:50	3:13	LINE FAULT
589	24-Jun-22	BAGALKOT	110	LAKMESHWAR_BELATTI	BELATTI_110KV	5:40	6:01	0:21	LINE FAULT
590	24-Jun-22	BAGALKOT	110	LAKMESHWAR_GADAG1	STATION NOT AFFECTED LAKMESHWAR_110	1:52	2:17	0:25	LINE FAULT
591	24-Jun-22	BAGALKOT	110	LAKMESHWAR_SHIRAHATTI	LAKMESHWAR_110	0:22	2:21	1:59	LINE FAULT
592	24-Jun-22	BAGALKOT	110	MAHALINGAPUR220-HIDKAL	HIDKAL_110	4:02	12:04	8:02	LINE FAULT
593	24-Jun-22	BAGALKOT	110	MKHUBLI-NARENDRA(KITTUR)	KITTUR_110	5:46	8:22	2:36	LINE FAULT
594	24-Jun-22	BAGALKOT	110	MRUTYUNJAYNAGAR- NARENDRA(UAS DHARWAD)	UAS DHARWAD_110	11:41	17:34	5:53	LINE CLEAR AVAILED
595	24-Jun-22	BAGALKOT	110	NARENDRA-UAS	UAS DHARWAD_110	17:32	18:07	0:35	LINE CLEAR AVAILED
596	24-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
597	24-Jun-22	BAGALKOT	110	SHIRAHATTI-LAXMESHWAR	STATION NOT AFFECTED SHIRAHATTI_110	0:23	2:18	1:55	LINE FAULT
598	24-Jun-22	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	3:38	14:25	10:47	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
599	24-Jun-22	BAGALKOT	110	UAS DHARWAD-M R NAGAR	UAS DHARWAD_110	17:34	19:59	2:25	LINE CLEAR AVAILED
600	24-Jun-22	BAGALKOT	110	UGAR KHUD	KAGAWAD_110	5:50	6:02	0:12	LINE CLEAR AVAILED
601	24-Jun-22	BAGALKOT	220	220/110KV,HV1,LV1	KUDUCHI_220	20:51 (24.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
602	24-Jun-22	BAGALKOT	220	220/110KV,HV1,LV1	INDI_220	12:20	14:10	1:50	LINE CLEAR AVAILED
603	24-Jun-22	BAGALKOT	220	220/110KV,HV2,LV2	HAVERI_220	11:04	13:45	2:41	LINE CLEAR AVAILED
604	24-Jun-22	BAGALKOT	220	AMBEWADI-NAGJARI2	STATION NOT AFFECTED AMBEWADI_220	5:46	6:08	0:22	LINE FAULT
605	24-Jun-22	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	10:42	11:39	0:57	LINE CLEAR AVAILED
606	24-Jun-22	BAGALKOT	220	HUBLI-NAGHARI-2	HUBLI_220	11:01	16:55	7:39	LINE FAULT
607	24-Jun-22	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:05 (15.06.2022)			LINE OPEN:LINE CLEAR AVAILED
608	24-Jun-22	BAGALKOT	220	SIRSI220-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVAILED
609	24-Jun-22	BAGALKOT	220	SIRSI220-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVAILED
610	24-Jun-22	BENGALURU	66	APPAREL PARK - DODDABELAVANGALA	DODDABELAVANGALA	18:07	18:18	0:11	LOAD CHANGE OVER
611	24-Jun-22	BENGALURU	66	BANGARPET - KOLAR 220	BANGARPET	17:20	17:30	0:10	LOAD CHANGE OVER
612	24-Jun-22	BENGALURU	66	BANGARPET - MALUR 220	BANGARPET	10:35	10:45	0:10	LOAD CHANGE OVER
613	24-Jun-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	17:11	17:17	0:06	LOAD CHANGE OVER
614	24-Jun-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	18:01	18:09	0:08	LOAD CHANGE OVER
615	24-Jun-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	17:11	17:17	0:06	LOAD CHANGE OVER
616	24-Jun-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	18:01	18:09	0:08	LOAD CHANGE OVER
617	24-Jun-22	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	12:18	12:29	0:11	LOAD CHANGE OVER
618	24-Jun-22	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	16:59	17:06	0:07	LOAD CHANGE OVER
619	24-Jun-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	12:18	12:29	0:11	LOAD CHANGE OVER
620	24-Jun-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	16:59	17:06	0:07	LOAD CHANGE OVER
621	24-Jun-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	12:18	12:29	0:11	LOAD CHANGE OVER
622	24-Jun-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	16:59	17:06	0:07	LOAD CHANGE OVER
623	24-Jun-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	12:18	12:29	0:11	LOAD CHANGE OVER
624	24-Jun-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	16:59	17:06	0:07	LOAD CHANGE OVER
625	24-Jun-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:00	15:27	0:27	LOAD CHANGE OVER
626	24-Jun-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:11	17:30	0:19	LOAD CHANGE OVER
627	24-Jun-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	18:01	18:09	0:08	LOAD CHANGE OVER
628	24-Jun-22	BENGALURU	66	HV1	AREHALLI	12:16	12:18	0:02	LINE CLEAR AVAILED
629	24-Jun-22	BENGALURU	66	HV1	ATTUR YELAHANKA	14:35	14:38	0:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
630	24-Jun-22	BENGALURU	66	HV1	ATTUR YELAHANKA	15:56	15:59	0:03	LOAD CHANGE OVER
631	24-Jun-22	BENGALURU	66	HV1	KAMASAMUDRA	13:15	13:20	0:05	LINE CLEAR AVAILED
632	24-Jun-22	BENGALURU	66	HV1	VOKKALERI	17:30	18:00	0:30	LINE CLEAR AVAILED
633	24-Jun-22	BENGALURU	66	HV2	SARJAPURA 220	16:19	16:41	0:22	TRANSFORMER FAULT
634	24-Jun-22	BENGALURU	66	HV2	VOKKALERI	8:30	8:55	0:25	LINE CLEAR AVAILED
635	24-Jun-22	BENGALURU	66	HV2	MULABAGLU	9:28	9:57	0:29	TRANSFORMER FAULT
636	24-Jun-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	11:20	11:55	0:35	LINE CLEAR AVAILED
637	24-Jun-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	14:35	17:00	2:25	LINE CLEAR AVAILED
638	24-Jun-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	17:05	17:45	0:40	LINE CLEAR AVAILED
639	24-Jun-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	18:23	18:30	0:07	LINE FAULT
640	24-Jun-22	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	3:59	4:06	0:07	LINE FAULT
641	24-Jun-22	BENGALURU	66	MAASTI - ANDASUN SOLAR IPP	NO STATION AFFECTED	19:11	19:40	0:28	LINE FAULT
642	24-Jun-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:53	16:55	0:02	LOAD CHANGE OVER
643	24-Jun-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	11:03	11:06	0:03	LOAD CHANGE OVER
644	24-Jun-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:53	16:55	0:02	LOAD CHANGE OVER
645	24-Jun-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	11:03	11:06	0:03	LOAD CHANGE OVER
646	24-Jun-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:53	16:55	0:02	LOAD CHANGE OVER
647	24-Jun-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	11:03	11:06	0:03	LOAD CHANGE OVER
648	24-Jun-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	7:38	7:42	0:04	LOAD CHANGE OVER
649	24-Jun-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	23:05	23:15	0:10	LOAD CHANGE OVER
650	24-Jun-22	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	15:13:00(18/06/2022)			LINE OPEN: LINE FAULT
651	24-Jun-22	BENGALURU	220	HV2	MALUR 220	11:03	16:55	5:52	LINE CLEAR AVAILED
652	24-Jun-22	GULBARGA	66	HV2	UJJANI_66	7:25	7:30	0:05	TRANSFORMER FAULT
653	24-Jun-22	GULBARGA	66	HV2	UJJANI_66	9:40	9:45	0:05	TRANSFORMER FAULT
654	24-Jun-22	GULBARGA	66	HV2	UJJANI_66	10:30	10:40	0:10	TRANSFORMER FAULT
655	24-Jun-22	GULBARGA	66	HV2	UJJANI_66	11:20	11:25	0:05	TRANSFORMER FAULT
656	24-Jun-22	GULBARGA	66	HV2	UJJANI_66	18:15	18:20	0:05	TRANSFORMER FAULT
657	24-Jun-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	JAWALGERA_110	1:48	1:59	0:11	LINE FAULT
658	24-Jun-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	23:54	23:59	0:05	LINE FAULT
659	24-Jun-22	GULBARGA	110	JAWALGERA-ADVAMERESHWAR	JAWALGERA_110	1:50	2:00	0:10	MAIN SUPPLY FAILURE
660	24-Jun-22	GULBARGA	110	KUKUNOOR-KUSHTAGI	KUKUNOOR_110	7:00	9:20	2:20	MAIN SUPPLY FAILURE
661	24-Jun-22	GULBARGA	110	KUSHTAGI-TAWARGERA	TAWARGERA_110	23:11	23:27	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
662	24-Jun-22	GULBARGA	110	KUSHTAGI-VAJRABANDI	VAJRABANDI_110,YELBURGA_110 ,KUKUNOOR_110	7:03	8:52	1:49	LINE CLEAR AVAILED
663	24-Jun-22	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	11:02	12:35	1:33	LINE CLEAR AVAILED
664	24-Jun-22	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	13:18	13:28	0:10	LINE CLEAR AVAILED
665	24-Jun-22	GULBARGA	110	SEDAM-ULTRA TECH_IPP	SEDAM_220	11:02	12:40	1:38	LINE CLEAR AVAILED
666	24-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
667	24-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
668	24-Jun-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	1:54	1:59	0:05	LINE FAULT
669	24-Jun-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	2:50	2:57	0:07	LINE FAULT
670	24-Jun-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP,C OREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
671	24-Jun-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110,GABBUR_110,M. KOLLUR_110	19:44	19:56	0:12	LINE FAULT
672	24-Jun-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110,GABBUR_110,M. KOLLUR_110	19:44	19:55	0:11	LINE FAULT
673	24-Jun-22	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAPUR_1 10,MASKI_110,VALAKAMADINNI_ 110	3:10	3:20	0:10	LINE FAULT
674	24-Jun-22	GULBARGA	110	TAVERGERA-KUSHTAGI	TAVERGERA_110	23:11	23:27	0:16	MAIN SUPPLY FAILURE
675	24-Jun-22	GULBARGA	110	UJJANI-SOKKE	UJJANI_66	15:35	16:00	0:25	MAIN SUPPLY FAILURE
676	24-Jun-22	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
677	24-Jun-22	GULBARGA	220	LINGAPUR-AARESSTEEL_IPP	AARESSTEEL_IPP	15:15	17:06	1:51	LINE CLEAR AVAILED
678	24-Jun-22	GULBARGA	220	LINGAPUR-JINDAL 2_IPP	LINGAPUR_220	8:50	18:10	9:20	LINE CLEAR AVAILED
679	24-Jun-22	GULBARGA	220	LINGSUGUR-RTPS1	LINGSUGUR_220	4:20	4:50	0:30	LINE FAULT
680	24-Jun-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN: LINE FAULT
681	24-Jun-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
682	24-Jun-22	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:03	13:10	4:07	LINE CLEAR AVAILED
683	24-Jun-22	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	8:53	13:10	4:17	NFBC ISSUED
684	24-Jun-22	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:54	15:49	4:55	NFBC ISSUED
685	24-Jun-22	HASSAN	66	CHANNAR-MALALI	CHANNARAYAPATNA_66	5:05	5:20	0:15	LINE FAULT
686	24-Jun-22	HASSAN	66	HV1	CHANNARAYAPATNA_66	12:10	13:10	1:00	LINE CLEAR AVAILED
687	24-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
688	24-Jun-22	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	8:54	13:10	4:16	LINE CLEAR AVAILED
689	24-Jun-22	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	10:53	15:48	4:55	LINE CLEAR AVAILED
690	24-Jun-22	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	11:40	14:43	3:03	LINE CLEAR AVAILED
691	24-Jun-22	HASSAN	110	HV1	SORABA_110	3:00	4:10	1:10	TRANSFORMER FAULT
692	24-Jun-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
693	24-Jun-22	HASSAN	110	HV2	ANAVATTI_110	12:32	12:49	0:17	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
694	24-Jun-22	HASSAN	110	HV2	SORABA_110	3:00	4:10	1:10	TRANSFORMER FAULT
695	24-Jun-22	HASSAN	110	HV2	SORABA_110	5:40	6:05	0:25	LINE CLEAR AVAILED
696	24-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
697	24-Jun-22	HASSAN	110	JOG-JST2	mghejog_gen	14:06	14:30	0:24	LINE FAULT
698	24-Jun-22	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:00	13:08	3:08	LINE CLEAR AVAILED
699	24-Jun-22	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	10:00	13:08	3:08	NFBC ISSUED
700	24-Jun-22	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	10:25	16:25	6:00	LINE CLEAR AVAILED
701	24-Jun-22	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	6:00	6:14	0:14	MAIN SUPPLY FAILURE
702	24-Jun-22	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	6:00	6:14	0:14	MAIN SUPPLY FAILURE
703	24-Jun-22	HASSAN	220	HV1	MSEZ_220	10:12	12:06	1:54	LINE CLEAR AVAILED
704	24-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
705	24-Jun-22	MYSURU	66	BEGUR -B MATTGERE	NO STATIONS EFFECTED	15:06	15:17	0:11	LINE FAULT
706	24-Jun-22	MYSURU	66	BG PURA-TALAKADU	CHANDALLI STATION INTERRUPTED.	12:37	15:20	2:43	LINE CLEAR AVAILED
707	24-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN:LINE CLEAR AVAILED
708	24-Jun-22	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66	10:20	14:55	4:34	LINE CLEAR AVAILED
709	24-Jun-22	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	10:05	18:54	8:49	LINE CLEAR AVAILED
710	24-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00(08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
711	24-Jun-22	MYSURU	66	HEBBANI-MEGHALAPURA	BGPURA_66 CHANDALLI_66 CHIDRAVALLI_66 GARGESHWARI_66 PARINAMIPURA_66 THALAKADU_66 THUMBLA_66 VYASRAJPURA_66 ,	5:17	5:29	0:12	LINE FAULT
712	24-Jun-22	MYSURU	66	HEBBANI-SFC 1	NO STATIONS EFFECTED	9:05	12:32	3:27	LINE CLEAR AVAILED
713	24-Jun-22	MYSURU	66	HEBBANI-SHIMSHA	NO STATIONS EFFECTED	11:30	12:56	1:26	LINE CLEAR AVAILED
714	24-Jun-22	MYSURU	66	HEBBANI-VADKEPURA	MALIYURU_66 KIRUGAVALU_66 VADKEPURA_66	18:27	18:36	0:09	LINE FAULT
715	24-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
716	24-Jun-22	MYSURU	66	HV1	CHUNCHUNKATTE_66	10:14	16:29	6:15	LINE CLEAR AVAILED
717	24-Jun-22	MYSURU	66	HV1	HURA_66	10:00	16:05	6:05	LINE CLEAR AVAILED
718	24-Jun-22	MYSURU	66	HV2	CHUNCHUNKATTE_66	10:10	16:20	6:10	LINE CLEAR AVAILED
719	24-Jun-22	MYSURU	66	HV2	HURA_66	10:00	16:05	6:05	LINE CLEAR AVAILED
720	24-Jun-22	MYSURU	66	KOPPA-NAGAMANGALA 220	NO STATIONS EFFECTED	12:05	17:30	5:25	NFBC ISSUED
721	24-Jun-22	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	15:25			LINE OPEN:LINE CLEAR AVAILED
722	24-Jun-22	MYSURU	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE STATION INTERRUPTED.	17:50	18:12	0:21	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
723	24-Jun-22	MYSURU	66	KUSHALANAGARA 220-PERIYAPATNA-1	HANAGODU_66, KAMPALAPURA_66, PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66,	17:50	18:11	0:21	LINE FAULT
724	24-Jun-22	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	9:35	13:22	3:46	NFBC ISSUED
725	24-Jun-22	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	9:45	17:00	7:15	LINE CLEAR AVAILED
726	24-Jun-22	MYSURU	66	MUGUR-JANNUR	JANNUR_66	9:45	17:00	7:15	LINE CLEAR AVAILED
727	24-Jun-22	MYSURU	66	MUGUR-KUNTHUR	MUGUR_66	9:45	17:00	7:15	LINE CLEAR AVAILED
728	24-Jun-22	MYSURU	66	MUGUR-THAYURU	NO STATIONS EFFECTED	9:40:00 (20.06.2022)			LINE OPEN:LINE CLEAR AVAILED
729	24-Jun-22	MYSURU	66	SANTHE SARAGURU-KADAKOLA 2	CHANDRAWADI_66	10:05	15:55	5:50	LINE CLEAR AVAILED
730	24-Jun-22	MYSURU	66	SFC SIVA-HEBBANI 2	NO STATIONS EFFECTED	9:06	12:33	3:26	NFBC ISSUED
731	24-Jun-22	MYSURU	220	HV2	TUBINAKERE_220	12:58	14:47	1:49	LINE CLEAR AVAILED
732	24-Jun-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
733	24-Jun-22	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	12:55	14:08	1:13	LINE CLEAR AVAILED
734	24-Jun-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	2:00	2:10	0:10	LINE FAULT
735	24-Jun-22	TUMKUR	66	BEVINAHALLI- CHANGAVARA_66	BEVINAHALLI_66	2:00	2:10	0:10	LINE FAULT
736	24-Jun-22	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 1	CHITRADURGA_66	12:38	12:47	0:09	LINE FAULT
737	24-Jun-22	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 2	CHITRADURGA_66	12:38	12:47	0:09	LINE FAULT
738	24-Jun-22	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 4	CHITRADURGA_66	12:38	12:47	0:09	LINE FAULT
739	24-Jun-22	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA3	CHITRADURGA_66	12:38	12:47	0:09	LINE FAULT
740	24-Jun-22	TUMKUR	66	HIRIYUR_220-220 PGCIL	HIRIYUR_220	11:58	12:23	0:25	LINE FAULT
741	24-Jun-22	TUMKUR	66	HIRIYUR_220-220 PGCIL	HIRIYUR_220	12:23	13:16	0:53	LINE FAULT
742	24-Jun-22	TUMKUR	66	HIRIYUR_220-220 PGCIL	HIRIYUR_220	15:16	15:40	0:24	LINE FAULT
743	24-Jun-22	TUMKUR	66	HIRIYUR_220-66KV PARSHAMPURA	HIRIYUR_220	10:20	10:30	0:10	LINE FAULT
744	24-Jun-22	TUMKUR	66	HIRIYUR_220-66KV PARSHAMPURA	HIRIYUR_220	10:20	10:30	0:10	LINE FAULT
745	24-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:55	10:05	0:10	LINE FAULT
746	24-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:00	12:35	0:35	MAIN SUPPLY FAILURE
747	24-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:40	13:55	0:15	MAIN SUPPLY FAILURE
748	24-Jun-22	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	8:20	8:25	0:05	LINE FAULT
749	24-Jun-22	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	19:10	19:27	0:17	LINE FAULT
750	24-Jun-22	TUMKUR	66	THALLAK 220-PR PURA	THALLAK_220	5:17	5:32	0:15	LINE FAULT
751	24-Jun-22	TUMKUR	66	TR1	NEELAGUNDA_220	23:20	23:25	0:05	TRANSFORMER FAULT
752	24-Jun-22	TUMKUR	66	TR1	CHITRADURGA_66	13:12	13:27	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
753	24-Jun-22	TUMKUR	66	TR1	CHITRADURGA_66	13:33	13:56	0:23	TRANSFORMER FAULT
754	24-Jun-22	TUMKUR	66	TR1	CHITRADURGA_66	15:43	15:50	0:07	TRANSFORMER FAULT
755	24-Jun-22	TUMKUR	66	TR1	CHITRADURGA_66	14:51	15:18	0:27	TRANSFORMER FAULT
756	24-Jun-22	TUMKUR	66	TR1	CHITRADURGA_66	15:50	21:02	5:12	TRANSFORMER FAULT
757	24-Jun-22	TUMKUR	66	TR1	PDKOTE_66	10:19	11:32	1:13	MAIN SUPPLY FAILURE
758	24-Jun-22	TUMKUR	66	TR1 AND TR2	CHITRADURGA_66	12:03	12:49	0:46	MAIN SUPPLY FAILURE
759	24-Jun-22	TUMKUR	66	TR1 AND TR2	CHITRADURGA_66	13:40	15:54	2:14	MAIN SUPPLY FAILURE
760	24-Jun-22	TUMKUR	66	TR1,TR2 AND TR3	HARIYABBE_66	10:20	11:32	1:12	MAIN SUPPLY FAILURE
761	24-Jun-22	TUMKUR	66	TR2	HARIYABBE_66	11:32	11:50	0:18	TRANSFORMER FAULT
762	24-Jun-22	TUMKUR	66	TR2	TOVINKERE_66	11:25	12:40	1:15	LINE CLEAR AVAILED
763	24-Jun-22	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:02	12:34	0:32	LINE FAULT
764	24-Jun-22	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	12:02	12:34	0:32	LINE FAULT
765	24-Jun-22	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	16:52	17:28	0:36	LINE FAULT
766	24-Jun-22	TUMKUR	220	DAVANGERE SRS- HONNALI	DAVANGERE_SRS_220	19:37(23.06.2022)	13:51(24.06.2022)-	18:14	LINE CHARGED
767	24-Jun-22	TUMKUR	220	DAVANGERE SRS- HONNALI	DAVANGERE_SRS_220	14:50(24.06.2022)			LINE OPEN: LINE FAULT
768	24-Jun-22	TUMKUR	220	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	23:45(24.06.2022)			LINE OPEN: LINE FAULT
769	24-Jun-22	TUMKUR	220	HIRIYUR220-MADHUGIRI220	HIRIYUR_220	11:58	12:40	0:42	LINE FAULT
770	24-Jun-22	TUMKUR	220	HIRIYUR220-MADHUGIRI220	HIRIYUR_220	12:40	12:55	0:15	LINE FAULT
771	24-Jun-22	TUMKUR	220	HIRIYUR220-MADHUGIRI220	HIRIYUR_220	13:03	13:15	0:12	LINE FAULT
772	24-Jun-22	TUMKUR	220	HIRIYUR220-MADHUGIRI220	HIRIYUR_220	13:15	13:30	0:15	LINE FAULT
773	24-Jun-22	TUMKUR	220	HIRIYUR220-MADHUGIRI220	HIRIYUR_220	16:35	19:40	3:05	LINE FAULT
774	24-Jun-22	TUMKUR	220	HIRIYUR220-MADHUGIRI220	HIRIYUR_220	19:40	20:26	0:46	LINE FAULT
775	24-Jun-22	TUMKUR	220	TR1	DAVANGERE_SRS_220	23:45(24.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
776	24-Jun-22	TUMKUR	220	TR1 ,TR2 AND TR3	CHITRADURGA_220	12:02	12:39	0:37	TRANSFORMER FAULT
777	25-Jun-22	BAGALKOT	110	110/11KV, HV1 & HV2	STATION NOT AFFECTED MANTU(G)_111	16:01	16:08	0:07	TRANSFORMER FAULT
778	25-Jun-22	BAGALKOT	110	110/11KV, HV2	MATTIHAL_110	15:41	17:00	1:19	LINE CLEAR AVAILED
779	25-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KARWAR_110	14:35	16:30	1:55	TRANSFORMER FAULT
780	25-Jun-22	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	11:33	12:06	0:33	TRANSFORMER FAULT
781	25-Jun-22	BAGALKOT	110	110/11KV,HV1	NANADI_110	10:54	14:13	3:19	LINE CLEAR AVAILED
782	25-Jun-22	BAGALKOT	110	110/11KV,HV1 AND HV2	STATION NOT AFFECTED GHATAPRABHA_110	17:44	18:08	0:24	HAND TRIPPED
783	25-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
784	25-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED KULIGOD_110	19:13	19:47	0:34	HAND TRIPPED
785	25-Jun-22	BAGALKOT	110	110/11KV,HV2	NANADI_110	9:58	14:00	4:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
786	25-Jun-22	BAGALKOT	110	110/11KV,HV3(HV2)	STATION NOT AFFECTED RATTIHALI_110	11:52	11:56	0:04	TRANSFORMER FAULT
787	25-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
788	25-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVALIED
789	25-Jun-22	BAGALKOT	110	ATHANI-SATTI	220KV ATHANI_220	5:35	5:46	0:11	LINE FAULT
790	25-Jun-22	BAGALKOT	110	BABLESHWAR-MAMADAPUR	BABLESHWAR_110	12:20	15:16	2:56	NFBC ISSUED
791	25-Jun-22	BAGALKOT	110	BAGALKOT-KATARAKI(NEER BUDIHAL)	NEER BUDIHAL_110	6:10	6:17	0:07	LINE FAULT
792	25-Jun-22	BAGALKOT	110	BAGEWADI220-MAMADAPUR-1	MAMDAPUR(B)_110	12:32	14:46	2:14	LINE CLEAR AVALIED
793	25-Jun-22	BAGALKOT	110	BAGEWADI220-MAMADAPUR-2	MAMDAPUR(B)_110	12:32	14:38	2:06	LINE CLEAR AVALIED
794	25-Jun-22	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	12:01	14:35	2:34	LINE CLEAR AVALIED
795	25-Jun-22	BAGALKOT	110	BAGEWADI-RBRK	BAGEWADI_220	1:07	1:24	0:17	LINE FAULT
796	25-Jun-22	BAGALKOT	110	BAGEWADI-RBRK	BAGEWADI_220	1:37	1:41	0:04	LINE FAULT
797	25-Jun-22	BAGALKOT	110	BAGEWADI-RBRK	BAGEWADI_220	1:41	1:45	0:04	LINE FAULT
798	25-Jun-22	BAGALKOT	110	BANAHATTI_JAMAKANDI	BANAHATTI_110KV	17:35	17:50	0:15	HAND TRIPPED
799	25-Jun-22	BAGALKOT	110	CHIKKODI-BHOJ(NANADI)	CHIKKODI_220	11:20	14:10	2:50	LINE CLEAR AVALIED
800	25-Jun-22	BAGALKOT	110	CHIKKODI-NANADI	NANADI_110	11:20	14:12	2:52	LINE CLEAR AVALIED
801	25-Jun-22	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTED HUBLI_220	11:37 (14.06.2022)			LINE OPEN:LINE CLEAR AVALIED
802	25-Jun-22	BAGALKOT	110	JAMAKH_PRABHULINGPUR	STATION NOT AFFECTED JAMAKHANDI_110	13:15	13:26	0:11	HAND TRIPPED
803	25-Jun-22	BAGALKOT	110	JAMAKH_PRABHULINGPUR	STATION NOT AFFECTED JAMAKHANDI_110	17:40	17:54	0:14	HAND TRIPPED
804	25-Jun-22	BAGALKOT	110	KAMBAGI-MAMADAPUR	KAMBAGI_110	13:02	13:39	0:37	LINE FAULT
805	25-Jun-22	BAGALKOT	110	KAMBAGI-TODALBAGI	KAMBAGI_110	13:38	13:39	0:01	LINE FAULT
806	25-Jun-22	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	13:22	17:01	3:39	LINE CLEAR AVALIED
807	25-Jun-22	BAGALKOT	110	MKHUBLI220-KHANAPUR	KHANAPUR_110	10:11	15:30	5:19	LINE FAULT
808	25-Jun-22	BAGALKOT	110	MUNDARGI-VIJAYA SUGARS	MUNDARGI_110	12:04	12:07	0:03	HAND TRIPPED
809	25-Jun-22	BAGALKOT	110	NANADI-DODDANNAVAR	NANADI_110	11:19	14:13	2:54	LINE CLEAR AVALIED
810	25-Jun-22	BAGALKOT	110	NAVALAGI-JAMAKHANDI	NAVALAGI_110	13:16	17:50	4:34	LINE CLEAR AVALIED
811	25-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVALIED
812	25-Jun-22	BAGALKOT	110	RANNABELAGALI- MUDHOL(UTTUR)	STATION NOT AFFECTED RANNABELAGALI_110	6:08	6:16	0:08	LINE FAULT
813	25-Jun-22	BAGALKOT	110	UCHAGOAN-UDYAMBAG	UCHAGOAN_110	6:57 (25.06.2022)			LINE OPEN:LINE CLEAR AVALIED
814	25-Jun-22	BAGALKOT	110	UTTUR-MAHALINGAPUR	UTTUR_110	6:07	6:24	0:17	LINE FAULT
815	25-Jun-22	BAGALKOT	110	VAJARMATTI-KATARAKI	VAJRAMATTI_220	15:50	15:54	0:04	LINE FAULT
816	25-Jun-22	BAGALKOT	220	220/110KV,HV1,LV1	KUDUCHI_220	20:51 (24.06.2022)	11:41 (25.06.2022)	14:51	TRANSFORMER CHARGED
817	25-Jun-22	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220	4:37	6:24	1:47	TRANSFORMER FAULT
818	25-Jun-22	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	12:43	17:58	5:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
819	25-Jun-22	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:05 (15.06.2022)			LINE OPEN:LINE CLEAR AVAILED
820	25-Jun-22	BAGALKOT	220	SIRSI220-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVAILED
821	25-Jun-22	BAGALKOT	220	SIRSI220-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVAILED
822	25-Jun-22	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE, WELCAST	22:24	22:34	0:10	LOAD CHANGE OVER
823	25-Jun-22	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	10:42	10:47	0:05	LOAD CHANGE OVER
824	25-Jun-22	BENGALURU	66	GOKULA - SRS PEENYA 1& 2 220	GOKULA, BEL (EHT), HMT (EHT)	12:00	18:25	6:25	LINE CLEAR AVALIED
825	25-Jun-22	BENGALURU	66	HEBBAL 220 - BANASAWADI	BANASAWADI	12:36	12:38	0:02	LINE CLEAR AVALIED
826	25-Jun-22	BENGALURU	66	HV1	BANASAWADI	12:36	12:41	0:05	MAIN SUPPLY FAILURE
827	25-Jun-22	BENGALURU	66	HV1	ISRO LAYOUT	15:17	15:19	0:02	LINE CLEAR AVALIED
828	25-Jun-22	BENGALURU	66	HV1	KANTEERAVA	14:13	14:25	0:12	LINE CLEAR AVALIED
829	25-Jun-22	BENGALURU	66	HV1	KORAMANGALA 220	7:05	8:03	0:58	TRANSFORMER FAULT
830	25-Jun-22	BENGALURU	66	HV1	RMZ	11:10	11:15	0:05	LINE CLEAR AVALIED
831	25-Jun-22	BENGALURU	66	HV1	DIVYASHREE TECH PARK	12:50	12:54	0:04	LINE CLEAR AVALIED
832	25-Jun-22	BENGALURU	66	HV1	BIDADI 220	13:42	14:34	0:52	TRANSFORMER FAULT
833	25-Jun-22	BENGALURU	66	HV1	BIDADI 220	20:03	20:31	0:28	LINE CLEAR AVALIED
834	25-Jun-22	BENGALURU	66	HV1	CHAKAVELU	18:20	18:25	0:04	LINE CLEAR AVALIED
835	25-Jun-22	BENGALURU	66	HV2	KANTEERAVA	11:15	11:20	0:05	LINE CLEAR AVALIED
836	25-Jun-22	BENGALURU	66	HV2	KHODAYS 220	6:12	6:23	0:11	TRANSFORMER FAULT
837	25-Jun-22	BENGALURU	66	HV2	RMZ	11:58	12:00	0:02	LINE CLEAR AVALIED
838	25-Jun-22	BENGALURU	66	HV2	DIVYASHREE TECH PARK	15:14	15:18	0:04	LINE CLEAR AVALIED
839	25-Jun-22	BENGALURU	66	HV2	TK HALLI 220	10:05	15:10	5:05	LINE CLEAR AVALIED
840	25-Jun-22	BENGALURU	66	HV2	AVERAHALLI	12:05	12:20	0:15	TRANSFORMER FAULT
841	25-Jun-22	BENGALURU	66	HV2	SARIAPURA 220	7:13	7:32	0:19	TRANSFORMER FAULT
842	25-Jun-22	BENGALURU	66	HV3	ADUGODI	10:50	14:34	3:44	LINE CLEAR AVALIED
843	25-Jun-22	BENGALURU	66	HV3	BANASAWADI	12:36	12:41	0:05	MAIN SUPPLY FAILURE
844	25-Jun-22	BENGALURU	66	HV3	RMZ	13:00	13:05	0:05	LINE CLEAR AVALIED
845	25-Jun-22	BENGALURU	66	HV3	DIVYASHREE TECH PARK	10:38	10:42	0:04	LINE CLEAR AVALIED
846	25-Jun-22	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	11:40	11:45	0:05	LOAD CHANGE OVER
847	25-Jun-22	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	18:56	18:59	0:03	LOAD CHANGE OVER
848	25-Jun-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	10:15	18:00	7:45	LINE CLEAR AVALIED
849	25-Jun-22	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	11:35	11:39	0:04	LOAD CHANGE OVER
850	25-Jun-22	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	22:10	22:15	0:05	LOAD CHANGE OVER
851	25-Jun-22	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	15:13:00(18/06/2022)			LINE OPEN: LINE FAULT
852	25-Jun-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	10:06	15:10	5:04	LINE CLEAR AVALIED
853	25-Jun-22	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	7:13	15:09	7:56	LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
854	25-Jun-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	10:06	15:10	5:04	LINE CLEAR AVAILED
855	25-Jun-22	BENGALURU	66	TK HALLI 220 - LIMBAVALI	NO STATION AFFECTED	9:33	15:00	5:27	LINE CLEAR AVAILED
856	25-Jun-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	9:31	14:55	5:24	LINE CLEAR AVAILED
857	25-Jun-22	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, DODDALAHALLI, SATHNUR (ACHLU)	8:38	15:14	6:36	LINE CLEAR AVAILED
858	25-Jun-22	BENGALURU	66	VR DODDI - SOMANAHALLI 220	VR DODDI	15:07	15:10	0:03	LOAD CHANGE OVER
859	25-Jun-22	BENGALURU	66	VR DODDI - TK HALLI 220	VR DODDI	7:12	7:17	0:05	LOAD CHANGE OVER
860	25-Jun-22	GULBARGA	66	HV2	UJJANI_66	9:00	9:05	0:05	TRANSFORMER FAULT
861	25-Jun-22	GULBARGA	66	HV2	UJJANI_66	10:50	10:55	0:05	TRANSFORMER FAULT
862	25-Jun-22	GULBARGA	66	HV2	UJJANI_66	11:20	11:25	0:05	TRANSFORMER FAULT
863	25-Jun-22	GULBARGA	66	HV2	UJJANI_66	12:30	12:35	0:05	TRANSFORMER FAULT
864	25-Jun-22	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGIDURGA_66	13:32	13:48	0:16	LINE FAULT
865	25-Jun-22	GULBARGA	66	UJJANI-SOKKE	UJJANI_66	13:30	13:40	0:10	MAIN SUPPLY FAILURE
866	25-Jun-22	GULBARGA	66	UJJANI-SOKKE	UJJANI_66	16:15	16:30	0:15	MAIN SUPPLY FAILURE
867	25-Jun-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	JAWALGERA_110	4:55	5:06	0:11	LINE FAULT
868	25-Jun-22	GULBARGA	110	ALAND-KAPNOOR	ALAND_110, KADAGANCHI_110	5:12	5:18	0:06	LINE FAULT
869	25-Jun-22	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	17:45	17:50	0:05	MAIN SUPPLY FAILURE
870	25-Jun-22	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR_110	20:43	20:52	0:09	LINE FAULT
871	25-Jun-22	GULBARGA	110	HALWARTHY-GINIGERA	GINIGERA_110	4:15	14:50	10:35	LINE CLEAR AVAILED
872	25-Jun-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	5:10	5:24	0:14	LINE FAULT
873	25-Jun-22	GULBARGA	110	HV1	MATAMARI_110	17:45	17:50	0:05	MAIN SUPPLY FAILURE
874	25-Jun-22	GULBARGA	110	HV1	MATAMARI_110	18:00	18:05	0:05	TRANSFORMER FAULT
875	25-Jun-22	GULBARGA	110	HV1	MATAMARI_110	15:55	16:06	0:11	TRANSFORMER FAULT
876	25-Jun-22	GULBARGA	110	HV2	SREERAMNAGAR_110	10:00	13:00	3:00	LINE CLEAR AVAILED
877	25-Jun-22	GULBARGA	110	JAWALGERA- ADVIAMRESHWARPUR	JAWALGERA_110	4:50	5:05	0:15	MAIN SUPPLY FAILURE
878	25-Jun-22	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMAN AL_110,HOREGONNAGAR_110	14:10	14:30	0:20	LINE FAULT
879	25-Jun-22	GULBARGA	110	LINGASUGUR-GURUGUNTA	GURUGUNTA_110,KHEL_IPP,LJVL_ IPP	10:04	10:52	0:48	LINE CLEAR AVAILED
880	25-Jun-22	GULBARGA	110	LINGASUGUR-KAREPOWER	CHAYADEVI_IPP,KAREPOWER_IPP	0:45	0:55	0:10	LINE FAULT
881	25-Jun-22	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	1:58	2:05	0:07	LINE FAULT
882	25-Jun-22	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	4:20	4:25	0:05	LINE FAULT
883	25-Jun-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:00	5:07	0:07	LINE FAULT
884	25-Jun-22	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORWAR TEMPLE_110	0:07	0:14	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
885	25-Jun-22	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORWAR TEMPLE_110	5:20	5:35	0:15	LINE FAULT
886	25-Jun-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	0:50	0:55	0:05	LINE FAULT
887	25-Jun-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	3:05	3:10	0:05	LINE FAULT
888	25-Jun-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110, DEVANGAON_110,RENUKA_IPP,A FZALPUR_110,KARAJAGI_110	21:30	21:34	0:04	LINE FAULT
889	25-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
890	25-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
891	25-Jun-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	3:02	3:07	0:05	LINE FAULT
892	25-Jun-22	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	4:45	4:55	0:10	LINE FAULT
893	25-Jun-22	GULBARGA	220	KUDLIGI-HIREMALLANAHOLI2	KUDLIGI_220	9:45	10:30	0:45	LINE CLEAR AVAILED
894	25-Jun-22	GULBARGA	220	LINGAPUR-JINDAL 2_IPP	LINGAPUR_220	8:15	18:45	10:30	LINE CLEAR AVAILED
895	25-Jun-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
896	25-Jun-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:05	13:20	0:15	LINE FAULT
897	25-Jun-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:55	14:10	0:15	LINE FAULT
898	25-Jun-22	HASSAN	66	CHANNAR-SHETTYHALLI	CHANNARAYAPATNA_66	8:05	9:00	0:55	LINE FAULT
899	25-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
900	25-Jun-22	HASSAN	66	HV2 CB	MANJUNATHPURA_66	0:15	0:48	0:33	TRANSFORMER FAULT
901	25-Jun-22	HASSAN	66	HV2 CB	MANJUNATHPURA_66	9:55	13:07	3:12	LINE CLEAR AVAILED
902	25-Jun-22	HASSAN	66	MATTNAV-DIDGTHL	MATTANAVILE_66	10:44	10:55	0:11	LINE FAULT
903	25-Jun-22	HASSAN	66	MATTNAV-DIDGTHL	MATTANAVILE_66	12:10	12:23	0:13	LINE FAULT
904	25-Jun-22	HASSAN	66	MATTNAV-DIDGTHL	MATTANAVILE_66	12:40	13:47	1:07	LINE FAULT
905	25-Jun-22	HASSAN	110	HV1	SHIRALKOPPA_110	9:55	19:25	9:30	LINE CLEAR AVAILED
906	25-Jun-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
907	25-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
908	25-Jun-22	HASSAN	110	LV1	MSEZ_220	10:12	12:07	1:55	LINE CLEAR AVAILED
909	25-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
910	25-Jun-22	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:25(25.06.2022)			LINE OPEN:LINE CLEAR AVAILED
911	25-Jun-22	MYSURU	66	AC GIRI -TUBINKERE	ADICHUNCHANAGIRI_66VADERAL LI_66	10:25	18:20	7:55	LINE CLEAR AVAILED
912	25-Jun-22	MYSURU	66	AKKIHEBBAL-KAVERI HYDRO	NO STATIONS EFFECTED	13:40	13:46	0:05	LINE FAULT
913	25-Jun-22	MYSURU	66	BG NAGARA-HIRISAVE	KADABALLY_66	10:25	23:08	12:43	LINE CLEAR AVAILED
914	25-Jun-22	MYSURU	66	BG NAGARA-NAGMANGALA	BG NAGARA_66	10:25	18:10	7:45	LINE CLEAR AVAILED
915	25-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
916	25-Jun-22	MYSURU	66	GUNDLUPETE-BEGUR-1	NO STATIONS EFFECTED	6:20	13:19	6:59	LINE CLEAR AVAILED
917	25-Jun-22	MYSURU	66	GUNDLUPETE-BEGUR-2	NO STATIONS EFFECTED	6:20	13:20	7:00	LINE CLEAR AVAILED
918	25-Jun-22	MYSURU	66	HALGUR-TK HALLI	NO STATIONS EFFECTED	8:50	14:10	5:20	NFBC ISSUED
919	25-Jun-22	MYSURU	66	HEBBANI -SATHEGALA	NO STATIONS EFFECTED	11:30	12:17	0:47	LINE CLEAR AVAILED
920	25-Jun-22	MYSURU	66	HEBBANI -SFC-2	NO STATIONS EFFECTED	10:25	11:47	1:22	LINE CLEAR AVAILED
921	25-Jun-22	MYSURU	66	HEBBANI -TK HALLI	NO STATIONS EFFECTED	10:15	14:05	3:50	LINE CLEAR AVAILED
922	25-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
923	25-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
924	25-Jun-22	MYSURU	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	4:40:00 (25.6.2022)			LINE OPEN:LINE CLEAR AVAILED
925	25-Jun-22	MYSURU	66	HOOTAGALLI-BARC-1	NO STATIONS EFFECTED	4:57:00 (25.6.2022)			LINE OPEN:LINE CLEAR AVAILED
926	25-Jun-22	MYSURU	66	HOOTAGALLI-BARC-2	NO STATIONS EFFECTED	4:57:00 (25.6.2022)			LINE OPEN:LINE CLEAR AVAILED
927	25-Jun-22	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	4:40:00 (25.6.2022)			LINE OPEN:LINE CLEAR AVAILED
928	25-Jun-22	MYSURU	66	HV1	K_HONNALGERE_66	10:10	10:50	0:40	MAIN SUPPLY FAILURE
929	25-Jun-22	MYSURU	66	HV2	RKNAGARA_66	21:01	21:30	0:28	LINE CLEAR AVAILED
930	25-Jun-22	MYSURU	66	KADAKOLA-DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	11:32	13:10	1:38	LINE CLEAR AVAILED
931	25-Jun-22	MYSURU	66	KADAKOLA-NANJANGUDU1	NO STATIONS EFFECTED	11:30	13:09	1:39	LINE CLEAR AVAILED
932	25-Jun-22	MYSURU	66	KADAKOLA-NANJANGUDU2	NO STATIONS EFFECTED	11:30	13:10	1:40	LINE CLEAR AVAILED
933	25-Jun-22	MYSURU	66	KADAKOLA-VAJMANGALA-1	AYRALLI_66MARADIHUNDI_66	12:52	16:55	4:03	LINE CLEAR AVAILED
934	25-Jun-22	MYSURU	66	KADAKOLA-VAJMANGALA-2	NO STATIONS EFFECTED	10:45	17:50	7:05	LINE CLEAR AVAILED
935	25-Jun-22	MYSURU	66	KM DODDI-MANDYA	K_HONNALGERE_66 KMDODDI_66 KKDODDI_66 KIADBMANDYA_66 SOMANAHALLI_66 TUMBEKERE_66MADDUR_66	14:42	14:57	0:15	HAND TRIPPED
936	25-Jun-22	MYSURU	66	KM DODDI-TK HALLI	NO STATIONS EFFECTED	9:30	14:55	5:25	NFBC ISSUED
937	25-Jun-22	MYSURU	66	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	13:20	13:25	0:05	LINE FAULT
939	25-Jun-22	MYSURU	66	KR PETE-KIKKERI	KIKKERI_66	13:39	13:48	0:08	LINE FAULT
940	25-Jun-22	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	15:25			LINE OPEN:LINE CLEAR AVAILED
941	25-Jun-22	MYSURU	66	MUGUR-THAYURU	NO STATIONS EFFECTED	9:40:00 (20.06.2022)			LINE OPEN:LINE CLEAR AVAILED
942	25-Jun-22	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 PONNAMPET_66, VIRAJPET_66,	14:50	15:09	0:19	LINE FAULT
943	25-Jun-22	MYSURU	66	RK NAGARA-DATAGALLI	RKNAGARA_66	10:30	17:08	6:38	LINE CLEAR AVAILED
944	25-Jun-22	MYSURU	66	RK NAGARA-MANTAGALLI	NO STATIONS EFFECTED	10:30	17:17	6:47	LINE CLEAR AVAILED
945	25-Jun-22	MYSURU	66	VAJMANGALA -HEBBANI	NO STATIONS EFFECTED	11:18	12:06	0:48	LINE CLEAR AVAILED
946	25-Jun-22	MYSURU	220	HV2	MADHUVANAHLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
947	25-Jun-22	MYSURU	220	KADAKOLA-BASTIPURA 1	NO STATIONS EFFECTED	5:51:19 (25.6.2022)			LINE OPEN:LINE CLEAR AVAILED
948	25-Jun-22	MYSURU	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	5:51:24 (25.6.2022)			LINE OPEN:LINE CLEAR AVAILED
949	25-Jun-22	MYSURU	220	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	11:28	12:45	1:17	LINE CLEAR AVAILED
950	25-Jun-22	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	5:43:00 (25.6.2022)			LINE OPEN:LINE CLEAR AVAILED
951	25-Jun-22	TUMKUR	66	ANCHEPALYA 220KV- KUNIGAL66	KUNIGAL	5:52	6:06	0:14	LINE FAULT
952	25-Jun-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:12	8:20	1:08	LINE CLEAR AVAILED
953	25-Jun-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	23:45(24.06.2022)	09:48(25.06.2022)	10:03	LINE CHARGED
954	25-Jun-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:01	10:03	0:02	LINE FAULT
955	25-Jun-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	5:25	5:55	0:30	LINE FAULT
956	25-Jun-22	TUMKUR	66	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	19:40	20:10	0:30	LINE FAULT
957	25-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:34	14:40	0:06	LINE FAULT
958	25-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:55	19:00	0:05	LINE FAULT
959	25-Jun-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	14:15	14:20	0:05	LINE FAULT
960	25-Jun-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	14:30	14:40	0:10	LINE FAULT
961	25-Jun-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	14:45	14:50	0:05	LINE FAULT
962	25-Jun-22	TUMKUR	66	TR1	CHITRADURGA_66	11:18	13:00	1:42	LINE CLEAR AVAILED
963	25-Jun-22	TUMKUR	66	TR1	CHITRADURGA_66	13:21	13:33	0:12	TRANSFORMER FAULT
964	25-Jun-22	TUMKUR	66	TR1	THIPPUR_66	13:25	13:30	0:05	TRANSFORMER FAULT
965	25-Jun-22	TUMKUR	66	TR2	SASALUHALLA_66	3:50	3:55	0:05	TRANSFORMER FAULT
966	25-Jun-22	TUMKUR	66	TR2	SASALUHALLA_66	14:15	14:25	0:10	TRANSFORMER FAULT
967	25-Jun-22	TUMKUR	66	TR2	SASALUHALLA_66	13:10	13:20	0:10	TRANSFORMER FAULT
968	25-Jun-22	TUMKUR	66	TR2	CHITRADURGA_66	13:28	13:30	0:02	TRANSFORMER FAULT
969	25-Jun-22	TUMKUR	220	DAVANGERE SRS- HONNALI	DAVANGERE_SRS_220	14:50(24.06.2022)			LINE OPEN: LINE FAULT
970	25-Jun-22	TUMKUR	220	TR1	DAVANGERE_SRS_220	23:45(24.06.2022)	10:21(25.06.2022)	10:36	TRANSFORMER CHARGED
971	26-Jun-22	BAGALKOT	110	110/11KV, HV2	MAMDAPUR(G)_110	13:11	16:56	3:45	LINE CLEAR AVAILED
972	26-Jun-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KAMBAGI_110	11:25	16:07	4:42	TRANSFORMER FAULT
973	26-Jun-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED HIREMASALI_110	7:05	7:35	0:30	HAND TRIPPED
974	26-Jun-22	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	13:07	16:10	3:03	LINE CLEAR AVAILED
975	26-Jun-22	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	17:10	17:36	0:26	TRANSFORMER FAULT
976	26-Jun-22	BAGALKOT	110	110/11KV,HV1	MK HUBLI_220	9:05	11:20	2:15	LINE CLEAR AVAILED
977	26-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
978	26-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED KULIGOD_110	12:16	12:31	0:15	HAND TRIPPED
979	26-Jun-22	BAGALKOT	110	110/11KV,HV3(HV2)	STATION NOT AFFECTED RATTIHALLI_110	15:35	15:41	0:06	TRANSFORMER FAULT
980	26-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
981	26-Jun-22	BAGALKOT	110	110/33KV,HV3	HANAGAL_110	10:25	10:45	0:20	TRANSFORMER FAULT
982	26-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVALIED
983	26-Jun-22	BAGALKOT	110	BELGAUM110-KANABARGI LAYOUT	BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVALIED
984	26-Jun-22	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA1	GHATAPRABHA_110	10:15	15:30	5:15	LINE CLEAR AVALIED
985	26-Jun-22	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_110	10:40	17:34	6:54	LINE CLEAR AVALIED
986	26-Jun-22	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	11:24	17:20	5:56	LINE CLEAR AVALIED
987	26-Jun-22	BAGALKOT	110	HAVERI-BYADAGI	HAVERI_220	11:25	17:19	5:54	LINE CLEAR AVALIED
988	26-Jun-22	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTED HUBLI_220	11:37 (14.06.2022)			LINE OPEN:LINE CLEAR AVALIED
989	26-Jun-22	BAGALKOT	110	HUBLI-RAMANAKOPPA	STATION NOT AFFECTED RAMANAKOPPA_110	4:32	8:44	4:12	LINE CLEAR AVALIED
990	26-Jun-22	BAGALKOT	110	HUKKERI_V S	HUKKERI_110 VS_110	5:50	6:08	0:18	LINE FAULT
991	26-Jun-22	BAGALKOT	110	MAHALINGAPUR220-RABAKAVI	RABAKAVI_110	10:32	18:46	8:14	LINE CLEAR AVALIED
992	26-Jun-22	BAGALKOT	110	MK HUBLI220-MK-HUBLI LINE 1	MK HUBLI_220	12:17	15:00	2:43	LINE CLEAR AVALIED
993	26-Jun-22	BAGALKOT	110	MKHUBLI-NARENDRA-2	STATION NOT AFFECTED MKHUBLI_220	14:47	14:52	0:05	LINE FAULT
994	26-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVALIED
995	26-Jun-22	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:12	18:30	8:18	NFBC ISSUED
996	26-Jun-22	BAGALKOT	110	SUVARNA SOUDA-MACHE	STATION NOT AFFECTED SUVARNA SOUDA_110	15:23	17:13	1:50	NFBC ISSUED
997	26-Jun-22	BAGALKOT	110	TAKKALAKI-THORVI	STATION NOT AFFECTED TAKKALAKI_110	13:50	13:51	0:01	LINE CLEAR AVALIED
998	26-Jun-22	BAGALKOT	110	TAKKALAKI-TIKOTA	STATION NOT AFFECTED TAKKALAKI_110	13:50	13:53	0:03	LINE CLEAR AVALIED
999	26-Jun-22	BAGALKOT	110	UCHAGOAN-UDYAMBAG	UCHAGOAN_110	6:57 (25.06.2022)	15:29 (26.06.2022)	8:32	LINE CHARGED
1000	26-Jun-22	BAGALKOT	110	VAJRAMATTI-SHIRAGUPPI	TOLAMATTI_110BISANAL_110 ,GIRISAGARA_110	14:55	15:05	0:10	HAND TRIPPED
1001	26-Jun-22	BAGALKOT	110	VAJRAMATTI-SHIRAGUPPI	TOLAMATTI_110BISANAL_110 ,GIRISAGARA_110	16:35	16:50	0:15	LINE FAULT
1002	26-Jun-22	BAGALKOT	220	CHIKKODI- KOLHAPUR1(TALANDAGI)	CHIKKODI_220	16:24	17:18	0:54	LINE FAULT
1003	26-Jun-22	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:05 (15.06.2022)			LINE OPEN:LINE CLEAR AVALIED
1004	26-Jun-22	BAGALKOT	220	SIRSI220-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVALIED
1005	26-Jun-22	BAGALKOT	220	SIRSI220-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1006	26-Jun-22	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR, BIEC	17:20	17:25	0:05	LOAD CHANGE OVER
1007	26-Jun-22	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, BIEC	6:54	7:03	0:09	LOAD CHANGE OVER
1008	26-Jun-22	BENGALURU	66	ARMY WELFARE ORGANISATION - KONDASPURA	ARMY WELFARE ORGANISATION	13:32	13:38	0:06	LOAD CHANGE OVER
1009	26-Jun-22	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	17:20	17:25	0:05	LOAD CHANGE OVER
1010	26-Jun-22	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	8:25	8:30	0:05	LOAD CHANGE OVER
1011	26-Jun-22	BENGALURU	66	CESSNA - SHOBHA APARTMENT	CESSNA	16:30	16:40	0:10	LOAD CHANGE OVER
1012	26-Jun-22	BENGALURU	66	CESSNA - VIKAS TECH PARK 220	CESSNA	8:30	8:42	0:12	LOAD CHANGE OVER
1013	26-Jun-22	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	6:30	6:35	0:05	LOAD CHANGE OVER
1014	26-Jun-22	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	16:20	16:24	0:04	LOAD CHANGE OVER
1015	26-Jun-22	BENGALURU	66	EPID 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, ALAMIC(EHT)	12:37	12:46	0:09	LINE FAULT
1016	26-Jun-22	BENGALURU	66	EXORA - CESSNA	EXORA	8:37	8:47	0:10	MAIN SUPPLY FAILURE
1017	26-Jun-22	BENGALURU	66	EXORA - CESSNA	EXORA	16:30	16:39	0:09	MAIN SUPPLY FAILURE
1018	26-Jun-22	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	17:00	17:02	0:02	LOAD CHANGE OVER
1019	26-Jun-22	BENGALURU	66	GOKULA - SRS PEENYA 1 & 2 220	GOKULA, BEL (EHT), HMT (EHT)	6:38	6:45	0:07	LOAD CHANGE OVER
1020	26-Jun-22	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI	10:50	11:19	0:29	LINE FAULT
1021	26-Jun-22	BENGALURU	66	HENNUR CROSS - HBR LAYOUT 220	HENNUR CROSS	11:26	11:29	0:03	LOAD CHANGE OVER
1022	26-Jun-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	12:45	12:48	0:03	LOAD CHANGE OVER
1023	26-Jun-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT), KONDASPURA	11:52	12:33	0:41	LINE CLEAR AVAILED
1024	26-Jun-22	BENGALURU	66	HV1	KADUGODI	14:00	14:02	0:02	LINE CLEAR AVAILED
1025	26-Jun-22	BENGALURU	66	HV1	KUMBALAGODU	9:13	16:55	7:42	LINE CLEAR AVAILED
1026	26-Jun-22	BENGALURU	66	HV1	NAGANATHPURA 220	19:53	20:10	0:17	TRANSFORMER FAULT
1027	26-Jun-22	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	10:18	10:25	0:07	LINE CLEAR AVAILED
1028	26-Jun-22	BENGALURU	66	HV1	BIDADI 220	12:56	13:28	0:32	LINE CLEAR AVAILED
1029	26-Jun-22	BENGALURU	66	HV1	CHAKAVELU	20:25	20:32	0:07	LINE CLEAR AVAILED
1030	26-Jun-22	BENGALURU	66	HV2	BG ROAD	4:15	4:19	0:04	TRANSFORMER FAULT
1031	26-Jun-22	BENGALURU	66	HV2	ELECTRONIC CITY	10:56	10:58	0:02	LINE CLEAR AVAILED
1032	26-Jun-22	BENGALURU	66	HV2	ISRO LAYOUT	11:26	11:28	0:02	LINE CLEAR AVAILED
1033	26-Jun-22	BENGALURU	66	HV2	KADUGODI	11:40	11:42	0:02	LINE CLEAR AVAILED
1034	26-Jun-22	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	13:07	13:09	0:02	LINE CLEAR AVAILED
1035	26-Jun-22	BENGALURU	66	HV2	AVERAHALLI	10:15	10:20	0:05	TRANSFORMER FAULT
1036	26-Jun-22	BENGALURU	66	HV2	BAGMANE WTP	13:27	13:30	0:02	LINE CLEAR AVAILED
1037	26-Jun-22	BENGALURU	66	HV2	PILLUMGUPA	13:14	13:20	0:06	LINE CLEAR AVAILED
1038	26-Jun-22	BENGALURU	66	HV3	KUMBALAGODU	9:13	16:55	7:42	LINE CLEAR AVAILED
1039	26-Jun-22	BENGALURU	66	IISc - HEBBALA 220	IISc	9:38	9:41	0:03	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1040	26-Jun-22	BENGALURU	66	IISc - NRS 220	IISc	22:15	22:20	0:05	LOAD CHANGE OVER
1041	26-Jun-22	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANISATION	ARMY WELFARE ORGANIZATION, ALAMIC(EHT)	12:37	12:48	0:11	LINE FAULT
1042	26-Jun-22	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, ALAMIC(EHT)	12:37	12:48	0:11	LINE FAULT
1043	26-Jun-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	6:15	6:30	0:15	LINE FAULT
1044	26-Jun-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	9:23	9:40	0:17	LINE FAULT
1045	26-Jun-22	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU	9:13	16:55	7:42	LINE CLEAR AVAILED
1046	26-Jun-22	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	17:12	17:16	0:04	LOAD CHANGE OVER
1047	26-Jun-22	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	7:09	7:14	0:05	LOAD CHANGE OVER
1048	26-Jun-22	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY	SHOBHA CITY	12:09	12:31	0:22	LINE CLEAR AVAILED
1049	26-Jun-22	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	6:25	6:32	0:07	LOAD CHANGE OVER
1050	26-Jun-22	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	17:24	17:34	0:10	LOAD CHANGE OVER
1051	26-Jun-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	17:18	17:23	0:05	LOAD CHANGE OVER
1052	26-Jun-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	7:13	7:18	0:05	LOAD CHANGE OVER
1053	26-Jun-22	BENGALURU	66	PERESANDRA - GOWRIBIDANUR 220	PERESANDRA	19:35	19:40	0:05	LOAD CHANGE OVER
1054	26-Jun-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	8:34	8:44	0:10	MAIN SUPPLY FAILURE
1055	26-Jun-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	15:50	16:00	0:10	MAIN SUPPLY FAILURE
1056	26-Jun-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, KIRLOSKAR(EHT)	10:58	11:10	0:12	LOAD CHANGE OVER
1057	26-Jun-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, KIRLOSKAR(EHT)	16:15	16:19	0:04	LOAD CHANGE OVER
1058	26-Jun-22	BENGALURU	66	SOMENAHALLI - AFTL SOLAR IPP	NO STATION AFFECTED	16:05	19:30	3:25	LINE CLEAR AVAILED
1059	26-Jun-22	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	16:05	18:50	2:45	LINE CLEAR AVAILED
1060	26-Jun-22	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	16:00	16:05	0:05	LINE CLEAR AVAILED
1061	26-Jun-22	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	15:13:00(18/06/2022)	16:58(26/06/2022)	169:05HRS	LINE CHARGED
1062	26-Jun-22	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	8:40	16:22	7:42	LINE CLEAR AVAILED
1063	26-Jun-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	9:28	9:50	0:22	LINE FAULT
1064	26-Jun-22	BENGALURU	66	YELAHANKA 220 - LINE3	WHEELS & AXLE(EHT), ESCORTS (EHT)YHT(9)	10:36	13:41	3:05	LINE CLEAR AVAILED
1065	26-Jun-22	GULBARGA	66	HV2	UJJANI_66	8:32	8:37	0:05	TRANSFORMER FAULT
1066	26-Jun-22	GULBARGA	66	HV2	UJJANI_66	8:55	9:05	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1067	26-Jun-22	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, GIRIYAPUR_66, MAGALA_66,SOVENHALLI_66,TU NGABHADRA_IPP	18:30	18:36	0:06	LINE FAULT
1068	26-Jun-22	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	4:10	4:15	0:05	LINE FAULT
1069	26-Jun-22	GULBARGA	66	UJJANI-SOKKE	UJJANI_66	10:15	10:30	0:15	MAIN SUPPLY FAILURE
1070	26-Jun-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	JAWALGERA_110	4:55	5:06	0:11	LINE FAULT
1071	26-Jun-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	2:37	2:44	0:07	LINE FAULT
1072	26-Jun-22	GULBARGA	110	HV1	HALAKUNDI_110	15:05	15:15	0:10	TRANSFORMER FAULT
1073	26-Jun-22	GULBARGA	110	HV2	MATAMARI_110	10:35	10:40	0:05	TRANSFORMER FAULT
1074	26-Jun-22	GULBARGA	110	HV2	DEODURGA_110	16:23	16:28	0:05	TRANSFORMER FAULT
1075	26-Jun-22	GULBARGA	110	HV3	GULBARGAWEST_110	10:00	13:33	3:33	LINE CLEAR AVAILED
1076	26-Jun-22	GULBARGA	110	JAWALGERA-ADVIAMARESHWAR	JAWALGERA_110	0:15	0:20	0:05	MAIN SUPPLY FAILURE
1077	26-Jun-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	21:15	21:25	0:10	LINE FAULT
1078	26-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	0:15	0:20	0:05	LINE FAULT
1079	26-Jun-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:48	20:01	0:13	LINE FAULT
1080	26-Jun-22	GULBARGA	110	NALWAR-CLN_IPP	NALWAR_110	1:40	2:00	0:20	LINE FAULT
1081	26-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
1082	26-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
1083	26-Jun-22	GULBARGA	220	LINGAPUR-JINDAL 2_IPP	LINGAPUR_220	8:13	18:25	10:12	LINE CLEAR AVAILED
1084	26-Jun-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
1085	26-Jun-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:10	11:25	0:15	LINE FAULT
1086	26-Jun-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:35	13:00	0:25	LINE FAULT
1087	26-Jun-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	14:00	20:20	6:20	LINE FAULT
1088	26-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1089	26-Jun-22	HASSAN	66	HV2	SINGAPURA_66	12:58	13:15	0:17	TRANSFORMER FAULT
1090	26-Jun-22	HASSAN	110	HV1	ALKOLA_110	10:55	17:20	6:25	LINE CLEAR AVAILED
1091	26-Jun-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1092	26-Jun-22	HASSAN	110	HV2	ALKOLA_110	10:12	17:23	7:11	LINE CLEAR AVAILED
1093	26-Jun-22	HASSAN	110	HV2	BARANGI_110	15:38	16:21	0:43	LINE CLEAR AVAILED
1094	26-Jun-22	HASSAN	110	HV2	ESSUR_110	15:14	16:00	0:46	LINE CLEAR AVAILED
1095	26-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1096	26-Jun-22	HASSAN	110	KADUR-NERELEKERE	KADUR_220	12:59	13:26	0:27	LINE FAULT
1097	26-Jun-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	6:53	11:56	5:03	LINE FAULT
1098	26-Jun-22	HASSAN	220	KEMAR-VARAHI	KEMAR_220	11:51	12:21	0:30	LINE FAULT
1099	26-Jun-22	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:52	12:22	0:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1100	26-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1101	26-Jun-22	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:25(25.06.2022)			LINE OPEN:LINE CLEAR AVAILED
1102	26-Jun-22	MYSURU	66	B G NAGARA-NAGAMANGALA	BGNAGARA_66 VADERALLI _66	10:40	11:15	0:35	LINE CLEAR AVAILED
1103	26-Jun-22	MYSURU	66	BETTADAPURA-K R NAGARA	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 KHBCOLONY_66 KR NAGARA_66 MIRLE _66	11:26	11:58	0:31	LINE FAULT
1104	26-Jun-22	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	19:02	19:11	0:09	LINE FAULT
1105	26-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN:LINE CLEAR AVAILED
1106	26-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1107	26-Jun-22	MYSURU	66	HEBBANI-MEGALAPURA	CHANDALLI_66 CHIDRAVALLI_66 BGPURA_66 GARGESHWARI_66 PARINAMIPURA_66 THUMBLA_66 TNARASIPURA_66 THALAKADU_66 VYASRAJPURA_66	6:58	7:07	0:09	LINE FAULT
1108	26-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1109	26-Jun-22	MYSURU	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	4:40:00 (25.6.2022)	1:32:00 PM (26.06.2022)	32:52:00	LINE CHARGED
1110	26-Jun-22	MYSURU	66	HOOTAGALLI-BARC-1	NO STATIONS EFFECTED	4:57:00 (25.6.2022)	1:25:00 PM (26.06.2022)	32:45:00	LINE CHARGED
1111	26-Jun-22	MYSURU	66	HOOTAGALLI-BARC-2	NO STATIONS EFFECTED	4:57:00 (25.6.2022)	1:25:00 PM (26.06.2022)	32:45:00	LINE CHARGED
1112	26-Jun-22	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	4:40:00 (25.6.2022)	1:33:00 PM (26.06.2022)	32:53:00	LINE CHARGED
1113	26-Jun-22	MYSURU	66	HV1	DEVANOORNGUDU_66	15:29	16:17	0:47	LINE CLEAR AVAILED
1114	26-Jun-22	MYSURU	66	HV1	KRPET_220	16:47	19:43	2:56	LINE CLEAR AVAILED
1115	26-Jun-22	MYSURU	66	HV1	YERALLI HAND POST_66	10:15	15:50	5:35	LINE CLEAR AVAILED
1116	26-Jun-22	MYSURU	66	HV1	YERALLI HAND POST_66	19:10	19:20	0:10	TRANSFORMER FAULT
1117	26-Jun-22	MYSURU	66	HV1	YERALLI HAND POST_66	19:35	19:45	0:10	TRANSFORMER FAULT
1118	26-Jun-22	MYSURU	66	HV2	DEVANOORNGUDU_66	15:29	16:17	0:47	LINE CLEAR AVAILED
1119	26-Jun-22	MYSURU	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	10:12	18:20	8:08	NFBC ISSUED
1120	26-Jun-22	MYSURU	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	10:19	17:30	7:11	NFBC ISSUED
1121	26-Jun-22	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	15:25			LINE OPEN:LINE CLEAR AVAILED
1122	26-Jun-22	MYSURU	66	KUSHALNAGARA-MYSORE1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 KHBCOLONY_66 KR NAGARA_66 MIRLE _66	11:27	11:32	0:05	LINE FAULT
1123	26-Jun-22	MYSURU	66	KUSHALNAGARA-MYSORE1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 KHBCOLONY_66 KR NAGARA_66 MIRLE _66	11:37	11:45	0:08	LINE FAULT
1124	26-Jun-22	MYSURU	66	KUSHALNAGARA-MYSORE1	MIRLE_66	14:51	14:56	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1125	26-Jun-22	MYSURU	66	MUGUR-THAYURU	NO STATIONS EFFECTED	9:40:00 (20.06.2022)			LINE OPEN:LINE CLEAR AVAILED
1126	26-Jun-22	MYSURU	66	SANTHESARGUR-KADAKOLA 1	ANTHARSANTHE_66 HDKOTE_66 YERALLI HAND POST_66	15:20	15:30	0:10	LINE FAULT
1127	26-Jun-22	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	14:39	14:45	0:06	LINE FAULT
1128	26-Jun-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1129	26-Jun-22	MYSURU	220	KADAKOLA-BASTIPURA 1	NO STATIONS EFFECTED	5:51:19 (25.6.2022)	12:19:00 PM (26.06.2022)	30:27:41	LINE CHARGED
1130	26-Jun-22	MYSURU	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	5:51:24 (25.6.2022)	12:31:00 PM (26.06.2022)	30:39:36	LINE CHARGED
1131	26-Jun-22	MYSURU	220	KADAKOLA-KOZHIKODE	NO STATIONS EFFECTED	5:43:00 (25.6.2022)	1:28:00 PM (26.06.2022)	31:45:00	LINE CHARGED
1132	26-Jun-22	MYSURU	220	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	7:01:00 AM (26.06.2022)			LINE OPEN:LINE CLEAR AVAILED
1133	26-Jun-22	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 1	CHITRADURGA_66 OLD MUSS,PANDARAHALLI_66,CHITRA HALLI_66,HDPURA_66,HOLALKER E_66,RAMGIRI_66	13:48	14:28	0:40	LINE FAULT
1134	26-Jun-22	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	P1&P2 CLUB	13:18	14:20	1:02	LINE FAULT
1135	26-Jun-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:30	10:35	0:05	LINE FAULT
1136	26-Jun-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	11:55	12:00	0:05	LINE FAULT
1137	26-Jun-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	13:55	14:00	0:05	LINE FAULT
1138	26-Jun-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	15:50	15:55	0:05	LINE FAULT
1139	26-Jun-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:35	15:45	0:10	LINE FAULT
1140	26-Jun-22	TUMKUR	66	TR1	KORA_66	10:30	19:10	8:40	LINE CLEAR AVAILED
1141	26-Jun-22	TUMKUR	66	TR1	JAVAGONDANAHALLI_66	6:40	6:50	0:10	TRANSFORMER FAULT
1142	26-Jun-22	TUMKUR	66	TR1 AND TR2	SASALUHALLA_66	5:05	6:10	1:05	TRANSFORMER FAULT
1143	26-Jun-22	TUMKUR	66	TR1 AND TR2	HANAGAL_66	11:20	11:25	0:05	LINE CLEAR AVAILED
1144	26-Jun-22	TUMKUR	66	TR2	MAVINAKATTE_66	12:05	13:10	1:05	LINE CLEAR AVAILED
1145	26-Jun-22	TUMKUR	220	DAVANGERE SRS- HONNALI	DAVANGERE_SRS_220	14:50			LINE OPEN: LINE FAULT
1146	26-Jun-22	TUMKUR	220	HONNALLI 220kV-220KV BENKIKERE	HONNALI_220	3:25	4:51	1:26	LINE FAULT
1147	26-Jun-22	TUMKUR	220	TR2	BENKIKERE_220	3:50	4:40	0:50	TRANSFORMER FAULT
1	27-Jun-22	BAGALKOT	110	110/11KV, HV1	MAMADAPUR(G)_110	8:02	10:00	1:58	TRANSFORMER FAULT
2	27-Jun-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJJRAMATTI_110	10:30	10:35	0:05	TRANSFORMER FAULT
3	27-Jun-22	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(G)_110	8:02	10:00	1:58	TRANSFORMER FAULT
4	27-Jun-22	BAGALKOT	110	110/11KV,HV1	HEBBALI_110	10:00	13:49	3:49	LINE CLEAR AVAILED
5	27-Jun-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	10:45	10:50	0:05	TRANSFORMER FAULT
6	27-Jun-22	BAGALKOT	110	110/11KV,HV1	KUDUCHI_220	9:18	9:22	0:04	TRANSFORMER FAULT
7	27-Jun-22	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	6:50	7:02	0:12	TRANSFORMER FAULT
8	27-Jun-22	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	10:06	19:49	9:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
9	27-Jun-22	BAGALKOT	110	110/11KV,HV1	VAJRAMATTI_110	10:29	10:35	0:06	TRANSFORMER FAULT
10	27-Jun-22	BAGALKOT	110	110/11KV,HV1	YADWAD_110	15:05	15:28	0:23	LINE CLEAR AVAILED
11	27-Jun-22	BAGALKOT	110	110/11KV,HV2	KALGATAGI_110	10:47	15:08	4:21	LINE CLEAR AVAILED
12	27-Jun-22	BAGALKOT	110	110/11KV,HV2	SHIRBUR_110	16:51	17:13	0:22	LINE CLEAR AVAILED
13	27-Jun-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
14	27-Jun-22	BAGALKOT	110	110/11KV,HV2	TODALBAGI_110	10:06	19:38	9:32	LINE CLEAR AVAILED
15	27-Jun-22	BAGALKOT	110	110/11KV,HV2(HV1)	NEER BUDIHAL_110	13:02	13:29	0:27	LINE CLEAR AVAILED
16	27-Jun-22	BAGALKOT	110	110/11KV,HV2(HV3)	GOPANKOPPA_110	9:47	10:21	0:34	TRANSFORMER FAULT
17	27-Jun-22	BAGALKOT	110	110/11KV,HV3(HV4)	GOPANKOPPA_110	11:08	11:50	0:42	TRANSFORMER FAULT
18	27-Jun-22	BAGALKOT	110	110/11KV,HV4	TODALBAGI_110	10:06	20:07	10:01	LINE CLEAR AVAILED
19	27-Jun-22	BAGALKOT	110	110/11KV,HV4(HV2)	GOPANKOPPA_110	11:08	11:55	0:47	TRANSFORMER FAULT
20	27-Jun-22	BAGALKOT	110	110/33KV, HV1	SOUNSHI_33 STATION NOT AFFECTED HUBLI_220	9:40	13:38	3:58	LINE CLEAR AVAILED
21	27-Jun-22	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
22	27-Jun-22	BAGALKOT	110	110/33KV,HV3	BIDARI_33 TODALBAGI_110	10:05	19:42	9:37	LINE CLEAR AVAILED
23	27-Jun-22	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED RANEENNUR_220	11:27	18:20	6:53	LINE CLEAR AVAILED
24	27-Jun-22	BAGALKOT	110	AIGALI-SAVALAGI	STATION NOT AFFECTED SAVALAGI_110	19:20	19:26	0:06	HAND TRIPPED
25	27-Jun-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
26	27-Jun-22	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR(B)_110	15:14	15:26	0:12	LINE CLEAR AVAILED
27	27-Jun-22	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR(B)_110	15:26	15:44	0:18	LINE CLEAR AVAILED
28	27-Jun-22	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR(B)_110	15:53	15:59	0:06	LINE CLEAR AVAILED
29	27-Jun-22	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR(B)_110	16:00	16:01	0:01	LINE CLEAR AVAILED
30	27-Jun-22	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR(B)_110	16:07	16:25	0:18	LINE CLEAR AVAILED
31	27-Jun-22	BAGALKOT	110	BELGAUM110-KANABARGI LAYOUT	BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED
32	27-Jun-22	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	7:42	7:50	0:08	LINE FAULT
33	27-Jun-22	BAGALKOT	110	HIREKERUR-RATTIHALLI	RATTIHALLI_110	10:45	18:23	7:38	LINE CLEAR AVAILED
34	27-Jun-22	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTED HUBLI_220	11:37 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
35	27-Jun-22	BAGALKOT	110	KAMBAGI-TODALBAGI(F2)	STATION NOT AFFECTED KAMBAGI_110	9:08	17:55	8:47	LINE CLEAR AVAILED
36	27-Jun-22	BAGALKOT	110	KAMBAGI-TODALBAGI(F2)	STATION NOT AFFECTED KAMBAGI_110	18:10	18:38	0:28	LINE CLEAR AVAILED
37	27-Jun-22	BAGALKOT	110	MAMADAPUR-GOKAK	MAMADAPUR(G)_110	7:41	9:53	2:12	LINE FAULT
38	27-Jun-22	BAGALKOT	110	MAMADPUR-SOUBHAGYA LAXMI	MAMADAPUR(G)_110	7:41	10:00	2:19	LINE FAULT
39	27-Jun-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
40	27-Jun-22	BAGALKOT	110	RANEBENNUR220-BYADAGI	STATION NOT AFFECTED RANEBENNUR_220	11:27	18:20	6:53	LINE CLEAR AVAILED
41	27-Jun-22	BAGALKOT	110	RANEBENNUR220-GUTTAL	STATION NOT AFFECTED RANEBENNUR_220	11:10	18:20	7:10	LINE CLEAR AVAILED
42	27-Jun-22	BAGALKOT	110	RANEBENNUR220-HIREKERUR	STATION NOT AFFECTED RANEBENNUR_220	10:45	18:20	7:35	LINE CLEAR AVAILED
43	27-Jun-22	BAGALKOT	110	RANEBENNUR220-HONNATTI	STATION NOT AFFECTED RANEBENNUR_220	11:10	18:20	7:10	LINE CLEAR AVAILED
44	27-Jun-22	BAGALKOT	110	SIRAGUPPI -BILAGI	BILAGI_110	22:30	22:35	0:05	LINE FAULT
45	27-Jun-22	BAGALKOT	110	TAKKALAKI-THORVI	STATION NOT AFFECTED TAKKALAKI_110	9:32	17:22	7:50	LINE CLEAR AVAILED
46	27-Jun-22	BAGALKOT	110	TAKKALAKI-TIKOTA	STATION NOT AFFECTED TAKKALAKI_110	17:24	17:26	0:02	LINE CLEAR AVAILED
47	27-Jun-22	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	1:41	14:48	13:07	LINE FAULT
48	27-Jun-22	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI_220	1:41	14:38	12:57	LINE FAULT
49	27-Jun-22	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:05 (15.06.2022)			LINE OPEN:LINE CLEAR AVAILED
50	27-Jun-22	BAGALKOT	220	SIRSI220-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVAILED
51	27-Jun-22	BAGALKOT	220	SIRSI220-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)			LINE OPEN:LINE CLEAR AVAILED
52	27-Jun-22	BAGALKOT	220	VAJJRAMATTI-KUDAGI-I (KUDAGI-II)	STATION NOT AFFECTED VAJJRAMATTI_220	23:04 (27.06.2022)			LINE OPEN:LINE CLEAR AVAILED
53	27-Jun-22	BENGALURU	66	ABBIGERE - MANYATHA TECH PARK 220	ABBIGERE, WELCASTE	0:50	1:02	0:12	LOAD CHANGE OVER
54	27-Jun-22	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	16:12	16:16	0:04	LOAD CHANGE OVER
55	27-Jun-22	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	11:24	11:28	0:04	LOAD CHANGE OVER
56	27-Jun-22	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	14:00	14:31	0:31	MAIN SUPPLY FAILURE
57	27-Jun-22	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	12:05(27/06/2022)			LINE OPEN: LINE FAULT
58	27-Jun-22	BENGALURU	66	BIDADI 220 - EPIPL (EHT)	EPIPL (EHT)	14:00	14:31	0:31	MAIN SUPPLY FAILURE
59	27-Jun-22	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	12:32	12:35	0:03	LOAD CHANGE OVER
60	27-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE	5:52	6:00	0:08	LINE FAULT
61	27-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE	11:10	11:22	0:12	LINE FAULT
62	27-Jun-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	THONDEBHAVI	16:02	16:33	0:31	LINE CLEAR AVAILED
63	27-Jun-22	BENGALURU	66	HENNUR CROSS - HBR LAYOUT 220	HENNUR CROSS	12:22	12:25	0:03	LOAD CHANGE OVER
64	27-Jun-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	21:10	21:13	0:03	LOAD CHANGE OVER
65	27-Jun-22	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	17:23	17:34	0:11	LOAD CHANGE OVER
66	27-Jun-22	BENGALURU	66	HSR LAYOUT 220 - ST JOHNS	ST JOHNS	17:15	17:19	0:04	LOAD CHANGE OVER
67	27-Jun-22	BENGALURU	66	HV1	AVANI	15:49	15:55	0:05	LINE CLEAR AVAILED
68	27-Jun-22	BENGALURU	66	HV1	BIDADI 220	12:05	13:13	1:08	MAIN SUPPLY FAILURE
69	27-Jun-22	BENGALURU	66	HV1	BIDADI 220	14:00	14:31	0:31	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
70	27-Jun-22	BENGALURU	66	HV1	BRIGADE GATEWAY	12:36	12:38	0:02	LINE CLEAR AVAILED
71	27-Jun-22	BENGALURU	66	HV1	HANUMANTHNAGARA	13:07	13:15	0:08	LINE CLEAR AVAILED
72	27-Jun-22	BENGALURU	66	HV1	JAYADEVA	12:37	12:39	0:02	LINE CLEAR AVAILED
73	27-Jun-22	BENGALURU	66	HV1	KODIHALLI HAROBELE	14:37	14:42	0:04	LINE CLEAR AVAILED
74	27-Jun-22	BENGALURU	66	HV1	PATHPALYA	12:02	12:12	0:09	LINE CLEAR AVAILED
75	27-Jun-22	BENGALURU	66	HV2	AREHALLI	11:24	11:28	0:04	LINE CLEAR AVAILED
76	27-Jun-22	BENGALURU	66	HV2	ATTUR YELAHANKA	6:50	7:00	0:10	TRANSFORMER FAULT
77	27-Jun-22	BENGALURU	66	HV2	BG ROAD	7:28	7:38	0:10	TRANSFORMER FAULT
78	27-Jun-22	BENGALURU	66	HV2	BIDADI 220	12:05	13:13	1:08	MAIN SUPPLY FAILURE
79	27-Jun-22	BENGALURU	66	HV2	BIDADI 220	14:00	14:31	0:31	MAIN SUPPLY FAILURE
80	27-Jun-22	BENGALURU	66	HV2	BRIGADE GATEWAY	10:14	10:16	0:02	LINE CLEAR AVAILED
81	27-Jun-22	BENGALURU	66	HV2	HANUMANTHNAGARA	14:02	14:05	0:03	LINE CLEAR AVAILED
82	27-Jun-22	BENGALURU	66	HV2	JAYADEVA	15:52	15:54	0:02	LINE CLEAR AVAILED
83	27-Jun-22	BENGALURU	66	HV2	KODIHALLI HAROBELE	13:16	13:20	0:03	LINE CLEAR AVAILED
84	27-Jun-22	BENGALURU	66	HV2	NANDAGUDI	12:33	13:22	0:48	LINE CLEAR AVAILED
85	27-Jun-22	BENGALURU	66	KUMBALAGODU 220 - HEJJALA	HEJJALA	14:00	14:26	0:26	LINE FAULT
86	27-Jun-22	BENGALURU	66	SRS PEENYA 220 - DG3	NO STATION AFFECTED	6:49	9:47	2:58	LINE FAULT
87	27-Jun-22	BENGALURU	220	HV2	BIDADI 220	12:05	13:13	1:08	TRANSFORMER FAULT
88	27-Jun-22	BENGALURU	400	DEVANAHALLI 400 - HOODY 400 2 O/G	NO STATION AFFECTED	11:50	18:42	6:52	MAIN SUPPLY FAILURE
89	27-Jun-22	BENGALURU	400	DEVANAHALLI 400 - PAVAGADA 400 2 I/C	NO STATION AFFECTED	12:13	13:08	0:55	MAIN SUPPLY FAILURE
90	27-Jun-22	BENGALURU	400	HOODY 400 - DEVANAHALLI 2 400	NO STATION AFFECTED	11:48	18:41	6:53	MAIN SUPPLY FAILURE
91	27-Jun-22	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	10:15	17:35	7:20	NFBC ISSUED
92	27-Jun-22	GULBARGA	66	HV1	ITTAGI_220	10:45	17:00	6:15	LINE CLEAR AVAILED
93	27-Jun-22	GULBARGA	66	HV2	ITTAGI_220	10:50	17:20	6:30	LINE CLEAR AVAILED
94	27-Jun-22	GULBARGA	66	HV2	UJJANI_66	9:15	9:20	0:05	TRANSFORMER FAULT
95	27-Jun-22	GULBARGA	66	HV2	UJJANI_66	10:00	10:05	0:05	TRANSFORMER FAULT
96	27-Jun-22	GULBARGA	66	HV2	UJJANI_66	13:30	13:35	0:05	TRANSFORMER FAULT
97	27-Jun-22	GULBARGA	66	ITTAGGI-BENNEHALLI	BENNEHALLI_66,KOTTUR_66	11:45	14:20	2:35	NFBC ISSUED
98	27-Jun-22	GULBARGA	66	UCCHANGIDURGA-PUNAMGATTA	UCCHANGIDURGA_66,BILCHOD_66	16:15	16:30	0:15	LINE FAULT
99	27-Jun-22	GULBARGA	66	UJJAINI-BILCHOD	UJJANI_66	12:20	12:25	0:05	LINE CLEAR AVAILED
100	27-Jun-22	GULBARGA	66	UJJANI-SOKKE	UJJANI_66	16:15	16:25	0:10	MAIN SUPPLY FAILURE
101	27-Jun-22	GULBARGA	66	UJJANI-SOKKE	UJJANI_66	2:30	2:40	0:10	MAIN SUPPLY FAILURE
102	27-Jun-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110,JAWALGERA_110	4:50	5:15	0:25	MAIN SUPPLY FAILURE
103	27-Jun-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110,JAWALGERA_110	23:36	23:39	0:03	MAIN SUPPLY FAILURE
104	27-Jun-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	1:06	1:12	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
105	27-Jun-22	GULBARGA	110	HV1	CHITAGUPPA_110	9:10	16:50	7:40	LINE CLEAR AVAILED
106	27-Jun-22	GULBARGA	110	HV1	CHITAGUPPA_110	17:20	18:05	0:45	LINE CLEAR AVAILED
107	27-Jun-22	GULBARGA	110	HV1	MUDDAPURA_110	11:18	15:50	4:32	LINE CLEAR AVAILED
108	27-Jun-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	23:36	23:40	0:04	LINE FAULT
109	27-Jun-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	22:28	22:33	0:05	LINE FAULT
110	27-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	2:25	2:45	0:20	LINE FAULT
111	27-Jun-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	19:52	20:10	0:18	LINE FAULT
112	27-Jun-22	GULBARGA	110	NALWAR-SHAHABAD(SHAHAPUR)2	JEWARGI_110,NALWAR_110	4:10	4:20	0:10	LINE FAULT
113	27-Jun-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
114	27-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
115	27-Jun-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
116	27-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	NALWAR_110,JEWARGI_110	4:14	4:19	0:05	LINE FAULT
117	27-Jun-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_220	4:14	4:19	0:05	LINE FAULT
118	27-Jun-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:58(26.06.2022)	00:04(27.06.2022)	0:06	LINE CHARGED
119	27-Jun-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:58(26.06.2022)	0:04(27.06.2022)	1:06	LINE CHARGED
120	27-Jun-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:59	0:04	0:05	LINE FAULT
121	27-Jun-22	GULBARGA	110	SHAHAPUR-YADGIR_110	YADGIR_110	21:39	21:50	0:11	LINE FAULT
122	27-Jun-22	GULBARGA	110	SHAHAPUR-YADGIR_110	YADGIR_110	23:02	23:07	0:05	LINE FAULT
123	27-Jun-22	GULBARGA	110	SHAHAPUR-YADGIR_110	YADGIR_110	23:22	23:26	0:04	LINE FAULT
124	27-Jun-22	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKHUNDA_110,YARADONA_110,BENNUR_110,BTPS_WATERWORKS,KAMPLI_110	9:53	12:53	3:00	LINE CLEAR AVAILED
125	27-Jun-22	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)	14:55(28.06.2022)	7678:37HRS	TRANSFORMER CHARGED
126	27-Jun-22	GULBARGA	220	ITTAGI-BMMISPAT_IPP	ITTAGI_220	7:51	18:56	11:05	NFBC ISSUED
127	27-Jun-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	1:22	1:30	0:08	LINE FAULT
128	27-Jun-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	8:48	20:58	12:10	LINE FAULT
129	27-Jun-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
130	27-Jun-22	HASSAN	66	HV2	BANDISHETTIHALLI_66	15:24	16:52	1:28	LINE CLEAR AVAILED
131	27-Jun-22	HASSAN	66	HV2	CHIKABOMMENAHALLI_66	21:08	21:18	0:10	TRANSFORMER FAULT
132	27-Jun-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
133	27-Jun-22	HASSAN	110	HV1	ARSIKERE_220	11:57	13:18	1:21	LINE CLEAR AVAILED
134	27-Jun-22	HASSAN	110	HV1	BARANGI_110	13:53	13:57	0:04	HAND TRIPPED
135	27-Jun-22	HASSAN	110	HV1	BARANGI_110	16:10	16:55	0:45	LINE CLEAR AVAILED
136	27-Jun-22	HASSAN	110	HV2	BANAVARA_110	22:40	22:45	0:05	MAIN SUPPLY FAILURE
137	27-Jun-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
138	27-Jun-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
139	27-Jun-22	HASSAN	110	HV3	PUTTUR_110	4:41	4:48	0:07	TRANSFORMER FAULT
140	27-Jun-22	HASSAN	110	HV3	PUTTUR_110	16:24	16:30	0:06	TRANSFORMER FAULT
141	27-Jun-22	HASSAN	110	HV3	PUTTUR_110	19:44	19:58	0:14	TRANSFORMER FAULT
142	27-Jun-22	HASSAN	110	KADUR-TNGL	KADUR_220	14:00	16:35	2:35	LINE CLEAR AVAILED
143	27-Jun-22	HASSAN	110	KEMAR-Manipal1	KEMAR_220	10:16	12:51	2:35	LINE CLEAR AVAILED
144	27-Jun-22	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:16	12:51	2:35	NFBC ISSUED
145	27-Jun-22	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	10:48	15:02	4:14	LINE CLEAR AVAILED
146	27-Jun-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	16:51	17:17	0:26	HAND TRIPPED
147	27-Jun-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:48	13:10	0:22	HAND TRIPPED
148	27-Jun-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	14:28	15:44	1:16	LINE CLEAR AVAILED
149	27-Jun-22	HASSAN	220	KEMAR-Varahi1	KEMAR_220	18:51	19:18	0:27	LINE FAULT
150	27-Jun-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:46	19:15	5:29	LINE FAULT
151	27-Jun-22	HASSAN	220	VARAHI-KEMAR1	gen_varahi	18:51	19:18	0:27	LINE FAULT
152	27-Jun-22	HASSAN	220	VARAHI-KEMAR2	gen_varahi	18:50	19:09	0:19	LINE FAULT
153	27-Jun-22	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	13:45	19:15	5:30	LINE FAULT
154	27-Jun-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
155	27-Jun-22	HASSAN	400	UPCL-HASSAN1	gen_upcl	23:25(25.06.2022)	7:10(27.06.2022)	31:44 hrs	LINE CHARGED
156	27-Jun-22	MYSURU	66	BILIKERE-GVGUDI	GVGUDI_66	10:19	12:29	2:09	LINE CLEAR AVAILED
157	27-Jun-22	MYSURU	66	BILIKERE-K R NAGARA	BILIKERE_66	10:23	12:29	2:06	LINE CLEAR AVAILED
158	27-Jun-22	MYSURU	66	BILIKERE-KHB	DMG_HALLI_66	10:20	12:30	2:10	LINE CLEAR AVAILED
159	27-Jun-22	MYSURU	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66	8:30	8:50	0:20	LINE FAULT
160	27-Jun-22	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN:LINE CLEAR AVAILED
161	27-Jun-22	MYSURU	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	12:00	17:35	5:35	LINE CLEAR AVAILED
162	27-Jun-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
163	27-Jun-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
164	27-Jun-22	MYSURU	66	HV 1	KOPPA_66	13:00	13:05	0:05	HAND TRIPPED
165	27-Jun-22	MYSURU	66	HV 2	KOPPA_66	13:09	13:24	0:15	HAND TRIPPED
166	27-Jun-22	MYSURU	66	HV1	BGNAGARA_66	13:45	14:20	0:35	LINE CLEAR AVAILED
167	27-Jun-22	MYSURU	66	HV1	GUDDENAHALLI_66	14:17	15:02	0:44	LINE CLEAR AVAILED
168	27-Jun-22	MYSURU	66	HV2	BGNAGARA_66	15:02	15:21	0:18	LINE CLEAR AVAILED
169	27-Jun-22	MYSURU	66	HV2	HARADANAHALLI_66	14:45	15:00	0:15	TRANSFORMER FAULT
170	27-Jun-22	MYSURU	66	HV2	SATHEGALA_66	14:15	14:35	0:20	LINE CLEAR AVAILED
171	27-Jun-22	MYSURU	66	KADAKOLA-MANTAGALLI	MANDAKALLI_66	7:12	7:29	0:17	LINE FAULT
172	27-Jun-22	MYSURU	66	KRNAGARA-BILIKERE	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 KHB COLONY_66	7:20	7:30	0:10	LINE FAULT
173	27-Jun-22	MYSURU	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	15:25			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
174	27-Jun-22	MYSURU	66	KUSHALNAGARA-MERCERA-1	NO STATIONS EFFECTED	11:33	11:46	0:13	HAND TRIPPED
175	27-Jun-22	MYSURU	66	MADHUVANAHALLI-HANNUR-2	NO STATIONS EFFECTED	6:56	7:01	0:05	LINE FAULT
176	27-Jun-22	MYSURU	66	MUGUR-THAYURU	NO STATIONS EFFECTED	9:40:00 (20.06.2022)			LINE OPEN:LINE CLEAR AVAILED
177	27-Jun-22	MYSURU	66	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	11:50	17:25	5:35	LINE CLEAR AVAILED
178	27-Jun-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
179	27-Jun-22	MYSURU	220	TUBINKERE -KOTIPURA-1	NO STATIONS EFFECTED	10:40	14:56	4:16	LINE CLEAR AVAILED
180	27-Jun-22	MYSURU	220	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	7:01:00 AM (26.06.2022)			LINE OPEN:LINE CLEAR AVAILED
181	27-Jun-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:20	16:30	9:10	LINE CLEAR AVAILED
182	27-Jun-22	TUMKUR	66	GUTTUR 220KV- HALASBALU_66	GUTTUR_220	15:00	15:25	0:25	LINE FAULT
183	27-Jun-22	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	10:27	16:00	5:33	LINE CLEAR AVAILED
184	27-Jun-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	11:50	12:00	0:10	LINE FAULT
185	27-Jun-22	TUMKUR	66	SASALUHALLA66- CHIKKAJAJUR66(SRS DAVANAGERE)	SASALUHALLA_66	19:50	19:55	0:05	LINE FAULT
186	27-Jun-22	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	12:10	12:35	0:25	LINE CLEAR AVAILED
187	27-Jun-22	TUMKUR	66	TR1	HIRIYUR_220	17:35	18:30	0:55	LINE CLEAR AVAILED
188	27-Jun-22	TUMKUR	66	TR1 AND TR2	HOSAKRE_66	7:10	16:10	9:00	MAIN SUPPLY FAILURE
189	27-Jun-22	TUMKUR	66	TR1 AND TR2	KADDAJI_66	12:00	12:30	0:30	LINE CLEAR AVAILED
190	27-Jun-22	TUMKUR	66	TR2	CHANNAGIRI_66	3:30	3:45	0:15	TRANSFORMER FAULT
191	27-Jun-22	TUMKUR	66	TR2	PATTANAYAKANAHALLI_66	7:50	8:40	0:50	LINE CLEAR AVAILED
192	27-Jun-22	TUMKUR	220	DAVANAGERE SRS- HONNALI	DAVANAGERE_SRS_220	14:50(24.06.2022)	14:23(26.06.2022)	47:33	LINE CHARGED
193	27-Jun-22	TUMKUR	220	TR1	HIRIYUR_220	17:35	18:35	1:00	LINE CLEAR AVAILED