

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:11.02.2020 TO 17.02.2020**

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	11-Feb-2020	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	15:26	16:51	1:25	LINE CLEAR AVAILED
2	11-Feb-2020	BAGALKOT	220	HARTI 1-BIDNAL	BIDNAL_220	13:25	19:08	5:43	LINE FAULT
3	11-Feb-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	12:32	13:39	1:07	LINE CLEAR AVAILED
4	11-Feb-2020	BAGALKOT	110	110/11KV,HV1	BETAGERI_110	10:11	17:11	7:00	LINE CLEAR AVAILED
5	11-Feb-2020	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	9:41	23:59	14:18	LINE CLEAR AVAILED
6	11-Feb-2020	BAGALKOT	220	220/110KV,HV2	AMBEWADI_220	17:56	19:43	1:47	LINE CLEAR AVAILED
7	11-Feb-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	0:00	10:35	10:35	LINE CLEAR AVAILED
8	11-Feb-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	11:32	13:10	1:38	LINE CLEAR AVAILED
9	11-Feb-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	16:49	18:43	1:54	LINE FAULT
10	11-Feb-2020	BAGALKOT	110	HAVERI220-TILUVALLI	TILUVALLI_110	17:17	18:25	1:08	LINE CLEAR AVAILED
11	11-Feb-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	11:11	11:30	0:19	LINE CLEAR AVAILED
12	11-Feb-2020	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	10:56	15:59	5:03	LINE CLEAR AVAILED
13	11-Feb-2020	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	16:35	18:45	2:10	LINE CLEAR AVAILED
14	11-Feb-2020	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	17:38	18:22	0:44	HAND TRIPPED
15	11-Feb-2020	BAGALKOT	110	110/11KV,HV2	RATTIHALLI_110	12:13	12:22	0:09	TRANSFORMER FAULT
16	11-Feb-2020	BAGALKOT	110	RANEENNUR220-(AREMALLAPUR)HONNATTI	HONNATTI_110	22:39	22:50	0:11	LINE FAULT
17	11-Feb-2020	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	9:25	13:08	3:43	LINE CLEAR AVAILED
18	11-Feb-2020	BAGALKOT	110	110/11KV,HV2	PH COMPOUND_110	0:00	20:44	20:44	LINE CLEAR AVAILED
19	11-Feb-2020	BAGALKOT	110	RAMANKOPPA-MUNDAGOD	MUNDAGOD_110	11:43	12:58	1:15	LINE CLEAR AVAILED
20	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-RABAKAVI&ITNAL	RABAKAVI_110&ITNAL_110	10:23	11:30	1:07	LINE CLEAR AVAILED
21	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-RABAKAVI&ITNAL	RABAKAVI_110&ITNAL_110	15:05	15:13	0:08	HAND TRIPPED
22	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	10:54	11:13	0:19	LINE FAULT
23	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	15:06	15:10	0:04	LINE FAULT
24	11-Feb-2020	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220	10:30	15:00	4:30	LINE CLEAR AVAILED
25	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-ITNAL	ITNAL_110	11:42	12:04	0:22	HAND TRIPPED
26	11-Feb-2020	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	15:26	16:51	1:25	LINE CLEAR AVAILED
27	11-Feb-2020	BAGALKOT	220	HARTI 1-BIDNAL	BIDNAL_220	13:25	19:08	5:43	LINE FAULT
28	11-Feb-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	12:32	13:39	1:07	LINE CLEAR AVAILED
29	11-Feb-2020	BAGALKOT	110	110/11KV,HV1	BETAGERI_110	10:11	17:11	7:00	LINE CLEAR AVAILED
30	11-Feb-2020	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	9:41	23:59	14:18	LINE CLEAR AVAILED
31	11-Feb-2020	BAGALKOT	220	220/110KV,HV2	AMBEWADI_220	17:56	19:43	1:47	LINE CLEAR AVAILED
32	11-Feb-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	0:00	10:35	10:35	LINE CLEAR AVAILED
33	11-Feb-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	11:32	13:10	1:38	LINE CLEAR AVAILED
34	11-Feb-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	16:49	18:43	1:54	LINE FAULT
35	11-Feb-2020	BAGALKOT	110	HAVERI220-TILUVALLI	TILUVALLI_110	17:17	18:25	1:08	LINE CLEAR AVAILED
36	11-Feb-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	11:11	11:30	0:19	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
37	11-Feb-2020	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	10:56	15:59	5:03	LINE CLEAR AVAILED
38	11-Feb-2020	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	16:35	18:45	2:10	LINE CLEAR AVAILED
39	11-Feb-2020	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	17:38	18:22	0:44	HAND TRIPPED
40	11-Feb-2020	BAGALKOT	110	110/11KV,HV2	RATTIHALLI_110	12:13	12:22	0:09	TRANSFORMER FAULT
41	11-Feb-2020	BAGALKOT	110	RANEBENNUR220-(AREMALLAPUR)HONNATTI	HONNATTI_110	22:39	22:50	0:11	LINE FAULT
42	11-Feb-2020	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	9:25	13:08	3:43	LINE CLEAR AVAILED
43	11-Feb-2020	BAGALKOT	110	110/11KV,HV2	PH COMPOUND_110	0:00	20:44	20:44	LINE CLEAR AVAILED
44	11-Feb-2020	BAGALKOT	110	RAMANKOPPA-MUNDAGOD	MUNDAGOD_110	11:43	12:58	1:15	LINE CLEAR AVAILED
45	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-RABAKAVI&ITNAL	RABAKAVI_110&ITNAL_110	10:23	11:30	1:07	LINE CLEAR AVAILED
46	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-RABAKAVI&ITNAL	RABAKAVI_110&ITNAL_110	15:05	15:13	0:08	HAND TRIPPED
47	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	10:54	11:13	0:19	LINE FAULT
48	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	15:06	15:10	0:04	LINE FAULT
49	11-Feb-2020	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220	10:30	15:00	4:30	LINE CLEAR AVAILED
50	11-Feb-2020	BAGALKOT	110	MAHALINGAPUR-ITNAL	ITNAL_110	11:42	12:04	0:22	HAND TRIPPED
51	11-Feb-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	8:35	9:58	1:23	LINE CLEAR AVAILED
52	11-Feb-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:30	18:33	1:03	LINE CLEAR AVAILED
53	11-Feb-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HOSKOTE 220 (EHT), SHIVANAHALLI,	6:46	7:16	0:30	LINE FAULT
54	11-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	7:32	7:41	0:09	LINE FAULT
55	11-Feb-2020	BENGALURU	66	HV2	KODIHALLI	8:11	8:21	0:10	TRANSFORMER FAULT
56	11-Feb-2020	BENGALURU	220	HV1	NRS 220	8:34	8:55	0:21	TRANSFORMER FAULT
57	11-Feb-2020	BENGALURU	220	HV2	NRS 220	8:34	9:16	0:42	TRANSFORMER FAULT
58	11-Feb-2020	BENGALURU	66	HV1	REMCO	7:27	7:45	0:18	LOAD CHANGE OVER
59	11-Feb-2020	BENGALURU	66	HV1	REMCO	12:09	12:30	0:21	MAIN SUPPLY FAILURE
60	11-Feb-2020	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT),R R NAGAR,REMCO	12:09	12:24	0:15	LINE FAULT
61	11-Feb-2020	GULBARGA	220	HV1	LINGASUGUR_220	16:15	18:50	2:35	LINE CLEAR AVAILED
62	11-Feb-2020	GULBARGA	220	HV1	SEDAM_220	14:45	18:00	3:15	LINE CLEAR AVAILED
63	11-Feb-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	1:09	23:59	22:50	LINE FAULT
64	11-Feb-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110,UGARSUGAR	2:02	2:10	0:08	LINE FAULT
65	11-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	_IPP	3:14	3:24	0:10	LINE FAULT
66	11-Feb-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	5:46	5:52	0:06	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
67	11-Feb-2020	GULBARGA	110	SHAHAPUR-RAICHUR1&2	GABUR_110,DEODURGA_110 ,GOOGLE_110	19:43	21:32	1:49	NFBC ISSUED
68	11-Feb-2020	GULBARGA	110	HV1,HV2	LINGASUGUR_220	14:20	14:30	0:10	TRANSFORMER FAULT
69	11-Feb-2020	GULBARGA	110	HV1,HV2	LINGASUGUR_220	15:58	16:10	0:12	TRANSFORMER FAULT
70	11-Feb-2020	GULBARGA	110	HV1,HV2	LINGASUGUR_220	18:00	18:05	0:05	TRANSFORMER FAULT
71	11-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	8:35	8:46	0:11	LINE FAULT
72	11-Feb-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:41	13:26	3:45	NFBC ISSUED
73	11-Feb-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	9:41	13:26	3:45	LINE CLEAR AVAILED
74	11-Feb-2020	HASSAN	110	KEMAR-Manipal1	KEMAR_220	9:23	16:06	6:43	NFBC ISSUED
75	11-Feb-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	9:23	16:06	6:43	NFBC ISSUED
76	11-Feb-2020	HASSAN	110	HV3	MRSMSG_220	12:34	14:51	2:17	LINE CLEAR AVAILED
77	11-Feb-2020	HASSAN	110	HV4	MRSMSG_220	10:09	12:33	2:24	LINE CLEAR AVAILED
78	11-Feb-2020	HASSAN	110	HV1	HALADY_110	11:37	14:31	2:54	LINE CLEAR AVAILED
79	11-Feb-2020	HASSAN	110	HV2	HALADY_110	9:57	16:48	6:51	LINE CLEAR AVAILED
80	11-Feb-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:08	15:22	5:14	LINE CLEAR AVAILED
81	11-Feb-2020	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	9:16	16:23	7:07	LINE CLEAR AVAILED
82	11-Feb-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	9:19	17:22	8:03	LINE CLEAR AVAILED
83	11-Feb-2020	HASSAN	110	HV1	MANIPAL_110	9:23	17:23	8:00	LINE CLEAR AVAILED
84	11-Feb-2020	HASSAN	110	HV2	MANIPAL_110	9:21	15:55	6:34	LINE CLEAR AVAILED
85	11-Feb-2020	HASSAN	110	HV3	MANIPAL_110	9:21	17:25	8:04	LINE CLEAR AVAILED
86	11-Feb-2020	HASSAN	110	HV4	MANIPAL_110	9:21	17:24	8:03	LINE CLEAR AVAILED
87	11-Feb-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	9:23	16:12	6:49	LINE CLEAR AVAILED
88	11-Feb-2020	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	9:16	17:24	8:08	MAIN SUPPLY FAILURE
89	11-Feb-2020	HASSAN	110	JOG-NK1	JOG_110	17:34	18:24	0:50	HAND TRIPPED
90	11-Feb-2020	HASSAN	110	JOG-NK2	JOG_110	17:34	18:24	0:50	HAND TRIPPED
91	11-Feb-2020	HASSAN	66	HASSN220-MALLALI	HASSAN-220	11:56	14:04	2:08	LINE CLEAR AVAILED
92	11-Feb-2020	HASSAN	66	HV1	MALLAPURA_66	9:23	11:45	2:22	LINE CLEAR AVAILED
93	11-Feb-2020	HASSAN	66	HV1	SHRAVANABELAGOLA_66	14:35	14:41	0:06	TRANSFORMER FAULT
94	11-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	14:35	14:41	0:06	TRANSFORMER FAULT
95	11-Feb-2020	HASSAN	66	LV3	MRSMSG_220	12:34	14:52	2:18	LINE CLEAR AVAILED
96	11-Feb-2020	HASSAN	66	LV4	MRSMSG_220	10:09	12:33	2:24	LINE CLEAR AVAILED
97	11-Feb-2020	MYSORE	66	HV2	CHANDAKAVADI-	11:56	13:00	1:03	LINE CLEAR AVAILED
98	11-Feb-2020	MYSORE	66	HV2	METAGALLY_66	10:53	11:59	1:05	LINE CLEAR AVAILED
99	11-Feb-2020	MYSORE	66	HV2	SFCSHIVA_66	9:32	23:59	14:26	LINE CLEAR AVAILED
100	11-Feb-2020	TUMKUR	66	TR-2	AVAREGERE_66	15:48	16:04	0:15	MAIN SUPPLY FAILURE
101	11-Feb-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	10:05	17:27	7:21	MAIN SUPPLY FAILURE
102	11-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	6:02	6:06	0:03	TRANSFORMER FAULT
103	11-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	10:05	17:31	7:26	MAIN SUPPLY FAILURE
104	11-Feb-2020	TUMKUR	66	CHANNAGIRI- (CHANNAGIRI(LINGDHLI)	CHANNAGIRI_66	19:24	19:27	0:03	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
105	11-Feb-2020	TUMKUR	66	CHANNAGIRI- (CHANNAGIRI(LINGDHLI))	CHANNAGIRI_66	10:09	17:26	7:17	MAIN SUPPLY FAILURE
106	11-Feb-2020	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	16:43	16:53	0:10	LINE FAULT
107	11-Feb-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	8:22	9:12	0:50	LINE FAULT
108	11-Feb-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:01	17:23	7:21	LINE CLEAR AVAILED
109	11-Feb-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	10:01	17:24	7:22	LINE CLEAR AVAILED
110	11-Feb-2020	TUMKUR	66	TR-2	HOSADURGA_66	10:47	10:53	0:06	TRANSFORMER FAULT
111	11-Feb-2020	TUMKUR	66	TR-2	MADHUGIRI_220	11:24	11:25	0:01	LINE CLEAR AVAILED
112	11-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	16:20	16:27	0:06	LINE FAULT
113	11-Feb-2020	TUMKUR	66	PANDARAHALLI- SPML_WIND _IPP_66	SPML_WIND_IPP_66	15:27	19:43	4:16	LINE CLEAR AVAILED
114	11-Feb-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	12:59	14:15	1:16	LINE CLEAR AVAILED
115	11-Feb-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	8:30	8:32	0:01	TRANSFORMER FAULT
116	11-Feb-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	9:12	9:13	0:01	MAIN SUPPLY FAILURE
117	11-Feb-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	17:26	17:27	0:01	LINE CLEAR AVAILED
118	11-Feb-2020	TUMKUR	66	TAVAREKERE (C)- GOPPENAHALLI	TAVAREKERE(C)_66	17:30	17:45	0:14	LINE CLEAR AVAILED
119	12-Feb-2020	BAGALKOT	110	110/11KV, HV2	GOPPANAKOPPA_110	11:09	11:29	0:20	LINE CLEAR AVAILED
120	12-Feb-2020	BAGALKOT	110	110/11KV, HV2	HIDIKAL_110	12:00	12:36	0:36	TRANSFORMER FAULT
121	12-Feb-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	12:06	23:59	11:53	LINE CLEAR AVAILED
122	12-Feb-2020	BAGALKOT	220	HARTI1-BIDNAL	BIDNAL_220	10:36	17:05	6:29	LINE CLEAR AVAILED
123	12-Feb-2020	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	8:07	8:11	0:04	TRANSFORMER FAULT
124	12-Feb-2020	BAGALKOT	110	ITANAL-RAIBAG1&2	ITANAL_110	16:16	17:55	1:39	LINE CLEAR AVAILED
125	12-Feb-2020	BAGALKOT	220	JK CEMENT -VAJRAMATTI	VAJRAMATTI_220	11:24	19:34	8:10	LINE CLEAR AVAILED
126	12-Feb-2020	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	11:25	16:35	5:10	LINE CLEAR AVAILED
127	12-Feb-2020	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	12:22	16:10	3:48	LINE CLEAR AVAILED
128	12-Feb-2020	BAGALKOT	110	110/11KV,HV2	SAVALGI_110	11:19	12:14	0:55	LINE CLEAR AVAILED
129	12-Feb-2020	BAGALKOT	110	110/11KV,HV3	RATTIHALLI_110	22:44	22:50	0:06	TRANSFORMER FAULT
130	12-Feb-2020	BAGALKOT	110	110/11KV,HV2	PH COMPOUND_110	10:00	17:08	7:08	LINE CLEAR AVAILED
131	12-Feb-2020	BAGALKOT	110	110/11KV,HV1	PH COMPOUND_110	10:46	16:30	5:44	LINE CLEAR AVAILED
132	12-Feb-2020	BAGALKOT	110	110/11KV,HV2	PG HUNSHYAL_110	12:02	12:28	0:26	LINE CLEAR AVAILED
133	12-Feb-2020	BAGALKOT	110	110/11KV,HV2	NANADI_110	12:42	13:39	0:57	LINE CLEAR AVAILED
134	12-Feb-2020	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	11:09	11:30	0:21	TRANSFORMER FAULT
135	12-Feb-2020	BAGALKOT	110	110/11KV,HV1	MAREGUDDI_110	10:11	11:55	1:44	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
136	12-Feb-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:39	19:00	0:20	LINE FAULT
137	12-Feb-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	0:00	7:22	7:22	LINE FAULT
138	12-Feb-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	7:22	17:55	10:33	LINE CLEAR AVAILED
139	12-Feb-2020	GULBARGA	220	LINGAPUR-JVSL	LINGAPUR_220	9:32	16:24	6:52	NFBC ISSUED
140	12-Feb-2020	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	20:50	21:19	0:29	LINE FAULT
141	12-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	17:04	17:21	0:17	LINE FAULT
142	12-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	2:50	2:58	0:08	LINE FAULT
143	12-Feb-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	0:02	0:12	0:10	LINE FAULT
144	12-Feb-2020	GULBARGA	110	HUMNBAD_MANNA-EH-HALLI	MANNA-EH-HALLI_110	17:02	17:12	0:10	LINE FAULT
145	12-Feb-2020	GULBARGA	110	HV3	KEMBHAVI_110	6:25	6:40	0:15	TRANSFORMER FAULT
146	12-Feb-2020	GULBARGA	110	HV3	KEMBHAVI_110	11:25	11:35	0:10	LINE CLEAR AVAILED
147	12-Feb-2020	GULBARGA	110	HV3	KEMBHAVI_110	11:40	12:15	0:35	TRANSFORMER FAULT
148	12-Feb-2020	GULBARGA	66	ITTIGI-KOGALI	KOGALI_66	21:10	21:20	0:10	LINE FAULT
149	12-Feb-2020	GULBARGA	66	HV1	KOGALI_66	11:00	11:35	0:35	LINE CLEAR AVAILED
150	12-Feb-2020	GULBARGA	66	HV2	KOGALI_66	11:00	11:35	0:35	LINE CLEAR AVAILED
151	12-Feb-2020	GULBARGA	66	KUDALIGI-CHORNOOR	CHORNOOR_66	21:15	23:15	2:00	LINE FAULT
152	12-Feb-2020	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	17:45	18:10	0:25	LINE CLEAR AVAILED
153	12-Feb-2020	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	15:31	17:21	1:50	LINE FAULT
154	12-Feb-2020	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	11:03	11:46	0:43	LINE CLEAR AVAILED
155	12-Feb-2020	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	11:54	11:57	0:03	LINE CLEAR AVAILED
156	12-Feb-2020	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	12:01	16:20	4:19	LINE CLEAR AVAILED
157	12-Feb-2020	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	16:25	16:30	0:05	LINE CLEAR AVAILED
158	12-Feb-2020	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	16:33	16:48	0:15	LINE CLEAR AVAILED
159	12-Feb-2020	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	13:37	17:26	3:49	LINE FAULT
160	12-Feb-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	11:04	16:47	5:43	LINE CLEAR AVAILED
161	12-Feb-2020	HASSAN	110	HV3	KAVOOR_220	13:08	14:11	1:03	LINE CLEAR AVAILED
162	12-Feb-2020	HASSAN	110	HV2	ARASIKERE_110	15:59	16:23	0:24	LINE CLEAR AVAILED
163	12-Feb-2020	HASSAN	110	HV2	BARANGI_110	14:55	15:25	0:30	LINE CLEAR AVAILED
164	12-Feb-2020	HASSAN	110	JOG-NK1	JOG_110	12:21	16:15	3:54	LINE CLEAR AVAILED
165	12-Feb-2020	HASSAN	110	JOG-NK2	JOG_110	12:21	16:11	3:50	LINE CLEAR AVAILED
166	12-Feb-2020	HASSAN	66	CHANNARA-SHETTIHALLY	CHANNARAYAPATNA_66	16:04	18:03	1:59	LINE CLEAR AVAILED
167	12-Feb-2020	HASSAN	66	DIDIGA-CRPATNA	DIDIGA_66	15:04	15:27	0:23	LINE CLEAR AVAILED
168	12-Feb-2020	HASSAN	66	HV1	DIDIGA_66	15:04	15:28	0:24	LINE CLEAR AVAILED
169	12-Feb-2020	HASSAN	66	HV1	HASSAN_66	10:00	14:43	4:43	LINE CLEAR AVAILED
170	12-Feb-2020	HASSAN	66	HV2	HASSAN_66	15:40	17:36	1:56	LINE CLEAR AVAILED
171	12-Feb-2020	HASSAN	66	HV2	MATTNAVILE_66	16:25	17:34	1:09	LINE CLEAR AVAILED
172	12-Feb-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	15:12	16:35	1:23	LINE CLEAR AVAILED
173	12-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	12:58	13:01	0:03	LINE CLEAR AVAILED
174	12-Feb-2020	MYSORE	66	HALAGURU-TK HALLI	HALAGUR_66	10:45	11:10	0:24	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
175	12-Feb-2020	MYSORE	66	HOOTAGALLI-DATTAGALLI	DATTAGALLY_66	10:20	17:37	7:16	NFBC ISSUED
176	12-Feb-2020	MYSORE	66	KUSHALNAGARA 220-MYSORE 1	MIRLE_66	6:12	6:32	0:20	LINE FAULT
177	12-Feb-2020	MYSORE	220	HV1	MADHUVANAHALLI_220	12:07	15:20	3:12	LINE CLEAR AVAILED
178	12-Feb-2020	MYSORE	66	RK NAGARA-DATTAGALLI	DATTAGALLY_66	10:27	18:05	7:38	NFBC ISSUED
179	12-Feb-2020	TUMKUR	110	TR-1	TURUVEKERE_110	11:46	11:56	0:10	TRANSFORMER FAULT
180	12-Feb-2020	TUMKUR	110	TR-2	TURUVEKERE_110	11:46	11:52	0:06	TRANSFORMER FAULT
181	12-Feb-2020	TUMKUR	110	TR-2	SAMPIGE_110	12:45	13:07	0:21	LINE CLEAR AVAILED
182	12-Feb-2020	TUMKUR	110	TR-1	SHETYKERE_110	11:40	13:52	2:11	LINE CLEAR AVAILED
183	12-Feb-2020	TUMKUR	110	TR-1	SHETYKERE_110	14:36	14:58	0:22	LINE CLEAR AVAILED
184	12-Feb-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	17:47	17:56	0:09	LINE FAULT
185	12-Feb-2020	TUMKUR	66	BASAVAPATNA-SRS DAVANAGERE	BASAVAPATNA_66	13:22	15:19	1:57	LINE CLEAR AVAILED
186	12-Feb-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	14:34	14:38	0:04	TRANSFORMER FAULT
187	12-Feb-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	11:10	12:09	0:58	LINE CLEAR AVAILED
188	12-Feb-2020	TUMKUR	66	TR-2	HALUVAGALU_66	10:57	11:02	0:04	TRANSFORMER FAULT
189	12-Feb-2020	TUMKUR	66	TR-2	HINDASGHATTA_66	7:27	13:24	5:57	LINE CLEAR AVAILED
190	12-Feb-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	7:52	8:08	0:15	MAIN SUPPLY FAILURE
191	12-Feb-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	12:20	12:36	0:16	MAIN SUPPLY FAILURE
192	12-Feb-2020	TUMKUR	66	KATTIGE- BEDRUGADDE	KATTIGE_66 RENEW WIND	13:51	15:51	1:59	LINE CLEAR AVAILED
193	12-Feb-2020	TUMKUR	66	KATTIGE- RENEW WIND IPP	ENERGY IPP_66 PANCHANAHALLI_66,	13:51	15:51	2:00	LINE CLEAR AVAILED
194	12-Feb-2020	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	8:08	8:43	0:35	MAIN SUPPLY FAILURE
195	12-Feb-2020	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66	10:00	16:25	6:24	MAIN SUPPLY FAILURE
196	12-Feb-2020	TUMKUR	66	TR-2	MATHOD_66	11:30	12:07	0:37	MAIN SUPPLY FAILURE
197	12-Feb-2020	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	11:30	12:08	0:37	MAIN SUPPLY FAILURE
198	12-Feb-2020	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	14:18	14:23	0:04	HAND TRIPPED
199	13-Feb-2020	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	0:00	17:47	17:47	LINE CLEAR AVAILED
200	13-Feb-2020	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	0:00	18:09	18:09	LINE CLEAR AVAILED
201	13-Feb-2020	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	0:00	18:10	18:10	LINE CLEAR AVAILED
202	13-Feb-2020	BAGALKOT	110	110/11KV,HV 1	ANAND NAGAR_110	11:04	11:58	0:54	HAND TRIPPED
203	13-Feb-2020	BAGALKOT	110	110/11KV,HV 1	ANAND NAGAR_110	13:02	13:22	0:20	HAND TRIPPED
204	13-Feb-2020	BAGALKOT	110	ANKOLA-KUMATA (L2)	KUMATA_110	8:55	17:43	8:48	NFBC ISSUED
205	13-Feb-2020	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	10:16	14:09	3:53	LINE CLEAR AVAILED
206	13-Feb-2020	BAGALKOT	220	BAGLKOT-VAJRAMATTI 2	BAGALKOT_220	0:00	17:24	17:24	LINE CLEAR AVAILED
207	13-Feb-2020	BAGALKOT	110	BIDNAL-NAVALGUND TO GOPANAKOPPA	NARAGUND_110	9:52	16:54	7:02	LINE CLEAR AVAILED
208	13-Feb-2020	BAGALKOT	110	110/33KV,HV 3	HIDIKAL_110&33KV KOLIGUDD&MYTRA	12:08	12:10	0:02	HAND TRIPPED
209	13-Feb-2020	BAGALKOT	110	110/33KV,HV 3	HIDIKAL_110&33KV KOLIGUDD&MYTRA	14:06	14:14	0:08	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
210	13-Feb-2020	BAGALKOT	110	110/11KV, HV 4	HIDIKAL_110	14:06	14:14	0:08	HAND TRIPPED
211	13-Feb-2020	BAGALKOT	110	NAVLGUND-KONNUR	KONNUR_110	10:24	16:45	6:21	LINE CLEAR AVAILED
212	13-Feb-2020	BAGALKOT	110	KONNUR-ANANT SOLAR	KONNUR_110	10:24	16:42	6:18	LINE CLEAR AVAILED
213	13-Feb-2020	BAGALKOT	110	110/11KV,HV 1 & LV1	KONNUR_110	10:23	16:39	6:16	LINE CLEAR AVAILED
214	13-Feb-2020	BAGALKOT	220	220/110KV HV1 & LV 1	KUDACHI_220	13:08	14:12	1:04	LINE CLEAR AVAILED
215	13-Feb-2020	BAGALKOT	220	220/110KV HV2 & LV 2	KUDACHI_220	13:52	14:18	0:26	LINE CLEAR AVAILED
216	13-Feb-2020	BAGALKOT	220	KUDACHI-CHIKODI2	KUDACHI_220	15:43	16:40	0:57	LINE CLEAR AVAILED
217	13-Feb-2020	BAGALKOT	220	KUDACHI-GHATAPRABHA	KUDACHI_220	16:46	16:48	0:02	LINE CLEAR AVAILED
218	13-Feb-2020	BAGALKOT	220	KUDACHI-GHATAPRABHA	KUDACHI_220	16:52	17:16	0:24	LINE CLEAR AVAILED
219	13-Feb-2020	BAGALKOT	220	KUDACHI-ATHANI	KUDACHI_220	17:24	17:43	0:19	LINE CLEAR AVAILED
220	13-Feb-2020	BAGALKOT	220	KUDACHI-MAHALINMGAPUR 2	KUDACHI_220	18:02	18:15	0:13	LINE CLEAR AVAILED
221	13-Feb-2020	BAGALKOT	110	KUDACHI-TERADAL	TERADAL_110	13:52	14:21	0:29	LINE CLEAR AVAILED
222	13-Feb-2020	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	10:47	15:14	4:27	LINE CLEAR AVAILED
223	13-Feb-2020	BAGALKOT	110	SIRSI220-UMACHAGI	UMACHAGI_110	8:31	23:59	15:28	LINE CLEAR AVAILED
224	13-Feb-2020	BAGALKOT	110	110/11KV,HV1	TERDAL_110	14:26	14:42	0:16	TRANSFORMER FAULT
225	13-Feb-2020	BAGALKOT	110	110/11KV,HV3	TERDAL_110	14:20	14:50	0:30	TRANSFORMER FAULT
226	13-Feb-2020	BAGALKOT	110	HUBLI220-TARIHAL	TARIHAL_110	17:54	23:59	6:05	LINE FAULT
227	13-Feb-2020	BAGALKOT	110	SUVARNSOUDA-MACHE	MACHE_110	18:43	18:45	0:02	MAIN SUPPLY FAILURE
228	13-Feb-2020	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,HEBBAL_33,KANAGAL_33	11:21	11:31	0:10	LINE CLEAR AVAILED
229	13-Feb-2020	BAGALKOT	110	110/11KV HV1&HV2	RANEBENNUR_110	10:27	19:16	8:49	LINE CLEAR AVAILED
230	13-Feb-2020	BAGALKOT	110	110/11KV HV3	RANEBENNUR_110	10:40	16:12	5:32	LINE CLEAR AVAILED
231	13-Feb-2020	BAGALKOT	110	110/11KV HV3	RANEBENNUR_110	16:15	19:10	2:55	LINE CLEAR AVAILED
232	13-Feb-2020	BAGALKOT	110	110/11KV,HV1	MUNDARGI_110	18:20	18:40	0:20	TRANSFORMER FAULT
233	13-Feb-2020	BAGALKOT	110	110/11KV,HV1	MUDDEBIHAL_110	16:14	16:17	0:03	TRANSFORMER FAULT
234	13-Feb-2020	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	16:11	16:12	0:01	TRANSFORMER FAULT
235	13-Feb-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	13:02	13:09	0:07	TRANSFORMER FAULT
236	13-Feb-2020	BAGALKOT	110	MAHALINGAPUR-NARENDRA1	MAHALINGAPUR_220	12:49	13:44	0:55	LINE CLEAR AVAILED
237	13-Feb-2020	BAGALKOT	110	220/110KV,HV2	MAHALINGAPUR_220	14:22	16:21	1:59	LINE CLEAR AVAILED
238	13-Feb-2020	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	15:54	16:20	0:26	TRANSFORMER FAULT
239	13-Feb-2020	BENGALURU	220	KANAKAPURA 220 - SOMANAHALLI 220	KANAKAPURA 220	14:32	14:51	0:19	LINE FAULT
240	13-Feb-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHAGAR, YEDUMADU, GODUR	14:32	14:58	0:26	LINE CLEAR AVAILED
241	13-Feb-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI, HONNIGANAHALLI, HALAGUR	14:32	14:58	0:26	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
242	13-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA,  SANKALGERE, BEVOOR, DASHAWARA	14:32	14:58	0:26	LINE CLEAR AVAILED
243	13-Feb-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	14:32	14:58	0:26	LINE CLEAR AVAILED
244	13-Feb-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANADODDI	14:32	14:58	0:26	LINE CLEAR AVAILED
245	13-Feb-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI,HANUMANTHN AGAR,YEDUMADU,GODUR	16:02	16:12	0:10	LINE FAULT
246	13-Feb-2020	BENGALURU	66	HV2	LEELA VENTURE	16:35	16:37	0:02	LINE CLEAR AVAILED
247	13-Feb-2020	BENGALURU	66	HV2	NRS 66	15:11	15:15	0:04	LINE CLEAR AVAILED
248	13-Feb-2020	BENGALURU	66	HV2	R R NAGAR	11:34	12:32	0:58	LINE CLEAR AVAILED
249	13-Feb-2020	BENGALURU	66	HV1	CHAKKAVELU	16:00	16:05	0:05	LOAD CHANGE OVER
250	13-Feb-2020	BENGALURU	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	18:30	18:48	0:17	LINE FAULT
251	13-Feb-2020	BENGALURU	66	HV1	DEVANAHALLI	5:07	5:13	0:05	TRANSFORMER FAULT
252	13-Feb-2020	BENGALURU	66	HV2	DABUSPETE 220	11:12	11:16	0:03	LINE CLEAR AVAILED
253	13-Feb-2020	BENGALURU	66	DABUSPETE 220 - KOLALA	SK STEEL(EHT)	9:47	10:42	0:54	LINE FAULT
254	13-Feb-2020	BENGALURU	66	CHIKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	10:30	11:30	0:59	LINE CLEAR AVAILED
255	13-Feb-2020	BENGALURU	66	CHIKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:52	18:57	1:04	LINE CLEAR AVAILED
256	13-Feb-2020	GULBARGA	220	HV2	MALLAT_220	13:34	14:25	0:51	LINE CLEAR AVAILED
257	13-Feb-2020	GULBARGA	220	HV1	MALLAT_220	14:55	15:24	0:29	LINE CLEAR AVAILED
258	13-Feb-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	11:43	11:51	0:08	LINE FAULT
259	13-Feb-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	12:37	12:58	0:21	LINE FAULT
260	13-Feb-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABUR_110	5:15	5:19	0:04	LINE FAULT
261	13-Feb-2020	GULBARGA	110	HV3	HALIKHED_110	12:56	13:00	0:04	TRANSFORMER FAULT
262	13-Feb-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	5:36	5:47	0:11	LINE FAULT
263	13-Feb-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	6:14	6:25	0:11	LINE FAULT
264	13-Feb-2020	GULBARGA	110	HV1	TEKKALKOTE_110	11:20	11:24	0:04	TRANSFORMER FAULT
265	13-Feb-2020	GULBARGA	110	HV2	TEKKALKOTE_110 KEMBHAVI_110,	14:25	14:55	0:30	TRANSFORMER FAULT
266	13-Feb-2020	GULBARGA	110	SHAHPUR-KEMBHAVI1	UGARSUGAR_IPP, HUNSAGI_110, ASKI_110 KEMBHAVI_110,	1:16	1:25	0:09	LINE FAULT
267	13-Feb-2020	GULBARGA	110	SHAHPUR-KEMBHAVI1	UGARSUGAR_IPP, HUNSAGI_110, ASKI_110	2:13	2:20	0:07	LINE FAULT



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
268	13-Feb-2020	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGAR_IPP, HUNSAGI_110, ASKI_110 SIRIGUPPA_110,	3:33	3:38	0:05	LINE FAULT
269	13-Feb-2020	GULBARGA	110	SINDHANOOR220-SIRIGUPPA	TEKKALKOTE_110, NSL_SUGARS	16:50	17:25	0:35	LINE FAULT
270	13-Feb-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABUR_110	21:45	21:50	0:05	LINE FAULT
271	13-Feb-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	20:40	20:55	0:15	LINE FAULT
272	13-Feb-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	21:45	22:05	0:20	LINE FAULT
273	13-Feb-2020	GULBARGA	110	MUNIRABAD-KOPPAL	KIRLOSKAR_110,HAREKRISHN AMETALLIC_IPP,GINIGERA_1 10,KOPPAL_110	9:20	12:30	3:10	LINE FAULT
274	13-Feb-2020	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	14:10	14:50	0:40	TRANSFORMER FAULT
275	13-Feb-2020	GULBARGA	66	HV2	KOTTUR_66	10:00	10:05	0:05	TRANSFORMER FAULT
276	13-Feb-2020	GULBARGA	66	HV1	TAMBRAHALLI_66	9:20	9:25	0:05	TRANSFORMER FAULT
277	13-Feb-2020	HASSAN	110	HV1	ALKOLA_110	13:01	13:35	0:34	LINE CLEAR AVAILED
278	13-Feb-2020	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:36	13:58	3:22	LINE CLEAR AVAILED
279	13-Feb-2020	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:36	13:58	3:22	LINE CLEAR AVAILED
280	13-Feb-2020	HASSAN	110	HV2	NANDIKUR_110	17:19	17:27	0:08	HAND TRIPPED
281	13-Feb-2020	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	17:02	17:29	0:27	LINE CLEAR AVAILED
282	13-Feb-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	8:47	8:52	0:05	LINE FAULT
283	13-Feb-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:11	10:51	0:40	LINE FAULT
284	13-Feb-2020	MYSORE	66	HV1	ARAKERE_66	12:55	17:38	4:42	LINE CLEAR AVAILED
285	13-Feb-2020	MYSORE	66	DEVANOOR (MYS)-VAGAMANGALA	DEVANOORMYS_66	18:04	19:39	1:35	LINE FAULT
286	13-Feb-2020	MYSORE	66	DEVANOOR (MYS)-RAJEEV NAGARA	RAJEEVNAGARA_66, FTS_66	18:04	19:39	1:35	LINE CLEAR AVAILED
287	13-Feb-2020	MYSORE	66	GUNDLUPETE-KABBALLI	BARGI, HANGALA, BOMMALAPURA & BEGUR	9:18	9:54	0:36	LINE CLEAR AVAILED
288	13-Feb-2020	MYSORE	66	GUNDLUPETE-CR NAGARA	GUNDULPET_66	9:18	9:54	0:36	LINE CLEAR AVAILED
289	13-Feb-2020	MYSORE	66	HV1	GUNDULPET_66	8:34	10:01	1:26	LINE CLEAR AVAILED
290	13-Feb-2020	MYSORE	66	HV1	GUNDULPET_66	14:27	19:02	4:35	LINE CLEAR AVAILED
291	13-Feb-2020	MYSORE	66	HV1	HOOTAGALLY_220	12:12	13:57	1:44	LINE CLEAR AVAILED
292	13-Feb-2020	MYSORE	66	HV2	HOOTAGALLY_220	10:09	13:58	3:49	LINE CLEAR AVAILED
293	13-Feb-2020	MYSORE	66	KHB STATION-HOOTAGALLI	KHBCOLONY_66	15:35	19:44	4:08	LINE CLEAR AVAILED
294	13-Feb-2020	MYSORE	66	HV1	KHBCOLONY_66	15:36	21:41	6:05	TRANSFORMER FAULT
295	13-Feb-2020	MYSORE	66	HV1	KHBCOLONY_66	21:45	21:56	0:11	HAND TRIPPED
296	13-Feb-2020	MYSORE	66	HV2	KHBCOLONY_66	15:22	19:45	4:22	TRANSFORMER FAULT
297	13-Feb-2020	MYSORE	66	HV2	KHBCOLONY_66	19:45	23:59	4:13	TRANSFORMER FAULT
298	13-Feb-2020	MYSORE	66	KR PET 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	14:49	14:54	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
299	13-Feb-2020	MYSORE	66	KUNTHUR-DR PETE	MUGUR_66 THAYURU_66 JANNUR_66 SANTHEMARAHALLI_66	14:16	14:28	0:11	LINE FAULT
300	13-Feb-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66, PGPALYA_66 DODDINADUVADI_66 KOTTANUR_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	12:33	12:46	0:13	HAND TRIPPED
301	13-Feb-2020	MYSORE	66	HV2	MALAVALLI_66	7:36	7:50	0:14	LINE CLEAR AVAILED
302	13-Feb-2020	MYSORE	66	VAJAMANGALA-JYOTHI NAGARA	JYOTHINAGARA_66	10:25	16:40	6:14	NFBC ISSUED
303	13-Feb-2020	MYSORE	66	VAJAMANGALA-DEVANOR (MYS)	DEVANOORMYS_66, BANNIMANTAP_66, FTS_66, RAJEEVNAGARA_66	13:49	13:57	0:08	LINE FAULT
304	13-Feb-2020	MYSORE	66	VAJAMANGALA-DEVANOR (MYS)	DEVANOORMYS_66, FTS_66, RAJEEVNAGARA_66	18:58	19:01	0:03	HAND TRIPPED
305	13-Feb-2020	MYSORE	66	VAJAMANGALA-DEVANOR (MYS)	DEVANOORMYS_66, FTS_66, RAJEEVNAGARA_66	19:09	19:34	0:24	HAND TRIPPED
306	13-Feb-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:17	13:58	1:41	LINE CLEAR AVAILED
307	13-Feb-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	12:05	13:56	1:50	LINE CLEAR AVAILED
308	13-Feb-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	22:14	23:18	1:04	LINE CLEAR AVAILED
309	13-Feb-2020	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	22:14	23:19	1:04	LINE CLEAR AVAILED
310	13-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110 ,	22:14	23:18	1:03	LINE CLEAR AVAILED
311	13-Feb-2020	TUMKUR	110	TR-1	HALKURKE_110	12:05	13:00	0:54	LINE CLEAR AVAILED
312	13-Feb-2020	TUMKUR	110	TR-1	HALKURKE_110	15:08	16:21	1:12	LINE CLEAR AVAILED
313	13-Feb-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110 , SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	22:20	23:15	0:55	LINE CLEAR AVAILED
314	13-Feb-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	8:17	8:21	0:03	TRANSFORMER FAULT
315	13-Feb-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	16:12	16:17	0:04	TRANSFORMER FAULT
316	13-Feb-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	16:17	19:22	3:05	LINE CLEAR AVAILED
317	13-Feb-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	16:17	19:22	3:05	LINE CLEAR AVAILED
318	13-Feb-2020	TUMKUR	66	TR-1	KUNDUR_66	18:46	19:20	0:33	LINE CLEAR AVAILED
319	13-Feb-2020	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	13:14	13:48	0:33	LINE CLEAR AVAILED
320	13-Feb-2020	TUMKUR	66	TR-2	SHYLAPURA_66	13:31	13:37	0:05	TRANSFORMER FAULT
321	13-Feb-2020	TUMKUR	66	TR-2	SANIKERE_66	9:29	9:42	0:12	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
322	13-Feb-2020	TUMKUR	66	TR-2	TAVAREKERE(H)_66	8:58	9:04	0:06	LINE CLEAR AVAILED
323	13-Feb-2020	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66	19:06	19:16	0:09	LINE FAULT
324	13-Feb-2020	TUMKUR	66	TR-1	TUMKUR_66	17:08	17:16	0:08	TRANSFORMER FAULT
325	14-Feb-2020	BAGALKOT	110	AMBEWADI220-NK2(KAVALWADA)	KAVALWADA_110	10:12	10:24	0:12	HAND TRIPPED
326	14-Feb-2020	BAGALKOT	110	AMBEWADI220-NK1(HALIYAL)	HALIYAL_110	11:48	19:16	7:28	LINE FAULT
327	14-Feb-2020	BAGALKOT	110	AMBEWADI220-NK2(KAVALWADA)	KAVALWADA_110	13:26	19:17	5:51	LINE CLEAR AVAILED
328	14-Feb-2020	BAGALKOT	110	110/11KV,HV1	AREMALLAPUR	6:40	6:44	0:04	HAND TRIPPED
329	14-Feb-2020	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	6:52	7:06	0:14	LOAD CURTAILMENT
330	14-Feb-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	10:35	23:59	13:24	LINE CLEAR AVAILED
331	14-Feb-2020	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	6:52	7:17	0:25	LOAD CURTAILMENT
332	14-Feb-2020	BAGALKOT	110	110/11KV,HV1	HANAGAL_110	6:53	8:10	1:17	LOAD CURTAILMENT
333	14-Feb-2020	BAGALKOT	110	HAVERI-HANAGAL	HANAGAL_110	13:24	13:28	0:04	LOAD CURTAILMENT
334	14-Feb-2020	BAGALKOT	110	110/33KV,HV 3	HIDIKAL-110&33KV KOIGUDD,ALAGAWADI,MYTR A	6:52	7:03	0:11	LOAD CURTAILMENT
335	14-Feb-2020	BAGALKOT	220	220/110KV HV2	KUDACHI_220	12:31	14:37	2:06	LINE CLEAR AVAILED
336	14-Feb-2020	BAGALKOT	220	220/110KV HV1	KUDACHI_220	15:22	15:51	0:29	LINE CLEAR AVAILED
337	14-Feb-2020	BAGALKOT	220	220/110KV HV2	KUDACHI_220	12:31	15:22	2:51	LINE CLEAR AVAILED
338	14-Feb-2020	BAGALKOT	220	220/110KV HV1	KUDACHI_220	15:23	16:56	1:33	LINE CLEAR AVAILED
339	14-Feb-2020	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	10:07	16:42	6:35	NFBC ISSUED
340	14-Feb-2020	BAGALKOT	110	110/33KV,HV2	HUBLI_220	15:53	16:52	0:59	LINE CLEAR AVAILED
341	14-Feb-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:41	14:10	1:29	LINE CLEAR AVAILED
342	14-Feb-2020	BAGALKOT	110	110/11KV,HV2	SAVALGI_110	6:52	7:12	0:20	LOAD CURTAILMENT
343	14-Feb-2020	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	6:52	7:02	0:10	LOAD CURTAILMENT
344	14-Feb-2020	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	14:35	14:50	0:15	TRANSFORMER FAULT
345	14-Feb-2020	BAGALKOT	220	HUBLI1-SIRSI	SIRSI_220	11:29	13:16	1:47	LINE CLEAR AVAILED
346	14-Feb-2020	BAGALKOT	220	HUBLI2-SIRSI	SIRSI_220	13:20	21:21	8:01	LINE CLEAR AVAILED
347	14-Feb-2020	BAGALKOT	220	SHARAVATHY1&2 - SIRSI	SIRSI_220	15:00	17:14	2:14	LINE CLEAR AVAILED
348	14-Feb-2020	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220	15:14	18:00	2:46	LINE CLEAR AVAILED
349	14-Feb-2020	BAGALKOT	110	110/11KV, HV2	MRUTHYUNJAY NAGAR_110	10:01	16:05	6:04	LINE CLEAR AVAILED
350	14-Feb-2020	BAGALKOT	110	110/11KV, HV1	MRUTHYUNJAY NAGAR_110	13:20	16:05	2:45	LINE CLEAR AVAILED
351	14-Feb-2020	BAGALKOT	110	AMBEWADI220-NK2(KAVALWADA)	KAVALWADA_110	10:12	10:24	0:12	HAND TRIPPED
352	14-Feb-2020	BAGALKOT	110	AMBEWADI220-NK1(HALIYAL)	HALIYAL_110	11:48	19:16	7:28	LINE FAULT
353	14-Feb-2020	BAGALKOT	110	AMBEWADI220-NK2(KAVALWADA)	KAVALWADA_110	13:26	19:17	5:51	LINE CLEAR AVAILED
354	14-Feb-2020	BAGALKOT	110	110/11KV,HV1	AREMALLAPUR	6:40	6:44	0:04	HAND TRIPPED
355	14-Feb-2020	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	6:52	7:06	0:14	LOAD CURTAILMENT
356	14-Feb-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	10:35	23:59	13:24	LINE CLEAR AVAILED
357	14-Feb-2020	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	6:52	7:17	0:25	LOAD CURTAILMENT
358	14-Feb-2020	BAGALKOT	110	110/11KV,HV1	HANAGAL_110	6:53	8:10	1:17	LOAD CURTAILMENT
359	14-Feb-2020	BAGALKOT	110	HAVERI-HANAGAL	HANAGAL_110	13:24	13:28	0:04	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
360	14-Feb-2020	BAGALKOT	110	110/33KV,HV 3	HIDIKAL-110&33KV KOIGUDD,ALAGAWADI,MYTRA	6:52	7:03	0:11	LOAD CURTAILMENT
361	14-Feb-2020	BAGALKOT	220	220/110KV HV2	KUDACHI_220	12:31	14:37	2:06	LINE CLEAR AVOIDED
362	14-Feb-2020	BAGALKOT	220	220/110KV HV1	KUDACHI_220	15:22	15:51	0:29	LINE CLEAR AVOIDED
363	14-Feb-2020	BAGALKOT	220	220/110KV HV2	KUDACHI_220	12:31	15:22	2:51	LINE CLEAR AVOIDED
364	14-Feb-2020	BAGALKOT	220	220/110KV HV1	KUDACHI_220	15:23	16:56	1:33	LINE CLEAR AVOIDED
365	14-Feb-2020	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	10:07	16:42	6:35	NFBC ISSUED
366	14-Feb-2020	BAGALKOT	110	110/33KV,HV2	HUBLI_220	15:53	16:52	0:59	LINE CLEAR AVOIDED
367	14-Feb-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:41	14:10	1:29	LINE CLEAR AVOIDED
368	14-Feb-2020	BAGALKOT	110	110/11KV,HV2	SAVALGI_110	6:52	7:12	0:20	LOAD CURTAILMENT
369	14-Feb-2020	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	6:52	7:02	0:10	LOAD CURTAILMENT
370	14-Feb-2020	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	14:35	14:50	0:15	TRANSFORMER FAULT
371	14-Feb-2020	BAGALKOT	220	HUBLI1-SIRSI	SIRSI_220	11:29	13:16	1:47	LINE CLEAR AVOIDED
372	14-Feb-2020	BAGALKOT	220	HUBLI2-SIRSI	SIRSI_220	13:20	21:21	8:01	LINE CLEAR AVOIDED
373	14-Feb-2020	BAGALKOT	220	SHARAVATHY1&2 - SIRSI	SIRSI_220	15:00	17:14	2:14	LINE CLEAR AVOIDED
374	14-Feb-2020	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220	15:14	18:00	2:46	LINE CLEAR AVOIDED
375	14-Feb-2020	BAGALKOT	110	110/11KV, HV2	MRUTHYUNJAY NAGAR_110	10:01	16:05	6:04	LINE CLEAR AVOIDED
376	14-Feb-2020	BAGALKOT	110	110/11KV, HV1	MRUTHYUNJAY NAGAR_110	13:20	16:05	2:45	LINE CLEAR AVOIDED
377	14-Feb-2020	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	18:05	18:10	0:05	LOAD CHANGE OVER
378	14-Feb-2020	BENGALURU	66	HV2	SIDDALAGATTA	14:28	14:48	0:20	LINE CLEAR AVOIDED
379	14-Feb-2020	BENGALURU	66	HV2	TK HALLI 220	14:32	14:41	0:08	TRANSFORMER FAULT
380	14-Feb-2020	BENGALURU	66	HV2	TK HALLI 220	4:44	4:49	0:05	TRANSFORMER FAULT
381	14-Feb-2020	BENGALURU	66	HV2	TK HALLI 220	5:07	5:18	0:11	TRANSFORMER FAULT
382	14-Feb-2020	BENGALURU	66	HV1	KODIHALLI	10:00	18:59	8:58	LINE CLEAR AVOIDED
383	14-Feb-2020	BENGALURU	66	HV2	KODIHALLI	11:28	11:33	0:05	TRANSFORMER FAULT
384	14-Feb-2020	BENGALURU	66	HV1	ELECTRONIC CITY P2 S1	18:04	18:10	0:05	LINE CLEAR AVOIDED
385	14-Feb-2020	BENGALURU	66	HV2	ELECTRONIC CITY P2 S1	10:02	18:10	8:07	LINE CLEAR AVOIDED
386	14-Feb-2020	BENGALURU	220	HV1	CHINTAMANI 220	8:40	10:35	1:55	TRANSFORMER FAULT
387	14-Feb-2020	BENGALURU	66	HV2	CHAKAVELU	9:15	9:27	0:12	TRANSFORMER FAULT
388	14-Feb-2020	BENGALURU	66	HV2	BOODIGERE	17:34	18:19	0:45	TRANSFORMER FAULT
389	14-Feb-2020	BENGALURU	66	HV2	BOODIGERE	18:19	18:50	0:30	TRANSFORMER FAULT
390	14-Feb-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI,DEVANGONDHI, LAKKUR	7:11	8:06	0:54	LOAD CURTAILMENT
391	14-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	16:30	16:40	0:10	LOAD CURTAILMENT
392	14-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	16:53	16:57	0:03	LOAD CURTAILMENT
393	14-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	7:26	7:40	0:14	LOAD CURTAILMENT
394	14-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	16:31	16:41	0:10	LOAD CURTAILMENT
395	14-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM	16:31	16:41	0:10	LOAD CURTAILMENT
396	14-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	MANGALA	16:53	16:57	0:03	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
397	14-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA KEMBODI, MUDIYANUR, H	22:15	22:54	0:39	LOAD CURTAILMENT
398	14-Feb-2020	BENGALURU	66	KOLAR 220 - NANGALI	GOLLAHALLI, BAIRAKURU, NANGALI KEMBODI, MUDIYANUR, H	16:31	16:40	0:09	LOAD CURTAILMENT
399	14-Feb-2020	BENGALURU	66	KOLAR 220 - NANGALI	GOLLAHALLI, BAIRAKURU, NANGALI	16:54	16:57	0:02	LOAD CURTAILMENT
400	14-Feb-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	16:29	16:38	0:08	LINE CLEAR AVAILED
401	14-Feb-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	16:53	16:56	0:02	LINE CLEAR AVAILED
402	14-Feb-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	7:21	7:35	0:14	LOAD CURTAILMENT
403	14-Feb-2020	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	9:15	9:22	0:07	LINE FAULT
404	14-Feb-2020	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	11:36	11:46	0:10	LOAD CHANGE OVER
405	14-Feb-2020	BENGALURU	66	HV1	GOWRIBIDANUR 220	1:52	2:03	0:11	TRANSFORMER FAULT
406	14-Feb-2020	BENGALURU	66	HV1	GOWRIBIDANUR 220	15:35	19:05	3:30	LINE CLEAR AVAILED
407	14-Feb-2020	BENGALURU	66	HV2	GOWRIBIDANUR 220	15:35	23:59	8:24	LINE CLEAR AVAILED
408	14-Feb-2020	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	7:20	7:48	0:28	LOAD CURTAILMENT
409	14-Feb-2020	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	23:20	23:35	0:15	LINE FAULT
410	14-Feb-2020	GULBARGA	110	HV3	BEVOOR_110	14:57	15:04	0:07	TRANSFORMER FAULT
411	14-Feb-2020	GULBARGA	110	HV3	BEVOOR_110	15:09	15:25	0:16	TRANSFORMER FAULT
412	14-Feb-2020	GULBARGA	110	CHITAGUPPA-ACMESOLAR IPP	CHITAGUPPA_110	11:34	11:49	0:15	LINE FAULT
413	14-Feb-2020	GULBARGA	110	HV1	CHINCHOLI_110	6:51	7:00	0:09	LOAD CURTAILMENT
414	14-Feb-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABUR_110	5:25	5:37	0:12	LINE FAULT
415	14-Feb-2020	GULBARGA	110	HV2	KEMBHAVI_110	11:45	11:55	0:10	TRANSFORMER FAULT
416	14-Feb-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA 110,SAIDAPUR_110 KEMBHAVI_110,	2:29	2:37	0:08	LINE FAULT
417	14-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	UGARSUGAR_IPP, HUNSAGI_110, ASKI_110 KEMBHAVI_110,	4:11	4:17	0:06	LINE FAULT
418	14-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	UGARSUGAR_IPP, HUNSAGI_110, ASKI_110	6:01	6:06	0:05	LINE FAULT
419	14-Feb-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KAMPLI_GLB_110, YERADONA_110, MALLAPURA_110, SRERAMANAGAR_110	11:39	11:46	0:07	LINE FAULT
420	14-Feb-2020	GULBARGA	110	SINDHANOOR-PGLR_WIND(NIRLOOTI_IPP)	SINDHANOOR_220	1:07	1:25	0:18	LINE FAULT
421	14-Feb-2020	GULBARGA	110	HV3	SIRIGUPPA_110	11:05	12:33	1:28	LINE CLEAR AVAILED
422	14-Feb-2020	GULBARGA	110	HV2	SIRIGUPPA_110	12:49	13:54	1:05	LINE CLEAR AVAILED
423	14-Feb-2020	GULBARGA	110	HV1	SIRIGUPPA_110	14:50	16:20	1:30	LINE CLEAR AVAILED
424	14-Feb-2020	GULBARGA	110	GABUR-BPSLR_IPP	GABUR_110	21:40	21:45	0:05	LINE FAULT
425	14-Feb-2020	GULBARGA	110	HV2	HANUMASAGAR_110	6:50	7:00	0:10	LINE CLEAR AVAILED
426	14-Feb-2020	GULBARGA	110	HV1	HANUMASAGAR_110	16:10	16:30	0:20	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
427	14-Feb-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,UGARSUGAR_IPP	20:30	20:35	0:05	LINE FAULT
428	14-Feb-2020	HASSAN	220	HV1	HASSAN_220	8:32	9:21	0:49	TRANSFORMER FAULT
429	14-Feb-2020	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	10:23	17:23	7:00	LINE CLEAR AVAILED
430	14-Feb-2020	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	10:23	17:23	7:00	NFBC ISSUED
431	14-Feb-2020	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	14:59	17:13	2:14	LINE CLEAR AVAILED
432	14-Feb-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	15:00	17:15	2:15	LINE CLEAR AVAILED
433	14-Feb-2020	HASSAN	220	GOPALAP-HSN400	GOPALAPURA_220	10:05	13:13	3:08	LINE CLEAR AVAILED
434	14-Feb-2020	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	8:36	9:23	0:47	HAND TRIPPED
435	14-Feb-2020	HASSAN	66	HASSN22-CHIKAMAGLUR2	HASSAN_220	8:39	9:23	0:44	HAND TRIPPED
436	14-Feb-2020	HASSAN	66	HASSN22-HN PURA	HASSAN_220	8:37	10:00	1:23	LINE CLEAR AVAILED
437	14-Feb-2020	HASSAN	66	LV1	HASSAN_220	8:32	9:22	0:50	HAND TRIPPED
438	14-Feb-2020	HASSAN	66	HASSN22-MALLALI	HASSAN_220	8:36	10:00	1:24	LINE CLEAR AVAILED
439	14-Feb-2020	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	8:36	9:22	0:46	HAND TRIPPED
440	14-Feb-2020	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	8:36	9:30	0:54	HAND TRIPPED
441	14-Feb-2020	HASSAN	110	MRSSHM-MPM	MRSMSG_220	9:08	12:19	3:11	NFBC ISSUED
442	14-Feb-2020	HASSAN	110	HV1	GANDAS_110	6:30	7:06	0:36	TRANSFORMER FAULT
443	14-Feb-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	13:43	13:51	0:08	HAND TRIPPED
444	14-Feb-2020	HASSAN	110	HV1	BRAHMAVARA_110	6:52	7:09	0:17	LOAD CURTAILMENT
445	14-Feb-2020	HASSAN	110	HV1	BRAHMAVARA_110	7:29	11:59	4:30	TRANSFORMER FAULT
446	14-Feb-2020	HASSAN	66	HV1	SINGAPURA_66	16:16	16:29	0:13	HAND TRIPPED
447	14-Feb-2020	HASSAN	66	HV2	SINGAPURA_66	16:16	16:29	0:13	HAND TRIPPED
448	14-Feb-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	11:47	12:36	0:49	LINE CLEAR AVAILED
449	14-Feb-2020	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	11:47	12:42	0:55	LINE CLEAR AVAILED
450	14-Feb-2020	MYSORE	66	HV1	GARUDANAUKADDA_66	10:53	11:52	0:59	LINE CLEAR AVAILED
451	14-Feb-2020	MYSORE	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66 KR NAGARA_66 BHERYA_66	7:17	7:24	0:07	HAND TRIPPED
452	14-Feb-2020	MYSORE	66	KUSHALNAGARA 220-BYLKUPPE	BYLUKUPPE_66	7:17	7:26	0:09	HAND TRIPPED
453	14-Feb-2020	MYSORE	66	KUSHALNAGARA 220-BETTADAPURA	KITTUR_66 CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66 VIRAJPET_66	7:17	7:24	0:07	HAND TRIPPED
454	14-Feb-2020	MYSORE	66	KUSHALNAGARA 220-PERIYAPATNA-1	PONNAMPET_66 PERIYAPATNA_66	7:17	7:26	0:09	HAND TRIPPED
455	14-Feb-2020	MYSORE	66	HV2	MALAVALLI_66	9:56	10:01	0:05	TRANSFORMER FAULT
456	14-Feb-2020	MYSORE	66	HV2	NAGAMANGALA_66	16:05	17:29	1:23	LINE CLEAR AVAILED
457	14-Feb-2020	MYSORE	66	HV1	TARIPURA_66	12:17	14:20	2:03	TRANSFORMER FAULT
458	14-Feb-2020	MYSORE	66	HV1	VIRAJPET_66	13:16	14:24	1:08	LINE CLEAR AVAILED
459	14-Feb-2020	MYSORE	66	HV2	VIRAJPET_66	13:16	14:24	1:08	LINE CLEAR AVAILED
460	14-Feb-2020	MYSORE	66	HV1	YELANDUR_66	6:50	6:55	0:04	LOAD CURTAILMENT
461	14-Feb-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	10:46	15:36	4:50	LINE CLEAR AVAILED
462	14-Feb-2020	TUMKUR	220	HIRIYUR 220kV- PGCIL	HIRIYUR_220	16:40	16:47	0:07	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
463	14-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110 , TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	2:07	2:21	0:13	LINE FAULT
464	14-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110 , TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,	9:51	10:01	0:09	LINE FAULT
465	14-Feb-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADDEHALI_110	15:07	15:11	0:04	HAND TRIPPED
466	14-Feb-2020	TUMKUR	66	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	10:09	12:20	2:10	LINE FAULT
467	14-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	10:58	11:00	0:02	TRANSFORMER FAULT
468	14-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	18:34	18:41	0:06	TRANSFORMER FAULT
469	14-Feb-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	10:04	19:11	9:07	LINE CLEAR AVAILED
470	14-Feb-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON2	MEGMICON 1_IPP_66	10:04	19:01	8:56	LINE CLEAR AVAILED
471	14-Feb-2020	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	12:26	12:51	0:24	LINE CLEAR AVAILED
472	14-Feb-2020	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	14:20	14:30	0:09	LINE CLEAR AVAILED
473	14-Feb-2020	TUMKUR	66	TR-2	HALUVAGALU_66	7:47	7:56	0:08	TRANSFORMER FAULT
474	14-Feb-2020	TUMKUR	66	TR-1	HIRIYUR_66	13:38	14:00	0:22	TRANSFORMER FAULT
475	14-Feb-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	16:35	17:06	0:30	HAND TRIPPED
476	14-Feb-2020	TUMKUR	66	TR-1	HIRIYUR_220	16:34	16:54	0:19	HAND TRIPPED
477	14-Feb-2020	TUMKUR	66	TR-2	HOSADURGA_66	16:50	17:29	0:38	LINE CLEAR AVAILED
478	14-Feb-2020	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	18:58	19:12	0:13	LINE FAULT
479	14-Feb-2020	TUMKUR	66	TR-2	MATHOD_66	13:16	13:21	0:04	TRANSFORMER FAULT
480	14-Feb-2020	TUMKUR	66	TR-2	SHYLAPURA_66	13:03	13:10	0:07	TRANSFORMER FAULT
481	14-Feb-2020	TUMKUR	66	TR-2	SHYLAPURA_66	16:52	18:53	2:01	TRANSFORMER FAULT
482	14-Feb-2020	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	17:05	17:22	0:17	LINE FAULT
483	14-Feb-2020	TUMKUR	66	THOVINAKERE-KORA	THOVINAKERE_66	9:02	9:15	0:13	LINE FAULT
484	14-Feb-2020	TUMKUR	66	SIRA- MADHUGIRI 1	SIRA_66,BOKKAPATNA_66,	12:28	12:53	0:25	LINE CLEAR AVAILED
485	14-Feb-2020	TUMKUR	66	SIRA- MADHUGIRI 2	KALLAMBELLA_66, BOKKAPATNA_66,	7:12	8:00	0:48	MAIN SUPPLY FAILURE
486	14-Feb-2020	TUMKUR	66	SIRA- MADHUGIRI 2	KALLAMBELLA_66, BOKKAPATNA_66,	12:28	12:54	0:26	LINE CLEAR AVAILED
487	14-Feb-2020	TUMKUR	66	SIRA- MADHUGIRI 2	KALLAMBELLA_66	14:20	14:31	0:10	LINE CLEAR AVAILED
488	14-Feb-2020	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	SIRA_66,GULIGENAHALLI_66,	7:11	7:50	0:38	LOAD CURTAILMENT
489	14-Feb-2020	TUMKUR	66	NEELAGUNDA 220kV-PUNABHAGHATTA	PUNABHAGHATTA_66,UCHC HANGIDURGA_66,JAGALUR_66,PALLAGATTE_66	11:40	12:00	0:20	LINE FAULT
490	14-Feb-2020	TUMKUR	66	TR-1	PAVAGADA_220	10:44	11:00	0:15	LINE CLEAR AVAILED
491	14-Feb-2020	TUMKUR	66	TR-1	PAVAGADA_220	15:21	16:34	1:13	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
492	15-Feb-2020	BAGALKOT	110	HIREKERUR-RATTIHALLI	RATTIHALLI_110	0:00	13:29	13:29	LINE CLEAR AVAILED
493	15-Feb-2020	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	0:00	21:10	21:10	LINE CLEAR AVAILED
494	15-Feb-2020	BAGALKOT	110	MUDHOL(UTTUR)-RANNABELAGALI	RANNABELAGALI_110	21:10	23:59	2:49	LINE CLEAR AVAILED
495	15-Feb-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	12:10	12:15	0:05	TRANSFORMER FAULT
496	15-Feb-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	22:44	23:06	0:22	LINE CLEAR AVAILED
497	15-Feb-2020	BAGALKOT	110	110/11KV,HV2	LOKAPUR_110	6:00	6:05	0:05	TRANSFORMER FAULT
498	15-Feb-2020	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	10:10	18:05	7:55	LINE CLEAR AVAILED
499	15-Feb-2020	BAGALKOT	66	DAVANGERE-HARIHAR-HOSPET	HARIHAR-HOSPET_66KV	21:09	23:59	2:50	LINE CLEAR AVAILED
500	15-Feb-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	10:55	11:06	0:11	LINE FAULT
501	15-Feb-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	11:11	11:20	0:08	LINE FAULT
502	15-Feb-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:31	13:21	0:50	LINE CLEAR AVAILED
503	15-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	11:15	11:33	0:18	LINE FAULT
504	15-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	15:10	15:15	0:05	LINE CLEAR AVAILED
505	15-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	18:54	18:59	0:05	LINE CLEAR AVAILED
506	15-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	19:13	19:17	0:04	LINE CLEAR AVAILED
507	15-Feb-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	17:41	17:55	0:14	LINE FAULT
508	15-Feb-2020	BENGALURU	66	HV1	ANDERSONPET	12:15	13:50	1:35	LINE CLEAR AVAILED
509	15-Feb-2020	BENGALURU	66	HV1	HONNIGANAHALLI	12:31	14:50	2:18	LINE CLEAR AVAILED
510	15-Feb-2020	BENGALURU	66	HV2	HONNIGANAHALLI	12:31	15:05	2:33	LINE CLEAR AVAILED
511	15-Feb-2020	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	19:55	20:03	0:08	LINE FAULT
512	15-Feb-2020	BENGALURU	66	HV2	JIGANI	14:14	14:17	0:03	LINE CLEAR AVAILED
513	15-Feb-2020	BENGALURU	66	HV3	JIGANI	14:14	14:17	0:03	LINE CLEAR AVAILED
514	15-Feb-2020	BENGALURU	66	HV1	JIGANI 220	9:09	9:19	0:10	LINE CLEAR AVAILED
515	15-Feb-2020	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	15:07	16:33	1:26	LINE FAULT
516	15-Feb-2020	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI (EHT)	VRISHBHAVATHI 220	11:00	17:00	6:00	LINE CLEAR AVAILED
517	15-Feb-2020	BENGALURU	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	10:20	17:00	6:40	LINE CLEAR AVAILED
518	15-Feb-2020	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	10:20	17:00	6:40	LINE CLEAR AVAILED
519	15-Feb-2020	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	10:20	17:00	6:40	LINE CLEAR AVAILED
520	15-Feb-2020	BENGALURU	66	ADUGODI - JAYADEVA 1	ADUGODI	8:25	8:32	0:07	LOAD CHANGE OVER
521	15-Feb-2020	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	9:41	9:47	0:06	LOAD CHANGE OVER
522	15-Feb-2020	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	17:10	17:14	0:04	LOAD CHANGE OVER
523	15-Feb-2020	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY	8:58	9:08	0:10	LOAD CHANGE OVER
524	15-Feb-2020	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY PH-2 SEC-1	ELECTRONIC CITY	18:28	18:32	0:04	LOAD CHANGE OVER
525	15-Feb-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC- 1	9:14	16:59	7:45	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
526	15-Feb-2020	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC- 1	13:31	14:15	0:44	LINE CLEAR AVAILED
527	15-Feb-2020	BENGALURU	66	HV2	JAYADEVA ATTIMARADANAHALLI,	10:11	11:06	0:55	LINE CLEAR AVAILED
528	15-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA, ATTIMARADANAHALLI,	6:55	7:05	0:10	LINE FAULT
529	15-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	15:55	16:03	0:08	LINE FAULT
530	15-Feb-2020	BENGALURU	66	KENGERI SATELLITE TOWN - VRISHABHAVATHI 220	KENGERI SATELLITE TOWN	10:20	13:30	3:10	MAIN SUPPLY FAILURE
531	15-Feb-2020	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	16:50	16:56	0:06	LOAD CHANGE OVER
532	15-Feb-2020	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	4:47	6:01	1:14	LINE CLEAR AVAILED
533	15-Feb-2020	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	4:48	6:08	1:20	LINE CLEAR AVAILED
534	15-Feb-2020	BENGALURU	66	PADMANABHANAGAR -NATIONAL COLLEGE	PADMANABHANAGAR	12:10	12:33	0:23	LOAD CHANGE OVER
535	15-Feb-2020	BENGALURU	66	HV1	RAJANUKUNTE	9:57	10:29	0:32	TRANSFORMER FAULT
536	15-Feb-2020	BENGALURU	66	HV2	SHAMARAJU TECH PARK	8:11	8:41	0:30	TRANSFORMER FAULT
537	15-Feb-2020	BENGALURU	66	HV2	SHAMARAJU TECH PARK	12:06	12:35	0:29	LINE CLEAR AVAILED
538	15-Feb-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	7:52	8:05	0:13	LOAD CHANGE OVER
539	15-Feb-2020	BENGALURU	66	L R BANDE - HEBBAL 220	L R BANDE	10:03	18:19	8:16	LINE CLEAR AVAILED
540	15-Feb-2020	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	0:23	0:35	0:12	LINE CLEAR AVAILED
541	15-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR _IPP, ASKI_110, HUNSGI_110	5:22	5:32	0:10	LINE FAULT
542	15-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR _IPP, ASKI_110, HUNSGI_110	12:49	12:58	0:09	LINE FAULT
543	15-Feb-2020	GULBARGA	110	HV2	HATTI_110	7:07	7:19	0:12	TRANSFORMER FAULT
544	15-Feb-2020	GULBARGA	110	HV2	KAMPLI_GLB_110	9:01	9:33	0:32	TRANSFORMER FAULT
545	15-Feb-2020	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	0:00	0:23	0:23	LINE CLEAR AVAILED
546	15-Feb-2020	GULBARGA	110	YELBURGA-PRPJSR	YELBURGA_110	18:32	23:29	4:57	LINE CLEAR AVAILED
547	15-Feb-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	10:20	10:31	0:11	LINE FAULT
548	15-Feb-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	10:35	10:49	0:14	LINE CLEAR AVAILED
549	15-Feb-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	14:25	16:18	1:53	LINE CLEAR AVAILED
550	15-Feb-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,RAJEASHREE CEMENTS_IPP,KORAWAR TEMPLE_110	14:35	14:53	0:18	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
551	15-Feb-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,RAJEASHREE CEMENTS_IPP,KORAWAR TEMPLE_110	14:55	16:27	1:32	LINE FAULT
552	15-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	11:29	20:41	9:12	LINE CLEAR AVAILED
553	15-Feb-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	14:16	20:29	6:13	LINE FAULT
554	15-Feb-2020	HASSAN	220	MRSSHM-VARAH11	MRSMSG_220	18:37	23:59	5:22	LINE FAULT
555	15-Feb-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	14:46	17:28	2:42	LINE FAULT
556	15-Feb-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	17:28	23:59	6:31	LINE FAULT
557	15-Feb-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	11:28	20:46	9:18	LINE CLEAR AVAILED
558	15-Feb-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	18:37	23:59	5:22	LINE FAULT
559	15-Feb-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	14:46	17:27	2:41	LINE FAULT
560	15-Feb-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	17:49	23:59	6:10	LINE FAULT
561	15-Feb-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	14:16	20:28	6:12	LINE FAULT
562	15-Feb-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	17:53	20:09	2:16	LINE CLEAR AVAILED
563	15-Feb-2020	HASSAN	110	HV1	PUTTUR_110	15:29	16:28	0:59	LINE CLEAR AVAILED
564	15-Feb-2020	HASSAN	110	HV2	PUTTUR_110	15:29	16:29	1:00	LINE CLEAR AVAILED
565	15-Feb-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	0:12	0:25	0:13	MAIN SUPPLY FAILURE
566	15-Feb-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:03	12:07	0:04	MAIN SUPPLY FAILURE
567	15-Feb-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:51	12:56	0:05	MAIN SUPPLY FAILURE
568	15-Feb-2020	HASSAN	110	HV1	ARASIKERE_110	13:18	13:25	0:07	HAND TRIPPED
569	15-Feb-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	14:46	14:51	0:05	LINE FAULT
570	15-Feb-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	17:49	20:20	2:31	MAIN SUPPLY FAILURE
571	15-Feb-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	11:35	12:03	0:28	LINE CLEAR AVAILED
572	15-Feb-2020	HASSAN	110	HV1	MOODABIDRE_110	5:28	5:44	0:16	TRANSFORMER FAULT
573	15-Feb-2020	HASSAN	110	HV2	SORABA_110	10:27	10:36	0:09	TRANSFORMER FAULT
574	15-Feb-2020	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	10:43	10:53	0:10	LINE FAULT
575	15-Feb-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	9:01	17:20	8:19	NFBC ISSUED
576	15-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESPURA_66	9:00	17:19	8:19	LINE CLEAR AVAILED
577	15-Feb-2020	MYSORE	66	HV1	DUNDANAHALLI_66	13:17	14:13	0:55	LINE CLEAR AVAILED
578	15-Feb-2020	MYSORE	66	HV2	DUNDANAHALLI_66	11:40	13:15	1:34	LINE CLEAR AVAILED
579	15-Feb-2020	MYSORE	66	HOOTAGALLI-FTS 1	FTS_66	11:50	14:16	2:25	LINE FAULT
580	15-Feb-2020	MYSORE	66	HV2	HOOTAGALLY_220	11:08	12:46	1:38	TRANSFORMER FAULT
581	15-Feb-2020	MYSORE	66	HV1	KIKKERI_66	11:33	12:45	1:11	LINE CLEAR AVAILED
582	15-Feb-2020	MYSORE	66	HV2	KOLLEGALA_66	16:00	17:40	1:40	LINE CLEAR AVAILED
583	15-Feb-2020	MYSORE	66	HV2	MYSORESOUTH_66	17:52	17:59	0:07	TRANSFORMER FAULT
584	15-Feb-2020	MYSORE	66	HV2	NAGAMANGALA_66	11:04	11:28	0:23	LINE CLEAR AVAILED
585	15-Feb-2020	MYSORE	66	HV1	TARIPURA_66	13:11	13:31	0:20	LINE CLEAR AVAILED
586	15-Feb-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	10:38	13:10	2:32	LINE FAULT
587	15-Feb-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	10:38	11:52	1:14	LINE CLEAR AVAILED
588	15-Feb-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	12:50	13:10	0:19	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
589	15-Feb-2020	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	6:29	7:03	0:33	TRANSFORMER FAULT
590	15-Feb-2020	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	HONNALLI_220	12:50	14:40	1:50	LINE CLEAR AVOIDED
591	15-Feb-2020	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	7:05	10:45	3:39	LOAD CURTAILMENT
592	15-Feb-2020	TUMKUR	220	THALLAK 220kV-HIRIYUR	THALLAKK_220	12:30	17:09	4:38	LINE CLEAR AVOIDED
593	15-Feb-2020	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	15:45	17:34	1:48	LINE CLEAR AVOIDED
594	15-Feb-2020	TUMKUR	110	TR-1	BIDARE_110	5:45	5:50	0:05	TRANSFORMER FAULT
595	15-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110 , TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	15:06	15:15	0:08	LINE FAULT
596	15-Feb-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110 , SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	13:12	14:28	1:16	LINE CLEAR AVOIDED
597	15-Feb-2020	TUMKUR	66	TR-2	CHELURU_66	12:34	13:27	0:53	LINE CLEAR AVOIDED
598	15-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:15	14:21	0:06	LINE FAULT
599	15-Feb-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66 HARIHAR_66, HARIHAR_66	15:39	17:16	1:37	LINE FAULT
600	15-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HOSPET_66, BANUVALLI_66, NANDIGUDI_66	7:25	11:44	4:18	LINE CLEAR AVOIDED
601	15-Feb-2020	TUMKUR	66	TR-1	HANAGAL_66	10:13	14:38	4:25	LINE CLEAR AVOIDED
602	15-Feb-2020	TUMKUR	66	HARIHARA-DAVANGERE SRS	HARIHAR_66	10:50	12:04	1:14	MAIN SUPPLY FAILURE
603	15-Feb-2020	TUMKUR	66	TR-1	HARIHAR_66	10:50	12:04	1:14	MAIN SUPPLY FAILURE
604	15-Feb-2020	TUMKUR	66	TR-2	HARIHAR_66	10:50	12:04	1:14	MAIN SUPPLY FAILURE
605	15-Feb-2020	TUMKUR	66	HIREGUNTANUR- SIRIGERE	HIREGUNTANUR_66	11:26	13:06	1:40	LINE CLEAR AVOIDED
606	15-Feb-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:34	7:05	0:31	HAND TRIPPED
607	15-Feb-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	6:35	7:41	1:06	LINE CLEAR AVOIDED
608	15-Feb-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	6:35	7:07	0:32	HAND TRIPPED
609	15-Feb-2020	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	6:35	7:07	0:32	HAND TRIPPED
610	15-Feb-2020	TUMKUR	66	HIRIYURKV 220kV- SUZLON 2	SUZLON1_IPP_66	8:01	8:03	0:02	HAND TRIPPED
611	15-Feb-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	8:21	8:52	0:30	LOAD CURTAILMENT
612	15-Feb-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:09	11:04	0:55	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
613	15-Feb-2020	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GORRENNAHALLI_66, SASUVEHALLI_66,CHANNAGI	12:55	13:11	0:16	LOAD CURTAILMENT
614	15-Feb-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	RI_66	7:50	8:29	0:39	LOAD CURTAILMENT
615	15-Feb-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGI	10:18	10:30	0:11	LOAD CURTAILMENT
616	15-Feb-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	RI_66	12:55	13:10	0:14	LOAD CURTAILMENT
617	15-Feb-2020	TUMKUR	66	TR-1	PAVAGADA_220	8:45	9:04	0:19	TRANSFORMER FAULT
618	15-Feb-2020	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	17:07	17:58	0:51	HAND TRIPPED
619	15-Feb-2020	TUMKUR	66	THOVINAKERE-KORA	THOVINAKERE_66	9:10	9:22	0:12	LINE FAULT
620	16-Feb-2020	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	11:15	11:21	0:06	TRANSFORMER FAULT
621	16-Feb-2020	BAGALKOT	220	220/110KV,HV3	BAGEWADI_220,NIDUNGUN DI_110,SINDAPUR_110, MUNDARGI_110,SINGATALU	10:50	11:00	0:10	TRANSFORMER FAULT
622	16-Feb-2020	BAGALKOT	110	110/33KV,HV2	R_33	14:01	14:10	0:09	TRANSFORMER FAULT
623	16-Feb-2020	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	6:11	12:19	6:08	NFBC ISSUED
624	16-Feb-2020	BAGALKOT	110	MK HUBLI -KITTUR	KITTUR_110	9:46	10:19	0:33	LINE FAULT
625	16-Feb-2020	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	16:20	16:34	0:14	TRANSFORMER FAULT
626	16-Feb-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	10:07	10:11	0:04	TRANSFORMER FAULT
627	16-Feb-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	15:18	15:24	0:06	TRANSFORMER FAULT
628	16-Feb-2020	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	16:50	17:10	0:20	TRANSFORMER FAULT
629	16-Feb-2020	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	9:46	18:01	8:15	LINE FAULT
630	16-Feb-2020	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	13:08	18:01	4:53	LINE CLEAR AVAILED
631	16-Feb-2020	BAGALKOT	110	110/11KV,HV2	HATTARGI_110	10:43	11:35	0:52	LINE CLEAR AVAILED
632	16-Feb-2020	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	12:11	12:14	0:03	TRANSFORMER FAULT
633	16-Feb-2020	BAGALKOT	110	SPV-MUKARTHAL	MUKARTIHAL_110	19:22	23:59	4:37	LINE CLEAR AVAILED
634	16-Feb-2020	BENGALURU	66	MALUR 220 -KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:03	9:07	0:04	LINE FAULT
635	16-Feb-2020	BENGALURU	220	HV1	CHINTAMANI 220	7:05	10:12	3:07	TRANSFORMER FAULT
636	16-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR, YENNIGADALE, CHELUR,	8:00	8:15	0:15	MAIN SUPPLY FAILURE
637	16-Feb-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	CHAKAVELU TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	8:00	8:15	0:15	MAIN SUPPLY FAILURE
638	16-Feb-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	CHAKAVELU TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	8:00	8:15	0:15	MAIN SUPPLY FAILURE
639	16-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR, YENNIGADALE, CHELUR,	10:15	10:25	0:10	MAIN SUPPLY FAILURE
640	16-Feb-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	CHAKAVELU TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:15	10:24	0:09	MAIN SUPPLY FAILURE
641	16-Feb-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	CHAKAVELU TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:15	10:23	0:08	MAIN SUPPLY FAILURE
642	16-Feb-2020	BENGALURU	220	HV1	CHINTAMANI 220	13:22	14:34	1:12	TRANSFORMER FAULT
643	16-Feb-2020	BENGALURU	66	HV1	NANGLI	21:37	21:48	0:10	LINE CLEAR AVAILED
644	16-Feb-2020	BENGALURU	66	TEKAL - KGF	TEKAL, BUDIKOTE	5:55	6:15	0:19	LINE FAULT
645	16-Feb-2020	BENGALURU	66	HV1	NANGLI	21:37	21:48	0:10	LINE CLEAR AVAILED
646	16-Feb-2020	BENGALURU	66	HV1	VOLVO	9:07	9:10	0:02	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
647	16-Feb-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	11:17	16:05	4:48	LINE CLEAR AVAILED
648	16-Feb-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	16:05	18:57	2:52	LINE FAULT
649	16-Feb-2020	BENGALURU	220	HV2	YARANDANAHALLI 220	16:05	16:31	0:26	TRANSFORMER FAULT
650	16-Feb-2020	BENGALURU	220	HV3	YARANDANAHALLI 220	16:05	16:31	0:26	TRANSFORMER FAULT
651	16-Feb-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	16:05	16:35	0:30	LINE FAULT
652	16-Feb-2020	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	16:05	16:40	0:35	LINE FAULT
653	16-Feb-2020	BENGALURU	66	ANEKAL - YARANDANAHALLI 220	ANEKAL	16:40	18:45	2:05	LINE FAULT
654	16-Feb-2020	BENGALURU	66	YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	16:05	16:35	0:30	LINE FAULT
655	16-Feb-2020	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	7:08	7:18	0:10	LOAD CHANGE OVER
656	16-Feb-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	7:20	7:26	0:06	LOAD CHANGE OVER
657	16-Feb-2020	BENGALURU	66	HV1	JIGANI	11:31	11:39	0:08	LINE CLEAR AVAILED
658	16-Feb-2020	BENGALURU	66	HV2	JIGANI	9:04	9:06	0:02	LINE CLEAR AVAILED
659	16-Feb-2020	BENGALURU	66	HV3	JIGANI	9:04	9:06	0:02	LINE CLEAR AVAILED
660	16-Feb-2020	BENGALURU	66	HV2	JIGANI 220	14:07	14:09	0:02	LINE CLEAR AVAILED
661	16-Feb-2020	BENGALURU	66	JIGANI 66 - SOMANAHALLI	JIGANI 66	11:35	11:45	0:10	LOAD CHANGE OVER
662	16-Feb-2020	BENGALURU	66	JIGANI 66 - YARANDANAHALLI	JIGANI 66	14:00	14:05	0:05	LOAD CHANGE OVER
663	16-Feb-2020	BENGALURU	66	D CROSS - NRS 220	D CROSS	11:34	14:52	3:18	LINE CLEAR AVAILED
664	16-Feb-2020	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	5:09	5:15	0:06	MAIN SUPPLY FAILURE
665	16-Feb-2020	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	5:09	5:15	0:06	MAIN SUPPLY FAILURE
666	16-Feb-2020	BENGALURU	220	EDC 220 - HAL 220	EDC 220	5:09	5:50	0:41	LINE FAULT
667	16-Feb-2020	BENGALURU	220	HV1	EDC 220 - AUSTIN TOWN	5:09	5:50	0:41	TRANSFORMER FAULT
668	16-Feb-2020	BENGALURU	66	EDC 220 - AUSTIN TOWN	KORMANGALA	5:09	5:50	0:41	MAIN SUPPLY FAILURE
669	16-Feb-2020	BENGALURU	66	EDC 220 - BMTC	BMTC	5:09	5:50	0:41	MAIN SUPPLY FAILURE
670	16-Feb-2020	BENGALURU	66	EDC 220 - B STATION	B STATION	5:09	5:50	0:41	MAIN SUPPLY FAILURE
671	16-Feb-2020	BENGALURU	220	EDC 220 - NIMHANS 220	NIMHANS 220	5:09	5:40	0:31	MAIN SUPPLY FAILURE
672	16-Feb-2020	BENGALURU	220	HAL 220 - EDC 220	EDC 220 - BAGMANGALURU TECH PARK, GTRF	5:09	23:59	18:50	LINE FAULT
673	16-Feb-2020	BENGALURU	66	HAL 220 - HOODY 2	(EHT)	14:17	14:38	0:21	LINE CLEAR AVAILED
674	16-Feb-2020	BENGALURU	220	HV1	KHODAYS 220	6:02	6:32	0:30	TRANSFORMER FAULT
675	16-Feb-2020	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	6:02	6:32	0:30	MAIN SUPPLY FAILURE
676	16-Feb-2020	BENGALURU	66	HV1	ANJANAPURA	6:02	6:32	0:30	MAIN SUPPLY FAILURE
677	16-Feb-2020	BENGALURU	66	HV2	ANJANAPURA	6:02	6:32	0:30	MAIN SUPPLY FAILURE
678	16-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA JAYANAGAR, NATIONAL COLLEGE,	5:09	5:40	0:31	MAIN SUPPLY FAILURE
679	16-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	PADMANABHANAGAR	5:09	5:40	0:31	MAIN SUPPLY FAILURE
680	16-Feb-2020	BENGALURU	66	ADUGODI - HAL 2	ADUGODI	22:20	22:40	0:20	LOAD CHANGE OVER
681	16-Feb-2020	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	5:32	5:37	0:05	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
682	16-Feb-2020	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	20:02	20:11	0:09	LOAD CHANGE OVER
683	16-Feb-2020	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	11:35	11:50	0:15	LOAD CHANGE OVER
684	16-Feb-2020	BENGALURU	66	BG ROAD - JIGANI 220	BG ROAD	13:52	13:58	0:06	LOAD CHANGE OVER
685	16-Feb-2020	BENGALURU	66	BYADARHALLI - T G HALLI	BYADARHALLI, KODIGENAHALLI	13:06	14:49	1:43	LINE CLEAR AVAILED
686	16-Feb-2020	BENGALURU	66	ELITE PROMENEDE -RBI	ELITE PROMENEDE	10:48	10:53	0:05	LOAD CHANGE OVER
687	16-Feb-2020	BENGALURU	66	ELITE PROMENEDE -KHODAYS 220	ELITE PROMENEDE	18:27	18:30	0:03	LOAD CHANGE OVER
688	16-Feb-2020	BENGALURU	66	ELITE PROMENEDE -RBI	ELITE PROMENEDE	17:50	17:56	0:06	LOAD CHANGE OVER
689	16-Feb-2020	BENGALURU	66	ELITE PROMENEDE -KHODAYS 220	ELITE PROMENEDE	21:03	21:09	0:06	LOAD CHANGE OVER
690	16-Feb-2020	BENGALURU	66	HV1	EPIP 220	6:14	6:33	0:19	TRANSFORMER FAULT
691	16-Feb-2020	BENGALURU	66	R R NAGAR - SUBRAMANYAPURA 220	R R NAGAR	10:35	10:40	0:05	LOAD CHANGE OVER
692	16-Feb-2020	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	21:15	21:23	0:08	LOAD CHANGE OVER
693	16-Feb-2020	BENGALURU	66	R R NAGAR - SUBRAMANYAPURA 220	R R NAGAR	23:25	23:30	0:05	LOAD CHANGE OVER
694	16-Feb-2020	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	6:05	6:15	0:10	LOAD CHANGE OVER
695	16-Feb-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	10:45	10:55	0:10	LOAD CHANGE OVER
696	16-Feb-2020	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	18:25	18:35	0:10	LOAD CHANGE OVER
697	16-Feb-2020	GULBARGA	110	HV2	HATTI_110	7:13	7:21	0:08	TRANSFORMER FAULT
698	16-Feb-2020	GULBARGA	110	HV2	HATTI_110	9:08	9:16	0:08	TRANSFORMER FAULT
699	16-Feb-2020	GULBARGA	110	LADHA-RNWSLR	LADHA_110	10:30	10:51	0:21	LINE FAULT
700	16-Feb-2020	GULBARGA	110	BHALKI-LADHA	LADHA_110	9:10	10:15	1:05	LINE FAULT
701	16-Feb-2020	GULBARGA	110	SINDHANOOR220-SINDHANOOR	SINDHANOOR_110	18:35	18:45	0:10	MAIN SUPPLY FAILURE
702	16-Feb-2020	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	18:33	18:45	0:12	LINE FAULT
703	16-Feb-2020	GULBARGA	110	SINDHANOOR-PGLR_WIND(NIRLOOTI_IPP)	SINDHANOOR_220	22:39	22:50	0:11	LINE FAULT
704	16-Feb-2020	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	10:19	16:29	6:10	LINE CLEAR AVAILED
705	16-Feb-2020	HASSAN	220	GER SOPA-TALGUPA2	gerusoppa_gen	10:34	16:38	6:04	LINE CLEAR AVAILED
706	16-Feb-2020	HASSAN	220	MRSSH M-VARAH I1	MRS MG_220	0:00	17:07	17:07	LINE FAULT
707	16-Feb-2020	HASSAN	220	MRSSH M-VARAH I2	MRS MG_220	0:00	17:25	17:25	LINE FAULT
708	16-Feb-2020	HASSAN	220	MRSSH M-VARAH I2	MRS MG_220	18:01	18:25	0:24	LINE FAULT
709	16-Feb-2020	HASSAN	220	MRSSH M-ANTR SNH	MRS MG_220	18:01	18:29	0:28	LINE FAULT
710	16-Feb-2020	HASSAN	220	MRSSH M-HASSAN	MRS MG_220	18:01	18:29	0:28	LINE FAULT
711	16-Feb-2020	HASSAN	220	MRSSH M-HONNALLI	MRS MG_220	18:01	18:40	0:39	LINE FAULT
712	16-Feb-2020	HASSAN	220	MRSSH M-HSN4001	MRS MG_220	18:01	18:29	0:28	LINE FAULT
713	16-Feb-2020	HASSAN	220	HV1	MRS MG_220	18:01	18:30	0:29	TRANSFORMER FAULT
714	16-Feb-2020	HASSAN	220	HV2	MRS MG_220	18:01	18:31	0:30	TRANSFORMER FAULT
715	16-Feb-2020	HASSAN	220	HV3	MRS MG_220	18:02	18:30	0:28	TRANSFORMER FAULT
716	16-Feb-2020	HASSAN	220	MRSSH M-KADUR	MRS MG_220	18:01	18:29	0:28	LINE FAULT
717	16-Feb-2020	HASSAN	220	MRSSH M-KBCRS	MRS MG_220	18:01	18:29	0:28	LINE FAULT
718	16-Feb-2020	HASSAN	220	MRSSH M-SHARAVATHY1	MRS MG_220	18:01	18:29	0:28	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
719	16-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	18:01	18:29	0:28	LINE FAULT
720	16-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	18:01	18:29	0:28	LINE FAULT
721	16-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	18:01	18:29	0:28	LINE FAULT
722	16-Feb-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	18:01	18:39	0:38	LINE FAULT
723	16-Feb-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	18:01	18:39	0:38	LINE FAULT
724	16-Feb-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:32	16:39	6:07	LINE CLEAR AVAILED
725	16-Feb-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	0:00	17:07	17:07	LINE FAULT
726	16-Feb-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	0:00	17:25	17:25	LINE FAULT
727	16-Feb-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	18:01	23:59	5:58	LINE FAULT
728	16-Feb-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	18:00	18:30	0:30	LOAD CURTAILMENT
729	16-Feb-2020	HASSAN	110	SAGARA-ALKLA	SAGARA_110	18:24	18:49	0:25	LOAD CURTAILMENT
730	16-Feb-2020	HASSAN	110	SAGARA-IDLE	SAGARA_110	18:32	19:14	0:42	LOAD CURTAILMENT
731	16-Feb-2020	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	18:15	18:38	0:23	LINE FAULT
732	16-Feb-2020	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	18:15	18:38	0:23	LINE FAULT
733	16-Feb-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	18:15	18:54	0:39	LINE FAULT
734	16-Feb-2020	HASSAN	110	LV1	MRSMSG_220	18:13	18:30	0:17	TRANSFORMER FAULT
735	16-Feb-2020	HASSAN	110	LV2	MRSMSG_220	18:13	18:31	0:18	TRANSFORMER FAULT
736	16-Feb-2020	HASSAN	110	LV3	MRSMSG_220	18:13	18:30	0:17	TRANSFORMER FAULT
737	16-Feb-2020	HASSAN	110	MRSSHM-MPM	MRSMSG_220	18:16	18:36	0:20	LINE FAULT
738	16-Feb-2020	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	18:01	18:36	0:35	LINE FAULT
739	16-Feb-2020	HASSAN	110	MRSSHM-SS1	MRSMSG_220	18:15	18:32	0:17	LINE FAULT
740	16-Feb-2020	HASSAN	110	MRSSHM-SS2	MRSMSG_220	18:15	18:33	0:18	LINE FAULT
741	16-Feb-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	18:15	18:34	0:19	LINE FAULT
742	16-Feb-2020	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	18:15	18:34	0:19	LINE FAULT
743	16-Feb-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	18:01	18:35	0:34	LINE FAULT
744	16-Feb-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	18:01	18:35	0:34	LINE FAULT
745	16-Feb-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	9:01	17:06	8:05	NFBC ISSUED
746	16-Feb-2020	HASSAN	66	MATTA NAV-DIDGTHL	MATTA NAVILE_66	17:01	17:19	0:18	HAND TRIPPED
747	16-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	9:00	17:06	8:06	LINE CLEAR AVAILED
748	16-Feb-2020	HASSAN	66	HV1	SHRAVANABELAGOLA_66	17:30	17:38	0:08	TRANSFORMER FAULT
749	16-Feb-2020	MYSORE	66	HV1	FTS_66	10:00	17:47	7:46	LINE CLEAR AVAILED
750	16-Feb-2020	MYSORE	66	HV2	FTS_66	10:00	17:47	7:46	LINE CLEAR AVAILED
751	16-Feb-2020	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66	7:19	8:00	0:40	LINE CLEAR AVAILED
752	16-Feb-2020	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	7:19	8:01	0:41	LINE CLEAR AVAILED
753	16-Feb-2020	MYSORE	66	GUNDLUPETE-KABALLI	HANGLA_66 BHARGI_66 GUNDULPET_66	7:19	8:00	0:40	LINE CLEAR AVAILED
754	16-Feb-2020	MYSORE	66	GUNDLUPETE-CR NAGARA	HANGLA_66 BHARGI_66 GUNDULPET_66	7:19	8:00	0:40	LINE CLEAR AVAILED
755	16-Feb-2020	MYSORE	66	HV1	GUNDULPET_66 NANJANGUD_66	7:18	8:02	0:43	LINE CLEAR AVAILED
756	16-Feb-2020	MYSORE	66	KADAKOLA-NANJANGUD 1	THANDYA_66	10:04	18:15	8:11	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
757	16-Feb-2020	MYSORE	66	KADAKOLA-NANJANGUD 2	NANJANGUDU_66 THANDYA_66	10:04	18:17	8:13	LINE CLEAR AVAILED
758	16-Feb-2020	MYSORE	66	HV1	SATHEGALA_66	13:23	13:54	0:30	LINE CLEAR AVAILED
759	16-Feb-2020	MYSORE	66	HV2	SANTHEMARAHALLI_66	9:19	19:00	9:40	TRANSFORMER FAULT
760	16-Feb-2020	MYSORE	66	HV5	SFCSHIVA_66	16:06	23:59	7:52	LINE CLEAR AVAILED
761	16-Feb-2020	TUMKUR	110	HONNAVALI 110-ADAN SOLAR_	ADAN SOLAR_IPP_66	18:01	18:12	0:11	LINE FAULT
762	16-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	21:44	21:47	0:03	TRANSFORMER FAULT
763	16-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:24	18:43	0:19	LINE FAULT
764	16-Feb-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	19:03	19:14	0:10	LINE FAULT
765	16-Feb-2020	TUMKUR	66	TR-2	NITTUR_220	4:11	4:32	0:20	TRANSFORMER FAULT
766	17-Feb-2020	BAGALKOT	110	AMBEWADI-NAGJHARI 1	AMBEWADI_220	10:55	12:51	1:56	LINE CLEAR AVAILED
767	17-Feb-2020	BAGALKOT	110	AMBEWADI-NK 2	KAVALLWAD_110	17:01	17:07	0:06	HAND TRIPPED
768	17-Feb-2020	BAGALKOT	110	110/11KV,HV 1	AINAPUR_110	11:52	12:06	0:14	TRANSFORMER FAULT
769	17-Feb-2020	BAGALKOT	110	ANKOLA-ARGA	ARGA_110	17:15	18:34	1:19	LINE CLEAR AVAILED
770	17-Feb-2020	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	9:13	9:18	0:05	HAND TRIPPED
771	17-Feb-2020	BAGALKOT	220	220/110KV,HV1&LV1	BIDNAL_220	12:04	17:21	5:17	LINE CLEAR AVAILED
772	17-Feb-2020	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	11:42	18:03	6:21	LINE CLEAR AVAILED
773	17-Feb-2020	BAGALKOT	110	BIDNAL220-GADAG ROAD	GADAG ROAD_110	10:09	18:09	8:00	LINE CLEAR AVAILED
774	17-Feb-2020	BAGALKOT	110	BIDNAL220-PH COMPOUND	PH COMPOUND_110	11:43	18:06	6:23	LINE CLEAR AVAILED
775	17-Feb-2020	BAGALKOT	110	BIDNAL-HUBLI2	BIDNAL_220	17:22	23:59	6:37	LINE CLEAR AVAILED
776	17-Feb-2020	BAGALKOT	220	220/110KV,HV2&LV2	BIJAPUR_220	13:25	14:14	0:49	HAND TRIPPED
777	17-Feb-2020	BAGALKOT	220	220/110KV,HV1&LV1	BIJAPUR_220	14:17	15:13	0:56	HAND TRIPPED
778	17-Feb-2020	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	0:00	16:00	16:00	LINE CLEAR AVAILED
779	17-Feb-2020	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	17:15	17:33	0:18	TRANSFORMER FAULT
780	17-Feb-2020	BAGALKOT	110	110/11KV, HV1	UTTUR_110	21:30	23:59	2:29	TRANSFORMER FAULT
781	17-Feb-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_110	17:19	17:43	0:24	LINE CLEAR AVAILED
782	17-Feb-2020	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	8:44	8:59	0:15	LINE FAULT
783	17-Feb-2020	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	9:56	18:05	8:09	LINE CLEAR AVAILED
784	17-Feb-2020	BAGALKOT	110	110/11KV, HV3	MUNDARGI_110	11:30	12:44	1:14	LINE CLEAR AVAILED
785	17-Feb-2020	BAGALKOT	110	KNM SOLAR- MUDDEBIHAL	MUDDEBIHAL_110	11:32	14:10	2:38	LINE FAULT
786	17-Feb-2020	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	16:35	17:43	1:08	LINE FAULT
787	17-Feb-2020	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGADA_33, KARADI_33	8:02	8:09	0:07	TRANSFORMER FAULT
788	17-Feb-2020	BAGALKOT	110	KUDALSANGAM- HUNGUND	HUNGUND_110	15:49	15:52	0:03	LINE FAULT
789	17-Feb-2020	BAGALKOT	110	110/11KV, HV2	HATTARGI_110	15:40	16:35	0:55	LINE CLEAR AVAILED
790	17-Feb-2020	BAGALKOT	110	110/11KV, HV2	HANGAL_110	14:18	14:27	0:09	HAND TRIPPED
791	17-Feb-2020	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	14:36	14:41	0:05	HAND TRIPPED
792	17-Feb-2020	BENGALURU	66	HV2	WELCAST STEEL	21:35	21:50	0:15	TRANSFORMER FAULT



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
793	17-Feb-2020	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	17:38	18:14	0:36	MAIN SUPPLY FAILURE
794	17-Feb-2020	BENGALURU	220	MALUR 220 - KOLAR 3	SARJAPURA 220, VIKAS TEC PARK 220	17:38	18:15	0:37	MAIN SUPPLY FAILURE
795	17-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKALM BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML(EHT), KYASAMBALLI, DODDAKARI	11:49	13:28	1:39	LINE CLEAR AVAILED
796	17-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, MAASTHI, DEVGONDHI,	15:19	15:28	0:09	LINE FAULT
797	17-Feb-2020	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR	19:00	19:05	0:05	LINE FAULT
798	17-Feb-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	17:38	18:14	0:36	MAIN SUPPLY FAILURE
799	17-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:38	18:19	0:41	MAIN SUPPLY FAILURE
800	17-Feb-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:38	18:19	0:41	MAIN SUPPLY FAILURE
801	17-Feb-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	(EHT)	17:38	18:20	0:42	MAIN SUPPLY FAILURE
802	17-Feb-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MAASTHI, DEVGONDHI,	17:38	18:20	0:42	MAIN SUPPLY FAILURE
803	17-Feb-2020	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR	17:38	18:20	0:42	MAIN SUPPLY FAILURE
804	17-Feb-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	17:39	18:20	0:41	MAIN SUPPLY FAILURE
805	17-Feb-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:39	18:20	0:41	MAIN SUPPLY FAILURE
806	17-Feb-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	17:39	18:20	0:41	MAIN SUPPLY FAILURE
807	17-Feb-2020	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	17:39	18:10	0:31	MAIN SUPPLY FAILURE
808	17-Feb-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	17:39	18:10	0:31	MAIN SUPPLY FAILURE
809	17-Feb-2020	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	17:39	18:13	0:34	MAIN SUPPLY FAILURE
810	17-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL(EHT), SUGUTUR, SM MANGALA	17:39	18:13	0:34	MAIN SUPPLY FAILURE
811	17-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR, THAYLUR, TAMAKA, NG	17:39	18:14	0:35	MAIN SUPPLY FAILURE
812	17-Feb-2020	BENGALURU	66	KOLAR 220 - TYALUR	HULKUR, MALLANAYAKANAHALLI	17:39	18:14	0:35	MAIN SUPPLY FAILURE
813	17-Feb-2020	BENGALURU	66	KOLAR 220 - MULBAGALU	AVANI, MULBAGALU	17:39	18:14	0:35	MAIN SUPPLY FAILURE
814	17-Feb-2020	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPETE, KEMBODI, MUDIYANUR, H	17:39	18:15	0:36	MAIN SUPPLY FAILURE
815	17-Feb-2020	BENGALURU	66	KOLAR 220 - NANGLI	GOLLAHALLI, BAIRAKURU, NANGLI	17:39	18:15	0:36	MAIN SUPPLY FAILURE
816	17-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO(EHT), DAALSNUR	17:39	18:16	0:37	MAIN SUPPLY FAILURE
817	17-Feb-2020	BENGALURU	66	HV1	AREHALLI	11:09	11:12	0:03	LINE CLEAR AVAILED
818	17-Feb-2020	BENGALURU	66	HV2	ELECTRONIC CITY	16:54	17:43	0:49	LINE CLEAR AVAILED
819	17-Feb-2020	BENGALURU	66	HOODY 220 - ITI	ITI	17:38	17:52	0:14	LINE FAULT
820	17-Feb-2020	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	17:38	17:52	0:14	LINE FAULT
821	17-Feb-2020	BENGALURU	66	HOODY 220 - ITI	ITI	23:58	23:59	0:01	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
822	17-Feb-2020	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	23:58	23:59	0:01	LINE FAULT
823	17-Feb-2020	BENGALURU	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	9:19	10:14	0:55	LINE FAULT
824	17-Feb-2020	BENGALURU	66	HV1	RAJANUKUNTE	11:16	12:59	1:43	LINE CLEAR AVAILED
825	17-Feb-2020	BENGALURU	66	HV2	RAJANUKUNTE	11:17	12:59	1:42	LINE CLEAR AVAILED
826	17-Feb-2020	BENGALURU	66	HV2	REMCO	7:24	7:25	0:01	LOAD CHANGE OVER
827	17-Feb-2020	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	0:02	0:05	0:03	LOAD CHANGE OVER
828	17-Feb-2020	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	17:39	18:08	0:29	MAIN SUPPLY FAILURE
829	17-Feb-2020	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	17:39	18:08	0:29	MAIN SUPPLY FAILURE
830	17-Feb-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	17:39	18:09	0:30	LINE CLEAR AVAILED
831	17-Feb-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	17:39	18:09	0:30	LINE CLEAR AVAILED
832	17-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:39	18:20	0:41	LINE CLEAR AVAILED
833	17-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI, YENNIGADALE, CHELUR,	17:39	18:20	0:41	LINE CLEAR AVAILED
834	17-Feb-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	CHAKAVELU TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA, IRAGAMPALLI, M	17:39	18:20	0:41	LINE CLEAR AVAILED
835	17-Feb-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	CHAKAVELU TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA, IRAGAMPALLI, M	17:39	18:20	0:41	LINE CLEAR AVAILED
836	17-Feb-2020	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	GOLLAHALLI	17:39	18:20	0:41	LINE CLEAR AVAILED
837	17-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	8:53	8:55	0:02	LINE CLEAR AVAILED
838	17-Feb-2020	BENGALURU	66	HV2	KIADB 220	8:06	9:19	1:13	LINE CLEAR AVAILED
839	17-Feb-2020	BENGALURU	66	HV2	KIADB 220	13:30	14:09	0:39	LINE CLEAR AVAILED
840	17-Feb-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	18:11	18:19	0:08	LINE FAULT
841	17-Feb-2020	BENGALURU	66	H GOLLAHALLI - KOLAR 220	H GOLLAHALLI	3:00	3:10	0:10	LINE FAULT
842	17-Feb-2020	BENGALURU	66	HV1	H GOLLAHALLI	3:00	3:15	0:15	TRANSFORMER FAULT
843	17-Feb-2020	BENGALURU	66	H GOLLAHALLI - KOLAR 220	H GOLLAHALLI	14:30	14:40	0:10	LINE FAULT
844	17-Feb-2020	BENGALURU	66	HV1	H GOLLAHALLI	14:30	14:40	0:10	TRANSFORMER FAULT
845	17-Feb-2020	BENGALURU	66	HV1	A STATION 66	13:12	23:59	10:47	TRANSFORMER FAULT
846	17-Feb-2020	BENGALURU	66	HV2	A STATION 66	13:12	23:59	10:47	TRANSFORMER FAULT
847	17-Feb-2020	GULBARGA	110	GABUR-RAICHUR	GABUR_110	12:20	13:35	1:15	LINE CLEAR AVAILED
848	17-Feb-2020	GULBARGA	110	HV2	HATTI_110	7:40	7:47	0:07	TRANSFORMER FAULT
849	17-Feb-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110	1:15	1:20	0:05	LINE FAULT
850	17-Feb-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110	5:55	6:00	0:05	LINE FAULT
851	17-Feb-2020	GULBARGA	110	HV1	SINDHANOOR_110	10:00	10:30	0:30	LINE CLEAR AVAILED
852	17-Feb-2020	GULBARGA	110	HV2	SINDHANOOR_110	10:00	17:30	7:30	LINE CLEAR AVAILED
853	17-Feb-2020	GULBARGA	110	HV2	TEKKALKOTE_110	6:50	6:55	0:05	TRANSFORMER FAULT
854	17-Feb-2020	GULBARGA	110	HV1	TEKKALKOTE_110	11:05	11:10	0:05	TRANSFORMER FAULT
855	17-Feb-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAIDAPUR_110	6:13	6:19	0:06	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
856	17-Feb-2020	GULBARGA	220	LINGAPUR-KUSHTAGI	LINGAPUR_220	15:10	18:00	2:50	LINE CLEAR AVAILED
857	17-Feb-2020	GULBARGA	220	HV2	ALIPUR_220	11:52	12:33	0:41	HAND TRIPPED
858	17-Feb-2020	GULBARGA	110	ALIPUR-BELLARYNORTH	BELLARYNORTH_110,SOMAS AMUDRA_110,MOKA_110,P DHALLI_110,BISHALLI_110,JA NAKI_IPP,BASAISTEELAACC_I PP	6:46	6:50	0:04	LINE FAULT
859	17-Feb-2020	GULBARGA	110	MALLAT-BYAGWAT1	MALLAT_220	19:50	20:08	0:18	LINE FAULT
860	17-Feb-2020	GULBARGA	220	ALIPUR-BTPS	NEELGUNDA_220,GUTTI_220	16:48	18:08	1:20	LINE CLEAR AVAILED
861	17-Feb-2020	GULBARGA	220	ALIPUR-RAGALPADU	NEELGUNDA_220,GUTTI_220	18:45	19:26	0:41	LINE CLEAR AVAILED
862	17-Feb-2020	GULBARGA	220	HV1	ALIPUR_220	19:00	19:19	0:19	TRANSFORMER FAULT
863	17-Feb-2020	GULBARGA	220	HV2	ALIPUR_220	19:00	19:15	0:15	TRANSFORMER FAULT
864	17-Feb-2020	GULBARGA	110	SIDHANOOR220-PGLR_WIND	SIDHANOOR_220	22:14	22:35	0:21	LINE FAULT
865	17-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, ASKI_110, HUNSGI_110	19:50	20:00	0:10	LINE FAULT
866	17-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, ASKI_110, HUNSGI_110	21:50	22:00	0:10	LINE FAULT
867	17-Feb-2020	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	15:15	16:55	1:40	MAIN SUPPLY FAILURE
868	17-Feb-2020	GULBARGA	220	HV1	SHAHAPUR_220	11:28	11:31	0:03	LINE CLEAR AVAILED
869	17-Feb-2020	GULBARGA	110	HV1	SINDHANOOR_110	17:35	18:20	0:45	LINE CLEAR AVAILED
870	17-Feb-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	0:00	8:34	8:34	LINE FAULT
871	17-Feb-2020	HASSAN	110	HV2	ANANDAPURA_110	0:00	18:59	18:59	TRANSFORMER FAULT
872	17-Feb-2020	HASSAN	110	HV1	JAVAGAL_110	11:55	12:57	1:02	LINE CLEAR AVAILED
873	17-Feb-2020	HASSAN	110	HV2	JAVAGAL_110	11:55	12:57	1:02	LINE CLEAR AVAILED
874	17-Feb-2020	HASSAN	110	JOG110-AMBTR2	JOG_110	10:21	23:59	13:38	LINE CLEAR AVAILED
875	17-Feb-2020	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	11:51	17:45	5:54	LINE CLEAR AVAILED
876	17-Feb-2020	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	17:47	23:59	6:12	LINE CLEAR AVAILED
877	17-Feb-2020	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	12:00	12:07	0:07	LINE FAULT
878	17-Feb-2020	HASSAN	110	HV2	KONAJE_110	12:00	12:11	0:11	LOAD CURTAILMENT
879	17-Feb-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	11:47	17:44	5:57	LINE CLEAR AVAILED
880	17-Feb-2020	HASSAN	66	HV1	SHRAVANABELAGOLA_66	13:26	13:32	0:06	TRANSFORMER FAULT
881	17-Feb-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	12:23	14:07	1:44	LINE FAULT
882	17-Feb-2020	MYSORE	66	MADHUVANAHALLY-PG PALYA	PGPALYA_66	7:24	7:30	0:06	LINE FAULT
883	17-Feb-2020	MYSORE	66	HV1	KHBCOLONY_66	12:19	15:03	2:43	LINE CLEAR AVAILED
884	17-Feb-2020	MYSORE	66	HV2	JYOTHINAGARA_66	15:28	15:51	0:23	LINE CLEAR AVAILED
885	17-Feb-2020	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI_220	12:37	16:20	3:42	LINE CLEAR AVAILED
886	17-Feb-2020	TUMKUR	110	TR-1	KBCROSS_220	21:33	22:18	0:45	TRANSFORMER FAULT
887	17-Feb-2020	TUMKUR	66	TR-1	BADAVANAHALLI_66	17:03	17:18	0:14	LINE CLEAR AVAILED
888	17-Feb-2020	TUMKUR	66	BUKKAPATNA-SIRA	BUKKAPATNA_66	12:38	14:32	1:54	LINE CLEAR AVAILED
889	17-Feb-2020	TUMKUR	66	TR-2	CHITRADURGA_66	11:26	18:50	7:24	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
890	17-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:43	8:04	0:20	LINE FAULT
891	17-Feb-2020	TUMKUR	66	KATTIGE- BEDRUGADDE	KATTIGE_66	2:07	2:11	0:04	LINE FAULT
892	17-Feb-2020	TUMKUR	66	KATTIGE- BEDRUGADDE	KATTIGE_66	12:48	17:35	4:46	LINE FAULT
893	17-Feb-2020	TUMKUR	66	TR-1	KATTIGE_66 RENEW WIND	10:47	18:31	7:44	TRANSFORMER FAULT
894	17-Feb-2020	TUMKUR	66	KATTIGE- RENEW WIND IPP	ENERGY_IPP_66	10:47	18:12	7:24	LINE FAULT
895	17-Feb-2020	TUMKUR	66	TR-2	MADHUGIRI_220	17:19	17:55	0:35	LINE CLEAR AVAILED
896	17-Feb-2020	TUMKUR	66	TR-1	MADHUGIRI_220	12:37	16:20	3:43	LINE CLEAR AVAILED
897	17-Feb-2020	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	12:36	16:20	3:43	LINE CLEAR AVAILED
898	17-Feb-2020	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	12:36	16:20	3:43	LINE CLEAR AVAILED
899	17-Feb-2020	TUMKUR	66	TR-2	NAYAKANAHATTI_66	7:58	8:32	0:34	LINE CLEAR AVAILED
900	17-Feb-2020	TUMKUR	66	TR-2	TELAGI_66	10:49	11:13	0:23	LINE CLEAR AVAILED