

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 23.10.2018 TO 29.10.2018

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
1	23-Oct-18	Bagalkot	110	110/11KV,HV1	ACHANUR_110	18:23	18:36	0:13	LOAD CURTAILMENT
2	23-Oct-18	Bagalkot	110	110/11KV,HV2	AINAPUR_110	18:23	18:29	0:06	LOAD CURTAILMENT
3	23-Oct-18	Bagalkot	110	110/11KV,HV2	AINAPUR_110	18:31	18:40	0:09	LOAD CURTAILMENT
4	23-Oct-18	Bagalkot	110	110/11KV,HV1	ATHARGA_110	18:24	18:37	0:13	LOAD CURTAILMENT
5	23-Oct-18	Bagalkot	110	110/33KV,HV3	UGAR KHUD_110	20:06	20:09	0:03	HAND TRIPPED
6	23-Oct-18	Bagalkot	110	UGAR KHUD-UGAR SUGAR	UGAR KHUD_110	20:06	20:13	0:07	HAND TRIPPED
7	23-Oct-18	Bagalkot	110	110/33KV,HV1	TIKOTA_110	18:31	18:42	0:11	LOAD CURTAILMENT
8	23-Oct-18	Bagalkot	110	110/11KV,HV2	SHIROL_110	18:13	18:27	0:14	HAND TRIPPED
9	23-Oct-18	Bagalkot	110	110/11KV,HV2	SANKESHWAR_110	9:45	15:13	5:28	HAND TRIPPED
10	23-Oct-18	Bagalkot	110	110/11KV,HV1	SANKESHWAR_110	10:35	15:13	4:38	HAND TRIPPED
11	23-Oct-18	Bagalkot	110	110/33KV,HV3	SANKESHWAR_110	11:26	15:12	3:46	HAND TRIPPED
12	23-Oct-18	Bagalkot	110	110/11KV,HV2	SANKESHWAR_110	18:23	18:45	0:22	LOAD CURTAILMENT
13	23-Oct-18	Bagalkot	110	GOPPANKOPPA 1-MRUTHYUNJAY NAGAR	MRUTHYUNJAY NAGAR_110	6:11	9:28	3:17	LINE FAULT
14	23-Oct-18	Bagalkot	110	DHARWAD BIO-NAVALGUND	NAVALGUND_110	8:02	9:04	1:02	LINE FAULT
15	23-Oct-18	Bagalkot	220	NAGJHARI 3-HUBLI 220	HUBLI_220	0:00	16:29	16:29	LINE CLEAR AVAILED
16	23-Oct-18	Bagalkot	110	110/11KV, HV4	GAJENDRAGAD_110	18:23	18:40	0:17	LOAD CURTAILMENT
17	23-Oct-18	Bagalkot	110	SHIRGUPPI SUGARS-KAGAWAD	KAGAWAD_110	20:05	20:10	0:05	HAND TRIPPED
18	23-Oct-18	Bagalkot	110	KUDACHI220-KUDACHI	KUDACHI_110	9:59	23:59	14:00	LINE CLEAR AVAILED
19	23-Oct-18	Bagalkot	110	KUDACHI220-UGARKHUD	UGARKHUD_110	9:59	19:45	9:46	LINE CLEAR AVAILED
20	23-Oct-18	Bagalkot	220	BIDNAL-NARENDRA	BIDNAL_220	8:08	11:38	3:30	LINE CLEAR AVAILED
21	23-Oct-18	Bagalkot	220	NAGJHARI-BIDNAL	BIDNAL_220	12:32	14:10	1:38	LINE CLEAR AVAILED
22	23-Oct-18	Bagalkot	110	GAMESHA-KULIGOD	KULIGOD_110	15:46	16:43	0:57	LINE CLEAR AVAILED
23	23-Oct-18	Bagalkot	220	LINGAPUR-GADAG	GADAG_220	7:52	15:36	7:44	LINE CLEAR AVAILED
24	23-Oct-18	Bagalkot	220	ARESS STEEL-GADAG	GADAG_220	8:04	19:35	11:31	LINE CLEAR AVAILED
25	23-Oct-18	Bagalkot	220	NARENDRA-HAVERI	HAVERI_220	8:08	11:40	3:32	LINE CLEAR AVAILED
26	23-Oct-18	Bagalkot	110	110/11KV, HV1	LAXMESHWAR_110	18:23	18:41	0:18	LOAD CURTAILMENT
27	23-Oct-18	Bagalkot	110	220/110KV, LV3	MAHALINGAPUR_220, HIDIKAL_110,RABKAVI_110, ITANAL_110	16:35	17:10	0:35	LINE CLEAR AVAILED
28	23-Oct-18	Bagalkot	110	110/11KV, HV2	MALGHAN(B)_110	16:09	17:11	1:02	LINE CLEAR AVAILED
29	23-Oct-18	Bagalkot	66	66/33KV, HV4	HARIHAR HOSPET_66	18:22	18:43	0:21	LOAD CURTAILMENT
30	23-Oct-18	Bagalkot	110	110/11KV, HV2	HIDIKAL_110	11:57	12:06	0:09	LINE CLEAR AVAILED
31	23-Oct-18	Bagalkot	110	110/33KV, HV3	HIDIKAL_110	18:23	18:47	0:24	LOAD CURTAILMENT
32	23-Oct-18	Bangalore	66	HV1	B G ROAD	16:48	17:31	0:43	LINE CLEAR AVAILED
33	23-Oct-18	Bangalore	66	HV2	DEVARABISANAHALLI	0:19	0:37	0:18	LINE CLEAR AVAILED
34	23-Oct-18	Bangalore	66	HV2	DEVARABISANAHALLI	7:30	7:53	0:23	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
35	23-Oct-18	Bangalore	66	HAL 220 - HOODY 1	KADUBISANAHALLI, ISRO(EHT)	13:39	15:21	1:42	LINE CLEAR AVAILED
36	23-Oct-18	Bangalore	66	BAGEPALLI - GOWRIBIDANUR 1	THIMMAMPALLI, SOMANATHPURA	15:45	17:19	1:34	LINE CLEAR AVAILED
37	23-Oct-18	Bangalore	66	BAGEPALLI - GOWRIBIDANUR 2	BAGEPALLI	15:44	16:43	0:59	LINE CLEAR AVAILED
38	23-Oct-18	Bangalore	66	HV2	BAGEPALLI	11:32	11:37	0:04	LINE CLEAR AVAILED
39	23-Oct-18	Bangalore	66	HV3	CHIKKABALLAPURA I/A	10:34	14:02	3:28	LINE CLEAR AVAILED
40	23-Oct-18	Bangalore	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	14:10	14:35	0:24	MAIN SUPPLY FAILURE
41	23-Oct-18	Bangalore	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	14:11	14:13	0:02	MAIN SUPPLY FAILURE
42	23-Oct-18	Bangalore	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	14:10	14:13	0:02	MAIN SUPPLY FAILURE
43	23-Oct-18	Bangalore	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	14:11	14:35	0:24	MAIN SUPPLY FAILURE
44	23-Oct-18	Bangalore	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	14:11	14:13	0:02	MAIN SUPPLY FAILURE
45	23-Oct-18	Bangalore	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI, YELDUR	14:11	14:13	0:02	MAIN SUPPLY FAILURE
46	23-Oct-18	Bangalore	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	14:10	14:12	0:02	MAIN SUPPLY FAILURE
47	23-Oct-18	Bangalore	66	CHINTAMANI 220 - YENNIGADALE	YENIGADALE, CHELUR, CHAKAVELU	14:10	14:13	0:02	MAIN SUPPLY FAILURE
48	23-Oct-18	Bangalore	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	22:59	23:59	0:59	MAIN SUPPLY FAILURE
49	23-Oct-18	Bangalore	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	22:59	23:59	0:59	MAIN SUPPLY FAILURE
50	23-Oct-18	Bangalore	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	23:00	23:59	0:58	MAIN SUPPLY FAILURE
51	23-Oct-18	Bangalore	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	22:59	23:59	0:59	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
52	23-Oct-18	Bangalore	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	22:59	23:59	0:59	MAIN SUPPLY FAILURE
53	23-Oct-18	Bangalore	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, YELDUR	23:00	23:26	0:26	MAIN SUPPLY FAILURE
54	23-Oct-18	Bangalore	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	22:59	23:59	0:59	MAIN SUPPLY FAILURE
55	23-Oct-18	Bangalore	66	CHINTAMANI 220 - YENNIGADALE	YENIGADALE, CHELUR, CHAKAVELU	22:59	23:59	0:59	MAIN SUPPLY FAILURE
56	23-Oct-18	Bangalore	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	22:56	23:59	1:02	MAIN SUPPLY FAILURE
57	23-Oct-18	Bangalore	220	HV1	CHINTAMANI 220	14:00	14:11	0:11	TRANSFORMER FAULT
58	23-Oct-18	Bangalore	220	HV2	CHINTAMANI 220	14:00	14:12	0:12	TRANSFORMER FAULT
59	23-Oct-18	Bangalore	220	HV3	CHINTAMANI 220	14:00	14:12	0:12	TRANSFORMER FAULT
60	23-Oct-18	Bangalore	220	HV1	CHINTAMANI 220	22:59	23:59	0:59	LINE CLEAR AVAILED
61	23-Oct-18	Bangalore	220	HV2	CHINTAMANI 220	22:59	23:59	0:59	LINE CLEAR AVAILED
62	23-Oct-18	Bangalore	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	23:00	23:59	0:58	LINE CLEAR AVAILED
63	23-Oct-18	Bangalore	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	14:00	14:13	0:12	LINE FAULT
64	23-Oct-18	Bangalore	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	0:00	0:03	0:03	LINE CLEAR AVAILED
65	23-Oct-18	Bangalore	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	0:00	0:02	0:02	LINE CLEAR AVAILED
66	23-Oct-18	Bangalore	66	HV1	DEVANAHALLI	0:00	0:11	0:11	MAIN SUPPLY FAILURE
67	23-Oct-18	Bangalore	66	HV2	DEVANAHALLI	0:00	0:12	0:12	MAIN SUPPLY FAILURE
68	23-Oct-18	Bangalore	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	3:07	3:33	0:25	LINE FAULT
69	23-Oct-18	Bangalore	66	KEMBODI - KOLAR 220	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:52	19:01	0:08	LOAD CURTAILMENT
70	23-Oct-18	Bangalore	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI	15:00	15:13	0:13	LINE FAULT
71	23-Oct-18	Bangalore	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	15:24	15:29	0:04	LINE CLEAR AVAILED
72	23-Oct-18	Bangalore	66	SM MANGALA - CHINTAMANI 220	SM MANGALA	22:56	23:05	0:08	LOAD CHANGEOVER
73	23-Oct-18	Bangalore	66	HV1	SUGUTURU	13:00	13:05	0:04	LINE CLEAR AVAILED
74	23-Oct-18	Bangalore	66	HV2	SUGUTURU	14:24	14:30	0:05	LINE CLEAR AVAILED
75	23-Oct-18	Bangalore	66	HV2	YEDUMADU	13:30	14:04	0:34	LINE CLEAR AVAILED
76	23-Oct-18	Gulbarga	220	LINGAPUR-GADAG1	LINGAPUR_220	8:17	18:43	10:26	NBFC ISSUED
77	23-Oct-18	Gulbarga	110	BYAGAWAT-ACMBSLR	BYAGAWAT_110	15:15	15:30	0:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
78	23-Oct-18	Gulbarga	110	HV1	KUDITINI_110	10:55	11:01	0:06	TRANSFORMER FAULT
79	23-Oct-18	Gulbarga	110	HV3	YELBURGA_110	18:31	18:51	0:20	LOAD CURTAILMENT
80	23-Oct-18	Gulbarga	110	HV1	MAHAGOAN_110	18:22	19:02	0:40	LOAD CURTAILMENT
81	23-Oct-18	Gulbarga	110	HV1	SIRWAR_110	18:23	18:30	0:07	LOAD CURTAILMENT
82	23-Oct-18	Gulbarga	110	SINDHANOOR-RAICHUR2(IDLE LINE)	MANVI_110,MADLAPUR_110	10:22	13:48	3:26	LINE CLEAR AVAILED
83	23-Oct-18	Gulbarga	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	19:29	19:35	0:06	LINE FAULT
84	23-Oct-18	Gulbarga	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	19:52	20:44	0:52	LINE FAULT
85	23-Oct-18	Gulbarga	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	21:46	22:24	0:38	LINE FAULT
86	23-Oct-18	Gulbarga	110	SANTHAPUR-RNWSLR	SANTHAPUR_110	12:25	12:45	0:20	LINE FAULT
87	23-Oct-18	Gulbarga	110	HV1	DHADESUGUR_110	18:32	18:42	0:10	TRANSFORMER FAULT
88	23-Oct-18	Gulbarga	110	HV1	PDHALLI_110	18:23	18:27	0:04	LOAD CURTAILMENT
89	23-Oct-18	Gulbarga	110	HV1,HV2,HV3	LINGASUGUR_220	18:23	18:43	0:20	LOAD CURTAILMENT
90	23-Oct-18	Gulbarga	66	ITAGGI-HIREHADAGALLI	HIREHADAGALLI_66	2:30	2:45	0:15	LINE FAULT
91	23-Oct-18	Hasssan	220	KEMARVarahi3	KEMAR_220	0:00	16:10	16:10	HAND TRIPPED
92	23-Oct-18	Hasssan	220	MRSSHM-VARAH12	MRSMSG_220	10:00	14:48	4:48	LINE CLEAR AVAILED
93	23-Oct-18	Hasssan	220	VARAH1-KEMAR3	varahi_gen	0:00	16:11	16:11	LINE FAULT
94	23-Oct-18	Hasssan	220	VARAH1-SHIMOGA2	varahi_gen	10:01	14:49	4:48	LINE CLEAR AVAILED
95	23-Oct-18	Hasssan	110	HV1	KEMAR_220	12:27	12:37	0:10	LINE CLEAR AVAILED
96	23-Oct-18	Hasssan	110	HV2	KEMAR_220	12:49	13:02	0:13	LINE CLEAR AVAILED
97	23-Oct-18	Hasssan	110	HV1	HALADY_110	8:52	12:16	3:24	LINE CLEAR AVAILED
98	23-Oct-18	Hasssan	110	HV1	HALADY_110	18:23	18:31	0:08	TRANSFORMER FAULT
99	23-Oct-18	Hasssan	110	HV2	HALADY_110	8:52	12:14	3:22	LINE CLEAR AVAILED
100	23-Oct-18	Hasssan	110	HV2	BAIKAMPADY_110	0:00	14:45	14:45	TRANSFORMER FAULT
101	23-Oct-18	Hasssan	110	HV1	BIRUR_110	18:24	18:38	0:14	MAIN SUPPLY FAILURE
102	23-Oct-18	Hasssan	110	HV1	DMKURKE_110	18:33	18:43	0:10	MAIN SUPPLY FAILURE
103	23-Oct-18	Hasssan	110	HV2	GANDASI_110	18:22	18:33	0:11	MAIN SUPPLY FAILURE
104	23-Oct-18	Hasssan	110	HV2	GERUMARA_110	18:32	19:01	0:29	MAIN SUPPLY FAILURE
105	23-Oct-18	Hasssan	110	HV2	SORABA_110	0:23	0:41	0:18	TRANSFORMER FAULT
106	23-Oct-18	Hasssan	66	HV2	ARAKALGUD_66	15:16	15:37	0:21	LINE CLEAR AVAILED
107	23-Oct-18	Hasssan	66	HV1	HANGARANAHALLI_66	18:32	18:39	0:07	MAIN SUPPLY FAILURE
108	23-Oct-18	Hasssan	66	HV1	HARIHARAPURA_66	20:28	20:36	0:08	TRANSFORMER FAULT
109	23-Oct-18	Hasssan	66	HV2	RMWNGR_66	18:30	18:49	0:19	MAIN SUPPLY FAILURE
110	23-Oct-18	Hasssan	66	HV2	SALAGAME_66	18:30	18:37	0:07	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
111	23-Oct-18	Hasssan	66	HV1	SATHENAHALLI_66	18:31	18:36	0:05	MAIN SUPPLY FAILURE
112	23-Oct-18	Hasssan	66	HV2	SHANTHIGRAMA_66	18:31	18:47	0:16	MAIN SUPPLY FAILURE
113	23-Oct-18	Hasssan	66	HV2	CHANNARAYAPATNA_66	18:22	18:40	0:18	MAIN SUPPLY FAILURE
114	23-Oct-18	Hasssan	66	HV2	BASAVAGHATTA_66	18:32	18:44	0:12	MAIN SUPPLY FAILURE
115	23-Oct-18	Mysore	66	HV2	ADDIHALLI_66	18:31	18:33	0:02	LOAD CURTAILMENT
116	23-Oct-18	Mysore	66	HV1	BGNAGARA_66	18:31	18:39	0:08	LOAD CURTAILMENT
117	23-Oct-18	Mysore	66	HV1	BILIKERE_66	18:31	18:41	0:09	LOAD CURTAILMENT
118	23-Oct-18	Mysore	66	HV2	BOOKANAKERE_66	18:21	18:30	0:08	LOAD CURTAILMENT
119	23-Oct-18	Mysore	66	HV2	CHINAKURALI_66	18:22	18:51	0:29	LOAD CURTAILMENT
120	23-Oct-18	Mysore	66	CR NAGARA-YELANDUR	YELANDUR_66	0:08	0:19	0:11	LINE FAULT
121	23-Oct-18	Mysore	66	HV1	DODDINADUVADI_66	18:32	19:05	0:32	LOAD CURTAILMENT
122	23-Oct-18	Mysore	66	HV2	DODDARAYAPET_66	18:32	18:50	0:17	LOAD CURTAILMENT
123	23-Oct-18	Mysore	66	HV2	ELAVALA_66	18:22	18:35	0:13	LOAD CURTAILMENT
124	23-Oct-18	Mysore	66	HV1	HAMPAPURA_66	12:11	13:19	1:07	LINE CLEAR AVAILED
125	23-Oct-18	Mysore	66	HV2	HANAGODU_66	17:16	18:09	0:53	LINE CLEAR AVAILED
126	23-Oct-18	Mysore	66	HV2	HANNUR_66	18:22	19:00	0:37	LOAD CURTAILMENT
127	23-Oct-18	Mysore	66	HV2	HDKOTE_66	18:32	19:00	0:28	LOAD CURTAILMENT
128	23-Oct-18	Mysore	66	HV1	HOOTAGALLY_220	10:54	10:56	0:02	HAND TRIPPED
129	23-Oct-18	Mysore	220	HV1	HOOTAGALLY_220	11:09	11:13	0:03	HAND TRIPPED
130	23-Oct-18	Mysore	66	HV1	HOOTAGALLY_220	12:27	12:29	0:01	HAND TRIPPED
131	23-Oct-18	Mysore	66	HV2	HOOTAGALLY_220	10:53	10:56	0:02	HAND TRIPPED
132	23-Oct-18	Mysore	220	HV2	HOOTAGALLY_220	11:02	11:06	0:03	HAND TRIPPED
133	23-Oct-18	Mysore	66	HV2	HOOTAGALLY_220	12:27	12:29	0:01	HAND TRIPPED
134	23-Oct-18	Mysore	220	HV3	HOOTAGALLY_220	9:54	10:10	0:16	HAND TRIPPED
135	23-Oct-18	Mysore	66	HV2	JAIPUR_66	18:32	18:48	0:16	LOAD CURTAILMENT
136	23-Oct-18	Mysore	66	KADAKOLA-SARGUR1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	1:58	2:03	0:05	LINE FAULT
137	23-Oct-18	Mysore	66	HV2	KMDODDI_66	18:32	18:58	0:26	LINE CLEAR AVAILED
138	23-Oct-18	Mysore	66	HV2	KOLLEGALA_66	18:32	19:15	0:42	LOAD CURTAILMENT
139	23-Oct-18	Mysore	66	KR PET 220-CR PATNA	ANEGOLAL_66 KRISHNAPURA_66	6:22	6:30	0:08	LINE FAULT
140	23-Oct-18	Mysore	66	HV1	KUSHALANAGARA_66	18:31	18:50	0:18	LOAD CURTAILMENT
141	23-Oct-18	Mysore	66	HV1	MEGALAPURA_66	18:31	18:41	0:10	LOAD CURTAILMENT
142	23-Oct-18	Mysore	66	MEGALAPURA-SFC	BGNAGARA_66 CHIDRAVALLI_66	11:36	11:41	0:04	LINE FAULT
143	23-Oct-18	Mysore	66	MIRLE-HOOTAGALLY	MIRLE_66	14:45	15:45	1:00	LINE CLEAR AVAILED
144	23-Oct-18	Mysore	66	HV1	PANDAVAPURA_66	18:23	18:33	0:10	LOAD CURTAILMENT
145	23-Oct-18	Mysore	66	HV1	SALIGRAMA_66	12:16	13:52	1:35	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
146	23-Oct-18	Mysore	66	HV2	SALIGRAMA_66	12:20	14:14	1:54	LINE CLEAR AVAILED
147	23-Oct-18	Mysore	66	HV1	SANIVARASANTHE_66	15:22	15:52	0:30	LINE CLEAR AVAILED
148	23-Oct-18	Mysore	66	HV1	TARIPURA_66	10:05	13:29	3:23	LINE CLEAR AVAILED
149	23-Oct-18	Mysore	66	HV1	YELANDUR_66	18:21	18:25	0:03	LOAD CURTAILMENT
150	23-Oct-18	Tumkur	220	ANCHEPALYA 220kV- NELMANGALA	ANCHEPALYA_220	17:37	19:05	1:28	LINE CLEAR AVAILED
151	23-Oct-18	Tumkur	110	TR-2	KADEHALLI_110	15:40	17:00	1:20	MAIN SUPPLY FAILURE
152	23-Oct-18	Tumkur	110	KALLUR- NITTUR	KALLUR_110	13:56	15:02	1:06	LINE CLEAR AVAILED
153	23-Oct-18	Tumkur	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	12:25	12:47	0:22	LINE CLEAR AVAILED
154	23-Oct-18	Tumkur	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	15:37	17:01	1:23	LINE CLEAR AVAILED
155	23-Oct-18	Tumkur	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	8:06	8:16	0:10	LINE FAULT
156	23-Oct-18	Tumkur	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66	11:30	14:02	2:32	LINE CLEAR AVAILED
157	23-Oct-18	Tumkur	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	19:46	19:59	0:12	LINE FAULT
158	23-Oct-18	Tumkur	66	TR-1	BHAKTHARAHALLI_66	12:14	12:42	0:27	LINE CLEAR AVAILED
159	23-Oct-18	Tumkur	66	TR-1 &2	BRAHMASANDRA_66	9:56	11:17	1:20	LINE CLEAR AVAILED
160	23-Oct-18	Tumkur	66	TR-2	CHIKKABANAGERE_66	12:58	14:04	1:05	LINE CLEAR AVAILED
161	23-Oct-18	Tumkur	66	CHITRADURGA 220kV- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	5:18	5:35	0:16	LINE FAULT
162	23-Oct-18	Tumkur	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	4:17	5:19	1:02	LINE FAULT
163	23-Oct-18	Tumkur	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	5:19	7:52	2:33	HAND TRIPPED
164	23-Oct-18	Tumkur	66	TR-1	CHITRADURGA_66	10:31	16:49	6:17	LINE CLEAR AVAILED
165	23-Oct-18	Tumkur	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	14:41	15:08	0:27	MAIN SUPPLY FAILURE
166	23-Oct-18	Tumkur	66	TR-1	DEVARAHALLI_66	14:47	15:08	0:21	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
167	23-Oct-18	Tumkur	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	11:11	11:31	0:19	HAND TRIPPED
168	23-Oct-18	Tumkur	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:11	11:31	0:19	HAND TRIPPED
169	23-Oct-18	Tumkur	66	TR-2	HARAPPANAHALLI_66	18:16	18:40	0:24	LINE CLEAR AVAILED
170	23-Oct-18	Tumkur	66	TR-1	HOLALKERE_66	13:12	13:37	0:25	LINE CLEAR AVAILED
171	23-Oct-18	Tumkur	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	14:15	15:14	0:58	HAND TRIPPED
172	23-Oct-18	Tumkur	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	0:53	1:06	0:12	LINE FAULT
173	23-Oct-18	Tumkur	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	2:31	6:06	3:35	LINE FAULT
174	23-Oct-18	Tumkur	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	14:15	15:21	1:05	HAND TRIPPED
175	23-Oct-18	Tumkur	66	LINGADAHALLI- P R PURA	LINGADAHALLI_TMK2_66	16:17	16:21	0:03	MAIN SUPPLY FAILURE
176	23-Oct-18	Tumkur	66	TR-2	NAYAKANAHATTI_66	17:20	17:30	0:09	TRANSFORMER FAULT
177	23-Oct-18	Tumkur	66	TR-2	NITRAHALLI_66	10:16	11:00	0:44	LINE CLEAR AVAILED
178	23-Oct-18	Tumkur	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	16:11	16:19	0:07	HAND TRIPPED
179	23-Oct-18	Tumkur	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:55	14:59	3:04	LINE FAULT
180	23-Oct-18	Tumkur	66	YEDIYUR- ANCHEPALYA	YEDIYUR_66	11:30	16:29	4:58	LINE CLEAR AVAILED
181	24-Oct-18	BAGALKOT	220	AMBEWADI 220-PONDA1	AMBEWADI_220	17:04	17:52	0:48	LINE FAULT
182	24-Oct-18	BAGALKOT	110	AMBEWADI 220-SUPA 1	AMBEWADI_220	17:08	17:44	0:36	LINE FAULT
183	24-Oct-18	BAGALKOT	110	ENERCON2-SOUDATTI	SOUDATTI_220	6:13	8:35	2:22	LINE FAULT
184	24-Oct-18	BAGALKOT	220	NAGJHARI 3-HUBLI 220	HUBLI_220	8:14	15:49	7:35	LINE FAULT
185	24-Oct-18	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	10:03	10:54	0:51	LINE CLEAR AVAILED
186	24-Oct-18	BAGALKOT	110	110/33KV, HV2	BAGALKOT_110	11:16	11:58	0:42	LINE CLEAR AVAILED
187	24-Oct-18	BAGALKOT	110	110/11KV, HV4	KERUR_110	13:03	14:26	1:23	LINE CLEAR AVAILED
188	24-Oct-18	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	22:10	22:26	0:16	LINE FAULT
189	24-Oct-18	BANGALORE	66	HV2	ELECTRONIC CITY P2 S2	18:19	18:24	0:05	TRANSFORMER FAULT
190	24-Oct-18	BANGALORE	66	ELECTRONIC CITY P2 S2 - BIOCON (EHT)	BIOCON (EHT)	3:01	3:15	0:14	LINE FAULT
191	24-Oct-18	BANGALORE	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	10:23	14:03	3:40	LINE CLEAR AVAILED
192	24-Oct-18	BANGALORE	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK	7:54	9:14	1:19	LINE FAULT
193	24-Oct-18	BANGALORE	66	HOODY 220 - HAL 2	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT)	7:54	8:42	0:47	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
194	24-Oct-18	BANGALORE	66	BAGMANE WORLD TECH PARK - HOODY 1	BAGMANE WORLD TECH PARK	7:54	9:14	1:19	LINE FAULT
195	24-Oct-18	BANGALORE	66	HV2	BANASWADI	7:54	8:44	0:49	MAIN SUPPLY FAILURE
196	24-Oct-18	BANGALORE	66	HV2	BANASWADI	9:20	9:23	0:03	LOAD CHANGEVER
197	24-Oct-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	0:00	1:54	1:54	MAIN SUPPLY FAILURE
198	24-Oct-18	BANGALORE	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	0:00	1:52	1:52	MAIN SUPPLY FAILURE
199	24-Oct-18	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	0:00	1:53	1:53	MAIN SUPPLY FAILURE
200	24-Oct-18	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	0:00	1:54	1:54	MAIN SUPPLY FAILURE
201	24-Oct-18	BANGALORE	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	0:00	1:56	1:56	MAIN SUPPLY FAILURE
202	24-Oct-18	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	0:00	1:53	1:53	MAIN SUPPLY FAILURE
203	24-Oct-18	BANGALORE	66	CHINTAMANI 220 - YENNIGADALE	YENIGADALE, CHELUR, CHAKAVELU	0:00	1:52	1:52	MAIN SUPPLY FAILURE
204	24-Oct-18	BANGALORE	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	0:00	2:05	2:05	MAIN SUPPLY FAILURE
205	24-Oct-18	BANGALORE	66	SRINIVASPURA - KOLAR 220	SRINIVASPURA, YELDUR	2:00	2:05	0:05	MAIN SUPPLY FAILURE
206	24-Oct-18	BANGALORE	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	2:00	2:10	0:10	LOAD CHANGEVER
207	24-Oct-18	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	17:40	17:57	0:17	LINE FAULT
208	24-Oct-18	BANGALORE	66	GANJIGUNTE - CHINTAMANI 2	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:37	5:45	0:07	LINE FAULT
209	24-Oct-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:37	5:45	0:07	LINE FAULT
210	24-Oct-18	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	8:52	11:48	2:56	LINE CLEAR AVAIED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
211	24-Oct-18	GULBARGA	220	HV1	SIDHANOOR_220	14:35	14:50	0:15	TRANSFORMER FAULT
212	24-Oct-18	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	14:05	17:38	3:33	LINE FAULT
213	24-Oct-18	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KA MPLI_110	3:43	3:54	0:11	LINE FAULT
214	24-Oct-18	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KA MPLI_110	5:20	5:26	0:06	LINE FAULT
215	24-Oct-18	GULBARGA	110	SANTHAPUR-RNWSLR	SANTHAPUR_110	13:05	13:20	0:15	LINE FAULT
216	24-Oct-18	GULBARGA	110	SINDHANOOR-RAICHUR2(IDLE)	MANVI_110,MADALAPUR_110	14:39	14:59	0:20	LINE FAULT
217	24-Oct-18	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KA MPLI_110	14:39	14:59	0:20	LINE FAULT
218	24-Oct-18	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SRERAMAN AGAR_110,GANGAVATHI_110,VENKATAGIRI_110	14:39	14:57	0:18	LINE FAULT
219	24-Oct-18	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	14:39	14:59	0:20	LINE FAULT
220	24-Oct-18	GULBARGA	110	SINDHANOOR-PGLR_WIND	SIDHANOOR_220	14:39	14:59	0:20	LINE FAULT
221	24-Oct-18	GULBARGA	110	HV3	TEKKALAKOTE_110	14:39	14:48	0:09	TRANSFORMER FAULT
222	24-Oct-18	GULBARGA	110	HV1	SIRWAR_110	12:56	13:15	0:19	LINE CLEAR AVAILED
223	24-Oct-18	GULBARGA	110	LINGASUGUR-LATUR WIND	LINGASUGUR_220	10:57	17:30	6:33	LINE CLEAR AVAILED
224	24-Oct-18	GULBARGA	110	HV1	PDHALLI_110	7:21	7:28	0:07	TRANSFORMER FAULT
225	24-Oct-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	10:20	10:45	0:25	LINE FAULT
226	24-Oct-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,JANAWAD A_110,DONGRAGOA_110,DIGGI_110	6:13	6:16	0:03	LINE FAULT
227	24-Oct-18	GULBARGA	110	HV1,HV2,HV3	HALIKHED_110	14:12	14:30	0:18	TRANSFORMER FAULT
228	24-Oct-18	GULBARGA	66	HV1	KOTTUR_66	10:39	11:35	0:56	LINE CLEAR AVAILED
229	24-Oct-18	HASSAN	220	HV1	KADUR_220	10:28	11:23	0:55	LINE CLEAR AVAILED
230	24-Oct-18	HASSAN	220	HV1	KADUR_220	17:00	18:18	1:18	LINE CLEAR AVAILED
231	24-Oct-18	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	10:27	19:02	8:35	LINE CLEAR AVAILED
232	24-Oct-18	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:28	23:59	13:31	LINE CLEAR AVAILED
233	24-Oct-18	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:12	13:59	3:47	LINE CLEAR AVAILED
234	24-Oct-18	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:26	19:02	8:36	NBFC ISSUED
235	24-Oct-18	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:28	23:59	13:31	NBFC ISSUED
236	24-Oct-18	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	10:13	14:00	3:47	LINE CLEAR AVAILED
237	24-Oct-18	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	11:07	14:30	3:23	LINE CLEAR AVAILED
238	24-Oct-18	HASSAN	220	TALAGU-SGS1	TALAGUPP_400	11:07	14:39	3:32	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
239	24-Oct-18	HASSAN	110	KADUR-AJAMPURA	KADUR_220	17:00	17:10	0:10	LINE CLEAR AVAILED
240	24-Oct-18	HASSAN	110	HV1	KADUR_220	16:59	17:04	0:05	LINE CLEAR AVAILED
241	24-Oct-18	HASSAN	110	HV2	KADUR_220	16:59	17:04	0:05	LINE CLEAR AVAILED
242	24-Oct-18	HASSAN	110	LV1	KADUR_220	10:28	11:23	0:55	LINE CLEAR AVAILED
243	24-Oct-18	HASSAN	110	LV1	KADUR_220	11:45	12:20	0:35	HAND TRIPPED
244	24-Oct-18	HASSAN	110	LV1	KADUR_220	12:30	13:27	0:57	HAND TRIPPED
245	24-Oct-18	HASSAN	110	LV1	KADUR_220	13:28	13:49	0:21	HAND TRIPPED
246	24-Oct-18	HASSAN	110	LV2	KADUR_220	17:00	17:04	0:04	HAND TRIPPED
247	24-Oct-18	HASSAN	110	KADUR-NERELEKERE	KADUR_220	17:00	17:04	0:04	LINE CLEAR AVAILED
248	24-Oct-18	HASSAN	110	KADUR-NGNHL	KADUR_220	17:00	17:06	0:06	LINE CLEAR AVAILED
249	24-Oct-18	HASSAN	110	KADUR-TNGL	KADUR_220	17:00	17:06	0:06	LINE CLEAR AVAILED
250	24-Oct-18	HASSAN	110	KADUR-YGTI	KADUR_220	14:00	14:21	0:21	LINE FAULT
251	24-Oct-18	HASSAN	110	KADURYGTI	KADUR_220	17:00	17:06	0:06	LINE CLEAR AVAILED
252	24-Oct-18	HASSAN	110	HV1	ANAVATTI_110	10:20	10:35	0:15	HAND TRIPPED
253	24-Oct-18	HASSAN	110	HV2	ANAVATTI_110	10:20	10:35	0:15	HAND TRIPPED
254	24-Oct-18	MYSORE	66	HV2	GUNDULPET_66	8:18	13:55	5:36	LINE CLEAR AVAILED
255	24-Oct-18	MYSORE	66	HOOTAGALLI-ELAWALA	ELAVALA_66 GAVADAGERE_66	13:11	13:15	0:04	LINE FAULT
256	24-Oct-18	MYSORE	66	HV1	NAGAMANGALA_66	18:28	18:30	0:01	LOAD CURTAILMENT
257	24-Oct-18	MYSORE	66	HV1	SATHEGALA_66	18:28	18:35	0:06	LOAD CURTAILMENT
258	24-Oct-18	MYSORE	66	HV2	SANTHESARAGUR_66	18:28	18:42	0:13	LOAD CURTAILMENT
259	24-Oct-18	MYSORE	66	HV2	SANTHESARAGUR_66	18:29	18:47	0:18	LOAD CURTAILMENT
260	24-Oct-18	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	6:19	6:27	0:07	LINE FAULT
261	24-Oct-18	TUMKUR	220	TR-2(100MVA)	DAVANGERE_SRS_220	10:30	11:54	1:24	LINE CLEAR AVAILED
262	24-Oct-18	TUMKUR	110	TR-3	AMMASANDRA_110	8:18	13:49	5:30	LINE CLEAR AVAILED
263	24-Oct-18	TUMKUR	66	TR-2	CHIKKABANAGERE_66	12:58	14:04	1:05	LINE CLEAR AVAILED
264	24-Oct-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:29	11:56	1:27	HAND TRIPPED
265	24-Oct-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:02	10:13	0:11	HAND TRIPPED
266	24-Oct-18	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	10:02	10:05	0:03	HAND TRIPPED
267	24-Oct-18	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:29	11:57	1:27	HAND TRIPPED
268	24-Oct-18	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:22	14:33	0:10	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
269	24-Oct-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:28	11:57	1:28	HAND TRIPPED
270	24-Oct-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:51	17:33	9:42	HAND TRIPPED
271	24-Oct-18	TUMKUR	66	TR-2	GARAGA_66	11:30	11:48	0:17	LINE CLEAR AVAILED
272	24-Oct-18	TUMKUR	66	TR-2	GARAGA_66	13:43	14:39	0:56	LINE CLEAR AVAILED
273	24-Oct-18	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	15:30	15:53	0:22	LINE FAULT
274	24-Oct-18	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	8:02	18:04	10:02	HAND TRIPPED
275	24-Oct-18	TUMKUR	66	MADHUGIRI 220kV- NAGALMADIKE	SHYLAPURA_66, NAGALMADIKE_66, LINGADAHALLI_TMK2_66, MANGALWADA_66, YNHOSKOTE_66	9:37	9:51	0:13	LINE FAULT
276	24-Oct-18	TUMKUR	66	NAGALMADIKE-MADHUGIRI	NAGALMADIKE_66	9:37	9:56	0:18	LINE FAULT
277	24-Oct-18	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	7:04	10:08	3:04	NBFC ISSUED
278	24-Oct-18	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 2	CHITRADURGA_66	8:02	10:08	2:06	NBFC ISSUED
279	24-Oct-18	TUMKUR	66	RANGANATHPURA- WELSPUNSOLAR_IPP1	WELSPUNSOLAR1_IPP_66	12:24	12:44	0:20	LOAD CURTAILMENT
280	24-Oct-18	TUMKUR	66	RANGANATHPURA- WELSPUNSOLAR_IPP2	WELSPUNSOLAR2_IPP_66	12:24	12:44	0:20	LOAD CURTAILMENT
281	24-Oct-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	18:23	18:35	0:12	LINE CLEAR AVAILED
282	25-Oct-18	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	14:44	14:48	0:04	TRANSFORMER FAULT
283	25-Oct-18	BAGALKOT	66	66/11KV,HV-2	HARHAR-HOSPET_66	7:40	8:32	0:52	HAND TRIPPED
284	25-Oct-18	BAGALKOT	110	BAGEWADI-RAMPUR	NIDAGUNDI_110	11:14	11:20	0:06	LINE FAULT
285	25-Oct-18	BAGALKOT	110	110/11KV,HV-1	BILAGI_110	0:18	0:25	0:07	TRANSFORMER FAULT
286	25-Oct-18	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	10:55	23:59	13:04	HAND TRIPPED
287	25-Oct-18	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	10:55	19:08	8:13	HAND TRIPPED
288	25-Oct-18	BAGALKOT	110	BELGAUM-ANKALI	ANKALI_110	19:10	19:21	0:11	LINE FAULT
289	25-Oct-18	BAGALKOT	110	BELGAUM-ANKALI	ANKALI_110	20:50	21:25	0:35	LINE FAULT
290	25-Oct-18	BAGALKOT	110	HATTARAGI -BELGAUM	DADDI_110	9:38	14:14	4:36	HAND TRIPPED
291	25-Oct-18	BAGALKOT	110	KUDACHI-AINAPUR	AINAPUR_110	10:25	8:24	21:59	LINE CLEAR AVAILED
292	25-Oct-18	BAGALKOT	110	110/11KV,HV-1	KUDACHI_220	11:08	11:14	0:06	HAND TRIPPED
293	25-Oct-18	BAGALKOT	110	110/11KV,HV-1	KUDACHI_220	11:19	11:22	0:03	HAND TRIPPED
294	25-Oct-18	BAGALKOT	110	110/11KV,HV-1	KUDACHI_220	11:28	11:32	0:04	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
295	25-Oct-18	BAGALKOT	110	KUDACHI-UGAR KHUD	UGAR KHUD_110	12:16	15:31	3:15	HAND TRIPPED
296	25-Oct-18	BAGALKOT	110	KUDACHI220 TO KUDACHI 110	KUDACHI_110	0:00	15:37	15:37	LINE CLEAR AVAILED
297	25-Oct-18	BAGALKOT	110	110/33KV,HV4	ZALKI_110	16:50	17:01	0:11	TRANSFORMER FAULT
298	25-Oct-18	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	12:11	12:12	0:01	TRANSFORMER FAULT
299	25-Oct-18	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	15:35	15:46	0:11	TRANSFORMER FAULT
300	25-Oct-18	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	9:10	9:30	0:20	LINE CLEAR AVAILED
301	25-Oct-18	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	10:38	11:55	1:17	LINE CLEAR AVAILED
302	25-Oct-18	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	16:43	16:56	0:13	LINE CLEAR AVAILED
303	25-Oct-18	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	16:43	16:56	0:13	LINE CLEAR AVAILED
304	25-Oct-18	BAGALKOT	110	110/11KV,HV2	PH COMPOUND_110	11:41	12:26	0:45	HAND TRIPPED
305	25-Oct-18	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220,HIDIKAL_110,RABKAVI_110	12:45	13:08	0:23	TRANSFORMER FAULT
306	25-Oct-18	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220,HIDIKAL_110,RABKAVI_110	13:22	13:41	0:19	TRANSFORMER FAULT
307	25-Oct-18	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	12:59	13:47	0:48	HAND TRIPPED
308	25-Oct-18	BAGALKOT	110	MAHALINGAPUR220-RABKAVI	RABKAVI_110	13:00	13:14	0:14	HAND TRIPPED
309	25-Oct-18	BAGALKOT	110	MAHALINGAPUR220-RABKAVI	RABKAVI_110	13:40	13:49	0:09	HAND TRIPPED
310	25-Oct-18	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	19:19	19:30	0:11	LINE FAULT
311	25-Oct-18	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	11:56	12:13	0:17	HAND TRIPPED
312	25-Oct-18	BAGALKOT	110	110/11KV,HV1	KUMATA_110	16:52	16:53	0:01	HAND TRIPPED
313	25-Oct-18	BANGALORE	66	HV1	AGALAKOTE	19:16	19:20	0:04	TRANSFORMER FAULT
314	25-Oct-18	BANGALORE	66	AGALAKOTE - ANCHEPALYA 220	AGALAKOTE	9:20	9:50	0:30	MAIN SUPPLY FAILURE
315	25-Oct-18	BANGALORE	66	AGALAKOTE - ANCHEPALYA 220	AGALAKOTE	17:15	19:10	1:55	MAIN SUPPLY FAILURE
316	25-Oct-18	BANGALORE	66	HV1	ANDERSONPET	15:42	16:00	0:18	LINE CLEAR AVAILED
317	25-Oct-18	BANGALORE	66	HV2	DALASANUR	12:13	12:47	0:34	LINE CLEAR AVAILED
318	25-Oct-18	BANGALORE	66	RAGANKUNTE - DB PURA	AIR (EHT)	12:03	13:39	1:36	LOAD CHANGEOVER
319	25-Oct-18	BANGALORE	66	HV1	HAROBEL	10:09	10:11	0:02	MAIN SUPPLY FAILURE
320	25-Oct-18	BANGALORE	66	HV1	HAROBEL	19:00	19:06	0:06	TRANSFORMER FAULT
321	25-Oct-18	BANGALORE	66	HV2	HAROBEL	19:00	19:06	0:06	TRANSFORMER FAULT
322	25-Oct-18	BANGALORE	66	HAROBEL - KANAKAPURA 220	HAROBEL, HUKUNDA, KODIHALLI, HUNSENAHALLI, KUDUR	10:09	10:15	0:06	LINE FAULT
323	25-Oct-18	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR	9:10	10:30	1:20	MAIN SUPPLY FAILURE
324	25-Oct-18	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI	11:50	12:15	0:25	MAIN SUPPLY FAILURE
325	25-Oct-18	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI	17:10	19:05	1:55	MAIN SUPPLY FAILURE
326	25-Oct-18	BANGALORE	66	KUDUR - HULLENAHALLI	KUDUR	9:30	19:05	9:34	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
327	25-Oct-18	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:30	14:46	1:15	MAIN SUPPLY FAILURE
328	25-Oct-18	BANGALORE	66	KOLAR 220 - NARASAPURA	NARASAPURA	13:30	14:46	1:15	MAIN SUPPLY FAILURE
329	25-Oct-18	BANGALORE	220	HV3	KOLAR 220	13:30	14:46	1:15	LINE CLEAR AVAIED
330	25-Oct-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	15:10	15:11	0:01	LINE FAULT
331	25-Oct-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	23:04	23:09	0:04	LINE FAULT
332	25-Oct-18	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:48	5:55	0:07	LINE FAULT
333	25-Oct-18	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:16	13:27	0:10	LINE FAULT
334	25-Oct-18	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE	10:11	16:36	6:25	LINE CLEAR AVAIED
335	25-Oct-18	BANGALORE	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	9:54	10:05	0:10	LOAD CHANGEOVER
336	25-Oct-18	BANGALORE	66	HV2	HAL 220	9:53	9:54	0:01	LOAD CHANGEOVER
337	25-Oct-18	BANGALORE	66	HAL 220 - HAL (EHT)	HAL (EHT)	9:53	9:54	0:01	LOAD CHANGEOVER
338	25-Oct-18	BANGALORE	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	10:01	10:03	0:01	LOAD CHANGEOVER
339	25-Oct-18	BANGALORE	66	HV2	HAL 220	12:13	12:20	0:06	LINE CLEAR AVAIED
340	25-Oct-18	BANGALORE	66	C STATION - HEBBAL 220	C STATION	11:14	11:18	0:04	LOAD CHANGEOVER
341	25-Oct-18	BANGALORE	66	C STATION - A STATION 220	C STATION	18:22	18:26	0:04	LOAD CHANGEOVER
342	25-Oct-18	BANGALORE	66	HV1	HSR LAYOUT 220	11:01	12:53	1:52	LINE CLEAR AVAIED
343	25-Oct-18	BANGALORE	66	HV2	HSR LAYOUT 220	13:10	16:01	2:51	LINE CLEAR AVAIED
344	25-Oct-18	BANGALORE	66	HV1	BOODIGERE	9:30	9:40	0:09	LINE CLEAR AVAIED
345	25-Oct-18	BANGALORE	66	HV2	BOODIGERE	15:05	15:41	0:36	LINE CLEAR AVAIED
346	25-Oct-18	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE	10:11	16:36	6:25	LINE CLEAR AVAIED
347	25-Oct-18	BANGALORE	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	9:54	10:05	0:10	LOAD CHANGEOVER
348	25-Oct-18	BANGALORE	66	HV2	HAL 220	9:53	9:54	0:01	LOAD CHANGEOVER
349	25-Oct-18	BANGALORE	66	HAL 220 - HAL (EHT)	HAL (EHT)	9:53	9:54	0:01	LOAD CHANGEOVER
350	25-Oct-18	BANGALORE	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	10:01	10:03	0:01	LOAD CHANGEOVER
351	25-Oct-18	BANGALORE	66	HV2	HAL 220	12:13	12:20	0:06	LINE CLEAR AVAIED
352	25-Oct-18	BANGALORE	66	C STATION - HEBBAL 220	C STATION	11:14	11:18	0:04	LOAD CHANGEOVER
353	25-Oct-18	BANGALORE	66	C STATION - A STATION 220	C STATION	18:22	18:26	0:04	LOAD CHANGEOVER
354	25-Oct-18	BANGALORE	66	HV1	HSR LAYOUT 220	11:01	12:53	1:52	LINE CLEAR AVAIED
355	25-Oct-18	BANGALORE	66	HV2	HSR LAYOUT 220	13:10	16:01	2:51	LINE CLEAR AVAIED
356	25-Oct-18	BANGALORE	66	HV1	BOODIGERE	9:30	9:40	0:09	LINE CLEAR AVAIED
357	25-Oct-18	BANGALORE	66	HV2	BOODIGERE	15:05	15:41	0:36	LINE CLEAR AVAIED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
358	25-Oct-18	BANGALORE	66	HV1	AGALAKOTE	19:16	19:20	0:04	TRANSFORMER FAULT
359	25-Oct-18	BANGALORE	66	AGALAKOTE - ANCHEPALYA 220	AGALAKOTE	9:20	9:50	0:30	MAIN SUPPLY FAILURE
360	25-Oct-18	BANGALORE	66	AGALAKOTE - ANCHEPALYA 220	AGALAKOTE	17:15	19:10	1:55	MAIN SUPPLY FAILURE
361	25-Oct-18	BANGALORE	66	HV1	ANDERSONPET	15:42	16:00	0:18	LINE CLEAR AVAILED
362	25-Oct-18	BANGALORE	66	HV2	DALASANUR	12:13	12:47	0:34	LINE CLEAR AVAILED
363	25-Oct-18	BANGALORE	66	RAGANKUNTE - DB PURA	AIR (EHT)	12:03	13:39	1:36	LOAD CHANGEOVER
364	25-Oct-18	BANGALORE	66	HV1	HAROBELE	10:09	10:11	0:02	MAIN SUPPLY FAILURE
365	25-Oct-18	BANGALORE	66	HV1	HAROBELE	19:00	19:06	0:06	TRANSFORMER FAULT
366	25-Oct-18	BANGALORE	66	HV2	HAROBELE	19:00	19:06	0:06	TRANSFORMER FAULT
367	25-Oct-18	BANGALORE	66	HAROBELE - KANAKAPURA 220	HAROBELE, HUKUNDA, KODIHALLI, HUNSENAHALLI, KUDUR	10:09	10:15	0:06	LINE FAULT
368	25-Oct-18	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR	9:10	10:30	1:20	MAIN SUPPLY FAILURE
369	25-Oct-18	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI	11:50	12:15	0:25	MAIN SUPPLY FAILURE
370	25-Oct-18	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI	17:10	19:05	1:55	MAIN SUPPLY FAILURE
371	25-Oct-18	BANGALORE	66	KUDUR - HULLENAHALLI	KUDUR	9:30	19:05	9:34	LINE CLEAR AVAILED
372	25-Oct-18	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:30	14:46	1:15	MAIN SUPPLY FAILURE
373	25-Oct-18	BANGALORE	66	KOLAR 220 - NARASAPURA	NARASAPURA	13:30	14:46	1:15	MAIN SUPPLY FAILURE
374	25-Oct-18	BANGALORE	220	HV3	KOLAR 220	13:30	14:46	1:15	LINE CLEAR AVAILED
375	25-Oct-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	15:10	15:11	0:01	LINE FAULT
376	25-Oct-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	23:04	23:09	0:04	LINE FAULT
377	25-Oct-18	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:48	5:55	0:07	LINE FAULT
378	25-Oct-18	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:16	13:27	0:10	LINE FAULT
379	25-Oct-18	GULBARGA	220	RAICHUR-RTPS1,RTPS2	RAICHUR_220	12:15	12:35	0:20	LINE CLEAR AVAILED
380	25-Oct-18	GULBARGA	220	HV1	RAICHUR_220	9:38	11:54	2:16	LINE CLEAR AVAILED
381	25-Oct-18	GULBARGA	220	HV1,HV2	RAICHUR_220	16:21	17:20	0:59	HAND TRIPPED
382	25-Oct-18	GULBARGA	220	HV1,HV2	RAICHUR_220	18:34	18:54	0:20	HAND TRIPPED
383	25-Oct-18	GULBARGA	220	HV2,LV2	RAICHUR_220	11:55	12:35	0:40	HAND TRIPPED
384	25-Oct-18	GULBARGA	110	HV2	MAHAGOAN_110	12:29	12:52	0:23	HAND TRIPPED
385	25-Oct-18	GULBARGA	110	HV3	MANTHAL_110	14:01	14:50	0:49	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
386	25-Oct-18	GULBARGA	110	HV1	MANTHAL_110	14:00	14:05	0:05	LINE CLEAR AVAILED
387	25-Oct-18	GULBARGA	110	MUNIRABAD-SINDHANOOR1	GANGAVATHI_110,KARTAGI_110,VENKATAGIRI_110,SRE RAMANAGAR_110	14:45	15:05	0:20	LINE FAULT
388	25-Oct-18	GULBARGA	110	HV1	SIRWAR_110	8:27	8:37	0:10	LINE CLEAR AVAILED
389	25-Oct-18	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	12:10	12:20	0:10	LINE CLEAR AVAILED
390	25-Oct-18	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	13:10	13:21	0:11	LINE CLEAR AVAILED
391	25-Oct-18	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110.M GSSK_IPP,BSSK_IPP	17:21	17:44	0:23	LINE CLEAR AVAILED
392	25-Oct-18	GULBARGA	110	SANTHAPUR-RNWSLR	SANTHAPUR_110	12:21	12:25	0:04	LINE FAULT
393	25-Oct-18	GULBARGA	66	ITTAGGI-RENEWSOLAR1	ITTAGI_220	11:53	13:06	1:13	LINE CLEAR AVAILED
394	25-Oct-18	GULBARGA	66	ITTAGGI-RENEWSOLAR2	ITTAGI_220	14:03	16:08	2:05	LINE CLEAR AVAILED
395	25-Oct-18	HASSAN	220	HV1	KADUR_220	11:42	18:41	6:59	LINE CLEAR AVAILED
396	25-Oct-18	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	10:44	13:27	2:43	LINE CLEAR AVAILED
397	25-Oct-18	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:44	13:28	2:44	NBFC ISSUED
398	25-Oct-18	HASSAN	110	LV1	KADUR_220	17:51	23:59	6:08	LINE CLEAR AVAILED
399	25-Oct-18	HASSAN	110	KADUR-TNGL	KADUR_220	11:23	14:41	3:18	LINE CLEAR AVAILED
400	25-Oct-18	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	8:56	9:09	0:13	LINE FAULT
401	25-Oct-18	HASSAN	110	HV2	BAIKAMPADY_110	7:06	16:57	9:51	LINE CLEAR AVAILED
402	25-Oct-18	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	8:59	9:11	0:12	MAIN SUPPLY FAILURE
403	25-Oct-18	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	8:59	9:10	0:11	MAIN SUPPLY FAILURE
404	25-Oct-18	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	8:57	11:35	2:38	MAIN SUPPLY FAILURE
405	25-Oct-18	HASSAN	110	HIRIYA-KARAYA	PUTTUR_220	10:40	12:53	2:13	LINE CLEAR AVAILED
406	25-Oct-18	HASSAN	66	HV2	ARAKALGUD_66	11:57	13:51	1:54	LINE CLEAR AVAILED
407	25-Oct-18	HASSAN	66	HV2	RAMNATHPURA_66	15:35	16:15	0:40	HAND TRIPPED
408	25-Oct-18	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	15:35	16:15	0:40	HAND TRIPPED
409	25-Oct-18	MYSORE	66	BG NAGARA-YEDIYUR	ADICHUNCHANAGIRI_66 VADERALLI_66	11:54	12:21	0:27	LINE FAULT
410	25-Oct-18	MYSORE	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	7:28	17:58	10:30	LINE CLEAR AVAILED
411	25-Oct-18	MYSORE	66	KR NAGARA-BILIKERE	KRNAGARA_66	12:37	14:28	1:50	LINE CLEAR AVAILED
412	25-Oct-18	MYSORE	66	KR NAGARA-KUSHALANAGAR	KRNAGARA_66	12:38	14:09	1:31	LINE CLEAR AVAILED
413	25-Oct-18	MYSORE	66	KR NAGARA-CHUNCHUNKATTE	KRNAGARA_66	12:38	14:09	1:31	LINE CLEAR AVAILED
414	25-Oct-18	MYSORE	66	HV1	PANDYADAHUNDI_66	11:21	12:54	1:33	LINE CLEAR AVAILED
415	25-Oct-18	MYSORE	66	HV2	PANDYADAHUNDI_66	12:55	14:11	1:16	LINE CLEAR AVAILED
416	25-Oct-18	MYSORE	66	SFC SIVA-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66	7:33	7:41	0:07	LINE FAULT
417	25-Oct-18	MYSORE	66	HV1	SHIVALLY_66	12:32	14:08	1:36	TRANSFORMER FAULT
418	25-Oct-18	MYSORE	66	HV2	SHIVALLY_66	11:37	13:09	1:32	LINE CLEAR AVAILED
419	25-Oct-18	MYSORE	66	SUNTIKOPPA-MADIKERI	SUNTIKOPPA_66	17:16	17:17	0:01	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
420	25-Oct-18	MYSORE	66	VAJAMANGALA-MEGALAPURA	MEGALAPURA_66 TNARASIPURA_66 THUMBLA_66	7:32	7:46	0:13	LINE FAULT
421	25-Oct-18	TUMKUR	220	TR-1 & TR-2	ANCHEPALYA_220	9:00	19:11	10:11	NBFC ISSUED
422	25-Oct-18	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA	ANCHEPALYA_220	9:00	19:11	10:11	NBFC ISSUED
423	25-Oct-18	TUMKUR	220	ANCHEPALYA 220kV- MAGADI	ANCHEPALYA_220	8:48	19:08	10:19	NBFC ISSUED
424	25-Oct-18	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2, ANCHEPALYA 220kV- AMRUTHUR, ANCHEPALYA 220kV- HEBBUR, ANCHEPALYA 220kV- HULIYURDURGA, ANCHEPALYA 220kV- KEMPANAHALLI, ANCHEPALYA 220kV- T G HALLI, ANCHEPALYA 220kV- VIJAYASTEEL, ANCHEPALYA 220kV- YEDIYUR	KUDUR_66, HULLENAHALLI_66, AMRUTHUR_66, SANTEMAVATTUR_66, HEBBUR_66, THIMMASANDRA_66, BHAKTHARAHALLI_66, HULIYURDURGA_66, CHAWANAKUPPE_66, KEMPANAHALLI_66, AGALKOTE_66, MAGADI_66, TGHALLI_66, VGDODDI_66, VIJAYASTEELS_EHT_66, YEDIYUR_66	9:00	19:11	10:11	HAND TRIPPED
425	25-Oct-18	TUMKUR	66	TR-1 & TR-2	ANCHEPALYA_220	9:00	19:11	10:11	HAND TRIPPED
426	25-Oct-18	TUMKUR	66	TR-2	ANCHEPALYA_66	10:01	10:47	0:46	MAIN SUPPLY FAILURE
427	25-Oct-18	TUMKUR	66	TR-2	ANCHEPALYA_66	18:36	19:15	0:38	MAIN SUPPLY FAILURE
428	25-Oct-18	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	9:10	12:34	3:24	LINE CLEAR AVAILED
429	25-Oct-18	TUMKUR	66	BHAKTARAHALLI- ANCHEPALYA	BHAKTHARAHALLI_66	9:00	19:24	10:24	MAIN SUPPLY FAILURE
430	25-Oct-18	TUMKUR	66	TR-2	CHANNAGIRI_66	15:20	15:34	0:14	TRANSFORMER FAULT
431	25-Oct-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:00	18:24	10:24	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
432	25-Oct-18	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	9:15	9:26	0:11	LINE FAULT
433	25-Oct-18	TUMKUR	66	TR-3	HOLALKERE_66	16:57	17:45	0:47	LINE CLEAR AVAILED
434	25-Oct-18	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR SIRA	JAVAGONDANAHALLI_66, BEVINAHALLI_66	9:15	9:36	0:21	MAIN SUPPLY FAILURE
435	25-Oct-18	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66, KALAMRANAHALLI- TATASOLAR IPP	BPCLSOLAR_IPP_66, TATASOLAR_IPP_66	20:50	22:02	1:11	LINE CLEAR AVAILED
436	25-Oct-18	TUMKUR	66	TR-1	RANGENAHALLI_66	11:07	13:05	1:58	LINE CLEAR AVAILED
437	25-Oct-18	TUMKUR	66	TR-1	SASALUHALLA_66	17:11	17:15	0:04	HAND TRIPPED
438	25-Oct-18	TUMKUR	66	TR-1 & TR-2	THIMMASANDRA_66	9:26	14:32	5:06	MAIN SUPPLY FAILURE
439	25-Oct-18	TUMKUR	66	MELEKOTE HEBBUR- THIMMASANDRA	THIMMASANDRA_66	10:04	14:32	4:28	MAIN SUPPLY FAILURE
440	25-Oct-18	TUMKUR	66	TR-1	TUMKUR_66	12:10	12:58	0:48	HAND TRIPPED
441	25-Oct-18	TUMKUR	66	TR-1	YNHOSKOTE_66	15:11	15:12	0:01	TRANSFORMER FAULT
442	26-Oct-18	BAGALKOT	110	KIADB -BHUTANAL	BHUTANAL_110&TIKOTA_1 10	12:44	12:46	0:02	LINE FAULT
443	26-Oct-18	BAGALKOT	110	KIADB -BHUTANAL	BHUTANAL_110&TIKOTA_1 10	12:52	12:55	0:03	LINE FAULT
444	26-Oct-18	BAGALKOT	110	BELGAUM-KANABARGI	KANABARGI_110	14:50	16:22	1:32	HAND TRIPPED
445	26-Oct-18	BAGALKOT	110	BELGAUM-ANKALAGI	ANKALAGI_110	15:05	15:17	0:12	HAND TRIPPED
446	26-Oct-18	BAGALKOT	110	BELGAUM-BELGAUM(NEHRU NAGAR)	BELGAUM(NEHRU NAGAR)_110	15:08	15:14	0:06	HAND TRIPPED
447	26-Oct-18	BAGALKOT	220	BELGAUM -CHIKKODI 2	BELGAUM_220	10:53	23:59	13:06	HAND TRIPPED
448	26-Oct-18	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	0:00	15:09	15:09	LINE CLEAR AVAILED
449	26-Oct-18	BAGALKOT	110	JAMAKHANDI-PRABHI LINEGESHWAR	JAMAKHANDI_110	11:49	12:02	0:13	HAND TRIPPED
450	26-Oct-18	BAGALKOT	110	JAMAKHANDI-MAHALINGAPUR	JAMAKHANDI_110	12:02	13:27	1:25	HAND TRIPPED
451	26-Oct-18	BAGALKOT	110	CHIKKODI-ANKALI	ANKALI_110	10:14	17:22	7:08	HAND TRIPPED
452	26-Oct-18	BAGALKOT	110	KIRUVATTI-SIRSI	KIRUVATTI_110	13:37	13:51	0:14	LINE FAULT
453	26-Oct-18	BAGALKOT	110	KUDACHI-TERADAL	TERADAL_110	9:33	18:45	9:12	HAND TRIPPED
454	26-Oct-18	BAGALKOT	110	110/11KV,HV-2	KUD DHARWAD_110	16:14	16:54	0:40	HAND TRIPPED
455	26-Oct-18	BAGALKOT	110	110/33KV,HV-3	LAXMESHVAR_110	18:52	19:06	0:14	TRANSFORMER FAULT
456	26-Oct-18	BAGALKOT	110	KUDUCHI220-YELLAPARHATTI	YELLAPARHATTI_110	9:40	18:41	9:01	LINE CLEAR AVAILED
457	26-Oct-18	BAGALKOT	110	110/11KV,HV1&2	YELLAPARHATTI_110	9:40	18:42	9:02	LINE CLEAR AVAILED
458	26-Oct-18	BAGALKOT	220	ENERGON-VAJRAMATTI	VAJRAMATTI_220	19:06	20:30	1:24	LINE CLEAR AVAILED
459	26-Oct-18	BAGALKOT	110	110/11KV,HV3	TIKOTA_110	12:17	13:20	1:03	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
460	26-Oct-18	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	8:18	8:31	0:13	LINE FAULT
461	26-Oct-18	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	12:05	12:47	0:42	LINE CLEAR AVAILED
462	26-Oct-18	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	12:04	13:19	1:15	LINE CLEAR AVAILED
463	26-Oct-18	BANGALORE	66	CB PURA I/A - DB PURA 2	CB PURA I/A	12:25	12:57	0:32	LINE FAULT
464	26-Oct-18	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	17:37	17:45	0:08	LINE FAULT
465	26-Oct-18	BANGALORE	66	DABUSPET 220 - HIREHALLI	HIREHALLI	11:01	13:20	2:19	LINE CLEAR AVAILED
466	26-Oct-18	BANGALORE	66	DB PURA 220 - CB PURA 2	CB PURA I/A	12:25	12:34	0:09	LINE FAULT
467	26-Oct-18	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	17:20	17:37	0:16	LINE FAULT
468	26-Oct-18	BANGALORE	66	HV1	HOSKOTE 220	15:22	15:25	0:02	TRANSFORMER FAULT
469	26-Oct-18	BANGALORE	66	HV1	HULLENAHALLI	9:26	10:50	1:23	LINE CLEAR AVAILED
470	26-Oct-18	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:28	13:42	0:13	LINE FAULT
471	26-Oct-18	BANGALORE	66	KYALANUR - TALAGAWARA	KYALANUR	16:45	16:55	0:09	LOAD CHANGEVER
472	26-Oct-18	BANGALORE	66	VEMGAL - KOLAR 220	VEMGAL, KYALANUR	13:10	13:20	0:10	MAIN SUPPLY FAILURE
473	26-Oct-18	BANGALORE	66	KYALANUR - VEMGAL	VEMGAL	13:40	14:12	0:32	MAIN SUPPLY FAILURE
474	26-Oct-18	BANGALORE	66	HV1	LAKKUR	13:08	16:30	3:21	LINE CLEAR AVAILED
475	26-Oct-18	BANGALORE	66	HV2	LAKKUR	16:35	16:40	0:05	LINE CLEAR AVAILED
476	26-Oct-18	BANGALORE	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	6:57	7:01	0:03	LINE FAULT
477	26-Oct-18	BANGALORE	66	HV1	TUBUGERE	16:00	16:10	0:10	LINE CLEAR AVAILED
478	26-Oct-18	BANGALORE	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	13:08	13:46	0:37	LINE CLEAR AVAILED
479	26-Oct-18	BANGALORE	66	HV1	BTM 4TH PHASE	13:08	13:57	0:48	LINE CLEAR AVAILED
480	26-Oct-18	BANGALORE	66	HV2	BTM 4TH PHASE	13:08	13:53	0:44	LINE CLEAR AVAILED
481	26-Oct-18	BANGALORE	66	HV2	BTM 4TH PHASE	23:36	23:48	0:12	TRANSFORMER FAULT
482	26-Oct-18	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENTS, CESSNO, CESSNO(EHT)	12:12	12:28	0:16	LOAD CURTAILMENT
483	26-Oct-18	BANGALORE	220	SOMANAHALLI 220 - NAGANATHPURA 220	NAGANATHPURA 220	12:11	12:42	0:31	HAND TRIPPED
484	26-Oct-18	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	12:11	12:43	0:32	MAIN SUPPLY FAILURE
485	26-Oct-18	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON (EHT), TECH MAHINDRA(EHT)	12:11	12:44	0:33	MAIN SUPPLY FAILURE
486	26-Oct-18	BANGALORE	66	HV1	NAGANATHPURA 220	12:11	12:39	0:28	MAIN SUPPLY FAILURE
487	26-Oct-18	BANGALORE	66	HV2	NAGANATHPURA 220	12:11	12:40	0:29	MAIN SUPPLY FAILURE
488	26-Oct-18	BANGALORE	66	HV3	NAGANATHPURA 220	12:11	12:40	0:29	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
489	26-Oct-18	BANGALORE	66	TK HALLI 220 - MANDYA 1	MANDYA	16:33	18:14	1:40	MAIN SUPPLY FAILURE
490	26-Oct-18	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	16:33	18:02	1:28	LINE FAULT
491	26-Oct-18	BANGALORE	66	TK HALLI 220 - SHIMSHA 1	TK HALLI 220	16:33	17:04	0:30	LINE FAULT
492	26-Oct-18	BANGALORE	66	TK HALLI 220 - SHIMSHA 2	TK HALLI 220	16:33	17:02	0:29	LINE FAULT
493	26-Oct-18	BANGALORE	66	TK HALLI 220 - IGGALUR	IGGALUR, AKKURMOLE	16:33	16:44	0:10	MAIN SUPPLY FAILURE
494	26-Oct-18	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	16:33	17:12	0:38	MAIN SUPPLY FAILURE
495	26-Oct-18	BANGALORE	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR	16:33	17:10	0:36	MAIN SUPPLY FAILURE
496	26-Oct-18	BANGALORE	66	TK HALLI 220 - IGGALUR	IGGALUR, AKKURMOLE	16:45	16:50	0:05	MAIN SUPPLY FAILURE
497	26-Oct-18	BANGALORE	220	HV2	TK HALLI 220	16:33	16:44	0:10	TRANSFORMER FAULT
498	26-Oct-18	BANGALORE	220	HV2	TK HALLI 220	16:45	16:50	0:04	TRANSFORMER FAULT
499	26-Oct-18	BANGALORE	66	HV2	TK HALLI 220	15:38	15:48	0:10	LINE CLEAR AVAILED
500	26-Oct-18	GULBARGA	220	HV2	ITTAGI_220	16:22	17:04	0:42	LINE CLEAR AVAILED
501	26-Oct-18	GULBARGA	220	KUSTAGI-LINGAPUR	LINGAPUR_220	10:11	12:49	2:38	NBFC ISSUED
502	26-Oct-18	GULBARGA	220	HV1	SEDAM_220	10:45	11:10	0:25	LINE CLEAR AVAILED
503	26-Oct-18	GULBARGA	110	GURUMITAL-SEDAM	GURUMITAKAL_110, KONKAL_110	10:42	11:31	0:49	LINE CLEAR AVAILED
504	26-Oct-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARG OAN_110,KAMALANAGAR_1 10	11:09	11:18	0:09	LINE FAULT
505	26-Oct-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARG OAN_110,KAMALANAGAR_1 10	12:10	12:19	0:09	LINE FAULT
506	26-Oct-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARG OAN_110,KAMALANAGAR_1 10	9:39	10:06	0:27	LINE FAULT
507	26-Oct-18	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARG OAN_110,KAMALANAGAR_1 10	9:15	9:23	0:08	LINE FAULT
508	26-Oct-18	GULBARGA	110	HALBURGA-KOLHAR2	KOLHAR_110,JANAWADA_1 10,NSSK SUGAR FACTORY_IPP	9:15	9:24	0:09	LINE FAULT
509	26-Oct-18	GULBARGA	110	HALBURGA-KOLHAR2	KOLHAR_110,JANAWADA_1 10,NSSK SUGAR FACTORY_IPP	9:39	10:55	1:16	LINE FAULT
510	26-Oct-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	10:58	13:22	2:24	LINE CLEAR AVAILED
511	26-Oct-18	GULBARGA	110	KOLHAR-JANAWADA	JANAWADA_110,NSSK SUGAR FACTORY_IPP	12:10	12:18	0:08	LINE CLEAR AVAILED
512	26-Oct-18	GULBARGA	110	HV1	SIRWAR_110	11:55	12:19	0:24	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
513	26-Oct-18	GULBARGA	110	YADGIR-KONKAL	YADGIR_110	0:00	10:10	10:10	LINE FAULT
514	26-Oct-18	GULBARGA	110	YADGIR-KONKAL	YADGIR_110	11:14	23:59	12:45	LINE FAULT
515	26-Oct-18	GULBARGA	110	HV2	SHAKTINAGAR_110	11:28	12:16	0:48	LINE CLEAR AVAILED
516	26-Oct-18	GULBARGA	110	HALBARGA-KOLHAR	KOLHAR_110	0:00	11:55	11:55	LINE FAULT
517	26-Oct-18	GULBARGA	66	HV2	KOTTUR_66	11:56	13:19	1:23	LINE CLEAR AVAILED
518	26-Oct-18	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	5:34	18:35	13:01	LINE CLEAR AVAILED
519	26-Oct-18	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	14:06	14:42	0:36	LINE FAULT
520	26-Oct-18	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:12	14:34	0:22	LINE FAULT
521	26-Oct-18	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	0:00	16:37	16:37	LINE CLEAR AVAILED
522	26-Oct-18	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	14:07	14:11	0:04	LINE FAULT
523	26-Oct-18	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	0:00	16:37	16:37	NBFC ISSUED
524	26-Oct-18	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	14:07	14:34	0:27	LINE FAULT
525	26-Oct-18	HASSAN	110	HV2	BAIKAMPADY_110	13:17	13:37	0:20	TRANSFORMER FAULT
526	26-Oct-18	HASSAN	110	HV2	HIRIYADKA_110	11:39	13:33	1:54	LINE CLEAR AVAILED
527	26-Oct-18	HASSAN	110	HV2	JOG_110	10:04	16:35	6:31	LINE CLEAR AVAILED
528	26-Oct-18	HASSAN	110	KADUR-YGTI	KADUR_220	15:51	16:16	0:25	LINE FAULT
529	26-Oct-18	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:20	11:28	0:08	LINE FAULT
530	26-Oct-18	HASSAN	110	LPH-LST3	lph_gen	16:22	17:17	0:55	LINE FAULT
531	26-Oct-18	HASSAN	110	LPH-LST4	lph_gen	16:22	17:11	0:49	LINE FAULT
532	26-Oct-18	HASSAN	110	LPH-LST3	lph_gen	17:05	17:35	0:30	LINE FAULT
533	26-Oct-18	HASSAN	110	LPH-LST4	lph_gen	17:05	17:35	0:30	LINE FAULT
534	26-Oct-18	HASSAN	110	LPHLST3	lph_gen	22:15	23:05	0:50	LINE CLEAR AVAILED
535	26-Oct-18	HASSAN	110	LPH-LST4	lph_gen	22:15	23:05	0:50	LINE CLEAR AVAILED
536	26-Oct-18	HASSAN	66	HV2	ARAKALGUD_66	1:07	5:37	4:30	TRANSFORMER FAULT
537	26-Oct-18	HASSAN	66	ARAKALMALLIPATNA	ARAKALGUD_66	1:07	5:32	4:25	LINE FAULT
538	26-Oct-18	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	10:23	12:50	2:27	LINE CLEAR AVAILED
539	26-Oct-18	HASSAN	66	HV1	HAGARE_66	14:58	15:16	0:18	LINE CLEAR AVAILED
540	26-Oct-18	HASSAN	66	HV2	HIRESAVE_66	12:03	15:21	3:18	LINE CLEAR AVAILED
541	26-Oct-18	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:43	16:07	4:24	LINE CLEAR AVAILED
542	26-Oct-18	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	11:47	16:17	4:30	LINE CLEAR AVAILED
543	26-Oct-18	HASSAN	66	HV1	MOSALEHOSAHALLI_66	12:10	13:54	1:44	NBFC ISSUED
544	26-Oct-18	HASSAN	66	HV1	MOSALEHOSAHALLI_66	16:13	16:17	0:04	HAND TRIPPED
545	26-Oct-18	HASSAN	66	HV2	RAMNATHPURA_66	14:26	14:52	0:26	MAIN SUPPLY FAILURE
546	26-Oct-18	HASSAN	66	HV2	RAMNATHPURA_66	17:32	17:42	0:10	HAND TRIPPED
547	26-Oct-18	HASSAN	66	HV1	RAMNATHPURA_66	14:26	14:52	0:26	MAIN SUPPLY FAILURE
548	26-Oct-18	HASSAN	66	HV1	RAMNATHPURA_66	17:32	17:42	0:10	HAND TRIPPED
549	26-Oct-18	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	14:26	14:52	0:26	MAIN SUPPLY FAILURE
550	26-Oct-18	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	17:32	17:42	0:10	HAND TRIPPED
551	26-Oct-18	HASSAN	66	RAMNAT-KUSALNAGARA	RAMNATHPURA_66	14:26	14:52	0:26	MAIN SUPPLY FAILURE
552	26-Oct-18	HASSAN	66	RAMNAT-KUSALNAGARA	RAMNATHPURA_66	17:32	17:42	0:10	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
553	26-Oct-18	MYSORE	66	HV1	AKKIHEBBAL_66	9:21	9:30	0:08	HAND TRIPPED
554	26-Oct-18	MYSORE	66	HV2	AKKIHEBBAL_66	9:21	9:30	0:08	HAND TRIPPED
555	26-Oct-18	MYSORE	66	HV1	ANEGOLAL_66	11:29	12:49	1:20	LINE CLEAR AVAILED
556	26-Oct-18	MYSORE	66	HV1	ANEGOLAL_66	13:04	13:36	0:32	LINE CLEAR AVAILED
557	26-Oct-18	MYSORE	66	HV1	ANEGOLAL_66	14:28	14:34	0:05	LINE CLEAR AVAILED
558	26-Oct-18	MYSORE	66	HV2	ANEGOLAL_66	10:10	11:30	1:20	LINE CLEAR AVAILED
559	26-Oct-18	MYSORE	66	HV2	ANEGOLAL_66	14:00	14:30	0:30	LINE CLEAR AVAILED
560	26-Oct-18	MYSORE	66	HV1	HANNUR_66	15:14	15:34	0:19	LINE CLEAR AVAILED
561	26-Oct-18	MYSORE	66	HV1	HANNUR_66	12:10	12:50	0:40	LINE CLEAR AVAILED
562	26-Oct-18	MYSORE	66	HV2	HANNUR_66	12:10	13:20	1:10	LINE CLEAR AVAILED
563	26-Oct-18	MYSORE	66	HV1	HARADANAHALLI_66	13:10	14:29	1:19	LINE CLEAR AVAILED
564	26-Oct-18	MYSORE	66	HV2	HARADANAHALLI_66	12:15	13:45	1:30	LINE CLEAR AVAILED
565	26-Oct-18	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66	8:49	8:55	0:06	LINE FAULT
566	26-Oct-18	MYSORE	66	HV1	K_HONNALGERE_66	16:34	16:44	0:10	HAND TRIPPED
567	26-Oct-18	MYSORE	66	HV2	K_HONNALGERE_66	16:34	16:44	0:10	HAND TRIPPED
568	26-Oct-18	MYSORE	66	HV1	K_HONNALGERE_66	18:08	18:12	0:04	HAND TRIPPED
569	26-Oct-18	MYSORE	66	HV2	K_HONNALGERE_66	18:08	18:12	0:04	HAND TRIPPED
570	26-Oct-18	MYSORE	66	KIKKERI-KRPET	KIKKERI_66	11:15	13:09	1:53	LINE CLEAR AVAILED
571	26-Oct-18	MYSORE	66	HV1	KRPET_66	13:32	14:09	0:36	LINE CLEAR AVAILED
572	26-Oct-18	MYSORE	66	HV3	KRPET_66	13:32	14:09	0:36	LINE CLEAR AVAILED
573	26-Oct-18	MYSORE	66	MEGALAPURA-SFC	CHIDRAVALLI_66 THUMBLA TNARASIPURA_66 BGPURA_66	14:22	14:28	0:06	LINE FAULT
574	26-Oct-18	TUMKUR	220	TR-1 & TR-2(HV SIDE)	ANCHEPALYA_220	12:13	17:43	5:29	LINE CLEAR AVAILED
575	26-Oct-18	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA	ANCHEPALYA_220	12:13	17:42	5:28	LINE CLEAR AVAILED
576	26-Oct-18	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA	ANCHEPALYA_220	12:13	17:42	5:28	LINE CLEAR AVAILED
577	26-Oct-18	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	9:32	11:17	1:44	LINE CLEAR AVAILED
578	26-Oct-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	8:43	12:13	3:30	LINE CLEAR AVAILED
579	26-Oct-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	16:51	18:20	1:29	LINE CLEAR AVAILED
580	26-Oct-18	TUMKUR	66	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	ANCHEPALYA 220kV- ANCHEPALYA 1	12:13	14:48	2:34	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
581	26-Oct-18	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	16:51	17:47	0:56	LINE CLEAR AVAILED
582	26-Oct-18	TUMKUR	66	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	ANCHEPALYA 220kV- ANCHEPALYA 1	12:13	18:20	6:07	LINE CLEAR AVAILED
583	26-Oct-18	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	12:13	18:20	6:07	LINE CLEAR AVAILED
584	26-Oct-18	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	8:43	12:26	3:43	LINE CLEAR AVAILED
585	26-Oct-18	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	16:51	17:47	0:55	LINE CLEAR AVAILED
586	26-Oct-18	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	12:13	12:26	0:13	LINE CLEAR AVAILED
587	26-Oct-18	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	16:51	17:46	0:55	LINE CLEAR AVAILED
588	26-Oct-18	TUMKUR	66	TR-1 & TR-2(LV SIDE)	ANCHEPALYA_220	12:13	17:47	5:33	LINE CLEAR AVAILED
589	26-Oct-18	TUMKUR	66	HEBBUR_66, THIMMASANDRA_66, BHAKTHARAHALLI_66	ANCHEPALYA 220kV- HEBBUR	12:13	18:20	6:07	LINE CLEAR AVAILED
590	26-Oct-18	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR	YEDIYUR_66	16:51	17:48	0:57	LINE CLEAR AVAILED
591	26-Oct-18	TUMKUR	66	TR-2	ANCHEPALYA_66	9:47	14:10	4:23	LINE CLEAR AVAILED
592	26-Oct-18	TUMKUR	66	TR-2	ANCHEPALYA_66	15:55	18:16	2:20	HAND TRIPPED
593	26-Oct-18	TUMKUR	66	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	CHITRADURGA 220kV- PANDARAHALLI 2	8:13	8:47	0:34	LINE FAULT
594	26-Oct-18	TUMKUR	66	TR-2	HALURAMESHWARA_66	16:15	16:48	0:32	LINE CLEAR AVAILED
595	26-Oct-18	TUMKUR	66	TR-2	HALURAMESHWARA_66	18:06	18:26	0:20	LINE CLEAR AVAILED
596	26-Oct-18	TUMKUR	66	TR-2	HIREGUNTANUR_66	8:04	8:32	0:27	LINE CLEAR AVAILED
597	26-Oct-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	8:52	8:57	0:05	HAND TRIPPED
598	26-Oct-18	TUMKUR	66	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	HONNALLI 220kV- CHANNAGIRI	10:38	12:30	1:51	LINE FAULT
599	26-Oct-18	TUMKUR	66	TR-1 & TR-2	KUNIGAL_66	9:35	15:20	5:45	LINE CLEAR AVAILED
600	26-Oct-18	TUMKUR	66	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	MADHUGIRI 220kV- SIRA	16:57	17:16	0:19	HAND TRIPPED
601	26-Oct-18	TUMKUR	66	TR-1	MAYAKONDA_66	12:22	13:58	1:35	LINE CLEAR AVAILED
602	26-Oct-18	TUMKUR	66	SIRA- MADHUGIRI 1	SIRA_66	16:53	17:27	0:34	HAND TRIPPED
603	26-Oct-18	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	17:21	17:27	0:05	HAND TRIPPED
604	26-Oct-18	TUMKUR	66	CHALLAKERE_66, SANIKERE_66	CHALLAKERE_66, SANIKERE_66	20:55	21:01	0:06	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
605	26-Oct-18	TUMKUR	66	TR-1	YNHOSKOTE_66	13:16	13:55	0:38	TRANSFORMER FAULT
606	27-Oct-18	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	20:21	23:59	3:38	LINE FAULT
607	27-Oct-18	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	16:45	18:31	1:46	LINE CLEAR AVAILED
608	27-Oct-18	BAGALKOT	110	110/11KV, HV2	DAVALESHWAR_110	13:02	14:41	1:39	LINE CLEAR AVAILED
609	27-Oct-18	BAGALKOT	110	110/11KV,HV2A	JAMKHANDI_110	8:00	9:54	1:54	HAND TRIPPED
610	27-Oct-18	BAGALKOT	110	110/11KV,HV3	JAMKHANDI_110	9:50	9:54	0:04	HAND TRIPPED
611	27-Oct-18	BAGALKOT	110	KARAWAR220-ARGA	ARGA_110	9:57	15:12	5:15	LINE FAULT
612	27-Oct-18	BAGALKOT	110	SOLARIS-KARAWAR220	KARAWAR_220	16:23	18:07	1:44	LINE CLEAR AVAILED
613	27-Oct-18	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(G)_110	11:13	12:13	1:00	LINE CLEAR AVAILED
614	27-Oct-18	BAGALKOT	110	110/11KV,HV3	KULIGOD_110	10:08	10:20	0:12	TRANSFORMER FAULT
615	27-Oct-18	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	19:28	19:28	HAND TRIPPED
616	27-Oct-18	BAGALKOT	110	NARENDRA220-KUD DHARWAD	KUD DHARWAD_110	12:59	13:11	0:12	LINE FAULT
617	27-Oct-18	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	14:18	14:27	0:09	TRANSFORMER FAULT
618	27-Oct-18	BAGALKOT	110	110/11KV,HV2	TERDAL_110	11:27	13:17	1:50	HAND TRIPPED
619	27-Oct-18	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	13:15	13:17	0:02	LINE CLEAR AVAILED
620	27-Oct-18	BAGALKOT	220	NAGJHARI 1-HUBLI	HUBLI_220	11:54	12:17	0:23	LINE FAULT
621	27-Oct-18	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	13:45	14:10	0:25	LINE FAULT
622	27-Oct-18	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	14:11	19:51	5:40	LINE FAULT
623	27-Oct-18	BAGALKOT	110	SOUDATTI 220-SOUDATTI 1	SOUDATTI_110	12:06	16:10	4:04	LINE CLEAR AVAILED
624	27-Oct-18	BAGALKOT	110	110/1KV,HV1	SANKESHWAR_110	14:31	14:35	0:04	TRANSFORMER FAULT
625	27-Oct-18	BAGALKOT	110	SIRSI-KUMATA2	KUMATA_110	11:00	11:33	0:33	HAND TRIPPED
626	27-Oct-18	BAGALKOT	110	SIRSI-KUMATA1	KUMATA_110	11:00	11:33	0:33	HAND TRIPPED
627	27-Oct-18	BANGALORE	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	14:15	15:05	0:50	LINE CLEAR AVAILED
628	27-Oct-18	BANGALORE	66	APPAREL PARK - DB PURA 220	APPAREL PARK	16:25	16:40	0:15	LOAD CHANGEOVER
629	27-Oct-18	BANGALORE	66	BYADRAHALLI - KODIGEHALLI	KODIGEHALLI, TAVAREKERE	12:14	12:47	0:32	LINE CLEAR AVAILED
630	27-Oct-18	BANGALORE	66	HV2	DEVARABISANAHALLI	4:19	4:35	0:15	LINE CLEAR AVAILED
631	27-Oct-18	BANGALORE	66	HV2	DEVARABISANAHALLI	7:50	8:10	0:20	LINE CLEAR AVAILED
632	27-Oct-18	BANGALORE	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	14:33	14:37	0:04	LOAD CHANGEOVER
633	27-Oct-18	BANGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	16:09	16:13	0:04	LOAD CHANGEOVER
634	27-Oct-18	BANGALORE	66	ELECTRONIC CITY - INFOSYS (EHT)	INFOSYS (EHT)	10:43	13:30	2:47	LINE FAULT
635	27-Oct-18	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	23:04	23:42	0:38	LINE FAULT
636	27-Oct-18	BANGALORE	66	HV2	VICTORIA HOSPITAL	10:04	10:07	0:03	LINE CLEAR AVAILED
637	27-Oct-18	BANGALORE	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	23:05	23:10	0:05	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
638	27-Oct-18	BANGALORE	66	HV2	NELEKADIRENAHALLI	14:20	14:30	0:10	TRANSFORMER FAULT
639	27-Oct-18	BANGALORE	66	HV2	KUMBALAGODU	13:30	15:09	1:38	LINE CLEAR AVAILED
640	27-Oct-18	BANGALORE	66	HV3	BANGARPET	8:10	9:25	1:15	LINE CLEAR AVAILED
641	27-Oct-18	BANGALORE	66	GUNDAMGERE - DB PURA 220	GUNDAMGERE	13:40	14:00	0:20	LOAD CHANGEOVER
642	27-Oct-18	BANGALORE	66	GUNDAMGERE - GOWRIBIDANUR 220	GUNDAMGERE	16:30	16:40	0:10	LOAD CHANGEOVER
643	27-Oct-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI	10:05	10:15	0:09	LINE FAULT
644	27-Oct-18	BANGALORE	66	HV1	SUGATUR	11:13	11:36	0:23	TRANSFORMER FAULT
645	27-Oct-18	GULBARGA	220	HV1,HV2	RAICHUR_220	13:30	13:55	0:25	LINE CLEAR AVAILED
646	27-Oct-18	GULBARGA	220	LINGAPUR-BTPS	BTPS_400	5:01	17:02	12:01	LINE FAULT
647	27-Oct-18	GULBARGA	220	HV2	ITTAGI_220	8:55	14:11	5:16	HAND TRIPPED
648	27-Oct-18	GULBARGA	110	HV2	ALIPUR_220	9:06	14:01	4:55	LINE CLEAR AVAILED
649	27-Oct-18	GULBARGA	110	HV2	SIRIGUPPA_110	10:02	10:52	0:50	LINE CLEAR AVAILED
650	27-Oct-18	GULBARGA	110	HV2	SIRIGUPPA_110	10:57	11:07	0:10	TRANSFORMER FAULT
651	27-Oct-18	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPURA_110,MANVI_110	11:46	12:07	0:21	LINE CLEAR AVAILED
652	27-Oct-18	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,DONGARG OAN_110,KAMALANAGAR_110	1:04	1:15	0:11	LINE FAULT
653	27-Oct-18	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,DONGARG OAN_110,KAMALANAGAR_110	11:05	11:25	0:20	LINE FAULT
654	27-Oct-18	GULBARGA	110	HALBURGA-KOLHAR1,2	KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY_IPP	11:05	11:25	0:20	LINE FAULT
655	27-Oct-18	GULBARGA	110	HALBURGA-KOLHAR1,2	KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY_IPP	11:51	12:05	0:14	LINE FAULT
656	27-Oct-18	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,DONGARG OAN_110,KAMALANAGAR_110	11:51	12:00	0:09	LINE FAULT
657	27-Oct-18	GULBARGA	110	SANTHAPUR-CSPSLR,WARDASLR,RNW_SLR	SANTHAPUR_110	11:33	11:40	0:07	LINE CLEAR AVAILED
658	27-Oct-18	GULBARGA	110	SANTHAPUR-CSPSLR,WARDASLR,RNW_SLR	SANTHAPUR_110	12:04	12:31	0:27	LINE CLEAR AVAILED
659	27-Oct-18	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	22:42	23:59	1:17	LINE FAULT
660	27-Oct-18	GULBARGA	110	SIDHANOOR-RAICHUR2(IDLE LINE)	MANVI_110	9:10	13:15	4:05	LINE CLEAR AVAILED
661	27-Oct-18	GULBARGA	110	HV1	PD_HALLI_110	17:00	17:15	0:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
662	27-Oct-18	GULBARGA	110	KOLHAR- SHAHI_SOLAR	KOLHAR_110	10:15	10:55	0:40	LINE FAULT
663	27-Oct-18	GULBARGA	110	MALLAT--BYAGAWAT,ACMBSLR	BYAGAWAT_110	15:17	15:40	0:23	LINE CLEAR AVAILED
664	27-Oct-18	GULBARGA	66	LV1	ITTAGI_220	5:40	6:00	0:20	TRANSFORMER FAULT
665	27-Oct-18	GULBARGA	66	LV2	ITTAGI_220	5:40	6:00	0:20	TRANSFORMER FAULT
666	27-Oct-18	GULBARGA	66	ITTAGGI-BENNAHALLI	BENNAHALLI_66,KOTTUR_6 6,UJJANI_66	5:40	6:10	0:30	LINE FAULT
667	27-Oct-18	GULBARGA	66	ITTAGGI-KUDLIGI1,2	KUDLIGI_66,CHORNOOR_66 ,BANAVEKAL_66,GUDEKOTE _66,CJHALLI_66,HOSAHALLI _66	5:40	6:10	0:30	LINE FAULT
668	27-Oct-18	GULBARGA	66	ITTAGGI-HBHALLI	HAGARIBOMMANAHALLI_6 6	8:56	15:04	6:08	LINE CLEAR AVAILED
669	27-Oct-18	GULBARGA	66	ITTAGGI-TBHALLI	TAMBRAHALLI_66,MORAGE RA_66,HAMPASAGAR_66	10:35	14:30	3:55	LINE CLEAR AVAILED
670	27-Oct-18	GULBARGA	66	ITTAGGI-SUZLON1,2	ITTAGI_220	10:38	11:00	0:22	LINE CLEAR AVAILED
671	27-Oct-18	GULBARGA	66	ITTAGGI-BENNAHLLI	BENNAHALLI_66,KOTTUR_6 6,UJJANI_66	11:35	13:18	1:43	LINE CLEAR AVAILED
672	27-Oct-18	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	6:15	19:20	13:05	LINE CLEAR AVAILED
673	27-Oct-18	HASSAN	110	KEMAR-Manipal2	KEMAR_220	11:59	13:14	1:15	LINE CLEAR AVAILED
674	27-Oct-18	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	6:14	19:19	13:05	NBFC ISSUED
675	27-Oct-18	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	9:36	23:59	14:23	LINE FAULT
676	27-Oct-18	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	10:14	11:30	1:16	HAND TRIPPED
677	27-Oct-18	HASSAN	110	LPH-LST4	lph_gen	18:10	19:57	1:47	LINE FAULT
678	27-Oct-18	HASSAN	66	HASSN22-HN PURA	hassan_220	11:47	12:23	0:36	LINE CLEAR AVAILED
679	27-Oct-18	HASSAN	66	HV2	BELUR_66	10:26	10:32	0:06	TRANSFORMER FAULT
680	27-Oct-18	HASSAN	66	HV2	BELUR_66	15:08	15:20	0:12	TRANSFORMER FAULT
681	27-Oct-18	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:50	15:57	0:07	LINE FAULT
682	27-Oct-18	HASSAN	66	HV1	HASSAN_66	9:20	17:35	8:15	LINE CLEAR AVAILED
683	27-Oct-18	HASSAN	66	HV2	HASSAN_66	13:25	16:15	2:50	LINE CLEAR AVAILED
684	27-Oct-18	HASSAN	66	RAMNAT-KUSALNAGARA	RAMNATHPURA_66	8:49	23:59	15:10	HAND TRIPPED
685	27-Oct-18	MYSORE	66	HV1	FTS_66	6:46	8:13	1:27	HAND TRIPPED
686	27-Oct-18	MYSORE	66	HV2	FTS_66	4:06	18:05	13:58	HAND TRIPPED
687	27-Oct-18	MYSORE	66	HV2	FTS_66	19:34	19:42	0:08	TRANSFORMER FAULT
688	27-Oct-18	MYSORE	66	HV2	FTS_66	19:42	19:57	0:15	TRANSFORMER FAULT
689	27-Oct-18	MYSORE	66	HV2	FTS_66	19:57	21:37	1:39	TRANSFORMER FAULT
690	27-Oct-18	MYSORE	66	HV2	FTS_66	21:37	23:59	2:21	TRANSFORMER FAULT
691	27-Oct-18	MYSORE	66	HV1	GARUDANAUKADDA_66	13:52	14:20	0:28	LINE CLEAR AVAILED
692	27-Oct-18	MYSORE	66	HV2	HULLAHALLI_66	11:00	12:07	1:07	LINE CLEAR AVAILED
693	27-Oct-18	MYSORE	66	HV2	HULLAHALLI_66	12:30	12:40	0:10	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
694	27-Oct-18	MYSORE	66	HV1	HUNSUR_66	11:46	13:36	1:50	LINE CLEAR AVAILED
695	27-Oct-18	MYSORE	66	HV2	HUNSUR_66	13:53	15:00	1:06	LINE CLEAR AVAILED
696	27-Oct-18	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 K_HONNALGERE_66 MADDUR_66	9:29	14:25	4:55	LINE CLEAR AVAILED
697	27-Oct-18	MYSORE	66	KIADB MANDYA-MADDUR	KIADBMANDYA_66 K_HONNALGERE_66 MADDUR_66	9:29	14:39	5:10	LINE CLEAR AVAILED
698	27-Oct-18	MYSORE	66	KIADB MANDYA-MY SUGAR	KIADBMANDYA_66 K_HONNALGERE_66 MADDUR_66	9:29	14:25	4:55	LINE CLEAR AVAILED
699	27-Oct-18	MYSORE	66	HV1	PGPALYA_66	14:13	16:10	1:56	LINE CLEAR AVAILED
700	27-Oct-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 BASARALU_66 SHIVALLY_66 VADERALLI_66	11:29	11:39	0:09	LINE FAULT
701	27-Oct-18	TUMKUR	220	TR-1(100MVA)	NITTUR_220	12:12	13:17	1:04	LINE CLEAR AVAILED
702	27-Oct-18	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	15:55	17:02	1:06	LINE CLEAR AVAILED
703	27-Oct-18	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	15:03	18:20	3:16	LOAD CURTAILMENT
704	27-Oct-18	TUMKUR	110	TR-1	BIDARE	15:43	15:51	0:08	LINE CLEAR AVAILED
705	27-Oct-18	TUMKUR	110	TR-1(100MVA)	NITTUR_220	14:22	15:20	0:58	LINE CLEAR AVAILED
706	27-Oct-18	TUMKUR	110	TR-2(100MVA)	NITTUR_220	14:30	15:20	0:50	LINE CLEAR AVAILED
707	27-Oct-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	16:47	16:57	0:09	LINE FAULT
708	27-Oct-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	17:32	22:08	4:36	LINE CLEAR AVAILED
709	27-Oct-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:42	15:04	5:22	LINE FAULT
710	27-Oct-18	TUMKUR	66	TR-2	ANCHEPALYA_66	13:37	13:42	0:05	TRANSFORMER FAULT
711	27-Oct-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:19	18:03	9:44	LOAD CHANGEOVER
712	27-Oct-18	TUMKUR	66	TR-2	GULIGENAHALLI_66	12:32	12:38	0:06	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
713	27-Oct-18	TUMKUR	66	HIRIYUR 220KV- MATHOD 2	HINDASGHATTA_66 ,MATH OD_66	9:38	9:44	0:06	LOAD CURTAILMENT
714	27-Oct-18	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66, RAMPURA_66	5:43	5:55	0:12	LINE FAULT
715	27-Oct-18	TUMKUR	66	TR-2	YNHOSKOTE_66	13:10	13:23	0:13	LINE CLEAR AVAILED
716	27-Oct-18	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	1:00	1:16	0:15	LINE FAULT
717	27-Oct-18	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:37	13:49	0:12	LINE FAULT
718	27-Oct-18	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:49	13:52	0:02	LINE FAULT
719	27-Oct-18	TUMKUR	66	TR-2	TAVAREKERE(H)_66	8:00	8:14	0:13	TRANSFORMER FAULT
720	28-Oct-18	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	8:04	23:59	15:55	LINE CLEAR AVAILED
721	28-Oct-18	BAGALKOT	110	110/33KV, HV2	BELGAUM_110	9:01	14:25	5:24	LINE CLEAR AVAILED
722	28-Oct-18	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	12:13	15:48	3:35	LINE FAULT
723	28-Oct-18	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	21:52	23:59	2:07	HAND TRIPPED
724	28-Oct-18	BAGALKOT	220	NARENDRA-AMBEWAD1	NARENDRA_220	16:05	17:39	1:34	LINE CLEAR AVAILED
725	28-Oct-18	BAGALKOT	110	NARENDRA220-KUD DHARWAD	KUD DHARWAD_110	11:47	11:52	0:05	LINE FAULT
726	28-Oct-18	BAGALKOT	220	HUBLI2-SIRSI	SIRSI_220	9:13	23:59	14:46	LINE FAULT
727	28-Oct-18	BAGALKOT	110	110/11KV,HV1	ZALKI_110	14:02	14:06	0:04	TRANSFORMER FAULT
728	28-Oct-18	BAGALKOT	110	110/11KV,HV1	TERDAL_110	14:12	14:18	0:06	TRANSFORMER FAULT
729	28-Oct-18	BAGALKOT	110	JOE 1-SIRSI	SIRSI_110	10:20	13:52	3:32	NBFC ISSUED
730	28-Oct-18	BAGALKOT	110	110/11KV,HV-1	SAIDAPUR_110	12:50	13:47	0:57	HAND TRIPPED
731	28-Oct-18	BAGALKOT	110	MUNDARAGI-VIJAY SUGARS	MUNDARAGI_110	6:19	6:28	0:09	LINE FAULT
732	28-Oct-18	BAGALKOT	110	110/11KV,HV-3	MUDHOL_110	6:35	6:39	0:04	TRANSFORMER FAULT
733	28-Oct-18	BAGALKOT	110	110/11KV,HV-3	MUDHOL_110	6:46	6:53	0:07	TRANSFORMER FAULT
734	28-Oct-18	BANGALORE	66	HV2	ANEKAL	10:35	10:40	0:05	LINE CLEAR AVAILED
735	28-Oct-18	BANGALORE	66	HV1	BANGARPET	15:30	15:41	0:11	TRANSFORMER FAULT
736	28-Oct-18	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	21:30	21:38	0:07	LINE FAULT
737	28-Oct-18	BANGALORE	66	HV2	KODIHALLI KANAKPURA	13:43	14:06	0:22	TRANSFORMER FAULT
738	28-Oct-18	BANGALORE	66	HV1	SIDLAGATTA	9:56	10:50	0:53	TRANSFORMER FAULT
739	28-Oct-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI	11:03	17:19	6:16	LINE CLEAR AVAILED
740	28-Oct-18	BANGALORE	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	18:05	18:10	0:05	LOAD CHANGEVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
741	28-Oct-18	BANGALORE	66	HV2	ABBIGERE	2:54	3:21	0:26	TRANSFORMER FAULT
742	28-Oct-18	BANGALORE	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	8:40	8:50	0:10	LOAD CHANGEOVER
743	28-Oct-18	BANGALORE	66	BANASHANKARI - AREHALLI	BANASHANKARI	17:23	17:40	0:17	LOAD CHANGEOVER
744	28-Oct-18	BANGALORE	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	6:28	6:40	0:12	LOAD CHANGEOVER
745	28-Oct-18	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	13:11	14:19	1:08	LINE FAULT
746	28-Oct-18	BANGALORE	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	8:45	8:55	0:10	LOAD CHANGEOVER
747	28-Oct-18	BANGALORE	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KUMBALAGODU	16:36	16:44	0:08	LOAD CHANGEOVER
748	28-Oct-18	BANGALORE	66	HV1	NELEKADIRENAHALLI	14:07	14:14	0:07	LINE CLEAR AVAILED
749	28-Oct-18	BANGALORE	66	HV2	NELEKADIRENAHALLI	13:38	14:01	0:22	LINE CLEAR AVAILED
750	28-Oct-18	BANGALORE	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	6:10	6:15	0:05	LOAD CHANGEOVER
751	28-Oct-18	BANGALORE	66	PLATINUM CITY - SAHAKARINAGAR	PLATINUM CITY	8:10	8:15	0:05	LOAD CHANGEOVER
752	28-Oct-18	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	6:30	6:35	0:05	LOAD CHANGEOVER
753	28-Oct-18	BANGALORE	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	11:00	17:33	6:33	LINE CLEAR AVAILED
754	28-Oct-18	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	11:00	17:33	6:33	LINE CLEAR AVAILED
755	28-Oct-18	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:00	17:33	6:33	LINE CLEAR AVAILED
756	28-Oct-18	BANGALORE	66	HV1	VIKAS TECH PARK 220	11:00	17:33	6:33	LINE CLEAR AVAILED
757	28-Oct-18	BANGALORE	66	HV2	VIKAS TECH PARK 220	11:00	17:33	6:33	LINE CLEAR AVAILED
758	28-Oct-18	BANGALORE	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK, GTP (EHT)	11:03	11:05	0:02	LOAD CHANGEOVER
759	28-Oct-18	BANGALORE	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK, GTP (EHT)	17:27	17:28	0:01	LOAD CHANGEOVER
760	28-Oct-18	BANGALORE	220	JIGANI 220 - SOMANAHALLI 220	JIGANI 220	13:15	14:37	1:22	LINE CLEAR AVAILED
761	28-Oct-18	BANGALORE	66	HV1	JIGANI 220	13:15	14:37	1:22	MAIN SUPPLY FAILURE
762	28-Oct-18	BANGALORE	66	HV2	JIGANI 220	13:15	14:37	1:22	MAIN SUPPLY FAILURE
763	28-Oct-18	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	13:12	13:28	0:16	LOAD CHANGEOVER
764	28-Oct-18	BANGALORE	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 66	14:15	14:32	0:17	LOAD CHANGEOVER
765	28-Oct-18	GULBARGA	110	HALBARGA-KOLHAR1	KOLHAR_110,JANAWADA_1 10,NSSK SUGAR FACTORY_IPP	7:35	7:45	0:10	LINE FAULT
766	28-Oct-18	GULBARGA	110	HALBARGA-KOLHAR1	KOLHAR_110,JANAWADA_1 10,NSSK SUGAR FACTORY_IPP	11:49	11:52	0:03	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
767	28-Oct-18	GULBARGA	110	HALBARGA-KOLHAR1	KOLHAR_110,JANAWADA_1 10,NSSK SUGAR FACTORY_IPP	11:55	14:07	2:12	LINE FAULT
768	28-Oct-18	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_1 10	0:18	0:25	0:07	LINE FAULT
769	28-Oct-18	GULBARGA	110	YADAGIR-SHAHPUR	YADAGIR_110	10:30	10:35	0:05	LINE CLEAR AVAILED
770	28-Oct-18	GULBARGA	110	YADAGIR-SHAHAPUR	YADAGIR_110	11:15	11:20	0:05	LINE CLEAR AVAILED
771	28-Oct-18	GULBARGA	110	HV3	HATTI_110	8:40	10:20	1:40	LINE CLEAR AVAILED
772	28-Oct-18	GULBARGA	66	LV1,LV2	ITTAGI_220	12:00	12:23	0:23	TRANSFORMER FAULT
773	28-Oct-18	GULBARGA	66	ITTAGGI-RENEWSOLAR1	ITTAGI_220	14:19	14:26	0:07	LINE CLEAR AVAILED
774	28-Oct-18	GULBARGA	66	KOTTUR-SUZLON-1	KOTTUR_66	12:12	12:38	0:26	LINE FAULT
775	28-Oct-18	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	8:20	19:02	10:42	LINE CLEAR AVAILED
776	28-Oct-18	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	8:20	19:02	10:42	LINE CLEAR AVAILED
777	28-Oct-18	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	8:45	14:36	5:51	LINE CLEAR AVAILED
778	28-Oct-18	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	8:45	14:52	6:07	LINE CLEAR AVAILED
779	28-Oct-18	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	6:32	19:02	12:30	NBFC ISSUED
780	28-Oct-18	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	6:32	19:03	12:31	NBFC ISSUED
781	28-Oct-18	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	0:00	13:11	13:11	LINE FAULT
782	28-Oct-18	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	13:17	23:59	10:42	LINE FAULT
783	28-Oct-18	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	8:45	14:37	5:52	NBFC ISSUED
784	28-Oct-18	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	8:45	14:52	6:07	NBFC ISSUED
785	28-Oct-18	HASSAN	110	LPH-LST4	lph_gen	6:13	23:59	17:46	LINE FAULT
786	28-Oct-18	HASSAN	110	HV2	SORABA_110	3:10	3:18	0:08	TRANSFORMER FAULT
787	28-Oct-18	HASSAN	110	HV2	SORABA_110	8:48	8:50	0:02	TRANSFORMER FAULT
788	28-Oct-18	HASSAN	66	HV1	HASSAN_66	9:40	12:30	2:50	LINE CLEAR AVAILED
789	28-Oct-18	MYSORE	66	HV1	ARAKERE_66	14:14	14:18	0:03	TRANSFORMER FAULT
790	28-Oct-18	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	6:23	6:36	0:13	LINE FAULT
791	28-Oct-18	MYSORE	66	HV2	FTS_66	13:53	14:32	0:39	HAND TRIPPED
792	28-Oct-18	MYSORE	66	HV2	FTS_66	14:46	15:35	0:48	HAND TRIPPED
793	28-Oct-18	MYSORE	66	HV3	KUSHALANAGARA_66	10:06	11:19	1:13	LINE CLEAR AVAILED
794	28-Oct-18	MYSORE	66	MADHUVANAHALLI-YELANDUR	YELANDUR_66	6:23	6:31	0:08	LINE FAULT
795	28-Oct-18	MYSORE	66	MANDYA-CHIKKA MANDYA	BESAGARAHALLI_66 CHIKKA_MANDYA_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	5:44	5:57	0:12	LINE FAULT
796	28-Oct-18	MYSORE	66	HV2	THALAKADU_66	4:11	4:28	0:17	MAIN SUPPLY FAILURE
797	28-Oct-18	MYSORE	66	HV1	THALAKADU_66	4:11	4:28	0:17	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
798	28-Oct-18	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	14:41	19:13	4:32	HAND TRIPPED
799	28-Oct-18	TUMKUR	66	CHITRADURGA 220kv- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	20:48	21:07	0:19	LINE FAULT
800	28-Oct-18	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:39	15:59	5:19	LINE FAULT
801	28-Oct-18	TUMKUR	66	DEVARAHALLI- CHANNAGIRI	DEVARAHALLI_66	17:02	22:14	5:11	MAIN SUPPLY FAILURE
802	28-Oct-18	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	9:07	17:58	8:51	LOAD CHANGEOVER
803	28-Oct-18	TUMKUR	66	HIRIYUR 220KV- MATHOD 2	HINDASGHATTA_66 ,MATH OD_66	13:01	13:12	0:11	LOAD CURTAILMENT
804	28-Oct-18	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:50	14:15	0:25	LINE FAULT
805	28-Oct-18	TUMKUR	66	HIRIYUR 220KV- ENERCON-1 &2	ENERCON1_IPP_66, ENERCON2_IPP_66	10:21	10:28	0:07	LOAD CURTAILMENT
806	28-Oct-18	TUMKUR	66	HIRIYUR 220KV- SUZLON 2	SUZLON2_IPP_66	14:20	14:30	0:10	LOAD CURTAILMENT
807	28-Oct-18	TUMKUR	66	RANGANATHPURA- HIRIYUR	RANGANATHAPURA_66	13:45	14:40	0:55	LINE FAULT
808	28-Oct-18	TUMKUR	66	TR-1 &2	TAVAREKERE(C)_66	16:58	22:23	5:25	MAIN SUPPLY FAILURE
809	28-Oct-18	TUMKUR	66	TR-2	YARAGUNTA_66	10:51	12:22	1:31	LINE CLEAR AVAILED
810	28-Oct-18	TUMKUR	66	MATHOD- AVANTIIPP_66	AVANTHI_IPP_66	12:41	12:47	0:06	LOAD CURTAILMENT
811	28-Oct-18	TUMKUR	66	HOLALKERE- PANDARAHALLI 2	HOLALKERE_66	9:25	9:30	0:05	LINE FAULT
812	28-Oct-18	TUMKUR	66	HOLALKERE- PANDARAHALLI 2	HOLALKERE_66	10:00	10:05	0:05	LINE FAULT
813	28-Oct-18	TUMKUR	66	HOLALKERE- CHIKKAJAJUR	HOLALKERE_66	9:40	10:35	0:55	LINE CLEAR AVAILED
814	28-Oct-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:07	6:22	0:14	LINE FAULT
815	28-Oct-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:30	14:05	7:35	HAND TRIPPED
816	28-Oct-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	14:15	14:24	0:08	LINE FAULT
817	28-Oct-18	TUMKUR	66	DAVANGERE SRS- H- HOSPET	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:30	9:42	0:12	LINE FAULT
818	28-Oct-18	TUMKUR	66	TR-1 &2	CHANNAGIRI_66	17:06	22:11	5:05	MAIN SUPPLY FAILURE
819	28-Oct-18	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	12:12	13:45	1:32	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
820	29-Oct-18	BAGALKOT	110	BAGALKOT220-LOKAPUR1	LOKAPUR_110, SALAHALLI_110	3:15	3:32	0:17	LINE FAULT
821	29-Oct-18	BAGALKOT	220	XELDOM-AMBEWADI	AMBEWADI_220	14:10	17:56	3:46	LINE FAULT
822	29-Oct-18	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	0:00	20:32	20:32	LINE CLEAR AVAILED
823	29-Oct-18	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	12:08	14:02	1:54	LINE CLEAR AVAILED
824	29-Oct-18	BAGALKOT	110	110/11KV, HV3	BIJAPUR CITY_110	12:07	12:42	0:35	LINE CLEAR AVAILED
825	29-Oct-18	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	0:00	20:30	20:30	LINE CLEAR AVAILED
826	29-Oct-18	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:00	7:17	7:17	HAND TRIPPED
827	29-Oct-18	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	9:32	20:32	11:00	LINE CLEAR AVAILED
828	29-Oct-18	BAGALKOT	110	110/33KV, HV4	GOPPANAKOPPA_110	12:00	13:17	1:17	LINE CLEAR AVAILED
829	29-Oct-18	BAGALKOT	110	110/33KV, HV2	HUNGUND_110	11:42	12:11	0:29	LINE CLEAR AVAILED
830	29-Oct-18	BAGALKOT	220	SIRSI-SHARAVATHI2	SIRSI_220	11:03	12:41	1:38	LINE CLEAR AVAILED
831	29-Oct-18	BAGALKOT	110	110/33KV, HV1&HV2	JAMKHANDI_110	16:00	16:06	0:06	TRANSFORMER FAULT
832	29-Oct-18	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	16:00	16:06	0:06	TRANSFORMER FAULT
833	29-Oct-18	BAGALKOT	110	ICPL-UTTUR	UTTUR_110	17:11	17:54	0:43	HAND TRIPPED
834	29-Oct-18	BAGALKOT	110	SUVARNA SOUDA-MACHE	MACHE_110	3:32	3:53	0:21	LINE FAULT
835	29-Oct-18	BAGALKOT	110	SHIVASAGAR SUGAR-SALAHALLI	SALAHALLI_110	4:08	11:58	7:50	LINE FAULT
836	29-Oct-18	BAGALKOT	110	RANNABELAGALI-UTTUR	UTTUR_110	10:30	17:06	6:36	NBFC ISSUED
837	29-Oct-18	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	7:04	23:59	16:55	HAND TRIPPED
838	29-Oct-18	BAGALKOT	110	110/11KV,HV2	MALGHAN (B)_110	14:09	14:15	0:06	HAND TRIPPED
839	29-Oct-18	BAGALKOT	110	220/110KV,LV1	HUBLI_220	1:58	23:59	22:01	LINE CLEAR AVAILED
840	29-Oct-18	BANGALORE	66	DB PURA 220 - DG 1	AIR (EHT)	2:55	3:01	0:06	LINE FAULT
841	29-Oct-18	BANGALORE	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	10:30	12:05	1:35	LINE CLEAR AVAILED
842	29-Oct-18	BANGALORE	66	HV2	JIGANI 66	13:58	14:17	0:19	LINE CLEAR AVAILED
843	29-Oct-18	BANGALORE	66	HV1	KONDASPURA	7:20	8:22	1:02	TRANSFORMER FAULT
844	29-Oct-18	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANGONDHI	7:23	7:27	0:04	LINE FAULT
845	29-Oct-18	BANGALORE	66	HV1	AMARJYOTHI	6:43	7:18	0:34	MAIN SUPPLY FAILURE
846	29-Oct-18	BANGALORE	66	HV1	AMARJYOTHI	12:33	12:38	0:04	LOAD CHANGEOVER
847	29-Oct-18	BANGALORE	66	AUSTIN TOWN - HSR LAYOUT 220	AMARJYOTHI	6:43	7:18	0:34	LINE FAULT
848	29-Oct-18	BANGALORE	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	8:15	8:20	0:05	LOAD CHANGEOVER
849	29-Oct-18	BANGALORE	220	HV2	EDC 220	6:43	6:54	0:10	TRANSFORMER FAULT
850	29-Oct-18	BANGALORE	66	EDC 220 - B STATION	B STATION	6:43	7:02	0:18	MAIN SUPPLY FAILURE
851	29-Oct-18	BANGALORE	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	6:43	7:06	0:22	MAIN SUPPLY FAILURE
852	29-Oct-18	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	17:14	17:39	0:24	LINE FAULT
853	29-Oct-18	BANGALORE	66	HV1	NGEF	5:21	6:25	1:03	LINE CLEAR AVAILED
854	29-Oct-18	BANGALORE	66	RBI - ELITA PROMENEDE	RBI	8:25	8:30	0:05	LOAD CHANGEOVER
855	29-Oct-18	BANGALORE	66	SHOBHA APARTMENTS - HSR LAYOUT 220	SHOBHA APARTMENTS	14:36	14:46	0:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
856	29-Oct-18	BANGALORE	66	SHOBHA APARTMENTS - CESSNO	CESSNO, CESSNO(EHT)	14:36	15:00	0:24	LINE FAULT
857	29-Oct-18	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENTS	14:36	14:48	0:12	LINE FAULT
858	29-Oct-18	BANGALORE	220	HV2	VIKAS TECH PARK 220	12:21	12:26	0:05	LINE CLEAR AVAILED
859	29-Oct-18	BANGALORE	66	HV1	VIKAS TECH PARK 220	12:21	12:26	0:05	MAIN SUPPLY FAILURE
860	29-Oct-18	BANGALORE	66	HV2	VIKAS TECH PARK 220	12:21	12:26	0:05	MAIN SUPPLY FAILURE
861	29-Oct-18	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	12:21	12:26	0:05	MAIN SUPPLY FAILURE
862	29-Oct-18	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:21	12:26	0:05	MAIN SUPPLY FAILURE
863	29-Oct-18	BANGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK, GLOBAL TECH PARK (EHT)	12:21	12:26	0:05	MAIN SUPPLY FAILURE
864	29-Oct-18	BANGALORE	66	HV1	JIGANI 220	12:20	13:03	0:43	LINE CLEAR AVAILED
865	29-Oct-18	BANGALORE	66	HV1	JIGANI 220	14:44	14:56	0:12	LOAD CHANGEVER
866	29-Oct-18	BANGALORE	66	HV1	JIGANI 220	16:05	17:00	0:55	LOAD CHANGEVER
867	29-Oct-18	BANGALORE	66	HV2	JIGANI 220	14:44	14:56	0:12	LOAD CHANGEVER
868	29-Oct-18	BANGALORE	66	HV2	JIGANI 220	16:05	17:00	0:55	LOAD CHANGEVER
869	29-Oct-18	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	14:44	14:52	0:08	LOAD CHANGEVER
870	29-Oct-18	BANGALORE	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 66	16:07	17:00	0:52	LOAD CHANGEVER
871	29-Oct-18	GULBARGA	110	SANTAPUR-RENEWSOLAR_IPP	SANTHAPUR_110	12:30	12:55	0:25	LINE CLEAR AVAILED
872	29-Oct-18	GULBARGA	110	HALBURGA-KOLHAR2	KOLHAR_110,JANAWADA_110,NSSK_SUGAR_FACTORY	10:54	11:20	0:26	LINE FAULT
873	29-Oct-18	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,DONGRAG OA_110,KAMALANAGAR_110	10:50	11:07	0:17	LINE FAULT
874	29-Oct-18	GULBARGA	110	HV2	BETAGERA_110	13:26	13:33	0:07	TRANSFORMER FAULT
875	29-Oct-18	GULBARGA	110	HV2	HATTI_110	10:15	10:21	0:06	TRANSFORMER FAULT
876	29-Oct-18	GULBARGA	110	HV2	BHALKI_110	18:08	18:24	0:16	TRANSFORMER FAULT
877	29-Oct-18	GULBARGA	110	HV1	PD_HALLI_110	16:29	18:00	1:31	LINE CLEAR AVAILED
878	29-Oct-18	GULBARGA	66	LV1, LV2	ITTAGI_220	10:50	10:58	0:08	TRANSFORMER FAULT
879	29-Oct-18	GULBARGA	66	ITTAGI-RENEWSOLAR2	ITTAGI_220	9:43	9:52	0:09	LINE FAULT
880	29-Oct-18	GULBARGA	66	ITTAGI-RENEWSOLAR2	ITTAGI_220	10:20	12:18	1:58	LINE FAULT
881	29-Oct-18	GULBARGA	66	MUNIRABAD220-MSDLIN	HANASI_66	8:05	16:35	8:30	LINE CLEAR AVAILED
882	29-Oct-18	GULBARGA	66	HV1, HV2	UPANAYAKANAHALLI_66	9:07	10:11	1:04	LINE CLEAR AVAILED
883	29-Oct-18	HASSAN	220	KEMAR_220	KEMAR-Kavoor1	6:33	18:38	12:05	LINE CLEAR AVAILED
884	29-Oct-18	HASSAN	220	KEMAR_220	KEMAR-Kavoor2	6:33	18:38	12:05	LINE CLEAR AVAILED
885	29-Oct-18	HASSAN	220	MSEZ_220	MSEZ-KEMAR1	6:32	18:38	12:06	NBFC ISSUED
886	29-Oct-18	HASSAN	220	MSEZ_220	MSEZ-KEMAR2	6:32	18:38	12:06	NBFC ISSUED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
887	29-Oct-18	HASSAN	220	SHARAVATY_GEN	SHRAVATY-SIRISI 1	0:00	13:31	13:31	LINE FAULT
888	29-Oct-18	HASSAN	110	DMKURK_110	DMKURK-HONNAVALI	10:15	10:20	0:05	MAIN SUPPLY FAILURE
889	29-Oct-18	HASSAN	110	ESSUR_110	HV1	7:27	18:09	10:42	LINE CLEAR AVAILED
890	29-Oct-18	HASSAN	110	ESSUR_110	HV1	18:24	18:40	0:16	LINE CLEAR AVAILED
891	29-Oct-18	HASSAN	110	KADUR_220	HV2	1:09	2:21	1:12	LINE FAULT
892	29-Oct-18	HASSAN	110	KADUR_220	HV2	8:13	11:40	3:27	LINE CLEAR AVAILED
893	29-Oct-18	HASSAN	110	KITTADAHALLY_110	HV1	12:18	13:38	1:20	LINE CLEAR AVAILED
894	29-Oct-18	HASSAN	110	SAGARA_110	SAGARA-SORABA	15:57	16:06	0:09	HAND TRIPPED
895	29-Oct-18	HASSAN	110	SHIRALKOPPA_220	SHRLKP-SORAB	15:47	15:54	0:07	HAND TRIPPED
896	29-Oct-18	HASSAN	66	ARAKALGUD_66	HV2	13:14	16:53	3:39	LINE CLEAR AVAILED
897	29-Oct-18	HASSAN	66	ARAKALGUD_66	ARAKAL-MALLIPATNA	13:14	17:19	4:05	LINE FAULT
898	29-Oct-18	HASSAN	66	BYACHANAHALLY_66	BYACHAN-HNPURA	6:37	6:38	0:01	LINE CLEAR AVAILED
899	29-Oct-18	HASSAN	66	BYACHANAHALLY_66	HV1	2:09	8:38	6:29	LINE FAULT
900	29-Oct-18	HASSAN	66	RAMNATPURA_66	RAMNAT-KUSALNAGARA	0:00	18:13	18:13	HAND TRIPPED
901	29-Oct-18	MYSORE	66	HV2	AKKIHEBBAL_66	17:04	17:43	0:38	LINE CLEAR AVAILED
902	29-Oct-18	MYSORE	66	HV1	BYLUKUPPE_66	10:08	11:10	1:01	LINE CLEAR AVAILED
903	29-Oct-18	MYSORE	66	DEVANUR(MYS)-VAJAMANGALA	DEVANOORMYS_66 RAJEEVNAGARA_66 FTS_66	0:03	0:27	0:23	LINE FAULT
904	29-Oct-18	MYSORE	66	DEVANUR(MYS)-VAJAMANGALA	DEVANOORMYS_66 RAJEEVNAGARA_66	0:27	8:34	8:06	LINE FAULT
905	29-Oct-18	MYSORE	66	HV1	HONNALLY_MYS_66	12:30	14:08	1:37	LINE CLEAR AVAILED
906	29-Oct-18	MYSORE	66	HV2	HONNALLY_MYS_66	13:23	14:35	1:12	LINE CLEAR AVAILED
907	29-Oct-18	MYSORE	220	HV1	KRPET_220	14:03	14:52	0:48	LINE CLEAR AVAILED
908	29-Oct-18	MYSORE	66	HV1	RAVANDUR_66	13:37	13:54	0:17	TRANSFORMER FAULT
909	29-Oct-18	MYSORE	66	HV1	THALAKADU_66	5:50	5:54	0:04	HAND TRIPPED
910	29-Oct-18	MYSORE	66	HV2	THALAKADU_66	5:50	5:54	0:04	HAND TRIPPED
911	29-Oct-18	MYSORE	66	HV1	THALAKADU_66	9:47	9:51	0:03	HAND TRIPPED
912	29-Oct-18	MYSORE	66	HV2	THALAKADU_66	9:47	9:51	0:03	HAND TRIPPED
913	29-Oct-18	MYSORE	66	HV1	THALAKADU_66	21:10	21:16	0:06	HAND TRIPPED
914	29-Oct-18	MYSORE	66	HV2	THALAKADU_66	21:10	21:16	0:06	HAND TRIPPED
915	29-Oct-18	MYSORE	66	HV1	THALAKADU_66	23:25	23:29	0:04	HAND TRIPPED
916	29-Oct-18	MYSORE	66	HV2	THALAKADU_66	23:25	23:29	0:04	HAND TRIPPED
917	29-Oct-18	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	16:53	17:05	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASONS
918	29-Oct-18	TUMKUR	110	HONNAVALI 110- KADUR	HONNAVALI_110, DMKURKE_110	10:10	10:15	0:05	HAND TRIPPED
919	29-Oct-18	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	10:03	10:31	0:28	LINE CLEAR AVAILED
920	29-Oct-18	TUMKUR	110	TR-2	KBCROSS_220	10:03	10:20	0:16	LINE CLEAR AVAILED
921	29-Oct-18	TUMKUR	110	TR-1	SAMPIGE_110	5:26	5:32	0:06	TRANSFORMER FAULT
922	29-Oct-18	TUMKUR	110	TR-1	SAMPIGE_110	9:04	9:31	0:26	LINE CLEAR AVAILED
923	29-Oct-18	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	5:58	6:14	0:16	LINE FAULT
924	29-Oct-18	TUMKUR	66	TR-2	CHANNAGIRI_66	16:11	16:17	0:06	TRANSFORMER FAULT
925	29-Oct-18	TUMKUR	66	TR-2	CHELURU_66	12:56	16:15	3:19	LINE CLEAR AVAILED
926	29-Oct-18	TUMKUR	66	CHIKKABANAGERE- GLOBAL IPP	GLOBALTECHPARK_IPP_66	9:09	9:20	0:11	HAND TRIPPED
927	29-Oct-18	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	6:44	9:10	2:25	LINE CLEAR AVAILED
928	29-Oct-18	TUMKUR	66	DYAVARANAHALI-RANGENAHALI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:24	17:36	9:12	HAND TRIPPED
929	29-Oct-18	TUMKUR	66	TR-2	GUTTUR_66	11:02	13:00	1:57	LINE CLEAR AVAILED
930	29-Oct-18	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	23:01	23:14	0:12	LINE FAULT
931	29-Oct-18	TUMKUR	66	TR-2	MANGALWADA_66	10:06	10:11	0:04	TRANSFORMER FAULT
932	29-Oct-18	TUMKUR	66	TR-1	NAGALMADIKE_66	9:53	13:15	3:22	HAND TRIPPED
933	29-Oct-18	TUMKUR	66	TELAGI- VESTAS IPP	VESTAS_IPP_66	8:50	8:56	0:05	LINE CLEAR AVAILED
934	29-Oct-18	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	11:21	11:53	0:32	HAND TRIPPED
935	29-Oct-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:06	14:43	2:36	LINE FAULT
936	29-Oct-18	TUMKUR	66	TR-1	YNHOSKOTE_66	11:45	12:41	0:56	LINE CLEAR AVAILED
937	29-Oct-18	TUMKUR	66	TR-2	YNHOSKOTE_66	12:43	13:17	0:33	LINE CLEAR AVAILED