

**400/220/110/66 kV TRANSMISSION OUTAGES FROM :19.10.2021 to 25.10.2021**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	19-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET 66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVALIED
2	19-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN LINE CLEAR AVALIED
3	19-Oct-2021	BAGALKOT	110	110/11KV,HV2	YELPHARATTI_110	13:07	13:16	0:09	TRANSFORMER FAULT
4	19-Oct-2021	BAGALKOT	110	110/11KV,HV3	TARIHAL_110	18:40 (19.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVALIED
5	19-Oct-2021	BAGALKOT	110	110/33KV, HV3	RON_110, MUSHIGERI_33	9:47	9:57	0:10	HAND TRIPPED
6	19-Oct-2021	BAGALKOT	110	110/33KV, HV3	RON_110, MUSHIGERI_33	10:37	10:45	0:08	HAND TRIPPED
7	19-Oct-2021	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
8	19-Oct-2021	BAGALKOT	110	110KV BALIGERI	ATHANI_220	4:34	4:42	0:08	LINE FAULT
9	19-Oct-2021	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI(TAUSHI)_110	4:34	4:42	0:08	LINE FAULT
10	19-Oct-2021	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	18:30	18:38	0:08	LOAD CURTAILMENT
11	19-Oct-2021	BAGALKOT	110	BALLIGAVI-HIREKERUR	HIREKERUR_110	13:05	18:35	5:30	LINE CLEAR AVALIED
12	19-Oct-2021	BAGALKOT	110	BIDNAL-KONNUR	KONNUR_110	23:35 (18.10.2021)	0:10 (19.10.2021)	0:35 hrs	LINE CHARGED
13	19-Oct-2021	BAGALKOT	110	BIDNAL-NARGUND	NARGUND_110	23:35 (18.10.2021)	0:10 (19.10.2021)	0:35 hrs	LINE CHARGED
14	19-Oct-2021	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	18:28	19:48	1:20	LOAD CURTAILMENT
15	19-Oct-2021	BAGALKOT	110	GHATAPRABHA- MANTUR	MANTUR(GHP)_110	13:36	21:07	7:31	LINE FAULT
16	19-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA 110	18:15 (24.06.2021)			LINE OPEN LINE CLEAR AVALIED
17	19-Oct-2021	BAGALKOT	110	NARENDRA220- MRUTHYUNJAY NAGAR2	MRUTHYUNJAY NAGAR_110	3:35	13:54	10:19	LINE FAULT
18	19-Oct-2021	BAGALKOT	110	NARENDRA-KUD DHARWAD	KUD DHARWAD_110	11:05	15:56	4:51	NFBC ISSUED
19	19-Oct-2021	BAGALKOT	110	NAVALGUND- KONNUR	KONNUR_110	23:35 (18.10.2021)	00:11 (19.10.2021)	0:36 hrs	LINE CHARGED
20	19-Oct-2021	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	14:59	18:03	3:04	NFBC ISSUED
21	19-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	NARENDRA_220	11:08	15:50	4:42	LINE CLEAR AVALIED
22	19-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220	10:29	12:49	2:20	LINE CLEAR AVALIED
23	19-Oct-2021	BAGALKOT	220	220/110KV, HV2&LV2	RANEENNUR_220	14:59	17:56	2:57	LINE CLEAR AVALIED
24	19-Oct-2021	BAGALKOT	220	220/110KV, HV2&LV2	KUDACHI_220	13:00	13:21	0:21	LINE CLEAR AVALIED
25	19-Oct-2021	BAGALKOT	220	ATHANI-KUDUCHI	ATHANI_220	12:31	13:40	1:09	NFBC ISSUED
26	19-Oct-2021	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	12:30	13:41	1:11	LINE CLEAR AVALIED
27	19-Oct-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)			LINE OPEN,LINE FAULT
28	19-Oct-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVALIED
29	19-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
30	19-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN LINE CLEAR AVALIED
31	19-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN LINE CLEAR AVALIED
32	19-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
33	19-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
34	19-Oct-2021	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	BG ROAD, JIGANI LINK ROAD	20:00	20:05	0:05	LOAD CHANGE OVER
35	19-Oct-2021	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD, JIGANI LINK ROAD	18:32	19:22	0:50	MAIN SUPPLY FAILURE
36	19-Oct-2021	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	18:32	19:44	1:12	MAIN SUPPLY FAILURE
37	19-Oct-2021	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	18:32	19:43	1:11	MAIN SUPPLY FAILURE
38	19-Oct-2021	BENGALURU	66	BIDADI 220 - EPIPL (EHT)	EPIPL (EHT)	18:32	19:38	1:06	MAIN SUPPLY FAILURE
39	19-Oct-2021	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	18:32	19:57	1:25	MAIN SUPPLY FAILURE
40	19-Oct-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	18:32	19:38	1:06	MAIN SUPPLY FAILURE
41	19-Oct-2021	BENGALURU	66	BYDRAHALLI - T G HALLI	TAVAREKERE, KODIGEHALI	15:47	16:04	0:17	LINE FAULT
42	19-Oct-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	16:45	16:50	0:05	LINE FAULT
43	19-Oct-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	17:40	21:10	3:30	LINE CLEAR AVAILED
44	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	17:57	19:19	1:22	MAIN SUPPLY FAILURE
45	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	17:57	19:19	1:22	MAIN SUPPLY FAILURE
46	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	17:57	19:19	1:22	MAIN SUPPLY FAILURE
47	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	17:57	19:19	1:22	MAIN SUPPLY FAILURE
48	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	17:57	19:26	1:29	MAIN SUPPLY FAILURE
49	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	17:57	19:19	1:22	MAIN SUPPLY FAILURE
50	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:57	19:19	1:22	MAIN SUPPLY FAILURE
51	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	17:57	19:19	1:22	MAIN SUPPLY FAILURE
52	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENHALLI, CHEEMANGALA	17:57	19:29	1:32	MAIN SUPPLY FAILURE
53	19-Oct-2021	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLI CROSS	17:57	19:19	1:22	MAIN SUPPLY FAILURE
54	19-Oct-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	6:04	6:56	0:51	MAIN SUPPLY FAILURE
55	19-Oct-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	6:04	6:56	0:51	MAIN SUPPLY FAILURE
56	19-Oct-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	18:15	18:56	0:40	LOAD CURTAILMENT
57	19-Oct-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	18:15	18:56	0:40	LOAD CURTAILMENT
58	19-Oct-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	6:04	6:56	0:52	MAIN SUPPLY FAILURE
59	19-Oct-2021	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	18:32	18:44	0:12	MAIN SUPPLY FAILURE
60	19-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA	18:25	19:35	1:10	LINE CLEAR AVAILED
61	19-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	18:25	19:35	1:10	LINE CLEAR AVAILED
62	19-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	17:35	19:47	2:12	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
63	19-Oct-2021	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR, YADUMADU	18:32	19:30	0:58	MAIN SUPPLY FAILURE
64	19-Oct-2021	BENGALURU	66	HV1	BIDADI 220	18:32	19:39	1:07	MAIN SUPPLY FAILURE
65	19-Oct-2021	BENGALURU	66	HV1	BANASAWADI	13:20	13:27	0:07	LOAD CHANGE OVER
66	19-Oct-2021	BENGALURU	66	HV1	BANASAWADI	13:54	13:58	0:04	LOAD CHANGE OVER
67	19-Oct-2021	BENGALURU	66	HV1	MEI LAYOUT	12:27	12:30	0:03	LINE CLEAR AVOID
68	19-Oct-2021	BENGALURU	66	HV1	MEI LAYOUT	19:54	20:32	0:38	TRANSFORMER FAULT
69	19-Oct-2021	BENGALURU	66	HV1	HONNIGANAHALLI	12:25	12:30	0:05	TRANSFORMER FAULT
70	19-Oct-2021	BENGALURU	66	HV1	GOWRIBIDANUR 220	19:20	19:30	0:10	LINE CLEAR AVOID
71	19-Oct-2021	BENGALURU	66	HV2	BIDADI 220	18:32	19:39	1:07	MAIN SUPPLY FAILURE
72	19-Oct-2021	BENGALURU	66	HV2	MEI LAYOUT	14:30	14:32	0:02	LINE CLEAR AVOID
73	19-Oct-2021	BENGALURU	66	HV2	JAYANAGAR	15:41	16:58	1:17	TRANSFORMER FAULT
74	19-Oct-2021	BENGALURU	66	HV2	GOWRIBIDANUR 220	19:20	19:30	0:10	LINE CLEAR AVOID
75	19-Oct-2021	BENGALURU	66	HV3	BANASAWADI	13:20	13:27	0:07	LOAD CHANGE OVER
76	19-Oct-2021	BENGALURU	66	HV3	BANASAWADI	13:54	13:58	0:04	LOAD CHANGE OVER
77	19-Oct-2021	BENGALURU	66	IISc - HEBBALA 220	IISc	13:21	13:33	0:12	MAIN SUPPLY FAILURE
78	19-Oct-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	18:00	18:05	0:05	LOAD CURTAILMENT
79	19-Oct-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	18:03	18:30	0:27	LOAD CURTAILMENT
80	19-Oct-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	19:15	20:05	0:50	LOAD CURTAILMENT
81	19-Oct-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	6:16	6:33	0:17	LINE FAULT
82	19-Oct-2021	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	18:15	19:45	1:30	LOAD CURTAILMENT
83	19-Oct-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:30	19:15	0:45	LOAD CURTAILMENT
84	19-Oct-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	20:05	20:30	0:25	LOAD CURTAILMENT
85	19-Oct-2021	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	19:55	19:57	0:02	LOAD CHANGE OVER
86	19-Oct-2021	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	18:33	19:20	0:47	MAIN SUPPLY FAILURE
87	19-Oct-2021	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	13:52	13:55	0:03	LOAD CHANGE OVER
88	19-Oct-2021	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	13:20	13:27	0:07	MAIN SUPPLY FAILURE
89	19-Oct-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:20	19:14	0:54	LOAD CURTAILMENT
90	19-Oct-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	19:14	20:04	0:50	LOAD CURTAILMENT
91	19-Oct-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	19:14	20:04	0:50	LOAD CURTAILMENT
92	19-Oct-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVGONDHI, LAKKUR	18:18	19:14	0:56	LOAD CURTAILMENT
93	19-Oct-2021	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	15:41	16:58	1:17	LINE FAULT
94	19-Oct-2021	BENGALURU	66	PADMANABHANAGARA - JAYANAGARA	PADMANABHANAGARA	15:41	15:54	0:13	MAIN SUPPLY FAILURE
95	19-Oct-2021	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	17:32	17:35	0:03	LOAD CHANGE OVER
96	19-Oct-2021	BENGALURU	66	RBI - KHODAYS 220	RBI	20:16	20:21	0:05	LOAD CHANGE OVER
97	19-Oct-2021	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	18:33	18:55	0:22	LOAD CHANGE OVER
98	19-Oct-2021	BENGALURU	66	SARAKKI - SUBRAMANYPURA 220	SARAKKI	19:01	19:10	0:09	LOAD CHANGE OVER
99	19-Oct-2021	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY, BTM 4TH PHASE	18:32	19:00	0:28	MAIN SUPPLY FAILURE
100	19-Oct-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	ISKON, SUBRAMANYAPURA 66	18:32	18:53	0:21	MAIN SUPPLY FAILURE
101	19-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	5:27	5:41	0:14	LINE FAULT
102	19-Oct-2021	BENGALURU	220	BIDADI 220 - BIDADI PGCIL 1 & 2 400	BIDADI 220	18:32	19:21	0:49	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
103	19-Oct-2021	BENGALURU	220	CHINTAMANI 220 - PGCIL 1	CHINTAMANI 220	17:57	19:18	1:21	MAIN SUPPLY FAILURE
104	19-Oct-2021	BENGALURU	220	CHINTAMANI 220 - PGCIL 2	CHINTAMANI 220	17:57	19:18	1:21	MAIN SUPPLY FAILURE
105	19-Oct-2021	BENGALURU	220	DB PURA 220 - NELAMANGALA 1	NO STATION AFFECTED	6:04	9:46	3:41	LINE FAULT
106	19-Oct-2021	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	13:21	13:40	0:19	LINE CLEAR AVOIDED
107	19-Oct-2021	BENGALURU	220	HV1	BIDADI 220	18:32	19:28	0:56	MAIN SUPPLY FAILURE
108	19-Oct-2021	BENGALURU	220	HV1	HEBBALA 220	13:21	13:45	0:24	TRANSFORMER FAULT
109	19-Oct-2021	BENGALURU	220	HV1	SOMANAHALLI 220	18:32	19:45	1:13	LINE CLEAR AVOIDED
110	19-Oct-2021	BENGALURU	220	HV1	CHINTAMANI 220	17:57	19:19	1:22	MAIN SUPPLY FAILURE
111	19-Oct-2021	BENGALURU	220	HV1	SARIJAPURA 220	12:56(18-10-2021)	18:05(19-10-2021)	5:08 hrs	TRANSFORMER CHARGED
112	19-Oct-2021	BENGALURU	220	HV2	BIDADI 220	18:32	19:37	1:05	MAIN SUPPLY FAILURE
113	19-Oct-2021	BENGALURU	220	HV2	HEBBALA 220	13:20	18:15	4:55	TRANSFORMER FAULT
114	19-Oct-2021	BENGALURU	220	HV2	SOMANAHALLI 220	18:32	19:45	1:13	LINE CLEAR AVOIDED
115	19-Oct-2021	BENGALURU	220	HV2	DB PURA 220	6:04	6:36	0:31	TRANSFORMER FAULT
116	19-Oct-2021	BENGALURU	220	HV2	CHINTAMANI 220	17:57	19:19	1:22	MAIN SUPPLY FAILURE
117	19-Oct-2021	BENGALURU	220	HV3	SOMANAHALLI 220	18:32	19:45	1:13	LINE CLEAR AVOIDED
118	19-Oct-2021	BENGALURU	220	LV2	DB PURA 220	6:04	6:56	0:51	TRANSFORMER FAULT
119	19-Oct-2021	BENGALURU	220	SOMANAHALLI 220 - BIDADI 220	SOMANAHALLI 220	18:32	19:35	1:03	MAIN SUPPLY FAILURE
120	19-Oct-2021	GULBARGA	66	TELAGI-KARABARAHALLI	KARABARAHALLI_66	20:45	21:15	0:30	LINE CLEAR AVOIDED
121	19-Oct-2021	GULBARGA	66	UCHCHANGIDURGA-BILACHOD	BILCHOD_66	22:00(19.10.20.21)			LINE OPEN LINE CLEAR AVOIDED
122	19-Oct-2021	GULBARGA	110	ADAVI AMARESHWARA-SINDHANOOR	ADAVI AMARESHWAR_110	20:06	20:17	0:11	MAIN SUPPLY FAILURE
123	19-Oct-2021	GULBARGA	110	ADAVI AMARESHWARA-SINDHANOOR	ADAVI AMARESHWAR_110	20:39	20:49	0:10	MAIN SUPPLY FAILURE
124	19-Oct-2021	GULBARGA	110	CHIDRI-HALBARGA	CHUDRI_110	10:20	10:25	0:05	MAIN SUPPLY FAILURE
125	19-Oct-2021	GULBARGA	110	HALBARGA-CHIDRI	KAMTHANA_110,HABSIKOTE_110	10:20	10:25	0:05	LINE FAULT
126	19-Oct-2021	GULBARGA	110	HV1	SHAHABAD_220	10:39	11:58	1:19	LINE CLEAR AVOIDED
127	19-Oct-2021	GULBARGA	110	HV3	VALKAMDINNI_110	18:50	18:55	0:05	TRANSFORMER FAULT
128	19-Oct-2021	GULBARGA	110	HV3	HATTI_110	11:57	11:58	0:01	TRANSFORMER FAULT
129	19-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	21:45	21:50	0:05	LINE FAULT
130	19-Oct-2021	GULBARGA	110	JAWALGERA-SINDHANOOR	JAWALGERA_110	20:05	20:15	0:10	MAIN SUPPLY FAILURE
131	19-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	6:04	6:14	0:10	LINE FAULT
132	19-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	20:40	20:50	0:10	LINE FAULT
133	19-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110	20:01	20:11	0:10	LINE FAULT
134	19-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110	20:36	20:46	0:10	LINE FAULT
135	19-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:28	22:35	0:07	LINE FAULT
136	19-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	21:20(18.10.2021)	06:55(19.10.2021)	09:35HRS	LINE CHARGED
137	19-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	3:55	4:12	0:17	LINE FAULT
138	19-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN LINE CLEAR AVOIDED
139	19-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN LINE CLEAR AVOIDED
140	19-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAID HAPUR_110,SANATHI_IPP,CORE GREEN SUGAR_IPP	3:50	3:58	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
141	19-Oct-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADIGERA_110,SDAID HAPUR_110,SANATHI_IPP,CORE GREEN SUGAR IPP	21:18	21:26	0:08	LINE FAULT
142	19-Oct-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN LINE CLEAR AVAILED
143	19-Oct-2021	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	ADAVIAMARESHWARA_110	20:07	20:17	0:10	LINE FAULT
144	19-Oct-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110	18:55	19:20	0:25	LINE FAULT
145	19-Oct-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRI GERA CROSS_110,NSL SUGAR IPP,VOORA IPP	6:15	6:25	0:10	LINE FAULT
146	19-Oct-2021	GULBARGA	110	SINDHANOOR-SUZLONE_IPP	SINDHANOOR_220	19:00	19:10	0:10	LINE FAULT
147	19-Oct-2021	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	10:22	10:30	0:08	MAIN SUPPLY FAILURE
148	19-Oct-2021	GULBARGA	110	YERADONA-BENNUR	BENNUR_110	11:20	11:35	0:15	LINE FAULT
149	19-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
150	19-Oct-2021	GULBARGA	220	NEELAGUNDA-GUTTUR	NEELAGUNDA_220	5:03	14:19	9:16	LINE FAULT
151	19-Oct-2021	GULBARGA	220	SHAHAPUR-RTPS2	RTPS_220	13:30	19:27	5:57	LINE FAULT
152	19-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	01:01(18.10.2021)			LINE OPEN LINE CLEAR AVAILED
153	19-Oct-2021	HASSAN	66	HV1	RAMPURA_66	9:59	13:39	3:40	LINE CLEAR AVAILED
154	19-Oct-2021	HASSAN	66	HV1	RAMPURA_66	14:28	16:11	1:43	LINE CLEAR AVAILED
155	19-Oct-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	18:52	19:51	0:59	LINE CLEAR AVAILED
156	19-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
157	19-Oct-2021	HASSAN	110	HV2	HOSNGADI_110	16:33	17:40	1:07	TRANSFORMER FAULT
158	19-Oct-2021	HASSAN	110	HV2	KONAJE_110	9:43	10:03	0:20	MAIN SUPPLY FAILURE
159	19-Oct-2021	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	9:41	12:16	2:35	LINE FAULT
160	19-Oct-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:43	10:07	0:24	MAIN SUPPLY FAILURE
161	19-Oct-2021	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	9:31(18.10.2021)			LINE OPEN,LINE FAULT
162	19-Oct-2021	MYSURU	66	BESAGRALLI-KOPPA	BESAGARAHALLI_66	21:45(19.10.21)			LINE OPEN LINE CLEAR AVAILED
163	19-Oct-2021	MYSURU	66	BESAGRALLI-KOPPA	BESAGARAHALLI_66	21:45	9:55:57 (20/10/2021)	12:10HRS	LINE CHARGED
164	19-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN LINE CLEAR AVAILED
165	19-Oct-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	9:54	10:13	0:19	LINE FAULT
166	19-Oct-2021	MYSURU	66	ELIVALA-HOOTAGALLY	NO STATIONS EFFECTED	14:21	14:36	0:14	LINE FAULT
167	19-Oct-2021	MYSURU	66	HOOTAGALLI-KAGGERE(HAMPAPURA)	HAMPAPURA(KG)_66	15:10	18:31	3:21	LINE FAULT
168	19-Oct-2021	MYSURU	66	HV1	METAGALLY_66	7:53	7:58	0:04	TRANSFORMER FAULT
169	19-Oct-2021	MYSURU	66	HV2	METAGALLY_66	7:53	7:58	0:04	TRANSFORMER FAULT
170	19-Oct-2021	MYSURU	66	HV3	PONNAMPET_66	12:10	12:41	0:30	LINE CLEAR AVAILED
171	19-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACHALLI	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI 66 SANTHEBACHALLI 66	6:59	7:03	0:03	LINE FAULT
172	19-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN LINE CLEAR AVAILED
173	19-Oct-2021	MYSURU	66	PERIYAPATNA-KAMPLAPURA	KAMPLAPURA_66	16:15	16:21	0:06	LINE FAULT
174	19-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42(5.10.21)			LINE OPEN LINE CLEAR AVAILED
175	19-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	21:37:24 (13.10.2021)	12:12:00 (19/10/2021)	134:34:36	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
176	19-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
177	19-Oct-2021	TUMKUR	66	PAVAGADA 220KV- NAGALAMADIKE	NAGALAMADIKE_66	6:01	6:30	0:28	LINE FAULT
178	19-Oct-2021	TUMKUR	66	TR-1	SANTHEMAVATHURU_66	16:53	17:03	0:10	TRANSFORMER FAULT
179	19-Oct-2021	TUMKUR	66	TR-2	ANTHARASANAHALI_220	10:23	11:52	1:28	LINE CLEAR AVAILED
180	19-Oct-2021	TUMKUR	66	TR-2	ANTHARASANAHALI_220	12:45	13:00	0:14	TRANSFORMER FAULT
181	19-Oct-2021	TUMKUR	66	TR-2	BADIHALI_66	18:40	18:49	0:09	HAND TRIPPED
182	19-Oct-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	16:24	16:41	0:17	TRANSFORMER FAULT
183	19-Oct-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	17:10	17:14	0:04	TRANSFORMER FAULT
184	20-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
185	20-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN LINE CLEAR AVAILED
186	20-Oct-2021	BAGALKOT	110	110/11KV,HV1	ZALKI_110	15:23	16:32	1:09	TRANSFORMER FAULT
187	20-Oct-2021	BAGALKOT	110	110/11KV,HV2	ZALKI_110	15:23	16:29	1:06	TRANSFORMER FAULT
188	20-Oct-2021	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	16:05	16:10	0:05	TRANSFORMER FAULT
189	20-Oct-2021	BAGALKOT	110	110/11KV,HV2	SHIRABUR_110	11:53	12:10	0:17	TRANSFORMER FAULT
190	20-Oct-2021	BAGALKOT	110	110/11KV,HV2	MANTUR_110	6:05	6:10	0:05	TRANSFORMER FAULT
191	20-Oct-2021	BAGALKOT	110	110/11KV,HV2	SHIROL_110	15:20	16:15	0:55	TRANSFORMER FAULT
192	20-Oct-2021	BAGALKOT	110	110/11KV,HV3	TARIHAL_110	18:40 (19.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
193	20-Oct-2021	BAGALKOT	110	110/11KV,HV3	TARIHAL_110	18:40 (19.10.2021)	13:20(20.10.21)	18:20 hrs	TRANSFORMER CHARGED
194	20-Oct-2021	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
195	20-Oct-2021	BAGALKOT	110	110/33KV,HV3	KIADB BIJAPUR_110 & HONNUTAGI&NAGATHAN_33	14:54	14:59	0:05	TRANSFORMER FAULT
196	20-Oct-2021	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI_33	15:23	16:28	1:05	TRANSFORMER FAULT
197	20-Oct-2021	BAGALKOT	110	110/33KV,HV4	ZALKI_110, NEVARAGI_33,DHULKHED_33, HALASANGI_33	15:23	16:28	1:05	TRANSFORMER FAULT
198	20-Oct-2021	BAGALKOT	110	ESALE 1 & ESOLE 2-SIRSI	SIRSI_110	12:45 (20.10.2021)			LINE OPEN LINE CLEAR AVAILED
199	20-Oct-2021	BAGALKOT	110	GHATAPRABHA-SURYODAYA ONE SOLAR	GHATAPRABHA_110	8:57	9:09	0:12	LINE FAULT
200	20-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN LINE CLEAR AVAILED
201	20-Oct-2021	BAGALKOT	110	INDI-CHADCHAN	ZALKI_110	15:24	16:28	1:04	LINE FAULT
202	20-Oct-2021	BAGALKOT	110	INDI-ZALKI	ZALKI_110	15:23	16:28	1:05	LINE FAULT
203	20-Oct-2021	BAGALKOT	110	INDI-ZALKI2	INDI_220	13:25	13:30	0:05	LINE FAULT
204	20-Oct-2021	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	14:49	18:21	3:32	NFBC ISSUED
205	20-Oct-2021	BAGALKOT	110	SRS HUBLI -TARIHAL	TARIHAL_110	12:47	13:05	0:18	LINE CLEAR AVAILED
206	20-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	NARENDRA_220	12:47	17:26	4:39	LINE CLEAR AVAILED
207	20-Oct-2021	BAGALKOT	220	220/110KV, HV1&LV1	MK HUBLI_220	14:30	16:00	1:30	LINE CLEAR AVAILED
208	20-Oct-2021	BAGALKOT	220	220/110KV, HV2&LV2	MK HUBLI_220	16:05	16:47	0:42	LINE CLEAR AVAILED
209	20-Oct-2021	BAGALKOT	220	HUBLI- NAGIHARI3	HUBLI_220	11:54	12:18	0:24	LINE FAULT
210	20-Oct-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)			LINE OPEN,LINE FAULT
211	20-Oct-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
212	20-Oct-2021	BAGALKOT	220	NARENDRA- HAVERI	NARENDRA_220	9:39	15:54	6:15	LINE CLEAR AVAILED
213	20-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
214	20-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN LINE CLEAR AVAILED
215	20-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN LINE CLEAR AVAILED
216	20-Oct-2021	BAGALKOT	220	VAJRAMATTI -BAGALKOT1	VAJRAMATTI_220	11:53	12:04	0:11	LINE FAULT
217	20-Oct-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
218	20-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
219	20-Oct-2021	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALIC CROSS	16:44	16:51	0:07	LINE FAULT
220	20-Oct-2021	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	NO STATION AFFECTED	10:23	11:17	0:54	LINE FAULT
221	20-Oct-2021	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 2	JAKKASANDRA	10:23	11:19	0:56	LINE FAULT
222	20-Oct-2021	BENGALURU	66	HV1	MEI LAYOUT	11:41	11:44	0:03	LINE CLEAR AVAILED
223	20-Oct-2021	BENGALURU	66	HV1	YARANDANAHALLI 220	19:38	20:03	0:25	LINE CLEAR AVAILED
224	20-Oct-2021	BENGALURU	66	HV1	JIGANI 220	19:38	20:12	0:34	MAIN SUPPLY FAILURE
225	20-Oct-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	19:38	20:03	0:25	LINE CLEAR AVAILED
226	20-Oct-2021	BENGALURU	66	HV2	THIMMAMPALLI	19:02	19:07	0:04	TRANSFORMER FAULT
227	20-Oct-2021	BENGALURU	66	HV2	JIGANI 220	19:38	20:12	0:34	MAIN SUPPLY FAILURE
228	20-Oct-2021	BENGALURU	66	HV2	SARJAPURA 220	10:33	10:39	0:06	LINE CLEAR AVAILED
229	20-Oct-2021	BENGALURU	66	HV3	YARANDANAHALLI 220	19:38	20:03	0:25	LINE CLEAR AVAILED
230	20-Oct-2021	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	19:38	20:12	0:34	MAIN SUPPLY FAILURE
231	20-Oct-2021	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	19:38	20:12	0:34	MAIN SUPPLY FAILURE
232	20-Oct-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	12:44	12:53	0:09	LINE FAULT
233	20-Oct-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	14:33	14:43	0:10	LINE FAULT
234	20-Oct-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	14:43	16:40	1:57	LINE FAULT
235	20-Oct-2021	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	7:55	8:05	0:10	LOAD CHANGE OVER
236	20-Oct-2021	BENGALURU	66	SARJAPURA - CHANDAPURA	CHANDAPURA	10:33	10:40	0:07	LINE CLEAR AVAILED
237	20-Oct-2021	BENGALURU	66	SARJAPURA - DOMMASANDRA	DOMMASANDRA	10:33	10:40	0:07	LINE CLEAR AVAILED
238	20-Oct-2021	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY, BTM 4TH PHASE	5:50	5:55	0:05	LOAD CHANGE OVER
239	20-Oct-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	ISKON, SUBRAMANYAPURA 66	11:15	11:30	0:15	LOAD CHANGE OVER
240	20-Oct-2021	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	21:22	21:25	0:02	LINE FAULT
241	20-Oct-2021	BENGALURU	66	VIDYANAGAR - HOSKOTE 66	NO STATION AFFECTED	14:24	16:07	1:42	LINE FAULT
242	20-Oct-2021	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	19:38	20:03	0:25	LINE CLEAR AVAILED
243	20-Oct-2021	BENGALURU	220	HV1	JIGANI 220	19:38	20:12	0:34	MAIN SUPPLY FAILURE
244	20-Oct-2021	BENGALURU	220	HV2	JIGANI 220	19:38	20:12	0:34	MAIN SUPPLY FAILURE
245	20-Oct-2021	BENGALURU	220	HV3	YARANDANAHALLI 220	19:38	20:03	0:25	LINE CLEAR AVAILED
246	20-Oct-2021	BENGALURU	220	MYLSANDRA 400 - YARANDANAHALLI 220	YARANDANAHALLI 220 , JIGANI 220	19:38	20:03	0:25	LINE FAULT
247	20-Oct-2021	BENGALURU	220	YARANDANAHALLI 220 - MYLSANDRA 220	YARANDANAHALLI 220 , JIGANI 220	19:38	20:03	0:25	MAIN SUPPLY FAILURE
248	20-Oct-2021	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	11:10	11:20	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
249	20-Oct-2021	GULBARGA	66	UCHCHANGIDURGA-BILACHOD	BILCHOD_66	22:00(19.10.20.21)	11:00(20.10.2021)	13:00 HRS	LINE CHARGED
250	20-Oct-2021	GULBARGA	66	UCHCHANGIDURGA-PUNABGHATA	UCHCHANGIDURGA_66	7:55	11:00	3:05	LINE CLEAR AVAILED
251	20-Oct-2021	GULBARGA	110	ALIPUR-BELLARY NORTH1	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,B ASAI STEELA	18:45	19:02	0:17	LINE FAULT
252	20-Oct-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110, DIGGI_110	1:25	1:30	0:05	MAIN SUPPLY FAILURE
253	20-Oct-2021	GULBARGA	110	HATTI-SOMANMARADI_IPP	HATTI_110	15:15	15:24	0:09	LINE FAULT
254	20-Oct-2021	GULBARGA	110	HUMANABAD-MANEKAHALLI	MANEKAHALLI_110	5:24	5:38	0:14	LINE FAULT
255	20-Oct-2021	GULBARGA	110	HUMNABAD-BHALKI	HUMNABAD-BHALKI	20:34	23:09	2:35	LINE FAULT
256	20-Oct-2021	GULBARGA	110	HV1	GANDHINAGAR_110	9:42	9:52	0:10	LINE CLEAR AVAILED
257	20-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	20:40	20:45	0:05	LINE FAULT
258	20-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	22:35	22:45	0:10	LINE FAULT
259	20-Oct-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	18:18	18:24	0:06	LINE FAULT
260	20-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	6:01	6:11	0:10	LINE FAULT
261	20-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	1:09	1:19	0:10	LINE FAULT
262	20-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	2:24	2:34	0:10	LINE FAULT
263	20-Oct-2021	GULBARGA	110	MATAMARI-RAICHUR	MATAMARI_110	19:00	20:00	1:00	MAIN SUPPLY FAILURE
264	20-Oct-2021	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110,YERAG ERA_110,YAPALDINNI_110	18:05	18:11	0:06	MAIN SUPPLY FAILURE
265	20-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	23:20	23:25	0:05	LINE FAULT
266	20-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	2:04	2:10	0:06	LINE FAULT
267	20-Oct-2021	GULBARGA	110	SEDAM-VASAVADATTA_IPP	SEDAM_220	9:40	14:05	4:25	LINE CLEAR AVAILED
268	20-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN LINE CLEAR AVAILED
269	20-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN LINE CLEAR AVAILED
270	20-Oct-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN LINE CLEAR AVAILED
271	20-Oct-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	5:58	6:06	0:08	LINE FAULT
272	20-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
273	20-Oct-2021	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	6:00	6:10	0:10	LINE FAULT
274	20-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	01:01(18.10.2021)	07:02(20.10.2021)	54:01HRS	LINE CHARGED
275	20-Oct-2021	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	7:38	15:29	7:51	LINE CLEAR AVAILED
276	20-Oct-2021	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	12:55	15:29	2:34	LINE CLEAR AVAILED
277	20-Oct-2021	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	12:55	15:52	2:57	LINE CLEAR AVAILED
278	20-Oct-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	12:57	15:33	2:36	LINE CLEAR AVAILED
279	20-Oct-2021	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	12:55	15:33	2:38	LINE CLEAR AVAILED
280	20-Oct-2021	HASSAN	66	HV1	HALEBEEDU_66	12:55	13:12	0:17	TRANSFORMER FAULT
281	20-Oct-2021	HASSAN	66	HV1	SIGEBAGE_66	8:47	9:09	0:22	LINE CLEAR AVAILED
282	20-Oct-2021	HASSAN	66	HV1	CHANNARAYAPATNA_66	12:55	15:29	2:34	LINE CLEAR AVAILED
283	20-Oct-2021	HASSAN	66	HV2	ARAKALGUD_66	22:49	23:00	0:11	TRANSFORMER FAULT
284	20-Oct-2021	HASSAN	66	HV2	CHANNARAYAPATNA_66	12:55	15:29	2:34	LINE CLEAR AVAILED
285	20-Oct-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	18:27	18:41	0:14	LINE FAULT
286	20-Oct-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	18:30	18:42	0:12	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
287	20-Oct-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	12:40	12:52	0:12	LINE FAULT
288	20-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
289	20-Oct-2021	HASSAN	110	HV2	HOSNGADI_110	16:04	17:09	1:05	TRANSFORMER FAULT
290	20-Oct-2021	HASSAN	110	HV2	HOSNGADI_110	18:04	19:24	1:20	LINE CLEAR AVAILED
291	20-Oct-2021	HASSAN	110	HV4	BAIKAMPADY_110	13:00	16:00	3:00	LINE CLEAR AVAILED
292	20-Oct-2021	HASSAN	110	HV6	KAVOOR_220	16:38	16:43	0:05	TRANSFORMER FAULT
293	20-Oct-2021	HASSAN	110	JOG-JLT4	mghejog_gen	10:33	12:50	2:17	LINE CLEAR AVAILED
294	20-Oct-2021	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	9:36	10:01	0:25	LINE CLEAR AVAILED
295	20-Oct-2021	HASSAN	110	LPH-MGHE 2	lph_gen	10:33	12:50	2:17	NFBC ISSUED
296	20-Oct-2021	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	10:10	11:35	1:25	NFBC ISSUED
297	20-Oct-2021	HASSAN	220	KEMAR-UPCL1	KEMAR_220	9:46	11:49	2:03	LINE CLEAR AVAILED
298	20-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:10	14:24	2:14	LINE FAULT
299	20-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:05	12:34	0:29	LINE FAULT
300	20-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	13:58	14:25	0:27	LINE FAULT
301	20-Oct-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	12:40	17:02	4:22	LINE FAULT
302	20-Oct-2021	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	12:10	14:24	2:14	LINE FAULT
303	20-Oct-2021	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	12:05	12:34	0:29	LINE FAULT
304	20-Oct-2021	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	13:58	14:25	0:27	LINE FAULT
305	20-Oct-2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	9:46	11:49	2:03	NFBC ISSUED
306	20-Oct-2021	HASSAN	220	VARAH1-KEMAR2	varahi_gen	11:51	12:19	0:28	LINE FAULT
307	20-Oct-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	12:40	17:02	4:22	LINE FAULT
308	20-Oct-2021	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	9:31(18.10.2021)			LINE OPEN,LINE FAULT
309	20-Oct-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	10:09	15:16	5:07	NFBC ISSUED
310	20-Oct-2021	MYSURU	66	BESAGRALLI-KOPPA	BESAGARAHALLI_66	21:45	9:55:57 (20/10/2021)	12:10HRS	LINE CHARGED
311	20-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN LINE CLEAR AVAILED
312	20-Oct-2021	MYSURU	66	BOOKANAKERE-CHINKURALI	CHINAKURALI_66 BANANGADI_66 PANDAVAPURA_66	21:25	21:53	0:28	LINE FAULT
313	20-Oct-2021	MYSURU	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	20:52	20:57	0:04	LINE FAULT
314	20-Oct-2021	MYSURU	66	ELWALA-HUNSUR	GAVADAGERE_66	20:16	20:35	0:18	LINE FAULT
315	20-Oct-2021	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	8:29	18:31	10:02	LINE FAULT
316	20-Oct-2021	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	11:36	18:49	7:13	LINE FAULT
317	20-Oct-2021	MYSURU	66	HAMPAPURA-BASARALU	BASARALU_66 BESAGARAHALLI_66 KOPPA_66 KESLAGERE_66	21:26	21:50	0:23	LINE FAULT
318	20-Oct-2021	MYSURU	66	HOOTAGALLI-KAGGERE(HAMPAPURA)	HAMPAPURA(KG)_66	20:48	20:59	0:11	LINE FAULT
319	20-Oct-2021	MYSURU	66	JAKKANAHALLI-NAGMANGALA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66	20:51	20:57	0:05	LINE FAULT
320	20-Oct-2021	MYSURU	66	JAKKANAHALLI-NAGMANGALA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66	23:29	23:36	0:06	LINE FAULT
321	20-Oct-2021	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	18:17	18:40	0:23	LINE CLEAR AVAILED
322	20-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	21:44:47 (20/10/2021)			LINE OPEN,LINE FAULT
323	20-Oct-2021	MYSURU	66	KR PETE 220-KR PETE 1	KRPET_66 AKKIHBBAL_66 KIKKERI_66	21:53	21:58	0:04	LINE FAULT
324	20-Oct-2021	MYSURU	66	KR PETE 220-KR PETE 2	KRPET_66 AKKIHBBAL_66 KIKKERI_66	21:53	21:58	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
325	20-Oct-2021	MYSURU	66	KR PETE 220- MAHADESHWARAPURA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66 JAKKANAHALLI_66	21:11	21:15	0:04	LINE FAULT
326	20-Oct-2021	MYSURU	66	KR PETE 220- MAHADESHWARAPURA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66 JAKKANAHALLI_66	21:40	22:02	0:21	LINE FAULT
327	20-Oct-2021	MYSURU	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66 PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	22:28	22:54	0:26	LINE FAULT
328	20-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN LINE CLEAR AVAILED
329	20-Oct-2021	MYSURU	66	PONNAMPETE-HV1	PONNAMPET_66	12:06	12:25	0:19	LINE CLEAR AVAILED
330	20-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42(5.10.21)			LINE OPEN LINE CLEAR AVAILED
331	20-Oct-2021	MYSURU	66	TARIPURA-MHS	NO STATIONS EFFECTED	23:16	23:41	0:25	LINE FAULT
332	20-Oct-2021	MYSURU	66	TUBINKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	21:46	21:50	0:04	LINE FAULT
333	20-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66	23:29	23:34	0:05	LINE FAULT
334	20-Oct-2021	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	23:32:00 (20/10/2021)			LINE OPEN, LINE FAULT
335	20-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
336	20-Oct-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:32	10:46	0:13	LINE FAULT
337	20-Oct-2021	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	10:32	12:50	2:17	LINE FAULT
338	20-Oct-2021	TUMKUR	66	HINDASGHATTA66- HIRIYUR220KV	HINDASGHATTA_66	15:54	19:01	3:07	NFBC ISSUED
339	20-Oct-2021	TUMKUR	66	HULIYURDURGA- ANCHEPALYA	HULIYURDURGA_66,	21:05	21:25	0:19	MAIN SUPPLY FAILURE
340	20-Oct-2021	TUMKUR	66	PAVAGADA- MADHUGIRI(PAVAGADA 220)	PAVAGADA_220	19:53	20:43	0:50	LINE FAULT
341	20-Oct-2021	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	20:02	20:40	0:38	LINE FAULT
342	20-Oct-2021	TUMKUR	66	SANTEMNAVATTUR- ANCHEPALYA220	SANTEMNAVATTUR_66	10:28	10:33	0:05	LOAD CURTAILMENT
343	20-Oct-2021	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	4:44	5:34	0:49	LINE FAULT
344	20-Oct-2021	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	4:44	5:34	0:49	LINE FAULT
345	20-Oct-2021	TUMKUR	66	TR-1	PAVAGADA_220	19:53	20:05	0:11	TRANSFORMER FAULT
346	20-Oct-2021	TUMKUR	66	TR-1	SANTHEMNAVATHURU_66	16:37	16:57	0:20	HAND TRIPPED
347	20-Oct-2021	TUMKUR	66	TR-1	SOKKE_66	9:21	9:25	0:04	HAND TRIPPED
348	20-Oct-2021	TUMKUR	66	TR-2	ANTHARASANAHALLI_220	10:33	10:47	0:14	TRANSFORMER FAULT
349	20-Oct-2021	TUMKUR	66	TR-2	LINGADAHALLI_66	18:25	18:30	0:04	LINE CLEAR AVAILED
350	20-Oct-2021	TUMKUR	66	TR-2	SANTHEMNAVATHURU_66	12:00	12:20	0:20	HAND TRIPPED
351	20-Oct-2021	TUMKUR	220	TR-1	PAVAGADA_220	19:53	20:02	0:09	TRANSFORMER FAULT
352	20-Oct-2021	TUMKUR	220	TR-2	PAVAGADA_220	19:53	19:57	0:03	TRANSFORMER FAULT
353	21-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
354	21-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
355	21-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
356	21-Oct-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
357	21-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
358	21-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN LINE CLEAR AVAILED
359	21-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
360	21-Oct-2021	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
361	21-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN LINE CLEAR AVAILED
362	21-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN LINE CLEAR AVAILED
363	21-Oct-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	3:22 (07.10.2021)	20:01 (21.10.2021)	352:39HRS	LINE CHARGED
364	21-Oct-2021	BAGALKOT	110	110/11KV,HV3	TARIHAL_110	18:40 (19.10.2021)	13:07 (21.10.2021)	44:27HRS	TRANSFORMER CHARGED
365	21-Oct-2021	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	11:42	11:53	0:11	LINE FAULT
366	21-Oct-2021	BAGALKOT	110	110/11KV,HV2	HANAGAL_110	12:49	12:51	0:02	TRANSFORMER FAULT
367	21-Oct-2021	BAGALKOT	110	110/11KV,HV2	HANAGAL_110	14:06	14:07	0:01	TRANSFORMER FAULT
368	21-Oct-2021	BAGALKOT	110	110/33KV,HV1	HANAGAL_110 & PALA_33 & BASAPUR_33	16:54	17:58	1:04	TRANSFORMER FAULT
369	21-Oct-2021	BAGALKOT	110	110/11KV,HV3	HIREKERUR_110	22:51 (21.10.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
370	21-Oct-2021	BAGALKOT	110	110/11KV,HV4	KERUR_110	20:11	20:28	0:17	TRANSFORMER FAULT
371	21-Oct-2021	BAGALKOT	110	KONNUR-ANT SOLAR	KONNUR_110	12:27	17:29	5:02	LINE CLEAR AVAILED
372	21-Oct-2021	BAGALKOT	110	KUDACHI220-KUDACHI110	KUDACHI_110	12:30	12:49	0:19	LINE FAULT
373	21-Oct-2021	BAGALKOT	110	TAKKALAKI-WRD SOLAR	TAKKALAKI_110	11:43	11:53	0:10	HAND TRIPPED
374	21-Oct-2021	BAGALKOT	110	TAKKALAKI-KNSOLAR	TAKKALAKI_110	11:43	11:54	0:11	HAND TRIPPED
375	21-Oct-2021	BAGALKOT	110	SIRSI-KUMATA 2	SIRSI_110	23:43 (21.10.2021)			LINE OPEN,LINE FAULT
376	21-Oct-2021	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	23:54 (21.10.2021)			MAIN SUPPLY FAILURE
377	21-Oct-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	10:44	15:18	4:34	LINE CLEAR AVAILED
378	21-Oct-2021	BAGALKOT	220	VAJRAMATTI -BAGALKOT1	VAJRAMATTI_220	10:09	19:27	9:18	LINE FAULT
379	21-Oct-2021	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	15:51 (21.10.2021)			LINE OPEN,LINE FAULT
380	21-Oct-2021	BAGALKOT	220	BAGALKOT -VAJARAMATTI 1	220 KV R/S BAGAKOT	10:40	19:29	8:49	NFBC ISSUED
381	21-Oct-2021	BAGALKOT	220	CHIKKODI- MUGALKOD2	CHIKKODI_220	10:16	13:32	3:16	LINE CLEAR AVAILED
382	21-Oct-2021	BAGALKOT	220	MUGALKOD- CHIKKODI2	MUGALKOD_220	10:15	13:30	3:15	LINE CLEAR AVAILED
383	21-Oct-2021	BAGALKOT	110	SIRSI220- KAVALWADA	KAVALWAD_110	13:01	13:12	0:11	LINE FAULT
384	21-Oct-2021	BAGALKOT	110	SHIRAGUPPI-VAJRAMATTI	VAJRAMATTI_110	20:05	20:10	0:05	LINE FAULT
385	21-Oct-2021	BAGALKOT	110	SHIRAGUPPI-VAJRAMATTI	VAJRAMATTI_110	23:45	23:55	0:10	LINE FAULT
386	21-Oct-2021	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	20:05	20:15	0:10	LINE FAULT
387	21-Oct-2021	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	23:45	23:55	0:10	LINE FAULT
388	21-Oct-2021	BAGALKOT	110	SIRAGUPPI-TOLAMATTI	TOLAMATTI_110	20:05	20:15	0:10	MAIN SUPPLY FAILURE
389	21-Oct-2021	BAGALKOT	110	SIRAGUPPI-TOLAMATTI	TOLAMATTI_110	23:45	23:55	0:10	MAIN SUPPLY FAILURE
390	21-Oct-2021	BAGALKOT	110	BILAGI-BISANAL	BISANAL_110	20:05	20:15	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
391	21-Oct-2021	BAGALKOT	110	BILAGI-BISANAL	BISANAL_110	23:45	23:55	0:10	MAIN SUPPLY FAILURE
392	21-Oct-2021	BAGALKOT	110	BILAGI-GIRISAGARA	GIRISAGARA_110	20:05	20:15	0:10	MAIN SUPPLY FAILURE
393	21-Oct-2021	BAGALKOT	110	BILAGI-GIRISAGARA	GIRISAGARA_110	23:45	23:55	0:10	MAIN SUPPLY FAILURE
394	21-Oct-2021	BAGALKOT	110	INDI220- ZALKI2	ZALKI_110	10:15	13:30	3:15	LINE FAULT
395	21-Oct-2021	BAGALKOT	110	SIRSI-KUMATA 1	SIRSI_110	23:43 (21.10.2021)			LINE OPEN,LINE FAULT
396	21-Oct-2021	BAGALKOT	110	KUMATA-SIRSI 2	KUMATA_110	23:54 (21.10.2021)			MAIN SUPPLY FAILURE
397	21-Oct-2021	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	11:27	11:32	0:05	LOAD CHANGE OVER
398	21-Oct-2021	BENGALURU	66	BMTC - EAST DIVISION COMPOUND 220	BMTC	10:05	16:03	5:58	LINE CLEAR AVAILED
399	21-Oct-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	12:21	12:33	0:12	MAIN SUPPLY FAILURE
400	21-Oct-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	19:30	19:36	0:06	LOAD CHANGE OVER
401	21-Oct-2021	BENGALURU	66	IISc - NRS 220	IISc	11:34	11:39	0:05	LOAD CHANGE OVER
402	21-Oct-2021	BENGALURU	66	ISRO LAYOUT - SARAKKI 1	NO STATION AFFECTED	8:02	14:19	6:17	LINE FAULT
403	21-Oct-2021	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K & C VALLEY, NAL (EHT)	11:45	12:26	0:41	LINE FAULT
404	21-Oct-2021	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K & C VALLEY, NAL (EHT)	13:34	15:00	1:26	LINE FAULT
405	21-Oct-2021	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA, WIDIA(EHT)	13:31	14:50	1:19	LINE CLEAR AVAILED
406	21-Oct-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT)	21:58	22:06	0:08	LINE FAULT
407	21-Oct-2021	BENGALURU	66	HV1	NAGANATHPURA 220	21:58	22:06	0:08	TRANSFORMER FAULT
408	21-Oct-2021	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	12:54	13:00	0:06	LOAD CHANGE OVER
409	21-Oct-2021	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	14:28	14:34	0:06	LOAD CHANGE OVER
410	21-Oct-2021	BENGALURU	66	HV2	RAJANUKUNTE	14:58	15:05	0:07	LINE CLEAR AVAILED
411	21-Oct-2021	BENGALURU	66	HV2	R R NAGAR	13:53	14:22	0:29	LINE CLEAR AVAILED
412	21-Oct-2021	BENGALURU	220	SRS PEENYA 220 - HEBBALA 220	NO STATION AFFECTED	11:33	13:45	2:12	LINE FAULT
413	21-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:02	6:12	0:09	LINE FAULT
414	21-Oct-2021	BENGALURU	220	NELAMANGALA 400 - YELAHANKA 220	NO STATION AFFECTED	11:38	13:48	2:09	LINE FAULT
415	21-Oct-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	23:12	23:23	0:11	LINE FAULT
416	21-Oct-2021	BENGALURU	66	DEVANAHALLI - DB PURA 1	NO STATION AFFECTED	12:10	15:11	3:01	LINE CLEAR AVAILED
417	21-Oct-2021	BENGALURU	66	HV1	N G HULKUR	16:05	17:13	1:08	LINE CLEAR AVAILED
418	21-Oct-2021	BENGALURU	220	HV2	MAGADI 220	10:10	16:56	6:45	LINE CLEAR AVAILED
419	21-Oct-2021	BENGALURU	66	HV1	KAMASAMUDRA	13:15	13:39	0:24	LINE CLEAR AVAILED
420	21-Oct-2021	BENGALURU	66	HV1	DALASNUR	17:25	18:08	0:42	LINE CLEAR AVAILED
421	21-Oct-2021	BENGALURU	66	HV2	ANEKAL	6:18	6:28	0:09	TRANSFORMER FAULT
422	21-Oct-2021	BENGALURU	66	VIDYANAGAR - BEGUR 220	VIDYANAGAR	18:20	18:43	0:23	LINE CLEAR AVAILED
423	21-Oct-2021	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	12:21	12:33	0:12	LINE FAULT
424	21-Oct-2021	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, DIBBURAHALLI	23:12	23:29	0:16	LINE FAULT
425	21-Oct-2021	BENGALURU	66	SADLI - DIBBURALLI	DIBBURALLI	23:12	23:29	0:16	LINE FAULT
426	21-Oct-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	13:12	13:15	0:03	MAIN SUPPLY FAILURE
427	21-Oct-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	13:12	13:15	0:03	MAIN SUPPLY FAILURE
428	21-Oct-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:12	13:15	0:03	MAIN SUPPLY FAILURE
429	21-Oct-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:12	15:16	0:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
430	21-Oct-2021	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	15:12	15:16	0:04	LINE CLEAR AVAILED
431	21-Oct-2021	BENGALURU	220	HV1	MALUR 220	13:12	15:34	2:22	LINE CLEAR AVAILED
432	21-Oct-2021	BENGALURU	220	LV1	MALUR 220	13:12	15:36	2:24	LINE CLEAR AVAILED
433	21-Oct-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	15:34	15:37	0:03	LINE CLEAR AVAILED
434	21-Oct-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	15:34	15:37	0:03	LINE CLEAR AVAILED
435	21-Oct-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:34	15:37	0:03	LINE CLEAR AVAILED
436	21-Oct-2021	BENGALURU	220	HV1	SARIJAPURA 220	12:58	19:00	6:02	LINE CLEAR AVAILED
437	21-Oct-2021	BENGALURU	66	HV2	SARIJAPURA 220	12:56	13:00	0:04	MAIN SUPPLY FAILURE
438	21-Oct-2021	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:56	13:00	0:04	MAIN SUPPLY FAILURE
439	21-Oct-2021	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	13:00	13:43	0:43	MAIN SUPPLY FAILURE
440	21-Oct-2021	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:57	19:03	0:06	LINE CLEAR AVAILED
441	21-Oct-2021	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	18:58	19:01	0:03	LINE CLEAR AVAILED
442	21-Oct-2021	BENGALURU	66	HV2	SARIJAPURA 220	18:58	19:01	0:03	LINE CLEAR AVAILED
443	21-Oct-2021	BENGALURU	66	HV1	CHINTAMANI 66	9:36	9:52	0:16	LINE CLEAR AVAILED
444	21-Oct-2021	BENGALURU	66	HV1	CHINTAMANI 66	11:48	11:52	0:04	LINE CLEAR AVAILED
445	21-Oct-2021	BENGALURU	400	NELAMANGALA 400 - DEVANAHALLI 400	NO STATION AFFECTED	22:12(21-10-21)			LINE OPEN,LINE FAULT
446	21-Oct-2021	BENGALURU	400	HOODY 400 - DEVANAHALLI 2 400	NO STATION AFFECTED	21:57(21/10/2021)			LINE OPEN,LINE FAULT
447	21-Oct-2021	BENGALURU	400	DEVANAHALLI 400 - NELAMANGALA 400	NO STATION AFFECTED	22:12(21-10-21)			LINE OPEN,LINE FAULT
448	21-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:57 (21.10.2021)			LINE OPEN LINE CLEAR AVAILED
449	21-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
450	21-Oct-2021	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	6:55	17:20	10:25	LINE FAULT
451	21-Oct-2021	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	10:48	13:50	3:02	LINE CLEAR AVAILED
452	21-Oct-2021	GULBARGA	220	HV1	SHAHABAD_220	5:53	6:40	0:47	TRANSFORMER FAULT
453	21-Oct-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN LINE CLEAR AVAILED
454	21-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN LINE CLEAR AVAILED
455	21-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN LINE CLEAR AVAILED
456	21-Oct-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	9:40	18:26	8:46	NFBC ISSUED
457	21-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	16:27	16:43	0:16	LINE FAULT
458	21-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	0:17	0:20	0:03	LINE FAULT
459	21-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:25	4:00	0:35	LINE FAULT
460	21-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	11:01	12:30	1:29	LINE CLEAR AVAILED
461	21-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:30	20:43	0:13	LINE FAULT
462	21-Oct-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	4:30	4:40	0:10	LINE FAULT
463	21-Oct-2021	GULBARGA	110	HALABARGA-ACME SOLAR IPP	HALABARGA_220	22:48	22:53	0:05	LINE FAULT
464	21-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI 1&2	MADEWAL_110,MORATAGI_110,DEVA NGAON_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110,YADRAMI_110,MORATAGI_110	5:53	6:40	0:47	LINE CLEAR AVAILED
465	21-Oct-2021	GULBARGA	110	SHAHABAD-FARTHABAD	FARTHABAD_110,GULBARGA SOUTH_110	6:19	9:58	3:39	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
466	21-Oct-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110	20:23	20:30	0:07	LINE FAULT
467	21-Oct-2021	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	5:54	5:59	0:05	LINE FAULT
468	21-Oct-2021	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	6:13	6:13	0:00	LINE FAULT
469	21-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	5:35	5:45	0:10	LINE FAULT
470	21-Oct-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	5:45	5:50	0:05	MAIN SUPPLY FAILURE
471	21-Oct-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	6:15	6:40	0:25	MAIN SUPPLY FAILURE
472	21-Oct-2021	GULBARGA	110	YEREGERA-MADIYAL	YEREGERA_110	17:13	17:55	0:42	MAIN SUPPLY FAILURE
473	21-Oct-2021	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	5:10	5:50	0:40	MAIN SUPPLY FAILURE
474	21-Oct-2021	GULBARGA	110	SHAHBAD-JEEWARGI	JEEWARGI_110	5:50	6:20	0:30	MAIN SUPPLY FAILURE
475	21-Oct-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	18:08	18:20	0:12	LINE FAULT
476	21-Oct-2021	GULBARGA	110	ADAVI AMARESHWARA-MALLAT	ADAVI AMRESHWAR_110	20:23	20:30	0:07	MAIN SUPPLY FAILURE
477	21-Oct-2021	GULBARGA	66	HV3	HALUVAGALU_66	8:10	8:15	0:05	LINE CLEAR AVAILED
478	21-Oct-2021	GULBARGA	66	HV2	BENNEHALLI_66	7:30	7:45	0:15	TRANSFORMER FAULT
479	21-Oct-2021	GULBARGA	66	GUDEKOTE-BADALADKU	GUDEKOTE_66	10:00	13:30	3:30	LINE CLEAR AVAILED
480	21-Oct-2021	GULBARGA	66	MUNIRABAD-MSDLINE(IDLE LINE)	HANSI_66	8:02	8:07	0:05	LINE FAULT
481	21-Oct-2021	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKANAHALLI_66,HAGARIBOMMANAHALLI_66,RR STEELS IPP	18:15	18:20	0:05	LINE FAULT
482	21-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
483	21-Oct-2021	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	9:31(18.10.2021)			LINE OPEN,LINE FAULT
484	21-Oct-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	23:32(21.10.2021)			LINE OPEN,LINE FAULT
485	21-Oct-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	19:43(21.10.2021)			LINE OPEN,LINE FAULT
486	21-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN,LINE FAULT
487	21-Oct-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	22:30(21.10.2021)			LINE OPEN,LINE FAULT
488	21-Oct-2021	HASSAN	220	HV1	HASSAN_220	11:31	12:58	1:27	LINE CLEAR AVAILED
489	21-Oct-2021	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	11:30	13:01	1:31	LINE CLEAR AVAILED
490	21-Oct-2021	HASSAN	66	HASSN22-CHIKAMAGLUR2	HASSAN_220	11:30	13:02	1:32	LINE CLEAR AVAILED
491	21-Oct-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	11:07	13:25	2:18	LINE CLEAR AVAILED
492	21-Oct-2021	HASSAN	66	LV1	HASSAN_220	11:31	13:00	1:29	LINE CLEAR AVAILED
493	21-Oct-2021	HASSAN	66	HASSN22-MALLALI	HASSAN_220	11:22	13:28	2:06	LINE CLEAR AVAILED
494	21-Oct-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	11:27	11:29	0:02	HAND TRIPPED
495	21-Oct-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	13:09	13:12	0:03	HAND TRIPPED
496	21-Oct-2021	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	11:11	11:18	0:07	HAND TRIPPED
497	21-Oct-2021	HASSAN	66	HASSN22-SKPURA2	HASSAN_220	11:11	11:18	0:07	HAND TRIPPED
498	21-Oct-2021	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	13:14	13:23	0:09	HAND TRIPPED
499	21-Oct-2021	HASSAN	66	HASSN22-SKPURA2	HASSAN_220	13:14	13:24	0:10	HAND TRIPPED
500	21-Oct-2021	HASSAN	110	HGUNJE-HALADY	HEGGUNJE_220	4:23	5:12	0:49	LINE FAULT
501	21-Oct-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	11:23	13:37	2:14	LINE CLEAR AVAILED
502	21-Oct-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	18:18	21:09	2:51	LINE FAULT
503	21-Oct-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	18:14	19:29	1:15	LINE FAULT
504	21-Oct-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	9:32	11:18	1:46	LINE CLEAR AVAILED
505	21-Oct-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	13:51	14:26	0:35	LINE CLEAR AVAILED
506	21-Oct-2021	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	13:51	14:26	0:35	LINE CLEAR AVAILED
507	21-Oct-2021	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	4:23	5:13	0:50	MAIN SUPPLY FAILURE
508	21-Oct-2021	HASSAN	110	HV1	ANANDAPURA_110	9:56	17:17	7:21	LINE CLEAR AVAILED
509	21-Oct-2021	HASSAN	110	HV2	ANANDAPURA_110	9:56	18:04	8:08	LINE CLEAR AVAILED
510	21-Oct-2021	HASSAN	110	HV3	BAIKAMPADI_110	4:38	5:06	0:28	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
511	21-Oct-2021	HASSAN	110	HV1	BANTWAL_110	10:04	12:32	2:28	LINE CLEAR AVAILED
512	21-Oct-2021	HASSAN	110	HV2	BHADRAVATHI_110	15:13	16:34	1:21	LINE CLEAR AVAILED
513	21-Oct-2021	HASSAN	110	HV1	GAJNUR_110	11:45	12:52	1:07	LINE CLEAR AVAILED
514	21-Oct-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	13:54	14:27	0:33	MAIN SUPPLY FAILURE
515	21-Oct-2021	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	13:56	14:24	0:28	MAIN SUPPLY FAILURE
516	21-Oct-2021	HASSAN	110	HV2	GURUVAYANAKERE_110	10:04	13:17	3:13	LINE CLEAR AVAILED
517	21-Oct-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	18:19	21:09	2:50	MAIN SUPPLY FAILURE
518	21-Oct-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	18:14	19:29	1:15	LINE FAULT
519	21-Oct-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	3:48	5:51	2:03	MAIN SUPPLY FAILURE
520	21-Oct-2021	HASSAN	110	HV2	HOSANGADI_110	13:03	17:05	4:02	LINE CLEAR AVAILED
521	21-Oct-2021	HASSAN	110	HULICA-HSNGD	HULICAL_110	19:40	21:05	1:25	LINE FAULT
522	21-Oct-2021	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	12:40	14:15	1:35	LINE CLEAR AVAILED
523	21-Oct-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	19:43	20:41	0:58	MAIN SUPPLY FAILURE
524	21-Oct-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	19:35	21:13	1:38	MAIN SUPPLY FAILURE
525	21-Oct-2021	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	19:11	19:53	0:42	LINE FAULT
526	21-Oct-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	19:37	20:05	0:28	LINE FAULT
527	21-Oct-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:34	12:43	0:09	LINE FAULT
528	21-Oct-2021	HASSAN	110	HV2	VITTAL_110	2:09	2:52	0:43	HAND TRIPPED
529	21-Oct-2021	HASSAN	110	HV2	VITTAL_110	19:13	20:12	0:59	HAND TRIPPED
530	21-Oct-2021	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	1:15	1:28	0:13	LINE FAULT
531	21-Oct-2021	HASSAN	66	HV1	MALLAPURA_66	12:43	14:15	1:32	LINE CLEAR AVAILED
532	21-Oct-2021	HASSAN	66	HV2	MALLAPURA_66	12:43	14:15	1:32	LINE CLEAR AVAILED
533	21-Oct-2021	HASSAN	66	MLLAPU-SHIMOGA	MALLAPURA_66	12:43	14:14	1:31	LINE CLEAR AVAILED
534	21-Oct-2021	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	17:34	18:44	1:10	LINE FAULT
535	21-Oct-2021	HASSAN	66	CHIKKAK-HASN	CHIKKAKONDAGOLA_66	17:34	17:59	0:25	LINE FAULT
536	21-Oct-2021	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	18:35	18:50	0:15	HAND TRIPPED
537	21-Oct-2021	HASSAN	66	HV1	HALEBEEDU_66	12:15	13:08	0:53	LINE CLEAR AVAILED
538	21-Oct-2021	HASSAN	66	HV2	HALEBEEDU_66	12:14	12:23	0:09	LINE CLEAR AVAILED
539	21-Oct-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	0:20	0:25	0:05	LINE FAULT
540	21-Oct-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	22:12	22:26	0:14	LINE FAULT
541	21-Oct-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	6:16	6:35	0:19	LINE FAULT
542	21-Oct-2021	HASSAN	66	HV1	MAGGE_66	10:00	11:20	1:20	MAIN SUPPLY FAILURE
543	21-Oct-2021	HASSAN	66	HV1	MAGGE_66	13:15	13:25	0:10	MAIN SUPPLY FAILURE
544	21-Oct-2021	HASSAN	66	HV2	MAGGE_66	10:00	11:20	1:20	MAIN SUPPLY FAILURE
545	21-Oct-2021	HASSAN	66	HV2	MAGGE_66	13:15	13:25	0:10	MAIN SUPPLY FAILURE
546	21-Oct-2021	HASSAN	66	MATTANAV-DIDGTHL	MATTNAVILE_66	19:10	19:20	0:10	LINE FAULT
547	21-Oct-2021	HASSAN	66	HV2	MATTNAVILE_66	13:50	14:10	0:20	LINE CLEAR AVAILED
548	21-Oct-2021	HASSAN	66	HV2	SHRAVANABELAGOLA_66	12:50	13:10	0:20	LINE CLEAR AVAILED
549	21-Oct-2021	HASSAN	66	HV1	SHANTHIGRAMMA_66	12:25	13:00	0:35	LINE CLEAR AVAILED
550	21-Oct-2021	HASSAN	66	HV2	SHANTHIGRAMMA_66	11:42	12:25	0:43	LINE CLEAR AVAILED
551	21-Oct-2021	HASSAN	66	HV1	YESLUR_66	11:35	13:04	1:29	MAIN SUPPLY FAILURE
552	21-Oct-2021	MYSURU	66	BG NAGARA-ANCHEPALYA	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	19:13	19:32	22:44	LINE FAULT
553	21-Oct-2021	MYSURU	66	HV2	BGPURA_66	12:05	12:25	0:20	LINE CLEAR AVAILED
554	21-Oct-2021	MYSURU	66	HV1	DEVANOORNGUDU_66	9:29	17:00	7:30	LINE CLEAR AVAILED
555	21-Oct-2021	MYSURU	66	ELVALA-HOOTGALLY	NO STATIONS EFFECTED	5:49	18:31	12:42	LINE FAULT
556	21-Oct-2021	MYSURU	66	HV2	HAMPAPURA_66	6:07	18:49	12:42	LINE CLEAR AVAILED
557	21-Oct-2021	MYSURU	66	HANNUR-KOTHNUR	NO STATIONS EFFECTED	1:13	1:20	0:06	LINE FAULT
558	21-Oct-2021	MYSURU	66	HV2	JAKKANAHALLY_66	6:58	7:16	0:18	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
559	21-Oct-2021	MYSURU	66	HV2	JAKKANAHALLY_66	9:51	12:15	2:24	TRANSFORMER FAULT
560	21-Oct-2021	MYSURU	66	JAKKANALLI-NAGMANGLA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66	21:50	21:56	0:06	LINE FAULT
561	21-Oct-2021	MYSURU	66	KIRUGAVALU-VADKEPURA	KIRUGAVALU_66	14:53	15:05	0:12	LINE FAULT
562	21-Oct-2021	MYSURU	66	KOLLEGALA-PRINAMIPURA	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	9:17	9:22	0:04	LINE FAULT
563	21-Oct-2021	MYSURU	66	KRPET-KIKKERI	NO STATIONS EFFECTED	22:23	22:32	0:09	LINE FAULT
564	21-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	21:50	21:54	0:04	LINE FAULT
565	21-Oct-2021	MYSURU	66	VAJMANGALA-BANNUR	BANNUR_66	12:57	13:08	0:11	LINE FAULT
566	21-Oct-2021	MYSURU	66	VAJMANGALA-BANNUR	MALIYURU_66BANNUR_66	16:14	16:29	0:15	LINE FAULT
567	21-Oct-2021	MYSURU	66	VAJMANGALA-KADAKOLA2	NO STATIONS EFFECTED	0:00	6:52	6:52	LINE FAULT
568	21-Oct-2021	MYSURU	66	VAJMANGALA-MEGLAPURA	NO STATIONS EFFECTED	14:47	14:54	0:07	LINE FAULT
569	21-Oct-2021	MYSURU	66	KOLLEGALA-PRINAMIPURA	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	17:44(21.10.2021)			LINE OPEN,LINE FAULT
570	21-Oct-2021	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	23:32:00 (20/10/2021)	6:52:00 (21/10/2021)	7:20HRS	LINE CHARGED
571	21-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA		21:44:47 (20/10/2021)	8:40:00 (21/10/2021)	10:55HRS	LINE CHARGED
572	21-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN LINE CLEAR AVAILED
573	21-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42(5.10.2021)			LINE OPEN LINE CLEAR AVAILED
574	21-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN LINE CLEAR AVAILED
575	21-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
576	21-Oct-2021	TUMKUR	220	TR-2	ANTHARASANAHALLI_220	23:32	0:24	0:52	TRANSFORMER FAULT
577	21-Oct-2021	TUMKUR	220	TR-3	ANTHARASANAHALLI_220	23:32	0:24	0:52	TRANSFORMER FAULT
578	21-Oct-2021	TUMKUR	220	TR-1	KIADB_220	15:42	15:56	0:14	LINE CLEAR AVAILED
579	21-Oct-2021	TUMKUR	220	TR-2	KIADB_220	13:06	18:22	5:15	LINE CLEAR AVAILED
580	21-Oct-2021	TUMKUR	110	TR-2	KADEHALLI_110	22:12	7:15	9:03	TRANSFORMER FAULT
581	21-Oct-2021	TUMKUR	110	KB CROSS 220kv-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	21:50	22:07	0:16	LINE FAULT
582	21-Oct-2021	TUMKUR	110	NITTUR 220kv-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	23:21	23:28	0:07	HAND TRIPPED
583	21-Oct-2021	TUMKUR	110	NITTUR 220kv- GUBBI	GUBBI_110, BIDARE_110	22:59	2:20	3:20	LINE FAULT
584	21-Oct-2021	TUMKUR	110	TR-2	NITTUR_220	16:15	16:42	0:27	LINE CLEAR AVAILED
585	21-Oct-2021	TUMKUR	110	NITTUR 220kv- KADABA	KADABA_110	23:21	23:27	0:06	HAND TRIPPED
586	21-Oct-2021	TUMKUR	110	NITTUR 220kv- KALLUR	KALLUR_110	23:21	23:27	0:06	HAND TRIPPED
587	21-Oct-2021	TUMKUR	110	NITTUR 220kv- KG TEMPLE	KGTEMPLE_110, UNGRA_110	23:21	23:36	0:15	HAND TRIPPED
588	21-Oct-2021	TUMKUR	110	TR-1(LV-1)	NITTUR_220	22:59	23:29	0:29	TRANSFORMER FAULT
589	21-Oct-2021	TUMKUR	110	TR-1(LV-2)	NITTUR_220	22:59	23:27	0:27	TRANSFORMER FAULT
590	21-Oct-2021	TUMKUR	66	TR-1	ANTHARASANAHALLI_220	23:50	0:35	0:45	HAND TRIPPED
591	21-Oct-2021	TUMKUR	66	TR-2	ANTHARASANAHALLI_220	23:50	0:35	0:45	HAND TRIPPED
592	21-Oct-2021	TUMKUR	66	ANTHRASANAHALLI 220kv-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	23:50	0:29	0:39	HAND TRIPPED
593	21-Oct-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	23:50	6:43	7:03	LINE CLEAR AVAILED
594	21-Oct-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	23:51	0:52	1:01	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
595	21-Oct-2021	TUMKUR	66	ANTHRASANAHALI 220KV-WIPRO1	WIPRO_EHT	23:58	0.:47	0:47	HAND TRIPPED
596	21-Oct-2021	TUMKUR	66	TR-3(LV-3)	ANTHARASANAHALI_220	23:50	0:27	0:57	HAND TRIPPED
597	21-Oct-2021	TUMKUR	66	BUKKAPATNA-SIRA	BUKKAPATNA_66	1:20	1:50	0:30	MAIN SUPPLY FAILURE
598	21-Oct-2021	TUMKUR	66	TR-2	CHITRAHALI_66	8:00	8:05	0:05	TRANSFORMER FAULT
599	21-Oct-2021	TUMKUR	66	DAVANGERE SRS-YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALI_66	18:13	18:22	0:09	LINE FAULT
600	21-Oct-2021	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	11:12	11:18	0:06	LINE FAULT
601	21-Oct-2021	TUMKUR	66	TR-2	HOLALKERE_66	15:22	17:10	1:48	LINE CLEAR AVAILED
602	21-Oct-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:17	18:30	0:12	LINE FAULT
603	21-Oct-2021	TUMKUR	66	HONNALLI 220kv-KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	11:26	11:36	0:10	LINE FAULT
604	21-Oct-2021	TUMKUR	66	HONNALLI 220kv-NYAMATHI_66	NYAMATHI_66	11:17	11:26	0:09	LINE FAULT
605	21-Oct-2021	TUMKUR	66	HONNALLI 220kv-NYAMATHI_66	NYAMATHI_66	22:21	22:48	0:27	LINE FAULT
606	21-Oct-2021	TUMKUR	66	HONNALLI 220kv-BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	16:50	16:59	0:09	LINE FAULT
607	21-Oct-2021	TUMKUR	66	HONNALLI-HONNALLI	HONNALLI_66, KATTIGE_66	22:34	22:44	0:10	LINE FAULT
608	21-Oct-2021	TUMKUR	66	TR-2(LV-2)	KIADB_220	13:06	16:02	2:56	LINE CLEAR AVAILED
609	21-Oct-2021	TUMKUR	66	TR-1	KIADB_220	15:39	16:05	0:25	LOAD CHANGE OVER
610	21-Oct-2021	TUMKUR	66	TR-1(LV-1)	KIADB_220	15:48	15:57	0:09	LINE CLEAR AVAILED
611	21-Oct-2021	TUMKUR	66	LINGADAHALLI-SHIMOGA(NALLUR)	LINGDHALLI_66	21:56	22:03	0:07	LINE FAULT
612	21-Oct-2021	TUMKUR	66	LINGADAHALLI-SHIMOGA(NALLUR)	LINGDHALLI_66	22:39	22:51	0:12	LINE FAULT
613	21-Oct-2021	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	6:35	7:19	0:43	MAIN SUPPLY FAILURE
614	21-Oct-2021	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	17:05	17:36	0:30	LINE CLEAR AVAILED
615	21-Oct-2021	TUMKUR	66	TR-2	PATNAYAKANAHALLI_66	13:10	16:44	3:34	LINE CLEAR AVAILED
616	21-Oct-2021	TUMKUR	66	TR-1	PAVAGADA_220	12:54	15:00	2:06	LINE CLEAR AVAILED
617	21-Oct-2021	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	18:18	18:28	0:09	LINE FAULT
618	21-Oct-2021	TUMKUR	66	PAVAGADA_NAGALMADIKE	NAGALAMADIKE_66	10:48	10:59	0:10	LINE FAULT
619	21-Oct-2021	TUMKUR	66	TR-1	RAMAPURA_66	9:05	9:15	0:09	LINE CLEAR AVAILED
620	21-Oct-2021	TUMKUR	66	TR-1	RAMAPURA_66	17:44	17:51	0:06	TRANSFORMER FAULT
621	21-Oct-2021	TUMKUR	66	SAVALANGA 66kv-HNLI220_NYMT	SAVALANGA_66	11:26	11:51	0:24	MAIN SUPPLY FAILURE
622	21-Oct-2021	TUMKUR	66	SAVALANGA 66kv-HNLI220_NYMT	SAVALANGA_66	11:53	12:13	0:19	LINE FAULT
623	21-Oct-2021	TUMKUR	66	TR-1	SAVALANGA_66	11:26	11:53	0:27	MAIN SUPPLY FAILURE
624	21-Oct-2021	TUMKUR	66	TR-1	SAVALANGA_66	11:53	15:35	3:41	TRANSFORMER FAULT
625	22-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN LINE CLEAR AVAILED
626	22-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
627	22-Oct-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
628	22-Oct-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
629	22-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
630	22-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN LINE CLEAR AVAILED
631	22-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
632	22-Oct-2021	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
633	22-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN LINE CLEAR AVALIED
634	22-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN LINE CLEAR AVALIED
635	22-Oct-2021	BAGALKOT	110	110/11KV,HV3	HIREKERUR_110	22:51 (21.10.2021)	14:47 (22.10.2021)	15:56HRS	TRANSFORMER CHARGED
636	22-Oct-2021	BAGALKOT	110	SIRSI-KUMATA 2	SIRSI_110	23:43 (21.10.2021)	6:44 (22.10.2021)	7:01HRS	LINE CHARGED
637	22-Oct-2021	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	23:54 (21.10.2021)	11:07 (22.10.2021)	11:13HRS	LINE CHARGED
638	22-Oct-2021	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	15:51 (21.10.2021)	16:56 (22.10.2021)	25:05HRS	LINE CHARGED
639	22-Oct-2021	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	11:46	13:10	1:24	LINE CLEAR AVALIED
640	22-Oct-2021	BAGALKOT	110	110/11KV,HV4	KERUR_110	10:54	12:38	1:44	LINE CLEAR AVALIED
641	22-Oct-2021	BAGALKOT	220	BELGAUM- NARENDRA1	BELGAUM_220	13:38	18:52	5:14	LINE FAULT
642	22-Oct-2021	BAGALKOT	220	VAJRAMATTI -BAGALKOT1	VAJRAMATTI_220	10:36	19:32	8:56	LINE CLEAR AVALIED
643	22-Oct-2021	BAGALKOT	220	VAJRAMATTI -BAGALKOT2	VAJRAMATTI_220	15:00	15:15	0:15	LINE FAULT
644	22-Oct-2021	BAGALKOT	220	VAJRAMATTI- ENORGON SOLAR	VAJRAMATTI_220	17:50	18:13	0:23	LINE FAULT
645	22-Oct-2021	BAGALKOT	220	VAJRAMATTI220- KAVATAGI LIS	VAJRAMATTI_220	17:50	18:07	0:17	LINE FAULT
646	22-Oct-2021	BAGALKOT	110	VAJARMATTI-KATARAKI110	KATARAKI_110	11:30	16:03	4:33	LINE FAULT
647	22-Oct-2021	BAGALKOT	220	SOUDATTI- BIDNAL	SOUDATTI_220	6:03	8:41	2:38	LINE FAULT
648	22-Oct-2021	BAGALKOT	220	NARENDRA- BELGAUM1	NARENDRA_220	13:37	18:49	5:12	LINE CLEAR AVALIED
649	22-Oct-2021	BAGALKOT	220	NARENDRA- BELGAUM2	NARENDRA_220	13:37	18:49	5:12	LINE CLEAR AVALIED
650	22-Oct-2021	BAGALKOT	220	MUGALKOD- CHIKKODI1	MUGALKOD_220	10:31	13:20	2:49	NFBC ISSUED
651	22-Oct-2021	BAGALKOT	220	220/110KV, HV1(HV2)&LV1(LV2)	GADAG_220	14:42	18:36	3:54	LINE CLEAR AVALIED
652	22-Oct-2021	BAGALKOT	220	BIDNAL- SOUDATTI	BIDNAL_220	6:04	8:31	2:27	LINE FAULT
653	22-Oct-2021	BAGALKOT	220	BIDNAL-HIREBENDIGERI1	BIDNAL_220	5:34	9:12	3:38	LINE FAULT
654	22-Oct-2021	BAGALKOT	220	BIDNAL-HIREBENDIGERI2	BIDNAL_220	5:34	9:19	3:45	LINE FAULT
655	22-Oct-2021	BAGALKOT	220	BAGALKOT- VAJRAMATTI1	BAGALKOT_220	10:38	19:39	9:01	LINE CLEAR AVALIED
656	22-Oct-2021	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	12:48	13:39	0:51	LINE FAULT
657	22-Oct-2021	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	2:53	7:02	4:09	LINE CLEAR AVALIED
658	22-Oct-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	16:39	16:46	0:07	HAND TRIPPED
659	22-Oct-2021	BAGALKOT	110	ATHANI-SATTI	SATTI_110	17:14	17:32	0:18	LOAD CURTAILMENT
660	22-Oct-2021	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	17:28	17:49	0:21	LOAD CURTAILMENT
661	22-Oct-2021	BAGALKOT	110	HIDIDKAL-ITANAL	ITANAL_110	13:05	13:31	0:26	LINE CLEAR AVALIED
662	22-Oct-2021	BAGALKOT	110	110/11KV,HV3	HIREKERUR_110	15:51	18:14	2:23	LINE CLEAR AVALIED
663	22-Oct-2021	BAGALKOT	110	110/11KV,HV	KANABARGI LAY OUT_110	12:10	14:11	2:01	LINE CLEAR AVALIED
664	22-Oct-2021	BAGALKOT	110	KONNUR-ANANT SOLAR	KONNUR_110	19:52	22:39	2:47	LINE CLEAR AVALIED
665	22-Oct-2021	BAGALKOT	110	110/11KV,HV1	MORATAGI_110	12:48	12:58	0:10	TRANSFORMER FAULT
666	22-Oct-2021	BAGALKOT	110	YADAWAD-ISEL SOLAR	YADAWAD_110	18:21	21:21	3:00	LINE CLEAR AVALIED
667	22-Oct-2021	BAGALKOT	110	JOG 1-SIRSI	SIRSI_110	10:40	12:05	1:25	LINE FAULT
668	22-Oct-2021	BAGALKOT	110	SIRSI-KUMTA 1	SIRSI_110	16:40	19:25	2:45	LINE FAULT
669	22-Oct-2021	BAGALKOT	110	SIRSI-KUMTA 2	SIRSI_110	16:40	19:25	2:45	LINE FAULT
670	22-Oct-2021	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MALGHAN(S)_110	17:25	18:30	1:05	LINE CLEAR AVALIED
671	22-Oct-2021	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(G)_110	11:00	12:05	1:05	LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
672	22-Oct-2021	BAGALKOT	110	KUMATA-SIRSI 2	KUMATA_110	23:54 (21.10.2021)	11:07 (22.10.2021)	11:13HRS	LINE CHARGED
673	22-Oct-2021	BAGALKOT	110	SIRSI-KUMATA 1	SIRSI_110	23:43 (21.10.2021)	6:44 (22.10.2021)	7:01HRS	LINE CHARGED
674	22-Oct-2021	BAGALKOT	110	110/11KV,HV1	SHIROL_110	6:05	6:15	0:10	TRANSFORMER FAULT
675	22-Oct-2021	BAGALKOT	110	110/11KV,HV1	SHIROL_110	12:10	12:30	0:20	LINE CLEAR AVAILED
676	22-Oct-2021	BAGALKOT	110	110/11KV,HV2	DAMBAL_110	16:10	17:40	1:30	LINE CLEAR AVAILED
677	22-Oct-2021	BAGALKOT	220	RANEBENNUR-BELLIGAVI	RANEBENNUR_220	10:31	16:11	5:40	MAIN SUPPLY FAILURE
678	22-Oct-2021	BAGALKOT	110	RANEBENNUR-HIREKERUR	RANEBENNUR_220	9:52	10:10	0:18	MAIN SUPPLY FAILURE
679	22-Oct-2021	BAGALKOT	110	RANEBENNUR-HONNATTI	RANEBENNUR_220	9:52	10:10	0:18	MAIN SUPPLY FAILURE
680	22-Oct-2021	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	RANEBENNUR_220	9:52	10:10	0:18	MAIN SUPPLY FAILURE
681	22-Oct-2021	BAGALKOT	220	RANEBENNUR-GUTTAL	RANEBENNUR_220	9:52	10:10	0:18	MAIN SUPPLY FAILURE
682	22-Oct-2021	BAGALKOT	110	ATHANI-SATTI	ATHANI_220	17:14	17:32	0:18	HAND TRIPPED
683	22-Oct-2021	BAGALKOT	110	110/11KV,HV5	HANAGAL_110	15:40	17:00	1:20	LINE CLEAR AVAILED
684	22-Oct-2021	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI	5:50	5:59	0:09	LOAD CHANGE OVER
685	22-Oct-2021	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	0:09	0:16	0:07	MAIN SUPPLY FAILURE
686	22-Oct-2021	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	0:09	0:16	0:07	LINE CLEAR AVAILED
687	22-Oct-2021	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	0:09	0:16	0:07	LINE CLEAR AVAILED
688	22-Oct-2021	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	1:37	1:50	0:13	MAIN SUPPLY FAILURE
689	22-Oct-2021	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	1:37	1:50	0:13	LINE CLEAR AVAILED
690	22-Oct-2021	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	1:37	1:50	0:13	LINE CLEAR AVAILED
691	22-Oct-2021	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 220	13:11	13:42	0:31	LINE FAULT
692	22-Oct-2021	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	14:56	15:14	0:18	LINE CLEAR AVAILED
693	22-Oct-2021	BENGALURU	66	HV1	HSR LAYOUT 220	15:06	15:08	0:02	LINE CLEAR AVAILED
694	22-Oct-2021	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	14:56	15:09	0:13	LINE CLEAR AVAILED
695	22-Oct-2021	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	14:51	14:56	0:05	LINE CLEAR AVAILED
696	22-Oct-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	14:59	15:30	0:31	LINE FAULT
697	22-Oct-2021	BENGALURU	220	MANYATHA TECH PARK 220 - HOODY 220	MANYATHA TECH PARK 220	13:11	13:42	0:31	LINE FAULT
698	22-Oct-2021	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 2	SHOBHA CITY	13:11	13:42	0:31	LINE CLEAR AVAILED
699	22-Oct-2021	BENGALURU	66	MANYATHA TECH PARK 220 - PEENYA 2	SAHAKARINAGAR	13:11	13:42	0:31	LINE CLEAR AVAILED
700	22-Oct-2021	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	0:09	0:39	0:30	MAIN SUPPLY FAILURE
701	22-Oct-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	0:09	0:39	0:30	LINE CLEAR AVAILED
702	22-Oct-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	0:09	0:39	0:30	LINE CLEAR AVAILED
703	22-Oct-2021	BENGALURU	220	NRS 220 - A STATION 220	NRS 220	1:37	1:50	0:13	MAIN SUPPLY FAILURE
704	22-Oct-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	1:37	1:50	0:13	LINE CLEAR AVAILED
705	22-Oct-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	1:37	1:50	0:13	LINE CLEAR AVAILED
706	22-Oct-2021	BENGALURU	66	HV1	RAJANUKUNTE	18:35	18:40	0:05	LINE CLEAR AVAILED
707	22-Oct-2021	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	0:09	0:39	0:30	LINE FAULT
708	22-Oct-2021	BENGALURU	66	HV2	VIJAYANAGARA	0:09	1:03	0:54	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
709	22-Oct-2021	BENGALURU	66	HV2	VIJAYANAGARA	4:49	5:42	0:53	MAIN SUPPLY FAILURE
710	22-Oct-2021	BENGALURU	66	HV2	VIJAYANAGARA	2:12	2:18	0:06	LOAD CHANGE OVER
711	22-Oct-2021	BENGALURU	66	HV2	VIJAYANAGARA	8:53	9:03	0:10	LOAD CHANGE OVER
712	22-Oct-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	10:00	11:25	1:25	LINE CLEAR AVOIDED
713	22-Oct-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	10:00	16:49	6:49	LINE CLEAR AVOIDED
714	22-Oct-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	18:03	18:15	0:12	LINE FAULT
715	22-Oct-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	22:05	22:39	0:34	LINE FAULT
716	22-Oct-2021	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	VIDHURASHWATHA, GUNDLU KOTTURU	1:27	1:36	0:09	LINE FAULT
717	22-Oct-2021	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	1:27	1:36	0:09	LINE FAULT
718	22-Oct-2021	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	SRS PEENYA 220	0:08	0:39	0:30	LINE FAULT
719	22-Oct-2021	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 4	NRS 220	0:10	1:04	0:54	LINE FAULT
720	22-Oct-2021	BENGALURU	220	NELAMANGALA 400 - ANCHEPALYA 1	ANCHEPALYA 220	0:22	0:55	0:33	LINE FAULT
721	22-Oct-2021	BENGALURU	220	NELMANGALA 400 - DB PURA 1	NO STATION AFFECTED	0:10	2:21	2:11	LINE FAULT
722	22-Oct-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	5:12	5:42	0:29	LINE FAULT
723	22-Oct-2021	BENGALURU	220	DB PURA 220 - NELAMANGALA 1	NO STATION AFFECTED	0:10	2:23	2:12	LINE FAULT
724	22-Oct-2021	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	17:36	18:20	0:43	LINE FAULT
725	22-Oct-2021	BENGALURU	66	NELMANGALA 66 - ALUR	NELAMANGALA 66	20:26	20:37	0:11	LOAD CHANGE OVER
726	22-Oct-2021	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	22:51	23:42	0:51	LINE FAULT
727	22-Oct-2021	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	22:51	23:43	0:52	LINE FAULT
728	22-Oct-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	9:52	10:00	0:08	LINE FAULT
729	22-Oct-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	21:51	22:04	0:13	LINE FAULT
730	22-Oct-2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	21:41	21:51	0:09	LINE FAULT
731	22-Oct-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	21:51	22:03	0:11	LINE FAULT
732	22-Oct-2021	BENGALURU	66	HV2	MAASTHI	13:02	13:46	0:44	LINE CLEAR AVOIDED
733	22-Oct-2021	BENGALURU	66	HV1	H GOLLAHALLI	15:00	15:15	0:15	LINE CLEAR AVOIDED
734	22-Oct-2021	BENGALURU	66	HV1	H GOLLAHALLI	15:15	15:55	0:40	LINE CLEAR AVOIDED
735	22-Oct-2021	BENGALURU	66	HV1	DALASNUR	12:14	12:58	0:43	LINE CLEAR AVOIDED
736	22-Oct-2021	BENGALURU	66	HV2	ALUR	12:10	12:55	0:45	LINE CLEAR AVOIDED
737	22-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	0:00	0:05	0:05	LINE FAULT
738	22-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	0:06	7:10	7:04	MAIN SUPPLY FAILURE
739	22-Oct-2021	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	23:01	23:44	0:43	LINE FAULT
740	22-Oct-2021	BENGALURU	66	HV2	MANCHENAHALLI	9:09	9:20	0:11	LINE CLEAR AVOIDED
741	22-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	23:28(22-10-21)			MAIN SUPPLY FAILURE
742	22-Oct-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	23:50(22-10-2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
743	22-Oct-2021	BENGALURU	400	HOODY 400 - DEVANAHALLI 2 400	NO STATION AFFECTED	21:57(21/10/2021)	8:38(22/10/2021)	10:41HRS	LINE CHARGED
744	22-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:57 (21.10.2021)	7:40(22.10.2021)	8:43 HRS	LINE CHARGED
745	22-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
746	22-Oct-2021	GULBARGA	220	BTPSG-LINGAPUR	LINGAPUR_220	11:15	17:13	5:58	LINE CLEAR AVAILED
747	22-Oct-2021	GULBARGA	220	RAICHUR-JUEALA_IPP	RAICHUR_220	20:55	21:32	0:37	LINE FAULT
748	22-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN LINE CLEAR AVAILED
749	22-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN LINE CLEAR AVAILED
750	22-Oct-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1(IDLE LINE)	SHAHAPUR_110	13:00(08.10.2021)			LINE OPEN LINE CLEAR AVAILED
751	22-Oct-2021	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	14:17	16:31	2:14	LINE CLEAR AVAILED
752	22-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1	GULBARGA SOUTH_110,FARATHABAD_110	11:38	14:05	2:27	LINE CLEAR AVAILED
753	22-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	4:38	4:47	0:09	LINE FAULT
754	22-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:00	19:05	0:05	LINE FAULT
755	22-Oct-2021	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	10:48	17:30	6:42	LINE CLEAR AVAILED
756	22-Oct-2021	GULBARGA	110	MUNIRABAD-VYSANKERE2	STAR METALLIC_IPP	5:27	5:33	0:06	LINE FAULT
757	22-Oct-2021	GULBARGA	110	SHAHAPUR-YADGIR (IDLE LINE)	YADGIR_110	15:05	15:15	0:10	LINE FAULT
758	22-Oct-2021	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	13:20	13:27	0:07	LINE FAULT
759	22-Oct-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	5:24	10:00	4:36	LINE FAULT
760	22-Oct-2021	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	6:05	6:10	0:05	MAIN SUPPLY FAILURE
761	22-Oct-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BH ALKI SUGAR_IPP	5:46	5:52	0:06	LINE FAULT
762	22-Oct-2021	GULBARGA	110	MARGUTTI-SOLAR_IPP	MARGUTTI_110	18:25	23:10	4:45	LINE CLEAR AVAILED
763	22-Oct-2021	GULBARGA	110	JEEWARGI-SHAHAPUR	JEEWARGI_110	6:05	6:15	0:10	LINE FAULT
764	22-Oct-2021	GULBARGA	110	HV1	JEEWARGI_110	10:50	12:30	1:40	LINE CLEAR AVAILED
765	22-Oct-2021	GULBARGA	110	HV1	JEEWARGI_110	11:05	12:30	1:25	LINE CLEAR AVAILED
766	22-Oct-2021	GULBARGA	110	METRI-ALIPUR	METRI_110	8:20	8:30	0:10	MAIN SUPPLY FAILURE
767	22-Oct-2021	GULBARGA	110	METRI-ALIPUR	METRI_110	9:00	9:45	0:45	MAIN SUPPLY FAILURE
768	22-Oct-2021	GULBARGA	110	METRI-ALIPUR	METRI_110	13:05	13:15	0:10	MAIN SUPPLY FAILURE
769	22-Oct-2021	GULBARGA	110	KANAKAGIRI-KUSHTAGI	KANAKAGIRI_110	1:00	1:10	0:10	MAIN SUPPLY FAILURE
770	22-Oct-2021	GULBARGA	110	HV2	HATTI_110	17:45	17:50	0:05	TRANSFORMER FAULT
771	22-Oct-2021	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	6:05	6:10	0:05	MAIN SUPPLY FAILURE
772	22-Oct-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	4:05	4:10	0:05	TRANSFORMER FAULT
773	22-Oct-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	4:40	4:45	0:05	TRANSFORMER FAULT
774	22-Oct-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	7:35	7:40	0:05	TRANSFORMER FAULT
775	22-Oct-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	9:20	9:30	0:10	TRANSFORMER FAULT
776	22-Oct-2021	GULBARGA	66	MUNIRABAD-SANKLAPUR	SANKLAPURA_110	9:20	17:49	8:29	LINE CLEAR AVAILED
777	22-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
778	22-Oct-2021	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	9:31(18.10.2021)			LINE OPEN,LINE FAULT
779	22-Oct-2021	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	19:43(21.10.2021)			LINE OPEN,LINE FAULT
780	22-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN,LINE FAULT
781	22-Oct-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	22:30(21.10.2021)			LINE OPEN,LINE FAULT
782	22-Oct-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	21:10(22.10.2021)			LINE OPEN,LINE FAULT
783	22-Oct-2021	HASSAN	220	VARAH1-KEMAR1	varahi_gen	21:11(22.10.2021)			LINE OPEN,LINE FAULT
784	22-Oct-2021	HASSAN	220	MRSSHM-ANTRSNH	MRS MG_220	23:32(21.10.2021)			LINE OPEN,LINE FAULT
785	22-Oct-2021	HASSAN	220	MRSSHM-HONNALLI	MRS MG_220	10:18(22.10.2021)			LINE OPEN LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
786	22-Oct-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	15:27	17:28	2:01	LINE CLEAR AVAILED
787	22-Oct-2021	HASSAN	220	HV1	HGGUNJE_220	10:19	11:52	1:33	LINE CLEAR AVAILED
788	22-Oct-2021	HASSAN	110	LV1	HGGUNJE_220	10:19	11:53	1:34	LINE CLEAR AVAILED
789	22-Oct-2021	HASSAN	220	HV2	SHIRALKOPPA_220	12:05	17:36	5:31	LINE CLEAR AVAILED
790	22-Oct-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:54	11:59	0:05	HAND TRIPPED
791	22-Oct-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:57	12:01	0:04	LINE CLEAR AVAILED
792	22-Oct-2021	HASSAN	110	LV2	SHIRALKOPPA_220	12:05	17:37	5:32	LINE CLEAR AVAILED
793	22-Oct-2021	HASSAN	110	HV1	BANAVARA_110	13:54	14:32	0:38	LINE CLEAR AVAILED
794	22-Oct-2021	HASSAN	110	HV2	BANAVARA_110	12:50	13:45	0:55	LINE CLEAR AVAILED
795	22-Oct-2021	HASSAN	110	KAVOOR-AMR	KAVOOR_220	10:24	13:05	2:41	LINE CLEAR AVAILED
796	22-Oct-2021	HASSAN	110	KAVOOR-KIOCL	KAVOOR_220	9:30	18:24	8:54	LINE CLEAR AVAILED
797	22-Oct-2021	HASSAN	110	HV1	KONAJE_110	8:45	8:48	0:03	HAND TRIPPED
798	22-Oct-2021	HASSAN	110	HV2	KONAJE_110	8:45	8:48	0:03	HAND TRIPPED
799	22-Oct-2021	HASSAN	110	HV3	KONAJE_110	8:45	8:48	0:03	HAND TRIPPED
800	22-Oct-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:01	10:39	0:38	LINE FAULT
801	22-Oct-2021	HASSAN	110	HV1	KONDENALU_110	15:50	16:58	1:08	LINE CLEAR AVAILED
802	22-Oct-2021	HASSAN	110	HV2	KUNDAPURA_110	15:39	16:00	0:21	TRANSFORMER FAULT
803	22-Oct-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:10	11:32	1:22	NFBC ISSUED
804	22-Oct-2021	HASSAN	110	HV2	NERALAKERE_110	11:40	12:10	0:30	LINE CLEAR AVAILED
805	22-Oct-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	11:34	11:45	0:11	HAND TRIPPED
806	22-Oct-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	6:02	6:25	0:23	LINE FAULT
807	22-Oct-2021	HASSAN	66	HV1	MALLAPURA_66	13:48	14:19	0:31	LINE CLEAR AVAILED
808	22-Oct-2021	HASSAN	66	HV2	MALLAPURA_66	13:48	14:19	0:31	LINE CLEAR AVAILED
809	22-Oct-2021	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	13:48	14:18	0:30	LINE CLEAR AVAILED
810	22-Oct-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	13:03	14:10	1:07	LINE FAULT
811	22-Oct-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:30	16:31	2:01	LINE FAULT
812	22-Oct-2021	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	10:54	15:47	4:53	LINE CLEAR AVAILED
813	22-Oct-2021	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	13:04	14:08	1:04	LINE FAULT
814	22-Oct-2021	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	14:31	16:31	2:00	LINE FAULT
815	22-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:01	13:23	1:22	LINE FAULT
816	22-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:35	17:13	3:38	LINE FAULT
817	22-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	13:42	14:39	0:57	LINE FAULT
818	22-Oct-2021	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	12:01	13:23	1:22	LINE FAULT
819	22-Oct-2021	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	13:35	17:13	3:38	LINE FAULT
820	22-Oct-2021	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	13:42	14:39	0:57	LINE FAULT
821	22-Oct-2021	MYSURU	66	HV1	CHANDAKAWADI_66	10:40	11:40	22:44	LINE CLEAR AVAILED
822	22-Oct-2021	MYSURU	66	HV2	CHANDAKAWADI_66	14:59	15:13	0:14	LINE CLEAR AVAILED
823	22-Oct-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	9:35	9:47	0:11	LINE FAULT
824	22-Oct-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	14:30	18:31	4:01	LINE FAULT
825	22-Oct-2021	MYSURU	66	DMG HALLI-KHB	DMG_HALLI_66	10:00	18:49	8:49	LINE CLEAR AVAILED
826	22-Oct-2021	MYSURU	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	0:59	1:09	0:09	HAND TRIPPED
827	22-Oct-2021	MYSURU	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	4:26	4:40	0:13	LINE FAULT
828	22-Oct-2021	MYSURU	66	KUSHALNAGARA-MERCERA-1	MADIKERI_66	5:18	5:32	0:14	LINE FAULT
829	22-Oct-2021	MYSURU	66	KUSHALNAGARA-SUNTIKOPPA	SUNTIKOPPA_66	5:18	5:32	0:14	LINE FAULT
830	22-Oct-2021	MYSURU	66	KUSHALNAGARA-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	7:41	7:51	0:10	LINE FAULT
831	22-Oct-2021	MYSURU	66	HV1	THANDYA_66	11:46	13:04	1:17	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
832	22-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	22:34	22:39	0:05	LINE FAULT
833	22-Oct-2021	MYSURU	66	KOLLEGALA-PRINAMIPURA	NO STATIONS EFFECTED	17:44:44	10:20 (22.10.2021)	16:35HRS	LINE CHARGED
834	22-Oct-2021	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	23:32:00 (20/10/2021)	6:52:00 (21/10/2021)	7:20HRS	LINE CHARGED
835	22-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	21:44:47 (20/10/2021)	8:40:00 (21/10/2021)	10:55HRS	LINE CHARGED
836	22-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN LINE CLEAR AVAILED
837	22-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN LINE CLEAR AVAILED
838	22-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN LINE CLEAR AVAILED
839	22-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)	12:49:54 (22.10.2021)	843:36HRS	TRANSFORMER CHARGED
840	22-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)	17:49:37 (23.10.2021)	797:10HRS	LINE CHARGED
841	22-Oct-2021	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA-1	ANCHEPALYA_220	0:10	0:56	0:45	LINE FAULT
842	22-Oct-2021	TUMKUR	110	TR-1	AMMASANDRA_110	13:58	14:19	13:23	LINE CLEAR AVAILED
843	22-Oct-2021	TUMKUR	110	TR-3	AMMASANDRA_110	13:20	13:22	0:02	LINE CLEAR AVAILED
844	22-Oct-2021	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110	7:37	7:57	0:20	LINE FAULT
845	22-Oct-2021	TUMKUR	110	TR-1	SAMPIGE_110	12:15	12:33	0:17	LINE CLEAR AVAILED
846	22-Oct-2021	TUMKUR	110	TR-2	SAMPIGE_110	12:34	12:57	0:22	LINE CLEAR AVAILED
847	22-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVANI_66	0:25	1:00	0:34	HAND TRIPPED
848	22-Oct-2021	TUMKUR	66	ANCHEPALYA 66kV- ANCHEPALYA 1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	0:25	1:08	0:43	HAND TRIPPED
849	22-Oct-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	0:25	0:59	0:34	HAND TRIPPED
850	22-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	0:25	0:59	0:34	HAND TRIPPED
851	22-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	0:25	1:00	0:35	HAND TRIPPED
852	22-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	0:25	1:00	0:34	HAND TRIPPED
853	22-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	0:25	1:00	0:35	HAND TRIPPED
854	22-Oct-2021	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR_66	YEDIYUR_66,THIPPUR_66,JIDDEGERE_6 6	0:25	1:00	0:34	HAND TRIPPED
855	22-Oct-2021	TUMKUR	66	TR-1	BADAVANAHALLI_66	15:32	16:13	0:40	LINE CLEAR AVAILED
856	22-Oct-2021	TUMKUR	66	TR-2	BALENAHALLI_66	10:14	10:26	0:11	TRANSFORMER FAULT
857	22-Oct-2021	TUMKUR	66	TR-2	BELLAVI_66	12:37	14:30	1:52	LINE CLEAR AVAILED
858	22-Oct-2021	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	21:43	21:46	0:02	MAIN SUPPLY FAILURE
859	22-Oct-2021	TUMKUR	66	BHARAMAGIRI66-SRS 220KV HIRIYUR	BHARAMAGIRI_66	0:34	2:44	2:10	LINE FAULT
860	22-Oct-2021	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP_66	GOLDEN HATCHERIES_IPP_66	16:52	16:55	0:02	MAIN SUPPLY FAILURE
861	22-Oct-2021	TUMKUR	66	TR-1	NIDSALE_66	11:37	12:46	1:09	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
862	22-Oct-2021	TUMKUR	66	CHIKKABANAGERE-HARIYABBE	CHIKKABANAGERE_66	15:33	15:48	0:15	LINE CLEAR AVAILED
863	22-Oct-2021	TUMKUR	66	TR-2	NYAMATHI_66	10:58	18:49	7:51	LINE CLEAR AVAILED
864	22-Oct-2021	TUMKUR	66	TR-2	NAYAKANAHATTI_66	10:47	10:54	0:07	TRANSFORMER FAULT
865	23-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN LINE CLEAR AVAILED
866	23-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
867	23-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
868	23-Oct-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
869	23-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
870	23-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN LINE CLEAR AVAILED
871	23-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
872	23-Oct-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN,LINE FAULT
873	23-Oct-2021	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	1:38	8:15	6:37	LINE FAULT
874	23-Oct-2021	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	1:38	8:15	6:37	LINE FAULT
875	23-Oct-2021	BAGALKOT	220	NARENDRA- BELGAUM1	NARENDRA_220	1:38	8:30	6:52	LINE FAULT
876	23-Oct-2021	BAGALKOT	220	NARENDRA- BELGAUM2	NARENDRA_220	1:38	8:30	6:52	LINE FAULT
877	23-Oct-2021	BAGALKOT	220	NARENDRA- HAVERI	NARENDRA_220	1:38	8:16	6:38	LINE FAULT
878	23-Oct-2021	BAGALKOT	220	220/110KV, HV1	NARENDRA_220	1:38	8:32	6:54	TRANSFORMER FAULT
879	23-Oct-2021	BAGALKOT	220	220/110KV, HV2	NARENDRA_220	1:38	8:35	6:57	TRANSFORMER FAULT
880	23-Oct-2021	BAGALKOT	110	NARENDRA220-TADASINKOPPA	TADASINKOPPA_110	1:38	8:36	6:58	LINE FAULT
881	23-Oct-2021	BAGALKOT	110	NARENDRA220-MRUTHYUNJAY NAGAR	MRUTHYUNJAY NAGAR_110	1:38	8:36	6:58	LINE FAULT
882	23-Oct-2021	BAGALKOT	110	NARENDRA220- UAS(KUD1)	UAS DHARWAD_110	1:38	8:44	7:06	LINE FAULT
883	23-Oct-2021	BAGALKOT	110	NARENDRA220- BELUR1	BELUR_110	1:38	2:30	0:52	LINE FAULT
884	23-Oct-2021	BAGALKOT	110	NARENDRA220- BELUR2	BELUR_110	1:38	2:30	0:52	LINE FAULT
885	23-Oct-2021	BAGALKOT	220	AMBEWADI- NAGJHARI1	AMBEWADI_220	10:28	15:43	5:15	LINE CLEAR AVAILED
886	23-Oct-2021	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	AMBEWADI_220	11:23	11:40	0:17	HAND TRIPPED
887	23-Oct-2021	BAGALKOT	220	220/110KV, HV1	AMBEWADI_220	11:23	11:40	0:27	HAND TRIPPED
888	23-Oct-2021	BAGALKOT	220	HUBLI- SIRS12	HUBLI_220	17:49	20:12	1:23	LINE CLEAR AVAILED
889	23-Oct-2021	BAGALKOT	110	NARENDRA2-BELUR	BELUR_110	9:23	9:30	0:07	HAND TRIPPED
890	23-Oct-2021	BAGALKOT	110	110/33KV,HV3	KIADB BIJAPUR_110 &HONNUTAGI,NAGATHAN_33	0:26	4:02	3:36	TRANSFORMER FAULT
891	23-Oct-2021	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	10:05(23.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
892	23-Oct-2021	BAGALKOT	110	UTTUR-YADAWAD	YADAWAD_110	1:39	1:46	0:07	LINE FAULT
893	23-Oct-2021	BAGALKOT	110	110/11KV,HV2	TAKKALAKI_110	12:15	12:20	0:05	TRANSFORMER FAULT
894	23-Oct-2021	BAGALKOT	110	NARENDRA-TADASINAKOPPA	TADASINAKOPPA_110	1:09	9:04	7:55	MAIN SUPPLY FAILURE
895	23-Oct-2021	BAGALKOT	110	SATTI-RABKAVI	RABKAVI_110	9:40	10:45	1:05	LINE CLEAR AVAILED
896	23-Oct-2021	BAGALKOT	110	110/11KV,HV1	NIDGUNDI_110	8:20	8:25	0:05	TRANSFORMER FAULT
897	23-Oct-2021	BAGALKOT	110	NARENDRA 1-MRUTHUNJAY NAGAR	MRUTHUNJAY NAGAR_110	1:35	10:47	9:12	LINE CLEAR AVAILED
898	23-Oct-2021	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	13:10	19:10	6:00	LINE CLEAR AVAILED
899	23-Oct-2021	BAGALKOT	110	NARENDRA-KUD DHARWAD	KUD DHARWAD_110	2:15	9:00	6:45	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
900	23-Oct-2021	BAGALKOT	110	110/11KV,HV1	SHIRAGUPPI_110	11:55	12:35	0:40	LINE CLEAR AVAILED
901	23-Oct-2021	BAGALKOT	110	110/11KV,HV1	GIRISAGAR_110	17:10	18:15	1:05	LINE CLEAR AVAILED
902	23-Oct-2021	BAGALKOT	110	110/11KV,HV1	NAVALAGI_110	1:35	2:15	0:40	TRANSFORMER FAULT
903	23-Oct-2021	BAGALKOT	110	110/11KV,HV2	NAVALAGI_110	1:35	2:15	0:40	TRANSFORMER FAULT
904	23-Oct-2021	BAGALKOT	220	ATHANI-KSSKN	ATHANI_220	23:16	23:38	0:22	LINE FAULT
905	23-Oct-2021	BAGALKOT	220	RANEENNUR-BELLIGAVI	RANEENNUR_220	7:20	13:10	5:50	LINE FAULT
906	23-Oct-2021	BAGALKOT	220	RANEENNUR-BELLIGAVI	RANEENNUR_220	13:10	15:04	1:54	LINE CLEAR AVAILED
907	23-Oct-2021	BAGALKOT	110	INDI-ZALKI2	INDI_220	10:30	10:40	0:10	LINE FAULT
908	23-Oct-2021	BAGALKOT	110	KARWAR-ARGA	KARWAR_220	19:58	22:08	2:10	LINE FAULT
909	23-Oct-2021	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
910	23-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN LINE CLEAR AVAILED
911	23-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN LINE CLEAR AVAILED
912	23-Oct-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	11:02	11:04	0:02	LOAD CHANGE OVER
913	23-Oct-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	15:02	15:09	0:07	LOAD CHANGE OVER
914	23-Oct-2021	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	4:49	4:54	0:05	MAIN SUPPLY FAILURE
915	23-Oct-2021	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	4:49	4:54	0:05	LINE CLEAR AVAILED
916	23-Oct-2021	BENGALURU	66	A STATION 220 - A STATION 66 2	A STATION 66	4:49	4:54	0:05	LINE CLEAR AVAILED
917	23-Oct-2021	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	13:24	13:44	0:20	LINE CLEAR AVAILED
918	23-Oct-2021	BENGALURU	66	HAL 220 - ADUGODI 2	AMARIYOTHI	13:24	13:44	0:20	LINE CLEAR AVAILED
919	23-Oct-2021	BENGALURU	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	10:05	16:40	6:35	LINE CLEAR AVAILED
920	23-Oct-2021	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	10:50	10:55	0:05	LOAD CHANGE OVER
921	23-Oct-2021	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	15:53	15:58	0:05	LOAD CHANGE OVER
922	23-Oct-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HONNIGANAHALLI, ACHALU, HALAGURU, DODDALAHALLI	3:39	4:07	0:28	LINE FAULT
923	23-Oct-2021	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K&C VALLEY	18:05	18:30	0:25	LINE FAULT
924	23-Oct-2021	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	4:49	5:05	0:16	LINE FAULT
925	23-Oct-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	4:49	5:48	0:59	LINE FAULT
926	23-Oct-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	4:49	5:05	0:16	LINE CLEAR AVAILED
927	23-Oct-2021	BENGALURU	66	HV2	SUBRAMANYAPURA 66	14:38	14:54	0:16	TRANSFORMER FAULT
928	23-Oct-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	4:00	4:13	0:13	LINE FAULT
929	23-Oct-2021	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	7:34	7:51	0:17	LINE FAULT
930	23-Oct-2021	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	1:27	1:36	0:09	LINE FAULT
931	23-Oct-2021	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	SRS PEENYA 220	4:49	5:05	0:15	LINE FAULT
932	23-Oct-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	22:13	22:33	0:20	LINE FAULT
933	23-Oct-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	22:13	22:36	0:22	LINE FAULT
934	23-Oct-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	22:19	22:33	0:13	MAIN SUPPLY FAILURE
935	23-Oct-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	0:08	0:24	0:16	LINE FAULT
936	23-Oct-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:00	16:10	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
937	23-Oct-2021	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	5:23	6:06	0:43	LINE FAULT
938	23-Oct-2021	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	6:06	6:17	0:11	LINE FAULT
939	23-Oct-2021	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	17:18	18:00	0:41	LINE FAULT
940	23-Oct-2021	BENGALURU	66	LV1	MALUR 220	22:13	22:33	0:19	TRANSFORMER FAULT
941	23-Oct-2021	BENGALURU	220	HV1	MALUR 220	22:13	22:31	0:17	TRANSFORMER FAULT
942	23-Oct-2021	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	11:25	18:33	7:08	LINE CLEAR AVAILED
943	23-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	0:20	0:40	0:20	LINE FAULT
944	23-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	0:40	1:24	0:44	LINE FAULT
945	23-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	14:45	22:22	7:37	LINE CLEAR AVAILED
946	23-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	15:12	15:45	0:33	LINE FAULT
947	23-Oct-2021	BENGALURU	66	KACHMARANAHALLI - MINOR IRRIGATION	KACHMARANAHALLI	20:01	20:28	0:27	MAIN SUPPLY FAILURE
948	23-Oct-2021	BENGALURU	66	KACHMARANAHALLI - MINOR IRRIGATION	KACHMARANAHALLI	22:01	22:38	0:37	MAIN SUPPLY FAILURE
949	23-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	16:05	17:15	1:10	LINE FAULT
950	23-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	23:28(22-10-21)	7:05(23-10-21)	7:36HRS	LINE CHARGED
951	23-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	22:05(23-10-21)			MAIN SUPPLY FAILURE
952	23-Oct-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	23:50(22-10-2021)	0:10(23-10-2021)	0:19HRS	LINE CHARGED
953	23-Oct-2021	BENGALURU	220	HV2	KIADB DB PURA 220	22:13(23-10-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
954	23-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	1:47(23.10.2021)			LINE OPEN LINE CLEAR AVAILED
955	23-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
956	23-Oct-2021	GULBARGA	220	HV2, LV2	HALBARGA_220	8:08	8:22	0:14	TRANSFORMER FAULT
957	23-Oct-2021	GULBARGA	220	HV1, HV2	ALIPUR_220	8:44	12:50	4:06	LINE CLEAR AVAILED
958	23-Oct-2021	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	12:49	18:33	5:44	LINE FAULT
959	23-Oct-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	1:52	6:06	4:14	LINE FAULT
960	23-Oct-2021	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	21:40	22:10	0:30	LINE FAULT
961	23-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110, KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN LINE CLEAR AVAILED
962	23-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN LINE CLEAR AVAILED
963	23-Oct-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1(IDLE LINE)	SHAHAPUR_110	13:00(08.10.2021)	13:30(23.10.2021)	360:30HRS	LINE CHARGED
964	23-Oct-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110, MADLAPUR_110, MA NVI_110	21:20	21:24	0:04	LINE FAULT
965	23-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110, VALKAMDINNI_110	22:22	22:37	0:15	LINE FAULT
966	23-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110, YERDONA_110, SRNAGAR_110, MALLAPURA_110	20:55	21:05	0:10	LINE FAULT
967	23-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110, YERDONA_110, SRNAGAR_110, MALLAPURA_110	23:46	23:56	0:10	LINE FAULT
968	23-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110, SR NAGAR_110	11:49	11:59	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
969	23-Oct-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,VALAKAMDINNI_110	0:20	0:30	0:10	LINE FAULT
970	23-Oct-2021	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110,KUKUNOOR_110	16:26 (23.10.2021)			LINE OPEN,LINE FAULT
971	23-Oct-2021	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKGIRI_110,GANADAL_110,NAVLI_110	17:17	18:25	1:08	LINE FAULT
972	23-Oct-2021	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110, KONKAL_110	5:02	5:07	0:05	LINE FAULT
973	23-Oct-2021	GULBARGA	110	NIRNA-CHITGUPPA	NIRNA_110	12:50	13:00	0:10	MAIN SUPPLY FAILURE
974	23-Oct-2021	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	8:21	12:51	4:30	MAIN SUPPLY FAILURE
975	23-Oct-2021	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	13:25	13:47	0:22	MAIN SUPPLY FAILURE
976	23-Oct-2021	GULBARGA	110	PDHALLI-JANAKISTEELS_IPP	PD_HALLI_110	13:47	18:25	4:38	LINE CLEAR AVAILED
977	23-Oct-2021	GULBARGA	110	PDHALLI-CLEANSOLAR_IPP	PD_HALLI_110	13:47	16:10	2:23	LINE CLEAR AVAILED
978	23-Oct-2021	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	15:38	15:51	0:13	MAIN SUPPLY FAILURE
979	23-Oct-2021	GULBARGA	110	PDHALLI-CLEANSOLAR_IPP	PD_HALLI_110	16:25	16:30	0:05	LINE CLEAR AVAILED
980	23-Oct-2021	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	23:09	23:52	0:43	MAIN SUPPLY FAILURE
981	23-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	3:40	3:45	0:05	MAIN SUPPLY FAILURE
982	23-Oct-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	23:30	23:45	0:15	MAIN SUPPLY FAILURE
983	23-Oct-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	20:58	21:05	0:07	MAIN SUPPLY FAILURE
984	23-Oct-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	23:45	23:55	0:10	MAIN SUPPLY FAILURE
985	23-Oct-2021	GULBARGA	110	NALWAR-CLEANSOLAR_IPP	NALWAR_110	4:40	4:50	0:10	LINE FAULT
986	23-Oct-2021	GULBARGA	110	NALWAR-CLEANSOLAR_IPP	NALWAR_110	6:05	6:20	0:15	LINE FAULT
987	23-Oct-2021	GULBARGA	110	HV3	VALKAMDINNI_110	9:35	9:39	0:04	TRANSFORMER FAULT
988	23-Oct-2021	GULBARGA	110	HV3	VALKAMDINNI_110	19:21	19:35	0:14	TRANSFORMER FAULT
989	23-Oct-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	1:01	1:21	0:20	LINE FAULT
990	23-Oct-2021	GULBARGA	110	HV1	SIRIGERICROSS_110	11:19	11:29	0:10	TRANSFORMER FAULT
991	23-Oct-2021	GULBARGA	110	HV2	SIRIGERICROSS_110	19:17	19:27	0:10	TRANSFORMER FAULT
992	23-Oct-2021	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	10:00	10:25	0:25	MAIN SUPPLY FAILURE
993	23-Oct-2021	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	14:40	14:50	0:10	MAIN SUPPLY FAILURE
994	23-Oct-2021	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	21:09	21:15	0:06	LINE FAULT
995	23-Oct-2021	GULBARGA	110	KANAKAGIRI-KUSHTAGI	KANAKAGIRI_110	17:20	18:25	1:05	MAIN SUPPLY FAILURE
996	23-Oct-2021	GULBARGA	110	NALWAR-CLEANSOLAR_IPP	NALWAR_110	4:40	4:50	0:10	LINE FAULT
997	23-Oct-2021	GULBARGA	110	NALWAR-CLEANSOLAR_IPP	NALWAR_110	6:05	6:20	0:15	MAIN SUPPLY FAILURE
998	23-Oct-2021	GULBARGA	110	MALLAT-BYGWAT	BYGWAT_110	22:31	22:37	0:06	MAIN SUPPLY FAILURE
999	23-Oct-2021	GULBARGA	110	HV3	BISILAHALLI_110	7:25	7:35	0:10	TRANSFORMER FAULT
1000	23-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	8:19	12:50	4:31	MAIN SUPPLY FAILURE
1001	23-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	13:25	13:47	0:22	MAIN SUPPLY FAILURE
1002	23-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	15:38	15:50	0:12	MAIN SUPPLY FAILURE
1003	23-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	23:08	23:50	0:42	MAIN SUPPLY FAILURE
1004	23-Oct-2021	GULBARGA	66	TAMBRAHALLI-ITTAGI	TAMBRAHALLI_66	12:15	12:35	0:20	MAIN SUPPLY FAILURE
1005	23-Oct-2021	GULBARGA	66	NEELGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHINGIDURGA_66	23:40	23:50	0:10	LINE FAULT
1006	23-Oct-2021	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	17:55	18:00	0:05	LINE FAULT
1007	23-Oct-2021	GULBARGA	66	MUNIRABAD-MSDLNE(IDLE LINE)	HANSI_66	17:40	20:50	3:10	LINE FAULT
1008	23-Oct-2021	GULBARGA	66	HANASI-BADALADUKU	HANASI_66	14:45	14:55	0:10	MAIN SUPPLY FAILURE
1009	23-Oct-2021	GULBARGA	66	HV1	GUDEKOTE_66	14:15	14:35	0:20	LINE CLEAR AVAILED
1010	23-Oct-2021	GULBARGA	66	HV1	GUDEKOTE_66	6:15	6:30	0:15	LINE CLEAR AVAILED
1011	23-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1012	23-Oct-2021	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	9:31(18.10.2021)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1013	23-Oct-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	19:43(21.10.2021)			LINE OPEN,LINE FAULT
1014	23-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN,LINE FAULT
1015	23-Oct-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	22:30(21.10.2021)			LINE OPEN,LINE FAULT
1016	23-Oct-2021	HASSAN	220	VARAH1-KEMAR1	varahi_gen	21:11(22.10.2021)			LINE OPEN,LINE FAULT
1017	23-Oct-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	23:32(21.10.2021)			LINE OPEN,LINE FAULT
1018	23-Oct-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	10:18(22.10.2021)			LINE OPEN LINE CLEAR AVAILED
1019	23-Oct-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	17:32(23.10.2021)			LINE OPEN,LINE FAULT
1020	23-Oct-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	21:10(22.10.2021)	11:57(23.10.2021)	38:47HRS	LINE CHARGED
1021	23-Oct-2021	HASSAN	220	HASSN22-PGCL	HASSAN_220	10:58	15:13	4:15	LINE CLEAR AVAILED
1022	23-Oct-2021	HASSAN	220	HV1	ARASIKERE_220	22:20	22:47	0:27	TRANSFORMER FAULT
1023	23-Oct-2021	HASSAN	110	LV1	ARASIKERE_220	22:20	22:47	0:27	TRANSFORMER FAULT
1024	23-Oct-2021	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	5:22	6:03	0:41	LINE FAULT
1025	23-Oct-2021	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	13:50	14:21	0:31	LINE FAULT
1026	23-Oct-2021	HASSAN	220	KADUR-DABUSET	KADUR_220	5:22	6:20	0:58	LINE FAULT
1027	23-Oct-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:58	17:31	5:33	LINE FAULT
1028	23-Oct-2021	HASSAN	220	MRSSHM-ARSIKRE	MRSMSG_220	5:22	6:03	0:41	LINE FAULT
1029	23-Oct-2021	HASSAN	220	MRSSHM-ARSIKRE	MRSMSG_220	13:50	14:18	0:28	LINE FAULT
1030	23-Oct-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	0:38	12:48	12:10	LINE FAULT
1031	23-Oct-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	8:12	9:12	1:00	LINE FAULT
1032	23-Oct-2021	HASSAN	110	JOG-JLT3	mghejog_gen	20:12	20:37	0:25	HAND TRIPPED
1033	23-Oct-2021	HASSAN	110	JOG-JLT4	mghejog_gen	20:12	20:53	0:41	HAND TRIPPED
1034	23-Oct-2021	HASSAN	110	JOG-JST1	mghejog_gen	20:12	20:33	0:21	HAND TRIPPED
1035	23-Oct-2021	HASSAN	110	JOG-JST2	mghejog_gen	11:39	12:15	0:36	LINE FAULT
1036	23-Oct-2021	HASSAN	110	JOG-JST2	mghejog_gen	20:12	20:33	0:21	HAND TRIPPED
1037	23-Oct-2021	HASSAN	110	JOG-NK2	mghejog_gen	20:12	20:35	0:23	HAND TRIPPED
1038	23-Oct-2021	HASSAN	110	JOG110-MGHE	JOG_110	11:40	12:45	1:05	LINE FAULT
1039	23-Oct-2021	HASSAN	110	HV1	KADUR_220	19:00	19:34	0:34	TRANSFORMER FAULT
1040	23-Oct-2021	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	8:13	9:14	1:01	MAIN SUPPLY FAILURE
1041	23-Oct-2021	HASSAN	110	HV5	MRSMSG_22-	10:00	13:12	3:12	LINE CLEAR AVAILED
1042	23-Oct-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	11:35	12:15	0:40	LINE FAULT
1043	23-Oct-2021	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	14:41	15:00	0:19	LINE FAULT
1044	23-Oct-2021	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	15:20	16:43	1:23	LINE FAULT
1045	23-Oct-2021	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	19:31	20:03	0:32	LINE FAULT
1046	23-Oct-2021	HASSAN	66	HV2	ARAKALGUD_66	2:15	11:45	9:30	TRANSFORMER FAULT
1047	23-Oct-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	0:19	0:28	0:09	LINE FAULT
1048	23-Oct-2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	9:37	9:43	0:06	LINE FAULT
1049	23-Oct-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	18:10	18:26	0:16	LINE FAULT
1050	23-Oct-2021	MYSURU	66	HV2	BOOKANAKERE_66	13:37	13:59	22:44	LINE CLEAR AVAILED
1051	23-Oct-2021	MYSURU	66	ELWALA-HOOTAGALLI	NO STATIONS EFFECTED	6:44	7:08	0:23	LINE FAULT
1052	23-Oct-2021	MYSURU	66	HANNUR-AJJIPURA	AJJIPURA_66 COWDALLI_66 BANDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	7:31	7:36	0:04	LINE FAULT
1053	23-Oct-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	20:34	21:31	0:56	LINE FAULT
1054	23-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	2:53	18:49	15:56	LINE FAULT
1055	23-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	10:08	12:26	2:18	LINE CLEAR AVAILED
1056	23-Oct-2021	MYSURU	66	KUNTHUR-MADHUVANAHALLI	NO STATIONS EFFECTED	7:29	7:34	0:05	LINE FAULT
1057	23-Oct-2021	MYSURU	66	HV1	MADDUR_66	11:03	11:45	0:41	HAND TRIPPED
1058	23-Oct-2021	MYSURU	66	HV1	MADDUR_66	16:39	16:59	0:20	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1059	23-Oct-2021	MYSURU	66	MEGALAPURA-HEBBANI	NO STATIONS EFFECTED	20:55	21:13	0:17	LINE FAULT
1060	23-Oct-2021	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	20:55	21:00	0:05	LINE FAULT
1061	23-Oct-2021	MYSURU	66	HV2	THALAKADU_66	20:31	21:16	0:45	TRANSFORMER FAULT
1062	23-Oct-2021	MYSURU	66	TUBINKERE-G UKKADA	G UKKADA_66 SRIRANGAPATNA_66	16:45	16:46	0:01	HAND TRIPPED
1063	23-Oct-2021	MYSURU	220	HV1	TUBINAKERE_220	12:53	15:27	2:34	LINE CLEAR AVAILED
1064	23-Oct-2021	MYSURU	66	HV1	TUBINAKERE_66	16:40	16:46	0:06	HAND TRIPPED
1065	23-Oct-2021	MYSURU	66	HV2	TUBINAKERE_66	16:41	16:46	0:05	HAND TRIPPED
1066	23-Oct-2021	MYSURU	66	TUBINKERE-MANDYA 2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 KESLAGERE_66 BASARALU_66 BESAGARAHALLI_66 KADKOTHANAHALLI_66	16:45	16:46	0:01	HAND TRIPPED
1067	23-Oct-2021	MYSURU	66	TUBINKERE-MANDYA 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 KESLAGERE_66 BASARALU_66 BESAGARAHALLI_66 KADKOTHANAHALLI_66	16:45	16:47	0:01	HAND TRIPPED
1068	23-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	17:12	17:13	0:01	HAND TRIPPED
1069	23-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	17:12	17:13	0:01	HAND TRIPPED
1070	23-Oct-2021	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66	17:12	17:13	0:01	HAND TRIPPED
1071	23-Oct-2021	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66	6:15	6:38	0:23	LINE FAULT
1072	23-Oct-2021	MYSURU	66	HV1	YETHAMBADI_66	5:15	7:20	2:04	TRANSFORMER FAULT
1073	23-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	19:13:28			LINE OPEN LINE CLEAR AVAILED
1074	23-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN LINE CLEAR AVAILED
1075	23-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN LINE CLEAR AVAILED
1076	23-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06 (20.09.2021)			LINE OPEN LINE CLEAR AVAILED
1077	23-Oct-2021	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	0:38	12:47	12:08	LINE FAULT
1078	23-Oct-2021	TUMKUR	66	TR-2	ANTHARASANAHALLI_220	10:09	18:56	8:47	LINE CLEAR AVAILED
1079	23-Oct-2021	TUMKUR	66	BALENAHALLI-CHALKERE66	BALENAHALLI_66	18:44	18:57	0:12	HAND TRIPPED
1080	23-Oct-2021	TUMKUR	66	BHARAMAGIRI66-MATHOD66	BHARAMAGIRI_66	7:03	7:14	0:10	LINE FAULT
1081	23-Oct-2021	TUMKUR	66	DAVANGERE SRS-CHITRADURGA1	CHITRADURGA_220	13:17	13:59	0:41	LINE FAULT
1082	23-Oct-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:47	5:49	0:02	LINE FAULT
1083	23-Oct-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	1:51	2:10	0:19	TRANSFORMER FAULT
1084	23-Oct-2021	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	8:10	18:30	10:20	LINE CLEAR AVAILED
1085	23-Oct-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	9:35	9:44	0:09	LINE FAULT
1086	23-Oct-2021	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	13:16	13:28	0:12	TRANSFORMER FAULT
1087	23-Oct-2021	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	23:18	23:27	0:08	TRANSFORMER FAULT
1088	23-Oct-2021	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	15:02	15:32	0:29	LINE FAULT
1089	23-Oct-2021	TUMKUR	66	TR-2	NYAMATHI_66	16:02	17:29	1:27	LINE CLEAR AVAILED
1090	24-Oct-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1091	24-Oct-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
1092	24-Oct-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN LINE CLEAR AVAILED
1093	24-Oct-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
1094	24-Oct-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
1095	24-Oct-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN LINE CLEAR AVAILED
1096	24-Oct-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1097	24-Oct-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN,LINE FAULT
1098	24-Oct-2021	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	10:05 (23.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1099	24-Oct-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	11:57	13:47	1:50	LINE FAULT
1100	24-Oct-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	8:30	8:45	0:15	HAND TRIPPED
1101	24-Oct-2021	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	6:40	6:56	0:16	LINE FAULT
1102	24-Oct-2021	BAGALKOT	110	110/11KV,HV1	TIKOTA_110	11:07	11:15	0:08	TRANSFORMER FAULT
1103	24-Oct-2021	BAGALKOT	110	JOG 2-SIRSI	SIRSI_110	21:35 (24.10.2021)			LINE OPEN,LINE FAULT
1104	24-Oct-2021	BAGALKOT	110	110/33KV,HV1	MUNAVALLI_110 & MUNAVALLI &HOOLIKATTI_33	15:30	16:00	0:30	TRANSFORMER FAULT
1105	24-Oct-2021	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110	15:30	16:30	1:00	TRANSFORMER FAULT
1106	24-Oct-2021	BAGALKOT	110	110/33KV,HV1	MATTIHAL_110	0:30	0:35	0:05	TRANSFORMER FAULT
1107	24-Oct-2021	BAGALKOT	220	RANEBENNUR-BELLIGAVI	RANEBENNUR_220	11:07	15:19	4:12	MAIN SUPPLY FAILURE
1108	24-Oct-2021	BAGALKOT	110	MAREGUDDI-MUNDAGANUR	MUNDAGANUR_110	6:20	6:38	0:18	LINE FAULT
1109	24-Oct-2021	BAGALKOT	220	ATHANI-KSSKN	ATHANI_220	0:26	0:45	0:19	LINE FAULT
1110	24-Oct-2021	BAGALKOT	110	110/11KV,HV1	MUNAVALLI_110	15:30	16:00	0:30	TRANSFORMER FAULT
1111	24-Oct-2021	BAGALKOT	110	110/33KV,HV2	MUNAVALLI_110	15:30	16:30	1:00	TRANSFORMER FAULT
1112	24-Oct-2021	BAGALKOT	110	110/11KV,HV4	KERUR_110	9:58	11:28	1:30	LINE CLEAR AVAILED
1113	24-Oct-2021	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED CHIKKODI_110 , KHAROSHI_33 & KERUR_33	21:32 (28.09.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1114	24-Oct-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	17:40 (04.10.2021)			LINE OPEN LINE CLEAR AVAILED
1115	24-Oct-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN LINE CLEAR AVAILED
1116	24-Oct-2021	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	8:27	8:56	0:29	MAIN SUPPLY FAILURE
1117	24-Oct-2021	BENGALURU	66	HV1	BANASAWADI	8:27	8:35	0:08	MAIN SUPPLY FAILURE
1118	24-Oct-2021	BENGALURU	66	HV3	BANASAWADI	8:27	8:35	0:08	MAIN SUPPLY FAILURE
1119	24-Oct-2021	BENGALURU	66	HV1	BANASAWADI	9:25	9:28	0:03	LOAD CHANGE OVER
1120	24-Oct-2021	BENGALURU	66	HV3	BANASAWADI	9:25	9:28	0:03	LOAD CHANGE OVER
1121	24-Oct-2021	BENGALURU	66	C STATION - HEBBALA 220	C STATION	8:27	8:43	0:16	MAIN SUPPLY FAILURE
1122	24-Oct-2021	BENGALURU	66	C STATION - A STATION 220	C STATION	16:11	16:13	0:02	LOAD CHANGE OVER
1123	24-Oct-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	11:16	11:19	0:03	LOAD CHANGE OVER
1124	24-Oct-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	12:02	12:05	0:03	LOAD CHANGE OVER
1125	24-Oct-2021	BENGALURU	66	IISc - HEBBALA 220	IISc	8:27	8:38	0:11	MAIN SUPPLY FAILURE
1126	24-Oct-2021	BENGALURU	66	IISc - NRS 220	IISc	16:51	16:54	0:03	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1127	24-Oct-2021	BENGALURU	220	MANYATHA TECH PARK 220 - HEBBALA 220	HEBBALA 220	8:27	8:48	0:21	LINE FAULT
1128	24-Oct-2021	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 1	MANYATHA 66	8:27	8:48	0:21	LINE CLEAR AVAILED
1129	24-Oct-2021	BENGALURU	220	NAGANATHPURA 220 - SOMANAHALLI 220	NAGANATHPURA 220	0:44	1:45	1:01	LINE FAULT
1130	24-Oct-2021	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	0:44	1:49	1:05	LINE CLEAR AVAILED
1131	24-Oct-2021	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	0:44	1:52	1:08	LINE CLEAR AVAILED
1132	24-Oct-2021	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY	ELECTRONIC CITY, INFOSYS(EHT)	0:44	1:49	1:05	LINE CLEAR AVAILED
1133	24-Oct-2021	BENGALURU	66	NGEF - ITI 220	NGEF, NGEF(EHT)	10:00	17:25	7:25	LINE CLEAR AVAILED
1134	24-Oct-2021	BENGALURU	66	SOMANAHALLI 220 - BG ROAD	BG ROAD	6:26	6:46	0:20	LINE FAULT
1135	24-Oct-2021	BENGALURU	220	SOMANAHALLI 220 - NAGANATHPURA 220	NAGANATHPURA 220	0:44	1:45	1:01	LINE FAULT
1136	24-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:56	15:00	2:04	LINE FAULT
1137	24-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:00	15:59	0:59	LINE CLEAR AVAILED
1138	24-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	15:02	16:05	1:03	LINE CLEAR AVAILED
1139	24-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	15:06	16:03	0:57	LINE CLEAR AVAILED
1140	24-Oct-2021	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	15:09	16:01	0:52	LINE CLEAR AVAILED
1141	24-Oct-2021	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	8:27	8:34	0:07	MAIN SUPPLY FAILURE
1142	24-Oct-2021	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	9:03	9:07	0:04	LOAD CHANGE OVER
1143	24-Oct-2021	BENGALURU	220	HV1	MITTEMARI 220	0:12	0:16	0:04	TRANSFORMER FAULT
1144	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	0:12	0:16	0:04	MAIN SUPPLY FAILURE
1145	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	0:12	0:16	0:04	MAIN SUPPLY FAILURE
1146	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	0:12	0:17	0:05	MAIN SUPPLY FAILURE
1147	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	0:12	0:16	0:04	MAIN SUPPLY FAILURE
1148	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	0:12	0:16	0:04	MAIN SUPPLY FAILURE
1149	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	0:12	0:16	0:04	MAIN SUPPLY FAILURE
1150	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	0:12	0:17	0:05	MAIN SUPPLY FAILURE
1151	24-Oct-2021	BENGALURU	66	HV1	MITTEMARI 220	0:12	0:52	0:40	MAIN SUPPLY FAILURE
1152	24-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	1:49	9:20	7:31	LINE FAULT
1153	24-Oct-2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	1:49	9:20	7:31	LINE FAULT
1154	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	1:49	2:44	0:55	MAIN SUPPLY FAILURE
1155	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	1:49	2:44	0:55	MAIN SUPPLY FAILURE
1156	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	1:49	2:44	0:55	MAIN SUPPLY FAILURE
1157	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	1:49	2:44	0:55	MAIN SUPPLY FAILURE
1158	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	1:49	2:43	0:54	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1159	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	1:49	2:42	0:53	MAIN SUPPLY FAILURE
1160	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	1:49	2:43	0:54	MAIN SUPPLY FAILURE
1161	24-Oct-2021	BENGALURU	66	HV1	MITTEMARI 220	1:49	2:43	0:54	MAIN SUPPLY FAILURE
1162	24-Oct-2021	BENGALURU	66	VATADOSANAHALLI - MITTEMARI 220	MITTEMARI 220	6:27	6:48	0:21	MAIN SUPPLY FAILURE
1163	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	6:27	6:48	0:21	MAIN SUPPLY FAILURE
1164	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	6:27	6:48	0:21	MAIN SUPPLY FAILURE
1165	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	6:27	6:48	0:21	MAIN SUPPLY FAILURE
1166	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	6:27	6:48	0:21	MAIN SUPPLY FAILURE
1167	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	6:27	6:48	0:21	MAIN SUPPLY FAILURE
1168	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	6:27	6:48	0:21	MAIN SUPPLY FAILURE
1169	24-Oct-2021	BENGALURU	66	HV1	MITTEMARI 220	6:27	6:48	0:21	MAIN SUPPLY FAILURE
1170	24-Oct-2021	BENGALURU	220	HV1	MITTEMARI 220	1:49	9:10	7:21	MAIN SUPPLY FAILURE
1171	24-Oct-2021	BENGALURU	220	HV2	MITTEMARI 220	1:49	9:10	7:21	MAIN SUPPLY FAILURE
1172	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	9:10	9:18	0:08	LINE CLEAR AVAILED
1173	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	9:10	9:17	0:07	LINE CLEAR AVAILED
1174	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	9:10	9:17	0:07	LINE CLEAR AVAILED
1175	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	9:10	9:18	0:08	LINE CLEAR AVAILED
1176	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	9:10	9:17	0:07	LINE CLEAR AVAILED
1177	24-Oct-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	9:10	9:22	0:12	LINE CLEAR AVAILED
1178	24-Oct-2021	BENGALURU	66	HV1	MITTEMARI 220	9:10	9:18	0:08	LINE CLEAR AVAILED
1179	24-Oct-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	1:34	2:46	1:12	LINE FAULT
1180	24-Oct-2021	BENGALURU	220	NELMANGALA 400 - MAGADI 220	MAGADI 220, ANCHEPALYA 220	0:22	0:57	0:34	LINE FAULT
1181	24-Oct-2021	BENGALURU	66	VIDYANAGAR - BEGUR 220	VIDYANAGAR, HENNUR CROSS	11:18	12:01	0:43	LINE CLEAR AVAILED
1182	24-Oct-2021	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	11:17	12:01	0:43	LINE CLEAR AVAILED
1183	24-Oct-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	8:35	9:12	0:36	LINE FAULT
1184	24-Oct-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	7:40	8:01	0:21	LINE FAULT
1185	24-Oct-2021	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	23:12	23:31	0:18	LINE FAULT
1186	24-Oct-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	17:48	17:56	0:07	LINE FAULT
1187	24-Oct-2021	BENGALURU	66	HV2	THIMMAMPALLI	0:01	0:04	0:02	TRANSFORMER FAULT
1188	24-Oct-2021	BENGALURU	66	HV1	DODDABELAVANGALA	0:20	0:38	0:17	TRANSFORMER FAULT
1189	24-Oct-2021	BENGALURU	66	KACHMARANAHALLI - MINOR IRRIGATION	KACHMARANAHALLI	12:05	12:10	0:05	LOAD CHANGE OVER
1190	24-Oct-2021	BENGALURU	66	KACHMARANAHALLI - DOMMASANDRA	KACHMARANAHALLI	15:50	15:52	0:02	LOAD CHANGE OVER
1191	24-Oct-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSANAHALLI	6:26	6:49	0:23	LINE FAULT
1192	24-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 1	NO STATION AFFECTED	1:50	7:25	5:35	MAIN SUPPLY FAILURE



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1193	24-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2	RAILWAYS	1:50	7:25	5:35	MAIN SUPPLY FAILURE
1194	24-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	22:05(23-10-21)	9:08(24-10-2021)	11:02HRS	LINE CHARGED
1195	24-Oct-2021	BENGALURU	220	HV2	KIADB DB PURA 220	22:13(23-10-2021)	1:02(24-10-2021)	2:48HRS	TRANSFORMER CHARGED
1196	24-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE2	NO STATION AFFECTED	8:10:36(24-10-2021)			LINE OPEN,LINE FAULT
1197	24-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	22:05(23-10-21)			MAIN SUPPLY FAILURE
1198	24-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	1:47(23.10.2021)			LINE OPEN LINE CLEAR AVAILED
1199	24-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1200	24-Oct-2021	GULBARGA	220	HV1	ALIPUR_220	6:24	7:52	1:28	TRANSFORMER FAULT
1201	24-Oct-2021	GULBARGA	220	HV2	ALIPUR_220	6:24	12:18	5:54	TRANSFORMER FAULT
1202	24-Oct-2021	GULBARGA	220	HV1	ALIPUR_220	12:03	12:18	0:15	LINE CLEAR AVAILED
1203	24-Oct-2021	GULBARGA	220	ALIPUR-RAGALPADU	ALIPUR_220	7:52	12:17	4:25	LINE FAULT
1204	24-Oct-2021	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	7:52	12:09	4:17	LINE FAULT
1205	24-Oct-2021	GULBARGA	220	BTPSG-ALIPUR	ALIPUR_220	12:09	12:14	0:05	LINE FAULT
1206	24-Oct-2021	GULBARGA	220	NEELGUNDA-ANANTHANAHALLI IPP	NEELGUNDA_220	11:12	18:04	6:52	LINE CLEAR AVAILED
1207	24-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN LINE CLEAR AVAILED
1208	24-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN LINE CLEAR AVAILED
1209	24-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	12:20	12:25	0:05	LINE CLEAR AVAILED
1210	24-Oct-2021	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110,KUKUNOOR_110	16:26 (23.10.2021)	1:15 (24.10.2021)	8:49 HRS	LINE CHARGED
1211	24-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	21:20	22:30	1:10	LINE CLEAR AVAILED
1212	24-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	0:47	0:55	0:08	LINE FAULT
1213	24-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	2:22	2:31	0:09	LINE FAULT
1214	24-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	21:13	21:24	0:11	LINE FAULT
1215	24-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	22:58(24.05.2021)			LINE OPEN,LINE FAULT
1216	24-Oct-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	6:06	6:12	0:06	LINE FAULT
1217	24-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	12:10	12:20	0:10	LINE FAULT
1218	24-Oct-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	13:25	13:35	0:10	LINE FAULT
1219	24-Oct-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	5:47	5:55	0:08	LINE FAULT
1220	24-Oct-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	6:06	6:12	0:06	LINE FAULT
1221	24-Oct-2021	GULBARGA	110	SEDAM-VICAT SAGAR	SEDAM_220	20:30	20:45	0:15	LINE FAULT
1222	24-Oct-2021	GULBARGA	110	HV2	NIRNA_110	9:00	9:05	0:05	TRANSFORMER FAULT
1223	24-Oct-2021	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	12:22	12:27	0:05	LINE FAULT
1224	24-Oct-2021	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_110	6:20	12:40	6:20	MAIN SUPPLY FAILURE
1225	24-Oct-2021	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_110	14:54	14:56	0:02	LINE FAULT
1226	24-Oct-2021	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_110	19:00	19:05	0:05	LINE FAULT
1227	24-Oct-2021	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_110	21:50	22:05	0:15	LINE FAULT
1228	24-Oct-2021	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	6:22	8:02	1:40	MAIN SUPPLY FAILURE
1229	24-Oct-2021	GULBARGA	110	PDHALLI-BASAISTEELS_IPP	PD_HALLI_110	8:02	8:50	0:48	LINE CLEAR AVAILED
1230	24-Oct-2021	GULBARGA	110	PDHALLI-BASAISTEELS_IPP	PD_HALLI_110	10:34	10:41	0:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1231	24-Oct-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	12:10	12:20	0:10	MAIN SUPPLY FAILURE
1232	24-Oct-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	13:25	13:35	0:10	MAIN SUPPLY FAILURE
1233	24-Oct-2021	GULBARGA	110	HV4	YELBURGA_110	2:19	2:34	0:15	TRANSFORMER FAULT
1234	24-Oct-2021	GULBARGA	110	HV4	YELBURGA_110	2:59	3:16	0:17	TRANSFORMER FAULT
1235	24-Oct-2021	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	6:10	8:12	2:02	MAIN SUPPLY FAILURE
1236	24-Oct-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	12:25	12:30	0:05	MAIN SUPPLY FAILURE
1237	24-Oct-2021	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	13:25	13:35	0:10	MAIN SUPPLY FAILURE
1238	24-Oct-2021	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	3:00	3:07	0:07	LINE FAULT
1239	24-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	6:21	8:03	1:42	MAIN SUPPLY FAILURE
1240	24-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	12:03	12:19	0:16	MAIN SUPPLY FAILURE
1241	24-Oct-2021	GULBARGA	66	HV1	HARAPANAHALLI_66	2:55	3:55	1:00	TRANSFORMER FAULT
1242	24-Oct-2021	GULBARGA	66	HV2	HALAVAGALU_66	10:25	10:50	0:25	LINE CLEAR AVAILED
1243	24-Oct-2021	GULBARGA	66	KUDLIGI-KUDLIGI_66	KUDLIGI_66, HANSI_66	16:20	17:00	0:40	LINE FAULT
1244	24-Oct-2021	GULBARGA	66	NEELGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHINGIDURGA_66	4:08	4:17	0:09	LINE FAULT
1245	24-Oct-2021	GULBARGA	66	NEELGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHINGIDURGA_66	5:45	5:51	0:06	LINE FAULT
1246	24-Oct-2021	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKANAHALLI_66,HAGARIBOMMANAHALLI_66,RR STEELS IPP	17:35	17:43	0:08	LINE FAULT
1247	24-Oct-2021	GULBARGA	66	HANASI-BADALADAKU	HANASI_66	16:20	17:00	0:40	MAIN SUPPLY FAILURE
1248	24-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1249	24-Oct-2021	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	9:31(18.10.2021)			LINE OPEN,LINE FAULT
1250	24-Oct-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	19:43(21.10.2021)			LINE OPEN,LINE FAULT
1251	24-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN,LINE FAULT
1252	24-Oct-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	22:30(21.10.2021)			LINE OPEN,LINE FAULT
1253	24-Oct-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	23:32(21.10.2021)			LINE OPEN,LINE FAULT
1254	24-Oct-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	10:18(22.10.2021)			LINE OPEN LINE CLEAR AVAILED
1255	24-Oct-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	22:04(24.10.2021)			LINE OPEN,LINE FAULT
1256	24-Oct-2021	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	22:04(24.10.2021)			LINE OPEN,LINE FAULT
1257	24-Oct-2021	HASSAN	110	JOG-NK2	mghejog_gen	21:34(24.10.2021)			LINE OPEN,LINE FAULT
1258	24-Oct-2021	HASSAN	110	HV1	TOGARSI_110	21:10(24.10.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1259	24-Oct-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	17:32(23.10.2021)	13:43(24.10.2021)	20:11HRS	LINE CHARGED
1260	24-Oct-2021	HASSAN	220	VARAH1-KEMAR1	varahi_gen	21:10(22.10.2021)	13:43(24.10.2021)	40:33HRS	LINE CHARGED
1261	24-Oct-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	7:59	15:48	7:49	LINE CLEAR AVAILED
1262	24-Oct-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	16:13	16:52	0:39	LINE FAULT
1263	24-Oct-2021	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	16:14	16:52	0:38	LINE FAULT
1264	24-Oct-2021	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	11:58	13:47	1:49	LINE FAULT
1265	24-Oct-2021	HASSAN	110	HV2	ANAVATTI_110	16:05	16:43	0:38	TRANSFORMER FAULT
1266	24-Oct-2021	HASSAN	110	HV2	BARANGI_110	15:33	17:06	1:33	LINE CLEAR AVAILED
1267	24-Oct-2021	HASSAN	110	JOG-JST1	mghejog_gen	22:10	22:33	0:23	LINE FAULT
1268	24-Oct-2021	HASSAN	110	JOG-JST2	mghejog_gen	22:10	22:33	0:23	LINE FAULT
1269	24-Oct-2021	HASSAN	110	HV2	KADUR_220	8:20	10:35	2:15	TRANSFORMER FAULT
1270	24-Oct-2021	HASSAN	110	LPH-LST4	lph_gen	22:10	22:33	0:23	LINE FAULT
1271	24-Oct-2021	HASSAN	110	HV2	SHIKARIPURA_110	15:34	16:26	0:52	LINE CLEAR AVAILED
1272	24-Oct-2021	HASSAN	66	HV1	BASAVAGHATTA_66	6:12	6:31	0:19	TRANSFORMER FAULT
1273	24-Oct-2021	MYSURU	66	HV2	AKKIHEBBAL_66	6:13	6:25	22:44	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1274	24-Oct-2021	MYSURU	66	CR NAGARA-YALANDUR	NO STATIONS EFFECTED	9:40	9:47	0:06	LINE FAULT
1275	24-Oct-2021	MYSURU	220	HOOTAGALLI-BASTIPURA-2	NO STATIONS EFFECTED	9:34	14:47	5:13	LINE CLEAR AVAILED
1276	24-Oct-2021	MYSURU	66	HANNUR-MADHUVANAHALLI-2	NO STATIONS EFFECTED	7:21	18:31	11:10	LINE FAULT
1277	24-Oct-2021	MYSURU	66	HV2	HDKOTE_66	12:21	18:49	6:28	LINE CLEAR AVAILED
1278	24-Oct-2021	MYSURU	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	7:36	7:50	0:14	LINE FAULT
1279	24-Oct-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	9:32	11:35	2:03	LINE CLEAR AVAILED
1280	24-Oct-2021	MYSURU	66	KUNTHUR-DR PETE	SANTHEMARAHALLI_66 THAYURU_66 MUGUR_66 JANNUR_66TNARASIPURA_66	17:57	18:02	0:05	LINE FAULT
1281	24-Oct-2021	MYSURU	66	KUSHALNAGARA-MYSORE-1	MIRLE_66	3:05	3:19	0:13	LINE FAULT
1282	24-Oct-2021	MYSURU	66	KUSHALNAGARA-SUNTIKOPPA	NO STATIONS EFFECTED	16:13	16:20	0:06	LINE FAULT
1283	24-Oct-2021	MYSURU	66	SANTHEMARALLI-DR PETE	SANTHEMARAHALLI_66	10:00	11:55	1:55	LINE CLEAR AVAILED
1284	24-Oct-2021	MYSURU	66	HV2	SANTHEMARAHALLI_66	10:00	16:16	6:16	LINE CLEAR AVAILED
1285	24-Oct-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	23:44	23:50	0:05	TRANSFORMER FAULT
1286	24-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACALI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN LINE CLEAR AVAILED
1287	24-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09(10/10/2021)			LINE OPEN LINE CLEAR AVAILED
1288	24-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN LINE CLEAR AVAILED
1289	24-Oct-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN LINE CLEAR AVAILED
1290	24-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	22:21:13 (24.10.2021)	11:38:00 (25.10.2021)	13:16HRS	LINE CHARGED
1291	24-Oct-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	19:13:28 (23.10.2021)	9:50:00 (24.10.2021)	14:36HRS	LINE CHARGED
1292	24-Oct-2021	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	1:35	6:22	4:47	LINE FAULT
1293	24-Oct-2021	TUMKUR	220	TR-2	MADHUGIRI 220kV	3:26	8:27	5:00	TRANSFORMER FAULT
1294	24-Oct-2021	TUMKUR	220	PAVAGADA220-MADHUGIRI 2	PAVAGADA_220	1:47	6:16	4:28	LINE FAULT
1295	24-Oct-2021	TUMKUR	110	TR-1	KALLUR_110	0:35	6:06	5:30	TRANSFORMER FAULT
1296	24-Oct-2021	TUMKUR	66	ANTHRASANAHALLI 220kV-KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_66, BELADARA_66	22:23	22:54	0:31	LINE CLEAR AVAILED
1297	24-Oct-2021	TUMKUR	66	DAVANGERE SRS-CHITRADURGA1	CHITRADURGA_220	18:09	18:20	0:10	LINE FAULT
1298	24-Oct-2021	TUMKUR	66	TR-2(LV SIDE)	MADHUGIRI 220kV	3:26	8:32	5:05	TRANSFORMER FAULT
1299	24-Oct-2021	TUMKUR	66	MADHUGIRI 66kV-MADHUGIRI (OLD) 220KV	MADHUGIRI_66	8:30	8:33	0:02	HAND TRIPPED
1300	24-Oct-2021	TUMKUR	66	PAVAGADA220-PAVAGADA2	PAVAGADA_220	1:48	6:22	4:34	LINE FAULT
1301	24-Oct-2021	TUMKUR	66	TR-1	NIDSALE_66	9:16	12:04	2:47	LINE CLEAR AVAILED
1302	24-Oct-2021	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	12:58	14:59	2:00	TRANSFORMER FAULT
1303	25-Oct-2021	BAGALKOT	110	110KV/11 KV,HV1	ITNAL_110	10:55	11:10	0:15	TRANSFORMER FAULT
1304	25-Oct-2021	BAGALKOT	110	110KV/11 KV,HV1	SANKESHWAR_110	11:15	16:00	4:45	LINE CLEAR AVAILED
1305	25-Oct-2021	BAGALKOT	110	110KV/11KV,HV1	MUNDAGANUR_110	13:05	13:55	0:50	LINE CLEAR AVAILED
1306	25-Oct-2021	BAGALKOT	110	220/110KV,LV1	MK HBLLI_220	1:00	7:00	6:00	LINE CLEAR AVAILED
1307	25-Oct-2021	BAGALKOT	110	GHATAPRABHA-KABBUR	GHATAPRABHA_220	6:42	7:13	0:31	LINE FAULT
1308	25-Oct-2021	BAGALKOT	110	HALIYAL-ALNAVAR	HALIYAL_110	15:58	16:19	0:21	LINE FAULT
1309	25-Oct-2021	BAGALKOT	110	INDI-ZALKI2	INDI_220	5:02	5:18	0:20	LINE FAULT
1310	25-Oct-2021	BAGALKOT	110	MUGALKHOD-ITNAL2	MUGALKHOD_220	11:40	13:30	2:50	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1311	25-Oct-2021	BAGALKOT	110	MUGALKHOD-RAIBAG1	MUGALKHOD_220	10:18	12:28	2:10	NFBC ISSUED
1312	25-Oct-2021	BAGALKOT	220	220/110KV,HV1,LV1	AMBEWADI_220	17:27 (25.10.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1313	25-Oct-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)		6:47	0:04	LINE FAULT
1314	25-Oct-2021	BENGALURU	66	HOODY 220 - BAGHMANE WORLD TECH PARK	NO STATION AFFECTED	14:57	16:15	1:18	LINE FAULT
1315	25-Oct-2021	BENGALURU	66	HV1	HSR LAYOUT 220	20:52	21:01	0:09	TRANSFORMER FAULT
1316	25-Oct-2021	BENGALURU	66	HV1	VIJAYANAGARA	9:15	9:20	0:05	LOAD CHANGE OVER
1317	25-Oct-2021	BENGALURU	66	HV1	VOLVO	20:40	21:05	0:25	TRANSFORMER FAULT
1318	25-Oct-2021	BENGALURU	66	HV1	VOLVO	21:25	21:45	0:20	TRANSFORMER FAULT
1319	25-Oct-2021	BENGALURU	66	HV1	WEL CAST STEEL	13:40	13:42	0:02	LINE CLEAR AVAILED
1320	25-Oct-2021	BENGALURU	66	HV1	SOMENAHALLI	10:15	10:50	0:35	LINE CLEAR AVAILED
1321	25-Oct-2021	BENGALURU	66	HV1	PALLICHERLU	11:49	13:20	1:31	LINE CLEAR AVAILED
1322	25-Oct-2021	BENGALURU	66	HV2	ANJANAPURA	9:00	9:02	0:02	LINE CLEAR AVAILED
1323	25-Oct-2021	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	13:48	13:53	0:05	TRANSFORMER FAULT
1324	25-Oct-2021	BENGALURU	66	HV2	SARIJAPURA 220	11:59	13:16	1:16	LINE CLEAR AVAILED
1325	25-Oct-2021	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU	9:20	18:08	8:48	LINE CLEAR AVAILED
1326	25-Oct-2021	BENGALURU	66	PALLICHERLU - CHINTAMANI 220	PALLICHERLU	13:11	13:14	0:03	LINE CLEAR AVAILED
1327	25-Oct-2021	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	7:25	7:47	0:22	LINE FAULT
1328	25-Oct-2021	BENGALURU	66	T G HALLI - BYADARAHALLI	T G HALLI	6:00	6:05	0:05	LOAD CHANGE OVER
1329	25-Oct-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	11:14	11:27	0:13	LINE CLEAR AVAILED
1330	25-Oct-2021	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	11:14	11:27	0:13	LINE CLEAR AVAILED
1331	25-Oct-2021	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:14	11:27	0:13	LINE CLEAR AVAILED
1332	25-Oct-2021	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:59	16:43	1:44	LINE CLEAR AVAILED
1333	25-Oct-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:14	11:27	0:13	LINE CLEAR AVAILED
1334	25-Oct-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:59	16:43	1:44	LINE CLEAR AVAILED
1335	25-Oct-2021	BENGALURU	66	YEDUMADU - HANUMANTHNAGAR	YEDUMADU	17:25	17:40	0:15	LOAD CHANGE OVER
1336	25-Oct-2021	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	11:14	11:20	0:06	LOAD CHANGE OVER
1337	25-Oct-2021	BENGALURU	66	YELAHANKA 220 - LINE2	NO STATION AFFECTED	8:10:36(24-10-2021)	16:14(25-10-2021)	8:02 hrs	LINE CHARGED
1338	25-Oct-2021	BENGALURU	220	DB PURA 220 - NELAMANGALA 2	NO STATION AFFECTED	12:05	14:32	2:27	LINE CLEAR AVAILED
1339	25-Oct-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	22:05(23-10-21)	7:25(24-10-2021)	9:19 hrs	MAIN SUPPLY FAILURE
1340	25-Oct-2021	BENGALURU	220	HV2	TK HALLI 220	11:14	11:26	0:12	TRANSFORMER FAULT
1341	25-Oct-2021	BENGALURU	220	KIADB DB PURA 220 - GOWRIBIDANUR 220	NO STATION AFFECTED	13:33	14:08	0:34	LINE CLEAR AVAILED
1342	25-Oct-2021	BENGALURU	220	NELMANGALA 400 - DB PURA 2	NO STATION AFFECTED	12:03	14:31	2:27	LINE CLEAR AVAILED
1343	25-Oct-2021	GULBARGA	66	HV1	HARAPANAHALLI_66	9:35	13:20	3:45	LINE CLEAR AVAILED
1344	25-Oct-2021	GULBARGA	66	HV1	GUDEKOTE_66	6:15	6:30	0:15	LINE CLEAR AVAILED
1345	25-Oct-2021	GULBARGA	66	HV2	TELAGI_66	15:15	15:45	0:30	LINE CLEAR AVAILED
1346	25-Oct-2021	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	2:24	2:54	0:30	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1347	25-Oct-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	10:00	10:30	0:30	MAIN SUPPLY FAILURE
1348	25-Oct-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	13:10	14:20	1:10	MAIN SUPPLY FAILURE
1349	25-Oct-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	15:15	15:20	0:05	MAIN SUPPLY FAILURE
1350	25-Oct-2021	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	14:20	17:00	2:40	LINE CLEAR AVAILED
1351	25-Oct-2021	GULBARGA	110	HV1	KUDITINI_110	13:35	13:45	0:10	TRANSFORMER FAULT
1352	25-Oct-2021	GULBARGA	110	HV2	SREERAMANAGAR_110	12:05	12:16	0:11	TRANSFORMER FAULT
1353	25-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	4:50	4:55	0:05	LINE FAULT
1354	25-Oct-2021	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	8:40	8:50	0:10	LINE CLEAR AVAILED
1355	25-Oct-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	10:02	10:44	0:42	LINE FAULT
1356	25-Oct-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	15:15	15:21	0:06	LINE FAULT
1357	25-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	22:58(24.05.2021)	00:15(25.10.2021)	01:17HRS	LINE CHARGED
1358	25-Oct-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	0:24	0:35	0:11	LINE FAULT
1359	25-Oct-2021	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	10:45	14:35	3:50	LINE CLEAR AVAILED
1360	25-Oct-2021	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	19:32	19:37	0:05	LINE FAULT
1361	25-Oct-2021	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	22:56	23:03	0:07	LINE FAULT
1362	25-Oct-2021	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	4:30	4:35	0:05	MAIN SUPPLY FAILURE
1363	25-Oct-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	18:44	18:52	0:08	LINE FAULT
1364	25-Oct-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	13:10	14:20	1:10	LINE CLEAR AVAILED
1365	25-Oct-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN LINE CLEAR AVAILED
1366	25-Oct-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN LINE CLEAR AVAILED
1367	25-Oct-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1368	25-Oct-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	1:47(23.10.2021)	10:40(25.10.2021)	32:53HRS	LINE CHARGED
1369	25-Oct-2021	HASSAN	66	CHANNAR-SHETHLY	CHANNARAYAPATNA_66	12:18	14:13	1:55	LINE CLEAR AVAILED
1370	25-Oct-2021	HASSAN	66	HV1	KUDLIGERE_66	11:29	12:28	0:59	TRANSFORMER FAULT
1371	25-Oct-2021	HASSAN	66	HV2	HOLEHONNUR_66	12:35	13:07	0:32	LINE CLEAR AVAILED
1372	25-Oct-2021	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	16:57	17:11	0:14	LINE FAULT
1373	25-Oct-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:49	21:04	5:15	LINE FAULT
1374	25-Oct-2021	HASSAN	110	HULICA-HSNGD	HULICAL_110	13:27	13:54	0:27	HAND TRIPPED
1375	25-Oct-2021	HASSAN	110	HV1	TOGARSI_110	21:10(24.10.2021)	15:03(25.10.2021)	16:52 hrs	TRANSFORMER CHARGED
1376	25-Oct-2021	HASSAN	110	HV1	KAVOOR_220	9:26	20:00	10:34	LINE CLEAR AVAILED
1377	25-Oct-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1378	25-Oct-2021	HASSAN	110	HV3	BHADRAVATHI_110	12:05	14:35	2:30	TRANSFORMER FAULT
1379	25-Oct-2021	HASSAN	110	JOG-JST2	mghejog_gen	12:26	12:48	0:22	LINE FAULT
1380	25-Oct-2021	HASSAN	110	JOG-NK2	mghejog_gen	21:34(24.10.2021)	7:14(25.10.2021)	9:39 hrs	LINE CHARGED
1381	25-Oct-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:00	18:25	4:25	LINE CLEAR AVAILED
1382	25-Oct-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:04	21:04	5:00	LINE CLEAR AVAILED
1383	25-Oct-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	19:32(21.10.2021)			LINE OPEN, LINE FAULT
1384	25-Oct-2021	HASSAN	110	PUTTUR-PUTTUR2	PUTTUR_220	17:07	17:24	0:17	LINE FAULT
1385	25-Oct-2021	HASSAN	110	SAGARA-JST2	SAGARA_110	12:27	12:48	0:21	LINE FAULT
1386	25-Oct-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	22:30(21.10.2021)			LINE OPEN, LINE FAULT
1387	25-Oct-2021	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:39	12:22	1:43	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1388	25-Oct-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	19:56	21:25	1:29	NFBC ISSUED
1389	25-Oct-2021	HASSAN	220	MRSSH-M-ANTRSNH	MRSMSG_220	23:32(21.10.2021)			LINE OPEN,LINE FAULT
1390	25-Oct-2021	HASSAN	220	MRSSH-M-SHARAVATHY3	MRSMSG_220	22:04(24.10.2021)	12:51(25.10.2021)	13:46 hrs	LINE CHARGED
1391	25-Oct-2021	HASSAN	220	MRSSH-M-VARAH1	MRSMSG_220	19:43(21.10.2021)			LINE OPEN,LINE FAULT
1392	25-Oct-2021	HASSAN	220	MRSSH-M-VARAH13	MRSMSG_220	13:59(25.10.2021)			LINE OPEN LINE CLEAR AVAILED
1393	25-Oct-2021	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	22:04(24.10.2021)	12:51(25.10.2021)	13:46 hrs	LINE CHARGED
1394	25-Oct-2021	HASSAN	220	VARAH1-KEMAR1	varahi_gen	19:56	21:24	1:28	LINE CLEAR AVAILED
1395	25-Oct-2021	HASSAN	220	VARAH1-KEMAR1	varahi_gen	21:35	21:42	0:07	LINE FAULT
1396	25-Oct-2021	HASSAN	220	VARAH1-KEMAR2	varahi_gen	21:35	21:43	0:08	LINE FAULT
1397	25-Oct-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:10(25.10.2021)			LINE OPEN LINE CLEAR AVAILED
1398	25-Oct-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	9:31(18.10.2021)	10:33(25.10.2021)	169:01 hrs	LINE CHARGED
1399	25-Oct-2021	MYSURU	66	AKKIHEBBAL-KAVERI HYDRO	NO STATIONS EFFECTED	12:25	14:58	2:33	LINE CLEAR AVAILED
1400	25-Oct-2021	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	18:08:09 (10/10/2021)			LINE OPEN LINE CLEAR AVAILED
1401	25-Oct-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	0:07	0:12	0:05	TRANSFORMER FAULT
1402	25-Oct-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	7:01	7:27	0:26	TRANSFORMER FAULT
1403	25-Oct-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	10:22	11:20	0:58	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1404	25-Oct-2021	MYSURU	66	HV1	SUTTUR_66	12:03	18:31	6:28	LINE CLEAR AVAILED
1405	25-Oct-2021	MYSURU	66	HV1	BG PURA_66	11:35	12:00	0:25	LINE CLEAR AVAILED
1406	25-Oct-2021	MYSURU	66	HV1	CHUNCHUNKATTE_66	22:31	22:40	0:08	TRANSFORMER FAULT
1407	25-Oct-2021	MYSURU	66	HV2	HAMPAPURA_66	13:54	18:37	4:43	LINE CLEAR AVAILED
1408	25-Oct-2021	MYSURU	66	K HONALAGERE-MADDUR	MADDUR_66 SOMANAHALLI_66 K HONNALGERE_66	11:35	11:47	0:12	HAND TRIPPED
1409	25-Oct-2021	MYSURU	66	KIRUGAVALU-MALIYUR	VADKEPURA_66 KIRUGAVALU_66	0:42	1:00	0:17	LINE FAULT
1410	25-Oct-2021	MYSURU	66	KOLLEGALA-THALAKADU	NO STATIONS EFFECTED	8:40	11:38	2:57	LINE FAULT
1411	25-Oct-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN LINE CLEAR AVAILED
1412	25-Oct-2021	MYSURU	66	MADDUR-KIADB MANDYA	MADDUR_66 SOMANAHALLI_66 K HONNALGERE_66	11:45	20:40	8:55	LINE CLEAR AVAILED
1413	25-Oct-2021	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN LINE CLEAR AVAILED
1414	25-Oct-2021	MYSURU	66	SFC SHIVA-PGL	NO STATIONS EFFECTED	0:42	0:46	0:03	LINE FAULT
1415	25-Oct-2021	MYSURU	66	TUBINKERE-NAGAMANGALA1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	2:02	18:49	16:47	LINE FAULT
1416	25-Oct-2021	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1417	25-Oct-2021	MYSURU	220	KADAKOLA-BASTIPURA2	NO STATIONS EFFECTED	23:57	23:59	0:01	LINE FAULT
1418	25-Oct-2021	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1 IPP 66	MEGMICON 1_IPP_66	6:21	6:39	0:17	LINE FAULT
1419	25-Oct-2021	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	7:39	7:44	0:05	LINE CLEAR AVAILED
1420	25-Oct-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	11:57	12:16	0:19	MAIN SUPPLY FAILURE
1421	25-Oct-2021	TUMKUR	66	PD KOTE 66-CLEAR SOLAR IPP_66	CLEAR SOLAR_IPP_66	11:57	12:14	0:16	MAIN SUPPLY FAILURE
1422	25-Oct-2021	TUMKUR	66	PD KOTE66-AZURE POWER IPP_66	AZURE POWER_IPP_66	11:58	12:08	0:10	MAIN SUPPLY FAILURE
1423	25-Oct-2021	TUMKUR	66	PD KOTE66-SOLITAIRE IPP_66	SOLITAIRE_IPP_66	11:58	12:22	0:24	MAIN SUPPLY FAILURE
1424	25-Oct-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	19:04	19:26	0:22	LINE FAULT
1425	25-Oct-2021	TUMKUR	66	TR-1	BALENAHALLI_66	14:38	14:47	0:09	TRANSFORMER FAULT
1426	25-Oct-2021	TUMKUR	66	TR-1	BELLAVI_66	14:59	15:02	0:03	LINE CLEAR AVAILED
1427	25-Oct-2021	TUMKUR	66	TR-1	DODDASARANGI_66	15:49	16:38	0:48	LINE CLEAR AVAILED
1428	25-Oct-2021	TUMKUR	66	TR-1	MADHUGIRI_220	12:51	13:38	0:47	LINE CLEAR AVAILED
1429	25-Oct-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	10:54	10:59	0:05	TRANSFORMER FAULT
1430	25-Oct-2021	TUMKUR	66	TR-1	MADADAKERE_66	15:33	15:39	0:05	TRANSFORMER FAULT
1431	25-Oct-2021	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	11:03	12:42	1:39	LINE CLEAR AVAILED
1432	25-Oct-2021	TUMKUR	66	TR-1	HIREHALLI_66	5:05	8:30	3:25	LINE CLEAR AVAILED
1433	25-Oct-2021	TUMKUR	66	TR-2	HOLALKERE_66	11:49	12:09	0:20	LINE CLEAR AVAILED
1434	25-Oct-2021	TUMKUR	66	TR-2	HOSAKRE_66	11:25	13:30	2:04	LINE CLEAR AVAILED
1435	25-Oct-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	8:21	8:33	0:12	TRANSFORMER FAULT
1436	25-Oct-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	11:26	16:19	4:52	LINE CLEAR AVAILED
1437	25-Oct-2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	11:19	13:45	2:25	LINE CLEAR AVAILED