

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 24.12.2019 TO 30.12.2019**

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	24-Dec-19	BAGALKOT	220	220/110KV, HV1&LV1	BAGALKOT_220	10:16	14:48	4:32	LINE CLEAR AVAILED
2	24-Dec-19	BAGALKOT	220	220/110KV, HV2&LV2	BAGALKOT_220	14:49	18:04	3:15	LINE CLEAR AVAILED
3	24-Dec-19	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	0:09	1:31	1:22	LINE CLEAR AVAILED
4	24-Dec-19	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	9:52	10:32	0:40	LINE CLEAR AVAILED
5	24-Dec-19	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	15:41	23:59	8:18	TRANSFORMER FAULT
6	24-Dec-19	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	16:27	17:35	1:08	LINE CLEAR AVAILED
7	24-Dec-19	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	BHUTNAL_110	12:00	13:08	1:08	LINE CLEAR AVAILED
8	24-Dec-19	BAGALKOT	110	110/33KV, HV1	BELGAUM_110	14:57	16:19	1:22	LINE CLEAR AVAILED
9	24-Dec-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	10:44	17:55	7:11	LINE CLEAR AVAILED
10	24-Dec-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR1	SANKESHWAR_110	2:50	10:45	7:55	LINE FAULT
11	24-Dec-19	BAGALKOT	110	SOUDATTI220-RAMDURGA2	RAMDURGA_110	0:00	16:43	16:43	LINE CLEAR AVAILED
12	24-Dec-19	BAGALKOT	110	JAMAKHANDI-SHIROL	SHIROL_110	9:48	23:59	14:11	LINE CLEAR AVAILED
13	24-Dec-19	BAGALKOT	110	110/11KV,HV1	RAMDURGA_110	16:05	16:45	0:40	LINE CLEAR AVAILED
14	24-Dec-19	BAGALKOT	110	110/33KV,HV2	RAMDURGA_110,MUDAKAVI_33,GMR_33KV	15:15	16:45	1:30	LINE CLEAR AVAILED
15	24-Dec-19	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	15:12	16:54	1:42	LINE CLEAR AVAILED
16	24-Dec-19	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	16:59	17:46	0:47	LINE CLEAR AVAILED
17	24-Dec-19	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	14:26	15:22	0:56	LINE CLEAR AVAILED
18	24-Dec-19	BAGALKOT	110	SIRSI1&2-KUMTA	KUMTA_110	19:10	23:59	4:49	LINE CLEAR AVAILED
19	24-Dec-19	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	12:22	13:42	1:20	LINE CLEAR AVAILED
20	24-Dec-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR2	SANKESHWAR_110	3:05	3:40	0:35	HAND TRIPPED
21	24-Dec-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR2	SANKESHWAR_110	10:43	10:49	0:06	HAND TRIPPED
22	24-Dec-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	3:18	3:33	0:15	HAND TRIPPED
23	24-Dec-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	11:27	13:18	1:51	LINE CLEAR AVAILED
24	24-Dec-19	BAGALKOT	110	110/33KV,HV1	HUBLI_220	9:45	12:43	2:58	LINE CLEAR AVAILED
25	24-Dec-19	BAGALKOT	110	110/33KV,HV2	HUBLI_220	14:48	17:18	2:30	LINE CLEAR AVAILED
26	24-Dec-19	BENGALURU	66	MITTERMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	19:15	19:20	0:05	LOAD CHANGE OVER
27	24-Dec-19	BENGALURU	66	MANDIKAL - GOWRIBIDANUR 22	SOMENAHALLI, PERESANDRA, MANDIKAL	9:00	9:05	0:05	LOAD CHANGE OVER
28	24-Dec-19	BENGALURU	66	PATHPALYA - BAGEPALLI	PATHPALYA	9:00	9:05	0:05	LOAD CHANGE OVER
29	24-Dec-19	BENGALURU	66	PATHPALYA - MITTEMARI 220	PATHPALYA	19:35	19:40	0:05	LOAD CHANGE OVER
30	24-Dec-19	GULBARGA	220	ITTAGGI-NEELAGUNDA	NEELAGUNDA_220	10:20	16:18	5:58	LINE CLEAR AVAILED
31	24-Dec-19	GULBARGA	220	ITTAGGI-LINGAPUR	ITTAGI_220	10:20	15:40	5:20	LINE CLEAR AVAILED
32	24-Dec-19	GULBARGA	220	ITTAGGI-EMBASSY	ITTAGI_220	10:20	15:50	5:30	LINE CLEAR AVAILED
33	24-Dec-19	GULBARGA	220	ITTAGGI-HARKANALU	ITTAGI_220	10:20	16:18	5:58	LINE CLEAR AVAILED
34	24-Dec-19	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	6:19	7:21	1:02	LINE FAULT
35	24-Dec-19	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	7:35	9:23	1:48	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
36	24-Dec-19	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	9:30	9:35	0:05	LINE CLEAR AVAILED
37	24-Dec-19	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	12:30	15:45	3:15	LINE CLEAR AVAILED
38	24-Dec-19	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATII_110	8:20	16:31	8:11	LINE CLEAR AVAILED
39	24-Dec-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	12:13	12:34	0:21	LINE FAULT
40	24-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:05	5:24	5:19	LINE CLEAR AVAILED
41	24-Dec-19	HASSAN	220	GOPALAP-BASTIPURA	GOPALAPURA_220	0:00	18:23	18:23	LINE CLEAR AVAILED
42	24-Dec-19	HASSAN	110	HV1	MRSMSG_220	9:09	9:17	0:08	TRANSFORMER FAULT
43	24-Dec-19	HASSAN	110	HV2	MRSMSG_220	9:09	9:18	0:09	TRANSFORMER FAULT
44	24-Dec-19	HASSAN	110	HV3	MRSMSG_220	9:09	9:19	0:10	TRANSFORMER FAULT
45	24-Dec-19	HASSAN	110	HV4	MRSMSG_220	9:09	9:19	0:10	TRANSFORMER FAULT
46	24-Dec-19	HASSAN	110	HV1	BAIKAMPADY_110	11:06	16:59	5:53	LINE CLEAR AVAILED
47	24-Dec-19	HASSAN	110	HV1	GERUMARA_110	11:14	15:00	3:46	LINE CLEAR AVAILED
48	24-Dec-19	HASSAN	110	HV2	GERUMARA_110	11:14	15:00	3:46	LINE CLEAR AVAILED
49	24-Dec-19	HASSAN	110	HV2	GERUMARA_110	16:16	17:36	1:20	LINE CLEAR AVAILED
50	24-Dec-19	HASSAN	110	HV1	HIRIYADKA_110	10:00	13:17	3:17	LINE CLEAR AVAILED
51	24-Dec-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	12:13	13:23	1:10	LINE CLEAR AVAILED
52	24-Dec-19	HASSAN	110	HV2	KONDENALU_110	14:27	18:23	3:56	LINE CLEAR AVAILED
53	24-Dec-19	HASSAN	66	LV1	MRSMSG_220	9:09	9:18	0:09	HAND TRIPPED
54	24-Dec-19	HASSAN	66	LV2	MRSMSG_220	9:09	9:18	0:09	HAND TRIPPED
55	24-Dec-19	HASSAN	66	LV3	MRSMSG_220	9:09	9:19	0:10	HAND TRIPPED
56	24-Dec-19	HASSAN	66	LV4	MRSMSG_220	9:09	9:19	0:10	HAND TRIPPED
57	24-Dec-19	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	9:10	9:21	0:11	HAND TRIPPED
58	24-Dec-19	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	9:11	9:21	0:10	HAND TRIPPED
59	24-Dec-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:10	9:25	0:15	HAND TRIPPED
60	24-Dec-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:51	13:58	0:07	HAND TRIPPED
61	24-Dec-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	9:10	9:22	0:12	HAND TRIPPED
62	24-Dec-19	HASSAN	66	HV1	DODDAKADANUR_66	11:40	16:03	4:23	LINE CLEAR AVAILED
63	24-Dec-19	HASSAN	66	SAKALE-HANBAL	SAKALESH PURA_66	16:16	16:26	0:10	LINE FAULT
64	24-Dec-19	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:30	15:45	6:15	LINE CLEAR AVAILED
65	24-Dec-19	HASSAN	66	HV1	SINGAPURA_66	9:29	15:46	6:17	LINE CLEAR AVAILED
66	24-Dec-19	HASSAN	66	HV2	SINGAPURA_66	9:30	15:45	6:15	LINE CLEAR AVAILED
67	24-Dec-19	MYSORE	66	HV2	BOMMALAPURA_66	9:38	11:16	1:38	LINE CLEAR AVAILED
68	24-Dec-19	MYSORE	220	HV1	CRNAGAR_220	10:30	13:32	3:01	LINE CLEAR AVAILED
69	24-Dec-19	MYSORE	220	HV2	CRNAGAR_220	13:35	16:46	3:11	LINE CLEAR AVAILED
70	24-Dec-19	MYSORE	66	HV2	DEVANOORNGUDU_66	10:03	16:52	6:48	LINE CLEAR AVAILED
71	24-Dec-19	MYSORE	66	HV1	DEVANOORNGUDU_66	10:03	15:25	5:21	LINE CLEAR AVAILED
74	24-Dec-19	MYSORE	220	HV1	MADHUVANAHALLI_220	12:48	14:08	1:20	LINE CLEAR AVAILED
75	24-Dec-19	MYSORE	220	HV2	MADHUVANAHALLI_220	15:40	16:42	1:01	LINE CLEAR AVAILED
82	24-Dec-19	MYSORE	66	HV1	MADHUVANAHALLI_220	12:29	12:42	0:13	LINE CLEAR AVAILED
83	24-Dec-19	MYSORE	66	HV2	MADHUVANAHALLI_220	12:08	12:24	0:16	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
87	24-Dec-19	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66, TARIPURA_66	18:17	18:34	0:16	LINE FAULT
88	24-Dec-19	MYSORE	66	VAJMANGALA-MEGLAPURA	MEGALAPURA_66	10:37	18:07	7:29	NFBC ISSUED
89	24-Dec-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	13:40	17:20	3:39	LINE CLEAR AVAILED
90	24-Dec-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	13:37	19:19	5:42	LINE FAULT
91	24-Dec-19	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	16:00	17:45	1:45	LINE CLEAR AVAILED
92	24-Dec-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:36	19:08	5:32	LINE FAULT
93	24-Dec-19	TUMKUR	220	KB CROSS 220kv- NELAMANGALA	KBCROSS_220	10:24	14:06	3:41	LINE CLEAR AVAILED
94	24-Dec-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	14:12	15:47	1:35	LINE CLEAR AVAILED
95	24-Dec-19	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	15:31	16:08	0:37	HAND TRIPPED
96	24-Dec-19	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	10:39	17:46	7:07	LINE CLEAR AVAILED
97	24-Dec-19	TUMKUR	66	TR-1	CHITRADURGA_66	12:59	17:25	4:26	LINE CLEAR AVAILED
98	24-Dec-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	15:51	16:00	0:09	HAND TRIPPED
99	24-Dec-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	17:22	17:37	0:14	LINE FAULT
100	24-Dec-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	17:29	17:36	0:07	LINE FAULT
101	24-Dec-19	TUMKUR	66	TR-2	GUTTUR_66	16:00	16:42	0:41	LINE CLEAR AVAILED
102	24-Dec-19	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	14:12	14:38	0:26	HAND TRIPPED
103	24-Dec-19	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	15:40	16:00	0:20	HAND TRIPPED
104	24-Dec-19	TUMKUR	66	HIRIYURkv 220kv- SUZLON 2	SUZLON1_IPP_66	14:48	15:51	1:03	LINE CLEAR AVAILED
105	24-Dec-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	14:07	15:51	1:43	LINE CLEAR AVAILED
106	24-Dec-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	14:08	15:51	1:43	LINE CLEAR AVAILED
107	24-Dec-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	14:08	15:51	1:43	LINE CLEAR AVAILED
108	24-Dec-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:15	13:35	0:19	HAND TRIPPED
109	24-Dec-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	14:07	15:51	1:43	LINE CLEAR AVAILED
110	24-Dec-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	14:09	15:52	1:43	LINE CLEAR AVAILED
111	24-Dec-19	TUMKUR	66	TR-2	KOLALA_66	12:48	14:16	1:28	LINE CLEAR AVAILED
112	24-Dec-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	19:06	19:20	0:13	LINE FAULT
113	25-Dec-19	BAGALKOT	110	ARGA-ANKOLA	ANKOLA_110	14:54	14:58	0:04	LINE CLEAR AVAILED
114	25-Dec-19	BAGALKOT	110	BAGALKOT220-LOKAPUR	BAGALKOT_220	6:29	6:38	0:09	LINE FAULT
115	25-Dec-19	BAGALKOT	110	110/33KV, HV3	ATHANI_110, HALIYAL_33	18:35	19:54	1:19	TRANSFORMER FAULT
116	25-Dec-19	BAGALKOT	110	110/33KV, HV2	BELGAUM_110	11:22	13:57	2:35	LINE CLEAR AVAILED
117	25-Dec-19	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	12:35	14:16	1:41	LINE CLEAR AVAILED
118	25-Dec-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	17:35	18:16	0:41	LINE CLEAR AVAILED
119	25-Dec-19	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	3:07	3:51	0:44	LINE FAULT
120	25-Dec-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR1	SANKESHWAR_110	14:09	14:37	0:28	LINE FAULT
121	25-Dec-19	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220	10:05	14:21	4:16	LINE CLEAR AVAILED
122	25-Dec-19	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI_220	14:30	18:20	3:50	LINE CLEAR AVAILED
123	25-Dec-19	BAGALKOT	110	110/11KV,HV1	MUDDEBIHAL_110	10:11	23:59	13:48	TRANSFORMER FAULT
124	25-Dec-19	BAGALKOT	110	SIRSI1&2-KUMTA	KUMTA_110	0:00	9:59	9:59	LINE CLEAR AVAILED
125	25-Dec-19	BAGALKOT	110	KARWAR220-KUMTA	KUMTA_110	9:34	14:40	5:06	LINE FAULT
126	25-Dec-19	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	12:21	12:54	0:33	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
127	25-Dec-19	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	14:10	14:45	0:35	LINE FAULT
128	25-Dec-19	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	15:02	23:30	8:28	LINE CLEAR AVAILED
129	25-Dec-19	BENGALURU	66	HV2	BTM 4TH PHASE	14:10	14:46	0:36	LINE CLEAR AVAILED
130	25-Dec-19	GULBARGA	220	HV1	ITTAGI_220	18:13	18:20	0:07	TRANSFORMER FAULT
131	25-Dec-19	GULBARGA	220	HV2	ITTAGI_220	18:13	18:20	0:07	TRANSFORMER FAULT
132	25-Dec-19	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	5:46	12:00	6:14	LINE FAULT
133	25-Dec-19	GULBARGA	110	SEDAM-VICATASAGAR	VICATASAGAR CEMENTS_IPP	8:05	8:18	0:13	LINE FAULT
134	25-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:43	7:06	6:23	LINE CLEAR AVAILED
135	25-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:43	23:59	2:16	LINE CLEAR AVAILED
136	25-Dec-19	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	17:59	18:13	0:14	LINE FAULT
137	25-Dec-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	17:43	18:08	0:25	LINE FAULT
138	25-Dec-19	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	17:43	18:11	0:28	LINE FAULT
139	25-Dec-19	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	17:43	18:46	1:03	LINE FAULT
140	25-Dec-19	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	17:44	18:14	0:30	LINE FAULT
141	25-Dec-19	HASSAN	220	HV1	MRSMSG_220	17:43	18:14	0:31	TRANSFORMER FAULT
142	25-Dec-19	HASSAN	220	HV2	MRSMSG_220	17:43	18:15	0:32	TRANSFORMER FAULT
143	25-Dec-19	HASSAN	220	HV3	MRSMSG_220	17:44	18:15	0:31	TRANSFORMER FAULT
144	25-Dec-19	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	17:43	18:11	0:28	LINE FAULT
145	25-Dec-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	17:43	18:11	0:28	LINE FAULT
146	25-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	17:43	18:25	0:42	LINE FAULT
147	25-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	17:43	18:20	0:37	LINE FAULT
148	25-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	17:43	18:20	0:37	LINE FAULT
149	25-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	17:18	17:43	0:25	LINE FAULT
150	25-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	17:43	23:59	6:16	LINE FAULT
151	25-Dec-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	17:43	18:23	0:40	LINE FAULT
152	25-Dec-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	17:43	18:23	0:40	LINE FAULT
153	25-Dec-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	10:12	17:43	7:31	LINE CLEAR AVAILED
154	25-Dec-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	17:43	18:23	0:40	LINE FAULT
155	25-Dec-19	HASSAN	220	SHARAVATHY-SHIMOGA1	sharavathy_gen	17:43	18:20	0:37	HAND TRIPPED
156	25-Dec-19	HASSAN	220	SHARAVATHY-SHIMOGA3	sharavathy_gen	17:43	18:21	0:38	HAND TRIPPED
157	25-Dec-19	HASSAN	220	SHARAVATHY-SHIMOGA4	sharavathy_gen	17:08	23:59	6:51	LINE FAULT
158	25-Dec-19	HASSAN	220	VARAH1-SHMG3	varahi_gen	10:12	12:19	2:07	LINE CLEAR AVAILED
159	25-Dec-19	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	18:05	18:41	0:36	LINE FAULT
160	25-Dec-19	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	18:05	18:31	0:26	LINE FAULT
161	25-Dec-19	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	18:05	18:21	0:16	LINE FAULT
162	25-Dec-19	HASSAN	110	HV1	MRSMSG_220	18:05	18:25	0:20	TRANSFORMER FAULT
163	25-Dec-19	HASSAN	110	HV2	MRSMSG_220	18:06	18:24	0:18	TRANSFORMER FAULT
164	25-Dec-19	HASSAN	110	HV3	MRSMSG_220	18:06	18:24	0:18	TRANSFORMER FAULT
165	25-Dec-19	HASSAN	110	HV4	MRSMSG_220	18:06	18:23	0:17	TRANSFORMER FAULT
166	25-Dec-19	HASSAN	110	HV5	MRSMSG_220	18:06	18:28	0:22	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
167	25-Dec-19	HASSAN	110	MRSSHM-MPM	MRSMSG_220	18:05	18:36	0:31	LINE FAULT
168	25-Dec-19	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	17:44	18:21	0:37	LINE FAULT
169	25-Dec-19	HASSAN	110	MRSSHM-SS1	MRSMSG_220	18:06	18:27	0:21	LINE FAULT
170	25-Dec-19	HASSAN	110	MRSSHM-SS2	MRSMSG_220	18:06	18:27	0:21	LINE FAULT
171	25-Dec-19	HASSAN	110	KADUR-NGNHL	KADUR_220	11:10	11:35	0:25	HAND TRIPPED
172	25-Dec-19	HASSAN	66	LV1	MRSMSG_220	18:06	18:25	0:19	TRANSFORMER FAULT
173	25-Dec-19	HASSAN	66	LV2	MRSMSG_220	18:06	18:25	0:19	TRANSFORMER FAULT
174	25-Dec-19	HASSAN	66	LV3	MRSMSG_220	18:06	18:24	0:18	TRANSFORMER FAULT
175	25-Dec-19	HASSAN	66	LV4	MRSMSG_220	18:06	18:23	0:17	TRANSFORMER FAULT
176	25-Dec-19	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	18:06	18:29	0:23	LINE FAULT
177	25-Dec-19	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	18:06	18:30	0:24	LINE FAULT
178	25-Dec-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	14:08	14:12	0:04	LINE FAULT
179	25-Dec-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	17:44	18:25	0:41	LINE FAULT
180	25-Dec-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	17:44	18:29	0:45	LINE FAULT
181	25-Dec-19	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	6:13	6:18	0:04	LINE FAULT
182	25-Dec-19	MYSORE	66	HV2	COWDALLI_66	15:58	16:02	0:03	TRANSFORMER FAULT
183	25-Dec-19	MYSORE	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	6:29	6:33	0:03	LINE FAULT
185	25-Dec-19	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 KESLAGERE_66	3:09	3:20	0:10	LINE FAULT
187	25-Dec-19	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66	14:52	15:02	0:10	LINE FAULT
188	25-Dec-19	TUMKUR	66	CHAWDANKUPPE-ESENGY_SLR	ESENGY_SLR	17:59	21:53	3:53	LINE CLEAR AVAILED
189	25-Dec-19	TUMKUR	66	TR-2	GUTTUR_66	11:32	12:44	1:12	LINE CLEAR AVAILED
190	25-Dec-19	TUMKUR	66	TR-1	HOSADURGA_66	11:15	17:23	6:07	LINE CLEAR AVAILED
191	25-Dec-19	TUMKUR	66	TR-1	KORA_66	12:07	12:51	0:43	TRANSFORMER FAULT
192	25-Dec-19	TUMKUR	66	TR-1	KORA_66	14:03	14:10	0:07	TRANSFORMER FAULT
193	25-Dec-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TRAVANAGI_66, BASAVAPATNA_66, SANTERENINUR_66	5:20	5:26	0:06	LINE FAULT
194	25-Dec-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	8:46	9:04	0:17	LINE FAULT
195	25-Dec-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	13:17	13:35	0:17	LINE FAULT
196	25-Dec-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:00	18:20	0:20	LINE FAULT
197	25-Dec-19	TUMKUR	66	TR-1	MYLANAHALLI_66	9:46	10:47	1:00	LINE CLEAR AVAILED
198	26-Dec-19	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	9:11	9:18	0:07	LOAD CURTAILMENT
199	26-Dec-19	BAGALKOT	110	BIDNAL220-HUBLI2	BIDNAL_220	14:57	17:12	2:15	LINE CLEAR AVAILED
200	26-Dec-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:35	1:06	0:31	LINE FAULT
201	26-Dec-19	BAGALKOT	110	BELGAUM220-HUKKERI(UCHAGOAN)	HUKKERI_110	6:48	23:59	17:11	LINE CLEAR AVAILED
202	26-Dec-19	BAGALKOT	110	110/11KV, HV1	GAJENDRAGAD_110	9:11	9:22	0:11	LOAD CURTAILMENT
203	26-Dec-19	BAGALKOT	110	GHATAPRABHA220-HIDIKAL DAM	HIDIKAL DAM_110	18:55	20:05	1:10	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
204	26-Dec-19	BAGALKOT	110	GHATAPRABHA220-HIDIKAL DAM	HIDIKAL DAM_110	21:50	22:00	0:10	LINE FAULT
205	26-Dec-19	BAGALKOT	110	110/33KV, HV2	HUNAGUND_110,AMEENAGAD_33,KARADI_33	15:22	15:24	0:02	TRANSFORMER FAULT
206	26-Dec-19	BAGALKOT	110	110/11KV, HV2	KALAGATAGI_110	17:09	17:54	0:45	TRANSFORMER FAULT
207	26-Dec-19	BAGALKOT	110	110/11KV, HV2	KUD DHARWAD_110	6:24	6:54	0:30	TRANSFORMER FAULT
208	26-Dec-19	BAGALKOT	110	110/11KV, HV2	KUD DHARWAD_110	7:08	7:39	0:31	TRANSFORMER FAULT
209	26-Dec-19	BAGALKOT	110	110/11KV, HV1	MUDEBIHAL_110	0:00	14:31	14:31	LINE CLEAR AVAILED
210	26-Dec-19	BAGALKOT	110	SATISH SUGAR-PG HUNSHYAL	PG HUNSHYAL_110	18:52	18:58	0:06	LINE FAULT
211	26-Dec-19	BAGALKOT	110	SATISH SUGAR-PG HUNSHYAL	PG HUNSHYAL_110	21:50	22:00	0:10	LINE FAULT
212	26-Dec-19	BAGALKOT	110	SHIVASAGAR SUGARS-SALAHALLI	SALAHALLI_110	19:53	20:31	0:38	LINE FAULT
213	26-Dec-19	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	9:10	9:15	0:05	LOAD CURTAILMENT
214	26-Dec-19	BAGALKOT	110	110/33KV, HV2	SAVALAGI_110,HIREPADASALAGI,KALABILAGI_33,TUNGAL LIS_33	9:11	9:25	0:14	LOAD CURTAILMENT
215	26-Dec-19	BAGALKOT	220	DHINI1&2-GADAG	GADAG_220	18:09	23:59	5:50	LINE CLEAR AVAILED
216	26-Dec-19	BAGALKOT	220	220/110KV,HV3,LV3	GADAG_220	18:00	18:17	0:17	TRANSFORMER FAULT
217	26-Dec-19	BAGALKOT	110	110/33KV, HV1	HUBLI_220	10:28	14:49	4:21	LINE CLEAR AVAILED
218	26-Dec-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	12:27	23:59	11:32	LINE FAULT
219	26-Dec-19	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	16:32	16:45	0:13	TRANSFORMER FAULT
220	26-Dec-19	BENGALURU	66	HV1	YARANDANAHALLI 220	12:25	12:30	0:05	HAND TRIPPED
221	26-Dec-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	12:37	12:40	0:03	LOAD CHANGE OVER
222	26-Dec-19	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	11:15	11:30	0:15	LINE FAULT
223	26-Dec-19	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	11:34	12:15	0:41	LINE FAULT
224	26-Dec-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	12:27	12:37	0:10	LOAD CHANGE OVER
225	26-Dec-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	15:50	16:54	1:04	LINE FAULT
226	26-Dec-19	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	15:50	21:50	6:00	MAIN SUPPLY FAILURE
227	26-Dec-19	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66, JIGANI LINK ROAD	21:50	21:55	0:05	LOAD CHANGE OVER
228	26-Dec-19	BENGALURU	66	HV2	BOMMASANDRA	16:25	16:57	0:32	LINE CLEAR AVAILED
229	26-Dec-19	BENGALURU	66	HV1	DEVANAHALLI	2:17	2:23	0:05	TRANSFORMER FAULT
230	26-Dec-19	BENGALURU	66	HV1	DALSNUR	10:41	10:46	0:04	LINE CLEAR AVAILED
231	26-Dec-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	14:16	16:52	2:36	LINE FAULT
232	26-Dec-19	BENGALURU	220	LV2	CHINTAMANI 220	14:16	14:34	0:18	TRANSFORMER FAULT
233	26-Dec-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	23:07	23:09	0:02	LINE FAULT
234	26-Dec-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), CESSNO PARK (EHT)	19:25	22:24	2:58	LINE CLEAR AVAILED
235	26-Dec-19	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	19:25	20:25	0:59	MAIN SUPPLY FAILURE
236	26-Dec-19	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	NGEF, NGEF (EHT)	16:53	20:36	3:42	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
238	26-Dec-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATAVAHANA_IPP,AGRAWAL_IPP,SU ZLON_IPP,KAMALAPUR_110,METRI_110,RB NSFACTORY	1:13	1:20	0:07	LINE FAULT
239	26-Dec-19	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,KAM ALNAGAR_110	5:42	5:48	0:06	LINE FAULT
240	26-Dec-19	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,KAM ALNAGAR_110	7:18	7:26	0:08	LINE FAULT
241	26-Dec-19	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	12:45	12:50	0:05	LINE FAULT
242	26-Dec-19	GULBARGA	110	HV1	PDHALLI_110	9:15	9:20	0:05	LOAD CURTAILMENT
243	26-Dec-19	GULBARGA	110	PDHALLI-CLNMAX_IPP	PDHALLI_110	12:25	12:36	0:11	LINE FAULT
244	26-Dec-19	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	20:11	20:16	0:05	LINE FAULT
245	26-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	6:49	6:49	LINE CLEAR AVAILED
246	26-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:03	23:59	1:56	LINE CLEAR AVAILED
247	26-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	11:26	15:56	4:30	LINE FAULT
248	26-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	0:00	15:12	15:12	LINE FAULT
249	26-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	22:44	23:59	1:15	LINE FAULT
250	26-Dec-19	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	11:26	15:56	4:30	LINE FAULT
251	26-Dec-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	0:00	15:12	15:12	LINE FAULT
252	26-Dec-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	22:44	23:59	1:15	LINE FAULT
253	26-Dec-19	HASSAN	110	HV1	ARASIKERE_110	17:04	17:36	0:32	LINE CLEAR AVAILED
254	26-Dec-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	14:27	18:20	3:53	NFBC ISSUED
255	26-Dec-19	HASSAN	66	HV1	K.BYARAPURA_66	14:39	15:29	0:50	LINE CLEAR AVAILED
256	26-Dec-19	HASSAN	66	HV1	CHIKMAGALUR_66	11:31	12:13	0:42	LINE CLEAR AVAILED
257	26-Dec-19	HASSAN	66	HASSN220-ARAKALGUD1	HASSAN_220	9:35	13:41	4:06	LINE FAULT
258	26-Dec-19	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	9:44	13:42	3:58	LINE CLEAR AVAILED
259	26-Dec-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	9:17	9:32	0:15	MAIN SUPPLY FAILURE
260	26-Dec-19	HASSAN	66	HV1	S.BELAGOLA_66	14:12	14:27	0:15	LINE CLEAR AVAILED
261	26-Dec-19	HASSAN	66	HV2	S.BELAGOLA_66	14:12	14:27	0:15	LINE CLEAR AVAILED
262	26-Dec-19	MYSORE	66	HV2	BOMMALAPURA_66	16:44	19:08	2:24	LINE CLEAR AVAILED
265	26-Dec-19	MYSORE	66	DR PETE-KUNTHUR	JANNUR_66, MUGUR_66, SANTHEMARAHALLI_66, THAYURU_66	13:09	13:18	0:08	LINE FAULT
266	26-Dec-19	MYSORE	66	HV2	KIRUGAVALU_66	9:16	9:46	0:29	LOAD CURTAILMENT
267	26-Dec-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66	11:37	13:19	1:42	LINE CLEAR AVAILED
268	26-Dec-19	MYSORE	66	MADDUR-KIADB MANDYA	KIADBMANDYA_66,TUMBEKERE_66	11:28	11:44	0:16	HAND TRIPPED
269	26-Dec-19	MYSORE	66	MEGHALAPURA-SFC	CHIDRAVALLI_66, TNARASIPURA_66, THUMBLA_66	12:19	12:29	0:09	LINE FAULT
270	26-Dec-19	MYSORE	66	HV1	PANDAVAPURA_66	9:17	9:51	0:34	LOAD CURTAILMENT
272	26-Dec-19	MYSORE	66	HV3	PONNAMPET_66	10:02	14:06	4:04	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
273	26-Dec-19	MYSORE	66	HV2	PONNAMPET_66	9:17	9:25	0:08	LOAD CURTAILMENT
274	26-Dec-19	MYSORE	66	HV2	PONNAMPET_66	10:02	20:18	10:15	LINE CLEAR AVAILED
275	26-Dec-19	MYSORE	66	HV1	PONNAMPET_66	10:02	14:04	4:01	LINE CLEAR AVAILED
276	26-Dec-19	MYSORE	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	10:02	14:03	4:00	LINE CLEAR AVAILED
277	26-Dec-19	MYSORE	66	HV1	VIRAJPET_66	9:56	13:46	3:49	LINE CLEAR AVAILED
278	26-Dec-19	MYSORE	66	HV2	VIRAJPET_66	9:56	13:46	3:50	LINE CLEAR AVAILED
279	26-Dec-19	MYSORE	66	HV1	VIRAJPET_66	14:43	15:03	0:20	TRANSFORMER FAULT
280	26-Dec-19	MYSORE	66	HV1	VIRAJPET_66	15:53	16:42	0:49	TRANSFORMER FAULT
281	26-Dec-19	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	15:04	15:26	0:21	HAND TRIPPED
282	26-Dec-19	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	9:26	9:37	0:11	LOAD CURTAILMENT
283	26-Dec-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	9:26	9:54	0:28	LOAD CURTAILMENT
284	26-Dec-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	9:31	9:49	0:18	LOAD CURTAILMENT
285	26-Dec-19	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	9:30	9:53	0:23	LOAD CURTAILMENT
286	26-Dec-19	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	9:29	9:49	0:20	LOAD CURTAILMENT
287	26-Dec-19	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	10:29	17:57	7:28	LOAD CURTAILMENT
288	26-Dec-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELUR_66, HUSAKERE_66, ANKASANDRA_66	9:30	9:44	0:14	LOAD CURTAILMENT
289	26-Dec-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabasnete)	KOLALA_66, URDIGERE_66	9:30	9:43	0:12	LOAD CURTAILMENT
290	26-Dec-19	TUMKUR	66	TR-2	AVAREGERE_66	11:19	13:45	2:25	TRANSFORMER FAULT
291	26-Dec-19	TUMKUR	66	TR-2	AVAREGERE_66	16:24	16:58	0:33	TRANSFORMER FAULT
292	26-Dec-19	TUMKUR	66	TR-2	CHANNAGIRI_66	11:12	11:19	0:06	TRANSFORMER FAULT
293	26-Dec-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:47	14:58	0:11	LINE FAULT
294	26-Dec-19	TUMKUR	66	HIREHALLI - MELEKOTE	MELKOTE_66	16:13	16:31	0:17	LINE FAULT
295	26-Dec-19	TUMKUR	66	TR-1	HIEMALLANAHOLE_66	13:03	13:25	0:22	HAND TRIPPED
296	26-Dec-19	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	9:34	9:58	0:23	MAIN SUPPLY FAILURE
297	26-Dec-19	TUMKUR	66	TR-1	KATTIGE_66	7:55	8:00	0:05	TRANSFORMER FAULT
298	26-Dec-19	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	10:17	10:22	0:04	MAIN SUPPLY FAILURE
299	26-Dec-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	9:15	9:33	0:18	LINE FAULT
300	26-Dec-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	9:27	10:03	0:35	MAIN SUPPLY FAILURE
301	27-Dec-19	BAGALKOT	110	110/11KV, HV1	ANKALI_110	11:18	12:03	0:45	LINE CLEAR AVAILED
302	27-Dec-19	BAGALKOT	110	110/33KV, HV4	ANKALI_110, KOTAWADI_33	11:35	12:00	0:25	LINE CLEAR AVAILED
303	27-Dec-19	BAGALKOT	110	ANKOLA-KUMTA2	KUMTA_110	15:20	16:33	1:13	NFBC ISSUED
304	27-Dec-19	BAGALKOT	110	BAGALKOT220-KATARKI(NEERBUDIHAI)	NEERBUDIHAI_110	10:15	13:10	2:55	LINE FAULT
305	27-Dec-19	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	18:34	18:48	0:14	LINE CLEAR AVAILED
306	27-Dec-19	BAGALKOT	110	BAGEWADI220-NIDAGUNDI	NIDAGUNDI_110	11:05	14:50	3:45	LINE CLEAR AVAILED
307	27-Dec-19	BAGALKOT	110	BAGEWADI220-MUDDEBIHAL	MUDDEBIHAL_110	9:53	15:05	5:12	LINE FAULT
308	27-Dec-19	BAGALKOT	110	110/33KV, HV1	HANGAL_110, BALA_33	7:24	7:33	0:09	LOAD CURTAILMENT
309	27-Dec-19	BAGALKOT	110	HAVERI220-KNL_LIS	HAVERI_220	19:36	23:59	4:23	LINE FAULT
310	27-Dec-19	BAGALKOT	110	110/11KV, HV1	KALGHATAGI_110	10:30	10:55	0:25	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
311	27-Dec-19	BAGALKOT	110	110/11KV, HV1	KALGHATAGI_110	11:40	15:10	3:30	LINE CLEAR AVAILED
312	27-Dec-19	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	10:59	18:24	7:25	LINE CLEAR AVAILED
313	27-Dec-19	BAGALKOT	110	BALAJI SUGARS-MUDDEBIHAL	MUDDEBIHAL_110	9:55	15:32	5:37	MAIN SUPPLY FAILURE
314	27-Dec-19	BAGALKOT	110	110/11KV, HV2	MUNDAGOD_110	11:32	12:08	0:36	LINE CLEAR AVAILED
315	27-Dec-19	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	7:25	7:29	0:04	LOAD CURTAILMENT
316	27-Dec-19	BAGALKOT	110	RANEBENNUR-RATTIHALLI(TUMMINKATTI)	TUMMINKATTI_110	8:13	8:17	0:04	LINE FAULT
317	27-Dec-19	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	6:27	14:40	8:13	LINE FAULT
318	27-Dec-19	BAGALKOT	220	SHARAVATHY1-SIRSI	SIRSI_220	12:19	14:29	2:10	LINE CLEAR AVAILED
319	27-Dec-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	0:00	12:19	12:19	LINE CLEAR AVAILED
320	27-Dec-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	14:29	23:59	9:30	LINE CLEAR AVAILED
321	27-Dec-19	BAGALKOT	220	SHIROLKOPPA(BELLIGAVI)-RANEBENNUR	RANEBENNUR_220	0:00	8:10	8:10	LINE CLEAR AVAILED
322	27-Dec-19	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	8:05	8:43	0:38	HAND TRIPPED
323	27-Dec-19	BAGALKOT	220	SHIROLKOPPA(BELLIGAVI)-RANEBENNUR	RANEBENNUR_220	9:17	23:59	14:42	LINE CLEAR AVAILED
324	27-Dec-19	BAGALKOT	66	110/33KV,HV4	HARIHAR HOSPET_66,MUDENUR_33	7:24	7:56	0:32	LOAD CURTAILMENT
325	27-Dec-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	16:53	17:28	0:35	LINE CLEAR AVAILED
326	27-Dec-19	BAGALKOT	110	110/33KV,HV1	YARAGATTI_110,SHIVAPUR_33,CHUNCHNUR_33KV,BOSCH_33	16:53	17:03	0:10	LINE CLEAR AVAILED
327	27-Dec-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	7:24	7:44	0:20	LOAD CURTAILMENT
328	27-Dec-19	BAGALKOT	220	220/110KV ,HV2 & LV2	HUBLI_220	10:31	13:55	3:24	LINE CLEAR AVAILED
329	27-Dec-19	BAGALKOT	220	220/110KV ,HV1 & LV1	HUBLI_220	9:17	13:53	4:36	LINE CLEAR AVAILED
330	27-Dec-19	BAGALKOT	220	HUBLI-NARENDRA 1	HUBLI_220	0:00	10:31	10:31	LINE CLEAR AVAILED
331	27-Dec-19	BAGALKOT	110	SOUDATTI220-YARAGATTI	YARAGATTI_110	10:13	16:47	6:34	LINE CLEAR AVAILED
332	27-Dec-19	BAGALKOT	110	SOUDATTI220-RAMDURGA 1	RAMDURGA_110	18:13	19:08	0:55	LINE FAULT
333	27-Dec-19	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT) CHANDRAPPA CIRCLE	11:20	11:30	0:10	MAIN SUPPLY FAILURE
334	27-Dec-19	BENGALURU	66	HV2	KHB	10:12	10:15	0:03	LINE CLEAR AVAILED
335	27-Dec-19	BENGALURU	66	HV1	JANGAMKOTE	17:29	17:35	0:05	LINE CLEAR AVAILED
336	27-Dec-19	BENGALURU	66	HV2	BANASWADI	12:15	12:24	0:09	TRANSFORMER FAULT
337	27-Dec-19	BENGALURU	66	HV1	D CROSS	14:21	14:38	0:16	LINE CLEAR AVAILED
338	27-Dec-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:16	14:24	4:08	LINE CLEAR AVAILED
339	27-Dec-19	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	KORMANGALA 220	7:39	11:20	3:40	LINE FAULT
340	27-Dec-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	7:57	8:02	0:04	HAND TRIPPED
341	27-Dec-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	11:12	11:18	0:06	HAND TRIPPED
342	27-Dec-19	BENGALURU	220	HSR LAYOUT 220 - HOODY 220	HSR LAYOUT 220	7:39	10:56	3:16	LINE FAULT
343	27-Dec-19	BENGALURU	66	JANGAMAKOTE - VIJAYAPURA	JANGAMAKOTE	10:05	17:29	7:24	MAIN SUPPLY FAILURE
344	27-Dec-19	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	SHIVANAHALLI, CHANNAPATNA,	15:19	15:21	0:01	LINE CLEAR AVAILED
345	27-Dec-19	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	10:26	10:30	0:03	HAND TRIPPED
346	27-Dec-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	8:03	8:13	0:10	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
348	27-Dec-19	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI, BIJJAHALLI	15:56	16:00	0:03	LINE FAULT
349	27-Dec-19	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI, BIJJAHALLI	16:18	16:20	0:01	LINE CLEAR AVAILED
350	27-Dec-19	BENGALURU	66	HV3	ADUGODI	11:31	11:36	0:05	LOAD CHANGE OVER
351	27-Dec-19	BENGALURU	66	HV1	AMARJYOTHI	11:33	11:38	0:05	LOAD CHANGE OVER
352	27-Dec-19	BENGALURU	66	AMARJYOTHI - KORAMANGALA	AMARJYOTHI	7:40	8:15	0:35	LOAD CHANGE OVER
353	27-Dec-19	BENGALURU	66	AMARJYOTHI - LEELA VENTURE	AMARJYOTHI	11:30	11:35	0:05	LOAD CHANGE OVER
354	27-Dec-19	BENGALURU	66	SOUTH CITY - KHODAYS	SOUTH CITY	11:12	11:16	0:04	LOAD CHANGE OVER
355	27-Dec-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	7:10	7:15	0:04	LINE FAULT
356	27-Dec-19	BENGALURU	66	DEVANAHALLI - DB PURA 1	DEVANAHALLI	9:08	18:45	9:36	LINE CLEAR AVAILED
357	27-Dec-19	GULBARGA	220	LINGAPUR-GUDAHALLI1	LINGAPUR_220	10:14	14:34	4:20	LINE CLEAR AVAILED
358	27-Dec-19	GULBARGA	220	LINGAPUR-MUNIRABAD2	MUNIRABAD_220	11:06	15:24	4:18	LINE CLEAR AVAILED
359	27-Dec-19	GULBARGA	220	HV1	HALBARGA_220	14:38	15:45	1:07	LINE CLEAR AVAILED
360	27-Dec-19	GULBARGA	220	KUSTAGI-SUZLON1_IPP,SUZLON2_IPP	KUSTAGI_220	9:12	12:49	3:37	LINE CLEAR AVAILED
361	27-Dec-19	GULBARGA	110	HALBURGA-ACMESOLAR_IPP	HALBARGA_220	8:46	8:51	0:05	LINE FAULT
362	27-Dec-19	GULBARGA	110	HALBURGA-HUMNABAD1	HALLIKHED_110	9:33	9:38	0:05	LINE FAULT
363	27-Dec-19	GULBARGA	110	HV3	AFZALPUR_110	4:05	4:15	0:10	TRANSFORMER FAULT
364	27-Dec-19	GULBARGA	110	KEMBHAVI-SHAHPUR	KEMBHAVI_110, UGARSUGARS_IPP	2:05	2:10	0:05	LINE FAULT
365	27-Dec-19	GULBARGA	110	HV1	MAHAGOAN_110	7:15	7:20	0:05	LOAD CURTAILMENT
366	27-Dec-19	GULBARGA	110	HV1,HV2	RAJESHWAR_110	7:14	7:32	0:18	LOAD CURTAILMENT
367	27-Dec-19	GULBARGA	110	HV3	SIRUGUPPA_110	15:05	15:15	0:10	TRANSFORMER FAULT
368	27-Dec-19	GULBARGA	110	HV3	TEKKALAKOTE_110	11:25	11:40	0:15	TRANSFORMER FAULT
369	27-Dec-19	GULBARGA	110	WADI-SHAHBAD	WADI_110	8:46	8:51	0:05	LINE CLEAR AVAILED
370	27-Dec-19	GULBARGA	110	SINDHANOOR220-PGLR_WIND_IPP	SIDHANOOR_220	0:07	0:17	0:10	LINE FAULT
371	27-Dec-19	GULBARGA	110	SINDHANOOR220-PGLR_WIND_IPP	SIDHANOOR_220	13:33	15:33	2:00	LINE CLEAR AVAILED
372	27-Dec-19	GULBARGA	110	HV2	TAMBRAHALLI_66	8:15	8:22	0:07	TRANSFORMER FAULT
373	27-Dec-19	GULBARGA	110	HV2	TAMBRAHALLI_66	8:30	8:40	0:10	TRANSFORMER FAULT
374	27-Dec-19	GULBARGA	110	LINGASUGUR-RTPS1	LINGASUGUR_220	11:40	17:50	6:10	LINE CLEAR AVAILED
375	27-Dec-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	11:24	11:35	0:11	TRANSFORMER FAULT
376	27-Dec-19	GULBARGA	110	KOLHAR-HALBARGA	KOLHAR_110	14:10	14:20	0:10	LINE FAULT
377	27-Dec-19	GULBARGA	110	KOLHAR-HALBARGA	KOLHAR_110	14:10	14:15	0:05	LINE FAULT
378	27-Dec-19	GULBARGA	66	KEMBHAVI-UGARSUGARS_IPP	UGARSUGARS_IPP	7:13	7:20	0:07	LOAD CURTAILMENT
379	27-Dec-19	GULBARGA	66	KOGALI-ATRIASOLAR_IPP	KOGALI_66	18:10	20:04	1:54	LINE CLEAR AVAILED
380	27-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	6:08	6:08	LINE CLEAR AVAILED
381	27-Dec-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	0:00	11:58	11:58	LINE FAULT
382	27-Dec-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	0:00	11:58	11:58	LINE FAULT
383	27-Dec-19	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	12:22	14:30	2:08	LINE CLEAR AVAILED
384	27-Dec-19	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	6:27	14:40	8:13	LINE FAULT
385	27-Dec-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:20	10:23	0:03	HAND TRIPPED
386	27-Dec-19	HASSAN	110	HV1	ARASIKERE_220	12:17	14:53	2:36	LINE CLEAR AVAILED
387	27-Dec-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	3:21	3:27	0:06	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
388	27-Dec-19	HASSAN	110	BARANG-ANVATTI	BARANGI_110	12:32	12:38	0:06	LINE FAULT
389	27-Dec-19	HASSAN	110	BARANG-ANVATTI	BARANGI_110	13:05	13:11	0:06	LINE FAULT
390	27-Dec-19	HASSAN	110	HV2	GERUMARA_110	7:12	7:46	0:34	TRANSFORMER FAULT
391	27-Dec-19	HASSAN	110	KADUR-NGNHL	KADUR_220	10:28	13:26	2:58	NFBC ISSUED
392	27-Dec-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:13	20:44	11:31	NFBC ISSUED
393	27-Dec-19	HASSAN	110	SAGARA-JST1	SAGARA_110	11:37	11:54	0:17	HAND TRIPPED
394	27-Dec-19	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	17:54	18:26	0:32	MAIN SUPPLY FAILURE
395	27-Dec-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	17:54	18:53	0:59	MAIN SUPPLY FAILURE
396	27-Dec-19	HASSAN	110	HV1	BRAHMAVARA_110	7:14	7:29	0:15	MAIN SUPPLY FAILURE
397	27-Dec-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	13:08	15:06	1:58	LINE CLEAR AVAILED
398	27-Dec-19	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	11:29	15:05	3:36	LINE FAULT
399	27-Dec-19	HASSAN	66	HV2	CHIKMAGALUR_66	12:05	14:28	2:23	LINE CLEAR AVAILED
400	27-Dec-19	HASSAN	66	DIDIGA-CRPATNA	DIDIGA_66	10:31	13:06	2:35	LINE CLEAR AVAILED
401	27-Dec-19	HASSAN	66	HV1	DIDIGA_66	10:28	13:06	2:38	LINE CLEAR AVAILED
402	27-Dec-19	HASSAN	66	HV1	DODDAKADANUR_66	15:38	15:41	0:03	TRANSFORMER FAULT
403	27-Dec-19	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMAGALUR_66	12:03	14:27	2:24	LINE CLEAR AVAILED
404	27-Dec-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:36	12:05	0:29	MAIN SUPPLY FAILURE
405	27-Dec-19	HASSAN	66	HV1	MAGGE_66	11:52	12:05	0:13	MAIN SUPPLY FAILURE
406	27-Dec-19	HASSAN	66	HV2	MAGGE_66	11:52	12:08	0:16	MAIN SUPPLY FAILURE
407	27-Dec-19	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	11:37	12:29	0:52	LINE CLEAR AVAILED
408	27-Dec-19	HASSAN	66	HV2	SALAGAME_66	11:25	13:17	1:52	TRANSFORMER FAULT
409	27-Dec-19	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	13:25	13:28	0:03	HAND TRIPPED
410	27-Dec-19	HASSAN	66	HV1	UDAYAPURA_66	13:28	13:42	0:14	HAND TRIPPED
411	27-Dec-19	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	13:28	13:36	0:08	HAND TRIPPED
412	27-Dec-19	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	0:00	14:06	14:06	LINE CLEAR AVAILED
413	27-Dec-19	HASSAN	66	KIADB H-HASAN I\C	KIADB_66	12:04	15:08	3:04	MAIN SUPPLY FAILURE
414	27-Dec-19	MYSORE	66	HV1	BOMMALAPURA_66	11:55:00	13:43:45	1:48:45	LINE CLEAR AVAILED
415	27-Dec-19	MYSORE	66	HV2	BOOKANAKERE_66	13:12:02	13:19:11	0:07:09	TRANSFORMER FAULT
416	27-Dec-19	MYSORE	66	HV1	DUNDANAHALLI_66	16:00:00	16:25:12	0:25:12	LINE CLEAR AVAILED
417	27-Dec-19	MYSORE	66	FTS-RAJEEV NAGARA	FTS_66 BANNIMANTAP_66 JYOTHINAGARA_66	16:58:04	17:15:00	0:16:56	HAND TRIPPED
419	27-Dec-19	MYSORE	66	HALAGURU-HONAGANAHALLI	HALAGUR_66	10:55:30	11:32:58	0:37:28	HAND TRIPPED
423	27-Dec-19	MYSORE	66	HV2	HAMPAPURA_66	9:33:50	14:31:00	4:57:10	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
424	27-Dec-19	MYSORE	66	HV1	HANAGODU_66	10:00:00	19:06:56	9:06:56	LINE CLEAR AVAILED
425	27-Dec-19	MYSORE	66	HV2	HANAGODU_66	10:00:00	19:06:56	9:06:56	LINE CLEAR AVAILED
426	27-Dec-19	MYSORE	66	HV1	HAMPAPURA_66	9:42:00	14:30:00	4:48:00	LINE CLEAR AVAILED
427	27-Dec-19	MYSORE	66	HV1	HANNUR_66	11:45:05	14:06:19	2:21:14	LINE CLEAR AVAILED
428	27-Dec-19	MYSORE	66	HV2	HANNUR_66	12:59:55	14:29:30	1:29:35	LINE CLEAR AVAILED
429	27-Dec-19	MYSORE	66	HV1	JAKKANAHALLY_66	10:00:00	14:59:20	4:59:20	LINE CLEAR AVAILED
430	27-Dec-19	MYSORE	66	HV2	JAKKANAHALLY_66	10:00:00	14:59:20	4:59:20	LINE CLEAR AVAILED
432	27-Dec-19	MYSORE	66	KIRUGAVLU-MALIYURU	KIRUGAVLU_66	13:40:00	13:55:02	0:15:02	LINE FAULT
433	27-Dec-19	MYSORE	66	KIRUGAVLU-VADKEPURA	KIRUGAVLU_66	13:40:00	13:55:02	0:15:02	LINE FAULT
434	27-Dec-19	MYSORE	66	MEGHALAPURA-SFC	THUMBLA_66 CHIDRAVALLI_66	11:20:00	14:10:14	2:50:14	NFBC ISSUED
435	27-Dec-19	MYSORE	66	HV2	PANDAVAPURA_66	9:10:07	16:24:08	7:14:01	TRANSFORMER FAULT
436	27-Dec-19	MYSORE	66	HV2	PANDAVAPURA_66	16:38:00	16:53:49	0:15:49	LINE CLEAR AVAILED
438	27-Dec-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:19:17	18:26:54	8:07:37	LINE CLEAR AVAILED
439	27-Dec-19	MYSORE	66	HV2	SANTHESARAGUR_66	10:19:17	18:26:54	8:07:37	LINE CLEAR AVAILED
440	27-Dec-19	MYSORE	66	TUBINAKERE-G UKKADA	GARUDANAUKADDA_66	10:52:47	16:33:19	5:40:32	NFBC ISSUED
441	27-Dec-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	9:06:39	9:13:45	0:07:06	LINE FAULT
442	27-Dec-19	MYSORE	66	VAJMANGALA-DKMAIDAN	FTS_66 BANNIMANTAP_66 JYOTHINAGARA_66	16:38:00	16:49:00	0:11:00	LINE FAULT
443	27-Dec-19	MYSORE	66	VAJMANGALA-DKMAIDAN	FTS_66 BANNIMANTAP_66 JYOTHINAGARA_66	16:49:50	17:08:45	0:18:55	LINE FAULT
444	27-Dec-19	TUMKUR	400	TR-1(HV SIDE)	GUTUR_400	12:39	15:14	2:35	LINE CLEAR AVAILED
445	27-Dec-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	13:22	16:37	3:14	LINE FAULT
446	27-Dec-19	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	15:11	16:08	0:57	LINE CLEAR AVAILED
447	27-Dec-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:21	16:31	3:10	LINE FAULT
448	27-Dec-19	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	20:54	22:04	1:09	LINE CLEAR AVAILED
449	27-Dec-19	TUMKUR	110	TR-1	KGTEMPLE_110	12:17	13:49	1:32	LINE CLEAR AVAILED
450	27-Dec-19	TUMKUR	110	K G TEMPLE-NITTUR220	KGTEMPLE_110	12:55	13:49	0:53	LINE CLEAR AVAILED
451	27-Dec-19	TUMKUR	110	K G TEMPLE-UNGRDLI	KGTEMPLE_110	12:55	13:50	0:54	LINE CLEAR AVAILED
452	27-Dec-19	TUMKUR	66	TR-1(HV SIDE)	ANCHEPALYA_220	15:11	16:10	0:59	LINE CLEAR AVAILED
453	27-Dec-19	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	12:32	12:36	0:04	TRANSFORMER FAULT
454	27-Dec-19	TUMKUR	66	TR-2	HINDASGHATTA_66	16:04	16:29	0:25	TRANSFORMER FAULT
455	27-Dec-19	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	12:07	13:26	1:18	LINE CLEAR AVAILED
456	27-Dec-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	9:20	16:16	6:55	LINE FAULT
457	27-Dec-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	17:59	18:02	0:03	HAND TRIPPED
458	27-Dec-19	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	16:22	16:30	0:07	LINE CLEAR AVAILED
459	27-Dec-19	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	18:06	18:16	0:10	MAIN SUPPLY FAILURE
460	28-Dec-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	9:08	14:43	5:35	LINE CLEAR AVAILED
461	28-Dec-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	11:57	14:20	2:23	LINE FAULT
462	28-Dec-19	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_220	11:35	14:56	3:21	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
463	28-Dec-19	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	11:35	14:56	3:21	LINE CLEAR AVAILED
464	28-Dec-19	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	15:09	15:48	0:39	HAND TRIPPED
465	28-Dec-19	BAGALKOT	110	110/33KV, HV4	ANKALI_110, KOTAWADI_33	6:20	6:45	0:25	TRANSFORMER FAULT
466	28-Dec-19	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	0:00	14:14	14:14	LINE CLEAR AVAILED
467	28-Dec-19	BAGALKOT	110	BELGAUM220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	10:51	17:02	6:11	LINE CLEAR AVAILED
468	28-Dec-19	BAGALKOT	110	110/11KV, HV1	KANABARGI LAYOUT_110	9:49	17:21	7:32	LINE CLEAR AVAILED
469	28-Dec-19	BAGALKOT	110	110/11KV, HV4	KANABARGI LAYOUT_110	9:49	17:31	7:42	LINE CLEAR AVAILED
470	28-Dec-19	BAGALKOT	110	MAHALINGAPUR-MALALI	MALALI_110	11:22	11:30	0:08	LINE FAULT
471	28-Dec-19	BAGALKOT	110	110/33KV, HV3	MAMDAPUR(B)_110, LINGADALLI_33, DEVARGENNUR_33	15:30	16:40	1:10	LINE CLEAR AVAILED
472	28-Dec-19	BAGALKOT	66	DAVANAGERE-HARIHAR HOSPET	HARIHAR HOSPET_66	8:05	8:10	0:05	MAIN SUPPLY FAILURE
473	28-Dec-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	10:07	10:25	0:18	TRANSFORMER FAULT
474	28-Dec-19	BAGALKOT	110	YARAGATTI-KATAKOL	YARAGATTI_110,BENAKATTI_110	21:25	21:33	0:08	HAND TRIPPED
475	28-Dec-19	BAGALKOT	110	UCHAGOAN-UDAYMBAG	UDAYMBAG_110	10:30	14:23	3:53	LINE CLEAR AVAILED
476	28-Dec-19	BAGALKOT	110	110/11KV,HV1& HV2	UCHGOAN_110	10:28	14:28	4:00	LINE CLEAR AVAILED
477	28-Dec-19	BAGALKOT	110	UCHAGOAN-BELGAUM	UCHGOAN_110	10:33	14:28	3:55	LINE CLEAR AVAILED
478	28-Dec-19	BAGALKOT	110	UCHAGOAN-UDAYMBAG	UCHGOAN_110	10:24	14:28	4:04	LINE CLEAR AVAILED
479	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	11:38	11:41	0:03	MAIN SUPPLY FAILURE
480	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	11:38	11:41	0:03	MAIN SUPPLY FAILURE
481	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	11:38	11:41	0:03	MAIN SUPPLY FAILURE
482	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	11:38	11:41	0:03	MAIN SUPPLY FAILURE
483	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	11:38	11:41	0:03	MAIN SUPPLY FAILURE
484	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	11:38	11:41	0:03	MAIN SUPPLY FAILURE
485	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	11:38	11:41	0:03	MAIN SUPPLY FAILURE
486	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	11:38	11:41	0:03	MAIN SUPPLY FAILURE
487	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	11:38	11:41	0:03	MAIN SUPPLY FAILURE
488	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	13:04	13:07	0:03	MAIN SUPPLY FAILURE
489	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	13:04	13:07	0:03	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
490	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	13:04	13:07	0:03	MAIN SUPPLY FAILURE
491	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	13:04	13:07	0:03	MAIN SUPPLY FAILURE
492	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	13:04	13:07	0:03	MAIN SUPPLY FAILURE
493	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:04	13:07	0:03	MAIN SUPPLY FAILURE
494	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	13:04	13:07	0:03	MAIN SUPPLY FAILURE
495	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	13:04	13:07	0:03	MAIN SUPPLY FAILURE
496	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	13:04	13:07	0:03	MAIN SUPPLY FAILURE
497	28-Dec-19	BENGALURU	66	D CROSS - DB PURA 220	D CROSS	7:51	7:55	0:04	MAIN SUPPLY FAILURE
498	28-Dec-19	BENGALURU	66	D CROSS - DB PURA 220	D CROSS	10:07	10:17	0:10	MAIN SUPPLY FAILURE
499	28-Dec-19	BENGALURU	66	D CROSS - DB PURA 220	D CROSS	10:18	11:07	0:49	MAIN SUPPLY FAILURE
500	28-Dec-19	BENGALURU	66	D CROSS - DB PURA 220	D CROSS	15:03	15:20	0:17	MAIN SUPPLY FAILURE
501	28-Dec-19	BENGALURU	66	HV2	PADMANBHANAGAR	9:52	9:58	0:06	HAND TRIPPED
502	28-Dec-19	BENGALURU	66	HV2	EPIP 220	11:17	13:36	2:18	TRANSFORMER FAULT
503	28-Dec-19	BENGALURU	66	DEVANAHALLI - DB PURA 1	DEVANAHALLI	16:40	17:30	0:50	LINE CLEAR AVAILED
504	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	23:13	23:18	0:05	LINE FAULT
505	28-Dec-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	23:13	23:18	0:05	LINE FAULT
506	28-Dec-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	8:50	8:58	0:08	LINE FAULT
507	28-Dec-19	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	8:27	16:26	7:58	LINE CLEAR AVAILED
508	28-Dec-19	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	6:08	6:18	0:10	LINE FAULT
509	28-Dec-19	GULBARGA	220	ITTAGI-LINGAPUR	ITTAGI_220	13:58	15:20	1:22	LINE FAULT
510	28-Dec-19	GULBARGA	110	HV2	MAHAGOAN_110	12:38	13:15	0:37	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
511	28-Dec-19	GULBARGA	110	HV3	BEVOOR_110	1:15	1:23	0:08	TRANSFORMER FAULT
512	28-Dec-19	GULBARGA	110	LV1	ITTAGI_220	13:58	15:29	1:31	TRANSFORMER FAULT
513	28-Dec-19	GULBARGA	110	LV2	ITTAGI_220	13:58	15:35	1:37	TRANSFORMER FAULT
514	28-Dec-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	20:42	20:52	0:10	HAND TRIPPED
515	28-Dec-19	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	20:43	21:01	0:18	HAND TRIPPED
516	28-Dec-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	20:42	21:01	0:19	HAND TRIPPED
517	28-Dec-19	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	20:28	23:59	3:31	LINE FAULT
518	28-Dec-19	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	0:00	3:27	3:27	LINE FAULT
519	28-Dec-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	20:28	20:58	0:30	LINE FAULT
520	28-Dec-19	HASSAN	110	HV2	MSEZ_220	20:17	21:06	0:49	TRANSFORMER FAULT
521	28-Dec-19	HASSAN	110	HV1	BAIKAMPADY_110	20:45	21:05	0:20	MAIN SUPPLY FAILURE
522	28-Dec-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:09	17:18	0:09	HAND TRIPPED
523	28-Dec-19	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	10:39	10:55	0:16	LINE FAULT
524	28-Dec-19	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	12:56	14:42	1:46	LINE CLEAR AVAILED
525	28-Dec-19	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:38	10:55	0:17	LINE FAULT
526	28-Dec-19	HASSAN	66	HV2	SALAGAME_66	9:36	10:16	0:40	TRANSFORMER FAULT
527	28-Dec-19	HASSAN	66	HV2	SALAGAME_66	14:39	15:06	0:27	TRANSFORMER FAULT
528	28-Dec-19	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	5:17	5:24	0:07	LINE FAULT
529	28-Dec-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:40	12:04	0:24	TRANSFORMER FAULT
530	28-Dec-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	3:19	10:02	6:42	LINE CLEAR AVAILED
531	28-Dec-19	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	14:50	16:02	1:12	LINE FAULT
532	28-Dec-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	10:11	11:10	0:59	LINE CLEAR AVAILED
533	28-Dec-19	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	TIMMANAHALLI_110, HANDANKERE_110,	10:11	11:10	0:59	LINE CLEAR AVAILED
534	28-Dec-19	TUMKUR	66	TR-2	CHELURU_66	8:14	9:00	0:45	TRANSFORMER FAULT
535	28-Dec-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	19:14	19:20	0:06	LINE FAULT
536	28-Dec-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:46	7:01	0:15	LINE FAULT
537	28-Dec-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	22:44	22:59	0:15	HAND TRIPPED
538	28-Dec-19	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	22:36	22:44	0:07	LINE FAULT
539	28-Dec-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	22:44	22:59	0:15	HAND TRIPPED
540	28-Dec-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVAINAGI_66, BASAVAPATNA_66, SANTERENNIUR_66	12:04	12:16	0:12	LINE FAULT
541	28-Dec-19	TUMKUR	66	TR-1	MYLANAHALLI_66	10:29	10:43	0:13	TRANSFORMER FAULT
542	28-Dec-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	14:49	14:53	0:03	MAIN SUPPLY FAILURE
543	28-Dec-19	TUMKUR	66	THALLAK 220KV- SET DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	6:16	7:08	0:52	LINE FAULT
544	28-Dec-19	TUMKUR	66	THALLAK 220kv- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	7:21	9:43	2:22	LINE CLEAR AVAILED
545	29-Dec-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	12:22	12:31	0:09	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
546	29-Dec-19	BAGALKOT	110	110/11KV, HV1	HIREKERUR_110	15:43	16:01	0:18	TRANSFORMER FAULT
547	29-Dec-19	BAGALKOT	110	HAVERI220-KNL_LIS	HAVERI_220	0:00	11:53	11:53	LINE CLEAR AVAILED
548	29-Dec-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	14:48	14:51	0:03	TRANSFORMER FAULT
549	29-Dec-19	BAGALKOT	110	SHIRGUPPI SUGARS-KAGAWAD	KAGAWAD_110	12:22	12:32	0:10	LINE FAULT
550	29-Dec-19	BAGALKOT	220	KUDACHI-MAHALINGAPUR2	KUDACHI_220	12:23	12:55	0:32	LINE FAULT
551	29-Dec-19	BAGALKOT	110	SUVARNA SOUDA-MACHE	MACHE_110	11:40	16:05	4:25	LINE CLEAR AVAILED
552	29-Dec-19	BAGALKOT	110	ASHOKA IRON PLANT-MACHE	MACHE_110	9:52	16:03	6:11	LINE CLEAR AVAILED
553	29-Dec-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	0:00	11:49	11:49	LINE CLEAR AVAILED
554	29-Dec-19	BAGALKOT	66	110/33KV,HV4	HARIHAR HOSPET_66,MUDENUR_33	14:05	14:20	0:15	TRANSFORMER FAULT
555	29-Dec-19	BAGALKOT	110	UCHAGOAN-UDAYMBAG	UDAYMBAG_110	15:30	16:00	0:30	MAIN SUPPLY FAILURE
556	29-Dec-19	BAGALKOT	110	HATTARAGI-UCHAGOAN	UCHGOAN_110	15:30	16:00	0:30	MAIN SUPPLY FAILURE
557	29-Dec-19	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_IPP	5:18	5:25	0:07	LINE FAULT
558	29-Dec-19	BAGALKOT	220	HUBLI-SIRSI 1& 2	HUBLI_220	11:53	23:59	12:06	LINE CLEAR AVAILED
559	29-Dec-19	BAGALKOT	110	110/11KV,HV1 &HV2	SAIDAPUR_110	6:56	12:42	5:46	LINE CLEAR AVAILED
560	29-Dec-19	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT) CHANDRAPPA CIRCLE	10:10	10:15	0:05	LOAD CHANGE OVER
561	29-Dec-19	BENGALURU	66	KUMBALAGODU - KENGERT SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT) CHANDRAPPA CIRCLE	18:12	18:15	0:03	LOAD CHANGE OVER
562	29-Dec-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	17:10	17:15	0:05	HAND TRIPPED
563	29-Dec-19	BENGALURU	66	HV1	JIGANI 66	9:00	9:17	0:17	HAND TRIPPED
564	29-Dec-19	BENGALURU	66	HV1	JIGANI LINK ROAD	13:15	14:25	1:10	LINE CLEAR AVAILED
565	29-Dec-19	BENGALURU	66	HV1	BANGARPET	13:22	13:30	0:08	TRANSFORMER FAULT
566	29-Dec-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	1:41	1:52	0:11	LINE FAULT
567	29-Dec-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	1:41	1:52	0:11	LINE FAULT
568	29-Dec-19	BENGALURU	66	HV1	T K HALLI 220	6:19	6:22	0:03	TRANSFORMER FAULT
569	29-Dec-19	BENGALURU	66	HV1	T K HALLI 220	15:16	15:24	0:08	TRANSFORMER FAULT
570	29-Dec-19	GULBARGA	110	HV3	BEVOOR_110	14:36	14:42	0:06	TRANSFORMER FAULT
571	29-Dec-19	GULBARGA	110	HV3	BEVOOR_110	16:27	16:32	0:05	TRANSFORMER FAULT
572	29-Dec-19	GULBARGA	110	HV2	MAHAGOAN_110	16:00	16:35	0:35	LINE CLEAR AVAILED
573	29-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:43	23:59	0:16	HAND TRIPPED
574	29-Dec-19	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	0:00	3:30	3:30	LINE FAULT
575	29-Dec-19	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	20:28	23:59	3:31	LINE FAULT
576	29-Dec-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:45	18:10	8:25	NFBC ISSUED
577	29-Dec-19	HASSAN	66	HV1	CHIKMAGALUR_66	11:28	12:56	1:28	LINE CLEAR AVAILED
578	29-Dec-19	HASSAN	66	HV1	SAKLESH PURA_66	10:42	14:55	4:13	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
579	29-Dec-19	HASSAN	66	HV2	SALAGAME_66	0:59	1:04	0:05	TRANSFORMER FAULT
580	29-Dec-19	HASSAN	66	HV2	SALAGAME_66	3:27	3:34	0:07	TRANSFORMER FAULT
581	29-Dec-19	HASSAN	66	HV2	SALAGAME_66	14:20	14:27	0:07	TRANSFORMER FAULT
582	29-Dec-19	HASSAN	66	HV2	SALAGAME_66	20:33	23:59	3:26	TRANSFORMER FAULT
583	29-Dec-19	HASSAN	66	HV2	BASAVAGHATTA_66	10:21	12:08	1:47	TRANSFORMER FAULT
584	29-Dec-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	2:47	6:42	3:55	LINE CLEAR AVAILED
585	29-Dec-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	11:46	12:23	0:36	LINE CLEAR AVAILED
586	29-Dec-19	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	TIMMANAHALLI_110, HANDANKERE_110,	11:46	12:22	0:36	LINE CLEAR AVAILED
587	29-Dec-19	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	1:32	1:48	0:15	HAND TRIPPED
588	29-Dec-19	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	5:36	5:47	0:10	HAND TRIPPED
589	29-Dec-19	TUMKUR	110	NITTUR 220kv- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	12:14	12:28	0:13	HAND TRIPPED
590	29-Dec-19	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	12:58	13:00	0:02	MAIN SUPPLY FAILURE
591	29-Dec-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	15:55	16:04	0:09	LINE FAULT
592	29-Dec-19	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	15:26	16:05	0:38	LINE CLEAR AVAILED
593	29-Dec-19	TUMKUR	66	TR-1	KATTIGE_66	16:02	16:08	0:06	TRANSFORMER FAULT
594	29-Dec-19	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66 VENKATAPURA_66	7:42	8:00	0:18	LINE FAULT
595	29-Dec-19	TUMKUR	66	TR-1	MYLANAHALLI_66	6:45	7:03	0:18	TRANSFORMER FAULT
596	29-Dec-19	TUMKUR	66	YEDIYUR- BGNAGARA_66	BGNAGARA_66	10:54	10:55	0:00	LINE FAULT
597	30-Dec-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	12:19	13:27	1:08	LINE CLEAR AVAILED
598	30-Dec-19	BAGALKOT	220	AMBEWADI-NAGJHARI1	AMBEWADI_220	14:40	15:40	1:00	LINE CLEAR AVAILED
599	30-Dec-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	22:24	23:59	1:35	LINE FAULT
600	30-Dec-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	12:49	13:12	0:23	LINE CLEAR AVAILED
601	30-Dec-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	12:49	13:27	0:38	LINE CLEAR AVAILED
602	30-Dec-19	BAGALKOT	110	110/11KV,HV2	KIADB BIJAPUR_110	10:28	11:11	0:43	LINE CLEAR AVAILED
603	30-Dec-19	BAGALKOT	220	ADPH1&2-BAGEWADI	BAGEWADI_220	10:11	11:29	1:18	LINE CLEAR AVAILED
604	30-Dec-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_220	18:05	18:20	0:15	LINE FAULT
605	30-Dec-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	13:13	23:59	10:46	LINE CLEAR AVAILED
606	30-Dec-19	BAGALKOT	110	110/11KV,HV1	MALGHAN(B)_110	17:20	18:00	0:40	TRANSFORMER FAULT
607	30-Dec-19	BAGALKOT	110	HUBLI220-KADANAKOPPA	KADANAKOPPA_110	10:26	10:53	0:27	LINE FAULT
608	30-Dec-19	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	10:13	10:24	0:11	TRANSFORMER FAULT
609	30-Dec-19	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	12:22	13:45	1:23	TRANSFORMER FAULT
610	30-Dec-19	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	13:27	17:11	3:44	LINE FAULT
611	30-Dec-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	14:30	17:35	3:05	LINE CLEAR AVAILED
612	30-Dec-19	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	12:07	13:06	0:59	LINE CLEAR AVAILED
613	30-Dec-19	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	11:14	12:33	1:19	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
614	30-Dec-19	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	12:54	13:19	0:25	LINE CLEAR AVAILED
615	30-Dec-19	BAGALKOT	220	220/110KV,HV3,LV3	HUBLI_220	13:09	13:27	0:18	LINE CLEAR AVAILED
616	30-Dec-19	BAGALKOT	110	HUBLI220-PH COMPOUND	PH COMPOUND_110	12:34	12:35	0:01	HAND TRIPPED
617	30-Dec-19	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	12:43	13:03	0:20	LINE FAULT
618	30-Dec-19	BAGALKOT	110	HUBLI-TARIHAL2	TARIHAL_110	12:36	12:37	0:01	HAND TRIPPED
619	30-Dec-19	BAGALKOT	110	HUBLI-ANANDNAGAR	ANANDNAGAR_110	12:39	12:52	0:13	HAND TRIPPED
620	30-Dec-19	BAGALKOT	110	HUBLI-RAMANAKOPPA	RAMANAKOPPA_110	12:42	12:58	0:16	LINE FAULT
621	30-Dec-19	BAGALKOT	110	110/33KV,HV2	SADALAGA_110,BHOJ_110	12:58	13:32	0:34	LINE CLEAR AVAILED
622	30-Dec-19	BAGALKOT	110	110/11KV,HV1	SANKESHWAR_110	9:34	17:13	7:39	LINE CLEAR AVAILED
623	30-Dec-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	10:02	17:13	7:11	LINE CLEAR AVAILED
624	30-Dec-19	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,KANAGALA_33,HEBBAL_33,ACME SOLAR_33	11:07	11:19	0:12	LINE CLEAR AVAILED
625	30-Dec-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:05	9:13	0:08	LINE FAULT
626	30-Dec-19	BENGALURU	66	GANGIJUNTE - DIBBURAHALLI	DIBBURAHALLI	13:27	13:56	0:29	LINE CLEAR AVAILED
627	30-Dec-19	BENGALURU	66	HV2	BANSHANKARI	13:22	13:25	0:03	LINE CLEAR AVAILED
628	30-Dec-19	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI, SOMANTHPURA	9:40	9:45	0:05	LOAD CHANGE OVER
629	30-Dec-19	BENGALURU	66	BAGEPALLI - PATHPALYA	PATHPALYA, THIMMAMPALLI, SOMANTHPURA	19:25	19:35	0:10	LOAD CHANGE OVER
630	30-Dec-19	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (FHT) CHANDRAPPA CIRCLE	7:41	9:10	1:29	LINE FAULT
631	30-Dec-19	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	5:20	5:30	0:10	LOAD CHANGE OVER
632	30-Dec-19	BENGALURU	66	HV1	VIJAYAPURA	10:32	11:10	0:38	LINE CLEAR AVAILED
633	30-Dec-19	BENGALURU	66	HV1	VIJAYAPURA	13:18	15:02	1:44	LINE CLEAR AVAILED
634	30-Dec-19	GULBARGA	220	RTPS-LINGASUGUR 2	LINGASUGUR_220	10:35	13:35	3:00	LINE CLEAR AVAILED
635	30-Dec-19	GULBARGA	110	HV1	HANUMANAL_110	14:05	14:20	0:15	TRANSFORMER FAULT
636	30-Dec-19	GULBARGA	110	HV1	HANUMANAL_110	14:55	15:00	0:05	TRANSFORMER FAULT
637	30-Dec-19	GULBARGA	110	ALLIPUR-NORTH	SOMASAMUDRA_110,BELLARY NORTH_110, MOKA_110,P.D HALLI_110, BISLHALLI_110, JANAKI_IPP,BASAI STEEL ACC_IPP,	3:58	4:08	0:10	LINE FAULT
638	30-Dec-19	GULBARGA	110	SHAHABAD-BHAHYAWADI 2	YEDRAMI_110,MORATAGI_110	11:15	11:30	0:15	LINE CLEAR AVAILED
639	30-Dec-19	GULBARGA	110	HV2	TEKKALAKOTE_110	4:55	5:00	0:05	TRANSFORMER FAULT
640	30-Dec-19	GULBARGA	110	TEKKELKOTE_SHAHISLR_IPP	TEKKALAKOTE_110	20:00	20:55	0:55	LINE CLEAR AVAILED
641	30-Dec-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	6:20	6:20	LINE CLEAR AVAILED
642	30-Dec-19	HASSAN	110	KADUR-YGTI	KADUR_220	11:32	14:30	2:58	LINE CLEAR AVAILED
643	30-Dec-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:03	16:13	7:10	NFBC ISSUED
644	30-Dec-19	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	10:28	16:51	6:23	LINE CLEAR AVAILED
645	30-Dec-19	HASSAN	66	HV1	HALLIMYSORE_66	11:30	16:59	5:29	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
646	30-Dec-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	15:21	15:44	0:23	MAIN SUPPLY FAILURE
647	30-Dec-19	HASSAN	66	HV1	MAGGE_66	15:23	15:44	0:21	MAIN SUPPLY FAILURE
648	30-Dec-19	HASSAN	66	HV2	MAGGE_66	15:23	15:44	0:21	MAIN SUPPLY FAILURE
649	30-Dec-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	15:06	15:09	0:03	LINE FAULT
650	30-Dec-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	15:24	15:35	0:11	LINE FAULT
651	30-Dec-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	15:12	15:19	0:07	HAND TRIPPED
652	30-Dec-19	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	15:22	15:50	0:28	LINE CLEAR AVAILED
653	30-Dec-19	HASSAN	66	HV2	SALAGAME_66	0:00	11:17	11:17	TRANSFORMER FAULT
654	30-Dec-19	HASSAN	66	HV2	UDAYAPURA_66	15:19	16:16	0:57	LINE CLEAR AVAILED
655	30-Dec-19	MYSORE	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	17:06	17:16	0:09	LINE FAULT
656	30-Dec-19	MYSORE	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	17:31	17:41	0:09	LINE FAULT
657	30-Dec-19	MYSORE	66	HV1	ELAVALA_66	10:30	12:25	1:55	LINE CLEAR AVAILED
658	30-Dec-19	MYSORE	66	HV2	ELAVALA_66	11:22	17:57	6:34	LINE CLEAR AVAILED
662	30-Dec-19	MYSORE	66	HV1	KOLLEGALA_66	13:20	15:31	2:11	LINE CLEAR AVAILED
663	30-Dec-19	MYSORE	66	HV2	KOLLEGALA_66	10:55	13:23	2:28	LINE CLEAR AVAILED
665	30-Dec-19	MYSORE	66	HV1	SATHEGALA_66	10:38	11:08	0:30	LINE CLEAR AVAILED
666	30-Dec-19	MYSORE	66	VAJMANGALA-KADAKOL1	MARADIHUNDI_66 AYRALLI_66	6:33	6:42	0:08	LINE FAULT
668	30-Dec-19	MYSORE	66	HV2	YELANDUR_66	15:35	16:36	1:01	LINE CLEAR AVAILED
669	30-Dec-19	MYSORE	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	17:06	17:16	0:09	LINE FAULT
670	30-Dec-19	MYSORE	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66 MARTAHALLI_66	17:31	17:41	0:09	LINE FAULT
671	30-Dec-19	MYSORE	66	HV1	ELAVALA_66	10:30	12:25	1:55	LINE CLEAR AVAILED
672	30-Dec-19	MYSORE	66	HV2	ELAVALA_66	11:22	17:57	6:34	LINE CLEAR AVAILED
676	30-Dec-19	MYSORE	66	HV1	KOLLEGALA_66	13:20	15:31	2:11	LINE CLEAR AVAILED
677	30-Dec-19	MYSORE	66	HV2	KOLLEGALA_66	10:55	13:23	2:28	LINE CLEAR AVAILED
679	30-Dec-19	MYSORE	66	HV1	SATHEGALA_66	10:38	11:08	0:30	LINE CLEAR AVAILED
680	30-Dec-19	MYSORE	66	VAJMANGALA-KADAKOL1	MARADIHUNDI_66 AYRALLI_66	6:33	6:42	0:08	LINE FAULT
682	30-Dec-19	MYSORE	66	HV2	YELANDUR_66	15:35	16:36	1:01	LINE CLEAR AVAILED
683	30-Dec-19	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	15:48	15:59	0:10	LINE CLEAR AVAILED
684	30-Dec-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	11:13	13:30	2:16	LINE CLEAR AVAILED
685	30-Dec-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS 1	DAVANGERE_SRS_220	11:14	13:31	2:17	LINE CLEAR AVAILED
686	30-Dec-19	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	19:36	21:29	1:53	LINE CLEAR AVAILED
687	30-Dec-19	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	16:03	16:11	0:07	LINE CLEAR AVAILED
688	30-Dec-19	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	15:48	15:59	0:10	LINE CLEAR AVAILED
689	30-Dec-19	TUMKUR	66	TR-2	BELLAVI_66	9:15	9:38	0:23	LINE CLEAR AVAILED
690	30-Dec-19	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	13:27	14:08	0:40	LINE CLEAR AVAILED
691	30-Dec-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:05	14:19	2:14	LINE CLEAR AVAILED
692	30-Dec-19	TUMKUR	66	TR-2	CHIKKABANAGERE_66	12:56	14:32	1:36	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
693	30-Dec-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:05	22:15	0:10	LINE FAULT
694	30-Dec-19	TUMKUR	66	TR-2	GARAGA_66	11:41	14:40	2:59	LINE CLEAR AVAILED
695	30-Dec-19	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	16:59	17:01	0:01	HAND TRIPPED
696	30-Dec-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	22:09	22:20	0:11	LINE FAULT
697	30-Dec-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66 GOPPENAHALLI_66	18:54	19:03	0:08	LINE FAULT
698	30-Dec-19	TUMKUR	66	TR-1	KATTIGE_66	15:20	15:25	0:05	TRANSFORMER FAULT
699	30-Dec-19	TUMKUR	66	TR-1	KORA_66	5:59	6:04	0:05	TRANSFORMER FAULT
700	30-Dec-19	TUMKUR	66	TR-1	MYLANAHALLI_66	6:49	7:43	0:53	TRANSFORMER FAULT
701	30-Dec-19	TUMKUR	66	NITRAHALLI 66 -CLEAN SOLAR	CLEANMAXSOLAR_IPP_66	14:14	14:24	0:10	LINE CLEAR AVAILED
702	30-Dec-19	TUMKUR	66	TR-1	PAVAGADA_66	14:05	14:46	0:40	LINE CLEAR AVAILED
703	30-Dec-19	TUMKUR	66	YEDIYUR- BGNAGARA_66	BGNAGARA_66	15:10	15:15	0:05	LINE CLEAR AVAILED