

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 18.06.2019 TO 24.06.2019**

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	18-Jun-19	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIGATTA_33,SEABIRD_110	11:06	11:36	0:30	LINE CLEAR AVAILED
2	18-Jun-19	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	5:43	6:13	0:30	LINE FAULT
3	18-Jun-19	BAGALKOT	110	110/11KV,HV2	BIDNAL_110	10:23	16:33	6:10	LINE CLEAR AVAILED
4	18-Jun-19	BAGALKOT	110	CHIKKODI220-SANKESHWARA	SANKESHWARA_110	9:36	10:25	0:49	LINE CLEAR AVAILED
5	18-Jun-19	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	11:41	12:28	0:47	LINE CLEAR AVAILED
6	18-Jun-19	BAGALKOT	220	MUDASHINGI-CHIKKODI	CHIKKODI_220	0:00	11:07	11:07	NFBC ISSUED
7	18-Jun-19	BAGALKOT	220	ALMATTI 2-BAGEWADI	BAGEWADI_220	9:38	19:17	9:39	LINE CLEAR AVAILED
8	18-Jun-19	BAGALKOT	220	ATRIA 1-BAGEWADI	BAGEWADI_220	11:24	17:24	6:00	LINE CLEAR AVAILED
9	18-Jun-19	BAGALKOT	110	BAGEWADI 220-MUDDEBIHAL	MUDDEBIHAL_110	12:06	13:36	1:30	LINE CLEAR AVAILED
10	18-Jun-19	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110	11:43	16:27	4:44	LINE CLEAR AVAILED
11	18-Jun-19	BAGALKOT	110	RON1&2-GAJENDRAGAD	GAJENDRAGAD_110	11:58	18:02	6:04	LINE CLEAR AVAILED
12	18-Jun-19	BAGALKOT	110	RON -HIREHAL	HIREHAL_110	12:28	12:34	0:06	LINE CLEAR AVAILED
13	18-Jun-19	BAGALKOT	110	RON -HIREHAL	HIREHAL_110	17:14	17:34	0:20	LOAD CHANGEOVER
14	18-Jun-19	BAGALKOT	110	HIREHAL-BADAMI	BADAMI_110	17:34	17:54	0:20	LOAD CHANGEOVER
15	18-Jun-19	BAGALKOT	110	MY FAIR SOLAR-HIREHAL	HIREHAL_110	17:26	17:35	0:09	LOAD CHANGEOVER
16	18-Jun-19	BAGALKOT	110	110/33KV,HV1	KUMTA_110,ANKOLA_33,HONNAVAR_33	11:50	12:06	0:16	LINE CLEAR AVAILED
17	18-Jun-19	BAGALKOT	110	SOUDATTI220-RAMDURGA1	RAMDURGA_110	12:00	12:56	0:56	LINE FAULT
18	18-Jun-19	BAGALKOT	110	SOUDATTI220-RAMDURGA1	RAMDURGA_110	17:04	19:49	2:45	LINE FAULT
19	18-Jun-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	14:20	14:28	0:08	LINE FAULT
20	18-Jun-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	9:36	10:29	0:53	LINE CLEAR AVAILED
21	18-Jun-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	13:25	13:30	0:05	HAND TRIPPED
22	18-Jun-19	BAGALKOT	110	RON -GAJENDRAGAD 1&2	GAJENDRAGAD_110	12:36	17:58	5:22	LINE CLEAR AVAILED
23	18-Jun-19	BAGALKOT	110	GAMESHA-RON	RON_110	17:10	17:15	0:05	LOAD CHANGEOVER
24	18-Jun-19	BAGALKOT	110	RON - HIREHAL	HIREHAL_110	17:15	17:30	0:15	LOAD CHANGEOVER
25	18-Jun-19	BAGALKOT	110	110/33KV,HV3	RATTIHAL_110,HALLUR_33, MASSUR_33	10:06	19:17	9:11	LINE CLEAR AVAILED
26	18-Jun-19	BAGALKOT	110	110/11KV,HV1	RATTIHAL_110	10:15	19:05	8:50	LINE CLEAR AVAILED
27	18-Jun-19	BAGALKOT	110	110/11KV,HV2	RATTIHAL_110	10:06	19:14	9:08	LINE CLEAR AVAILED
28	18-Jun-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	11:41	17:00	5:19	LINE CLEAR AVAILED
29	18-Jun-19	BAGALKOT	110	RON -NAREGAL	NAREGAL_110	11:52	12:37	0:45	MAIN SUPPLY FAILURE
30	18-Jun-19	BAGALKOT	110	RON -NAREGAL	NAREGAL_110	16:42	17:12	0:30	LINE CLEAR AVAILED
31	18-Jun-19	BAGALKOT	220	RANEENNUR-SHIROLKOPPA(BALLIGAVI)	RANEENNUR_220	8:32	8:35	0:03	HAND TRIPPED
32	18-Jun-19	BAGALKOT	110	DAMBAL-MUNDARGI	MUNDARGI_110	9:35	18:10	8:35	LINE CLEAR AVAILED
33	18-Jun-19	BAGALKOT	110	110/11KV,HV1	MUNDARGI_110	9:35	18:10	8:35	LINE CLEAR AVAILED
34	18-Jun-19	BAGALKOT	110	110/11KV,HV2	MUNDARGI_110	9:35	18:13	8:38	LINE CLEAR AVAILED
35	18-Jun-19	BAGALKOT	110	110/33KV,HV3	MUNDARGI_110,SINGATALUR_33KV	9:35	18:10	8:35	LINE CLEAR AVAILED
36	18-Jun-19	BAGALKOT	110	VIJAY SUGAR-MUNDARGI	MUNDARGI_110	9:35	18:11	8:36	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
37	18-Jun-19	BAGALKOT	110	MAMADAPUR(B)-BABLESHWAR	BABLESHWAR_110	7:09	7:29	0:20	LOAD CURTAILMENT
38	18-Jun-19	BAGALKOT	110	MAMADAPUR(B)-SHIRBUR	SHIRBUR_110	7:09	7:32	0:23	LOAD CURTAILMENT
39	18-Jun-19	BAGALKOT	220	220/110KV,LV3	MAHALINGAPUR_220	0:00	20:36	20:36	LINE CLEAR AVAILED
40	18-Jun-19	BENGALURU	66	IISC - NRS 220	IISC	16:12	16:21	0:09	LOAD CHANGEOVER
41	18-Jun-19	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DAALSINUR	6:44	6:47	0:02	LOAD CURTAILMENT
42	18-Jun-19	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	13:12	13:20	0:08	LINE FAULT
43	18-Jun-19	BENGALURU	66	JANGAMKOTE - VIJAYAPURA	JANGAMAKOTE	12:40	12:55	0:15	LOAD CHANGEOVER
44	18-Jun-19	BENGALURU	66	JANGAMKOTE - MELUR	JANGAMAKOTE	17:40	17:50	0:10	LOAD CHANGEOVER
45	18-Jun-19	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	12:03	12:05	0:01	LINE CLEAR AVAILED
46	18-Jun-19	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	12:58	13:00	0:01	LINE CLEAR AVAILED
47	18-Jun-19	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	11:17	11:29	0:12	LINE CLEAR AVAILED
48	18-Jun-19	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	11:50	11:58	0:07	LINE CLEAR AVAILED
49	18-Jun-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	8:32	8:43	0:10	LINE FAULT
50	18-Jun-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	7:23	7:52	0:28	LOAD CURTAILMENT
51	18-Jun-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	6:44	7:16	0:32	LOAD CURTAILMENT
52	18-Jun-19	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	6:44	6:47	0:02	LOAD CURTAILMENT
53	18-Jun-19	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	7:16	7:45	0:29	LOAD CURTAILMENT
54	18-Jun-19	BENGALURU	66	HV2	CHANDRA LAYOUT	11:21	11:27	0:05	TRANSFORMER FAULT
55	18-Jun-19	BENGALURU	66	HV1	KADUBISANAHALLI	14:00	14:44	0:43	LINE CLEAR AVAILED
56	18-Jun-19	BENGALURU	66	HV2	NRS 220	9:13	9:20	0:07	LOAD CHANGEOVER
57	18-Jun-19	BENGALURU	66	HV1	ATTIBELE	16:16	16:21	0:05	TRANSFORMER FAULT
58	18-Jun-19	BENGALURU	66	HV1	KEMBODI	7:16	7:40	0:23	LOAD CURTAILMENT
59	18-Jun-19	BENGALURU	66	HV1	RANGANDODDI	16:10	16:35	0:24	LINE CLEAR AVAILED
60	18-Jun-19	BENGALURU	66	IISC - HEBBAL 220	IISC	12:47	12:52	0:05	LOAD CHANGEOVER
61	18-Jun-19	GULBARGA	220	LINGAPUR-MUNIRABADTR2	MUNIRABAD_220	9:19	15:42	6:23	NFBC ISSUED
62	18-Jun-19	GULBARGA	220	LINGAPUR-MUNIRABADTR2	MUNIRABAD_220	16:24	20:49	4:25	NFBC ISSUED
63	18-Jun-19	GULBARGA	110	HV2	KUSTAGI_220	10:48	11:04	0:16	TRANSFORMER FAULT
64	18-Jun-19	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110 ,HANUMANAL_110	11:47	12:05	0:18	LINE FAULT
65	18-Jun-19	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	10:48	11:10	0:22	MAIN SUPPLY FAILURE
66	18-Jun-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	3:41	3:54	0:13	LINE FAULT
67	18-Jun-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGO D_110,KAMALAPURA_110,METRI_110	7:01	7:11	0:10	LOAD CURTAILMENT
68	18-Jun-19	GULBARGA	110	CHITGUPPA-ACMESOLAR_IPP	CHITGUPPA_110	11:55	12:05	0:10	LINE FAULT
69	18-Jun-19	GULBARGA	110	LV1, LV2	ITTAGI_220	10:53	11:00	0:07	TRANSFORMER FAULT
70	18-Jun-19	GULBARGA	110	HV3	HATTI_110	19:16	19:35	0:19	TRANSFORMER FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
71	18-Jun-19	GULBARGA	110	HV2	HATTI_110	16:38	16:48	0:10	LINE CLEAR AVAILED
72	18-Jun-19	GULBARGA	110	HV2	HATTI_110	17:03	17:18	0:15	LINE CLEAR AVAILED
73	18-Jun-19	GULBARGA	110	HV2	HATTI_110	17:22	17:35	0:13	LINE CLEAR AVAILED
74	18-Jun-19	GULBARGA	110	HALBARGA-HUMNABAD110	HALKIJDRE_110	19:16	19:20	0:04	LINE FAULT
75	18-Jun-19	GULBARGA	66	ITTAGI-RENEWSOLAR2_IPP	ITTAGI_220	13:17	13:20	0:03	HAND TRIPPED
76	18-Jun-19	GULBARGA	66	HV1,HV2	UPANAYAKANAHALLI_66	9:40	9:50	0:10	LINE CLEAR AVAILED
77	18-Jun-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	2:10	6:55	4:45	LINE CLEAR AVAILED
78	18-Jun-19	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	16:40	20:16	3:36	LINE FAULT
79	18-Jun-19	HASSAN	220	KEMARMSEZ-2	MSEZ_220	16:40	20:15	3:35	LINE FAULT
80	18-Jun-19	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	10:37	12:15	1:38	LINE CLEAR AVAILED
81	18-Jun-19	HASSAN	110	HV2	GANDASI_110	13:07	14:15	1:08	LINE CLEAR AVAILED
82	18-Jun-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	12:03	14:10	2:07	LINE CLEAR AVAILED
83	18-Jun-19	HASSAN	110	ESSUR-BELIGAVI	ESSUR_110	10:25	17:25	7:00	LINE CLEAR AVAILED
84	18-Jun-19	HASSAN	110	HV1	ESSUR_110	10:25	17:25	7:00	LINE CLEAR AVAILED
85	18-Jun-19	HASSAN	110	HV2	ESSUR_110	10:25	17:25	7:00	LINE CLEAR AVAILED
86	18-Jun-19	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	10:03	16:53	6:50	LINE CLEAR AVAILED
87	18-Jun-19	HASSAN	110	HALADY11-HOSANGADI	HALADY_110	9:50	17:18	7:28	LINE CLEAR AVAILED
88	18-Jun-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	10:03	16:55	6:52	MAIN SUPPLY FAILURE
89	18-Jun-19	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	9:50	17:15	7:25	NFBC ISSUED
90	18-Jun-19	HASSAN	110	HOSNGD-HULIKAL	HOSANGADI_110	9:50	17:15	7:25	NFBC ISSUED
91	18-Jun-19	HASSAN	110	HV2	KADUR_220	10:11	11:14	1:03	LINE CLEAR AVAILED
92	18-Jun-19	HASSAN	110	HV1	BYACHANAHALLI_66	7:45	8:00	0:15	TRANSFORMER FAULT
93	18-Jun-19	HASSAN	110	HV1	BYACHANAHALLI_66	8:50	8:55	0:05	TRANSFORMER FAULT
94	18-Jun-19	HASSAN	110	HV1	BYACHANAHALLI_66	17:35	17:40	0:05	LINE CLEAR AVAILED
95	18-Jun-19	HASSAN	110	HV1	HANGARANAHALLY_66	9:20	16:30	7:10	LINE CLEAR AVAILED
96	18-Jun-19	HASSAN	110	HNPR2-HASS1	HOLENARASIPURA_220	10:10	11:40	1:30	LINE CLEAR AVAILED
97	18-Jun-19	HASSAN	110	KANDLI-SAKLESHPUR	KANDLI_66	12:05	13:33	1:28	LINE CLEAR AVAILED
98	18-Jun-19	HASSAN	110	SAKALE-HASSAN	SAKLESHPUR_66	12:05	13:33	1:28	LINE CLEAR AVAILED
99	18-Jun-19	MYSORE	66	CHUNCHUNKATTE-KR NAGARA	KRNAGARA_66	11:30	12:42	1:12	NFBC ISSUED
100	18-Jun-19	MYSORE	66	HOOTAGALLI-DATAGALLI	DATTAGALLY_66, RKNAGARA_66	10:26	10:30	0:04	HAND TRIPPED
101	18-Jun-19	MYSORE	66	HV2	HULLAHALLI_66	9:55	15:25	5:30	TRANSFORMER FAULT
102	18-Jun-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:20	11:45	1:25	LINE CLEAR AVAILED
103	18-Jun-19	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66, YELANDUR_66	10:55	12:10	1:15	LINE CLEAR AVAILED
104	18-Jun-19	MYSORE	220	HV2	BANDALLI_66, COWDALLI_66, DODDINADUVADI_66, HANNUR_66, KOTTANUR_66, MARTAHALLI_66, RAMAPURA_MYS_66	13:10	13:20	0:10	TRANSFORMER FAULT
105	18-Jun-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	13:10	18:26	5:16	LINE FAULT
106	18-Jun-19	MYSORE	66	HV1	RKNAGARA_66	11:30	13:16	1:46	LINE CLEAR AVAILED
107	18-Jun-19	MYSORE	66	HV2	RKNAGARA_66	13:16	14:29	1:12	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
108	18-Jun-19	MYSORE	66	HV1	SALIGRAMA_66	10:00	17:25	7:25	LINE CLEAR AVAILED
109	18-Jun-19	MYSORE	66	HV2	SALIGRAMA_66	10:00	17:36	7:36	LINE CLEAR AVAILED
110	18-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	11:15	18:49	7:34	LINE CLEAR AVAILED
111	18-Jun-19	MYSORE	66	HV5	SFCSHIVA_66	19:35	23:59	4:23	LINE CLEAR AVAILED
112	18-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	16:50	16:55	0:05	TRANSFORMER FAULT
113	18-Jun-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	7:26	7:52	0:25	HAND TRIPPED
114	18-Jun-19	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	15:49	17:01	1:11	LINE CLEAR AVAILED
115	18-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	16:50	16:55	0:05	TRANSFORMER FAULT
116	18-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:47	10:56	0:08	HAND TRIPPED
117	18-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	14:51	14:55	0:04	HAND TRIPPED
118	18-Jun-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	12:36	12:41	0:05	HAND TRIPPED
119	18-Jun-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	13:57	15:20	1:22	LINE CLEAR AVAILED
120	18-Jun-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	11:07	12:45	1:38	LINE CLEAR AVAILED
121	18-Jun-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	11:07	12:45	1:38	LINE CLEAR AVAILED
122	18-Jun-19	TUMKUR	66	TELAGI- VESTAS IPP	VESTAS_IPP_66	11:56	12:12	0:15	LINE FAULT
123	18-Jun-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:10	18:23	8:12	LINE FAULT
124	19-Jun-19	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIGATTA_33,SEABIRD_110	10:28	13:56	3:28	LINE CLEAR AVAILED
125	19-Jun-19	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	8:10	10:03	1:53	LINE CLEAR AVAILED
126	19-Jun-19	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	23:15	23:40	0:25	LINE CLEAR AVAILED
127	19-Jun-19	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	12:37	14:23	1:46	LINE CLEAR AVAILED
128	19-Jun-19	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	6:00	6:07	0:07	TRANSFORMER FAULT
129	19-Jun-19	BAGALKOT	110	BADAMI-KERUR	KERUR_110	10:08	11:42	1:34	LINE CLEAR AVAILED
130	19-Jun-19	BAGALKOT	110	KONNUR-KERUR	KERUR_110	7:17	10:54	3:37	LINE CLEAR AVAILED
131	19-Jun-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	9:52	10:31	0:39	HAND TRIPPED
132	19-Jun-19	BAGALKOT	220	220/110KV,HV2&LV2	MAHALINGAPUR_220	11:46	21:56	10:10	LINE CLEAR AVAILED
133	19-Jun-19	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	11:21	11:31	0:10	LOAD CHANGEOVER
134	19-Jun-19	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	13:52	14:05	0:13	TRANSFORMER FAULT
135	19-Jun-19	BAGALKOT	110	KUDUCHI220-TERDAL	TERDAL_110	0:00	11:41	11:41	NFBC ISSUED
136	19-Jun-19	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	11:41	23:59	12:18	LINE CLEAR AVAILED
137	19-Jun-19	BAGALKOT	110	NARENDRA(KUD DHARWAD)-TADASINAKOPPA	TADASINAKOPPA_110	10:34	15:11	4:37	NFBC ISSUED
138	19-Jun-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINAKOPPA_110	11:11	11:23	0:12	HAND TRIPPED
139	19-Jun-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINAKOPPA_110	15:17	23:59	8:42	LINE CLEAR AVAILED
140	19-Jun-19	BAGALKOT	110	TADASINKOPPA-TARIHAL	TADASINKOPPA_110	15:11	16:00	0:49	LINE CLEAR AVAILED
141	19-Jun-19	BAGALKOT	110	HUBLI220-ANANDANAGAR	ANANDANAGAR_110	10:06	16:22	6:16	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
142	19-Jun-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	12:14	13:25	1:11	LINE CLEAR AVAILED
143	19-Jun-19	BAGALKOT	110	RANNABELAGALI-MUDHOL	MUDHOL_110	11:28	11:46	0:18	HAND TRIPPED
144	19-Jun-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	12:43	13:33	0:50	LINE CLEAR AVAILED
145	19-Jun-19	BAGALKOT	110	SAVALAGI-TODALBAGI	TODALBAGI_110	16:15	16:20	0:05	LINE CLEAR AVAILED
146	19-Jun-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	16:15	16:50	0:35	LINE CLEAR AVAILED
147	19-Jun-19	BAGALKOT	110	110/11KV,HV2	TODALBAGI_110	16:15	16:50	0:35	LINE CLEAR AVAILED
148	19-Jun-19	BAGALKOT	110	110/11KV,HV3	TODALBAGI_110	16:00	16:20	0:20	LINE CLEAR AVAILED
149	19-Jun-19	BAGALKOT	110	NARENDRA-KUD DHARWAD1	KUD DHARWAD_110	12:06	14:41	2:35	LINE CLEAR AVAILED
150	19-Jun-19	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	18:12	18:16	0:04	LOAD CHANGEVER
151	19-Jun-19	BENGALURU	66	HV2	NRS 220	9:23	9:25	0:01	LOAD CHANGEVER
152	19-Jun-19	BENGALURU	66	NGEF - HOODY	NGEF, NGEF (EHT)	11:35	13:40	2:05	LINE CLEAR AVAILED
153	19-Jun-19	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	9:15	9:26	0:11	LOAD CHANGEVER
154	19-Jun-19	BENGALURU	66	KADUBISANAHALLI - CESSNO PARK (EHT)	CESSNO PARK (EHT)	8:11	16:00	7:49	MAIN SUPPLY FAILURE
155	19-Jun-19	BENGALURU	66	ITI - HEBBAL 220	BANASWADI	11:51	13:45	1:53	LINE CLEAR AVAILED
156	19-Jun-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	11:31	11:50	0:19	LINE FAULT
157	19-Jun-19	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	HSR LAYOUT 220	0:24	1:07	0:43	LINE FAULT
158	19-Jun-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	8:11	9:00	0:49	LINE FAULT
159	19-Jun-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	11:19	13:38	2:19	LINE CLEAR AVAILED
160	19-Jun-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	16:11	16:52	0:41	MAIN SUPPLY FAILURE
161	19-Jun-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, BTM 4TH PHASE	16:11	16:52	0:41	MAIN SUPPLY FAILURE
162	19-Jun-19	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	16:11	16:24	0:13	LINE FAULT
163	19-Jun-19	BENGALURU	220	HV3	SOMANAHALLI 220	16:11	16:43	0:32	TRANSFORMER FAULT
164	19-Jun-19	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	16:08	16:55	0:46	LINE FAULT
165	19-Jun-19	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	HSR LAYOUT 220	0:24	1:02	0:38	LINE FAULT
166	19-Jun-19	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	0:40	1:14	0:33	MAIN SUPPLY FAILURE
167	19-Jun-19	BENGALURU	66	HSR LAYOUT 220 - KORAMANGALA	KORAMANGALA, K & C VALLEY, NAL (EHT)	0:40	1:13	0:32	MAIN SUPPLY FAILURE
168	19-Jun-19	BENGALURU	66	HV2	CHAKAVELU	17:17	17:21	0:03	LINE CLEAR AVAILED
169	19-Jun-19	BENGALURU	66	HV2	TUBUGERE	18:00	18:05	0:05	LINE CLEAR AVAILED
170	19-Jun-19	BENGALURU	66	HV1	KEMBODI	11:36	12:50	1:13	LINE CLEAR AVAILED
171	19-Jun-19	BENGALURU	66	HV2	ELECTRONIC CITY P2 S1	10:04	10:20	0:15	TRANSFORMER FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
172	19-Jun-19	BENGALURU	66	HV2	ELECTRONIC CITY P2 S1	16:30	17:30	1:00	TRANSFORMER FAULT
173	19-Jun-19	BENGALURU	66	HV2	CHANDRA LAYOUT	9:39	9:54	0:15	TRANSFORMER FAULT
174	19-Jun-19	BENGALURU	66	HV1	BMTC	11:35	12:15	0:40	TRANSFORMER FAULT
175	19-Jun-19	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	10:04	10:16	0:12	LINE CLEAR AVAILED
176	19-Jun-19	GULBARGA	110	HV1	RAICHUR_220	10:00	11:16	1:16	LINE CLEAR AVAILED
177	19-Jun-19	GULBARGA	110	HALBARGA-CHIDRI2	CHIDRI_110	5:43	5:48	0:05	LINE FAULT
178	19-Jun-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	10:57	11:07	0:10	LINE FAULT
179	19-Jun-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	12:54	13:02	0:08	LINE FAULT
180	19-Jun-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	13:17	13:27	0:10	LINE FAULT
181	19-Jun-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOR_110	1:26	1:40	0:14	LINE FAULT
182	19-Jun-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOR_110	10:37	10:50	0:13	LINE FAULT
183	19-Jun-19	GULBARGA	110	GULBARGA UNIVERSITY-GULBARGA NORTH1	GULBARGA UNIVERSITY_110	11:26	12:05	0:39	LINE CLEAR AVAILED
184	19-Jun-19	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	1:25	1:45	0:20	MAIN SUPPLY FAILURE
185	19-Jun-19	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	10:39	11:27	0:48	MAIN SUPPLY FAILURE
186	19-Jun-19	GULBARGA	110	LV2	RAICHUR_220	11:25	12:16	0:51	LINE CLEAR AVAILED
187	19-Jun-19	GULBARGA	110	SHAHAPUR-SHAHPUR2	SHAHPUR_110	10:28	13:25	2:57	NFBC ISSUED
188	19-Jun-19	GULBARGA	110	MASKI-RNWSLR	MASKI_110	19:11	21:56	2:45	LINE CLEAR AVAILED
189	19-Jun-19	GULBARGA	110	PDHALLI-CLNMAX	PDHALLI_110	16:30	18:40	2:10	LINE CLEAR AVAILED
190	19-Jun-19	GULBARGA	66	KOGALI-ATRSOLR	KOGALI_66	12:04	12:15	0:11	LINE CLEAR AVAILED
191	19-Jun-19	GULBARGA	66	ITTAGGI-CLNSLR1	ITTAGI_220	11:23	11:30	0:07	LINE CLEAR AVAILED
192	19-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	13:29	13:34	0:05	TRANSFORMER FAULT
193	19-Jun-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	1:25	1:25	LINE CLEAR AVAILED
194	19-Jun-19	HASSAN	220	HASSN220-Shomoga	HASSAN_220	10:15	16:06	5:51	LINE CLEAR AVAILED
195	19-Jun-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	10:52	12:51	1:59	LINE CLEAR AVAILED
196	19-Jun-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:53	12:52	1:59	LINE CLEAR AVAILED
197	19-Jun-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:29	11:13	1:44	NFBC ISSUED
198	19-Jun-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	16:21	17:00	0:39	NFBC ISSUED
199	19-Jun-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:52	12:52	2:00	NFBC ISSUED
200	19-Jun-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:52	12:52	2:00	NFBC ISSUED
201	19-Jun-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:23	11:12	1:49	LINE CLEAR AVAILED
202	19-Jun-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	16:20	17:02	0:42	LINE CLEAR AVAILED
203	19-Jun-19	HASSAN	110	HV2	KEMAR_220	2:24	3:03	0:39	TRANSFORMER FAULT
204	19-Jun-19	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	11:11	17:00	5:49	LINE CLEAR AVAILED
205	19-Jun-19	HASSAN	110	HV1	BAIKAMPADI_110	11:23	12:12	0:49	LINE CLEAR AVAILED
206	19-Jun-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	16:40	18:27	1:47	LINE CLEAR AVAILED
207	19-Jun-19	HASSAN	110	HV1	GURUVAYANAKERE_110	12:33	13:11	0:38	LINE CLEAR AVAILED
208	19-Jun-19	HASSAN	110	HV3	HIRIYADKA_110	12:35	13:30	0:55	LINE CLEAR AVAILED
209	19-Jun-19	HASSAN	110	HV3	KONAJE_110	10:29	13:50	3:21	LINE CLEAR AVAILED
210	19-Jun-19	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:38	10:39	0:01	HAND TRIPPED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
211	19-Jun-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:20	16:25	0:05	LINE FAULT
212	19-Jun-19	HASSAN	66	HV1	HANGARANAHALLY_66	12:06	12:45	0:39	LINE CLEAR AVAILED
213	19-Jun-19	MYSORE	66	HV1	DODDABYADARAHALLI	15:25	16:06	0:41	HAND TRIPPED
214	19-Jun-19	MYSORE	66	HV2	DODDABYADARAHALLI	15:25	23:59	8:34	LINE CLEAR AVAILED
215	19-Jun-19	MYSORE	66	HV1	HEBBAL-	10:28	10:31	0:03	TRANSFORMER FAULT
216	19-Jun-19	MYSORE	66	HV2	KIKKERI	15:23	15:47	0:23	LINE CLEAR AVAILED
217	19-Jun-19	MYSORE	66	HV1	PANDAVAPURA-	10:01	17:00	6:58	LINE CLEAR AVAILED
218	19-Jun-19	MYSORE	66	HV2	TALAKADU-	17:19	17:27	0:08	TRANSFORMER FAULT
219	19-Jun-19	MYSORE	66	TUBINAKERE-MC-2	CHIKKMANDYA, BESAGARAHALLI, HAMPAPURA, KOPPA, HADLY, MALAVALLI & MANDYA	23:14	23:39	0:24	LINE FAULT
220	19-Jun-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI	15:23	16:06	0:42	LINE CLEAR AVAILED
221	19-Jun-19	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	11:34	12:04	0:29	LINE CLEAR AVAILED
222	19-Jun-19	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	12:09	12:42	0:33	LINE CLEAR AVAILED
223	19-Jun-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:07	12:11	1:04	LINE CLEAR AVAILED
224	19-Jun-19	TUMKUR	66	TR-2	GULIGENAHALLI_66	12:11	13:20	1:09	LINE CLEAR AVAILED
225	19-Jun-19	TUMKUR	66	TR-1& TR-2	HIREGUNTANUR_66	17:45	18:11	0:25	LINE CLEAR AVAILED
226	19-Jun-19	TUMKUR	66	MADHUGIRI 66KV- BADAVANAHALLI	BADAVANAHALLI_66	12:01	12:35	0:34	LINE CLEAR AVAILED
227	19-Jun-19	TUMKUR	66	TR-2	NAGALMADIKE_66	14:34	15:11	0:36	LINE CLEAR AVAILED
228	19-Jun-19	TUMKUR	66	TR-1	RAMPURA_66	11:48	12:31	0:43	LINE CLEAR AVAILED
229	19-Jun-19	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:47	16:51	7:04	LINE FAULT
230	20-Jun-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	6:30	6:51	0:21	HAND TRIPPED
231	20-Jun-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	7:39	8:35	0:56	HAND TRIPPED
232	20-Jun-19	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	8:40	13:01	4:21	LINE FAULT
233	20-Jun-19	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	14:41	15:30	0:49	TRANSFORMER FAULT
234	20-Jun-19	BAGALKOT	220	220/110KV,HV1&LV1	BIDNAL_220	10:48	17:09	6:21	LINE CLEAR AVAILED
235	20-Jun-19	BAGALKOT	110	BIDNAL 220-NAVALGUND	NAVALAGUND_110	10:27	17:22	6:55	LINE CLEAR AVAILED
236	20-Jun-19	BAGALKOT	110	BIDNAL 220-ANNIGERI	ANNIGERI_110	10:27	17:23	6:56	LINE CLEAR AVAILED
237	20-Jun-19	BAGALKOT	110	BIDNAL 220-GADAG ROAD	GADAG ROAD_110	9:35	17:31	7:56	LINE CLEAR AVAILED
238	20-Jun-19	BAGALKOT	110	BIDNAL 220-P H COMPOUND	P H COMPUND_110	10:27	17:24	6:57	LINE CLEAR AVAILED
239	20-Jun-19	BAGALKOT	110	BINDAL 220-HUBLI 2	BIDNAL_220	0:00	10:48	10:48	LINE CLEAR AVAILED
240	20-Jun-19	BAGALKOT	110	BINDAL 220-HUBLI 2	BIDNAL_220	17:09	23:59	6:50	LINE CLEAR AVAILED
241	20-Jun-19	BAGALKOT	220	CHIKKODI -GATAPRABHA	CHIKKODI_220	10:24	12:31	2:07	LINE CLEAR AVAILED
242	20-Jun-19	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	14:02	17:00	2:58	LINE CLEAR AVAILED
243	20-Jun-19	BAGALKOT	110	RON1&2-GAJENDRAGAD	GAJENDRAGAD_110	6:14	7:25	1:11	MAIN SUPPLY FAILURE
244	20-Jun-19	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	5:33	11:46	6:13	LINE FAULT
245	20-Jun-19	BAGALKOT	110	HUBLI2-TARIHAL	TARIHAL_110	13:05	13:06	0:01	HAND TRIPPED
246	20-Jun-19	BAGALKOT	110	HUBLI-TARIHAL1	TARIHAL_110	12:52	13:37	0:45	LINE CLEAR AVAILED
247	20-Jun-19	BAGALKOT	110	HUBLI-BIDNAL2	HUBLI_220	10:39	10:46	0:07	HAND TRIPPED
248	20-Jun-19	BAGALKOT	110	HIREHAL-RON	RON_110	8:02	13:27	5:25	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
249	20-Jun-19	BAGALKOT	110	GAMESH-RON	RON_110	9:36	9:57	0:21	HAND TRIPPED
250	20-Jun-19	BAGALKOT	110	110/33KV,HV3	RON_110,MUSIGHERI_33KV	6:10	8:02	1:52	TRANSFORMER FAULT
251	20-Jun-19	BAGALKOT	110	110/11KV,HV2	RON_110	6:10	8:02	1:52	TRANSFORMER FAULT
252	20-Jun-19	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	9:55	13:25	3:30	MAIN SUPPLY FAILURE
253	20-Jun-19	BAGALKOT	220	220/110KV,HV1,LV1	RANEENNUR_220	8:55	20:10	11:15	LINE CLEAR AVAILED
254	20-Jun-19	BAGALKOT	110	RANEENNUR-TUMMINKATTI(RATTIHAL)	TUMMINKATTI_110	8:50	8:55	0:05	HAND TRIPPED
255	20-Jun-19	BAGALKOT	110	110/11KV,HV1	RANEENNUR_220	8:50	8:55	0:05	HAND TRIPPED
256	20-Jun-19	BAGALKOT	110	110/11KV,HV2	RANEENNUR_220	20:22	20:29	0:07	HAND TRIPPED
257	20-Jun-19	BAGALKOT	110	110/11KV,HV3	RANEENNUR_220	8:50	8:55	0:05	HAND TRIPPED
258	20-Jun-19	BAGALKOT	110	110/33KV,HV3	RANEENNUR_220, GUDUGURMAIDUR_33KV,HALAGERI_33KV	8:50	8:55	0:05	HAND TRIPPED
259	20-Jun-19	BAGALKOT	110	110/33KV,HV4	RANEENNUR_220,RSNG_33KV,KUPELLUR_33KV	8:50	8:59	0:09	HAND TRIPPED
260	20-Jun-19	BAGALKOT	110	NARENDRA-BELUR2	NARENDRA_220	12:16	13:26	1:10	LINE CLEAR AVAILED
261	20-Jun-19	BAGALKOT	110	110/33KV,HV3	LAXMESHVAR_110,SSM_33KV,MMCL	8:00	8:19	0:19	TRANSFORMER FAULT
262	20-Jun-19	BAGALKOT	110	110/11KV,HV1	LAXMESHVAR_110	13:34	15:09	1:35	TRANSFORMER FAULT
263	20-Jun-19	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	10:01	10:03	0:02	LOAD CHANGEOVER
264	20-Jun-19	BENGALURU	66	WELCAST STEEL - ABBIGERE	WELCAST STEEL	11:50	11:54	0:04	LOAD CHANGEOVER
265	20-Jun-19	BENGALURU	66	HV1	WELCAST STEEL	0:42	2:40	1:58	LINE CLEAR AVAILED
266	20-Jun-19	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	9:38	9:40	0:02	LINE FAULT
267	20-Jun-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	5:36	5:43	0:07	LINE FAULT
268	20-Jun-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:14	5:35	0:20	LINE FAULT
269	20-Jun-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:14	5:35	0:20	LINE FAULT
270	20-Jun-19	BENGALURU	66	HV2	SUBRAMANYAPURA 66	14:57	14:58	0:01	LINE CLEAR AVAILED
271	20-Jun-19	GULBARGA	220	HV2	KUSTAGI_220	13:32	13:49	0:17	TRANSFORMER FAULT
272	20-Jun-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGO D_110,KAMALAPURA_110,METRI_110	5:12	5:24	0:12	LINE FAULT
273	20-Jun-19	GULBARGA	110	SINDHANOOR220-SIRUGUPPA	SIRIGUPPA_110, DHADESUGUR_110,TEKKALAKOTE_110	11:03	11:14	0:11	LINE FAULT
274	20-Jun-19	GULBARGA	110	SHAHPUR220-SHAHPUR2	SHAHPUR_110,NALWAR_110, GOOGLE_110,	3:04	13:18	10:14	LINE FAULT



Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
275	20-Jun-19	GULBARGA	110	SHAHPUR220-SHAHPUR1	SHAHPUR_110,NALWAR_110	13:42	13:50	0:08	LINE CLEAR AVAILED
276	20-Jun-19	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	13:33	14:01	0:28	MAIN SUPPLY FAILURE
277	20-Jun-19	GULBARGA	110	HV2	RAICHUR_220	11:39	12:42	1:03	LINE CLEAR AVAILED
278	20-Jun-19	GULBARGA	110	HV1	HANUMANAL_110	8:00	9:15	1:15	LINE CLEAR AVAILED
279	20-Jun-19	GULBARGA	110	HV2	HANUMANAL_110	7:20	9:05	1:45	LINE CLEAR AVAILED
280	20-Jun-19	GULBARGA	110	HV2	CHITAGUPPA_110	15:41	15:51	0:10	TRANSFORMER FAULT
281	20-Jun-19	GULBARGA	110	SHAHPUR220-SHAHPUR1	SHAHPUR_110,NALWAR_110	16:12	16:18	0:06	LINE CLEAR AVAILED
282	20-Jun-19	GULBARGA	110	SHAHPUR220-SHAHPUR2	SHAHPUR_110,NALWAR_110, GOOGLE_110,	13:42	19:50	6:08	LINE CLEAR AVAILED
283	20-Jun-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	SINDHANOR_110	22:22	22:38	0:16	LINE FAULT
284	20-Jun-19	GULBARGA	110	HV2	CHITAGUPPA_110	18:28	18:38	0:10	LINE CLEAR AVAILED
285	20-Jun-19	GULBARGA	66	ITTAGGI-CLNMAX1	ITTAGI_220	12:34	12:48	0:14	LINE CLEAR AVAILED
286	20-Jun-19	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	10:35	16:22	5:47	LINE CLEAR AVAILED
287	20-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	17:10	17:13	0:03	TRANSFORMER FAULT
288	20-Jun-19	GULBARGA	66	HV1	HAMPASAGAR_66	17:25	17:35	0:10	TRANSFORMER FAULT
289	20-Jun-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:04	7:24	7:20	LINE CLEAR AVAILED
290	20-Jun-19	HASSAN	220	HASSN22-PGCL	HASSAN_220	10:04	15:09	5:05	LINE CLEAR AVAILED
291	20-Jun-19	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	16:10	16:39	0:29	HAND TRIPPED
292	20-Jun-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	9:25	13:08	3:43	NFBC ISSUED
293	20-Jun-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	9:26	13:09	3:43	LINE CLEAR AVAILED
294	20-Jun-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	10:28	12:01	1:33	LINE CLEAR AVAILED
295	20-Jun-19	HASSAN	110	HV1	ARASIKERE_220	12:21	14:23	2:02	LINE CLEAR AVAILED
296	20-Jun-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	15:06	17:27	2:21	LINE CLEAR AVAILED
297	20-Jun-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	11:27	12:14	0:47	LINE CLEAR AVAILED
298	20-Jun-19	HASSAN	66	HASSN22-ARKD2	HASSAN_220	16:19	16:30	0:11	LINE FAULT
299	20-Jun-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	9:15	22:30	13:15	LINE CLEAR AVAILED
300	20-Jun-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:04	12:09	0:05	LINE FAULT
301	20-Jun-19	HASSAN	66	HV1	BYACHANAHALLI_66	7:33	7:39	0:06	TRANSFORMER FAULT
302	20-Jun-19	HASSAN	66	HV1	BYACHANAHALLI_66	9:55	10:10	0:15	MAIN SUPPLY FAILURE
303	20-Jun-19	HASSAN	66	HV1	BYACHANAHALLI_66	17:30	17:45	0:15	MAIN SUPPLY FAILURE
304	20-Jun-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	9:53	22:30	12:37	LINE CLEAR AVAILED
305	20-Jun-19	HASSAN	66	RAMNT-BNDSTHL	RAMNATHPURA_66	9:53	10:35	0:42	LINE CLEAR AVAILED
306	20-Jun-19	HASSAN	66	RAMNAT-KADAVNIKOTE	RAMNATHPURA_66	14:59	17:43	2:44	NFBC ISSUED
307	20-Jun-19	MYSORE	220	BASTHIPURA-KUSHAL NAGARA1	KUSHALNAGARA_220 MADIKERI_66 SUNTIKOPPA_66	10:14	17:19	7:04	LINE CLEAR AVAILED
308	20-Jun-19	MYSORE	220	BASTHIPURA-KUSHAL NAGARA2	KUSHALNAGARA_220 MADIKERI_66 SUNTIKOPPA_66	10:13	23:59	13:45	LINE CLEAR AVAILED
309	20-Jun-19	MYSORE	66	BANNANGADI-HUYGONALLY	BANANGADI_66	9:27	16:44	7:17	LINE CLEAR AVAILED
310	20-Jun-19	MYSORE	66	BILIKERE-KR NAGAR	BILIKERE_66 GVGUDI_66	10:05	10:33	0:28	LINE FAULT
311	20-Jun-19	MYSORE	66	DEVNUR(MYS)-FTS	DEVANOORMYS_66	10:18	17:35	7:17	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
312	20-Jun-19	MYSORE	66	DEVNUR(MYS)-VAGMANGLA	DEVANOORMYS_66	10:18	17:36	7:17	LINE CLEAR AVAILED
313	20-Jun-19	MYSORE	66	HV1	KIADBMANDYA_66	5:15	5:40	0:24	HAND TRIPPED
314	20-Jun-19	MYSORE	66	HV2	KIADBMANDYA_66	5:15	5:40	0:24	HAND TRIPPED
315	20-Jun-19	MYSORE	66	MADDUR-K.HONALGERE	MADDUR_66	9:59	12:38	2:38	LINE CLEAR AVAILED
316	20-Jun-19	MYSORE	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	10:08	17:42	7:33	LINE CLEAR AVAILED
317	20-Jun-19	MYSORE	66	MADIKERI-SUNTHIKOPA	MADIKERI_66	10:09	17:39	7:30	LINE CLEAR AVAILED
318	20-Jun-19	MYSORE	66	HV2	SALIGRAMA_66	15:00	17:17	2:17	LINE CLEAR AVAILED
319	20-Jun-19	MYSORE	66	HV1	SANTHEBACHALLI_66	8:14	8:24	0:10	TRANSFORMER FAULT
320	20-Jun-19	MYSORE	66	HV2	THALAKADU_66	19:03	19:10	0:06	HAND TRIPPED
321	20-Jun-19	TUMKUR	110	TR-3	AMMASANDRA_110	14:38	16:48	2:09	TRANSFORMER FAULT
322	20-Jun-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:25	8:31	0:05	TRANSFORMER FAULT
323	20-Jun-19	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	10:19	12:02	1:42	LINE CLEAR AVAILED
324	20-Jun-19	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	10:19	12:02	1:42	LINE CLEAR AVAILED
325	20-Jun-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:19	12:12	1:52	LINE CLEAR AVAILED
326	20-Jun-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66,CHITRADURGA_220	12:06	12:28	0:21	MAIN SUPPLY FAILURE
327	20-Jun-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	12:06	12:28	0:21	MAIN SUPPLY FAILURE
328	20-Jun-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	12:06	12:28	0:21	MAIN SUPPLY FAILURE
329	20-Jun-19	TUMKUR	66	TR-1	HANAGAL_66	11:19	11:30	0:11	LINE CLEAR AVAILED
330	20-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	9:53	10:03	0:09	HAND TRIPPED
331	20-Jun-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	5:55	10:10	4:15	LINE FAULT
332	20-Jun-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	18:45	19:17	0:32	LINE CLEAR AVAILED
333	20-Jun-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	5:55	5:59	0:04	LINE FAULT
334	20-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:45	15:51	3:05	LINE FAULT
335	20-Jun-19	TUMKUR	110	TR-3	AMMASANDRA_110	14:38	16:48	2:09	TRANSFORMER FAULT
336	20-Jun-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:25	8:31	0:05	TRANSFORMER FAULT
337	20-Jun-19	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	10:19	12:02	1:42	LINE CLEAR AVAILED
338	20-Jun-19	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	10:19	12:02	1:42	LINE CLEAR AVAILED
339	20-Jun-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:19	12:12	1:52	LINE CLEAR AVAILED
340	20-Jun-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66,CHITRADURGA_220	12:06	12:28	0:21	MAIN SUPPLY FAILURE
341	20-Jun-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	12:06	12:28	0:21	MAIN SUPPLY FAILURE

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
342	20-Jun-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	12:06	12:28	0:21	MAIN SUPPLY FAILURE
343	20-Jun-19	TUMKUR	66	TR-1	HANAGAL_66	11:19	11:30	0:11	LINE CLEAR AVAILED
344	20-Jun-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	9:53	10:03	0:09	HAND TRIPPED
345	20-Jun-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	5:55	10:10	4:15	LINE FAULT
346	20-Jun-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	18:45	19:17	0:32	LINE CLEAR AVAILED
347	20-Jun-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	5:55	5:59	0:04	LINE FAULT
348	20-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:45	15:51	3:05	LINE FAULT
349	21-Jun-19	BAGALKOT	110	BAGEWADI-MUDDEBIHAL(ACHANUR)	MUDDEBIHAL_110	10:54	10:57	0:03	HAND TRIPPED
350	21-Jun-19	BAGALKOT	110	BAGEWADI-NIDAGUNDI(RAMPUR)	NIDAGUNDI_110	10:55	11:02	0:07	HAND TRIPPED
351	21-Jun-19	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	5:53	5:59	0:06	TRANSFORMER FAULT
352	21-Jun-19	BAGALKOT	110	110/11KV,HV5	INDI_110	16:52	18:17	1:25	TRANSFORMER FAULT
353	21-Jun-19	BAGALKOT	110	110/33KV,HV2	KIRUVATTI_110,YELLAPUR_33KV	14:55	16:43	1:48	LINE CLEAR AVAILED
354	21-Jun-19	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	17:05	18:25	1:20	LINE CLEAR AVAILED
355	21-Jun-19	BAGALKOT	110	110/33KV,HV1	KUMTA_110,ANKOLA_33KV,HONNAVAR_33KV	12:23	12:44	0:21	LINE CLEAR AVAILED
356	21-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	5:29	7:43	2:14	TRANSFORMER FAULT
357	21-Jun-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	MAHALINGAPUR_220	5:29	6:19	0:50	LINE FAULT
358	21-Jun-19	BAGALKOT	220	220/110KV,HV3	HUBLI_220,RAMANKOPPA_110	19:20	20:15	0:55	MAIN SUPPLY FAILURE
359	21-Jun-19	BAGALKOT	110	110/11HV,HV2	MAMADAPUR_110	11:34	12:05	0:31	LINE CLEAR AVAILED
360	21-Jun-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	5:29	6:20	0:51	LINE FAULT
361	21-Jun-19	BAGALKOT	110	PG HUNSHYAL-MUDALGI(NAGNUR)	NAGNUR_110	23:02	23:07	0:05	LINE FAULT
362	21-Jun-19	BENGALURU	66	HV1	KIADB DB PURA 220	6:52	7:07	0:15	TRANSFORMER FAULT
363	21-Jun-19	BENGALURU	66	HV1	KIADB DB PURA 220	8:54	9:01	0:07	TRANSFORMER FAULT
364	21-Jun-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:35	17:40	0:05	LINE FAULT
365	21-Jun-19	BENGALURU	66	DEVANAHALLI - DB PURA 1	DEVANAHALLI	17:35	17:43	0:08	LINE FAULT
366	21-Jun-19	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	9:40	9:43	0:03	LOAD CHANGE OVER
367	21-Jun-19	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	11:28	11:32	0:04	LOAD CHANGE OVER
368	21-Jun-19	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	11:45	12:10	0:25	LOAD CHANGE OVER
369	21-Jun-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	14:10	14:15	0:05	LOAD CHANGE OVER
370	21-Jun-19	BENGALURU	66	HV2	TELECOM LAYOUT	9:52	10:00	0:08	TRANSFORMER FAULT
371	21-Jun-19	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	14:05	14:14	0:09	LOAD CHANGE OVER
372	21-Jun-19	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	12:05	12:10	0:04	LOAD CHANGE OVER
373	21-Jun-19	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	11:42	13:46	2:03	LINE FAULT
374	21-Jun-19	BENGALURU	66	HV2	KADUGODI	12:42	13:40	0:58	TRANSFORMER FAULT
375	21-Jun-19	GULBARGA	220	LINGAPUR-BTPSG	LINGAPUR_220	9:53	13:41	3:48	LINE CLEAR AVAILED
376	21-Jun-19	GULBARGA	220	HV1	ITTAGI_220	15:47	16:20	0:33	LINE CLEAR AVAILED
377	21-Jun-19	GULBARGA	220	HV2	ITTAGI_220	16:26	16:59	0:33	LINE CLEAR AVAILED
378	21-Jun-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	18:10	23:59	5:49	LINE FAULT
379	21-Jun-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	SINDHANOR_110	13:18	14:28	1:10	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
380	21-Jun-19	GULBARGA	110	HV1	KUDITINI_110	8:35	8:45	0:10	TRANSFORMER FAULT
381	21-Jun-19	GULBARGA	110	HUMNABAD220-MANEKHALLI	MANEKHALLI_110	6:10	10:46	4:36	LINE CLEAR AVAILED
382	21-Jun-19	GULBARGA	110	HV2	SHORAPUR_110	18:30	18:38	0:08	LINE CLEAR AVAILED
383	21-Jun-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	12:10	12:22	0:12	LINE CLEAR AVAILED
384	21-Jun-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:12	11:40	0:28	LINE CLEAR AVAILED
385	21-Jun-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	11:12	11:41	0:29	LINE CLEAR AVAILED
386	21-Jun-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	14:25	16:37	2:12	LINE FAULT
387	21-Jun-19	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	14:25	16:37	2:12	LINE FAULT
388	21-Jun-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:05	17:50	7:45	LINE CLEAR AVAILED
389	21-Jun-19	HASSAN	110	KADUR-NGNHL	KADUR_220	12:10	12:15	0:05	HAND TRIPPED
390	21-Jun-19	HASSAN	110	HV2	KUNDAPURA_110	9:16	13:58	4:42	LINE CLEAR AVAILED
391	21-Jun-19	HASSAN	66	HV2	BAGUR_66	10:00	13:50	3:50	LINE CLEAR AVAILED
392	21-Jun-19	HASSAN	66	HV1	BAGUR_66	16:17	16:23	0:06	LINE CLEAR AVAILED
393	21-Jun-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:20	12:45	1:25	LINE CLEAR AVAILED
394	21-Jun-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	19:21	19:30	0:09	LINE FAULT
395	21-Jun-19	HASSAN	66	HNPPURA-RAMNATHPURA	HNPPURA_66	19:25	19:30	0:05	LINE FAULT
396	21-Jun-19	HASSAN	66	HV1	DODDAKADANUR_66	11:31	13:53	2:22	LINE CLEAR AVAILED
397	21-Jun-19	MYSORE	66	HV1	KIKKERI_66	13:01	23:59	10:57	LINE CLEAR AVAILED
398	21-Jun-19	MYSORE	66	HV3	KUSHALANAGARA_66	16:46	16:55	0:09	TRANSFORMER FAULT
399	21-Jun-19	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	BILIKERE_66,BHERYA_66, DMG_HALLI_66, GVGUDI_66, KRNAGARA_66, MIRLE_66	10:47	10:58	0:10	LINE FAULT
400	21-Jun-19	MYSORE	66	HV2	MADDUR_66	11:22	12:36	1:14	LINE CLEAR AVAILED
401	21-Jun-19	MYSORE	220	HV1	MADHUVANAHALLI_220	14:47	16:35	1:48	LINE CLEAR AVAILED
402	21-Jun-19	MYSORE	220	HV2	MADHUVANAHALLI_220	11:08	14:03	2:54	LINE CLEAR AVAILED
403	21-Jun-19	MYSORE	66	HV1	MADHUVANAHALLI_220	10:44	19:06	8:22	LINE CLEAR AVAILED
404	21-Jun-19	MYSORE	66	HV2	MADHUVANAHALLI_220	10:44	19:06	8:22	LINE CLEAR AVAILED
405	21-Jun-19	MYSORE	66	HV1	SFCSHIVA_66	6:45	8:50	2:05	LINE CLEAR AVAILED
406	21-Jun-19	MYSORE	66	HV2	SFCSHIVA_66	6:45	8:51	2:06	LINE CLEAR AVAILED
407	21-Jun-19	MYSORE	66	HV3	SFCSHIVA_66	6:45	8:51	2:06	LINE CLEAR AVAILED
408	21-Jun-19	MYSORE	66	HV4	SFCSHIVA_66	6:45	9:00	2:15	LINE CLEAR AVAILED
409	21-Jun-19	MYSORE	66	HV1	THALAKADU_66	11:26	11:35	0:08	HAND TRIPPED
410	21-Jun-19	MYSORE	66	TALAKADU-HV2	THALAKADU_66	11:26	11:35	0:08	HAND TRIPPED
411	21-Jun-19	MYSORE	66	TUBINAKERE-G UKKADA	GARUDANAUKADDA_66	11:04	15:12	4:07	LINE CLEAR AVAILED
412	21-Jun-19	TUMKUR	66	TR-1 & TR-2	BRAHMASANDRA_66	12:11	12:22	0:11	HAND TRIPPED
413	21-Jun-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	11:23	12:01	0:37	HAND TRIPPED
414	21-Jun-19	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	8:45	12:00	3:15	LINE CLEAR AVAILED
415	21-Jun-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	11:23	13:55	2:31	LINE CLEAR AVAILED
416	21-Jun-19	TUMKUR	66	TR-2	CHIKKABANAGERE_66	11:32	13:55	2:23	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
417	21-Jun-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	12:13	12:37	0:24	HAND TRIPPED
418	21-Jun-19	TUMKUR	66	GUTUR 66-DAVANGERE SRS-1	GUTUR_66	13:02	13:38	0:36	HAND TRIPPED
419	21-Jun-19	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:48	18:26	0:38	LINE FAULT
420	21-Jun-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	20:32	20:48	0:16	LINE FAULT
421	21-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	19:13	21:10	1:56	LINE FAULT
422	22-Jun-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPURR_110	5:41	5:45	0:04	LINE FAULT
423	22-Jun-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	21:37	22:17	0:40	LINE CLEAR AVAILED
424	22-Jun-19	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	19:44	20:05	0:21	LINE FAULT
425	22-Jun-19	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	19:44	20:08	0:24	LINE FAULT
426	22-Jun-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	9:52	10:09	0:17	LINE FAULT
427	22-Jun-19	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	KUDUCHI_220,AINAPUR_110,KUDUCHI_110,TERDAL_110	5:32	5:38	0:06	TRANSFORMER FAULT
428	22-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	5:32	7:21	1:49	TRANSFORMER FAULT
429	22-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	18:02	22:00	3:58	TRANSFORMER FAULT
430	22-Jun-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	11:41	14:05	2:24	TRANSFORMER FAULT
431	22-Jun-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	15:44	16:13	0:29	LINE CLEAR AVAILED
432	22-Jun-19	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	19:14	19:23	0:09	TRANSFORMER FAULT
433	22-Jun-19	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	14:22	15:35	1:13	MAIN SUPPLY FAILURE
434	22-Jun-19	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	18:10	18:25	0:15	LOAD CHANGEOVER
435	22-Jun-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	10:58	12:14	1:16	LINE CLEAR AVAILED
436	22-Jun-19	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	14:22	15:30	1:08	MAIN SUPPLY FAILURE
437	22-Jun-19	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	14:22	17:23	3:01	LINE FAULT
438	22-Jun-19	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	14:22	17:23	3:01	LINE FAULT
439	22-Jun-19	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	14:22	15:40	1:18	MAIN SUPPLY FAILURE
440	22-Jun-19	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	17:40	18:00	0:20	MAIN SUPPLY FAILURE
441	22-Jun-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:22	15:45	1:23	MAIN SUPPLY FAILURE
442	22-Jun-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	17:40	18:06	0:26	MAIN SUPPLY FAILURE
443	22-Jun-19	BENGALURU	66	HV1	MALLASANDRA	19:25	19:35	0:10	TRANSFORMER FAULT
444	22-Jun-19	BENGALURU	66	HV2	HOSOR RAMAPURA	15:21	15:29	0:08	TRANSFORMER FAULT
445	22-Jun-19	BENGALURU	66	HV1	GOWRIBIDANUR 220	13:02	13:14	0:12	TRANSFORMER FAULT
446	22-Jun-19	BENGALURU	220	HV1	MALUR 220	14:22	15:30	1:08	MAIN SUPPLY FAILURE
447	22-Jun-19	BENGALURU	220	HV1	MALUR 220	17:42	17:49	0:07	MAIN SUPPLY FAILURE
448	22-Jun-19	BENGALURU	220	HV2	MALUR 220	14:22	15:30	1:08	MAIN SUPPLY FAILURE
449	22-Jun-19	BENGALURU	220	HV2	MALUR 220	17:42	17:49	0:07	MAIN SUPPLY FAILURE
450	22-Jun-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	8:43	8:58	0:14	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
451	22-Jun-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	14:22	15:10	0:48	LINE CLEAR AVAILED
452	22-Jun-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	18:10	18:15	0:05	LOAD CHANGEOVER
453	22-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	14:22	15:38	1:16	MAIN SUPPLY FAILURE
454	22-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	17:42	18:00	0:18	MAIN SUPPLY FAILURE
455	22-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:38	15:40	0:01	MAIN SUPPLY FAILURE
456	22-Jun-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	17:42	17:49	0:07	MAIN SUPPLY FAILURE
457	22-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	14:22	15:30	1:08	MAIN SUPPLY FAILURE
458	22-Jun-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:42	17:49	0:07	MAIN SUPPLY FAILURE
459	22-Jun-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	14:22	15:30	1:08	MAIN SUPPLY FAILURE
460	22-Jun-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:42	17:49	0:07	MAIN SUPPLY FAILURE
461	22-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	14:22	15:30	1:08	MAIN SUPPLY FAILURE
462	22-Jun-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	17:42	17:49	0:07	MAIN SUPPLY FAILURE
463	22-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	14:22	15:40	1:18	MAIN SUPPLY FAILURE
464	22-Jun-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	17:42	18:00	0:18	MAIN SUPPLY FAILURE
465	22-Jun-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	9:00	9:04	0:04	LOAD CHANGEOVER
466	22-Jun-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	18:38	18:41	0:03	LOAD CHANGEOVER
467	22-Jun-19	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	14:22	16:04	1:42	MAIN SUPPLY FAILURE
468	22-Jun-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	14:22	16:04	1:42	MAIN SUPPLY FAILURE
469	22-Jun-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:22	16:04	1:42	MAIN SUPPLY FAILURE
470	22-Jun-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	23:15	23:18	0:03	LOAD CHANGEOVER
471	22-Jun-19	BENGALURU	66	ABBIGERE - DG 3	ABBIGERE	11:03	11:06	0:03	LOAD CHANGEOVER
472	22-Jun-19	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	8:54	8:58	0:03	LOAD CHANGEOVER
473	22-Jun-19	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	15:16	15:19	0:03	LOAD CHANGEOVER
474	22-Jun-19	BENGALURU	66	ABBIGERE - DG 3	ABBIGERE	18:02	18:06	0:04	LOAD CHANGEOVER
475	22-Jun-19	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	9:00	9:06	0:06	LOAD CHANGEOVER
476	22-Jun-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	6:22	7:05	0:42	LINE FAULT
477	22-Jun-19	BENGALURU	66	HV2	TELECOM LAYOUT	15:32	15:36	0:03	TRANSFORMER FAULT
478	22-Jun-19	BENGALURU	220	HV1	VIKAS TECH PARK 220	14:20	16:04	1:44	MAIN SUPPLY FAILURE
479	22-Jun-19	BENGALURU	220	HV2	VIKAS TECH PARK 220	14:20	16:04	1:44	MAIN SUPPLY FAILURE
480	22-Jun-19	BENGALURU	220	HV1	VIKAS TECH PARK 220	17:40	18:03	0:23	MAIN SUPPLY FAILURE
481	22-Jun-19	BENGALURU	220	HV2	VIKAS TECH PARK 220	17:40	18:03	0:23	MAIN SUPPLY FAILURE
482	22-Jun-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	0:00	14:33	14:33	LINE FAULT
483	22-Jun-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	12:30	12:33	0:03	LINE CLEAR AVAILED
484	22-Jun-19	GULBARGA	220	RTPS-SHAHAPUR1	SHAHPUR_220	1:45	2:20	0:35	LINE FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
485	22-Jun-19	GULBARGA	110	SEDAM-MALKHED RAILWAY TRACTION	MALKHED RAILWAY STATION	11:00	12:44	1:44	LINE CLEAR AVAILED
486	22-Jun-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	5:46	5:55	0:09	LINE FAULT
487	22-Jun-19	GULBARGA	110	HV2	HATTI_110	3:25	3:35	0:10	TRANSFORMER FAULT
488	22-Jun-19	GULBARGA	110	HV2	HATTI_110	9:10	9:15	0:05	TRANSFORMER FAULT
489	22-Jun-19	GULBARGA	110	HV2	HATTI_110	10:05	10:10	0:05	TRANSFORMER FAULT
490	22-Jun-19	GULBARGA	110	SIDHANOOR-PGLR_WIND	SINDHANOR_220	23:52	23:59	0:07	LINE FAULT
491	22-Jun-19	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66, BANAVEKAL_66,CHORNOOR_66	17:12	17:32	0:20	LINE FAULT
492	22-Jun-19	HASSAN	66	HV1	ALDUR_66	13:58	14:40	0:42	LINE CLEAR AVAILED
493	22-Jun-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	14:23	16:00	1:37	LINE CLEAR AVAILED
494	22-Jun-19	MYSORE	66	COWDALLI-MARTALLI	MARTAHALLI_66, RAMAPURA_MYS_66	4:06	4:14	0:07	LINE FAULT
495	22-Jun-19	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	16:32	23:59	7:26	LINE FAULT
496	22-Jun-19	MYSORE	66	HV2	MADDUR_66	17:18	18:06	0:47	LINE CLEAR AVAILED
497	22-Jun-19	TUMKUR	66	TR-2	NITRAHALLI_66	17:49	17:58	0:08	TRANSFORMER FAULT
498	22-Jun-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:27	12:10	0:42	LINE FAULT
499	23-Jun-19	BAGALKOT	220	PONDA 2-AMBEWADI	AMBEWADI_220	0:00	16:48	16:48	LINE CLEAR AVAILED
500	23-Jun-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPURR_110	20:11	20:39	0:28	LINE FAULT
501	23-Jun-19	BAGALKOT	110	110/11KV,HV1&2	BELGAUM_110	10:37	10:48	0:11	HAND TRIPPED
502	23-Jun-19	BAGALKOT	220	BELGAUM-KANABARGI1	BELGAUM_220	17:46	23:59	6:13	LINE CLEAR AVAILED
503	23-Jun-19	BAGALKOT	220	BELGAUM-KANABARGI2	BELGAUM_220	16:46	23:59	7:13	LINE CLEAR AVAILED
504	23-Jun-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	19:59	23:59	4:00	LINE CLEAR AVAILED
505	23-Jun-19	BAGALKOT	110	HUBLI-KALAGATAGI	KALAGATAGI_110	19:59	23:59	4:00	MAIN SUPPLY FAILURE
506	23-Jun-19	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	9:11	14:31	5:20	LINE CLEAR AVAILED
507	23-Jun-19	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	KUDUCHI_220,UGAR KHUD_110,KUDUCHI_110,TERDAL_110	20:02	20:08	0:06	TRANSFORMER FAULT
508	23-Jun-19	BAGALKOT	220	KUDUCHI-CHIKKODI1	KUDUCHI_220	20:00	20:10	0:10	LINE FAULT
509	23-Jun-19	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	3:41	3:57	0:16	LINE FAULT
510	23-Jun-19	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	3:59	10:53	6:54	LINE CLEAR AVAILED
511	23-Jun-19	BAGALKOT	110	VIJAYA SUGARS-MUNDARGI	MUNDARGI_110	20:00	23:59	3:59	LINE FAULT
512	23-Jun-19	BAGALKOT	110	110/11KV, HV1	TERDAL_110	18:50	20:57	2:07	TRANSFORMER FAULT
513	23-Jun-19	BAGALKOT	110	110/11KV, HV1	SUARNASOUDA_110	10:02	16:18	6:16	LINE CLEAR AVAILED
514	23-Jun-19	BENGALURU	66	HV2	MALLASANDRA	18:05	18:46	0:41	TRANSFORMER FAULT
515	23-Jun-19	BENGALURU	66	HV2	GANJIGUNTE	0:00	9:00	8:59	TRANSFORMER FAULT
516	23-Jun-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	12:02	12:04	0:02	LOAD CHANGEOVER
517	23-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	13:10	13:12	0:02	LOAD CHANGEOVER
518	23-Jun-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	11:26	12:44	1:18	LINE FAULT
519	23-Jun-19	BENGALURU	66	HV2	TELECOM LAYOUT	0:22	0:30	0:08	TRANSFORMER FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
520	23-Jun-19	BENGALURU	66	HV2	TELECOM LAYOUT	9:20	9:25	0:05	TRANSFORMER FAULT
521	23-Jun-19	BENGALURU	66	ADUGODI - HSR LAYOUT	ADUGODI, BOSCH (EHT), AMARJYOTHI	11:55	12:03	0:08	LOAD CHANGEOVER
522	23-Jun-19	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	12:42	12:46	0:03	LOAD CHANGEOVER
523	23-Jun-19	BENGALURU	66	HSR LAYOUT 220 - KORAMANGALA	KORAMANGALA, K & C VALLEY, NAL (EHT)	12:43	12:46	0:03	LOAD CHANGEOVER
524	23-Jun-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:33	15:55	0:21	LINE FAULT
525	23-Jun-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:02	16:35	0:32	LINE FAULT
526	23-Jun-19	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	TK HALLI 220	19:10	19:29	0:19	LINE FAULT
527	23-Jun-19	BENGALURU	220	HSR LAYOUT 220 - HOODY 220	HSR LAYOUT 220	12:13	12:46	0:32	LOAD CHANGEOVER
528	23-Jun-19	BENGALURU	220	HSR LAYOUT 220 - HOODY 220	HSR LAYOUT 220	19:23	19:39	0:15	LOAD CHANGEOVER
529	23-Jun-19	BENGALURU	66	HV1	BOODIGERE	18:34	18:48	0:14	TRANSFORMER FAULT
530	23-Jun-19	GULBARGA	220	MALLAT-RTPS	MALLAT_220	6:30	23:59	17:29	LINE FAULT
531	23-Jun-19	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110,MADALAPURA_110	22:00	22:15	0:15	LINE FAULT
532	23-Jun-19	GULBARGA	110	MALLAT-BYAGAWAT2	MANVI_110,MADALAPURA_110	22:40	22:55	0:15	LINE FAULT
533	23-Jun-19	GULBARGA	110	BETAGERA-KESHAVCEMENTS	BETAGERA_110	19:40	19:58	0:18	LINE FAULT
534	23-Jun-19	GULBARGA	110	BETAGERA-KESHAVCEMENTS	BETAGERA_110	20:42	21:01	0:19	LINE FAULT
535	23-Jun-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	22:56	23:03	0:07	LINE FAULT
536	23-Jun-19	GULBARGA	110	BHALKI-BKLISUGAR,MGSSK	BHALKESHWAR SUGAR_IPP,MGSSK_IPP	22:29	22:36	0:07	LINE FAULT
537	23-Jun-19	GULBARGA	110	SIDHANOOR-PGLR_WIND	SINDHANOR_220	0:00	0:04	0:04	LINE FAULT
538	23-Jun-19	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	3:28	3:39	0:11	LINE FAULT
539	23-Jun-19	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOR_110	20:18	20:51	0:33	LINE CLEAR AVAILED
540	23-Jun-19	GULBARGA	110	SINDHANOOR-SUZLON1	SINDHANOR_220	22:18	22:35	0:17	LINE FAULT
541	23-Jun-19	GULBARGA	110	HV2	BHALKI_110	12:05	12:15	0:10	TRANSFORMER FAULT
542	23-Jun-19	GULBARGA	110	HV2	BHALKI_110	12:20	12:30	0:10	TRANSFORMER FAULT
543	23-Jun-19	GULBARGA	110	HV4	YELBURGA_110	16:04	16:15	0:11	TRANSFORMER FAULT
544	23-Jun-19	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	17:53	18:20	0:27	LINE FAULT
545	23-Jun-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	21:22	21:29	0:07	LINE FAULT
546	23-Jun-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	14:32	14:48	0:16	TRANSFORMER FAULT
547	23-Jun-19	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	8:37	19:38	11:01	NFBC ISSUED
548	23-Jun-19	HASSAN	66	HV2	HOLALUR_66	18:23	19:35	1:12	TRANSFORMER FAULT
549	23-Jun-19	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	9:02	13:41	4:39	LINE CLEAR AVAILED
550	23-Jun-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:06	15:15	0:09	LINE FAULT
551	23-Jun-19	MYSORE	66	BOOKANAKERE-CHINAKURALI	BANANGADI_66, CHINAKURALI_66	22:07	22:18	0:10	LINE FAULT
552	23-Jun-19	MYSORE	66	COWDALLI-MARTALLI	MARTAHALLI_66, RAMAPURA_MYS_66	18:06	18:12	0:05	LINE FAULT
553	23-Jun-19	MYSORE	66	HV1	HANNUR_66	10:00	17:30	7:30	LINE CLEAR AVAILED
554	23-Jun-19	MYSORE	66	HV2	HANNUR_66	10:00	17:30	7:30	LINE CLEAR AVAILED



Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
555	23-Jun-19	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66, COWDALLI_66, MARTAHALLI_66, RAMAPURA_MYS_66	14:15	17:30	3:15	LINE CLEAR AVAILED
556	23-Jun-19	MYSORE	220	HV1	HOOTAGALLY_220	10:10	12:58	2:48	LINE CLEAR AVAILED
557	23-Jun-19	MYSORE	220	HV2	HOOTAGALLY_220	10:20	13:01	2:41	LINE CLEAR AVAILED
558	23-Jun-19	MYSORE	220	HV3	HOOTAGALLY_220	10:30	13:02	2:32	LINE CLEAR AVAILED
559	23-Jun-19	MYSORE	66	HV1	HOOTAGALLY_220	10:29	12:59	2:30	LINE CLEAR AVAILED
560	23-Jun-19	MYSORE	66	HV2	HOOTAGALLY_220	10:29	13:00	2:31	LINE CLEAR AVAILED
561	23-Jun-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66, MADDUR_66, SOMANAHALLI_66	16:52	17:06	0:14	LINE FAULT
562	23-Jun-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66, MADDUR_66, SOMANAHALLI_66	17:24	17:30	0:06	LINE FAULT
563	23-Jun-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66, MADDUR_66, SOMANAHALLI_66	18:48	18:50	0:02	LINE FAULT
564	23-Jun-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	16:52	17:24	0:32	LINE FAULT
565	23-Jun-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	17:25	19:53	2:27	LINE FAULT
566	23-Jun-19	MYSORE	66	HV2	KMDODDI_66	10:20	10:35	0:14	TRANSFORMER FAULT
567	23-Jun-19	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66, KOLKARANADODDI_66, KIADBMANDYA_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	15:35	16:00	0:25	LINE FAULT
568	23-Jun-19	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66, KOLKARANADODDI_66, KIADBMANDYA_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	16:04	16:18	0:14	LINE FAULT
569	23-Jun-19	MYSORE	66	KM DODDI-MANDYA	KIADBMANDYA_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	16:28	23:59	7:31	LINE CLEAR AVAILED
570	23-Jun-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	6:23	6:29	0:06	LINE FAULT
571	23-Jun-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:25	16:26	6:00	NFBC ISSUED
572	23-Jun-19	MYSORE	66	METAGALLI-G UKKADA	HEBBAL_66, METAGALLY_66	10:06	10:21	0:15	HAND TRIPPED
573	23-Jun-19	TUMKUR	66	ANCHEPALYA 220KV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	14:18	14:38	0:20	LINE FAULT
574	23-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	12:40	15:00	2:20	TRANSFORMER FAULT
575	23-Jun-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:58	18:11	0:13	LINE FAULT
576	23-Jun-19	TUMKUR	66	TR-1	MADHUGIRI_220	15:37	22:17	6:39	TRANSFORMER FAULT
577	23-Jun-19	TUMKUR	66	TR-2	NITRAHALLI_66	23:14	23:21	0:07	TRANSFORMER FAULT
578	24-Jun-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	5:53	6:03	0:10	LINE FAULT
579	24-Jun-19	BAGALKOT	110	ATHANI-THAVASI	THAVASI_110	10:50	17:44	6:54	LINE FAULT
580	24-Jun-19	BAGALKOT	110	BAGALKOT-NEERBUDIHAI(KATARAKI)	NEERBUDIHAI_110	15:14	16:21	1:07	LINE FAULT
581	24-Jun-19	BAGALKOT	110	BAGALKOT-LOKAPUR1	LOKAPUR_110	15:14	16:25	1:11	LINE FAULT
582	24-Jun-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	11:04	23:59	12:55	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
583	24-Jun-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	10:50	11:59	1:09	LINE CLEAR AVAILED
584	24-Jun-19	BAGALKOT	110	110/11KV,HV1	BANAHATTI_110	9:32	23:59	14:27	LINE CLEAR AVAILED
585	24-Jun-19	BAGALKOT	110	110/33KV,HV-3	BELUR_110&33KV-UAS,UDL,TATA1&2,SOUTHERN FERRO_33	12:52	14:23	1:31	LINE CLEAR AVAILED
586	24-Jun-19	BAGALKOT	220	BELGAUM-KANABARGI1	BELGAUM_220	0:00	14:25	14:25	LINE CLEAR AVAILED
587	24-Jun-19	BAGALKOT	220	BELGAUM-KANABARGI2	BELGAUM_220	0:00	6:29	6:29	LINE CLEAR AVAILED
588	24-Jun-19	BAGALKOT	220	BELGAUM-KANABARGI2	BELGAUM_220	7:57	8:28	0:31	LINE FAULT
589	24-Jun-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	0:28	3:20	2:52	LINE CLEAR AVAILED
590	24-Jun-19	BAGALKOT	220	220/110KV HV-2&LV2	MAHALINGAPUR_220	0:01	23:59	23:58	TRANSFORMER FAULT
591	24-Jun-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR	VAJRAMATTI_220	10:45	23:59	13:14	NFBC ISSUED
592	24-Jun-19	BAGALKOT	110	HUBLI-KALAGATAGI	KALAGATAGI_110	0:00	14:36	14:36	LINE CLEAR AVAILED
593	24-Jun-19	BAGALKOT	220	220/110KV, HV1, HV2, LV1 &LV2	NARENDRA_220, SHEDBAL_110, BELAUR_110, MR NAGAR_110, TADASINKOPPA_110, KUD DHARWAD_110	2:01	2:34	0:33	TRANSFORMER FAULT
594	24-Jun-19	BAGALKOT	110	110/11KV, HV2	NANADI_110	8:15	8:45	0:30	LINE CLEAR AVAILED
595	24-Jun-19	BAGALKOT	110	110/11KV, HV1	MURDESHWAR_110	17:48	17:53	0:05	HAND TRIPPED
596	24-Jun-19	BAGALKOT	110	VIJAYA SUGARS-MUNDARGI	MUNDARGI_110	0:00	12:22	12:22	LINE CLEAR AVAILED
597	24-Jun-19	BAGALKOT	220	220/110KV, HV1, HV2, LV1 &LV2	KUDACHI_220, KUDACHI_110, UGARKHUD_110, AINAPUR_110, TERDAL_110, MORAB_110, YELPARATTI_110	5:42	5:51	0:09	TRANSFORMER FAULT
598	24-Jun-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	0:00	7:18	7:18	LINE CLEAR AVAILED
599	24-Jun-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	5:53	6:03	0:10	LINE FAULT
600	24-Jun-19	BAGALKOT	110	ATHANI-THAVASI	THAVASI_110	10:50	17:44	6:54	LINE FAULT
601	24-Jun-19	BAGALKOT	110	BAGALKOT-NEERBUDIHAL(KATARAKI)	NEERBUDIHAL_110	15:14	16:21	1:07	LINE FAULT
602	24-Jun-19	BAGALKOT	110	BAGALKOT-LOKAPUR1	LOKAPUR_110	15:14	16:25	1:11	LINE FAULT
603	24-Jun-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	11:04	23:59	12:55	LINE CLEAR AVAILED
604	24-Jun-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	10:50	11:59	1:09	LINE CLEAR AVAILED
605	24-Jun-19	BAGALKOT	110	110/11KV,HV1	BANAHATTI_110	9:32	23:59	14:27	LINE CLEAR AVAILED
606	24-Jun-19	BAGALKOT	110	110/33KV,HV-3	BELUR_110&33KV-UAS,UDL,TATA1&2,SOUTHERN FERRO_33	12:52	14:23	1:31	LINE CLEAR AVAILED
607	24-Jun-19	BAGALKOT	220	BELGAUM-KANABARGI1	BELGAUM_220	0:00	14:25	14:25	LINE CLEAR AVAILED
608	24-Jun-19	BAGALKOT	220	BELGAUM-KANABARGI2	BELGAUM_220	0:00	6:29	6:29	LINE CLEAR AVAILED
609	24-Jun-19	BAGALKOT	220	BELGAUM-KANABARGI2	BELGAUM_220	7:57	8:28	0:31	LINE FAULT
610	24-Jun-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	0:28	3:20	2:52	LINE CLEAR AVAILED
611	24-Jun-19	BAGALKOT	220	220/110KV HV-2&LV2	MAHALINGAPUR_220	0:01	23:59	23:58	TRANSFORMER FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
612	24-Jun-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR	VAJRAMATTI_220	10:45	23:59	13:14	NFBC ISSUED
613	24-Jun-19	BAGALKOT	110	HUBLI-KALAGATAGI	KALAGATAGI_110	0:00	14:36	14:36	LINE CLEAR AVAILED
614	24-Jun-19	BAGALKOT	220	220/110KV, HV1, HV2, LV1 & LV2	NARENDRA_220, SHEDBAL_110, BELAUR_110, MR NAGAR_110, TADASINKOPPA_110, KUD DHARWAD_110	2:01	2:34	0:33	TRANSFORMER FAULT
615	24-Jun-19	BAGALKOT	110	110/11KV, HV2	NANADI_110	8:15	8:45	0:30	LINE CLEAR AVAILED
616	24-Jun-19	BAGALKOT	110	110/11KV, HV1	MURDESHWAR_110	17:48	17:53	0:05	HAND TRIPPED
617	24-Jun-19	BAGALKOT	110	VIJAYA SUGARS-MUNDARGI	MUNDARGI_110	0:00	12:22	12:22	LINE CLEAR AVAILED
618	24-Jun-19	BAGALKOT	220	220/110KV, HV1, HV2, LV1 & LV2	KUDACHI_220, KUDACHI_110, UGARKHUD_110, AINAPUR_110, TERDAL_110, MORAB_110, YELPARATTI_110	5:42	5:51	0:09	TRANSFORMER FAULT
619	24-Jun-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	0:00	7:18	7:18	LINE CLEAR AVAILED
620	24-Jun-19	BENGALURU	66	HV2	DEVANAHALLI	12:02	14:47	2:45	LINE CLEAR AVAILED
621	24-Jun-19	BENGALURU	66	HV1	KEMPANAHALLI	17:21	19:21	1:59	LINE CLEAR AVAILED
622	24-Jun-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	20:55	21:03	0:07	LINE FAULT
623	24-Jun-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	12:25	12:42	0:16	LINE FAULT
624	24-Jun-19	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	23:40	23:54	0:14	LINE FAULT
625	24-Jun-19	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI	11:01	11:32	0:31	LINE CLEAR AVAILED
626	24-Jun-19	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	10:41	11:56	1:14	LINE FAULT
627	24-Jun-19	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	9:23	9:30	0:07	LOAD CHANGEOVER
628	24-Jun-19	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), AMARJYOTHI	6:45	6:55	0:10	LOAD CHANGEOVER
629	24-Jun-19	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	11:20	12:20	1:00	LINE FAULT
630	24-Jun-19	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	6:15	6:29	0:14	LOAD CHANGEOVER
631	24-Jun-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	6:15	6:29	0:14	LOAD CHANGEOVER
632	24-Jun-19	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	11:04	11:19	0:15	LOAD CHANGEOVER
633	24-Jun-19	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	16:20	16:26	0:06	LOAD CHANGEOVER
634	24-Jun-19	BENGALURU	66	HV1	BG ROAD	10:55	12:35	1:40	TRANSFORMER FAULT
635	24-Jun-19	BENGALURU	66	HV2	BG ROAD	10:40	12:50	2:10	TRANSFORMER FAULT
636	24-Jun-19	GULBARGA	220	KAPNOOR-SHAHAPUR1	KAPNOOR_220	5:08	6:00	0:52	LINE FAULT
637	24-Jun-19	GULBARGA	220	MALLAT-RTPS	MALLAT_220	0:00	12:00	12:00	LINE FAULT
638	24-Jun-19	GULBARGA	220	LINGAPUR-LINGASUGUR	SINDHANOOR_220	15:12	15:41	0:29	LINE FAULT
639	24-Jun-19	GULBARGA	220	HV1	KUSTAGI_220	23:20	23:48	0:28	TRANSFORMER FAULT
640	24-Jun-19	GULBARGA	220	JINDAL-LINGAPUR1	JINDAL_220	20:50	21:58	1:08	LINE FAULT
641	24-Jun-19	GULBARGA	220	JINDAL-LINGAPUR2	JINDAL_220	20:50	22:11	1:21	LINE FAULT
642	24-Jun-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	3:40	3:50	0:10	LINE FAULT

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
643	24-Jun-19	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	5:20	5:30	0:10	LINE FAULT
644	24-Jun-19	GULBARGA	110	RAICHUR-SINDHANOOR1	ALKOD_110,BYAGWAT_110,SIRWAR_110,V ALKAMDINNI_10	6:10	6:25	0:15	LINE FAULT
645	24-Jun-19	GULBARGA	110	SHAHPUR-KEMBAHVI1	KEMBHAVI_110, UGARSUGAR_IPP	4:40	4:55	0:15	LINE FAULT
646	24-Jun-19	GULBARGA	110	SHAHPUR-KEMBAHVI2	KBJNL_IPP	4:40	5:00	0:20	LINE FAULT
647	24-Jun-19	GULBARGA	110	SINDHANOOR-SUZLON1	SINDHANOOR_110	1:45	1:55	0:10	LINE FAULT
648	24-Jun-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	10:35	11:05	0:30	LINE CLEAR AVAILED
649	24-Jun-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	15:05	15:15	0:10	LINE CLEAR AVAILED
650	24-Jun-19	GULBARGA	110	SINDHANOOR-MUDDAPURA	MUDDAPURA_110	10:45	11:00	0:15	LINE CLEAR AVAILED
651	24-Jun-19	GULBARGA	110	SINDHANOOR-MUDDAPURA	MUDDAPURA_110	15:10	15:20	0:10	LINE CLEAR AVAILED
652	24-Jun-19	GULBARGA	110	HV3	HATTI_110	2:50	3:07	0:17	TRANSFORMER FAULT
653	24-Jun-19	GULBARGA	110	HV2	HATTI_110	14:25	14:30	0:05	TRANSFORMER FAULT
654	24-Jun-19	GULBARGA	110	HV2	HATTI_110	15:47	15:57	0:10	TRANSFORMER FAULT
655	24-Jun-19	GULBARGA	110	SHAHAPUR-KHANAPUR	SAIDAPUR_GLB_110,WADAGERA_110,KHA NAPUR_GLB_110,CORE GREEN SUGARS_IPP,SANNATHI_IPP	19:14	19:24	0:10	LINE FAULT
656	24-Jun-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGO D_110,KAMALAPURA_110,METRI_110	19:07	19:25	0:18	LINE FAULT
657	24-Jun-19	GULBARGA	110	SHAHABAD-BAGEWADI1	MANDEWAL_110,MORATAGI_110,AFZALPU R_110	14:08	14:35	0:27	LINE FAULT
658	24-Jun-19	HASSAN	400	TALAGUPPA_400	TALAGU-HSN400#1	10:55	17:27	6:32	NFBC ISSUED
659	24-Jun-19	HASSAN	110	AJJAMPURA_110	AJAMPU-KADUR	11:18	12:16	0:58	NFBC ISSUED
660	24-Jun-19	HASSAN	66	BALLUPETE_66	BALLUPETE-KANDLI	13:13	14:42	1:29	LINE CLEAR AVAILED
661	24-Jun-19	HASSAN	66	KANDLI_66	KANDLI-SAKLESHPU	15:01	16:23	1:22	LINE CLEAR AVAILED
662	24-Jun-19	HASSAN	66	SAKLESHPU_66	SAKALE-HASSAN	15:01	16:24	1:23	NFBC ISSUED
663	24-Jun-19	MYSORE	66	HV2	BILIKERE_66	15:15	16:06	0:51	LINE CLEAR AVAILED
664	24-Jun-19	MYSORE	66	HV1	JAKKANAHALLY_66	9:51	14:22	4:31	LINE CLEAR AVAILED
665	24-Jun-19	MYSORE	66	HV2	JAKKANAHALLY_66	9:51	14:22	4:31	LINE CLEAR AVAILED
666	24-Jun-19	MYSORE	66	HV1	K_HONNALGERE_66	13:50	14:43	0:52	LINE CLEAR AVAILED
667	24-Jun-19	MYSORE	66	HV1	KIADBMANDYA_66	8:31	9:12	0:40	HAND TRIPPED
668	24-Jun-19	MYSORE	66	HV2	KIADBMANDYA_66	8:31	9:11	0:40	HAND TRIPPED
669	24-Jun-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	9:09	10:26	1:17	LINE CLEAR AVAILED
670	24-Jun-19	MYSORE	66	HV2	KMDODDI_66	12:28	12:38	0:10	TRANSFORMER FAULT
671	24-Jun-19	MYSORE	66	MADDUR-KIADB MANDYA	MADDUR_66, KIADBMANDYA_66, SOMANAHALLI_66	10:14	10:27	0:12	HAND TRIPPED
672	24-Jun-19	MYSORE	66	HV2	MADIKERI_66	13:08	13:20	0:11	HAND TRIPPED
673	24-Jun-19	MYSORE	66	HV1	SRIRANGAPATNA_66	7:46	7:58	0:11	TRANSFORMER FAULT
674	24-Jun-19	TUMKUR	66	TR-1	BADAVANAHALLI_66	16:09	17:43	1:33	LINE CLEAR AVAILED

Sl.No	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
675	24-Jun-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	12:59	13:25	0:25	HAND TRIPPED
676	24-Jun-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	17:12	17:52	0:39	LINE FAULT
677	24-Jun-19	TUMKUR	66	TR-1	DEVARAHALLI_66	12:25	12:43	0:18	TRANSFORMER FAULT
678	24-Jun-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	4:53	5:13	0:19	LINE FAULT
679	24-Jun-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66,CHITRADURGA_220	16:58	17:53	0:55	LINE FAULT