

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 23.04.2019 to 29.04.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	23-Apr-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	5:21	5:41	0:20	LINE FAULT
2	23-Apr-19	BAGALKOT	110	BAGEWADI220-MAMDAPUR1	MAMADAPUR(B)_110	17:29	17:45	0:16	LINE FAULT
3	23-Apr-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR2	MAMADAPUR(B)_110	17:29	17:45	0:16	LINE FAULT
4	23-Apr-19	BAGALKOT	110	110/11KV,HV2	JAMKHANDI_110	10:48	10:55	0:07	TRANSFORMER FAULT
5	23-Apr-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	14:28	16:35	2:07	LINE FAULT
6	23-Apr-19	BAGALKOT	220	SIRSI-HUBLI 2	SIRSI_220	14:23	23:59	9:36	LINE FAULT
7	23-Apr-19	BAGALKOT	110	110/11KV,HV2	LAXMESWAR_110	0:00	0:22	0:22	LINE CLEAR AVAILED
8	23-Apr-19	BAGALKOT	110	110/33KV,HV3	LAXMESWAR_110	12:18	12:30	0:12	TRANSFORMER FAULT
9	23-Apr-19	BAGALKOT	110	220/110KV,LV1	KUDUCHI_220,UGAR KHUD_110,MORAB_110,AINAPUR_110,K UDUCHI_110,YELPARATTI_110,TERDAL_1 10	5:07	5:12	0:05	TRANSFORMER FAULT
10	23-Apr-19	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWAD	KAGAWAD_110	5:15	5:21	0:06	LINE FAULT
11	23-Apr-19	BENGALURU	220	HV2	TK HALLI 220	16:21	16:33	0:11	TRANSFORMER FAULT
12	23-Apr-19	BENGALURU	220	HV2	SUBRAMANYAPURA 220	17:45	18:10	0:25	MAIN SUPPLY FAILURE
13	23-Apr-19	BENGALURU	220	HV3	SUBRAMANYAPURA 220	17:45	18:13	0:27	MAIN SUPPLY FAILURE
14	23-Apr-19	BENGALURU	220	SOMANAHALLI 220 - KHODAYS 220	KHODAYS 220	17:45	18:10	0:25	LINE FAULT
15	23-Apr-19	BENGALURU	220	KHODAYS 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	17:45	18:17	0:32	LINE FAULT
16	23-Apr-19	BENGALURU	220	HV1	KHODAYS 220	17:45	18:18	0:33	MAIN SUPPLY FAILURE
17	23-Apr-19	BENGALURU	220	HV2	KHODAYS 220	17:45	18:18	0:32	MAIN SUPPLY FAILURE
18	23-Apr-19	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	TK HALLI 220	16:21	20:12	3:50	LINE FAULT
19	23-Apr-19	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	TK HALLI 220	16:21	16:38	0:16	LINE FAULT
20	23-Apr-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	16:21	16:33	0:11	MAIN SUPPLY FAILURE
21	23-Apr-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	17:45	18:15	0:29	MAIN SUPPLY FAILURE
22	23-Apr-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	17:45	18:15	0:29	MAIN SUPPLY FAILURE
23	23-Apr-19	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	17:45	18:13	0:28	MAIN SUPPLY FAILURE
24	23-Apr-19	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	17:45	18:15	0:29	MAIN SUPPLY FAILURE
25	23-Apr-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	18:54	18:57	0:02	LOAD CHANGEOVER
26	23-Apr-19	BENGALURU	66	HV1	KHODAYS 220	17:45	18:20	0:35	MAIN SUPPLY FAILURE
27	23-Apr-19	BENGALURU	66	HV2	KHODAYS 220	17:45	18:20	0:35	MAIN SUPPLY FAILURE
28	23-Apr-19	BENGALURU	66	HV1	KHB	3:10	3:25	0:14	TRANSFORMER FAULT
29	23-Apr-19	BENGALURU	66	HV1	CHANDRAPPA CIRCLE	21:57	22:10	0:13	TRANSFORMER FAULT
30	23-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	10:35	12:00	1:25	LINE CLEAR AVAILED
31	23-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	11:20	12:15	0:55	LINE CLEAR AVAILED
32	23-Apr-19	BENGALURU	66	HV1	HOSKOTE 220	6:03	6:13	0:10	TRANSFORMER FAULT
33	23-Apr-19	BENGALURU	66	HV1	HOSKOTE 220	6:17	6:22	0:05	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
34	23-Apr-19	BENGALURU	66	HV1	CHANDAPURA	12:05	12:10	0:05	LINE CLEAR AVAILED
35	23-Apr-19	BENGALURU	66	HV2	CHANDAPURA	14:48	15:20	0:32	LINE CLEAR AVAILED
36	23-Apr-19	BENGALURU	66	HV1	RANGANDODDI	9:53	10:27	0:33	LINE CLEAR AVAILED
37	23-Apr-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	19:05	19:15	0:10	LINE FAULT
38	23-Apr-19	GULBARGA	110	HV2	KOLHAR_110	17:15	18:05	0:50	LINE CLEAR AVAILED
39	23-Apr-19	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	5:38	5:40	0:02	LINE FAULT
40	23-Apr-19	GULBARGA	110	SIDHANOOR-TURVIHAL	TURVIHAL_110	4:18	4:25	0:07	LINE FAULT
41	23-Apr-19	GULBARGA	110	SIDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110,BTPS_ WATERWORKS	5:10	5:20	0:10	LINE FAULT
42	23-Apr-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	17:01	18:57	1:56	LINE FAULT
43	23-Apr-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	17:01	23:59	6:58	LINE FAULT
44	23-Apr-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	17:01	23:59	6:58	LINE FAULT
45	23-Apr-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	15:30	19:43	4:13	LINE FAULT
46	23-Apr-19	HASSAN	220	HV1	MSEZ_220	9:59	14:45	4:46	LINE CLEAR AVAILED
47	23-Apr-19	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	9:54	23:59	14:05	LINE FAULT
48	23-Apr-19	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	15:24	19:50	4:26	LINE FAULT
49	23-Apr-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	17:01	23:59	6:58	LINE FAULT
50	23-Apr-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	17:01	23:59	6:58	LINE FAULT
51	23-Apr-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	17:01	18:59	1:58	LINE FAULT
52	23-Apr-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	15:30	19:45	4:15	LINE FAULT
53	23-Apr-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	18:02	19:10	1:08	LINE FAULT
54	23-Apr-19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	17:27	18:25	0:58	LINE FAULT
55	23-Apr-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	17:27	18:41	1:14	LINE FAULT
56	23-Apr-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	18:42	19:30	0:48	LINE FAULT
57	23-Apr-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	19:30	23:59	4:29	LINE CLEAR AVAILED
58	23-Apr-19	HASSAN	110	LV1	MSEZ_220	9:59	14:45	4:46	LINE CLEAR AVAILED
59	23-Apr-19	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	18:03	19:14	1:11	MAIN SUPPLY FAILURE
60	23-Apr-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	18:03	19:14	1:11	MAIN SUPPLY FAILURE
61	23-Apr-19	HASSAN	110	HV2	HIRIYADKA_110	18:03	19:14	1:11	MAIN SUPPLY FAILURE
62	23-Apr-19	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	18:03	19:14	1:11	MAIN SUPPLY FAILURE
63	23-Apr-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	18:03	19:14	1:11	MAIN SUPPLY FAILURE
64	23-Apr-19	HASSAN	110	HOSNGD-HALDY	HOSNGADI_110	18:00	18:42	0:42	MAIN SUPPLY FAILURE
65	23-Apr-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	17:28	18:32	1:04	MAIN SUPPLY FAILURE
66	23-Apr-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	11:40	14:02	2:22	LINE CLEAR AVAILED
67	23-Apr-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	17:28	23:59	6:31	MAIN SUPPLY FAILURE
68	23-Apr-19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	17:28	18:32	1:04	MAIN SUPPLY FAILURE
69	23-Apr-19	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	17:28	18:32	1:04	MAIN SUPPLY FAILURE
70	23-Apr-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:55	15:20	0:25	HAND TRIPPED
71	23-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:07	18:46	11:39	LINE CLEAR AVAILED
72	23-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:07	18:46	11:39	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
73	23-Apr-19	MYSORE	66	G UKKADA-METAGALLI	SRIRANGAPATNA_66	9:00	10:30	1:29	LINE CLEAR AVAILED
74	23-Apr-19	MYSORE	66	HV1	HULLAHALLI_66	11:13	11:19	0:06	HAND TRIPPED
75	23-Apr-19	MYSORE	66	HV2	HULLAHALLI_66	11:00	11:04	0:03	HAND TRIPPED
76	23-Apr-19	MYSORE	66	HV1	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 K_HONNALGERE_66 TUMBEKERE_66	16:21	16:34	0:12	HAND TRIPPED
77	23-Apr-19	MYSORE	66	HV2	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 K_HONNALGERE_66 TUMBEKERE_66	16:21	16:34	0:12	HAND TRIPPED
78	23-Apr-19	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 K_HONNALGERE_66 TUMBEKERE_66	7:54	8:07	0:13	LINE FAULT
79	23-Apr-19	MYSORE	66	PARINAMIPURA-TALAKADU	BGPURA_66 THALAKADU_66	21:53	22:03	0:09	LINE FAULT
80	23-Apr-19	MYSORE	66	HV2	SATHEGALA_66	10:41	11:20	0:38	HAND TRIPPED
81	23-Apr-19	MYSORE	66	HV1	THANDYA_66	9:57	11:06	1:08	LINE CLEAR AVAILED
82	23-Apr-19	MYSORE	66	HV2	THANDYA_66	11:05	11:07	0:01	HAND TRIPPED
83	23-Apr-19	MYSORE	66	HV2	TNARASIPURA_66	16:14	16:29	0:15	LINE CLEAR AVAILED
84	23-Apr-19	TUMKUR	66	TR-1	CHITRADURGA_66	15:27	15:33	0:06	TRANSFORMER FAULT
85	23-Apr-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:36	12:38	0:01	LINE FAULT
86	23-Apr-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:02	9:08	0:05	HAND TRIPPED
87	24-Apr-19	BAGALKOT	220	XELDOM-AMBEWADI	AMBEWADI_220	14:06	18:51	4:45	LINE FAULT
88	24-Apr-19	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	8:38	14:11	5:33	NFBC ISSUED
89	24-Apr-19	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	22:53	23:59	1:06	LINE FAULT
90	24-Apr-19	BAGALKOT	220	220/110KV,HV2	BELGAUM_220	15:12	15:13	0:01	TRANSFORMER FAULT
91	24-Apr-19	BAGALKOT	220	220/110KV,HV1 & LV1	BELGAUM_220,ANKALAGI_110,UCHGOAN _110,VADAGOAN_110,KANABARGI_110,B ELGAUM_110	15:12	15:14	0:02	TRANSFORMER FAULT
92	24-Apr-19	BAGALKOT	110	MAHALINGAPUR220-DAVALESHWARA	DAVALESHWARA_110	1:30	1:33	0:03	MAIN SUPPLY FAILURE
93	24-Apr-19	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	19:14	21:13	1:59	LINE FAULT
94	24-Apr-19	BAGALKOT	110	110/11KV,HV2A	JAMKHANDI_110	16:01	17:23	1:22	LINE CLEAR AVAILED
95	24-Apr-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGHATAGI_110	14:29	15:45	1:16	MAIN SUPPLY FAILURE
96	24-Apr-19	BAGALKOT	110	KARWAR220-KUMTA	KUMTA_110	5:53	14:07	8:14	LINE FAULT
97	24-Apr-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110	6:14	8:19	2:05	LINE FAULT
98	24-Apr-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110	11:18	14:07	2:49	LINE CLEAR AVAILED
99	24-Apr-19	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	11:24	13:40	2:16	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
100	24-Apr-19	BAGALKOT	110	VAJRAMATTI220-MANTUR1	MANTUR_110	9:23	9:37	0:14	LINE FAULT
101	24-Apr-19	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	10:32	11:08	0:36	LINE CLEAR AVAILED
102	24-Apr-19	BAGALKOT	110	110/11KV,HV4	VADAGOAN_110	13:05	13:30	0:25	LINE CLEAR AVAILED
103	24-Apr-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	3:19	3:50	0:31	LINE FAULT
104	24-Apr-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	4:02	12:37	8:35	LINE FAULT
105	24-Apr-19	BAGALKOT	110	HUBLI-KALGHATAGI	KALGHATAGI_110	12:24	15:41	3:17	LINE FAULT
106	24-Apr-19	BAGALKOT	110	110/33KV,HV3	SINDAGI_110	12:32	14:38	2:06	LINE CLEAR AVAILED
107	24-Apr-19	BAGALKOT	110	110/33KV,HV3	SINDAGI_110,KALKERI_33KV,GOLGERI_33KV	14:41	14:47	0:06	TRANSFORMER FAULT
108	24-Apr-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	14:03	14:17	0:14	LINE FAULT
109	24-Apr-19	BAGALKOT	110	PG HUNSYAL-NAGNUR(MUDALGI)	NAGNUR_110	10:39	10:50	0:11	LINE FAULT
110	24-Apr-19	BAGALKOT	110	PG HUNSYAL-NAGNUR(MUDALGI)	NAGNUR_110	11:10	11:19	0:09	LINE FAULT
111	24-Apr-19	BAGALKOT	110	110/33KV,HV1	MK HUBLI_110,GANDHI WADA_33KV	13:00	13:49	0:49	LINE CLEAR AVAILED
112	24-Apr-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	0:00	6:28	6:28	LINE CLEAR AVAILED
113	24-Apr-19	BAGALKOT	110	PG HUNSYAL-NAGNUR(MUDALGI)	NAGNUR_110	11:39	13:41	2:02	LINE FAULT
114	24-Apr-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	12:53	14:24	1:31	LINE CLEAR AVAILED
115	24-Apr-19	BAGALKOT	220	SIRSI-HUBLI	SIRSI_220	0:00	11:57	11:57	LINE CLEAR AVAILED
116	24-Apr-19	BAGALKOT	220	SIRSI-HUBLI	SIRSI_220	12:00	15:19	3:19	LINE FAULT
117	24-Apr-19	BAGALKOT	220	SIRSI-HUBLI	SIRSI_220	15:19	18:03	2:44	LINE FAULT
118	24-Apr-19	BAGALKOT	110	110/33KV,HV3	TARIHAL_110,DHUMMAWADA_33KV,INDUSTRIAL ESTATE_33KV	10:09	11:12	1:03	LINE CLEAR AVAILED
119	24-Apr-19	BENGALURU	66	HV2	BUDIGERE	15:00	15:10	0:10	LINE CLEAR AVAILED
120	24-Apr-19	BENGALURU	66	HV1	BUDIGERE	16:10	16:35	0:25	LINE CLEAR AVAILED
121	24-Apr-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	13:01	13:37	0:35	LINE CLEAR AVAILED
122	24-Apr-19	BENGALURU	66	HV1	DALASNUR	11:02	11:34	0:31	LINE CLEAR AVAILED
123	24-Apr-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	18:00	18:15	0:15	LINE FAULT
124	24-Apr-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	7:37	7:47	0:10	LINE FAULT
125	24-Apr-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:12	11:15	0:02	LINE FAULT
126	24-Apr-19	BENGALURU	66	WELCAST - SRS PEENYA 220	WELCAST	9:44	9:50	0:06	LOAD CHANGE OVER
127	24-Apr-19	BENGALURU	66	WELCAST - ABBIGERE	WELCAST	13:30	13:34	0:04	LOAD CHANGE OVER
128	24-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	12:07	15:43	3:35	LINE FAULT
129	24-Apr-19	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	15:25	15:36	0:11	LOAD CHANGE OVER
130	24-Apr-19	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	18:20	18:30	0:10	LOAD CHANGE OVER
131	24-Apr-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	8:04	8:17	0:13	LOAD CHANGE OVER
132	24-Apr-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	8:12	8:17	0:05	LOAD CHANGE OVER
133	24-Apr-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	17:40	17:45	0:05	LOAD CHANGE OVER
134	24-Apr-19	BENGALURU	66	SRS PEENYA 220 - ALUR	ALUR, BIEC	8:04	8:30	0:26	LOAD CHANGE OVER
135	24-Apr-19	BENGALURU	66	NELAMANGALA 66 - ALUR	ALUR, BIEC	13:55	14:29	0:34	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
136	24-Apr-19	BENGALURU	66	SOLADEVANAHALLI - SRS PEENYA 220	ALUR, BIEC	17:23	17:36	0:13	LOAD CHANGEOVER
137	24-Apr-19	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	6:32	6:41	0:09	LINE FAULT
138	24-Apr-19	BENGALURU	66	HV2	GOKULA	11:30	11:35	0:04	LINE CLEAR AVAILED
139	24-Apr-19	BENGALURU	66	HV1	KHB	11:22	11:27	0:04	LINE CLEAR AVAILED
140	24-Apr-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	7:45	7:50	0:05	LOAD CHANGEOVER
141	24-Apr-19	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	9:44	9:50	0:05	LOAD CHANGEOVER
142	24-Apr-19	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	17:21	17:27	0:06	LOAD CHANGEOVER
143	24-Apr-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	8:15	8:20	0:05	LOAD CHANGEOVER
144	24-Apr-19	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	17:25	17:30	0:05	LOAD CHANGEOVER
145	24-Apr-19	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI, BRINDAVANA	7:05	9:25	2:19	LINE FAULT
146	24-Apr-19	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI, BRINDAVANA	9:47	9:50	0:02	LOAD CHANGEOVER
147	24-Apr-19	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI, BRINDAVANA	17:15	17:18	0:03	LOAD CHANGEOVER
148	24-Apr-19	BENGALURU	220	HV2	SRS PEENYA 220	7:05	7:27	0:21	TRANSFORMER FAULT
149	24-Apr-19	BENGALURU	220	HV2	SRS PEENYA 220	7:27	16:59	9:32	TRANSFORMER FAULT
150	24-Apr-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	14:26	14:55	0:29	LOAD CHANGEOVER
151	24-Apr-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	8:43	8:46	0:02	LOAD CHANGEOVER
152	24-Apr-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	17:15	17:20	0:05	LOAD CHANGEOVER
153	24-Apr-19	GULBARGA	400	BTPSG-RTPS	BTPSG_400	11:20	23:59	12:39	LINE CLEAR AVAILED
154	24-Apr-19	GULBARGA	220	LINGAPUR-JINDAL1,2,BTPS,BMM ISPAT,GDHALI1,2,KUSHTAGI,SINDHANO OR,MUNIRABAD TR1,TR2,KUSHTAGI,SINDHANOOR	LINGAPUR_220,KUSTAGI_220,BMM ISPAT_IPP	12:17	12:45	0:28	LINE CLEAR AVAILED
155	24-Apr-19	GULBARGA	110	HV1	HANUMSAGAR_110	9:10	9:20	0:10	TRANSFORMER FAULT
156	24-Apr-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	11:16	13:06	1:50	LINE CLEAR AVAILED
157	24-Apr-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	3:13	6:56	3:43	LINE CLEAR AVAILED
158	24-Apr-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	0:00	10:27	10:27	LINE FAULT
159	24-Apr-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	0:00	17:30	17:30	LINE FAULT
160	24-Apr-19	HASSAN	220	HV2	MSEZ_220	9:48	13:42	3:54	LINE CLEAR AVAILED
161	24-Apr-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	0:00	10:27	10:27	LINE FAULT
162	24-Apr-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	0:00	17:30	17:30	LINE FAULT
163	24-Apr-19	HASSAN	110	LV2	MSEZ_220	9:47	13:42	3:55	LINE CLEAR AVAILED
164	24-Apr-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	10:30	10:32	0:02	HAND TRIPPED
165	24-Apr-19	HASSAN	110	JOG110-LPH	JOG_110110	9:10	10:23	1:13	MAIN SUPPLY FAILURE
166	24-Apr-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	10:28	14:03	3:35	LINE CLEAR AVAILED
167	24-Apr-19	HASSAN	110	HV1	KONAJE_110	15:44	16:01	0:17	LINE CLEAR AVAILED
168	24-Apr-19	HASSAN	110	HV2	KONAJE_110	15:19	15:44	0:25	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
169	24-Apr-19	HASSAN	110	HV3	KONAJE_110	10:30	17:06	6:36	LINE CLEAR AVAILED
170	24-Apr-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	0:00	9:35	9:35	MAIN SUPPLY FAILURE
171	24-Apr-19	HASSAN	66	HV1	CHIKMAGALUR_66	5:32	6:41	1:09	MAIN SUPPLY FAILURE
172	24-Apr-19	HASSAN	66	HV1	HARIHARPURA_66	13:20	13:53	0:33	LINE CLEAR AVAILED
173	24-Apr-19	HASSAN	66	HASSN220-MALLALI	HASSAN_220	11:05	12:25	1:20	LINE CLEAR AVAILED
174	24-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	11:35	18:45	7:10	LINE CLEAR AVAILED
175	24-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	11:35	18:45	7:10	LINE CLEAR AVAILED
176	24-Apr-19	HASSAN	66	HV1	SIGEBAGE_66	10:10	17:29	7:19	LINE CLEAR AVAILED
177	24-Apr-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	10:10	17:29	7:19	LINE CLEAR AVAILED
178	24-Apr-19	MYSORE	66	HV1	HEBBAL_66	20:16	20:20	0:03	HAND TRIPPED
179	24-Apr-19	MYSORE	66	HV2	HEBBAL_66	20:16	23:59	3:42	LINE CLEAR AVAILED
180	24-Apr-19	MYSORE	66	HONNALLI-ATTIGULIPURA	ATTIGULIPURA_66	17:14	17:21	0:06	LINE CLEAR AVAILED
181	24-Apr-19	MYSORE	220	HV1	BOGADHI_66 DATTAGALLY_66 HEBBAL_66 METAGALLY_66 RKNAGARA_66 VIJAYANAGRAMYS_66.	13:16	16:27	3:11	LINE CLEAR AVAILED
182	24-Apr-19	MYSORE	220	HV2	BOGADHI_66 DATTAGALLY_66 HEBBAL_66 METAGALLY_66 RKNAGARA_66 VIJAYANAGRAMYS_66.	13:28	16:46	3:18	TRANSFORMER FAULT
183	24-Apr-19	MYSORE	66	HV1	HOOTAGALLY_220	13:27	16:44	3:17	LINE CLEAR AVAILED
184	24-Apr-19	MYSORE	66	HV2	HOOTAGALLY_220	13:23	16:47	3:24	LINE CLEAR AVAILED
185	24-Apr-19	MYSORE	66	HV1	KRNAGARA_66	11:44	12:05	0:21	LINE CLEAR AVAILED
186	24-Apr-19	MYSORE	66	HV1	KRNAGARA_66	12:05	23:59	11:53	LINE CLEAR AVAILED
187	24-Apr-19	MYSORE	66	HV2	KRNAGARA_66	13:02	14:27	1:25	LINE CLEAR AVAILED
188	24-Apr-19	MYSORE	66	KUNTHUR-DR PETE	MUGUR_66 THAYURU_66 SANTHEMARAHALLI_66 TNARASIPURA_66 STATIONS INTERRUPTED.	23:27	23:34	0:07	LINE FAULT
189	24-Apr-19	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	PARINAMIPURA_66 BGPURA_66 THALAKADU_66	17:13	17:20	0:07	LINE FAULT
190	24-Apr-19	MYSORE	66	PARINAMIPURA-TALAKADU	BGPURA_66 THALAKADU_66	4:24	4:32	0:08	LINE FAULT
191	24-Apr-19	MYSORE	66	RK NAGARA-DATTAGALLI	DATTAGALLY_66	14:48	15:25	0:37	HAND TRIPPED
192	24-Apr-19	TUMKUR	66	ANCHEPALYA 220kv- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	5:44	6:31	0:47	LINE FAULT
193	24-Apr-19	TUMKUR	66	DODDASARANGI-ANCHEPALYA	DODDASARANGI_66	0:31	0:41	0:09	LINE FAULT
194	24-Apr-19	TUMKUR	66	DODDASARANGI-ANCHEPALYA	DODDASARANGI_66	7:40	11:32	3:52	LINE FAULT
195	24-Apr-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	5:33	5:48	0:15	LINE FAULT
196	24-Apr-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:11	9:21	0:09	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
197	24-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:20	10:35	0:15	LINE FAULT
198	24-Apr-19	TUMKUR	66	DYAVARANAHALI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	15:46	17:38	1:52	MAIN SUPPLY FAILURE
199	24-Apr-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE 1	CHALLAKERE_66, SANIKERE_66	13:51	14:23	0:31	HAND TRIPPED
200	24-Apr-19	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	13:51	14:42	0:50	LINE FAULT
201	24-Apr-19	TUMKUR	66	TR-2 (LV-2)	THALLAKK_220	16:26	16:49	0:23	HAND TRIPPED
202	24-Apr-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:58	14:21	0:23	LINE FAULT
203	25-Apr-19	BAGALKOT	220	HIREBENDIGERI 1&2-BIDNAL	BIDNAL_220	9:03	17:29	8:26	LINE CLEAR AVAILED
204	25-Apr-19	BAGALKOT	220	HIREBENDIGERI 2-BIDNAL	BIDNAL_220	17:33	17:38	0:05	HAND TRIPPED
205	25-Apr-19	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	0:00	13:15	13:15	LINE CLEAR AVAILED
206	25-Apr-19	BAGALKOT	220	BELGAUM-NARENDRA 1	BELGAUM_220	14:33	15:07	0:34	LINE FAULT
207	25-Apr-19	BAGALKOT	110	DKSSK COGEN-CHIKKODI 220	CHIKKODI_220,DKSSK COGEN	11:14	12:22	1:08	LINE CLEAR AVAILED
208	25-Apr-19	BAGALKOT	110	KARWAR220-BINGA	BINGA_110	2:57	3:17	0:20	LINE FAULT
209	25-Apr-19	BAGALKOT	110	KARWAR220-BINGA	BINGA_110	4:58	13:11	8:13	LINE FAULT
210	25-Apr-19	BAGALKOT	110	KARWAR220-KUMTA	KUMTA_110	4:58	12:49	7:51	LINE FAULT
211	25-Apr-19	BAGALKOT	110	KARWAR220-BINGA	BINGA_110	13:46	13:57	0:11	HAND TRIPPED
212	25-Apr-19	BAGALKOT	220	220/110KV,HV1&2,LV1	KUDUCHI_220,TERDAL_110,YELLAPARATTI_110,MORAB_110,AINAPUR_110,UGAR KHUD_110,KUDUCHI_110	12:57	13:05	0:08	TRANSFORMER FAULT
213	25-Apr-19	BAGALKOT	220	KUDUCHI-GHATAPRABHA	KUDUCHI_220	10:24	13:51	3:27	NFBC ISSUED
214	25-Apr-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	15:02	15:09	0:07	HAND TRIPPED
215	25-Apr-19	BAGALKOT	110	110/11KV,HV4	VADAGOAN_110	13:03	14:06	1:03	TRANSFORMER FAULT
216	25-Apr-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	15:45	16:43	0:58	LINE CLEAR AVAILED
217	25-Apr-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	16:46	16:50	0:04	LINE CLEAR AVAILED
218	25-Apr-19	BAGALKOT	110	CHIKKODI220-NANADI	NANADI_110	10:55	12:15	1:20	MAIN SUPPLY FAILURE
219	25-Apr-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	0:04	0:20	0:16	TRANSFORMER FAULT
220	25-Apr-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	0:29	0:38	0:09	TRANSFORMER FAULT
221	25-Apr-19	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI(JAMKHANDI)	BANAHATTI_110	19:37	19:41	0:04	LOAD CURTAILMENT
222	25-Apr-19	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110,NTPCL_33KV,KOLAR WATER SUPPLY_33KV,KARJOL LIS_33KV	14:04	14:09	0:05	TRANSFORMER FAULT
223	25-Apr-19	BAGALKOT	110	KUMTA-SIRSI 1	KUMTA_110	13:00	23:59	10:59	LINE CLEAR AVAILED
224	25-Apr-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY	5:43	5:55	0:12	LINE FAULT
225	25-Apr-19	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	12:19	15:25	3:05	LINE CLEAR AVAILED
226	25-Apr-19	BENGALURU	220	HV2	HAL 220	11:06	11:51	0:44	TRANSFORMER FAULT
227	25-Apr-19	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	11:06	23:59	12:52	LINE FAULT
228	25-Apr-19	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	11:06	11:54	0:47	MAIN SUPPLY FAILURE
229	25-Apr-19	BENGALURU	66	HAL 220 - HAL (EHT)	HSL (EHT)	11:06	11:54	0:47	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
230	25-Apr-19	BENGALURU	66	HV1	HAL 220	11:08	11:58	0:50	MAIN SUPPLY FAILURE
231	25-Apr-19	BENGALURU	66	HV2	HAL 220	11:08	11:59	0:50	MAIN SUPPLY FAILURE
232	25-Apr-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	18:51	18:56	0:05	LOAD CHANGEOVER
233	25-Apr-19	BENGALURU	66	APPEATEL PARK - KIADB DB PRUA 220	APPEATEL PARK	12:41	12:45	0:04	LOAD CHANGEOVER
234	25-Apr-19	BENGALURU	66	HV2	YERANDANAHALLI 220	13:44	13:48	0:04	LOAD CHANGEOVER
235	25-Apr-19	BENGALURU	66	YERANDANAHALLI 220	YERANDANAHALLI 220	18:44	18:48	0:04	LOAD CHANGEOVER
236	25-Apr-19	GULBARGA	400	BTPSG-RTPS	BTPSG_400	0:00	18:55	18:55	LINE CLEAR AVAIED
237	25-Apr-19	HASSAN	220	ARSK2-NITTUR	ARASIKERE_220	8:18	17:56	9:38	LINE CLEAR AVAIED
238	25-Apr-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	9:54	18:22	8:28	LINE CLEAR AVAIED
239	25-Apr-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	9:54	18:25	8:31	LINE CLEAR AVAIED
240	25-Apr-19	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	9:54	18:22	8:28	NFBC ISSUED
241	25-Apr-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	9:54	18:25	8:31	NFBC ISSUED
242	25-Apr-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	16:48	18:45	1:57	MAIN SUPPLY FAILURE
243	25-Apr-19	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	8:05	18:17	10:12	LINE CLEAR AVAIED
244	25-Apr-19	HASSAN	110	HV2	GURUVAYANAKERE_110	10:19	13:12	2:53	LINE CLEAR AVAIED
245	25-Apr-19	HASSAN	110	KADUR-TNGL	KADUR_220	19:32	19:50	0:18	HAND TRIPPED
246	25-Apr-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	5:42	5:57	0:15	LINE FAULT
247	25-Apr-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	6:30	7:35	1:05	LINE FAULT
248	25-Apr-19	HASSAN	110	HV1	KONDENALU_110	10:27	18:37	8:10	LINE CLEAR AVAIED
249	25-Apr-19	HASSAN	110	HV2	KONDENALU_110	10:27	18:37	8:10	LINE CLEAR AVAIED
250	25-Apr-19	HASSAN	66	HV2	HASSAN_66	11:50	14:05	2:15	LINE CLEAR AVAIED
251	25-Apr-19	HASSAN	66	HV1	KANDLI_66	11:05	12:10	1:05	LINE CLEAR AVAIED
252	25-Apr-19	HASSAN	66	HV2	KANDLI_66	15:15	19:45	4:30	LINE CLEAR AVAIED
253	25-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:39	19:10	11:31	LINE CLEAR AVAIED
254	25-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:39	19:10	11:31	LINE CLEAR AVAIED
255	25-Apr-19	HASSAN	66	HV2	SINGAPURA_66	11:55	14:50	2:55	LINE CLEAR AVAIED
256	25-Apr-19	MYSORE	66	BOOKANKERE-CHINAKURALI	BANANGADI_66 CHINAKURALI_66 PANDAVAPURA_66	10:29	10:40	0:10	LINE FAULT
257	25-Apr-19	MYSORE	66	BOOKANKERE-CHINAKURALI	BANANGADI_66 CHINAKURALI_66 PANDAVAPURA_66	11:09	23:59	12:49	LINE FAULT
258	25-Apr-19	MYSORE	66	HANAGODU-PONNAMPETE	PONNAMPET_66 VIRAJPET_66	11:47	16:55	5:07	NFBC ISSUED
259	25-Apr-19	MYSORE	66	HOOTAGALLI-HEBBAL	HEBBAL_66	11:02	12:57	1:55	LINE CLEAR AVAIED
260	25-Apr-19	MYSORE	66	HV1	JAIPUR_66	10:00	12:42	2:42	LINE CLEAR AVAIED
261	25-Apr-19	MYSORE	66	HV1	KHBCOLONY_66	11:04	12:37	1:32	LINE CLEAR AVAIED
262	25-Apr-19	MYSORE	66	KR PETE 220-BOOKANKERE	BANANGADI_66 CHINAKURALI_66 PANDAVAPURA_66 BOOKANAKERE_66 GANJIGERE_66	7:40	7:47	0:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
263	25-Apr-19	MYSORE	66	KUNTHUR-DR PETE	MUGUR_66 SANTHEMARAHALLI_66 THAYURU_66 TNARASIPURA_66	4:54	4:57	0:02	LINE FAULT
264	25-Apr-19	MYSORE	66	HV2	MADHUVANAHALLI_220	13:15	14:02	0:47	LINE CLEAR AVAILED
265	25-Apr-19	MYSORE	66	HV1	METAGALLY_66	11:04	11:09	0:04	HAND TRIPPED
266	25-Apr-19	MYSORE	66	HV2	METAGALLY_66	11:04	11:09	0:04	HAND TRIPPED
267	25-Apr-19	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 1	PERIYAPATNA_66	11:10	11:15	0:05	LINE FAULT
268	25-Apr-19	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 2	PERIYAPATNA_66	11:10	11:15	0:05	LINE FAULT
269	25-Apr-19	MYSORE	66	PERIYAPATNA-HANAGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	11:10	16:35	5:25	LINE FAULT
270	25-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	13:35	21:20	7:45	LINE CLEAR AVAILED
271	25-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	11:37	20:20	8:42	LINE CLEAR AVAILED
272	25-Apr-19	MYSORE	66	HV1	THANDYA_66	9:45	14:09	4:23	LINE CLEAR AVAILED
273	25-Apr-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:56	12:31	0:34	LINE FAULT
274	25-Apr-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:57	12:31	0:34	LINE FAULT
275	25-Apr-19	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	8:19	17:56	9:36	LINE CLEAR AVAILED
276	25-Apr-19	TUMKUR	110	HONNAVALLI 110- KADUR220	HONNAVALLI_110	8:39	18:50	10:10	LINE CLEAR AVAILED
277	25-Apr-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	19:25	19:56	0:30	HAND TRIPPED
278	25-Apr-19	TUMKUR	66	TR-2	CHITRADURGA_220	11:56	12:41	0:44	TRANSFORMER FAULT
279	25-Apr-19	TUMKUR	66	TR-2	DAVANAGERE_66	7:22	7:28	0:05	TRANSFORMER FAULT
280	25-Apr-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	16:12	16:28	0:16	MAIN SUPPLY FAILURE
281	25-Apr-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	17:43	17:45	0:02	LINE CLEAR AVAILED
282	25-Apr-19	TUMKUR	66	HONNALLI 220kV- NALLUR	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	1:45	1:53	0:08	LINE FAULT
283	25-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	18:35	18:44	0:09	LINE FAULT
284	25-Apr-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	5:53	6:02	0:08	LINE FAULT
285	25-Apr-19	TUMKUR	66	TR-1	MYLANAHALLI_66	18:09	18:15	0:05	TRANSFORMER FAULT
286	26-Apr-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	11:08	16:16	5:08	LINE CLEAR AVAILED
287	26-Apr-19	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	9:58	11:51	1:53	LINE CLEAR AVAILED
288	26-Apr-19	BAGALKOT	220	ALAMATTI 1-BAGALKOT	BAGALKOT_220	12:03	13:46	1:43	LINE CLEAR AVAILED
289	26-Apr-19	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	17:38	23:59	6:21	LINE FAULT
290	26-Apr-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	16:58	17:13	0:15	LOAD CURTAILMENT
291	26-Apr-19	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	17:35	17:42	0:07	LOAD CURTAILMENT
292	26-Apr-19	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	21:58	22:34	0:36	TRANSFORMER FAULT
293	26-Apr-19	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	19:36	21:34	1:58	LINE CLEAR AVAILED
294	26-Apr-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	16:59	17:12	0:13	LOAD CURTAILMENT
295	26-Apr-19	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	17:36	17:57	0:21	LOAD CURTAILMENT
296	26-Apr-19	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	19:11	19:30	0:19	LINE CLEAR AVAILED
297	26-Apr-19	BAGALKOT	110	ENERCONE-BIJAPUR	BIJAPUR_220	1:05	1:12	0:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
298	26-Apr-19	BAGALKOT	220	HIREBENDIGERI 1&2-BIDNAL	BIDNAL_220	8:50	17:20	8:30	LINE CLEAR AVAILED
299	26-Apr-19	BAGALKOT	220	HIREBENDIGERI 2-BIDNAL	BIDNAL_220	18:18	23:59	5:41	LINE CLEAR AVAILED
300	26-Apr-19	BAGALKOT	220	BIDNAL220-SOUDATTI	BIDNAL_220	11:37	16:25	4:48	LINE FAULT
301	26-Apr-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	16:59	17:56	0:57	LOAD CURTAILMENT
302	26-Apr-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	16:59	17:14	0:15	LOAD CURTAILMENT
303	26-Apr-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	17:36	17:47	0:11	LOAD CURTAILMENT
304	26-Apr-19	BAGALKOT	110	JAMBAGI-MUDHOL	MUDHOL_110	1:53	10:11	8:18	LINE FAULT
305	26-Apr-19	BAGALKOT	66	110/33KV,HV4	HARIHAR HOSPET_110	16:59	18:00	1:01	LOAD CURTAILMENT
306	26-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_33KV	19:47	23:45	3:58	LINE CLEAR AVAILED
307	26-Apr-19	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	2:47	3:08	0:21	LINE FAULT
308	26-Apr-19	BAGALKOT	110	110/11KV,HV4	VADAGOAN_110	9:10	17:45	8:35	LINE CLEAR AVAILED
309	26-Apr-19	BAGALKOT	220	HUBLI220-NARENDRA2	HUBLI_220	11:52	15:54	4:02	LINE FAULT
310	26-Apr-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	11:37	16:17	4:40	LINE FAULT
311	26-Apr-19	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	11:52	12:19	0:27	LINE FAULT
312	26-Apr-19	BAGALKOT	220	220/110KV,HV1,LV1	SOUDATTI_220	17:04	17:50	0:46	LINE CLEAR AVAILED
313	26-Apr-19	BAGALKOT	220	220/110KV,HV2,LV2	SOUDATTI_220	17:55	18:47	0:52	LINE CLEAR AVAILED
314	26-Apr-19	BAGALKOT	110	SINDAGI-ALMELU	ALMELU_110	17:30	17:34	0:04	LOAD CURTAILMENT
315	26-Apr-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	16:58	17:10	0:12	LOAD CURTAILMENT
316	26-Apr-19	BAGALKOT	110	NARENDRA220-KUD DHARWAD1	KUD DHARWAD_110	19:02	19:33	0:31	LOAD CURTAILMENT
317	26-Apr-19	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	16:59	17:00	0:01	LOAD CURTAILMENT
318	26-Apr-19	BAGALKOT	110	110/11KV,HV2	RAIBAG_110	16:58	16:59	0:01	LOAD CURTAILMENT
319	26-Apr-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	17:38	18:25	0:47	LOAD CURTAILMENT
320	26-Apr-19	BAGALKOT	110	MAHALINGAPUR220-TERDAL	TERDAL_110	17:38	17:51	0:13	LOAD CURTAILMENT
321	26-Apr-19	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	19:12	19:22	0:10	LOAD CURTAILMENT
322	26-Apr-19	BAGALKOT	110	110/33KV,HV3	MUDEDEBIHAL_110,NALATAWAD_33KV	18:41	19:11	0:30	LOAD CURTAILMENT
323	26-Apr-19	BAGALKOT	110	110/33KV,HV3	MUDEDEBIHAL_110,NALATAWAD_33KV	17:45	18:30	0:45	LOAD CURTAILMENT
324	26-Apr-19	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	8:26	9:10	0:44	MAIN SUPPLY FAILURE
325	26-Apr-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	8:26	9:10	0:44	MAIN SUPPLY FAILURE
326	26-Apr-19	BENGALURU	66	HV1	RAJANAKUNTE	14:05	14:40	0:35	LINE CLEAR AVAILED
327	26-Apr-19	BENGALURU	66	HV1	TAVAREKERE	13:15	13:48	0:33	LINE CLEAR AVAILED
328	26-Apr-19	BENGALURU	66	HV2	RAJANAKUNTE	15:17	15:50	0:32	LINE CLEAR AVAILED
329	26-Apr-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	17:44	17:57	0:13	LOAD CURTAILMENT
330	26-Apr-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	17:46	17:57	0:10	LOAD CURTAILMENT
331	26-Apr-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HONNIGANAHALLI, HALAGUR	17:44	17:57	0:13	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
332	26-Apr-19	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	8:26	23:59	15:33	LINE FAULT
333	26-Apr-19	BENGALURU	220	HV1	HAL 220	8:26	9:09	0:43	TRANSFORMER FAULT
334	26-Apr-19	BENGALURU	66	HV2	KADUBISANAHALLI	9:30	9:45	0:15	TRANSFORMER FAULT
335	26-Apr-19	BENGALURU	220	LV1	HAL 220	8:26	9:09	0:43	TRANSFORMER FAULT
336	26-Apr-19	BENGALURU	66	VIDHURASHWATHA - BAGEPALLI	BAGEPALLI, GUNDLU KOTTUR	5:25	5:35	0:10	LINE FAULT
337	26-Apr-19	BENGALURU	66	HV2	BAGMANE WORLD TECH PARK	16:11	21:11	5:00	TRANSFORMER FAULT
338	26-Apr-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	20:40	21:41	1:01	LOAD CURTAILMENT
339	26-Apr-19	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	18:43	19:40	0:57	LOAD CURTAILMENT
340	26-Apr-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:41	19:39	0:58	LOAD CURTAILMENT
341	26-Apr-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:26	18:14	0:48	LOAD CURTAILMENT
342	26-Apr-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI	19:40	20:39	0:58	LOAD CURTAILMENT
343	26-Apr-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	17:26	18:14	0:48	LOAD CURTAILMENT
344	26-Apr-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	8:18	9:11	0:53	LINE CLEAR AVAILED
345	26-Apr-19	BENGALURU	66	DALASNUR - SRINIVASPURA	YELDUR	11:26	11:59	0:33	LINE CLEAR AVAILED
346	26-Apr-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	9:19	9:20	0:01	LOAD CHANGEOVER
347	26-Apr-19	BENGALURU	66	GOWRIBIDANUR - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	17:32	18:13	0:41	LOAD CURTAILMENT
348	26-Apr-19	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	12:24	15:01	2:37	LINE CLEAR AVAILED
349	26-Apr-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	17:27	18:05	0:37	LOAD CURTAILMENT
350	26-Apr-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	17:26	18:05	0:38	LOAD CURTAILMENT
351	26-Apr-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	18:50	19:10	0:19	LOAD CURTAILMENT
352	26-Apr-19	BENGALURU	66	KANASAWADI - YELAHANKA 220	KANASAWADI	11:10	11:15	0:05	LOAD CHANGEOVER
353	26-Apr-19	BENGALURU	66	KANASAWADI - DB PURA 220	KANASAWADI	14:10	14:15	0:05	LOAD CHANGEOVER
354	26-Apr-19	BENGALURU	66	NALLIMARADANAHALLI - CHIKKABALLAPURA I/A	NALLIMARADANAHALLI	13:10	13:40	0:30	LINE CLEAR AVAILED
355	26-Apr-19	BENGALURU	66	HV1	NALLIMARADANAHALLI	18:40	18:50	0:10	TRANSFORMER FAULT
356	26-Apr-19	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHBAD_220	12:51	13:29	0:38	LINE FAULT
357	26-Apr-19	GULBARGA	220	LINGAPUR-MUNIRABD_TR1	MUNIRABAD_220	13:26	13:49	0:23	LINE FAULT
358	26-Apr-19	GULBARGA	220	SHAHPUR-SHAHBAD	SHAHBAD_220	12:53	13:19	0:26	LINE FAULT
359	26-Apr-19	GULBARGA	220	SHAHPUR-LINGASUGUR	LINGASUGUR_220	9:05	23:59	14:54	LINE CLEAR AVAILED
360	26-Apr-19	GULBARGA	110	KAVITHAL-GAMESHA_IPP	KAVITAL_110	12:35	12:40	0:05	LINE CLEAR AVAILED
361	26-Apr-19	GULBARGA	110	KAVITHAL-GAMESHA_IPP	KAVITAL_110	14:10	14:15	0:05	LINE CLEAR AVAILED
362	26-Apr-19	GULBARGA	110	SINDHANOOR220-TURVIHAL	TURVIHAL_110	2:10	2:55	0:45	LINE FAULT
363	26-Apr-19	GULBARGA	110	HV2	CHINCHOLI_110	16:48	17:00	0:12	LOAD CURTAILMENT
364	26-Apr-19	GULBARGA	110	HV2	CHINCHOLI_110	17:37	17:50	0:13	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
365	26-Apr-19	GULBARGA	110	HV2	CHINCHOLI_110	18:44	18:53	0:09	LOAD CURTAILMENT
366	26-Apr-19	GULBARGA	110	HV2	HATTI_110	16:58	17:05	0:07	LOAD CURTAILMENT
367	26-Apr-19	GULBARGA	110	HV2	HANUMASAGAR_110	7:10	8:20	1:10	LINE CLEAR AVAILED
368	26-Apr-19	GULBARGA	110	HV3	HANUMASAGAR_110	18:39	18:47	0:08	LOAD CURTAILMENT
369	26-Apr-19	GULBARGA	110	HV1	HANUMASAGAR_110	18:40	18:45	0:05	LOAD CURTAILMENT
370	26-Apr-19	GULBARGA	110	HV2	KOLHAR_110	12:05	12:20	0:15	TRANSFORMER FAULT
371	26-Apr-19	GULBARGA	110	HV2	KOLHAR_110	16:55	17:05	0:10	TRANSFORMER FAULT
372	26-Apr-19	GULBARGA	110	HV2	KOLHAR_110	12:25	12:40	0:15	LINE CLEAR AVAILED
373	26-Apr-19	GULBARGA	110	HV2	KOLHAR_110	16:40	16:50	0:10	LINE CLEAR AVAILED
374	26-Apr-19	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110	20:27	21:43	1:16	LOAD CURTAILMENT
375	26-Apr-19	GULBARGA	110	MASKI-RNWSLR	MASKI_110	20:03	22:19	2:16	LINE CLEAR AVAILED
376	26-Apr-19	GULBARGA	110	RAICHUR-MATAMARI	MATMARI_110	17:45	18:30	0:45	LOAD CURTAILMENT
377	26-Apr-19	GULBARGA	110	HUMNABAD-BIDAR1	HALIKHED_110	18:46	19:15	0:29	LINE FAULT
378	26-Apr-19	GULBARGA	110	HV1	SIRWAR_110	16:45	16:50	0:05	LOAD CURTAILMENT
379	26-Apr-19	GULBARGA	110	HV1	SIRWAR_110	18:39	18:45	0:06	LOAD CURTAILMENT
380	26-Apr-19	GULBARGA	110	HV3	YELBURGA_110	18:40	18:52	0:12	LOAD CURTAILMENT
381	26-Apr-19	GULBARGA	110	HV4	YELBURGA_110	16:58	17:18	0:20	LOAD CURTAILMENT
382	26-Apr-19	GULBARGA	110	HV4	YELBURGA_110	16:45	16:55	0:10	LOAD CURTAILMENT
383	26-Apr-19	GULBARGA	110	HV4	YELBURGA_110	19:15	19:23	0:08	LOAD CURTAILMENT
384	26-Apr-19	GULBARGA	66	HV1	CJHALLI_66	16:40	16:50	0:10	TRANSFORMER FAULT
385	26-Apr-19	GULBARGA	66	HV1	CJHALLI_66	16:55	17:05	0:10	TRANSFORMER FAULT
386	26-Apr-19	GULBARGA	66	HV1	CJHALLI_66	19:10	20:15	1:05	TRANSFORMER FAULT
387	26-Apr-19	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	16:45	16:50	0:05	LINE CLEAR AVAILED
388	26-Apr-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:01	13:04	3:03	LINE CLEAR AVAILED
389	26-Apr-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:01	19:37	9:36	LINE CLEAR AVAILED
390	26-Apr-19	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	10:01	13:04	3:03	NFBC ISSUED
391	26-Apr-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	10:01	19:36	9:35	NFBC ISSUED
392	26-Apr-19	HASSAN	110	HV2	ANANDPURA_110	15:06	17:56	2:50	LINE CLEAR AVAILED
393	26-Apr-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:15	20:12	9:57	LINE CLEAR AVAILED
394	26-Apr-19	HASSAN	110	HV2	GERUMARA_110	16:59	17:20	0:21	LOAD CURTAILMENT
395	26-Apr-19	HASSAN	110	HV1	HALADY_110	16:43	17:00	0:17	LOAD CURTAILMENT
396	26-Apr-19	HASSAN	110	HV1	HALADY_110	18:40	18:55	0:15	LOAD CURTAILMENT
397	26-Apr-19	HASSAN	110	HV1	HALADY_110	19:14	19:30	0:16	LOAD CURTAILMENT
398	26-Apr-19	HASSAN	110	HV1	HOSANGADI_110	11:03	11:53	0:50	LINE CLEAR AVAILED
399	26-Apr-19	HASSAN	110	HV2	KEMAR_220	9:22	14:10	4:48	LINE CLEAR AVAILED
400	26-Apr-19	HASSAN	66	HV2	BASAVAGHATTA_66	16:57	17:08	0:11	LOAD CURTAILMENT
401	26-Apr-19	HASSAN	66	HV1	BYCHANAHALLY_66	8:25	8:35	0:10	TRANSFORMER FAULT
402	26-Apr-19	HASSAN	66	HV1	HANGRANAHALLY_66	16:59	17:07	0:08	LOAD CURTAILMENT
403	26-Apr-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	19:10	19:26	0:16	LOAD CURTAILMENT
404	26-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:21	18:41	11:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
405	26-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:21	18:41	11:20	LINE CLEAR AVAILED
406	26-Apr-19	HASSAN	66	HV2	SALAGAME_66	19:10	19:18	0:08	LOAD CURTAILMENT
407	26-Apr-19	HASSAN	66	HV1	SATHENAHALLY_66	19:15	19:20	0:05	LOAD CURTAILMENT
408	26-Apr-19	HASSAN	66	HV2	SINGAPURA_66	16:45	17:25	0:40	LOAD CURTAILMENT
409	26-Apr-19	HASSAN	66	HV2	SINGAPURA_66	18:38	19:01	0:23	LOAD CURTAILMENT
410	26-Apr-19	MYSORE	66	HV1	HANAGODU_66	19:10	19:22	0:12	LOAD CURTAILMENT
411	26-Apr-19	MYSORE	66	HV2	HDKOTE_66	16:58	17:20	0:21	LOAD CURTAILMENT
412	26-Apr-19	MYSORE	66	HV2	JAIPUR_66	16:58	17:14	0:15	LOAD CURTAILMENT
413	26-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 2	HURA_66, HULLAHALLI_66, DOORA_66,	6:07	6:14	0:06	LINE FAULT
414	26-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66,	10:24	14:15	3:51	LINE CLEAR AVAILED
415	26-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 2	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66,	10:24	14:15	3:51	LINE CLEAR AVAILED
416	26-Apr-19	MYSORE	66	HV2	KIRUGAVALU_66	19:10	19:50	0:40	LOAD CURTAILMENT
417	26-Apr-19	MYSORE	66	KR PETE 220-BOOKANKERE	BOOKANAKERE_66 GANJIGERE_66 BANANGADI_66 CHINAKURALI_66 PANDAVAPURA_66	7:40	9:01	1:21	LINE FAULT
418	26-Apr-19	MYSORE	66	HV2	KMDODDI_66	16:58	17:15	0:17	LOAD CURTAILMENT
419	26-Apr-19	MYSORE	66	HV1	KUSHALNAGARA_220	16:57	17:10	0:12	LOAD CURTAILMENT
420	26-Apr-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	11:35	11:58	0:23	LINE CLEAR AVAILED
421	26-Apr-19	MYSORE	66	HV1	PANDAVAPURA_66	16:55	17:17	0:22	LOAD CURTAILMENT
422	26-Apr-19	MYSORE	66	HV1	PANDAVAPURA_66	19:10	19:21	0:11	LOAD CURTAILMENT
423	26-Apr-19	MYSORE	66	HV1	SATHEGALA_66	16:45	0:00	7:15	LOAD CURTAILMENT
424	26-Apr-19	MYSORE	66	HV1	SATHEGALA_66	18:39	18:46	0:06	LOAD CURTAILMENT
425	26-Apr-19	MYSORE	66	HV2	SANTHESARAGUR_66	16:59	17:08	0:09	LOAD CURTAILMENT
426	26-Apr-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	16:45	16:55	0:10	LOAD CURTAILMENT
427	26-Apr-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	18:39	19:10	0:30	LOAD CURTAILMENT
428	26-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	8:40	18:01	9:21	LINE CLEAR AVAILED
429	26-Apr-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALLI_66 MEGALAPURA_66 THUMLA_66	5:27	0:00	18:32	LINE FAULT
430	26-Apr-19	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	22:51	23:04	0:12	LINE FAULT
431	26-Apr-19	TUMKUR	66	TR-1	DEVARAHALLI_66	7:04	7:10	0:06	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
432	27-Apr-19	BAGALKOT	110	AINAPUR -ATHANI SUGARS	AINAPUR_110	20:52	20:53	0:01	LINE FAULT
433	27-Apr-19	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	0:00	15:43	15:43	LINE CLEAR AVAILED
434	27-Apr-19	BAGALKOT	220	ALAMATTI 1-BAGALKOT	BAGALKOT_220	9:52	15:39	5:47	LINE CLEAR AVAILED
435	27-Apr-19	BAGALKOT	110	110/11KV,HV-1	BAGALKOT_110	16:44	17:26	0:42	LINE CLEAR AVAILED
436	27-Apr-19	BAGALKOT	110	110/11KV ,HV-1	BANAHATTI_110	6:46	8:26	1:40	LINE CLEAR AVAILED
437	27-Apr-19	BAGALKOT	110	110/11KV ,HV-2	BANAHATTI_110	8:26	9:13	0:47	LINE CLEAR AVAILED
438	27-Apr-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	18:21	19:19	0:58	HAND TRIPPED
439	27-Apr-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI1	BIDNAL_220	8:40	9:34	0:54	NFBC ISSUED
440	27-Apr-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI2	BIDNAL_220	9:01	13:20	4:19	NFBC ISSUED
441	27-Apr-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	10:49	15:04	4:15	NFBC ISSUED
442	27-Apr-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	15:41	22:01	6:20	LINE FAULT
443	27-Apr-19	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	16:41	19:55	3:14	LINE FAULT
444	27-Apr-19	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	15:33	19:55	4:22	LINE FAULT
445	27-Apr-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	14:20	20:06	5:46	LINE FAULT
446	27-Apr-19	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	17:42	18:16	0:34	HAND TRIPPED
447	27-Apr-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	14:20	15:41	1:21	LINE CLEAR AVAILED
448	27-Apr-19	BAGALKOT	110	BELGAUM-UCHAGOAN	UCHAGOAN_110	18:08	20:09	2:01	LINE CLEAR AVAILED
449	27-Apr-19	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	15:27	17:43	2:16	LINE CLEAR AVAILED
450	27-Apr-19	BAGALKOT	110	MAHALINGAPUR220-DAVALESHWAR	DAVALESHWAR_110	18:00	19:54	1:54	LINE CLEAR AVAILED
451	27-Apr-19	BAGALKOT	110	GADAG ROAD- GOPPANKOPPA	GOPPANKOPPA_110	17:50	17:56	0:06	LINE FAULT
452	27-Apr-19	BAGALKOT	110	GADAG ROAD-GOPPANKOPPA	GOPPANKOPPA_110	18:42	23:59	5:17	LINE CLEAR AVAILED
453	27-Apr-19	BAGALKOT	110	NARGUND(BIDNAL NAVALGUND)-GOPPANKOPPA	GOPPANAKOPPA_110	16:10	23:59	7:49	LINE FAULT
454	27-Apr-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	7:11	7:20	0:09	TRANSFORMER FAULT
455	27-Apr-19	BAGALKOT	220	HAVERI220-NARENDRA2	HAVERI_220	10:48	17:58	7:10	LINE CLEAR AVAILED
456	27-Apr-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	17:29	18:30	1:01	LINE FAULT
457	27-Apr-19	BAGALKOT	110	HUNAGUND-RAMPUR	RAMPUR_110	12:55	13:44	0:49	LINE FAULT
458	27-Apr-19	BAGALKOT	220	AMBEWADI-NAGJHARI1	AMBEWADI_220	9:38	18:44	9:06	LINE CLEAR AVAILED
459	27-Apr-19	BAGALKOT	110	AMBEWADI-SUPA1	AMBEWADI_220	16:58	18:08	1:10	LINE FAULT
460	27-Apr-19	BAGALKOT	110	AMBEWADI-SUPA2	AMBEWADI_220	16:59	18:08	1:09	LINE CLEAR AVAILED
461	27-Apr-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	21:00	21:39	0:39	TRANSFORMER FAULT
462	27-Apr-19	BAGALKOT	110	MAHALINGAPUR-JAMKHANDI	JAMKHANDI_110	16:10	19:26	3:16	MAIN SUPPLY FAILURE
463	27-Apr-19	BAGALKOT	110	VAJRAMATTI(PRABHULINGESHWAR)-JAMKHANDI	JAMKHANDI_110	19:26	23:59	4:33	LINE CLEAR AVAILED
464	27-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	0:07	0:12	0:05	TRANSFORMER FAULT
465	27-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	20:36	20:50	0:14	TRANSFORMER FAULT
466	27-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	21:21	21:25	0:04	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
467	27-Apr-19	BAGALKOT	110	VADAGAON-MACHE	MACHE_110	14:37	15:37	1:00	LINE FAULT
468	27-Apr-19	BAGALKOT	110	RANNABELGALI-UTTUR	UTTUR_110	17:44	19:37	1:53	LINE CLEAR AVAILED
469	27-Apr-19	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	13:48	14:05	0:17	LINE FAULT
470	27-Apr-19	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	17:22	18:01	0:39	LINE CLEAR AVAILED
471	27-Apr-19	BAGALKOT	110	SUARNASOUDA-MACHE	MACHE_110	15:16	15:29	0:13	MAIN SUPPLY FAILURE
472	27-Apr-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	15:41	22:01	6:20	LINE FAULT
473	27-Apr-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	16:21	19:25	3:04	LINE FAULT
474	27-Apr-19	BAGALKOT	220	220/110KV,HV1,HV2,LV1&LV2	SOUDATTI_220, SOUDATTI_110, MUNAVALLY_110,YARGATTI_110,NARGU ND_110, RAMDURG_110,MMCL_110	16:21	19:25	3:04	MAIN SUPPLY FAILURE
475	27-Apr-19	BAGALKOT	110	110/11KV, HV1	SOUDATTI_220	16:21	19:25	3:04	MAIN SUPPLY FAILURE
476	27-Apr-19	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	14:06	15:28	1:22	LINE FAULT
477	27-Apr-19	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	16:57	21:46	4:49	LINE FAULT
478	27-Apr-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	17:26	23:59	6:33	LINE FAULT
479	27-Apr-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	16:08	17:42	1:34	LINE FAULT
480	27-Apr-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:23	19:39	2:16	LINE FAULT
481	27-Apr-19	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	16:52	17:56	1:04	MAIN SUPPLY FAILURE
482	27-Apr-19	BAGALKOT	110	MKHUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	14:31	15:05	0:34	LINE FAULT
483	27-Apr-19	BAGALKOT	220	220/11KV,HV2,LV2	MAHALINGAPUR_220,BANAHATTI_110,R ABAKAVI_110,TERDAL_110,RANNABELAG ALI_110,DAVALESHWAR_110,GSM1&2_IP P	16:10	18:33	2:23	TRANSFORMER FAULT
484	27-Apr-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	16:36	19:11	2:35	LINE CLEAR AVAILED
485	27-Apr-19	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	18:04	18:22	0:18	TRANSFORMER FAULT
486	27-Apr-19	BAGALKOT	110	110/33KV, HV3	MACHE_110	14:31	17:25	2:54	TRANSFORMER FAULT
487	27-Apr-19	BAGALKOT	110	110/33KV, HV4	MACHE_110,ASHOK IRON PLANT_33,KHANAPUR_33	15:50	17:59	2:09	LINE CLEAR AVAILED
488	27-Apr-19	BAGALKOT	110	110/33KV, HV4	LAKAMAHALLI_110,ALNAVAR_33	16:17	16:36	0:19	TRANSFORMER FAULT
489	27-Apr-19	BAGALKOT	110	KUMTA-SIRSI 1	KUMTA_110	0:00	17:01	17:01	LINE CLEAR AVAILED
490	27-Apr-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	20:32	23:59	3:27	LINE CLEAR AVAILED
491	27-Apr-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	16:41	18:41	2:00	LINE FAULT
492	27-Apr-19	BAGALKOT	220	SHARAVATHI 1-SIRSI	SIRSI_220	18:47	23:59	5:12	LINE FAULT
493	27-Apr-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	19:03	23:59	4:56	LINE FAULT
494	27-Apr-19	BAGALKOT	110	KAVALWADA-KADANAKOPPA	KADANAKOPPA_110	13:48	14:27	0:39	LINE FAULT
495	27-Apr-19	BAGALKOT	110	KAVALWADA-KADANAKOPPA	KADANAKOPPA_110	20:52	23:59	3:07	LINE FAULT
496	27-Apr-19	BAGALKOT	110	SIRSI220-SIRSI1&2	SIRSI_110	13:48	14:00	0:12	LINE FAULT
497	27-Apr-19	BAGALKOT	110	SIRSI-KUMTA 1	KUMTA_110	18:32	23:59	5:27	LINE FAULT
498	27-Apr-19	BAGALKOT	220	NARENDRA-BELGAUM 1	NARENDRA_220	14:20	14:57	0:37	LINE FAULT
499	27-Apr-19	BENGALURU	66	HV1	NRS 220	12:08	13:55	1:47	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
500	27-Apr-19	BENGALURU	66	HV2	POTTERY ROAD	12:15	12:18	0:03	LINE CLEAR AVAILED
501	27-Apr-19	BENGALURU	66	HV2	TELECOM LAYOUT	9:48	9:56	0:08	TRANSFORMER FAULT
502	27-Apr-19	BENGALURU	66	HV2	VRISHBHAVATHI 220	9:15	9:18	0:03	LOAD CHANGEOVER
503	27-Apr-19	BENGALURU	66	HV1	VRISHBHAVATHI 220	10:26	10:30	0:04	LOAD CHANGEOVER
504	27-Apr-19	BENGALURU	66	LR BANDE - HEBBAL 220	LR BANDE	12:18	12:30	0:12	LOAD CHANGEOVER
505	27-Apr-19	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	14:44	14:55	0:11	LOAD CHANGEOVER
506	27-Apr-19	BENGALURU	66	HV2	TAVAREKERE	5:56	6:03	0:07	TRANSFORMER FAULT
507	27-Apr-19	BENGALURU	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	16:00	16:10	0:10	LOAD CHANGEOVER
508	27-Apr-19	BENGALURU	66	HV1	KHODAYS 220	11:19	11:22	0:03	MAIN SUPPLY FAILURE
509	27-Apr-19	BENGALURU	66	HV2	KHODAYS 220	11:19	11:23	0:03	MAIN SUPPLY FAILURE
510	27-Apr-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	11:18	11:24	0:06	MAIN SUPPLY FAILURE
511	27-Apr-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	11:18	11:23	0:05	MAIN SUPPLY FAILURE
512	27-Apr-19	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	11:18	11:23	0:05	MAIN SUPPLY FAILURE
513	27-Apr-19	BENGALURU	66	HV2	BAGMANE WORLD TECH PARK	13:45	19:20	5:35	LINE CLEAR AVAILED
514	27-Apr-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	1:17	1:41	0:23	LOAD CURTAILMENT
515	27-Apr-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	1:16	1:41	0:24	LOAD CURTAILMENT
516	27-Apr-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA	6:10	6:20	0:10	LINE FAULT
517	27-Apr-19	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	13:22	13:26	0:03	LINE CLEAR AVAILED
518	27-Apr-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASNUR, YELDUR	1:18	1:40	0:21	LOAD CURTAILMENT
519	27-Apr-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:00	13:20	3:20	LINE CLEAR AVAILED
520	27-Apr-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	5:36	6:15	0:38	LOAD CURTAILMENT
521	27-Apr-19	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	13:20	13:50	0:30	LINE CLEAR AVAILED
522	27-Apr-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	14:35	15:00	0:25	LINE CLEAR AVAILED
523	27-Apr-19	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	23:34	23:41	0:07	LOAD CHANGEOVER
524	27-Apr-19	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	11:22	11:28	0:06	LOAD CHANGEOVER
525	27-Apr-19	BENGALURU	66	YEDUMADU - HANUMANTHNAGARA	YEDUMADU	14:26	14:30	0:04	LOAD CHANGEOVER
526	27-Apr-19	BENGALURU	220	YELAHANKA 220 - KPCL 3	KPCL	18:46	19:47	1:00	LINE FAULT
527	27-Apr-19	BENGALURU	220	YELAHANKA 220 - SINGANAYAKANAHALLI 1	YELAHANKA 220	18:46	19:05	0:19	LINE FAULT
528	27-Apr-19	BENGALURU	220	YELAHANKA 220 - SINGANAYAKANAHALLI 2	YELAHANKA 220	18:46	23:59	5:12	LINE FAULT
529	27-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 1	YELAHANKA 220	18:46	19:07	0:21	MAIN SUPPLY FAILURE
530	27-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 2	YELAHANKA 220	18:46	19:07	0:21	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
531	27-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 3	ESCORTS (EHT), MANYATHA TECH PARK, ABBIGERE	18:46	19:07	0:21	MAIN SUPPLY FAILURE
532	27-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 4	ATTUR YELAHANKA, SAHAKARINAGAR, RAILWAYS (EHT)	18:46	19:07	0:21	MAIN SUPPLY FAILURE
533	27-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 5	KHB	18:46	19:07	0:21	MAIN SUPPLY FAILURE
534	27-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	18:46	19:07	0:20	MAIN SUPPLY FAILURE
535	27-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	18:46	19:07	0:20	MAIN SUPPLY FAILURE
536	27-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	18:46	19:07	0:20	MAIN SUPPLY FAILURE
537	27-Apr-19	BENGALURU	66	HV2	GUNDAMGERE	15:39	16:03	0:23	LINE CLEAR AVAIED
538	27-Apr-19	GULBARGA	220	LINGAPUR-MUNIRABD_TR1	MUNIRABAD_220	9:18	14:35	5:17	LINE CLEAR AVAIED
539	27-Apr-19	GULBARGA	220	LINGAPUR-GUDAHALLI1,2	LINGAPUR_220	13:19	20:14	6:55	LINE FAULT
540	27-Apr-19	GULBARGA	220	HV2	KUSTAGI_220	9:40	10:34	0:54	HAND TRIPPED
541	27-Apr-19	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	12:55	13:08	0:13	LINE FAULT
542	27-Apr-19	GULBARGA	220	HV1	KUSTAGI_220	12:55	13:18	0:23	TRANSFORMER FAULT
543	27-Apr-19	GULBARGA	220	HV2	KUSTAGI_220	12:55	13:12	0:17	LINE CLEAR AVAIED
544	27-Apr-19	GULBARGA	110	ALIPUR-PDHALLI	PD_HALLI_110	6:01	7:49	1:48	MAIN SUPPLY FAILURE
545	27-Apr-19	GULBARGA	110	HV1	YELBURGA_110	14:02	14:15	0:13	TRANSFORMER FAULT
546	27-Apr-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	19:02	19:13	0:11	LINE FAULT
547	27-Apr-19	GULBARGA	110	RAICHUR-SIDHANOOR1	SIRWAR_110,ALKOD_110	5:50	5:58	0:08	LINE FAULT
548	27-Apr-19	GULBARGA	66	HV1	CJHALLI_66	11:20	13:20	2:00	LINE CLEAR AVAIED
549	27-Apr-19	GULBARGA	66	HV2	TAMBRAHALLI_66	8:23	8:44	0:21	TRANSFORMER FAULT
550	27-Apr-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	19:11	19:11	LINE CLEAR AVAIED
551	27-Apr-19	HASSAN	220	HV2	MSEZ_220	9:57	14:18	4:21	LINE CLEAR AVAIED
552	27-Apr-19	HASSAN	220	SHRAVTYSIRISI 1	sharavathy_gen	18:50	23:59	5:09	LINE FAULT
553	27-Apr-19	HASSAN	220	HV1	SHIRALKOPPA_220	18:11	18:29	0:18	HAND TRIPPED
554	27-Apr-19	HASSAN	110	LV2	MSEZ_220	9:56	14:18	4:22	LINE CLEAR AVAIED
555	27-Apr-19	HASSAN	110	LV1	SHIRALKOPPA_220	18:10	18:30	0:20	HAND TRIPPED
556	27-Apr-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	17:59	18:34	0:35	LINE FAULT
557	27-Apr-19	HASSAN	110	HV2	ANANDPURA_110	14:42	15:26	0:44	HAND TRIPPED
558	27-Apr-19	HASSAN	110	HV2	ANAVATTI_100	17:38	18:33	0:55	TRANSFORMER FAULT
559	27-Apr-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_100	17:38	18:32	0:54	LINE FAULT
560	27-Apr-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	9:32	20:07	10:35	LINE CLEAR AVAIED
561	27-Apr-19	HASSAN	110	HV1	SHIVAPURA_110	11:56	12:23	0:27	LINE CLEAR AVAIED
562	27-Apr-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	7:57	7:58	0:01	HAND TRIPPED
563	27-Apr-19	HASSAN	66	HV1	ALDUR_66	8:07	9:07	1:00	LINE CLEAR AVAIED
564	27-Apr-19	HASSAN	66	HV1	BYACHANAHALLY_66	8:09	8:11	0:02	TRANSFORMER FAULT
565	27-Apr-19	HASSAN	66	HV1	CHIKMAGALUR_66	19:00	19:26	0:26	TRANSFORMER FAULT
566	27-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:34	18:48	11:14	LINE CLEAR AVAIED
567	27-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:34	18:48	11:14	LINE CLEAR AVAIED
568	27-Apr-19	HASSAN	66	HV2	MALLAPURA_66	15:33	16:21	0:48	LINE CLEAR AVAIED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
569	27-Apr-19	HASSAN	66	HV2	MALLAPURA_66	16:59	17:15	0:16	LINE CLEAR AVAILED
570	27-Apr-19	HASSAN	66	HV1	BASAVAGHATTA_66	12:17	12:58	0:41	MAIN SUPPLY FAILURE
571	27-Apr-19	HASSAN	66	HV2	BASAVAGHATTA_66	12:17	12:59	0:42	MAIN SUPPLY FAILURE
572	27-Apr-19	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	19:55	23:59	4:04	LINE FAULT
573	27-Apr-19	MYSORE	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66 HONNALLY_MYS_66	14:53	15:02	0:08	LOAD CURTAILMENT
574	27-Apr-19	MYSORE	66	CR NAGARA-PANYADAHUNDI	DEVANOORNGUDU_66 HEMMARGALA_66 KARYA_66 PANDYADAHUNDI_66 SUTTUR_66	14:49	15:07	0:18	LOAD CURTAILMENT
575	27-Apr-19	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	19:44	20:25	0:40	LINE FAULT
576	27-Apr-19	MYSORE	66	JAKKANAHALLI-NAGMANGALA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	19:39	19:51	0:12	LINE FAULT
577	27-Apr-19	MYSORE	66	HV1	JYOTHINAGARA_66	13:32	16:10	2:38	LINE CLEAR AVAILED
578	27-Apr-19	MYSORE	66	HV2	JYOTHINAGARA_66	9:33	13:26	3:53	LINE CLEAR AVAILED
579	27-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 2	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66,	9:44	9:52	0:08	LINE FAULT
580	27-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66,	9:44	9:52	0:08	LINE FAULT
581	27-Apr-19	MYSORE	66	MADHUVANAHALLI-DODDINDUVADI	DODDINADUVADI_66	15:40	15:46	0:06	LINE FAULT
582	27-Apr-19	MYSORE	66	SATHEGALA-KOLLEGALA	SATHEGALA_66	8:15	12:20	4:05	LINE CLEAR AVAILED
583	27-Apr-19	MYSORE	66	SATHEGALA-SFC	SATHEGALA_66	8:15	12:20	4:05	LINE CLEAR AVAILED
584	27-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	5:11	8:05	2:53	LINE CLEAR AVAILED
585	27-Apr-19	MYSORE	66	TUBINAKERE-NAGMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY _66 VADERALLI_66	15:32	15:38	0:05	LINE FAULT
586	27-Apr-19	MYSORE	66	TUBINAKERE-NAGMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY _66 VADERALLI_66	15:38	15:47	0:09	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
587	27-Apr-19	MYSORE	66	TUBINAKERE-NAGMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY _66 VADERALLI_66	15:47	18:33	2:45	LINE FAULT
588	27-Apr-19	MYSORE	66	TUBINAKERE-NAGMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 SHIVALLY_66	18:33	22:40	4:07	LINE FAULT
589	27-Apr-19	TUMKUR	220	ANTHRASANAHALLI 220kV- NELAMANGALA	ANTHRASANAHALLI_220	10:40	15:00	4:20	NFBC ISSUED
590	27-Apr-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_22	13:00	17:54	4:54	LINE CLEAR AVAILED
591	27-Apr-19	TUMKUR	220	TR-3	HIRIYUR_220	20:23	20:50	0:27	TRANSFORMER FAULT
592	27-Apr-19	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	14:41	18:34	3:52	LINE CLEAR AVAILED
593	27-Apr-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	14:34	14:44	0:09	LINE CLEAR AVAILED
594	27-Apr-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	16:24	16:42	0:17	HAND TRIPPED
595	27-Apr-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	1:13	1:32	0:18	LOAD CURTAILMENT
596	27-Apr-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	7:44	9:59	2:14	LINE FAULT
597	27-Apr-19	TUMKUR	66	TR-1	BELADARA_66	11:48	11:55	0:07	LINE CLEAR AVAILED
598	27-Apr-19	TUMKUR	66	TR-2	BELLAVI_66	11:28	11:36	0:08	LINE CLEAR AVAILED
599	27-Apr-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:46	12:56	0:09	LINE FAULT
600	27-Apr-19	TUMKUR	66	TR-2	HIREHALLY_66	10:24	10:32	0:08	TRANSFORMER FAULT
601	27-Apr-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	20:35	21:29	0:54	HAND TRIPPED
602	27-Apr-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	20:27	21:33	1:05	LINE CLEAR AVAILED
603	27-Apr-19	TUMKUR	66	HIRIYUR 220KV- RKP 2	RKP1_IPP_66	20:27	20:44	0:16	HAND TRIPPED
604	27-Apr-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	20:26	21:05	0:39	HAND TRIPPED
605	27-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	21:59	22:08	0:08	HAND TRIPPED
606	27-Apr-19	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	21:59	22:01	0:01	HAND TRIPPED
607	27-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	21:59	22:37	0:37	HAND TRIPPED
608	27-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	21:59	22:13	0:14	HAND TRIPPED
609	27-Apr-19	TUMKUR	66	MADHUGIRI 220kV- SIRA2	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	1:23	1:43	0:19	LOAD CURTAILMENT
610	27-Apr-19	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66	8:31	8:44	0:13	LINE FAULT
611	27-Apr-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	8:31	8:46	0:15	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
612	27-Apr-19	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	8:31	8:43	0:12	LINE FAULT
613	28-Apr-19	BAGALKOT	220	ATHANI -RAVI URJA 1&2	ATHANI_220	14:21	16:23	2:02	LINE CLEAR AVAILED
614	28-Apr-19	BAGALKOT	110	BAGALKOT- LOKAPUR 1	LOKAPUR_110	19:18	19:28	0:10	LINE FAULT
615	28-Apr-19	BAGALKOT	110	BAGALKOT- NEERBUDIHAL(KATARAKI)	NEERBUDIHAL_110	19:18	19:28	0:10	LINE FAULT
616	28-Apr-19	BAGALKOT	220	BAGEWADI -BIJAPUR 1&2	BAGEWADI_220	17:31	17:58	0:27	LINE FAULT
617	28-Apr-19	BAGALKOT	110	110/11KV,HV1	BILAGI_110	12:13	12:17	0:04	TRANSFORMER FAULT
618	28-Apr-19	BAGALKOT	220	220/110KV,HV1,LV1	BIJAPUR_220	10:57	13:09	2:12	LINE CLEAR AVAILED
619	28-Apr-19	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	12:21	13:44	1:23	LINE CLEAR AVAILED
620	28-Apr-19	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	14:30	16:08	1:38	LINE CLEAR AVAILED
621	28-Apr-19	BAGALKOT	110	CHIKKODI-ANKALI	ANKALI_110	17:06	18:21	1:15	LINE CLEAR AVAILED
622	28-Apr-19	BAGALKOT	110	GADAG ROAD-GOPPANKOPPA	GOPPANKOPPA_110	0:00	8:16	8:16	LINE CLEAR AVAILED
623	28-Apr-19	BAGALKOT	110	NARGUND(BIDNAL NAVALGUND)-GOPPANKOPPA	GOPPANAKOPPA_110	0:00	16:13	16:13	LINE CLEAR AVAILED
624	28-Apr-19	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPPANKOPPA	GOPPANAKOPPA_110	8:16	23:59	15:43	LINE CLEAR AVAILED
625	28-Apr-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	5:28	7:12	1:44	TRANSFORMER FAULT
626	28-Apr-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	8:08	8:20	0:12	TRANSFORMER FAULT
627	28-Apr-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	18:20	18:38	0:18	TRANSFORMER FAULT
628	28-Apr-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	17:18	18:21	1:03	LINE FAULT
629	28-Apr-19	BAGALKOT	220	AMBEWADI-NAGJHARI1	AMBEWADI_220	9:39	14:26	4:47	LINE CLEAR AVAILED
630	28-Apr-19	BAGALKOT	110	110/11KV,HV2A	JAMKHANDI_110	9:27	9:59	0:32	LINE CLEAR AVAILED
631	28-Apr-19	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YADAWAD_33, VANTGODI_33	20:55	21:10	0:15	TRANSFORMER FAULT
632	28-Apr-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	0:00	16:42	16:42	LINE CLEAR AVAILED
633	28-Apr-19	BAGALKOT	110	SATTI-RABAKAVI	SATTI_110	8:03	8:24	0:21	LINE CLEAR AVAILED
634	28-Apr-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	22:11	23:59	1:48	LINE CLEAR AVAILED
635	28-Apr-19	BAGALKOT	110	110/33KV, HV1	MK HUBLI_110,GANDIGAWADA_33	21:59	22:34	0:35	TRANSFORMER FAULT
636	28-Apr-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	20:25	21:28	1:03	LINE FAULT
637	28-Apr-19	BAGALKOT	110	KARWARA220-KUMTA	KUMTA_110	23:07	23:59	0:52	LINE FAULT
638	28-Apr-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	0:00	13:22	13:22	LINE CLEAR AVAILED
639	28-Apr-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	16:00	23:59	7:59	LINE CLEAR AVAILED
640	28-Apr-19	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	13:20	16:00	2:40	MAIN SUPPLY FAILURE
641	28-Apr-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	7:31	7:36	0:05	LINE FAULT
642	28-Apr-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	11:26	12:26	1:00	LINE CLEAR AVAILED
643	28-Apr-19	BAGALKOT	220	SHARAVATHI 1-SIRSI	SIRSI_220	0:00	19:22	19:22	LINE CLEAR AVAILED
644	28-Apr-19	BAGALKOT	220	SIRSI -HUBLI 1	SIRSI_220	10:17	10:56	0:39	LINE CLEAR AVAILED
645	28-Apr-19	BAGALKOT	220	SIRSI -HUBLI 2	SIRSI_220	10:57	11:23	0:26	LINE CLEAR AVAILED
646	28-Apr-19	BAGALKOT	220	SIRSI -HUBLI 2	SIRSI_220	19:39	23:59	4:20	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
647	28-Apr-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	0:00	18:32	18:32	LINE CLEAR AVAILED
648	28-Apr-19	BAGALKOT	110	KAVALWADA-KADANAKOPPA	KADANAKOPPA_110	0:00	11:21	11:21	LINE CLEAR AVAILED
649	28-Apr-19	BAGALKOT	110	KAVALWADA-KADANAKOPPA	KADANAKOPPA_110	11:28	11:41	0:13	HAND TRIPPED
650	28-Apr-19	BAGALKOT	110	SIRSI-KUMTA 1	KUMTA_110	0:00	7:11	7:11	LINE CLEAR AVAILED
651	28-Apr-19	BAGALKOT	110	SIRSI-KUMTA 2	KUMTA_110	23:23	23:59	0:36	LINE CLEAR AVAILED
652	28-Apr-19	BAGALKOT	110	KUMTA-SIRSI 1	KUMTA_110	12:24	18:51	6:27	LINE CLEAR AVAILED
653	28-Apr-19	BENGALURU	66	SRS PEENYA 220 - BIEC	BIEC	22:47	22:58	0:11	LINE CLEAR AVAILED
654	28-Apr-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	22:12	22:18	0:05	LOAD CHANGEOVER
655	28-Apr-19	BENGALURU	66	HV1	ELECTRONIC CITY P2 S1	9:58	10:11	0:12	MAIN SUPPLY FAILURE
656	28-Apr-19	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGNATHPURA 220	ELECTRONIC CITY P2 S1	9:58	10:05	0:06	LOAD CHANGEOVER
657	28-Apr-19	BENGALURU	66	ELECTRONIC CITY P2 S1 - ELECTRONIC CITY	ELECTRONIC CITY P2 S1	11:25	11:40	0:14	LOAD CHANGEOVER
658	28-Apr-19	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	17:00	17:27	0:27	LINE FAULT
659	28-Apr-19	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	22:49	23:59	1:09	LINE FAULT
660	28-Apr-19	BENGALURU	66	HV2	HOODY 220	7:59	8:55	0:55	LINE CLEAR AVAILED
661	28-Apr-19	BENGALURU	66	HOODY 220 - SHANTHINIKETHAN	SHANTHINIKETHAN	6:13	7:39	1:26	LINE CLEAR AVAILED
662	28-Apr-19	BENGALURU	66	ITI - HOODY 1	ITI, BANASWADI	8:38	9:09	0:31	LINE CLEAR AVAILED
663	28-Apr-19	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	5:26	5:32	0:06	LOAD CHANGEOVER
664	28-Apr-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	5:15	5:20	0:05	LOAD CHANGEOVER
665	28-Apr-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	22:09	22:17	0:08	LOAD CHANGEOVER
666	28-Apr-19	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	5:15	5:22	0:07	LOAD CHANGEOVER
667	28-Apr-19	BENGALURU	66	HV2	NRS 220	5:24	5:29	0:05	LOAD CHANGEOVER
668	28-Apr-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	21:45	21:52	0:07	LOAD CHANGEOVER
669	28-Apr-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	5:37	5:43	0:05	LOAD CHANGEOVER
670	28-Apr-19	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	9:05	9:08	0:03	LOAD CHANGEOVER
671	28-Apr-19	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	22:39	22:40	0:01	LOAD CHANGEOVER
672	28-Apr-19	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI	21:46	21:51	0:04	LOAD CHANGEOVER
673	28-Apr-19	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI	21:51	22:30	0:38	LINE FAULT
674	28-Apr-19	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	12:58	13:06	0:08	LOAD CHANGEOVER
675	28-Apr-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:58	13:06	0:08	LOAD CHANGEOVER
676	28-Apr-19	BENGALURU	66	HV1	HOSKOTE 220	8:47	8:55	0:07	TRANSFORMER FAULT
677	28-Apr-19	BENGALURU	66	HV1	HOSKOTE 220	10:36	10:45	0:08	TRANSFORMER FAULT
678	28-Apr-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:28	13:37	0:08	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
679	28-Apr-19	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA	11:00	13:55	2:54	LINE CLEAR AVAILED
680	28-Apr-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	14:20	15:00	0:40	LINE CLEAR AVAILED
681	28-Apr-19	BENGALURU	220	HV1	SARJAPURA 220	20:27	20:51	0:23	TRANSFORMER FAULT
682	28-Apr-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	20:27	21:36	1:08	LINE FAULT
683	28-Apr-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	20:27	20:52	0:24	MAIN SUPPLY FAILURE
684	28-Apr-19	BENGALURU	66	HV1	SARJAPURA 220	20:27	20:52	0:24	MAIN SUPPLY FAILURE
685	28-Apr-19	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	5:37	5:46	0:09	LOAD CHANGEOVER
686	28-Apr-19	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	9:22	9:30	0:08	LOAD CHANGEOVER
687	28-Apr-19	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	22:21	22:28	0:07	LOAD CHANGEOVER
688	28-Apr-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	5:37	5:45	0:08	LOAD CHANGEOVER
689	28-Apr-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	5:38	5:40	0:02	LOAD CHANGEOVER
690	28-Apr-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	9:22	9:30	0:08	LOAD CHANGEOVER
691	28-Apr-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	22:21	22:25	0:04	LOAD CHANGEOVER
692	28-Apr-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	22:22	22:25	0:03	LOAD CHANGEOVER
693	28-Apr-19	BENGALURU	220	HV1	JIGANI 220	11:59	13:14	1:15	LINE CLEAR AVAILED
694	28-Apr-19	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	11:59	13:14	1:15	MAIN SUPPLY FAILURE
695	28-Apr-19	GULBARGA	220	BMMIS-ITTAGI	NEELGUNDA_220,ITTAGI_220	7:20	23:59	16:39	LINE CLEAR AVAILED
696	28-Apr-19	GULBARGA	220	LINGAPUR-MUNIRABD_TR1	MUNIRABAD_220	11:42	13:30	1:48	LINE CLEAR AVAILED
697	28-Apr-19	GULBARGA	110	HV1	CHITAGUPPA_110	1:20	1:45	0:25	TRANSFORMER FAULT
698	28-Apr-19	GULBARGA	110	HV2	CHITAGUPPA_110	17:45	17:55	0:10	TRANSFORMER FAULT
699	28-Apr-19	GULBARGA	110	KUDITINI-BALLARY	KUDITINI_110,TORANGALLU	21:25	23:55	2:30	LINE FAULT
700	28-Apr-19	GULBARGA	110	MARGUTTI-CLEANSOLAR	MARGUTTI_110	4:45	5:00	0:15	LINE FAULT
701	28-Apr-19	GULBARGA	110	YELBURGA-PARAMPUJYA_IPP	YELBURGA_110	22:10	22:20	0:10	LINE FAULT
702	28-Apr-19	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	9:25	17:01	7:36	LINE CLEAR AVAILED
703	28-Apr-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:38	12:48	2:10	LINE CLEAR AVAILED
704	28-Apr-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:39	12:47	2:08	LINE CLEAR AVAILED
705	28-Apr-19	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	10:38	12:49	2:11	NFBC ISSUED
706	28-Apr-19	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	10:38	12:49	2:11	NFBC ISSUED
707	28-Apr-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	0:00	19:25	19:25	LINE FAULT
708	28-Apr-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:52	13:30	1:38	NFBC ISSUED
709	28-Apr-19	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	7:01	7:20	0:19	LINE FAULT
710	28-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	8:46	13:32	4:46	LINE CLEAR AVAILED
711	28-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	8:46	13:32	4:46	LINE CLEAR AVAILED
712	28-Apr-19	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPLU_66	10:43	12:42	1:59	LINE FAULT
713	28-Apr-19	MYSORE	66	CR NAGARA-KABHALLY	HARVEY_66	6:03	6:12	0:09	LINE FAULT
714	28-Apr-19	MYSORE	66	HV2	HANAGODU_66	14:04	23:59	9:54	LINE CLEAR AVAILED
715	28-Apr-19	MYSORE	66	HUNSUR-ELAVALA	GAVADAGERE_66	19:03	19:11	0:08	LINE FAULT
716	28-Apr-19	MYSORE	66	HV1	JAKKANAHALLY_66	6:36	6:43	0:07	TRANSFORMER FAULT
717	28-Apr-19	MYSORE	66	KADAKOLA-NANJANAGUDU 1	NANJANGUDU_66	10:11	16:35	6:24	LINE CLEAR AVAILED
718	28-Apr-19	MYSORE	66	HV1	MYSORESOUTH_66	7:02	7:25	0:23	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
719	28-Apr-19	MYSORE	66	HV2	MYSORESOUTH_66	7:02	7:25	0:22	HAND TRIPPED
720	28-Apr-19	MYSORE	66	NANJANAGUDU-THANDYA	NANJANGUDU_66	10:05	16:44	6:38	NFBC ISSUED
721	28-Apr-19	TUMKUR	220	ANTHRASANAHALLI 220KV- NELAMANGALA	ANTHRASANAHALLI_220	18:51	18:53	0:02	NFBC ISSUED
722	28-Apr-19	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	9:52	18:51	8:58	LINE CLEAR AVAILED
723	28-Apr-19	TUMKUR	220	TR-3	HIRIYUR_220	5:59	6:13	0:13	TRANSFORMER FAULT
724	28-Apr-19	TUMKUR	66	BHAKTHARA HALLI -ANCHEPALYA	BHAKTHARAHALLI_66	11:56	12:06	0:10	LINE CLEAR AVAILED
725	28-Apr-19	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	11:56	12:06	0:10	LINE CLEAR AVAILED
726	28-Apr-19	TUMKUR	66	TR-1	CHANNAGIRI_66	18:44	18:54	0:09	TRANSFORMER FAULT
727	28-Apr-19	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	9:26	9:41	0:15	LINE FAULT
728	28-Apr-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:25	14:36	0:11	LINE FAULT
729	28-Apr-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	15:03	15:13	0:10	LINE CLEAR AVAILED
730	28-Apr-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:03	6:20	0:16	HAND TRIPPED
731	28-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	18:27	18:53	0:26	HAND TRIPPED
732	28-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	11:26	11:31	0:05	HAND TRIPPED
733	28-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-2	INFOSYS1_EHT_66	6:34	7:11	0:36	HAND TRIPPED
734	28-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-2	INFOSYS1_EHT_66	11:21	11:24	0:02	HAND TRIPPED
735	28-Apr-19	TUMKUR	66	TR-1	LINGADAHALLY_66	20:03	20:19	0:16	LINE CLEAR AVAILED
736	28-Apr-19	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	1:06	1:26	0:19	LOAD CURTAILMENT
737	28-Apr-19	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	12:47	12:49	0:02	LINE FAULT
738	28-Apr-19	TUMKUR	66	TR-1	RAMPURA_66	19:12	19:28	0:15	TRANSFORMER FAULT
739	28-Apr-19	TUMKUR	66	TR-1	TUMKUR_66	23:08	23:28	0:20	TRANSFORMER FAULT
740	29-Apr-19	BAGALKOT	110	ATHANI-SATTI	SATTI_110	13:37	19:29	5:52	LINE FAULT
741	29-Apr-19	BAGALKOT	110	BAGALKOT-NEERBUDIHAL(KATARAKI)	NEERBUDIHAL_110	20:40	20:48	0:08	LINE FAULT
742	29-Apr-19	BAGALKOT	110	BAGALKOT-NEERBUDIHAL(KATARAKI)	NEERBUDIHAL_110	20:54	23:59	3:05	LINE FAULT
743	29-Apr-19	BAGALKOT	110	110/11KV,HV-2	BHUTANAL_110	6:36	6:55	0:19	HAND TRIPPED
744	29-Apr-19	BAGALKOT	110	GADAG-DSMBSL 1(SAMBAPUR ROAD)	SAMBAPUR ROAD_110	10:50	12:16	1:26	LINE CLEAR AVAILED
745	29-Apr-19	BAGALKOT	220	GADAG-DHONI 2(LINGAPUR 2)	GADAG_220	17:07	18:28	1:21	LINE CLEAR AVAILED
746	29-Apr-19	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	16:26	17:55	1:29	LINE CLEAR AVAILED
747	29-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	7:04	7:09	0:05	TRANSFORMER FAULT
748	29-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	7:31	7:34	0:03	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
749	29-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	7:43	7:47	0:04	HAND TRIPPED
750	29-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	8:14	8:23	0:09	TRANSFORMER FAULT
751	29-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	8:57	12:57	4:00	LINE CLEAR AVAILED
752	29-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	17:25	17:27	0:02	TRANSFORMER FAULT
753	29-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	18:16	18:21	0:05	TRANSFORMER FAULT
754	29-Apr-19	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	17:40	17:55	0:15	TRANSFORMER FAULT
755	29-Apr-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGHATAGI_110	9:03	17:25	8:22	LINE CLEAR AVAILED
756	29-Apr-19	BAGALKOT	220	SIRISI-HUBLI2	SIRSI_220	0:00	15:31	15:31	LINE CLEAR AVAILED
757	29-Apr-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	16:42	17:02	0:20	LINE CLEAR AVAILED
758	29-Apr-19	BAGALKOT	110	SOUDATTI220-SOUDATTI2	SOUDATTI_110	13:41	16:08	2:27	LINE CLEAR AVAILED
759	29-Apr-19	BAGALKOT	110	SOUDATTI220-RAMDURGA	RAMDURGA_110	14:17	14:52	0:35	LINE CLEAR AVAILED
760	29-Apr-19	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	3:40	4:20	0:40	TRANSFORMER FAULT
761	29-Apr-19	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	13:59	17:42	3:43	LINE CLEAR AVAILED
762	29-Apr-19	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	18:03	19:01	0:58	LINE CLEAR AVAILED
763	29-Apr-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	0:00	10:28	10:28	LINE CLEAR AVAILED
764	29-Apr-19	BAGALKOT	110	110/11KV, HV2	MAMDAPUR(G)_110	12:58	13:25	0:27	LINE CLEAR AVAILED
765	29-Apr-19	BAGALKOT	220	220/110KV,HV1&LV1	KUDACHI_220	15:06	16:57	1:51	LINE CLEAR AVAILED
766	29-Apr-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA_110	12:32	15:05	2:33	LINE CLEAR AVAILED
767	29-Apr-19	BAGALKOT	110	KARWAR220-KUMATA	KUMATA_110	0:00	15:04	15:04	LINE CLEAR AVAILED
768	29-Apr-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	15:35	16:13	0:38	LINE CLEAR AVAILED
769	29-Apr-19	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	18:01	18:22	0:21	TRANSFORMER FAULT
770	29-Apr-19	BAGALKOT	220	HAVERI-BIDNAL	BIDNAL_220	14:15	16:19	2:04	LINE CLEAR AVAILED
771	29-Apr-19	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	9:42	12:13	2:31	LINE CLEAR AVAILED
772	29-Apr-19	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	4:12	4:18	0:06	LOAD CHANGEOVER
773	29-Apr-19	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	4:15	4:20	0:05	LOAD CHANGEOVER
774	29-Apr-19	BENGALURU	66	SRS PEENYA 220 - BIEC	BIEC	3:57	4:04	0:07	LOAD CHANGEOVER
775	29-Apr-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	4:07	4:16	0:08	LOAD CHANGEOVER
776	29-Apr-19	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	3:48	3:51	0:02	LOAD CHANGEOVER
777	29-Apr-19	BENGALURU	66	HV2	TAVAREKERE	13:20	13:28	0:07	LINE CLEAR AVAILED
778	29-Apr-19	BENGALURU	66	HV2	NRS 220	4:21	4:26	0:04	LOAD CHANGEOVER
779	29-Apr-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	4:17	4:26	0:08	LOAD CHANGEOVER
780	29-Apr-19	BENGALURU	66	GOKULA - RMV	GOKULA, BEL (EHT)	4:08	4:17	0:09	LOAD CHANGEOVER
781	29-Apr-19	BENGALURU	66	ADUGODI - HSR 1 & 2	ADUGODI, BOSCH (EHT)	15:09	15:17	0:07	LOAD CHANGEOVER
782	29-Apr-19	BENGALURU	66	HV1	BANASHANKARI	14:32	14:43	0:11	LINE CLEAR AVAILED
783	29-Apr-19	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT)	23:14	23:59	0:44	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
784	29-Apr-19	BENGALURU	66	HV2	KHB	15:05	16:10	1:05	LINE CLEAR AVAILED
785	29-Apr-19	BENGALURU	66	HV1	KHB	11:55	13:16	1:21	LINE CLEAR AVAILED
786	29-Apr-19	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANAKUNTE	10:50	11:00	0:10	LOAD CHANGE OVER
787	29-Apr-19	BENGALURU	66	HV2	CHIKKABALLAPURA URBAN	13:56	14:08	0:12	TRANSFORMER FAULT
788	29-Apr-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	18:13	18:18	0:04	LINE FAULT
789	29-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	10:48	10:52	0:04	LOAD CHANGE OVER
790	29-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT), RAJANAKUNTE	13:55	14:04	0:09	LOAD CHANGE OVER
791	29-Apr-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	4:05	4:14	0:09	LOAD CHANGE OVER
792	29-Apr-19	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	4:05	4:14	0:09	LOAD CHANGE OVER
793	29-Apr-19	BENGALURU	66	WELCAST STEEL - ABBIGERE	WELCAST STEEL	4:25	4:28	0:03	LOAD CHANGE OVER
794	29-Apr-19	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	19:13	23:59	4:46	LINE FAULT
795	29-Apr-19	GULBARGA	220	BMMIS-ITTAGI	NEELGUNDA_220,ITTAGI_220	0:00	13:30	13:30	LINE CLEAR AVAILED
796	29-Apr-19	GULBARGA	220	SEDAM-SHREECEMENT_IPP	SHREECEMENT_IPP	15:33	16:24	0:51	LINE FAULT
797	29-Apr-19	GULBARGA	220	BTPSG-LINGAPUR	LINGAPUR_220	21:10	23:59	2:49	LINE FAULT
798	29-Apr-19	GULBARGA	220	SIDHANOOR220-LINGAPUR	LINGAPUR_220	17:12	23:59	6:47	LINE FAULT
799	29-Apr-19	GULBARGA	220	HV1	ITTAGI_220	20:12	20:43	0:31	TRANSFORMER FAULT
800	29-Apr-19	GULBARGA	220	HV2	ITTAGI_220	20:12	20:28	0:16	TRANSFORMER FAULT
801	29-Apr-19	GULBARGA	220	HV2	ITTAGI_220	20:55	21:00	0:05	TRANSFORMER FAULT
802	29-Apr-19	GULBARGA	220	HV2	ITTAGI_220	22:40	22:45	0:05	TRANSFORMER FAULT
803	29-Apr-19	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	8:16	14:00	5:44	MAIN SUPPLY FAILURE
804	29-Apr-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_GLB_110	8:30	12:22	3:52	LINE CLEAR AVAILED
805	29-Apr-19	GULBARGA	110	HV1	KAVITAL_110	6:14	6:25	0:11	TRANSFORMER FAULT
806	29-Apr-19	GULBARGA	110	HUMNABAD220-BIDAR1	HALIKHED_110	15:18	15:29	0:11	LINE FAULT
807	29-Apr-19	GULBARGA	110	HUMNABAD220-MANEKHALLI	MANEKHALLI_110	15:18	15:27	0:09	LINE FAULT
808	29-Apr-19	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR_110, KORWARTEMPLE_110, RAJSHREECEMENTS_IPP	15:33	23:59	8:26	LINE FAULT
809	29-Apr-19	GULBARGA	110	CHITAGUPPA-ACMSLR	CHITGUPPA_110	18:35	18:50	0:15	LINE FAULT
810	29-Apr-19	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	17:35	17:55	0:20	LINE FAULT
811	29-Apr-19	GULBARGA	110	MASKI-SIDHANOOR110	SIDHANOOR_110	19:22	19:35	0:13	LINE FAULT
812	29-Apr-19	GULBARGA	110	SIDHANOOR220-MUNIRABAD1	KARTAGI_110, GANGAVATHI_110, SRERAMANAGAR_110, VENKATAGIRI_110	19:50	20:50	1:00	LINE FAULT
813	29-Apr-19	GULBARGA	110	YELBURGA-TALTSLR	YELBURGA_110	23:10	23:37	0:27	HAND TRIPPED
814	29-Apr-19	GULBARGA	110	YELBURGA-TALTSLR	YELBURGA_110	23:10	23:37	0:27	HAND TRIPPED
815	29-Apr-19	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	8:16	13:35	5:19	MAIN SUPPLY FAILURE
816	29-Apr-19	GULBARGA	66	HV1	HAMPASAGAR_66	19:50	21:25	1:35	TRANSFORMER FAULT
817	29-Apr-19	GULBARGA	66	HANASI-KADALIGI	KUDLIGI_66	23:22	23:26	0:04	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
818	29-Apr-19	GULBARGA	66	ITTAGGI-BENNAHALLI	KOTTUR_66,UJJANI_66,BENNAHALLI_66	19:53	20:50	0:57	LINE FAULT
819	29-Apr-19	GULBARGA	66	ITTAGGI-BENNAHALLI	KOTTUR_66,UJJANI_66,BENNAHALLI_66	20:55	21:52	0:57	LINE FAULT
820	29-Apr-19	GULBARGA	66	ITTAGGI-HBHALLI	UPANAYAKANAHALLI_66,HAGARIBOMMA NAHALLI_66	19:42	20:55	1:13	LINE FAULT
821	29-Apr-19	GULBARGA	66	ITTAGGI-HIREHADAGALLI1,2	HIREHADAGALI_66GIRIYAPURA_66,SOVE NAHALLI_66,MAGALA_66,TUNGABHADRA _IPP	20:12	21:15	1:03	LINE FAULT
822	29-Apr-19	GULBARGA	66	ITTAGGI-RENEWSOLAR2	ITTAGI_220	19:37	21:40	2:03	LINE FAULT
823	29-Apr-19	HASSAN	220	GOPALAPR-HNPUR21	GOPALPURA_220	19:00	19:30	0:30	LINE FAULT
824	29-Apr-19	HASSAN	220	GOPALAPR-HNPUR21	GOPALPURA_220	19:40	23:59	4:19	LINE FAULT
825	29-Apr-19	HASSAN	220	HV1	HOLENARASIPURA_220	19:25	22:20	2:55	TRANSFORMER FAULT
826	29-Apr-19	HASSAN	220	HV2	HOLENARASIPURA_220	19:10	23:59	4:49	TRANSFORMER FAULT
827	29-Apr-19	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	16:16	18:08	1:52	LINE FAULT
828	29-Apr-19	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	16:17	19:05	2:48	LINE FAULT
829	29-Apr-19	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	16:17	17:24	1:07	LINE FAULT
830	29-Apr-19	HASSAN	220	MRSSHM-SHARAVATHY3	MRSSMG_220	16:16	18:02	1:46	LINE FAULT
831	29-Apr-19	HASSAN	220	MRSSHM-VARAHI1	MRSSMG_220	16:17	19:05	2:48	LINE FAULT
832	29-Apr-19	HASSAN	220	MRSSGM-VARAHI2	MRSSMG_220	16:17	17:23	1:06	LINE FAULT
833	29-Apr-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	10:50	13:37	2:47	LINE CLEAR AVAILED
834	29-Apr-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	19:10	23:59	4:49	LINE FAULT
835	29-Apr-19	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	19:30	23:59	4:29	LINE CLEAR AVAILED
836	29-Apr-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	19:10	23:59	4:49	LINE FAULT
837	29-Apr-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	19:10	23:59	4:49	LINE FAULT
838	29-Apr-19	HASSAN	66	MRSSHM-HOLUR	MRSSMG_220	9:15	9:36	0:21	LINE FAULT
839	29-Apr-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	17:26	17:28	0:02	LINE FAULT
840	29-Apr-19	HASSAN	66	HV1	BYACHANAHALLI_66	8:50	9:00	0:10	TRANSFORMER FAULT
841	29-Apr-19	HASSAN	66	HV1	BYACHANAHALLI_66	19:07	21:47	2:40	TRANSFORMER FAULT
842	29-Apr-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	19:35	22:28	2:53	NFBC ISSUED
843	29-Apr-19	HASSAN	66	HV1	DODDAKADANUR_66	19:35	22:28	2:53	NFBC ISSUED
844	29-Apr-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	19:35	22:28	2:53	NFBC ISSUED
845	29-Apr-19	HASSAN	66	HV1	HANGARANAHALLY_66	19:35	22:28	2:53	MAIN SUPPLY FAILURE
846	29-Apr-19	HASSAN	66	HV1	HARIHARAPURA_66	19:35	22:15	2:40	MAIN SUPPLY FAILURE
847	29-Apr-19	HASSAN	66	MOSALEH-BIOMASS	MOSALEHOSAHALLI_66	19:35	22:15	2:40	MAIN SUPPLY FAILURE
848	29-Apr-19	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	19:35	22:15	2:40	MAIN SUPPLY FAILURE
849	29-Apr-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	19:35	22:15	2:40	MAIN SUPPLY FAILURE
850	29-Apr-19	HASSAN	66	HV1	RAMNATHPURA_66	19:50	20:20	0:30	TRANSFORMER FAULT
851	29-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	7:50	18:05	10:15	LINE CLEAR AVAILED
852	29-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	7:50	18:05	10:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
853	29-Apr-19	MYSORE	66	HV2	JYOTHINAGARA_66	16:08	23:59	7:50	LINE CLEAR AVAILED
854	29-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 2	DOORA_66 HULLAHALLI_66 HURA_66	6:03	7:17	1:14	LINE CLEAR AVAILED
855	29-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66, B MATKERE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66, SANTHESARAGUR_66,	6:03	17:08	11:04	LINE CLEAR AVAILED
856	29-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 2	DOORA_66 HULLAHALLI_66 HURA_66	19:00	19:05	0:05	LINE FAULT
857	29-Apr-19	MYSORE	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	19:48	20:20	0:32	LINE FAULT
858	29-Apr-19	MYSORE	66	HV1	MADIKERI_66	14:09	15:48	1:38	LINE CLEAR AVAILED
859	29-Apr-19	MYSORE	66	HV1	SANTHESARAGUR_66	17:34	17:37	0:03	TRANSFORMER FAULT
860	29-Apr-19	MYSORE	66	HV2	SANTHESARAGUR_66	17:01	17:13	0:11	TRANSFORMER FAULT
861	29-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66	17:07	18:03	0:55	LINE CLEAR AVAILED
862	29-Apr-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	13:51	17:29	3:37	LINE CLEAR AVAILED
863	29-Apr-19	TUMKUR	110	TR-1	KGTEMPLE_110	14:06	18:31	4:24	LINE CLEAR AVAILED
864	29-Apr-19	TUMKUR	110	K G TEMPLE-NITTUR	KGTEMPLE_110	14:06	18:23	4:16	LINE CLEAR AVAILED
865	29-Apr-19	TUMKUR	110	K G TEMPLE-UNGRDLI	UNGRA_110	14:06	18:23	4:16	LINE CLEAR AVAILED
866	29-Apr-19	TUMKUR	110	NITTUR 220kv- KG TEMPLE	KGTEMPLE_110, UNGRA_110	14:18	19:45	5:26	LINE CLEAR AVAILED
867	29-Apr-19	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	17:14	19:33	2:19	MAIN SUPPLY FAILURE
868	29-Apr-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	21:07	21:31	0:23	LINE FAULT
869	29-Apr-19	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:58	16:11	0:12	LINE FAULT
870	29-Apr-19	TUMKUR	66	TR-2	HALURAMESHWARA_66	15:52	18:45	2:53	LINE CLEAR AVAILED
871	29-Apr-19	TUMKUR	66	TR-1	HARIHAR_66	20:21	20:26	0:05	TRANSFORMER FAULT
872	29-Apr-19	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	19:13	20:25	1:11	LINE FAULT
873	29-Apr-19	TUMKUR	66	TR-1	SAVALANGA_66	15:58	19:20	3:21	MAIN SUPPLY FAILURE
874	29-Apr-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	16:01	16:20	0:18	TRANSFORMER FAULT