

**400/220/110/66 kV TRANSMISSION OUTAGES FROM 21.09.2021 TO 27.09.2021**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	21-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVOIDED
2	21-Sep-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
3	21-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
4	21-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
5	21-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
6	21-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
7	21-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA 110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
8	21-Sep-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL 220	18:43 (01.08.2021)	16:11 (21.09.2021)	1221:28HRS	LINE CHARGED
9	21-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	14:58 (11.09.2021)			LINE OPEN,LINE CLEAR AVOIDED
10	21-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET 66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
11	21-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET 66	10:23 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
12	21-Sep-2021	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG 220	13:08 (14.09.2021)	11:32 (21.09.2021)	214:24HRS	LINE CHARGED
13	21-Sep-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI 220	12:55 (19.09.2021)			LINE OPEN, LINE FAULT
14	21-Sep-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI 220	15:56 (20.09.2021)			LINE OPEN,LINE CLEAR AVOIDED
15	21-Sep-2021	BAGALKOT	220	BELGAUM- CHIKKODI1	BELGAUM 220	10:22 (20.09.2021)			LINE OPEN,LINE CLEAR AVOIDED
16	21-Sep-2021	BAGALKOT	220	BIDNAL- HARTI2	BIDNAL 220	18:01 (20.09.2021)			LINE OPEN, LINE FAULT
17	21-Sep-2021	BAGALKOT	66	66/11KV,HV2	HARIHAR HOSPET_66	11:49	14:50	3:01	LINE CLEAR AVOIDED
18	21-Sep-2021	BAGALKOT	110	ALABAL-SPRS	ALABAL_110	10:30	18:28	7:58	LINE CLEAR AVOIDED
19	21-Sep-2021	BAGALKOT	110	BIDNAL-NAVALGUND	BIDNAL 220	18:14 (21.09.2021)			LINE OPEN, LINE FAULT
20	21-Sep-2021	BAGALKOT	110	RANEBENNUR-BYADAGI	BYADAGI_110	11:57	13:46	1:49	LINE CLEAR AVOIDED
21	21-Sep-2021	BAGALKOT	110	BYADAGI-SUZLON	BYADAGI_110	17:09	17:29	0:20	LINE FAULT
22	21-Sep-2021	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	12:32	18:54	6:22	TRANSFORMER FAULT
23	21-Sep-2021	BAGALKOT	110	110/11KV,HV1	GULEDGUDD_110	10:00	16:23	6:23	LINE CLEAR AVOIDED
24	21-Sep-2021	BAGALKOT	110	110/11KV,HV2	ITANAL_110	6:45	6:53	0:08	TRANSFORMER FAULT
25	21-Sep-2021	BAGALKOT	110	JAMBAGI-HALAKI(MUDHOL)	HALAKI_110	10:36	15:29	4:53	LINE CLEAR AVOIDED
26	21-Sep-2021	BAGALKOT	110	KULGERI CROSS-MRN BREAKER	KULAGERI CROSS_110	18:13	18:48	0:35	HAND TRIPPED
27	21-Sep-2021	BAGALKOT	110	MK HUBLI-KITTUR ( NARENDRA)	MK HUBLI_110	8:54	20:30	11:36	LINE CLEAR AVOIDED
28	21-Sep-2021	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	5:05	5:16	0:11	LINE FAULT
29	21-Sep-2021	BAGALKOT	220	SOUDATTI- MAHLNGAPUR	SOUDATTI_220	10:37	12:32	1:55	LINE CLEAR AVOIDED
30	21-Sep-2021	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	MAHALINGAPUR_220	10:38	12:33	1:55	LINE CLEAR AVOIDED
31	21-Sep-2021	BAGALKOT	220	220/110KV, HV4&LV4	GADAG_220	11:16	17:41	6:25	LINE CLEAR AVOIDED
32	21-Sep-2021	BAGALKOT	220	220/110KV, HV2&LV2	CHIKKODI_220	14:45	19:10	4:25	LINE CLEAR AVOIDED
33	21-Sep-2021	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	18:02	18:13	0:11	TRANSFORMER FAULT
34	21-Sep-2021	BAGALKOT	110	VAJRAMATTI220- BILAGI	SIRAGUPPI_110,BILAGI_110,GIRISA GAR_110, BISNAL_110& TOLAMATTI 110	18:18	18:32	0:14	LINE FAULT
35	21-Sep-2021	BAGALKOT	110	MAMADAPUR(B)- TODALBAGI	TODALBAGI_110	8:41	11:00	2:19	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
36	21-Sep-2021	BAGALKOT	110	TAKKALAKI- WARADA SOLAR	TAKKALAKI_110	3:54	4:48	0:54	HAND TRIPPED
37	21-Sep-2021	BAGALKOT	110	TAKKALAKI- KN SOLAR	TAKKALAKI_110	3:54	4:48	0:54	HAND TRIPPED
38	21-Sep-2021	BAGALKOT	110	110/11KV, HV3	SHIGGOAN_110	16:15	16:29	0:14	TRANSFORMER FAULT
39	21-Sep-2021	BAGALKOT	110	SATTI- RABAKAVI	SATTI_110	10:15	18:21	8:06	LINE CLEAR AVAILED
40	21-Sep-2021	BAGALKOT	110	SADALAGA- VPPL	SADALAGA_110	0:15	0:38	0:23	LINE FAULT
41	21-Sep-2021	BAGALKOT	110	BIDNAL220- NAVALGUND	NAVALGUND_110	18:10 (21.09.2021)			LINE OPEN, LINE FAULT
42	21-Sep-2021	BAGALKOT	110	NARENDRA220- MRUTHYUNJAY NAGAR2 (UAS)	UAS_110	10:45	17:31	6:46	LINE CLEAR AVAILED
43	21-Sep-2021	BAGALKOT	110	MRUTHYUNJAY NAGAR- NARENDRA2(UAS)	UAS_110	9:00	17:32	8:32	LINE CLEAR AVAILED
44	21-Sep-2021	BAGALKOT	110	110/11KV, HV2	MALGHAN(S)_110	13:46	13:55	0:09	LINE CLEAR AVAILED
45	21-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
46	21-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
47	21-Sep-2021	BAGALKOT	110	JAMBAGI- HALKI	HALKI_110	10:40	15:30	4:50	NFBC ISSUED
48	21-Sep-2021	BAGALKOT	110	RANEBENNUR220- BYADAGI	BYADAGI_110	12:15	13:46	1:31	LINE CLEAR AVAILED
49	21-Sep-2021	BAGALKOT	220	GADAG- HARTI2	GADAG_220	11:33	17:44	6:11	LINE CLEAR AVAILED
50	21-Sep-2021	BAGALKOT	110	110/33KV, HV2	KONNUR_110	18:15	18:50	0:35	MAIN SUPPLY FAILURE
51	21-Sep-2021	BAGALKOT	110	110/11KV, HV1	KONNUR_110	18:15	18:50	0:35	MAIN SUPPLY FAILURE
52	21-Sep-2021	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	18:15	18:50	0:35	MAIN SUPPLY FAILURE
53	21-Sep-2021	BAGALKOT	220	INDI220- SAVALSANGA	INDI_220	3:49	4:43	0:54	MAIN SUPPLY FAILURE
54	21-Sep-2021	BAGALKOT	220	INDI- BIJAPUR1	INDI_220	3:49	4:43	0:54	MAIN SUPPLY FAILURE
55	21-Sep-2021	BAGALKOT	220	INDI- BIJAPUR2	INDI_220	3:49	4:43	0:54	MAIN SUPPLY FAILURE
56	21-Sep-2021	BAGALKOT	110	INDI220- DEVARHIPPARAGI	DEVAR HIPPARAGI_110, HIREMASALI_110, ATHARGA_110	3:49	4:43	0:54	MAIN SUPPLY FAILURE
57	21-Sep-2021	BAGALKOT	110	INDI220- INDI	INDI_110	3:49	4:43	0:54	MAIN SUPPLY FAILURE
58	21-Sep-2021	BAGALKOT	110	INDI220- LACHYAN	LACHYAN_110, HIREBENNUR_110, LACHYAN_110	3:49	4:43	0:54	MAIN SUPPLY FAILURE
59	21-Sep-2021	BAGALKOT	110	INDI220- ZALKI1&2	ZALAKI_110, INCHAGERI_110, CHADCHAN_110	3:49	4:43	0:54	MAIN SUPPLY FAILURE
60	21-Sep-2021	BAGALKOT	110	110/11KV, HV1	INDI_220	3:49	4:43	0:54	MAIN SUPPLY FAILURE
61	21-Sep-2021	BAGALKOT	110	110/11KV, HV2	INDI_220	3:49	4:43	0:54	MAIN SUPPLY FAILURE
62	21-Sep-2021	BENGALURU	66	ABBIGERE - YELAHANKA 220	ABBIGERE	17:40	17:49	0:09	LOAD CHANGE OVER
63	21-Sep-2021	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	19:21	19:26	0:05	LOAD CHANGE OVER
64	21-Sep-2021	BENGALURU	66	ADUGODI - JAKKASANDRA	ADUGODI	13:13	13:37	0:24	MAIN SUPPLY FAILURE
65	21-Sep-2021	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	10:00	17:25	7:25	LINE CLEAR AVAILED
66	21-Sep-2021	BENGALURU	66	HV1	CHATRA	16:50	17:04	0:14	LINE CLEAR AVAILED
67	21-Sep-2021	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - NAGANATHPURA 220	ELECTRONIC CITY PH-2 SEC-2	9:07	10:07	1:00	LINE CLEAR AVAILED
68	21-Sep-2021	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE, AMAR JYOTHI	4:39	5:03	0:24	LINE FAULT
69	21-Sep-2021	BENGALURU	66	HV1	LEELA VENTURE	4:39	4:54	0:15	TRANSFORMER FAULT
70	21-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, JAKKASANDRA	13:11	13:21	0:10	LINE FAULT
71	21-Sep-2021	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	13:11	13:23	0:12	LINE FAULT
72	21-Sep-2021	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	ADUGODI	13:11	13:37	0:26	LINE FAULT
73	21-Sep-2021	BENGALURU	66	HV2	KODIGEHALLI	18:23	19:35	1:12	LINE CLEAR AVAILED
74	21-Sep-2021	BENGALURU	66	HV2	NRS 220	8:39	8:45	0:06	LINE CLEAR AVAILED
75	21-Sep-2021	BENGALURU	66	HV2	NRS 220	22:11	22:17	0:06	LINE CLEAR AVAILED
76	21-Sep-2021	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	17:34	17:46	0:12	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
77	21-Sep-2021	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	21:55	22:00	0:05	LOAD CHANGE OVER
78	21-Sep-2021	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYDRAHALLI, KODIGEHALI, TAVAREKERE	18:23	18:40	0:17	LINE FAULT
79	21-Sep-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	8:15	8:23	0:08	LINE FAULT
80	21-Sep-2021	BENGALURU	66	HV2	SUBRAMANYAPURA 66	9:32	9:45	0:13	TRANSFORMER FAULT
81	21-Sep-2021	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	20:46	23:22	2:36	LINE FAULT
82	21-Sep-2021	BENGALURU	66	HV2	VRISHABHAVATHI	16:17	16:20	0:03	LINE CLEAR AVAILED
83	21-Sep-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	10:00	16:40	6:40	LINE CLEAR AVAILED
84	21-Sep-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	10:00	10:06	0:06	LINE CLEAR AVAILED
85	21-Sep-2021	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT, BELL CERAMICS (EHT)	16:47	16:50	0:03	LOAD CHANGE OVER
86	21-Sep-2021	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	10:00	16:41	6:41	LINE CLEAR AVAILED
87	21-Sep-2021	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	10:00	16:47	6:47	LINE CLEAR AVAILED
88	21-Sep-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:00	16:42	6:42	LINE CLEAR AVAILED
89	21-Sep-2021	BENGALURU	66	HOSKOTE 220 - BOODIGERE	NO STATION AFFECTED	10:00	17:02	7:02	LINE CLEAR AVAILED
90	21-Sep-2021	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR	NO STATION AFFECTED	10:00	17:19	7:19	LINE CLEAR AVAILED
91	21-Sep-2021	BENGALURU	220	HV1	HOSKOTE 220	10:00	16:27	6:27	LINE CLEAR AVAILED
92	21-Sep-2021	BENGALURU	220	HV2	HOSKOTE 220	10:00	16:32	6:32	LINE CLEAR AVAILED
93	21-Sep-2021	BENGALURU	66	HV1	HOSKOTE 220	10:00	16:30	6:30	LINE CLEAR AVAILED
94	21-Sep-2021	BENGALURU	220	HOSKOTE 220 - KIADB HARDWARE PARK 220 - 1	HOSKOTE 220	10:00	16:27	6:27	LINE CLEAR AVAILED
95	21-Sep-2021	BENGALURU	220	HOSKOTE 220 - KIADB HARDWARE PARK 220 - 2	HOSKOTE 220	10:00	16:32	6:32	LINE CLEAR AVAILED
96	21-Sep-2021	BENGALURU	66	BEGUR 220 - BIAL 1	AIRPORT	10:00	16:32	6:32	LINE CLEAR AVAILED
97	21-Sep-2021	BENGALURU	66	BEGUR 220 - BIAL 2	NO STATION AFFECTED	10:00	16:34	6:34	LINE CLEAR AVAILED
98	21-Sep-2021	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	10:00	17:18	7:18	LINE CLEAR AVAILED
99	21-Sep-2021	BENGALURU	66	VIDYANAGAR - BIAL BEGUR 220	VIDYANAGAR, HENNUR CROSS	8:57	9:12	0:15	LINE FAULT
100	21-Sep-2021	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR, HENNUR CROSS	10:00	16:49	6:49	LINE CLEAR AVAILED
101	21-Sep-2021	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	10:00	17:36	7:36	LINE CLEAR AVAILED
102	21-Sep-2021	BENGALURU	220	HV1	BEGUR 220	10:00	16:30	6:30	LINE CLEAR AVAILED
103	21-Sep-2021	BENGALURU	220	HV2	BEGUR 220	10:00	16:30	6:30	LINE CLEAR AVAILED
104	21-Sep-2021	BENGALURU	66	HV1	BEGUR 220	10:00	18:20	8:20	LINE CLEAR AVAILED
105	21-Sep-2021	BENGALURU	66	HV2	BEGUR 220	10:00	18:20	8:20	LINE CLEAR AVAILED
106	21-Sep-2021	BENGALURU	220	BIAL BEGUR 220 - KIADB HARDWARE PARK 220 - 1	BIAL BEGUR 220	10:00	16:28	6:28	LINE CLEAR AVAILED
107	21-Sep-2021	BENGALURU	220	BIAL BEGUR 220 - KIADB HARDWARE PARK 220 - 2	BIAL BEGUR 220	10:00	16:30	6:30	LINE CLEAR AVAILED
108	21-Sep-2021	BENGALURU	66	KHW PARK 220 - SHELL(EHT)	SHELL(EHT)	10:33	17:45	7:12	LINE CLEAR AVAILED
109	21-Sep-2021	BENGALURU	66	KHW PARK 220 - BPH(EHT)	BPH(EHT)	10:34	17:24	6:50	LINE CLEAR AVAILED
110	21-Sep-2021	BENGALURU	220	HV1	KIADB HARWARE PARK 220	10:36	16:34	5:58	LINE CLEAR AVAILED
111	21-Sep-2021	BENGALURU	220	HV2	KIADB HARWARE PARK 220	10:36	17:09	6:33	LINE CLEAR AVAILED
112	21-Sep-2021	BENGALURU	66	HV1	KIADB HARWARE PARK 220	10:35	16:35	6:00	LINE CLEAR AVAILED
113	21-Sep-2021	BENGALURU	220	KIADB HARWARE PARK 220 - DEVENAHALLI 400 1	KIADB HARWARE PARK 220	10:30	16:25	5:55	LINE CLEAR AVAILED
114	21-Sep-2021	BENGALURU	220	KIADB HARWARE PARK 220 - DEVENAHALLI 400 2	KIADB HARWARE PARK 220	10:30	16:25	5:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
115	21-Sep-2021	BENGALURU	66	HV2	TEMAGONDALU	16:10	16:22	0:12	TRANSFORMER FAULT
116	21-Sep-2021	BENGALURU	66	HV1	MULBAGLU	15:22	15:25	0:02	LINE CLEAR AVAILED
117	21-Sep-2021	BENGALURU	66	HV1	MAGADI 66	1:46	1:50	0:03	TRANSFORMER FAULT
118	21-Sep-2021	BENGALURU	66	HV1	KYALANUR	21:06	21:37	0:30	TRANSFORMER FAULT
119	21-Sep-2021	BENGALURU	66	HV1	KACHMARANAHALLI	12:30	13:30	0:59	LINE CLEAR AVAILED
120	21-Sep-2021	BENGALURU	66	HV2	KACHMARANAHALLI	14:51	14:53	0:01	LINE CLEAR AVAILED
121	21-Sep-2021	BENGALURU	66	HV2	KACHMARANAHALLI	4:10	4:15	0:05	TRANSFORMER FAULT
122	21-Sep-2021	BENGALURU	66	HV2	CHANDAPURA	13:05	13:19	0:14	LINE CLEAR AVAILED
123	21-Sep-2021	BENGALURU	66	HV1	CHANDAPURA	13:18	13:20	0:01	LINE CLEAR AVAILED
124	21-Sep-2021	BENGALURU	66	HV1	AGALAKOTE	18:45	19:42	0:57	TRANSFORMER FAULT
125	21-Sep-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	7:18	7:28	0:10	LINE FAULT
126	21-Sep-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	7:28	7:32	0:03	LINE FAULT
127	21-Sep-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:10	18:29	0:19	LINE FAULT
128	21-Sep-2021	BENGALURU	66	WELCASTE - ABBIGERE	WELCASTE	17:36	17:43	0:07	LOAD CHANGE OVER
129	21-Sep-2021	BENGALURU	66	WELCASTE - SRS PEENYA 220	WELCASTE	22:18	22:22	0:04	LOAD CHANGE OVER
130	21-Sep-2021	BENGALURU	66	ANEKAL - SURYANAGAR	ANEKAL	17:09	17:26	0:17	LINE CLEAR AVAILED
131	21-Sep-2021	BENGALURU	66	ANEKAL - SAMANDUR	SAMANDUR	17:09	17:35	0:26	LINE CLEAR AVAILED
132	21-Sep-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	17:14	17:16	0:02	LOAD CHANGE OVER
133	21-Sep-2021	BENGALURU	220	HV2	HSR LAYOUT 220	15:25(19/09/2021)	17:02(21/09/2021)	41:37HRS	TRANSFORMER CHARGED
134	21-Sep-2021	GULBARGA	400	RTPS-BTPS	RTPS_400	12:09(21.09.2021)			LINE OPEN, LINE FAULT
135	21-Sep-2021	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	1:30	1:35	0:05	LINE FAULT
136	21-Sep-2021	GULBARGA	220	HV2	SHAHABAD_220	11:39	11:48	0:09	LINE CLEAR AVAILED
137	21-Sep-2021	GULBARGA	220	HV1	SHAHABAD_220	11:52	11:58	0:06	LINE CLEAR AVAILED
138	21-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
139	21-Sep-2021	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	21:52	22:19	0:27	LINE FAULT
140	21-Sep-2021	GULBARGA	220	SHAHABAD-KAPNOOR	KAPNOOR_220	12:39	13:04	0:25	LINE CLEAR AVAILED
141	21-Sep-2021	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	21:52	21:55	0:03	LINE FAULT
142	21-Sep-2021	GULBARGA	220	SINDHANOOR-LINGAPUR	LINGAPUR_220	11:15	15:20	4:05	NFBC ISSUED
143	21-Sep-2021	GULBARGA	220	KAPNOOR-SHAHABAD	KAPNOOR_220	12:37	13:07	0:30	LINE CLEAR AVAILED
144	21-Sep-2021	GULBARGA	220	LINGAPUR-LINGASUGUR	SINDHANOOR_220	11:10	15:18	4:08	LINE CLEAR AVAILED
145	21-Sep-2021	GULBARGA	220	RTPS-LINGASUGUR1	RTPS_220	0:16	15:42	15:26	LINE FAULT
146	21-Sep-2021	GULBARGA	220	RTPS-LINGASUGUR2	RTPS_220	3:24	11:50	8:26	LINE FAULT
147	21-Sep-2021	GULBARGA	220	RTPS-LINGASUGUR1	RTPS_220	15:42(21.09.2021)			LINE OPEN,LINE CLEAR AVAILED
148	21-Sep-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRGUPPA_110, TEKKALKOTE_110,NSL SUGAR_IPP	6:02	6:12	0:10	LINE FAULT
149	21-Sep-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDINAGAR_110	5:05	5:20	0:15	LINE FAULT
150	21-Sep-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRGUPPA_110, TEKKALKOTE_110,NSL SUGAR_IPP	21:28	21:38	0:10	LINE FAULT
151	21-Sep-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	20:44	20:54	0:10	LINE FAULT
152	21-Sep-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRGUPPA_110, TEKKALKOTE_110,NSL SUGAR_IPP	22:45	22:55	0:10	LINE FAULT
153	21-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
154	21-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
155	21-Sep-2021	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	2:43	2:50	0:07	LINE FAULT
156	21-Sep-2021	GULBARGA	110	HV2	HANUMANAL_110	6:45	6:50	0:05	TRANSFORMER FAULT
157	21-Sep-2021	GULBARGA	110	HV4	DEODURGA_110	8:00	8:10	0:10	TRANSFORMER FAULT
158	21-Sep-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	5:15	5:20	0:05	LINE FAULT
159	21-Sep-2021	GULBARGA	110	RAICHUR-APMC1,2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	9:06	9:17	0:11	LINE FAULT
160	21-Sep-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	11:50	12:00	0:10	LINE FAULT
161	21-Sep-2021	GULBARGA	110	RAICHUR-APMC1,2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	22:58	23:05	0:07	LINE FAULT
162	21-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GABBUR_110,DEODURGA_110,GOOGLE_110	23:50	23:58	0:08	LINE FAULT
163	21-Sep-2021	GULBARGA	110	JANAWADA-KOLHAR	JANAWADA_110	8:55	10:25	1:30	LINE CLEAR AVAILED
164	21-Sep-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	4:23	4:41	0:18	LINE FAULT
165	21-Sep-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	8:55	10:25	1:30	LINE CLEAR AVAILED
166	21-Sep-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	3:09	3:27	0:18	LINE FAULT
167	21-Sep-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:16	23:22	0:06	LINE FAULT
168	21-Sep-2021	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110,NIRNA_110	7:34	7:40	0:06	LINE FAULT
169	21-Sep-2021	GULBARGA	110	HUMNABAD-MANEKHELLI	MANEKHELLI_110	7:36	7:44	0:08	LINE FAULT
170	21-Sep-2021	GULBARGA	110	HUMNABAD-MANEKHELLI	MANEKHELLI_110	18:06	18:14	0:08	LINE FAULT
171	21-Sep-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	7:35	7:42	0:07	LINE FAULT
172	21-Sep-2021	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	5:43	5:45	0:02	MAIN SUPPLY FAILURE
173	21-Sep-2021	GULBARGA	110	HV2	HATTI_110	8:43	8:48	0:05	TRANSFORMER FAULT
174	21-Sep-2021	GULBARGA	110	HV2	HATTI_110	9:57	10:01	0:04	TRANSFORMER FAULT
175	21-Sep-2021	GULBARGA	110	HV2	HATTI_110	17:40	17:55	0:15	TRANSFORMER FAULT
176	21-Sep-2021	GULBARGA	110	HV2	HATTI_110	19:33	19:36	0:03	TRANSFORMER FAULT
177	21-Sep-2021	GULBARGA	66	MUNIRABAD-MHD LINE	VENKATAPUR_66,RRSTRRLS,UPHALLI_66	11:12(20.09.2021)	12:50(21.09.2021)	25:38HRS	LINE CHARGED
178	21-Sep-2021	GULBARGA	66	MUNIRABAD-MSD LINE(IDLE LINE)	HANASI_66	9:45	13:25	3:40	LINE CLEAR AVAILED
179	21-Sep-2021	GULBARGA	66	HV1	MUNIRABAD_220	10:20	12:48	2:28	LINE CLEAR AVAILED
180	21-Sep-2021	GULBARGA	66	NEELAGUNDA-HARAPANAHALLI	HARAPANAHALLI_66	18:35	18:40	0:05	LINE FAULT
181	21-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN,LINE CLEAR AVAILED
182	21-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
183	21-Sep-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
184	21-Sep-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN, LINE FAULT
185	21-Sep-2021	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	9:18(19.09.2021)	8:46(21.09.2021)	23:27 hrs	LINE CHARGED
186	21-Sep-2021	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	9:18(19.09.2021)	8:46(21.09.2021)	23:27 hrs	LINE CHARGED
187	21-Sep-2021	HASSAN	220	MRSSHM-KADUR	MRSMG_220	11:53	11:57	0:04	HAND TRIPPED
188	21-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	11:13	12:30	1:17	LINE CLEAR AVAILED
189	21-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	11:13	12:31	1:18	LINE CLEAR AVAILED
190	21-Sep-2021	HASSAN	220	HV2	PUTTUR_220	9:36	14:54	5:18	LINE CLEAR AVAILED
191	21-Sep-2021	HASSAN	110	LV2	PUTTUR_220	9:36	14:55	5:19	LINE CLEAR AVAILED
192	21-Sep-2021	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	11:13	12:30	1:17	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
193	21-Sep-2021	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	11:13	12:31	1:18	NFBC ISSUED
194	21-Sep-2021	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	8:51	10:22	1:31	LINE CLEAR AVAIED
195	21-Sep-2021	HASSAN	110	HV1	MADHUVANA_110	21:29	22:25	0:56	LINE CLEAR AVAIED
196	21-Sep-2021	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	10:05	14:10	4:05	LINE CLEAR AVAIED
197	21-Sep-2021	HASSAN	110	HV1	MANIPAL_110	10:12	10:42	0:30	LINE CLEAR AVAIED
198	21-Sep-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	8:53	19:26	10:33	LINE CLEAR AVAIED
199	21-Sep-2021	HASSAN	110	HV1	NITTUR_110	13:54	18:34	4:40	LINE CLEAR AVAIED
200	21-Sep-2021	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	9:46	15:45	5:59	LINE CLEAR AVAIED
201	21-Sep-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:49	10:52	0:03	HAND TRIPPED
202	21-Sep-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	13:58	14:02	0:04	HAND TRIPPED
203	21-Sep-2021	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:49	14:02	3:13	NFBC ISSUED
204	21-Sep-2021	HASSAN	110	HV1	SORABA_110	22:47	23:54	1:07	LINE CLEAR AVAIED
205	21-Sep-2021	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	10:48	14:00	3:12	LINE CLEAR AVAIED
206	21-Sep-2021	HASSAN	66	HV1	BANDISHETTIHALLY_66	21:05	21:12	0:07	MAIN SUPPLY FAILURE
207	21-Sep-2021	HASSAN	66	HV	CHIKABOMMENAHALLY_66	14:55	20:32	5:37	TRANSFORMER FAULT
208	21-Sep-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	11:11	15:14	4:03	LINE CLEAR AVAIED
209	21-Sep-2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	21:01	21:05	0:04	LINE FAULT
210	21-Sep-2021	HASSAN	66	HV2	HOLALUR_66	16:30	16:40	0:10	LINE CLEAR AVAIED
211	21-Sep-2021	HASSAN	66	SAKALE-HASSAN1	SAKLESHPUA_66	12:04	17:13	5:09	LINE FAULT
212	21-Sep-2021	HASSAN	66	HV1	SAKLESHPUA_66	12:04	12:35	0:31	TRANSFORMER FAULT
213	21-Sep-2021	MYSURU	220	HV2	KADAKOLA_220	10:19	15:15	22:44	TRANSFORMER FAULT
214	21-Sep-2021	MYSURU	66	KADAKOLA-SARGUR 1	JAYAPURA_66 HAMPAPURA_66	11:17	11:25	0:08	LINE FAULT
215	21-Sep-2021	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HULLALLI_66 HURA_66	11:17	11:25	0:08	LINE FAULT
216	21-Sep-2021	MYSURU	66	KUSHALANAGARA-MYSORE 1	MIRLE_66	12:05	13:06	1:01	LINE CLEAR AVAIED
217	21-Sep-2021	MYSURU	66	ARAKERE-TUBINAKERE	ARAKERE_66	11:22	11:45	0:22	LINE CLEAR AVAIED
218	21-Sep-2021	MYSURU	66	DKMAIDANA-VAJAMANGALA	NO STATIONS EFFECTED	9:24	16:15	6:51	HAND TRIPPED
219	21-Sep-2021	MYSURU	66	JYOTHINAGARA-DKMAIDANA	NO STATIONS EFFECTED	9:35	15:38	6:02	LINE CLEAR AVAIED
220	21-Sep-2021	MYSURU	66	HV1	KIRUGAVALU_66	11:08	12:28	1:20	LINE CLEAR AVAIED
221	21-Sep-2021	MYSURU	66	HV2	KIRUGAVALU_66	12:31	13:47	1:15	LINE CLEAR AVAIED
222	21-Sep-2021	MYSURU	66	HV1	KALAMANDIR_66	11:19	13:40	2:20	LINE CLEAR AVAIED
223	21-Sep-2021	MYSURU	66	HV2	KALAMANDIR_66	13:41	15:24	1:42	LINE CLEAR AVAIED
224	21-Sep-2021	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	16:27	16:31	0:04	HAND TRIPPED
225	21-Sep-2021	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	9:44	16:00	6:16	HAND TRIPPED
226	21-Sep-2021	MYSURU	66	HV1	NAGAMANGALA_66	4:10	5:12	1:02	LINE CLEAR AVAIED
227	21-Sep-2021	MYSURU	66	HV1	SANTHESARGUR_66	10:10	11:35	1:25	LINE CLEAR AVAIED
228	21-Sep-2021	MYSURU	220	VAJAMANGALA-TKHALLI	NO STATIONS EFFECTED	7:34	19:02	11:28	NFBC ISSUED
229	21-Sep-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN,LINE CLEAR AVAIED
230	21-Sep-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAIED
231	21-Sep-2021	MYSURU	66	HV1	BANNIMANTAP_66	12:58:30 21/09/2021			TRANSFORMER OPEN, LINE CLEAR AVAIED
232	21-Sep-2021	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	13:20	13:47	0:27	TRANSFORMER FAULT
233	21-Sep-2021	TUMKUR	220	TR-2(HV SIDE)	ANCHEPALYA_220	13:20	13:51	0:30	TRANSFORMER FAULT
234	21-Sep-2021	TUMKUR	110	TR-2	BANDIHALLI_110	16:31	17:42	1:10	HAND TRIPPED
235	21-Sep-2021	TUMKUR	110	TR-1	DODDAGUNI_110	11:47	14:14	2:26	LINE CLEAR AVAIED
236	21-Sep-2021	TUMKUR	66	BALENAHALLI-CHALKERE66	BALENAHALLI_66	18:39	18:54	0:15	LINE FAULT
237	21-Sep-2021	TUMKUR	66	BALENAHALLI66-CHITRADURGA	BALENAHALLI_66	18:24	18:40	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
238	21-Sep-2021	TUMKUR	66	BALENAHALLI66- FEFCWINDWIND IPP 66	FEFCWINDWIND_IPP_66	18:40	18:46	0:06	HAND TRIPPED
239	21-Sep-2021	TUMKUR	66	TR-2	BENNEHALLI_66	9:28	9:41	0:13	TRANSFORMER FAULT
240	21-Sep-2021	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP 66	GOLDEN HATCHERIES_IPP_66	11:46	12:01	0:15	LINE FAULT
241	21-Sep-2021	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP 66	GOLDEN HATCHERIES_IPP_66	13:01	13:41	0:39	LINE FAULT
242	21-Sep-2021	TUMKUR	66	TR-1	HANAGAL_66	7:12	7:22	0:09	HAND TRIPPED
243	21-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:59	18:03	0:03	LINE FAULT
244	21-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66, SASALUHALLA 66	18:33	18:42	0:09	LINE FAULT
245	21-Sep-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	16:52	17:02	0:09	LINE FAULT
246	21-Sep-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGU NDA 66	9:52	13:08	3:15	LINE CLEAR AVAILED
247	21-Sep-2021	TUMKUR	66	TR-1	JIDDIGERE_66	13:20	13:58	0:38	MAIN SUPPLY FAILURE
248	21-Sep-2021	TUMKUR	66	TR-1	KORTAGERE_66	11:54	18:52	6:58	LINE CLEAR AVAILED
249	21-Sep-2021	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	18:21	18:31	0:10	LINE FAULT
250	21-Sep-2021	TUMKUR	66	TR-2	RAMPURA_66	3:57	7:09	3:12	LINE CLEAR AVAILED
251	21-Sep-2021	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVANI_6 6	13:42	13:52	0:10	LINE CLEAR AVAILED
252	21-Sep-2021	TUMKUR	66	ANCHEPALYA 220kv- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI 66	11:42	15:09	3:26	LINE CLEAR AVAILED
253	21-Sep-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	13:42	13:52	0:09	LINE CLEAR AVAILED
254	21-Sep-2021	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE 66	13:42	13:52	0:09	LINE CLEAR AVAILED
255	21-Sep-2021	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	13:42	13:52	0:10	LINE CLEAR AVAILED
256	21-Sep-2021	TUMKUR	66	ANCHEPALYA 66kv-HEBBUR66	HEBBUR_66,THIMMASANDRA_66,H ONNENAHALLI 66	17:27	19:24	1:57	LINE CLEAR AVAILED
257	21-Sep-2021	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR_66	YEDIYUR_66,THIPPUR_66,JIDDEGER E 66	13:42	13:52	0:09	LINE CLEAR AVAILED
258	21-Sep-2021	TUMKUR	66	TR-1(LV-1)	ANCHEPALUA_220	13:20	13:51	0:30	TRANSFORMER FAULT
259	21-Sep-2021	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALUA_220	13:20	13:51	0:30	TRANSFORMER FAULT
260	22-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
261	22-Sep-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
262	22-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
263	22-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
264	22-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
265	22-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
266	22-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA 110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
267	22-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	14:58 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
268	22-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET 66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
269	22-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET 66	10:23 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
270	22-Sep-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI 220	12:55 (19.09.2021)			LINE OPEN, LINE FAULT
271	22-Sep-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	15:56 (20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
272	22-Sep-2021	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	10:22 (20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
273	22-Sep-2021	BAGALKOT	220	BIDNAL- HARTI2	STATION NOT AFFECTED BIDNAL 220	18:01 (20.09.2021)			LINE OPEN, LINE FAULT
274	22-Sep-2021	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED BIDNAL 220	18:14 (21.09.2021)	9:43 (22.09.2021)	15:29HRS	LINE CHARGED
275	22-Sep-2021	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED NAVALGUND 110	18:10 (21.09.2021)	15:40 (22.09.2021)	21:30HRS	LINE CHARGED
276	22-Sep-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	11:52	12:07	0:15	HAND TRIPPED
277	22-Sep-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	17:07	17:15	0:08	HAND TRIPPED
278	22-Sep-2021	BAGALKOT	110	110/11KV,HV1	GUTTAL_110	16:07	18:25	2:18	LINE CLEAR AVAILED
279	22-Sep-2021	BAGALKOT	110	110/11KV,HV1	HATTARAGI_110	11:25	13:55	2:30	LINE CLEAR AVAILED
280	22-Sep-2021	BAGALKOT	110	BELGAUM-HUDLI	HUDLI_110	5:00	5:15	0:15	LINE FAULT
281	22-Sep-2021	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	12:46	13:16	0:30	LINE CLEAR AVAILED
282	22-Sep-2021	BAGALKOT	110	110/11KV,HV1	LAKAMANAHALLI_110	13:30	13:45	0:15	LINE CLEAR AVAILED
283	22-Sep-2021	BAGALKOT	110	110/11KV,HV1	LAKAMANAHALLI_110	15:59	16:14	0:15	LINE CLEAR AVAILED
284	22-Sep-2021	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)	13:52	14:00	0:08	TRANSFORMER FAULT
285	22-Sep-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	12:03	17:05	6:57	LINE CLEAR AVAILED
286	22-Sep-2021	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	14:26	16:33	2:08	LINE CLEAR AVAILED
287	22-Sep-2021	BAGALKOT	220	KARWAR- KADRA1	KARWAR_220	11:35	14:22	2:47	LINE CLEAR AVAILED
288	22-Sep-2021	BAGALKOT	110	BELGAUM220- HUDALI (ANKALAGI)	HUDALI_110	5:02	5:15	0:13	LINE FAULT
289	22-Sep-2021	BAGALKOT	220	HAVERI- GUTTUR1	HAVERI_220	13:46 (22.09.2021)			LINE OPEN, LINE FAULT
290	22-Sep-2021	BAGALKOT	110	HAVERI220- HANGAL (TILUVALLI)	TILUVALLI_110	6:20	11:01	4:41	LINE FAULT
291	22-Sep-2021	BAGALKOT	110	HAVERI220- HANGAL (TILUVALLI)	TILUVALLI_110	11:39	12:03	0:24	HAND TRIPPED
292	22-Sep-2021	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110, SHIRGUPPI_110, GIRISAGAR_110, BISNAL_110, TOLMATTI_110	3:25	3:30	0:05	LINE FAULT
293	22-Sep-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)			LINE OPEN,LINE CLEAR AVAILED
294	22-Sep-2021	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	13:46	13:52	0:06	LINE FAULT
295	22-Sep-2021	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	13:55	14:01	0:06	LINE FAULT
296	22-Sep-2021	BAGALKOT	110	NIPPANI- HSSSK	NIPPANI_110	11:13	21:11	9:58	LINE CLEAR AVAILED
297	22-Sep-2021	BAGALKOT	110	NAVALGUND- NOKAR SOLAR	NAVALGUND_110	18:15	22:07	3:52	LINE CLEAR AVAILED
298	22-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI 220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
299	22-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI 220	09:06 (10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
300	22-Sep-2021	BAGALKOT	110	110/11KV, HV1	BISNAL_110	3:35	3:40	0:05	MAIN SUPPLY FAILURE
301	22-Sep-2021	BAGALKOT	110	110/33KV, HV2	BISNAL_110	3:35	3:40	0:05	MAIN SUPPLY FAILURE
302	22-Sep-2021	BAGALKOT	110	110/33KV, HV2	KONNUR_110	11:45	11:55	0:10	MAIN SUPPLY FAILURE
303	22-Sep-2021	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	11:45	11:55	0:10	MAIN SUPPLY FAILURE
304	22-Sep-2021	BAGALKOT	110	110/11KV, HV2	NARAGUND_110	11:45	11:55	0:10	MAIN SUPPLY FAILURE
305	22-Sep-2021	BAGALKOT	110	110/11KV, HV1	MUGALKOD_110	11:40	14:29	2:49	LINE CLEAR AVAILED
306	22-Sep-2021	BAGALKOT	110	110/11KV, HV1	BHOJ_110	16:20	16:30	0:10	TRANSFORMER FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
307	22-Sep-2021	BAGALKOT	220	ATHANI- KUDACHI	ATHANI_220	14:26	16:33	2:07	LINE CLEAR AVAILED
308	22-Sep-2021	BAGALKOT	110	110/11KV, LV2	ATHANI_220	13:22	13:37	0:15	LINE CLEAR AVAILED
309	22-Sep-2021	BAGALKOT	110	110/11KV, HV1	YARGATTI_110	13:10	14:50	1:40	TRANSFORMER FAULT
310	22-Sep-2021	BAGALKOT	110	110/11KV, HV1	YARGATTI_110	13:10	15:45	2:35	TRANSFORMER FAULT
311	22-Sep-2021	BAGALKOT	110	YARAGATTI- KADAKOL	KADAKOL_110	14:35	14:40	0:05	HAND TRIPPED
312	22-Sep-2021	BAGALKOT	110	110/11KV, HV2	TALIKOT_110	12:30	12:35	0:05	TRANSFORMER FAULT
313	22-Sep-2021	BAGALKOT	110	110/11KV, HV2	TALIKOT_110	13:35	13:40	0:05	TRANSFORMER FAULT
314	22-Sep-2021	BENGALURU	66	HV2	AMAR JYOTHI	0:40	0:45	0:05	LINE CLEAR AVAILED
315	22-Sep-2021	BENGALURU	66	HV2	AMAR JYOTHI	11:57	11:58	0:01	LINE CLEAR AVAILED
316	22-Sep-2021	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	15:31	15:35	0:04	LOAD CHANGE OVER
317	22-Sep-2021	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	16:23	16:27	0:04	LOAD CHANGE OVER
318	22-Sep-2021	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	NO STATION AFFECTED	6:00	6:40	0:40	LINE FAULT
319	22-Sep-2021	BENGALURU	66	HV3	HSR LAYOUT 220	16:09	16:13	0:04	LINE CLEAR AVAILED
320	22-Sep-2021	BENGALURU	66	HV2	HSR LAYOUT 220	16:09	16:13	0:04	LINE CLEAR AVAILED
321	22-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	15:48	15:50	0:02	LINE CLEAR AVAILED
322	22-Sep-2021	BENGALURU	66	HV1	ISRO LAYOUT	18:52	19:00	0:08	TRANSFORMER FAULT
323	22-Sep-2021	BENGALURU	220	HV2	NRS 220	13:05	13:17	0:12	TRANSFORMER FAULT
324	22-Sep-2021	BENGALURU	66	HV1	RAJANUKUNTE	16:38	17:03	0:25	LINE CLEAR AVAILED
325	22-Sep-2021	BENGALURU	66	HV2	RAJANUKUNTE	17:09	17:24	0:15	LINE CLEAR AVAILED
326	22-Sep-2021	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	13:38	13:40	0:02	LOAD CHANGE OVER
327	22-Sep-2021	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	14:32	14:35	0:03	LOAD CHANGE OVER
328	22-Sep-2021	BENGALURU	66	HV1	VRISHABHAVATHI 220	12:21	12:57	0:36	LINE CLEAR AVAILED
329	22-Sep-2021	BENGALURU	66	HV1	TEKAL	12:43	15:10	2:26	LINE CLEAR AVAILED
330	22-Sep-2021	BENGALURU	66	HV1	TEKAL	16:28	16:30	0:02	TRANSFORMER FAULT
331	22-Sep-2021	BENGALURU	66	HV1	KAMASAMUDRA	12:25	12:30	0:04	LINE CLEAR AVAILED
332	22-Sep-2021	BENGALURU	66	HV1	CHINTAMANI 66	11:24	11:28	0:04	LINE CLEAR AVAILED
333	22-Sep-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	17:27	18:08	0:40	LINE FAULT
334	22-Sep-2021	BENGALURU	66	HOSUR RAMAPURA - NITRALLI	NITRALLI, MADHUGIRI	14:23	16:00	1:36	LINE CLEAR AVAILED
335	22-Sep-2021	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	9:30	9:39	0:09	LOAD CHANGE OVER
336	22-Sep-2021	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	13:48	13:54	0:06	LOAD CHANGE OVER
337	22-Sep-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, KANASWADI	18:06	18:08	0:01	LINE CLEAR AVAILED
338	22-Sep-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, KANASWADI	18:25	19:16	0:51	LINE FAULT
339	22-Sep-2021	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	5:50	6:10	0:20	LINE FAULT
340	22-Sep-2021	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	23:43(22-9-2021)			LINE OPEN, LINE FAULT
341	22-Sep-2021	GULBARGA	400	RTPS-BTPS	RTPS_400	12:09(21.09.2021)	15:26(22.09.2021)	27:17 HRS	LINE CHARGED
342	22-Sep-2021	GULBARGA	220	RTPS-LINGASUGUR1	RTPS_220	15:42(21.09.2021)	13:22(22.06.2021)	21:38HRS	LINE CHARGED
343	22-Sep-2021	GULBARGA	220	KUSTAGI-LINGAPUR	KUSTAGI_220	14:10	14:42	0:32	LINE FAULT
344	22-Sep-2021	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	14:10(22.09.2021)			LINE OPEN, LINE FAULT
345	22-Sep-2021	GULBARGA	220	HV1	SHAHABAD_220	5:52	10:45	4:53	TRANSFORMER FAULT
346	22-Sep-2021	GULBARGA	220	HV1	MALLAT_220	12:11	13:51	1:40	LINE CLEAR AVAILED
347	22-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
348	22-Sep-2021	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	14:10	14:29	0:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
349	22-Sep-2021	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	6:03	6:32	0:29	LINE FAULT
350	22-Sep-2021	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	6:03	6:48	0:45	LINE FAULT
351	22-Sep-2021	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	6:03	6:28	0:25	LINE FAULT
352	22-Sep-2021	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	14:10	14:35	0:25	MAIN SUPPLY FAILURE
353	22-Sep-2021	GULBARGA	220	LINGAPUR-BMM	LINGAPUR_220	8:57	15:10	6:13	LINE CLEAR AVAILED
354	22-Sep-2021	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	5:05	5:27	0:22	LINE FAULT
355	22-Sep-2021	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	14:11	14:40	0:29	LINE FAULT
356	22-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
357	22-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
358	22-Sep-2021	GULBARGA	110	HV2	JEWARGI_110	7:14	7:18	0:04	TRANSFORMER FAULT
359	22-Sep-2021	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	0:25	0:37	0:12	LINE FAULT
360	22-Sep-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	5:52	7:14	1:22	LINE FAULT
361	22-Sep-2021	GULBARGA	110	RAJESHWAR-WARDHA SOLAR	RAJESHWAR_110	6:00	7:16	1:16	LINE FAULT
362	22-Sep-2021	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	6:00	6:35	0:35	MAIN SUPPLY FAILURE
363	22-Sep-2021	GULBARGA	110	SEDAM-ULTRATECH	ULTRATECH_IPP	5:28	5:40	0:12	LINE FAULT
364	22-Sep-2021	GULBARGA	110	HV2	HATTI_110	7:23	7:25	0:02	TRANSFORMER FAULT
365	22-Sep-2021	GULBARGA	110	HV4	SHAHABAD_220	8:35	9:20	0:45	LINE CLEAR AVAILED
366	22-Sep-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DE VANGAON_110,RENUKA_IPP,AFZAL PUR 110,KARAJAGI 110	5:56	6:03	0:07	LINE FAULT
367	22-Sep-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	23:40	23:49	0:09	LINE FAULT
368	22-Sep-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,W ADAGERA_110,CORE GREEN SUGAR IPP	13:48	14:20	0:32	LINE CLEAR AVAILED
369	22-Sep-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,W ADAGERA_110,CORE GREEN SUGAR IPP	21:53	22:05	0:12	LINE FAULT
370	22-Sep-2021	GULBARGA	110	RAICHUR-APMC1 & 2	APMC_110,CHIKSUGUR_110,SHAKT INAGAR 110	3:34	3:42	0:08	LINE FAULT
371	22-Sep-2021	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110, MANTHAL 110	6:03	6:32	0:29	LINE FAULT
372	22-Sep-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110,MUDDAPUR 110	14:11	14:46	0:35	LINE FAULT
373	22-Sep-2021	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110,TEKKALKOTE_110,D HADESUGUR_110,VOORA_IPP,NSL SUGAR IPP	20:22	20:32	0:10	LINE FAULT
374	22-Sep-2021	GULBARGA	110	HV1	BYGWAT_110	18:45	19:07	0:22	LINE CLEAR AVAILED
375	22-Sep-2021	GULBARGA	110	MALLAT-BYGWAT	BYGWAT_110	23:40	23:48	0:08	MAIN SUPPLY FAILURE
376	22-Sep-2021	GULBARGA	110	HATTI-SMNMRD	HATTI_110	14:10	14:41	0:31	LINE FAULT
377	22-Sep-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	4:45	5:01	0:16	LINE FAULT
378	22-Sep-2021	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	12:10	13:40	1:30	NFBC ISSUED
379	22-Sep-2021	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	12:14	13:42	1:28	LINE CLEAR AVAILED
380	22-Sep-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGARS_FACTORY,CHOWDAPUR_1 10	17:31	17:36	0:05	LINE FAULT
381	22-Sep-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	21:06	21:11	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
382	22-Sep-2021	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENHALLI_66,GIRIYAPURA_66,MAGALA_66,TUNGA BHADRA IPP	7:00	7:12	0:12	LINE FAULT
383	22-Sep-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	15:05	15:25	0:20	TRANSFORMER FAULT
384	22-Sep-2021	GULBARGA	66	KUDLIGI_220-KUDLIGI	KUDLIGI_66	6:00	6:15	0:15	LINE FAULT
385	22-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN,LINE CLEAR AVAILED
386	22-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
387	22-Sep-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
388	22-Sep-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN, LINE FAULT
389	22-Sep-2021	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	10:08 (22.09.2021)			LINE OPEN,LINE CLEAR AVAILED
390	22-Sep-2021	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	16:06	16:26	0:20	LINE CLEAR AVAILED
391	22-Sep-2021	HASSAN	110	KAVOOR-KIOCL	KAVOOR_220	10:50	11:51	1:01	LINE CLEAR AVAILED
392	22-Sep-2021	HASSAN	110	HV2	KONAJE_110	12:07	13:15	1:08	LINE CLEAR AVAILED
393	22-Sep-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	20:07	20:10	0:03	HAND TRIPPED
394	22-Sep-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	20:11	20:13	0:02	HAND TRIPPED
395	22-Sep-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:44	13:34	1:50	LINE CLEAR AVAILED
396	22-Sep-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:42	11:55	0:13	LINE FAULT
397	22-Sep-2021	HASSAN	66	HV1 CB	HETTUR_110	10:05	17:10	7:05	LINE CLEAR AVAILED
398	22-Sep-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	9:25	13:47	22:44	HAND TRIPPED
399	22-Sep-2021	MYSURU	220	HV2	KADAKOLA_220	10:00	13:39	3:39	LINE CLEAR AVAILED
400	22-Sep-2021	MYSURU	66	MADHUVANAHALLI-DODDINADUWADI	NO STATIONS EFFECTED	12:14	15:47	3:33	LINE CLEAR AVAILED
401	22-Sep-2021	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	12:16	16:52	4:35	LINE CLEAR AVAILED
402	22-Sep-2021	MYSURU	220	TUBINKERE-YALIYUR(RAILWAY)	NO STATIONS EFFECTED	10:35	14:35	4:00	LINE CLEAR AVAILED
403	22-Sep-2021	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	8:19	19:19	11:00	NFBC ISSUED
404	22-Sep-2021	MYSURU	220	HV2	VAJAMANGALA_220	11:10	16:46	5:35	LINE CLEAR AVAILED
405	22-Sep-2021	MYSURU	66	HV1	COWDALLI_66	9:35	12:46	3:11	LINE CLEAR AVAILED
406	22-Sep-2021	MYSURU	66	HV1	COWDALLI_66	13:40	19:33	5:53	LINE CLEAR AVAILED
407	22-Sep-2021	MYSURU	66	HV2	COWDALLI_66	9:35	9:55	0:20	LINE CLEAR AVAILED
408	22-Sep-2021	MYSURU	66	HV2	COWDALLI_66	12:46	14:01	1:14	LINE CLEAR AVAILED
409	22-Sep-2021	MYSURU	66	DEVNUR MYSORE-RAJEEVNAGARA	DEVANOORMYS_66 FTS_66 RAJEEVNAGARA_66 JYOTHINAGARA_66	17:12	17:20	0:08	HAND TRIPPED
410	22-Sep-2021	MYSURU	66	HV2	KIRUGAVALU_66	11:25	12:14	0:48	LINE CLEAR AVAILED
411	22-Sep-2021	MYSURU	66	KIRUGAVALU-MALIYUR	KIRUGAVALU_66 VADERALLI_66	18:26	18:46	0:20	LINE FAULT
412	22-Sep-2021	MYSURU	66	HV2	KMDODDI_66	12:40	13:20	0:40	LINE CLEAR AVAILED
413	22-Sep-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	6:37	6:44	0:07	LINE FAULT
414	22-Sep-2021	MYSURU	66	MEGHALAPURA-HEBBANI	NO STATIONS EFFECTED	10:32	10:54	0:22	HAND TRIPPED
415	22-Sep-2021	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	9:29	13:46	4:16	HAND TRIPPED
416	22-Sep-2021	MYSURU	66	HV2	PANDAVAPURA_66	13:20	14:02	0:42	LINE CLEAR AVAILED
417	22-Sep-2021	MYSURU	66	THANDYA-KADAKOLA	NO STATIONS EFFECTED	9:40	14:04	4:24	HAND TRIPPED
418	22-Sep-2021	MYSURU	220	HV2	HEBBANI_220	11:02	12:38	1:36	LINE CLEAR AVAILED
419	22-Sep-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
420	22-Sep-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
421	22-Sep-2021	MYSURU	66	HV1	BANNIMANTAP_66	12:58:30 21/09/2021	14:36:00 (23/09/2021)	25:37HRS	TRANSFORMER CHARGED
422	22-Sep-2021	TUMKUR	66	TR1 & TR2	PAVAGADA_66	16:29	20:30	4:01	LINE CLEAR AVAILED
423	22-Sep-2021	TUMKUR	66	TR1	Badavanahalli	8:06	8:15	0:08	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
424	22-Sep-2021	TUMKUR	66	TR2	RAMPURA_66	20:50	21:35	0:45	LINE CLEAR AVAILED
425	22-Sep-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	8:12	8:46	0:34	LINE FAULT
426	22-Sep-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	10:17	16:52	6:35	LINE CLEAR AVAILED
427	22-Sep-2021	TUMKUR	66	TR2	ANTHRASANAHALLI	13:08	13:31	0:23	TRANSFORMER FAULT
428	22-Sep-2021	TUMKUR	66	TR2	ANTHRASANAHALLI	13:32	13:54	0:22	LINE CLEAR AVAILED
429	22-Sep-2021	TUMKUR	66	TR2	MELEKOTE	7:26	8:52	1:25	MAIN SUPPLY FAILURE
430	22-Sep-2021	TUMKUR	66	TR1 & TR2	BADDIHALLI	10:10	16:20	6:10	LINE CLEAR AVAILED
431	22-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:42	15:51	0:09	LINE FAULT
432	22-Sep-2021	TUMKUR	66	CHITRADURGA 220kv-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:27	17:14	6:47	LINE CLEAR AVAILED
433	22-Sep-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:18	10:30	0:12	LINE FAULT
434	22-Sep-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:26	15:10	2:44	LINE CLEAR AVAILED
435	23-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
436	23-Sep-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
437	23-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
438	23-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
439	23-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
440	23-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
441	23-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
442	23-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)	19:06 (23.09.2021)	292:08HRS	LINE CHARGED
443	23-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
444	23-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
445	23-Sep-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	12:55 (19.09.2021)			LINE OPEN, LINE FAULT
446	23-Sep-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	15:56 (20.09.2021)	11:03 (23.09.2021)	67:07HRS	LINE CHARGED
447	23-Sep-2021	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:22 (20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
448	23-Sep-2021	BAGALKOT	220	BIDNAL- HARTI2	STATION NOT AFFECTED BIDNAL_220	18:01 (20.09.2021)	15:07 (23.09.2021)	69:06HRS	LINE CHARGED
449	23-Sep-2021	BAGALKOT	220	HAVERI- GUTTUR1	HAVERI_220	13:46 (22.09.2021)	16:42 (23.09.2021)	26:56HRS	LINE CHARGED
450	23-Sep-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)			LINE OPEN,LINE CLEAR AVAILED
451	23-Sep-2021	BAGALKOT	220	BIDNAL - HARTI1	BIDNAL_220	10:22	15:01	4:39	LINE CLEAR AVAILED
452	23-Sep-2021	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND_110	11:11	16:46	5:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
453	23-Sep-2021	BAGALKOT	110	220/110KV, LV2	BIJAPUR_220	16:10 (23.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
454	23-Sep-2021	BAGALKOT	110	110/11KV, HV1	GOKAK_110	10:10	13:45	3:35	LINE CLEAR AVAILED
455	23-Sep-2021	BAGALKOT	110	HALIYAL-ALNAVAR(GMR)	ALNAVAR_110	6:04	6:41	0:37	LINE FAULT
456	23-Sep-2021	BAGALKOT	110	HALIYAL-ALNAVAR(GMR)	ALNAVAR_110	7:19	9:59	2:40	LINE FAULT
457	23-Sep-2021	BAGALKOT	110	KERUR-KULAGERI CROSS(KONNUR)	KULAGERI CROSS_110	11:58	16:25	4:27	LINE CLEAR AVAILED
458	23-Sep-2021	BAGALKOT	110	KUD DHARWAD-LAKAMANAHALLI	LAKAMANAHALLI_110	10:55	18:37	7:42	LINE CLEAR AVAILED
459	23-Sep-2021	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)	3:24	3:55	0:31	TRANSFORMER FAULT
460	23-Sep-2021	BAGALKOT	110	MK HUBLI-KITTUR(NARENDRA)	KITTUR_110	8:53	20:12	11:19	LINE CLEAR AVAILED
461	23-Sep-2021	BAGALKOT	110	110/11KV, HV1	MUDALAGI_110	12:45	13:06	0:21	LINE CLEAR AVAILED
462	23-Sep-2021	BAGALKOT	110	NARENDRA-KUD DHARWAD 1	KUD DHARWAD_110	11:16	17:52	6:36	LINE CLEAR AVAILED
463	23-Sep-2021	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	14:58	15:00	0:02	TRANSFORMER FAULT
464	23-Sep-2021	BAGALKOT	110	RANEENNUR220-RATTIHALI	RATTIHALI_110	11:35	19:40	8:05	LINE CLEAR AVAILED
465	23-Sep-2021	BAGALKOT	220	HUBL- SIRSI2	HUBLI_220	5:07 (23.09.2021)			LINE OPEN, LINE CLEAR AVAILED
466	23-Sep-2021	BAGALKOT	220	HUBL- SIRSI1	HUBLI_220	11:05	17:35	6:30	HAND TRIPPED
467	23-Sep-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	5:07 (23.09.2021)			LINE OPEN, LINE FAULT
468	23-Sep-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	11:03 (23.09.201)			LINE OPEN, LINE CLEAR AVAILED
469	23-Sep-2021	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	10:18	14:31	4:13	LINE CLEAR AVAILED
470	23-Sep-2021	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	18:41	19:37	0:56	LINE CLEAR AVAILED
471	23-Sep-2021	BAGALKOT	220	HAVERI- BIDNAL	HAVERI_220	16:53	18:34	1:41	LINE CLEAR AVAILED
472	23-Sep-2021	BAGALKOT	110	RANEENNUR- TUMMINKATTI	TUMMINKATTI_110	11:35	19:42	8:07	LINE CLEAR AVAILED
473	23-Sep-2021	BAGALKOT	110	TARIHAL- IDLE (NAVANAGAR)	NAVANAGAR(H)_110	10:23	10:29	0:06	HAND TRIPPED
474	23-Sep-2021	BAGALKOT	110	110/11KV, HV1	SOUDATTI_110	10:03	17:30	7:27	LINE CLEAR AVAILED
475	23-Sep-2021	BAGALKOT	110	SHIGGOAN- AVANTI SOLAR	SHIGGOAN_110	10:18	17:04	6:46	LINE CLEAR AVAILED
476	23-Sep-2021	BAGALKOT	110	SHIGGOAN- SAVANUR	SHIGGOAN_110	15:15	16:57	1:42	LINE CLEAR AVAILED
477	23-Sep-2021	BAGALKOT	110	SHIGGOAN- MUNDAGOD	SHIGGOAN_110	15:15	17:00	1:45	LINE CLEAR AVAILED
478	23-Sep-2021	BAGALKOT	110	110/33KV, HV3	SHIGGOAN_110, SHIGGOAN_33, AMBUJA 33, SOALR 33	10:11	16:57	6:46	LINE CLEAR AVAILED
479	23-Sep-2021	BAGALKOT	110	110/11KV, HV1&HV2	SHIGGOAN_110	10:11	16:57	6:46	LINE CLEAR AVAILED
480	23-Sep-2021	BAGALKOT	220	220/110KV, HV1&LV1	RANEENNUR_220	11:38	15:00	3:22	LINE CLEAR AVAILED
481	23-Sep-2021	BAGALKOT	110	110/11KV, HV1&HV2	RANEENNUR_220	10:10	18:15	8:05	LINE CLEAR AVAILED
482	23-Sep-2021	BAGALKOT	110	110/33KV, HV3&HV4	RANEENNUR_220	10:10	18:15	8:05	LINE CLEAR AVAILED
483	23-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN, LINE CLEAR AVAILED
484	23-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN, LINE CLEAR AVAILED
485	23-Sep-2021	BAGALKOT	110	110/11KV, HV1	KHADAKLAT_110	10:20	15:40	5:20	LINE CLEAR AVAILED
486	23-Sep-2021	BAGALKOT	110	110/11KV, HV1	KHADAKLAT_110	12:25	15:30	3:05	LINE CLEAR AVAILED
487	23-Sep-2021	BAGALKOT	110	ALANAVAR- HALIYAL	HALIYAL_110	6:05	6:43	0:38	LINE FAULT
488	23-Sep-2021	BAGALKOT	110	ALANAVAR- HALIYAL	HALIYAL_110	7:19	9:59	2:40	LINE FAULT
489	23-Sep-2021	BAGALKOT	110	HALIYAL- GMR	HALIYAL_110	6:07	6:32	0:25	LINE FAULT
490	23-Sep-2021	BAGALKOT	110	110/11KV, HV1	HALIYAL_110	6:07	6:32	0:25	TRANSFORMER FAULT
491	23-Sep-2021	BAGALKOT	110	110/11KV, HV1	KUD DHARWAD_110	7:00	18:15	11:15	LINE CLEAR AVAILED
492	23-Sep-2021	BAGALKOT	110	110/11KV, HV2	KUD DHARWAD_110	7:00	18:15	11:15	LINE CLEAR AVAILED
493	23-Sep-2021	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:30	14:40	2:10	LINE CLEAR AVAILED
494	23-Sep-2021	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220	11:05	13:30	2:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
495	23-Sep-2021	BAGALKOT	110	110/11KV, HV1	CHIKKODI_110	14:05	14:10	0:05	TRANSFORMER FAULT
496	23-Sep-2021	BENGALURU	66	ATTUR YELAHANKA - DG3	ABBIGERE, WELCAST	8:19	8:36	0:17	LINE FAULT
497	23-Sep-2021	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	11:12	11:18	0:06	LOAD CHANGE OVER
498	23-Sep-2021	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	19:22	19:34	0:12	MAIN SUPPLY FAILURE
499	23-Sep-2021	BENGALURU	66	HV1	ANJANAPURA	9:50	9:55	0:05	LINE CLEAR AVAILED
500	23-Sep-2021	BENGALURU	66	HV1	DASHAVARA	14:31	14:40	0:09	TRANSFORMER FAULT
501	23-Sep-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	14:48	14:56	0:08	LOAD CHANGE OVER
502	23-Sep-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	16:06	16:12	0:06	LOAD CHANGE OVER
503	23-Sep-2021	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	9:38	9:42	0:04	LOAD CHANGE OVER
504	23-Sep-2021	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	18:03	18:07	0:04	LOAD CHANGE OVER
505	23-Sep-2021	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	10:02	10:11	0:09	LOAD CHANGE OVER
506	23-Sep-2021	BENGALURU	66	JAYANAGARA - NATIONAL COLLEGE	JAYANAGARA	17:54	17:57	0:03	LOAD CHANGE OVER
507	23-Sep-2021	BENGALURU	220	NIMHANS 220 - EAST DIVISION COMPOUND 220	NIMHANS 220	10:03	17:30	7:27	LINE CLEAR AVAILED
508	23-Sep-2021	BENGALURU	66	HV1	NIMHANS 220	10:03	17:30	7:27	LINE CLEAR AVAILED
509	23-Sep-2021	BENGALURU	66	HV2	NIMHANS 220	10:03	17:30	7:27	LINE CLEAR AVAILED
510	23-Sep-2021	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	10:02	10:06	0:04	LOAD CHANGE OVER
511	23-Sep-2021	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	18:12	18:16	0:04	LOAD CHANGE OVER
512	23-Sep-2021	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66, ISKON	8:38	8:40	0:02	LINE CLEAR AVAILED
513	23-Sep-2021	BENGALURU	66	V R DODDI - T K HALLI 220	V R DODDI	9:10	9:15	0:05	LOAD CHANGE OVER
514	23-Sep-2021	BENGALURU	66	YARANDANAHALLI 220 - JIGANI	KUMBARANAHALLI	19:55	20:27	0:32	LINE FAULT
515	23-Sep-2021	BENGALURU	66	YELAHANKA 220 - LINE1	NO STATION AFFECTED	19:22	19:28	0:06	MAIN SUPPLY FAILURE
516	23-Sep-2021	BENGALURU	66	YELAHANKA 220 - LINE2	NO STATION AFFECTED	19:22	19:28	0:06	MAIN SUPPLY FAILURE
517	23-Sep-2021	BENGALURU	66	YELAHANKA 220 - LINE3	WHEELS & AXLE(EHT), ESCORTS ( EHT )YHT(9), ATTUR YELAHANKA	19:22	19:28	0:06	MAIN SUPPLY FAILURE
518	23-Sep-2021	BENGALURU	66	YELAHANKA 220 - LINE4	SAHAKARINAGAR, ESCORTS(EHT)YHT(8)	19:22	19:28	0:06	MAIN SUPPLY FAILURE
519	23-Sep-2021	BENGALURU	66	YELAHANKA 220 - LINE5	KHB	19:22	19:28	0:06	MAIN SUPPLY FAILURE
520	23-Sep-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	19:22	19:28	0:06	MAIN SUPPLY FAILURE
521	23-Sep-2021	BENGALURU	220	HV2	YELAHANKA 220	19:22	19:28	0:06	TRANSFORMER FAULT
522	23-Sep-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	11:07	11:16	0:09	LINE CLEAR AVAILED
523	23-Sep-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	14:58	15:06	0:07	LINE CLEAR AVAILED
524	23-Sep-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:07	11:16	0:09	LINE CLEAR AVAILED
525	23-Sep-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	14:58	15:06	0:07	LINE CLEAR AVAILED
526	23-Sep-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	12:11	13:25	1:14	LINE CLEAR AVAILED
527	23-Sep-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	11:07	11:15	0:07	LINE CLEAR AVAILED
528	23-Sep-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	14:58	15:05	0:06	LINE CLEAR AVAILED
529	23-Sep-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	13:45	13:49	0:04	LINE FAULT
530	23-Sep-2021	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	5:52	6:10	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
531	23-Sep-2021	BENGALURU	66	SOMENAHALLI - PERESANDRA	NO STATION AFFECTED	15:00	15:42	0:41	LINE CLEAR AVAILED
532	23-Sep-2021	BENGALURU	220	HV2	DB PURA 220	11:08	14:56	3:48	LINE CLEAR AVAILED
533	23-Sep-2021	BENGALURU	220	LV1	GOWRIBIDANUR 220	9:40	10:15	0:35	TRANSFORMER FAULT
534	23-Sep-2021	BENGALURU	66	HV2	SADLI	16:05	16:10	0:05	LINE CLEAR AVAILED
535	23-Sep-2021	BENGALURU	66	HV1	SADLI	15:20	15:38	0:18	LINE CLEAR AVAILED
536	23-Sep-2021	BENGALURU	66	HV1	TEKAL	10:00	10:12	0:12	LINE CLEAR AVAILED
537	23-Sep-2021	BENGALURU	66	HV2	TEMAGONDALU	12:15	12:20	0:05	LINE CLEAR AVAILED
538	23-Sep-2021	BENGALURU	66	PERESANDRA - MITTEMARI 220	PERESANDRA	14:40	14:45	0:05	LOAD CHANGE OVER
539	23-Sep-2021	BENGALURU	66	PERESANDRA - GOWRIBIDANUR 220	PERESANDRA	15:50	15:55	0:05	LOAD CHANGE OVER
540	23-Sep-2021	BENGALURU	66	WELCASTE STEEL - SRS PEENYA 220	WELCASTE STEEL	22:20	22:27	0:07	LOAD CHANGE OVER
541	23-Sep-2021	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	14:10(22.09.2021)	15:10(23.09.2021)	25:00HRS	LINE CHARGED
542	23-Sep-2021	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	17:20	17:37	0:17	LINE FAULT
543	23-Sep-2021	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	22:37	22:46	0:09	LINE FAULT
544	23-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
545	23-Sep-2021	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	4:54	5:07	0:13	LINE FAULT
546	23-Sep-2021	GULBARGA	220	SHAHAPUR-KAPNOOR1	KAPNOOR_220	22:35	22:53	0:18	LINE FAULT
547	23-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
548	23-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
549	23-Sep-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110,MUDDAPUR 110	2:54	3:00	0:06	LINE FAULT
550	23-Sep-2021	GULBARGA	110	MASKI-RENEW SOLAR	MASKI_110	2:54	3:52	0:58	LINE FAULT
551	23-Sep-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,MUDDAPUR_110	4:55	5:03	0:08	LINE FAULT
552	23-Sep-2021	GULBARGA	110	MASKI-HATTI	HATTI_110	5:07	7:57	2:50	LINE FAULT
553	23-Sep-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,AFZAL PUR 110,KARAJAGI 110	5:56	6:03	0:07	LINE FAULT
554	23-Sep-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARAGI_110	20:22	20:35	0:13	LINE FAULT
555	23-Sep-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARAGI_110	20:50	21:15	0:25	LINE FAULT
556	23-Sep-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	18:30	18:43	0:13	LINE FAULT
557	23-Sep-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	21:16	21:26	0:10	LINE FAULT
558	23-Sep-2021	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	19:32	19:47	0:15	LINE FAULT
559	23-Sep-2021	GULBARGA	110	SEDAM-CHITHAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110,RAJESHREE CEMENT.	0:19	0:26	0:07	LINE FAULT
560	23-Sep-2021	GULBARGA	110	SEDAM-CHITHAPUR	CHITTAPUR_110,KORAWAR TEMPLE_110,RAJESHREE CEMENT.	0:51	0:55	0:04	LINE FAULT
561	23-Sep-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	20:21	20:34	0:13	LINE FAULT
562	23-Sep-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	20:50	21:15	0:25	LINE FAULT
563	23-Sep-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	22:48	23:01	0:13	LINE FAULT
564	23-Sep-2021	GULBARGA	110	PDHALLI-CLN MAX	PD_HALLI_110	17:26	18:32	1:06	LINE CLEAR AVAILED
565	23-Sep-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IP P,BHALKI SUGAR IPP	3:15	3:22	0:07	LINE FAULT
566	23-Sep-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	16:04	16:12	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
567	23-Sep-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	18:25	18:29	0:04	LINE FAULT
568	23-Sep-2021	GULBARGA	110	HALBARGA-KOLHAR1,2	KOLHAR_110,JANWADA_110,NSSK SUGAR FACTORY	10:15	11:20	1:05	NFBC ISSUED
569	23-Sep-2021	GULBARGA	110	HALBARGA-KOLHAR1,2	KOLHAR_110,JANWADA_110,NSSK SUGAR FACTORY	10:45	11:20	0:35	LINE CLEAR AVAILED
570	23-Sep-2021	GULBARGA	110	HV2	BISIHALLI_110	12:20	12:25	0:05	LINE CLEAR AVAILED
571	23-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN,LINE CLEAR AVAILED
572	23-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
573	23-Sep-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
574	23-Sep-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN, LINE FAULT
575	23-Sep-2021	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	10:08 (22.09.2021)			LINE OPEN,LINE CLEAR AVAILED
576	23-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	12:32	17:34	5:02	HAND TRIPPED
577	23-Sep-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	10:17	11:14	0:57	LINE CLEAR AVAILED
578	23-Sep-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	11:30	17:06	5:36	LINE CLEAR AVAILED
579	23-Sep-2021	HASSAN	220	HV1	SHIRALKOPPA_220	11:30	12:27	0:57	TRANSFORMER FAULT
580	23-Sep-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:17	11:14	0:57	HAND TRIPPED
581	23-Sep-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:30	17:06	5:36	HAND TRIPPED
582	23-Sep-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:10	11:12	1:02	HAND TRIPPED
583	23-Sep-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:12	11:24	0:12	LINE FAULT
584	23-Sep-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:30	11:56	0:26	MAIN SUPPLY FAILURE
585	23-Sep-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:56	12:01	0:05	LINE FAULT
586	23-Sep-2021	HASSAN	110	LV1	SHIRALKOPPA_220	11:58	12:27	0:29	TRANSFORMER FAULT
587	23-Sep-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:07	11:15	0:08	MAIN SUPPLY FAILURE
588	23-Sep-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:30	11:56	0:26	MAIN SUPPLY FAILURE
589	23-Sep-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:07	11:15	0:08	MAIN SUPPLY FAILURE
590	23-Sep-2021	HASSAN	110	SHRKP-SORAB	SHIRALKOPPA_220	11:30	11:56	0:26	MAIN SUPPLY FAILURE
591	23-Sep-2021	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:42	14:16	3:34	NFBC ISSUED
592	23-Sep-2021	HASSAN	110	VITTAL-PUTR_SLTUR	VITTAL_110	10:42	14:16	3:34	LINE CLEAR AVAILED
593	23-Sep-2021	HASSAN	66	HV2	HALLIMYSORE_66	11:05	12:20	1:15	LINE CLEAR AVAILED
594	23-Sep-2021	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	12:05	14:03	1:58	LINE CLEAR AVAILED
595	23-Sep-2021	HASSAN	66	HV1	MANJUNATHPURA_66	10:10	13:07	2:57	LINE CLEAR AVAILED
596	23-Sep-2021	HASSAN	66	HV2 CB	MNJUPR	10:10	13:07	2:57	LINE CLEAR AVAILED
597	23-Sep-2021	HASSAN	66	HNPR4	MOSALEHOSAHALLI_66	11:23	15:05	3:42	LINE CLEAR AVAILED
598	23-Sep-2021	HASSAN	66	HV1	MOSALEHOSAHALLI_66	10:40	15:05	4:25	LINE CLEAR AVAILED
599	23-Sep-2021	HASSAN	66	HV1	SAKLESHPURA_66	2:05	2:15	0:10	TRANSFORMER FAULT
600	23-Sep-2021	HASSAN	66	IPCL2	SAKLESHPURA_66	2:05	2:15	0:10	LINE FAULT
601	23-Sep-2021	MYSURU	66	HV1	COWDALLI_66	6:08	11:39	22:44	LINE CLEAR AVAILED
602	23-Sep-2021	MYSURU	66	HV2	COWDALLI_66	11:39	20:46	9:07	LINE CLEAR AVAILED
603	23-Sep-2021	MYSURU	66	DATAGALLI-HOOTAGALLI	NO STATIONS EFFECTED	10:01	12:49	2:48	NFBC ISSUED
604	23-Sep-2021	MYSURU	66	HV1	DATAGALLI_66	11:50	13:25	1:35	LINE CLEAR AVAILED
605	23-Sep-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	10:56	11:00	0:04	LINE FAULT
606	23-Sep-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	11:54	15:36	3:42	LINE FAULT
607	23-Sep-2021	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADAPURA_66 KITTUR_66 RAVANDURU_66 CHUNCHANAKATTE_66	12:34	12:37	0:02	LINE FAULT
608	23-Sep-2021	MYSURU	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66	14:24	14:34	0:10	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
609	23-Sep-2021	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66 GV GUDI_66 KR NAGARA_66 DMG HALLI_66 BILIKERE_66	12:30	12:39	0:09	HAND TRIPPED
610	23-Sep-2021	MYSURU	66	KUSHALNAGARA 220-PERIPATNA-1	PERIYAPATNA_66 PONNAMPETE_66 VIRAJPETE_66 KAMPLAPURA_66 HANGODU_66	14:24	14:34	0:10	LINE FAULT
611	23-Sep-2021	MYSURU	66	HV2	MADIKERI_66	9:45	9:49	0:03	TRANSFORMER FAULT
612	23-Sep-2021	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	10:04	12:53	2:48	HAND TRIPPED
613	23-Sep-2021	MYSURU	66	VAJMANGALA-MEGALAPURA	NO STATIONS EFFECTED	14:24	14:34	0:10	LINE FAULT
614	23-Sep-2021	MYSURU	66	HV1	SANTHESARGUR_66	16:47 (23.09.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
615	23-Sep-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI_66 BG NAGARA_66 AC GIRI_66VADERALLI 66	15:04:18(23.09.2021)			LINE OPEN,LINE CLEAR AVAILED
616	23-Sep-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
617	23-Sep-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
618	23-Sep-2021	TUMKUR	110	TR-1	TANDAGA_110	13:00	22:48	9:48	LINE CLEAR AVAILED
619	23-Sep-2021	TUMKUR	66	ANCHEPALYA 66kV-HEBBUR66	HEBBUR_66,THIMMASANDRA_66,H ONNENAHALLI_66	10:30	11:52	1:22	LINE CLEAR AVAILED
620	23-Sep-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:32	18:39	0:07	LINE FAULT
621	23-Sep-2021	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:04	14:15	0:10	LINE FAULT
622	23-Sep-2021	TUMKUR	66	TR-2	KORA_66	18:18	18:30	0:12	TRANSFORMER FAULT
623	23-Sep-2021	TUMKUR	66	KORATAGERE-HOLAVANHALLI	KORATAGERE_66	5:48	10:06	4:17	LINE FAULT
624	23-Sep-2021	TUMKUR	66	TR-2	LINGADAHALLI_66	14:10	14:18	0:07	LINE CLEAR AVAILED
625	23-Sep-2021	TUMKUR	66	TR-2	MADHUGIRI_66	9:35	17:31	7:56	LINE CLEAR AVAILED
626	23-Sep-2021	TUMKUR	66	TR-1	MYLONAHALLI_66	7:52	9:16	1:24	LINE CLEAR AVAILED
627	23-Sep-2021	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE66	NAYAKANHATTI_66	5:11	5:30	0:18	LINE FAULT
628	23-Sep-2021	TUMKUR	66	TR-2	PAVAGADA_66	12:52	13:10	0:18	LINE CLEAR AVAILED
629	23-Sep-2021	TUMKUR	66	TR-2	RAMAPURA_66	8:54	9:56	1:01	LINE CLEAR AVAILED
630	23-Sep-2021	TUMKUR	66	SOKKE 66-JAGLUR66	SOKKE_66	10:50	10:59	0:09	HAND TRIPPED
631	23-Sep-2021	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	16:00	17:17	1:17	LINE CLEAR AVAILED
632	23-Sep-2021	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	10:41	15:57	5:15	LINE CLEAR AVAILED
633	24-Sep-2021	BAGALKOT	66	66/11KV, HV1	STATION NOT AFFECTD HARIHAR HOSPET_66	8:00 (22.09.2021)	14:36 (24.09.2021)	6:36 hrs	TRANSFORMER CHARGED
634	24-Sep-2021	BAGALKOT	66	66/11KV, HV1	STATION NOT AFFECTD HARIHAR HOSPET_66	14:36	15:00	0:24	LINE CLEAR AVAILED
635	24-Sep-2021	BAGALKOT	66	66/11KV, HV1	STATION NOT AFFECTD HARIHAR HOSPET_66	15:00	21:05	6:05	LINE CLEAR AVAILED
636	24-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
637	24-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
638	24-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
639	24-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDAGANUR_110	18:26	18:31	0:05	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
640	24-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDAGANUR_110	18:53	19:05	0:12	LOAD CURTAILMENT
641	24-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LAXAMESHWAR_110	17:55	18:04	0:09	LOAD CURTAILMENT
642	24-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LAXAMESHWAR_110	18:40	18:48	0:08	LOAD CURTAILMENT
643	24-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDALASANGAM,_110	17:56	18:08	0:12	LOAD CURTAILMENT
644	24-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDALASANGAM,_110	18:41	18:45	0:04	LOAD CURTAILMENT
645	24-Sep-2021	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BABALESHWAR_110	14:41	14:47	0:06	TRANSFORMER FAULT
646	24-Sep-2021	BAGALKOT	110	110/11KV,HV1	TODALABAGI_110	18:42	20:19	1:37	LOAD CURTAILMENT
647	24-Sep-2021	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BABALESHWAR_110	17:30	17:55	0:25	TRANSFORMER FAULT
648	24-Sep-2021	BAGALKOT	110	110/11KV,HV1	ATHANI_220	15:03	15:13	0:10	LINE CLEAR AVAILED
649	24-Sep-2021	BAGALKOT	110	110/11KV,HV1	SANKESHWAR_110	16:50	17:20	0:30	LINE CLEAR AVAILED
650	24-Sep-2021	BAGALKOT	110	110/11KV,HV1 & HV2	AIGALI_110	10:00	17:15	7:15	LINE CLEAR AVAILED
651	24-Sep-2021	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED BABALESHWAR_110	19:09	19:31	0:22	LINE CLEAR AVAILED
652	24-Sep-2021	BAGALKOT	110	110/11KV,HV2	GOKAK_110	10:07	14:40	4:33	LINE CLEAR AVAILED
653	24-Sep-2021	BAGALKOT	110	110/11KV,HV2	GOPANAKOPPA_110	17:05	18:41	1:36	LINE CLEAR AVAILED
654	24-Sep-2021	BAGALKOT	110	110/11KV,HV2	SAVALAGI_110	17:56	18:08	0:12	LOAD CURTAILMENT
655	24-Sep-2021	BAGALKOT	110	110/11KV,HV2	SAVALAGI_110	18:41	18:51	0:10	LOAD CURTAILMENT
656	24-Sep-2021	BAGALKOT	110	110/11KV,HV2	GOPANAKOPPA_110	8:10	8:45	0:35	LINE CLEAR AVAILED
657	24-Sep-2021	BAGALKOT	110	110/11KV,HV4	GAJENDRGAD_110	17:57	18:10	0:13	LOAD CURTAILMENT
658	24-Sep-2021	BAGALKOT	110	110/11KV,HV4	GAJENDRGAD_110	18:42	18:55	0:13	LOAD CURTAILMENT
659	24-Sep-2021	BAGALKOT	110	110/33KV,HV1	PALA_33,BASAPUR LIS_110 HANAGAL_110	17:56	18:27	0:31	LOAD CURTAILMENT
660	24-Sep-2021	BAGALKOT	110	110/33KV,HV1	PALA_33,BASAPUR LIS_110 HANAGAL_110	18:41	19:23	0:42	LOAD CURTAILMENT
661	24-Sep-2021	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	15:32	16:03	0:31	LINE CLEAR AVAILED
662	24-Sep-2021	BAGALKOT	110	110/33KV,HV3	BAGALKOT_220, KATAGERI_33,GADDANAKERI_33	18:40	19:11	0:31	TRANSFORMER FAULT
663	24-Sep-2021	BAGALKOT	110	110/33KV,HV3	MYTRA SOLAR_33,KOLIGUDDA_33, HIDIKAL_110	17:56	18:07	0:11	LOAD CURTAILMENT
664	24-Sep-2021	BAGALKOT	110	110/33KV,HV3	MYTRA SOLAR_33,KOLIGUDDA_33, HIDIKAL_110	18:41	18:51	0:10	LOAD CURTAILMENT
665	24-Sep-2021	BAGALKOT	110	220/110KV,LV2	BIJAPUR_220	16:10 (23.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
666	24-Sep-2021	BAGALKOT	110	BAGALKOT220-GULEDGUDDA	GULEDGUDDA_110	18:40	19:10	0:30	LINE FAULT
667	24-Sep-2021	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	21:00 (24.08.21)	10:02 (24.09.21)	13:02 hrs	LINE CHARGED
668	24-Sep-2021	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
669	24-Sep-2021	BAGALKOT	110	GAJENDRGAD-RON 1& RON2	RON_110	9:59	17:28	7:29	LINE CLEAR AVAILED
670	24-Sep-2021	BAGALKOT	110	GHATAPRABHA-GHATAPRABHA2	GHATAPRABHA_220,HIDIKAL_110,I SLAMPUR_110	6:04	6:40	0:36	LINE FAULT
671	24-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
672	24-Sep-2021	BAGALKOT	110	KUDACHI220-MORAB(TERDAL)	MORAB_110 KUDACHI_220	18:39	18:49	0:10	LINE FAULT
673	24-Sep-2021	BAGALKOT	110	KUDUCCHI-MORAB(TERDAL)	MORAB_110	18:29	18:49	0:20	LINE FAULT
674	24-Sep-2021	BAGALKOT	110	NAREGAL-RON	RON_110	10:15	17:01	6:46	LINE CLEAR AVAILED
675	24-Sep-2021	BAGALKOT	110	NARENDRA220-BELUR2	STATION NOT AFFECTED BELUR_220	10:25	15:39	5:14	LINE CLEAR AVAILED
676	24-Sep-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
677	24-Sep-2021	BAGALKOT	110	RANEENNUR-HIREKERUR	STATION NOT AFFECTED RANEENNUR_220	10:12	18:23	8:11	NFBC ISSUED
678	24-Sep-2021	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	10:12	18:22	8:10	LINE CLEAR AVAILED
679	24-Sep-2021	BAGALKOT	110	RANEENNUR-HOSAHONNATTI	STATION NOT AFFECTED HOSAHONNATTI_110	3:25 (23.09.2021)	8:47 (24.09.2021)	5:22 hrs	LINE CHARGED
680	24-Sep-2021	BAGALKOT	110	RANEENNUR-HOSAHONNATTI	STATION NOT AFFECTED HOSAHONNATTI_110	12:08	16:51	4:43	LINE CLEAR AVAILED
681	24-Sep-2021	BAGALKOT	110	RON-BELAVANKI_110	BELAVANKI_110	10:00	17:05	7:05	HAND TRIPPED
682	24-Sep-2021	BAGALKOT	110	RON-GAJENDRAGAD	RON_110	10:15	17:22	7:07	LINE CLEAR AVAILED
683	24-Sep-2021	BAGALKOT	110	RON-HIREHAL	RON_110	10:35	18:32	7:57	LINE CLEAR AVAILED
684	24-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
685	24-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
686	24-Sep-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)			LINE OPEN,LINE CLEAR AVAILED
687	24-Sep-2021	BAGALKOT	110	SOUDATTI220-SOUDATTI	SODATTI_110	17:19	17:41	0:22	LINE CLEAR AVAILED
688	24-Sep-2021	BAGALKOT	110	VAJRAMATTI220-MANTUR 1&2	MANTUR_110	10:56	17:42	6:46	LINE CLEAR AVAILED
689	24-Sep-2021	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	12:10	14:35	2:25	LINE CLEAR AVAILED
690	24-Sep-2021	BAGALKOT	220	220/110KV,HV1,LV1	GADAG_220	16:23	16:54	0:31	LINE CLEAR AVAILED
691	24-Sep-2021	BAGALKOT	220	220/110KV,HV2	STATION NOT AFFECTED BIJAPUR_220	12:19 (24.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
692	24-Sep-2021	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	AMBEWADI_220	14:50	15:42	0:52	LINE FAULT
693	24-Sep-2021	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:22 (20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
694	24-Sep-2021	BAGALKOT	220	HUBIL- SIRSI2	HUBLI_220	11:16	14:00	2:44	LINE CLEAR AVAILED
695	24-Sep-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	5:07 (23.09.2021)	13:59 (24.09.2021)	8:52 hrs	LINE CHARGED
696	24-Sep-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	12:55 (19.09.2021)			LINE OPEN, LINE FAULT
697	24-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
698	24-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
699	24-Sep-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	11:03 (23.09.201)	16:06 (24.09.2021)	5:03 hrs	LINE CHARGED
700	24-Sep-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	5:07 (23.09.2021)	16:09 (24.09.2021)	11:02 hrs	LINE CHARGED
701	24-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:06 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
702	24-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:07 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
703	24-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
704	24-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
705	24-Sep-2021	BAGALKOT	400	DHONI-GUTTUR	DHONI_400	13:33	18:43	5:10	LINE FAULT
706	24-Sep-2021	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	03:40:00(24/09/2021)			LINE OPEN, LINE FAULT
707	24-Sep-2021	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI	5:54	6:03	0:09	LOAD CHANGE OVER
708	24-Sep-2021	BENGALURU	66	BYDRAHALLI - T G HALLI	KODIGEHALLI	19:48(24/09/2021)			LINE OPEN, LINE FAULT
709	24-Sep-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	14:29	14:44	0:14	LINE CLEAR AVAILED
710	24-Sep-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	11:37	11:43	0:06	MAIN SUPPLY FAILURE
711	24-Sep-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	14:30	14:44	0:14	LINE CLEAR AVAILED
712	24-Sep-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	11:37	11:43	0:06	MAIN SUPPLY FAILURE
713	24-Sep-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	14:30	14:44	0:14	LINE CLEAR AVAILED
714	24-Sep-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	11:37	11:43	0:06	MAIN SUPPLY FAILURE
715	24-Sep-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	14:30	14:44	0:14	LINE CLEAR AVAILED
716	24-Sep-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:37	11:43	0:06	MAIN SUPPLY FAILURE
717	24-Sep-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	14:29	14:44	0:14	LINE CLEAR AVAILED
718	24-Sep-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:37	11:43	0:06	MAIN SUPPLY FAILURE
719	24-Sep-2021	BENGALURU	66	GURUVINAPURA - T K HALLI 220	GURUVINAPURA, B V HALLI	10:45	11:05	0:20	MAIN SUPPLY FAILURE
720	24-Sep-2021	BENGALURU	66	GURUVINAPURA - T K HALLI 220	GURUVINAPURA, B V HALLI	15:44	15:49	0:05	MAIN SUPPLY FAILURE
721	24-Sep-2021	BENGALURU	66	HOODY 220 - HOSKOTE 66	NO STATION AFFECTED	7:46	8:57	1:11	LINE FAULT
722	24-Sep-2021	BENGALURU	66	HV1	MELUR	20:17	20:30	0:12	TRANSFORMER FAULT
723	24-Sep-2021	BENGALURU	66	HV1	KIADB HARDWARE PARK DEVANAHALLI 220	12:42	13:49	1:07	TRANSFORMER FAULT
724	24-Sep-2021	BENGALURU	66	HV1	HAROBEL	12:00	13:00	1:00	LINE CLEAR AVAILED
725	24-Sep-2021	BENGALURU	66	HV1	GOWRIBIDANUR 220	16:00	16:12	0:12	TRANSFORMER FAULT
726	24-Sep-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	11:25	11:43	0:18	TRANSFORMER FAULT
727	24-Sep-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	18:56	19:13	0:17	TRANSFORMER FAULT
728	24-Sep-2021	BENGALURU	66	HV2	MALLASANDRA	12:08	12:40	0:31	LINE CLEAR AVAILED
729	24-Sep-2021	BENGALURU	66	HV2	KANAKAPURA 66	14:25	14:32	0:07	TRANSFORMER FAULT
730	24-Sep-2021	BENGALURU	66	HV2	KANAKAPURA 66	18:09	18:20	0:11	TRANSFORMER FAULT
731	24-Sep-2021	BENGALURU	66	HV2	SOMAYAJANAHALLI	15:30	15:33	0:03	TRANSFORMER FAULT
732	24-Sep-2021	BENGALURU	66	IRGAMPALLI - CHINTAMANI 220	IRGAMPALLI	5:35	5:40	0:05	LINE FAULT
733	24-Sep-2021	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	NO STATION AFFECTED	5:35	5:50	0:15	LINE FAULT
734	24-Sep-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	18:54	19:24	0:30	LOAD CURTAILMENT
735	24-Sep-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	8:37	8:58	0:21	LINE FAULT
736	24-Sep-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	18:54	19:20	0:26	LOAD CURTAILMENT
737	24-Sep-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	19:20	19:55	0:35	LOAD CURTAILMENT
738	24-Sep-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	6:03	6:13	0:10	LINE FAULT
739	24-Sep-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	NO STATION AFFECTED	10:59	14:15	3:16	LINE CLEAR AVAILED
740	24-Sep-2021	BENGALURU	66	SOBHA FOREST - SOMANAHALLI 220	SOBHA FOREST	11:00	14:50	3:50	LINE CLEAR AVAILED
741	24-Sep-2021	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66, ISKON	14:38	14:46	0:08	LINE CLEAR AVAILED
742	24-Sep-2021	BENGALURU	66	SOMAYAJANAHALLI - LAKSHMIPURA	SOMAYAJANAHALLI	15:27	15:35	0:08	LINE FAULT
743	24-Sep-2021	BENGALURU	220	BEGUR 220 - HOODY 220	NO STATION AFFECTED	10:19	12:02	1:43	LINE FAULT
744	24-Sep-2021	BENGALURU	220	HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	10:19	12:02	1:43	LINE FAULT
745	24-Sep-2021	BENGALURU	220	HV1	DB PURA 220	11:30	14:30	3:00	LINE CLEAR AVAILED
746	24-Sep-2021	BENGALURU	220	LV1	GOWRIBIDANUR 220	8:20	12:25	4:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
747	24-Sep-2021	GULBARGA	66	KOTTUR-SUZLON-1	KOTTUR_66	6:40	6:49	0:09	LINE FAULT
748	24-Sep-2021	GULBARGA	66	KOTTUR-SUZLON-1	KOTTUR_66	6:40	6:50	0:10	LINE FAULT
749	24-Sep-2021	GULBARGA	110	ALIPUR-NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_I PP,BASAI STEELS ACC	4:59	5:05	0:06	LINE FAULT
750	24-Sep-2021	GULBARGA	110	GULBARGA WEST-KAPNOOR	GULBARGA WEST_110	9:35	18:20	8:45	NFBC ISSUED
751	24-Sep-2021	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	13:38	13:45	0:07	LINE FAULT
752	24-Sep-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_1 10,DIGGI_110	23:18	23:23	0:05	LINE FAULT
753	24-Sep-2021	GULBARGA	110	HV1	RAJESHWAR_110	17:24	17:30	0:06	LOAD CURTAILMENT
754	24-Sep-2021	GULBARGA	110	HV1	CHIKSUGUR_110	13:18	14:20	1:02	TRANSFORMER FAULT
755	24-Sep-2021	GULBARGA	110	HV1	CHIKSUGUR_110	14:20	15:24	1:04	LINE CLEAR AVAILED
756	24-Sep-2021	GULBARGA	110	HV1	GABBUR_110	17:25	17:35	0:10	LOAD CURTAILMENT
757	24-Sep-2021	GULBARGA	110	HV1	GULBARGA UNIVERSITY_110	19:20	19:30	0:10	TRANSFORMER FAULT
758	24-Sep-2021	GULBARGA	110	HV2	BISIHALLI_110	10:10	11:05	0:55	LINE CLEAR AVAILED
759	24-Sep-2021	GULBARGA	110	HV2	BISIHALLI_110	14:49	15:10	0:21	TRANSFORMER FAULT
760	24-Sep-2021	GULBARGA	110	HV2	JEEWARGI_110	12:35	17:00	4:25	NFBC ISSUED
761	24-Sep-2021	GULBARGA	110	HV2	KOLHAR_110	16:10	17:00	0:50	LINE CLEAR AVAILED
762	24-Sep-2021	GULBARGA	110	HV2	KOLHAR_110	15:50	17:00	1:10	LINE CLEAR AVAILED
763	24-Sep-2021	GULBARGA	110	HV3	YELBURGA_110	17:24	17:47	0:23	LOAD CURTAILMENT
764	24-Sep-2021	GULBARGA	110	HV3	CHIKSUGUR_110	0:14	1:02	0:48	TRANSFORMER FAULT
765	24-Sep-2021	GULBARGA	110	HV3	CHIKSUGUR_110	1:02	2:50	1:48	LINE CLEAR AVAILED
766	24-Sep-2021	GULBARGA	110	HV4	YELBURGA_110	17:25	17:42	0:17	LOAD CURTAILMENT
767	24-Sep-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	5:53	5:58	0:05	LINE FAULT
768	24-Sep-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	20:17	20:25	0:08	LINE FAULT
769	24-Sep-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,N SL SUGARS FACTORY	3:15	3:20	0:05	LINE FAULT
770	24-Sep-2021	GULBARGA	110	LV1	SHAHAPUR_220	11:29	12:07	0:38	LINE CLEAR AVAILED
771	24-Sep-2021	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	0:52	0:59	0:07	LINE FAULT
772	24-Sep-2021	GULBARGA	110	NAVALI-CLEANMAX_IPP	NAVALI_110	17:25	18:30	1:05	LINE CLEAR AVAILED
773	24-Sep-2021	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	5:00	5:06	0:06	MAIN SUPPLY FAILURE
774	24-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GABBUR_110,DEODURGA_110,GO OGLE_110,BP SOLAR IPP	20:25	20:30	0:05	LINE FAULT
775	24-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GABBUR_110,DEODURGA_110,GO OGLE_110,BP SOLAR IPP	4:08	4:15	0:07	LINE FAULT
776	24-Sep-2021	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	6:30	6:33	0:03	LINE FAULT
777	24-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
778	24-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
779	24-Sep-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	20:08	20:13	0:05	LINE FAULT
780	24-Sep-2021	GULBARGA	110	SHAHABAD-RAICHUR1&2	JEWARGI_110,NALWAR_110	10:08	10:40	0:32	LINE CLEAR AVAILED
781	24-Sep-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	19:40	19:55	0:15	LINE FAULT
782	24-Sep-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1&2	SHAHAPUR_110	20:40	21:08	0:28	LINE FAULT
783	24-Sep-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	14:19	14:25	0:06	LINE CLEAR AVAILED
784	24-Sep-2021	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADAVI AMARESHWAR_110	18:59	19:14	0:15	LINE FAULT
785	24-Sep-2021	GULBARGA	110	TEKKALKOTE-ABMN_SLR	TEKKALKOTE_110	0:05	0:20	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
786	24-Sep-2021	GULBARGA	110	TEKKALKOTE-ABMN_SLR	TEKKALKOTE_110	19:38	23:26	3:48	LINE CLEAR AVAILED
787	24-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
788	24-Sep-2021	GULBARGA	220	HV2	SHAHAPUR_220	11:58	14:32	2:34	LINE CLEAR AVAILED
789	24-Sep-2021	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	11:07	13:25	2:18	LINE CLEAR AVAILED
790	24-Sep-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:16	10:51	0:35	LINE FAULT
791	24-Sep-2021	HASSAN	66	HV1	HIRISAVE_66	11:13	13:31	2:18	NFBC ISSUED
792	24-Sep-2021	HASSAN	66	HV1	MAGGE_66	7:10	7:43	0:33	MAIN SUPPLY FAILURE
793	24-Sep-2021	HASSAN	66	HV1	SHRAVANABELAGOLA_66	18:27	18:39	0:12	LOAD CURTAILMENT
794	24-Sep-2021	HASSAN	66	HV2	HIRISAVE_66	11:13	13:28	2:15	NFBC ISSUED
795	24-Sep-2021	HASSAN	66	HV2	MAGGE_66	7:10	7:43	0:33	MAIN SUPPLY FAILURE
796	24-Sep-2021	HASSAN	66	HV2	RAMPURA_66	11:32	14:59	3:27	LINE CLEAR AVAILED
797	24-Sep-2021	HASSAN	66	HV2	RAMESHWARNAGARA_66	18:27	18:44	0:17	LOAD CURTAILMENT
798	24-Sep-2021	HASSAN	66	HV2	SALAGAME_66	18:27	18:45	0:18	LOAD CURTAILMENT
799	24-Sep-2021	HASSAN	66	HV2	BASAVAGHATTA_66	18:40	18:52	0:12	LOAD CURTAILMENT
800	24-Sep-2021	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	7:08	8:39	1:31	LINE FAULT
801	24-Sep-2021	HASSAN	66	MRSSHM-DVG2	MRS MG_220	18:40	18:48	0:08	LINE FAULT
802	24-Sep-2021	HASSAN	66	MRSSHM-HOLUR	MRS MG_220	11:14	11:38	0:24	LINE FAULT
803	24-Sep-2021	HASSAN	66	SAKALE-HASSAN1	SAKL SH PURA_66	7:08	8:38	1:30	LINE FAULT
804	24-Sep-2021	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:28	12:31	2:03	NFBC ISSUED
805	24-Sep-2021	HASSAN	110	HV1	HALADY_110	17:25	17:57	0:32	LOAD CURTAILMENT
806	24-Sep-2021	HASSAN	110	HV1	HALADY_110	18:41	19:14	0:33	LOAD CURTAILMENT
807	24-Sep-2021	HASSAN	110	HV1	KADUR_220	10:50	12:00	1:10	LINE CLEAR AVAILED
808	24-Sep-2021	HASSAN	110	HV1	KONDENALU_110	18:27	18:40	0:13	LOAD CURTAILMENT
809	24-Sep-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
810	24-Sep-2021	HASSAN	110	HV5	MRS MG_220	9:41	14:33	4:52	LINE CLEAR AVAILED
811	24-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)	10:35 (21.08.2021)	22:02 hrs	LINE CHARGED
812	24-Sep-2021	HASSAN	220	MRSSHM-ANTRSNH	MRS MG_220	8:50	12:14	3:24	LINE CLEAR AVAILED
813	24-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRS MG_220	17:08 (30.08.2021)	16:08 (4.09.2021)	23:00 hrs	LINE CHARGED
814	24-Sep-2021	HASSAN	220	MRSSHM-KBCRS	MRS MG_220	8:32 (24.09.2021)			LINE OPEN, LINE CLEAR AVAILED
815	24-Sep-2021	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	10:08 (22.09.2021)	19:06 (23.09.2021)	33:05 hrs	LINE CHARGED
816	24-Sep-2021	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	9:34	13:32	3:58	LINE CLEAR AVAILED
817	24-Sep-2021	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	9:34	13:32	3:58	LINE CLEAR AVAILED
818	24-Sep-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN, LINE FAULT
819	24-Sep-2021	MYSURU	66	DATAGALLI-HOOTAGALLI	DATAGALLI_66	19:53	20:24	0:30	LINE FAULT
820	24-Sep-2021	MYSURU	66	DATAGALLI-RK NAGARA	RK NAGARA_66	19:53	20:43	0:50	LINE FAULT
821	24-Sep-2021	MYSURU	66	HANNUR-KOTTANUR	NO STATIONS EFFECTED	6:38	6:48	0:10	LINE FAULT
822	24-Sep-2021	MYSURU	66	HV1	BG NAGARA_66	18:40	18:43	0:02	LOAD CURTAILMENT
823	24-Sep-2021	MYSURU	66	HV1	BILIKERE_66	8:42	10:59	2:16	LINE CLEAR AVAILED
824	24-Sep-2021	MYSURU	66	HV1	KHB STATION_66	10:46	14:03	3:16	LINE CLEAR AVAILED
825	24-Sep-2021	MYSURU	66	HV1	PANDAVAPURA_66	18:27	18:35	0:08	LOAD CURTAILMENT
826	24-Sep-2021	MYSURU	66	HV1	SANTHESARGUR_66	16:47 (23.09.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
827	24-Sep-2021	MYSURU	66	HV2	ADDIHALI_66	18:40	18:46	0:05	LOAD CURTAILMENT
828	24-Sep-2021	MYSURU	66	HV2	AKKIHEBBAL_66	18:26	18:34	0:07	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
829	24-Sep-2021	MYSURU	66	HV2	AKKIHEBBAL_66	18:40	18:56	0:15	LOAD CURTAILMENT
830	24-Sep-2021	MYSURU	66	HV2	BOOKANAKERE_66	18:40	18:47	0:07	LOAD CURTAILMENT
831	24-Sep-2021	MYSURU	66	HV2	JAKKANAHALLI_66	12:15	12:35	0:20	LINE CLEAR AVAILED
832	24-Sep-2021	MYSURU	66	HV2	KIRUGAVALU_66	18:27	18:57	0:30	LOAD CURTAILMENT
833	24-Sep-2021	MYSURU	66	HV2	KOLLEGALA_66	15:07	16:44	1:36	LINE CLEAR AVAILED
834	24-Sep-2021	MYSURU	66	HV2	MALAVALLI_66	18:27	18:37	0:10	LOAD CURTAILMENT
835	24-Sep-2021	MYSURU	66	KR PETE 220-SANTHEBACHALLI	SANTHEBACHALLI_66 ADDIHALI_66 BG NAGARA_66 AC GIRI_66 VADERALLI_66 HARIYALADAMMA_66	6:17	6:22	0:04	LINE FAULT
836	24-Sep-2021	MYSURU	66	KR PETE 220-SANTHEBACHALLI	SANTHEBACHALLI_66 ADDIHALI_66 BG NAGARA_66 AC GIRI_66 VADERALLI_66 HARIYALADAMMA_66	6:59	7:25	0:26	LINE FAULT
837	24-Sep-2021	MYSURU	66	KR PETE 220-SANTHEBACHALLI	SANTHEBACHALLI_66 ADDIHALI_66 BG NAGARA_66 AC GIRI_66 VADERALLI_66 HARIYALADAMMA_66	21:42	21:47	0:05	LINE FAULT
838	24-Sep-2021	MYSURU	66	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	15:17	15:50	0:33	LINE CLEAR AVAILED
839	24-Sep-2021	MYSURU	66	KUSHALNAGARA-MERCERA-1	NO STATIONS EFFECTED	15:33	15:51	0:18	LINE CLEAR AVAILED
840	24-Sep-2021	MYSURU	66	KUSHALNAGARA-MYSORE-1	MIRLE_66 KR NAGARA_66 BILIKERE_66 GV GUDI_66 DMG HALLI_66	15:17	15:50	0:33	LINE CLEAR AVAILED
841	24-Sep-2021	MYSURU	66	KUSHALNAGARA-MYSORE-2	BETTADAPURA_66 KITTUR_66 RAVANDUR_66 CHUNCHANAKATTE_66	15:17	15:50	0:33	LINE CLEAR AVAILED
842	24-Sep-2021	MYSURU	66	KUSHALNAGARA-PERİYAPATNA-1	NO STATIONS EFFECTED	15:17	15:45	0:28	LINE CLEAR AVAILED
843	24-Sep-2021	MYSURU	66	KUSHALNAGARA- RAMANTHAPURA1	KANGAL_66 ALURSIDDAPURA_66 CB HALLI_66 RUDRAPATNA_66	15:17	15:48	0:31	LINE CLEAR AVAILED
844	24-Sep-2021	MYSURU	66	MYSORE SOUTH -KADAKOLA	MYSORE SOUTH_66	10:00	17:25	7:25	LINE CLEAR AVAILED
845	24-Sep-2021	MYSURU	66	MYSORE SOUTH-GIS	MYSORE SOUTH_66	10:00	17:21	7:21	LINE CLEAR AVAILED
846	24-Sep-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
847	24-Sep-2021	MYSURU	66	RK NAGARA-MANTAGALLI	NO STATIONS EFFECTED	11:30	16:17	4:46	LINE CLEAR AVAILED
848	24-Sep-2021	MYSURU	66	RK NAGARA-MANTAGALLI	NO STATIONS EFFECTED	19:54	20:44	0:50	LINE FAULT
849	24-Sep-2021	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	5:25	5:30	0:05	LINE FAULT
850	24-Sep-2021	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	18:25	18:33	0:08	LINE FAULT
851	24-Sep-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18(23.09.2021)			LINE OPEN,LINE CLEAR AVAILED
852	24-Sep-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
853	24-Sep-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_66,K ADAJJI_66	10:25	15:41	5:15	LINE CLEAR AVAILED
854	24-Sep-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:16	13:17	2:00	LINE CLEAR AVAILED
855	24-Sep-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:37	9:51	0:13	LINE FAULT
856	24-Sep-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:06	11:18	1:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
857	24-Sep-2021	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	10:20	18:18	7:57	LINE CLEAR AVAILED
858	24-Sep-2021	TUMKUR	66	HINDASGHATTA66-HIRIYUR220KV	HINDASGHATTA_66	18:35	18:48	0:13	MAIN SUPPLY FAILURE
859	24-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:45	6:57	0:12	LINE FAULT
860	24-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66, SASALUHALLA_66	20:04	20:18	0:14	LINE FAULT
861	24-Sep-2021	TUMKUR	66	HONNALLI 220kv- KUNDUR66	KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE_66	8:46	8:58	0:12	LINE FAULT
862	24-Sep-2021	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:50	14:23	1:33	LINE FAULT
863	24-Sep-2021	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:08	21:51	5:42	LINE CLEAR AVAILED
864	24-Sep-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	19:34	21:51	2:16	LINE CLEAR AVAILED
865	24-Sep-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	9:13	9:16	0:03	LINE FAULT
866	24-Sep-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	9:30	9:35	0:04	LINE FAULT
867	24-Sep-2021	TUMKUR	66	LV-1	PAVAGADA_220	11:46	11:57	0:10	TRANSFORMER FAULT
868	24-Sep-2021	TUMKUR	66	LV-2	PAVAGADA_220	11:46	11:56	0:10	TRANSFORMER FAULT
869	24-Sep-2021	TUMKUR	66	MADHUGIRI 66kv- BADAVANAHALLI	BADAVANAHALLI_66	10:31	11:49	1:18	LINE CLEAR AVAILED
870	24-Sep-2021	TUMKUR	66	MADHUGIRI 66kv- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	10:31	11:47	1:16	LINE CLEAR AVAILED
871	24-Sep-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI	18:47	19:05	0:18	HAND TRIPPED
872	24-Sep-2021	TUMKUR	66	PAVAGADA 220kv- SHYLAPURA	SHYLAPURA_66	11:46	12:03	0:17	LINE FAULT
873	24-Sep-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	10:34	10:38	0:03	LINE FAULT
874	24-Sep-2021	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	10:38	15:56	5:18	LINE CLEAR AVAILED
875	24-Sep-2021	TUMKUR	66	THOVINAKERE66- SIRA (ANTHRASANAHALLI)	THOVINAKERE_66	10:20	10:33	0:13	LINE FAULT
876	24-Sep-2021	TUMKUR	66	TR-1	BENKIKERE_66	15:45	16:43	0:57	MAIN SUPPLY FAILURE
877	24-Sep-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	10:10	18:32	8:22	LINE CLEAR AVAILED
878	24-Sep-2021	TUMKUR	66	TR-1	MADHUGIRI_66	10:31	11:48	1:17	LINE CLEAR AVAILED
879	24-Sep-2021	TUMKUR	66	TR-1	MADADKERE_66	18:47	19:17	0:29	HAND TRIPPED
880	24-Sep-2021	TUMKUR	66	TR-1	MATHOD_66	18:41	19:05	0:24	TRANSFORMER FAULT
881	24-Sep-2021	TUMKUR	66	TR-1	PAVAGADA_220	18:11	18:14	0:02	HAND TRIPPED
882	24-Sep-2021	TUMKUR	66	TR-1	PAVAGADA_220	18:48	18:50	0:02	HAND TRIPPED
883	24-Sep-2021	TUMKUR	66	TR-1	PAVAGADA_220	23:15	23:17	0:01	HAND TRIPPED
884	24-Sep-2021	TUMKUR	66	TR-1	SOKKE_66	10:38	15:56	5:18	LINE CLEAR AVAILED
885	24-Sep-2021	TUMKUR	66	TR-2	BENKIKERE_66	15:45	16:42	0:56	MAIN SUPPLY FAILURE
886	24-Sep-2021	TUMKUR	66	TR-2	BHARAMGIRI_66	7:08	7:11	0:03	TRANSFORMER FAULT
887	24-Sep-2021	TUMKUR	66	TR-2	BHARAMGIRI_66	16:49	16:50	0:01	MAIN SUPPLY FAILURE
888	24-Sep-2021	TUMKUR	66	TR-2	DEVARAHALLI_66	10:10	18:32	8:22	LINE CLEAR AVAILED
889	24-Sep-2021	TUMKUR	66	TR-2	HONNALLI_66	15:39	18:07	2:28	LINE CLEAR AVAILED
890	24-Sep-2021	TUMKUR	66	TR-2	MADHUGIRI_66	10:31	11:48	1:17	LINE CLEAR AVAILED
891	24-Sep-2021	TUMKUR	66	TR-2	SHYLAPURA_66	18:42	19:09	0:27	TRANSFORMER FAULT
892	24-Sep-2021	TUMKUR	66	TR-3	DEVARAHALLI_66	10:10	18:32	8:22	LINE CLEAR AVAILED
893	24-Sep-2021	TUMKUR	110	TR-1	TURUVEKERE_110	13:42	15:37	1:55	LINE CLEAR AVAILED
894	24-Sep-2021	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	2:05	2:15	0:10	TRANSFORMER FAULT
895	24-Sep-2021	TUMKUR	110	TR-2	TURUVEKERE_110	15:37	15:56	0:19	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
896	24-Sep-2021	TUMKUR	220	TR-1	PAVAGADA_220	11:46	11:57	0:11	TRANSFORMER FAULT
897	24-Sep-2021	TUMKUR	220	TR-2	PAVAGADA_220	11:46	11:57	0:11	TRANSFORMER FAULT
898	25-Sep-2021	BAGALKOT	66	66/11KV, HV1	STATION NOT AFFECTED HARIHAR HOSPET	11:55	12:25	0:30	LINE CLEAR AVAILED
899	25-Sep-2021	BAGALKOT	66	66/11KV, HV2	STATION NOT AFFECTED HARIHAR HOSPET	12:49 (25.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
900	25-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
901	25-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
902	25-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
903	25-Sep-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	3:44	3:57	0:13	TRANSFORMER FAULT
904	25-Sep-2021	BAGALKOT	110	110/11KV, HV1&HV2	NAVANAGAR(B)_110	10:20	18:04	7:44	LINE CLEAR AVAILED
905	25-Sep-2021	BAGALKOT	110	110/11KV, HV4	SADALAGA_110	17:18	18:31	1:13	LINE CLEAR AVAILED
906	25-Sep-2021	BAGALKOT	110	110/11KV,HV1	BABLESHWAR_110	10:01	19:32	9:31	LINE CLEAR AVAILED
907	25-Sep-2021	BAGALKOT	110	110/11KV,HV1	GIRISAGAR_110	12:50	16:10	3:20	LINE CLEAR AVAILED
908	25-Sep-2021	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	21:25	21:30	0:05	TRANSFORMER FAULT
909	25-Sep-2021	BAGALKOT	110	110/11KV,HV1	SHIRAGUPPI_110	7:05	7:55	0:50	LINE CLEAR AVAILED
910	25-Sep-2021	BAGALKOT	110	110/11KV,HV1	SIRSI_220	10:57	14:03	3:06	LINE CLEAR AVAILED
911	25-Sep-2021	BAGALKOT	110	110/11KV,HV1	BAGALKOT_220	9:45	17:31	7:46	LINE CLEAR AVAILED
912	25-Sep-2021	BAGALKOT	110	110/11KV,HV1,HV2	BAGALKOT_110	9:10	18:06	8:56	LINE CLEAR AVAILED
913	25-Sep-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	12:45	12:57	0:12	LINE CLEAR AVAILED
914	25-Sep-2021	BAGALKOT	110	110/11KV,HV2	BAGALKOT_220	9:08	18:23	9:15	LINE CLEAR AVAILED
915	25-Sep-2021	BAGALKOT	110	110/11KV,HV2	GULEDAGUDDA_110	18:06	18:08	0:02	LINE CLEAR AVAILED
916	25-Sep-2021	BAGALKOT	110	110/11KV,HV4	BAILHONGAL_110	11:14	12:12	0:58	LINE CLEAR AVAILED
917	25-Sep-2021	BAGALKOT	110	110/33KV, HV2	SADALAGA_110 BHOJ_33	10:22	19:10	8:48	LINE CLEAR AVAILED
918	25-Sep-2021	BAGALKOT	110	110/33KV,HV3	RIDDI SIDDI_33,KOLAVI SUGAR_33, GOKAK_110	10:22	13:20	2:58	LINE CLEAR AVAILED
919	25-Sep-2021	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	18:02 (25.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
920	25-Sep-2021	BAGALKOT	110	220/110KV,LV2	BIJAPUR_220	16:10 (23.09.2021)	13:16 (25.09.2021)	21:06 hrs	TRANSFORMER CHARGED
921	25-Sep-2021	BAGALKOT	110	BAGALKOT220-BAGALKOT(RAMPUR)	BAGALKOT_110	9:10	18:06	8:56	LINE CLEAR AVAILED
922	25-Sep-2021	BAGALKOT	110	BAGALKOT-BAGALKOT2	BAGALKOT_110	9:10	18:00	8:50	LINE CLEAR AVAILED
923	25-Sep-2021	BAGALKOT	110	BAGALKOT-GULEDAGUDDA	GULEDAGUDDA_110	9:10	18:01	8:51	LINE CLEAR AVAILED
924	25-Sep-2021	BAGALKOT	110	BAGALKOT-KALADAGI	KALADAGI_110	9:10	18:20	9:10	LINE CLEAR AVAILED
925	25-Sep-2021	BAGALKOT	110	BAGALKOT-KERUR	STATION NOT AFFECTED KERUR_110	9:10	18:15	9:05	LINE CLEAR AVAILED
926	25-Sep-2021	BAGALKOT	110	BAGALKOT-LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	9:43	18:17	8:34	LINE CLEAR AVAILED
927	25-Sep-2021	BAGALKOT	110	BAGALKOT-NAVANAGAR1&2	NAVANAGAR_110	9:10	17:59	8:49	LINE CLEAR AVAILED
928	25-Sep-2021	BAGALKOT	110	BAGALKOT-NEER BIDIHAL(KATARAKI)	NEER BUDIHAL_110	9:10	18:16	9:06	LINE CLEAR AVAILED
929	25-Sep-2021	BAGALKOT	110	BAGALKOT-RAMDURGA	RAMDURGA_110	9:10	18:40	9:30	LINE CLEAR AVAILED
930	25-Sep-2021	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
931	25-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
932	25-Sep-2021	BAGALKOT	110	HAVERI-TILUVALI(HANAGAL)	HAVERI_220	6:06	18:22	12:16	LINE FAULT
933	25-Sep-2021	BAGALKOT	110	HUKKERI-HATARGI	STATION NOT AFFECTED HUKKERI_110	15:10 (25.09.2021)			LINE OPEN,LINE CLEAR AVAILED
934	25-Sep-2021	BAGALKOT	110	ITNAL-SULTANPUR(HIDKAL)	STATION NOT AFFECTED ITANAL_110	11:32 (25.09.2021)			LINE OPEN,LINE CLEAR AVAILED
935	25-Sep-2021	BAGALKOT	110	KERUR-BADAMI	STATION NOT EFFECTED KERUR_110	9:12	18:19	9:07	LINE CLEAR AVAILED
936	25-Sep-2021	BAGALKOT	110	KERUR-BAGALKOT220	STATION NOT EFFECTED KERUR_110	9:12	18:18	9:06	LINE CLEAR AVAILED
937	25-Sep-2021	BAGALKOT	110	LOKAPUR-BAGALKOT220	STATION NOT AFFECTED LOKAPUR_110	9:50	18:39	8:49	LINE CLEAR AVAILED
938	25-Sep-2021	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	12:06	12:59	0:53	LINE CLEAR AVAILED
939	25-Sep-2021	BAGALKOT	110	NAVANAGAR(B)-BAGALKOT220-1&2	NAVANAGAR(B)_110	10:20	18:04	7:44	LINE CLEAR AVAILED
940	25-Sep-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
941	25-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
942	25-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
943	25-Sep-2021	BAGALKOT	110	SLAHALLI-GMNAVAR WIND IPP	GMNAVAR WIND IPP_110 SALAHALLI_110	10:07	18:51	8:44	LINE CLEAR AVAILED
944	25-Sep-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)			LINE OPEN,LINE CLEAR AVAILED
945	25-Sep-2021	BAGALKOT	220	220/110KV,HV1,LV1	BAGALKOT_220	9:45	17:29	7:44	LINE CLEAR AVAILED
946	25-Sep-2021	BAGALKOT	220	220/110KV,HV2	STATION NOT AFFECTED BIJAPUR_220	12:19 (24.09.2021)	13:08 (25.09.2021)	0:49 hrs	TRANSFORMER CHARGED
947	25-Sep-2021	BAGALKOT	220	220/110KV,HV2,LV2	BAGALKOT_220	9:45	17:29	7:44	LINE CLEAR AVAILED
948	25-Sep-2021	BAGALKOT	220	220/110KV,HV3,LV3	BAGALKOT_220	9:46	17:29	7:43	LINE CLEAR AVAILED
949	25-Sep-2021	BAGALKOT	220	AMBEWADI-NAGJHARI2	AMBEWADI_220	22:41 (25.09.2021)			LINE OPEN, LINE FAULT
950	25-Sep-2021	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	AMBEWADI_220	9:30	16:29	6:59	LINE CLEAR AVAILED
951	25-Sep-2021	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	9:27	16:36	7:09	LINE CLEAR AVAILED
952	25-Sep-2021	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:22 (20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
953	25-Sep-2021	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	12:38	16:11	3:33	LINE FAULT
954	25-Sep-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	12:55 (19.09.2021)			LINE OPEN, LINE FAULT
955	25-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
956	25-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
957	25-Sep-2021	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	12:38	16:11	3:33	LINE FAULT
958	25-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:06 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
959	25-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:07 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
960	25-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
961	25-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
962	25-Sep-2021	BENGALURU	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	03:40:00(24/09/2021)	18:06(25/09/2021)	38:26HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
963	25-Sep-2021	BENGALURU	66	A STATION1 66 - A STATION 220	A STATION1 66	11:26	11:38	0:12	LINE CLEAR AVAILED
964	25-Sep-2021	BENGALURU	66	A STATION2 66 - A STATION 220	A STATION2 66	11:26	11:42	0:16	LINE CLEAR AVAILED
965	25-Sep-2021	BENGALURU	66	A STATION2 66 - NRS 220	A STATION2 66	20:56	21:02	0:06	LINE CLEAR AVAILED
966	25-Sep-2021	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	11:54	12:29	0:35	LINE CLEAR AVAILED
967	25-Sep-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	11:54	12:30	0:36	LINE CLEAR AVAILED
968	25-Sep-2021	BENGALURU	66	BYDRAHALLI - T G HALLI	KODIGEHALI	19:48(24/09/2021)	04:50:00(25/09/2021)	9:02 hrs	LINE CHARGED
969	25-Sep-2021	BENGALURU	66	BYDRAHALLI - T G HALLI	KODIGEHALI	20:44(25/09/2021)			LINE OPEN, LINE FAULT
970	25-Sep-2021	BENGALURU	66	CHANDRAPPA CIRCLE - VRISHABHAVATHI 220	CHANDRAPPA CIRCLE	10:00	17:00	7:00	LINE CLEAR AVAILED
971	25-Sep-2021	BENGALURU	66	ELECTRONIC CITY - INFOSYS(EHT)	INFOSYS(EHT)	10:39	16:24	5:45	LINE CLEAR AVAILED
972	25-Sep-2021	BENGALURU	66	HV1	BIDADI 220	11:54	12:07	0:13	LINE CLEAR AVAILED
973	25-Sep-2021	BENGALURU	66	HV1	VIJAYANAGARA	11:15	11:21	0:06	LOAD CHANGE OVER
974	25-Sep-2021	BENGALURU	66	HV1	MELUR	17:47	18:22	0:35	TRANSFORMER FAULT
975	25-Sep-2021	BENGALURU	66	HV1	MELUR	18:22	18:25	0:02	TRANSFORMER FAULT
976	25-Sep-2021	BENGALURU	66	HV1	MELUR	18:52	19:24	0:32	TRANSFORMER FAULT
977	25-Sep-2021	BENGALURU	66	HV1	MELUR	19:31	19:45	0:13	TRANSFORMER FAULT
978	25-Sep-2021	BENGALURU	66	HV1	DIBURALLI	13:10	13:30	0:20	TRANSFORMER FAULT
979	25-Sep-2021	BENGALURU	66	HV2	BIDADI 220	11:54	12:07	0:13	LINE CLEAR AVAILED
980	25-Sep-2021	BENGALURU	66	HV2	KADUBISANAHALLI	17:50	17:58	0:08	TRANSFORMER FAULT
981	25-Sep-2021	BENGALURU	66	HV2	DODDAKARI	6:53	7:00	0:07	LINE CLEAR AVAILED
982	25-Sep-2021	BENGALURU	66	HV2	SARJAPURA 220	10:45	10:51	0:06	MAIN SUPPLY FAILURE
983	25-Sep-2021	BENGALURU	66	HV2	SARJAPURA 220	12:20	12:25	0:05	MAIN SUPPLY FAILURE
984	25-Sep-2021	BENGALURU	66	HV3	BIDADI 220	11:54	12:07	0:13	LINE CLEAR AVAILED
985	25-Sep-2021	BENGALURU	66	KODIGEHALI - BYDRAHALLI	KODIGEHALI	12:07	12:15	0:08	LINE FAULT
986	25-Sep-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:03	14:24	1:21	LINE FAULT
987	25-Sep-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	16:11	16:30	0:19	LINE CLEAR AVAILED
988	25-Sep-2021	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	16:57(25/09/2021)			LINE OPEN, LINE FAULT
989	25-Sep-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	NO STATION AFFECTED	10:51	12:16	1:25	MAIN SUPPLY FAILURE
990	25-Sep-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:47	10:50	0:03	LINE CLEAR AVAILED
991	25-Sep-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:18	12:20	0:02	LINE CLEAR AVAILED
992	25-Sep-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	8:45	9:31	0:46	LINE CLEAR AVAILED
993	25-Sep-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	8:08	8:59	0:51	LINE FAULT
994	25-Sep-2021	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	9:54	9:58	0:04	LOAD CHANGE OVER
995	25-Sep-2021	BENGALURU	66	VICTORIA - NRS 220	VICTORIA	12:17	12:26	0:09	LINE FAULT
996	25-Sep-2021	BENGALURU	66	WELCASTE STEEL - ABBIGERE	WELCASTE STEEL	10:30	13:47	3:17	LINE CLEAR AVAILED
997	25-Sep-2021	BENGALURU	66	WELCASTE STEEL - SRS PEENYA 220	NO STATION AFFECTED	10:30	13:16	2:46	LINE CLEAR AVAILED
998	25-Sep-2021	BENGALURU	220	A STATION 220 - EAST DIVISION COMPOUND	A STATION 220	9:50	22:00	12:10	LINE CLEAR AVAILED
999	25-Sep-2021	BENGALURU	220	HV1	SARJAPURA 220	10:51	12:15	1:24	LINE CLEAR AVAILED
1000	25-Sep-2021	BENGALURU	220	HV2	BIDADI 220	11:54	12:07	0:13	TRANSFORMER FAULT
1001	25-Sep-2021	BENGALURU	220	LV1	GOWRIBIDANUR 220	9:05	9:45	0:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1002	25-Sep-2021	BENGALURU	220	LV2	GOWRIBIDANUR 220	9:55	10:15	0:20	LINE CLEAR AVAILED
1003	25-Sep-2021	GULBARGA	66	HV1	BACHIGODANHALLI_66	4:35	4:40	0:05	TRANSFORMER FAULT
1004	25-Sep-2021	GULBARGA	66	ITTAGI-HIREHADAGALI1&2	HIREHADAGALI_66,GIRIYAPURA_66, MAGALA_66,SOVENHALLI_66,THUN GABHADRA IPP	13:50	17:35	3:45	LINE CLEAR AVAILED
1005	25-Sep-2021	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH 110	11:08	18:29	7:21	LINE CLEAR AVAILED
1006	25-Sep-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IP P,BHALKI SUGAR IPP	5:28	5:36	0:08	LINE FAULT
1007	25-Sep-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	7:28	7:37	0:09	LINE FAULT
1008	25-Sep-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	10:11	16:18	6:07	LINE CLEAR AVAILED
1009	25-Sep-2021	GULBARGA	110	HALBARGA-HUMNABAD2	HUMNABAD_220	10:18	16:18	6:00	LINE CLEAR AVAILED
1010	25-Sep-2021	GULBARGA	110	HALBARGA-HUMNABAD2	HUMNABAD_220	10:18	16:18	6:00	LINE CLEAR AVAILED
1011	25-Sep-2021	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	8:55	15:51	6:56	NFBC ISSUED
1012	25-Sep-2021	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	10:16	15:58	5:42	NFBC ISSUED
1013	25-Sep-2021	GULBARGA	110	HV1	GULBARGA UNIVERSITY_110	8:35	8:45	0:10	TRANSFORMER FAULT
1014	25-Sep-2021	GULBARGA	110	HV1,HV2	ALIPUR_220	10:06	18:03	7:57	LINE CLEAR AVAILED
1015	25-Sep-2021	GULBARGA	110	HV2	ALIPUR_220	18:22	18:52	0:30	TRANSFORMER FAULT
1016	25-Sep-2021	GULBARGA	110	HV2	ALIPUR_220	18:20	19:10	0:50	TRANSFORMER FAULT
1017	25-Sep-2021	GULBARGA	110	HV2	ALIPUR_220	19:11	19:18	0:07	TRANSFORMER FAULT
1018	25-Sep-2021	GULBARGA	110	HV2	ALIPUR_220	19:25	19:44	0:19	TRANSFORMER FAULT
1019	25-Sep-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	8:14	8:23	0:09	LINE FAULT
1020	25-Sep-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:21	22:32	0:11	LINE FAULT
1021	25-Sep-2021	GULBARGA	110	NALWAR-CLNSLR	NALWAR_110	12:02	12:19	0:17	LINE FAULT
1022	25-Sep-2021	GULBARGA	110	NALWAR-SHAHBAD	NALWAR_110	4:17	4:25	0:08	LINE FAULT
1023	25-Sep-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	2:12	2:18	0:06	LINE FAULT
1024	25-Sep-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	4:28	4:35	0:07	LINE FAULT
1025	25-Sep-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI 110	1:16	1:21	0:05	LINE FAULT
1026	25-Sep-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI 110	1:16	1:21	0:05	LINE FAULT
1027	25-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1028	25-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
1029	25-Sep-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	4:02	4:24	0:22	LINE FAULT
1030	25-Sep-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:02	12:14	0:12	LINE FAULT
1031	25-Sep-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	4:19	4:42	0:23	LINE FAULT
1032	25-Sep-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1&2	SHAHAPUR_110	12:55	13:28	0:33	LINE CLEAR AVAILED
1033	25-Sep-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110	19:57	20:07	0:10	LINE FAULT
1034	25-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1035	25-Sep-2021	GULBARGA	220	HV2	ITTAGI_220	6:37	6:45	0:08	TRANSFORMER FAULT
1036	25-Sep-2021	GULBARGA	220	HV2,LV2	HALBARGA_220	6:42	6:55	0:13	TRANSFORMER FAULT
1037	25-Sep-2021	GULBARGA	220	LINGAPUR-BMM	LINGAPUR_220	6:34	10:33	3:59	LINE FAULT
1038	25-Sep-2021	GULBARGA	220	LINGASDUGUR-RTPS1	LINGASUGUR_220	1:10	1:42	0:32	LINE FAULT
1039	25-Sep-2021	GULBARGA	220	LINGASDUGUR-RTPS2	LINGASUGUR_220	5:18	6:21	1:03	LINE FAULT
1040	25-Sep-2021	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	19:37	20:00	0:23	LINE FAULT
1041	25-Sep-2021	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	10:41	13:25	2:44	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1042	25-Sep-2021	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	13:25	14:46	1:21	NFBC ISSUED
1043	25-Sep-2021	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	13:20	14:52	1:32	LINE CLEAR AVAILED
1044	25-Sep-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1045	25-Sep-2021	HASSAN	110	HV2	KADUR_220	10:30	11:15	0:45	LINE CLEAR AVAILED
1046	25-Sep-2021	HASSAN	110	HV2	KADUR_220	22:35	23:00	0:25	TRANSFORMER FAULT
1047	25-Sep-2021	HASSAN	110	HV5	MRSMSG_220	11:39	14:44	3:05	LINE CLEAR AVAILED
1048	25-Sep-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	13:22	13:45	0:23	LINE FAULT
1049	25-Sep-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	8:32 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1050	25-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:22	13:45	0:23	LINE FAULT
1051	25-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:25	14:23	0:58	LINE FAULT
1052	25-Sep-2021	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	13:22	13:45	0:23	LINE FAULT
1053	25-Sep-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN, LINE FAULT
1054	25-Sep-2021	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAWADI_66	10:01	17:39	7:37	LINE CLEAR AVAILED
1055	25-Sep-2021	MYSURU	66	CR NAGARA-GUNDLUPETE 2	TERAKANAMBI_66	9:43	17:33	7:49	NFBC ISSUED
1056	25-Sep-2021	MYSURU	66	CR NAGARA-YALANDUR	YALANDUR_66	10:20	16:37	6:17	NFBC ISSUED
1057	25-Sep-2021	MYSURU	66	DK MAIDANA-JYOTHINAGARA	DK MAIDANA_66	10:01	17:35	7:33	NFBC ISSUED
1058	25-Sep-2021	MYSURU	66	DR PETE -KUNTHUR	SANTHEMARALLI_66	10:36	16:14	5:38	NFBC ISSUED
1059	25-Sep-2021	MYSURU	66	FTS-HOOTAGALLI 1	FTS_66	18:51	19:12	0:20	LINE FAULT
1060	25-Sep-2021	MYSURU	66	FTS-HOOTAGALLI 2	FTS_66	18:51	19:12	0:20	LINE FAULT
1061	25-Sep-2021	MYSURU	66	HANNUR-AJJIPURA	BANDAHALLI_66 AJJIPURA_66 COWDALLI_66 RAMPURA_66 MARTALLI_66	5:17	5:27	0:09	LINE FAULT
1062	25-Sep-2021	MYSURU	66	HV1	KIADB MANDYA_66	8:08	17:35	9:27	LINE CLEAR AVAILED
1063	25-Sep-2021	MYSURU	66	HV1	KALAMANDIR_66	10:20	16:15	5:55	LINE CLEAR AVAILED
1064	25-Sep-2021	MYSURU	66	HV1	MADDUR_66	14:05	14:19	0:13	HAND TRIPPED
1065	25-Sep-2021	MYSURU	66	HV1	NAGAMANGALA_66	12:08	16:50	4:41	TRANSFORMER FAULT
1066	25-Sep-2021	MYSURU	66	HV1	NAGAMANGALA_66	18:10	21:35	3:24	LINE CLEAR AVAILED
1067	25-Sep-2021	MYSURU	66	HV1	VAJMANGALA_66	10:23	16:27	6:03	LINE CLEAR AVAILED
1068	25-Sep-2021	MYSURU	66	HV1	SANTHESARGUR_66	16:47 (23.09.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1069	25-Sep-2021	MYSURU	66	HV2	BILIKERE_66	12:01	12:08	0:06	TRANSFORMER FAULT
1070	25-Sep-2021	MYSURU	66	HV2	KIADB MANDYA_66	8:08	16:38	8:30	LINE CLEAR AVAILED
1071	25-Sep-2021	MYSURU	66	HV2	KALAMANDIR_66	10:20	16:15	5:55	LINE CLEAR AVAILED
1072	25-Sep-2021	MYSURU	66	HV2	NAGAMANGALA_66	16:15	16:20	0:05	TRANSFORMER FAULT
1073	25-Sep-2021	MYSURU	66	HV2	VAJMANGALA_66	10:10	16:52	6:42	LINE CLEAR AVAILED
1074	25-Sep-2021	MYSURU	66	KADAKOLA-DK MAIDANA	DK MAIDANA_66	10:06	18:51	8:44	LINE CLEAR AVAILED
1075	25-Sep-2021	MYSURU	66	KM DODDI-MANDYA	KIADB MANDYA_66 TUMBEKERE_66 MADDUR_66 K HONNALAGERE_6 SOMANAHALLI_66	8:08	10:19	2:11	LINE FAULT
1076	25-Sep-2021	MYSURU	66	KM DODDI-SCSL	NO STATIONS EFFECTED	8:08	8:51	0:43	LINE FAULT
1077	25-Sep-2021	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	10:05	17:46	7:41	NFBC ISSUED
1078	25-Sep-2021	MYSURU	66	MADHUVANAHALLI-KOLLEGALA 1	NO STATIONS EFFECTED	16:34	16:38	0:03	LINE FAULT
1079	25-Sep-2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	KUNTHUR STATION INTERRUPTED.	10:46	13:45	2:58	LINE CLEAR AVAILED
1080	25-Sep-2021	MYSURU	66	MUGUR-KUNTHUR	NO STATIONS EFFECTED	10:20	16:18	5:57	NFBC ISSUED
1081	25-Sep-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1082	25-Sep-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18(23.09.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1083	25-Sep-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1084	25-Sep-2021	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	6:30	6:45	0:15	LINE FAULT
1085	25-Sep-2021	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	9:20	9:32	0:11	LINE FAULT
1086	25-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:33	10:49	0:16	LINE FAULT
1087	25-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:47	17:56	0:09	LINE FAULT
1088	25-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	20:39	20:55	0:15	LINE FAULT
1089	25-Sep-2021	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	5:57	6:06	0:09	LINE FAULT
1090	25-Sep-2021	TUMKUR	66	TR-3	HARIYABBE_66	8:51	8:58	0:06	TRANSFORMER FAULT
1091	25-Sep-2021	TUMKUR	66	TR-3	HARIYABBE_66	13:43	13:54	0:11	TRANSFORMER FAULT
1092	26-Sep-2021	BAGALKOT	66	66/11KV, HV2	STATION NOT AFFECTED HARIHAR HOSPET	12:49 (25.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1093	26-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1094	26-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1095	26-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVOID
1096	26-Sep-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	1:00	1:21	0:21	TRANSFORMER FAULT
1097	26-Sep-2021	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	18:02 (25.09.2021)	9:25 (26.09.2021)	15:23 hrs	TRANSFORMER CHARGED
1098	26-Sep-2021	BAGALKOT	110	ACME SOLAR-SANKESHWAR	SANKESHWAR_110	17:25	19:15	1:50	LINE CLEAR AVOID
1099	26-Sep-2021	BAGALKOT	110	ALBAL-SAIPRIYA SOLAR	ALBAL_110	8:08	9:56	1:48	LINE CLEAR AVOID
1100	26-Sep-2021	BAGALKOT	110	ALBAL-SAIPRIYA SOLAR	ALBAL_110	15:55	19:19	3:24	LINE CLEAR AVOID
1101	26-Sep-2021	BAGALKOT	110	ALBAL-SAIPRIYA SOLAR	ALBAL_110	19:36	20:50	1:14	HAND TRIPPED
1102	26-Sep-2021	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_220	12:05	18:27	6:22	LINE CLEAR AVOID
1103	26-Sep-2021	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	12:05	18:36	6:31	LINE CLEAR AVOID
1104	26-Sep-2021	BAGALKOT	110	CHIKKODI-WINDMILL	CHIKKODI_110	12:05	18:42	6:37	LINE CLEAR AVOID
1105	26-Sep-2021	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN,LINE CLEAR AVOID
1106	26-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVTKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVOID
1107	26-Sep-2021	BAGALKOT	110	HUKKERI-HATARGI	STATION NOT AFFECTED HUKKERI_110	15:10 (25.09.2021)	7:42 (26.09.2021)	16:32 hrs	LINE CHARGED
1108	26-Sep-2021	BAGALKOT	110	INDI-LACHYAN	LACHAYAN_110,HIREBEVANUR_110 ,ROODAGI_110	9:53	9:58	0:05	LINE FAULT
1109	26-Sep-2021	BAGALKOT	110	INDI-ZALKI2	INDI_220	19:25	19:45	0:20	LINE FAULT
1110	26-Sep-2021	BAGALKOT	110	INDI-ZALKI2	INDI_220	19:50	20:46	0:56	LINE FAULT
1111	26-Sep-2021	BAGALKOT	110	INDI-ZALKI2	INDI_220	21:41	21:55	0:14	LINE FAULT
1112	26-Sep-2021	BAGALKOT	110	ITNAL-SULTANPUR(HIDKAL)	STATION NOT AFFECTED ITANAL_110	11:32 (25.09.2021)			LINE OPEN,LINE CLEAR AVOID
1113	26-Sep-2021	BAGALKOT	110	MALGHAN(B)-BASAVESHAWAR SUGARS	BASAVESHAWAR SUGARS_110 STATION NOT AFFECTED MALAGHAN(B)_110	8:06	18:52	10:46	LINE CLEAR AVOID
1114	26-Sep-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
1115	26-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVOID

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1116	26-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1117	26-Sep-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1118	26-Sep-2021	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_110 STATION NOT AFFECTED TODALBAGI_110	12:24	12:33	0:09	LINE FAULT
1119	26-Sep-2021	BAGALKOT	220	220/110KV,HV,LV	SIRSI_220	11:02	12:42	1:40	LINE CLEAR AVAILED
1120	26-Sep-2021	BAGALKOT	220	220/110KV,HV1	MK HUBLI_220	9:20	10:29	1:09	LINE CLEAR AVAILED
1121	26-Sep-2021	BAGALKOT	220	AMBEWADI-NAGJHARI2	AMBEWADI_220	22:41 (25.09.2021)			LINE OPEN, LINE FAULT
1122	26-Sep-2021	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:22 (20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1123	26-Sep-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	12:55 (19.09.2021)			LINE OPEN, LINE FAULT
1124	26-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
1125	26-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
1126	26-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:06 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1127	26-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:07 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1128	26-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
1129	26-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
1130	26-Sep-2021	BENGALURU	66	BANASHANKARI - SUBRAMANYAPURA 220	BANASHANKARI	16:02	16:08	0:06	LOAD CHANGE OVER
1131	26-Sep-2021	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	10:04	10:11	0:07	LOAD CHANGE OVER
1132	26-Sep-2021	BENGALURU	66	BYDRAHALLI - T G HALLI	KODIGEHALLI	20:44(25/09/2021)	00:57:00(26/09/ 2021)	3:13HRS	LINE CHARGED
1133	26-Sep-2021	BENGALURU	66	HV1	EPIP 220	23:30	23:37	0:07	TRANSFORMER FAULT
1134	26-Sep-2021	BENGALURU	66	HV1	KADUGODI	17:18	17:30	0:12	LINE CLEAR AVAILED
1135	26-Sep-2021	BENGALURU	66	HV1	REMCO	10:23	10:26	0:03	LINE CLEAR AVAILED
1136	26-Sep-2021	BENGALURU	66	HV1	REMCO	16:32	16:35	0:03	LINE CLEAR AVAILED
1137	26-Sep-2021	BENGALURU	66	HV1	VIJAYANAGARA	16:22	16:56	0:34	LOAD CHANGE OVER
1138	26-Sep-2021	BENGALURU	66	HV1	MELUR	11:33	11:58	0:24	TRANSFORMER FAULT
1139	26-Sep-2021	BENGALURU	66	HV1	MELUR	12:47	13:03	0:16	TRANSFORMER FAULT
1140	26-Sep-2021	BENGALURU	66	HV1	JIGANI LINK ROAD	10:40	10:44	0:03	LINE CLEAR AVAILED
1141	26-Sep-2021	BENGALURU	66	HV1	CHINTAMANI 66	17:23	17:42	0:19	TRANSFORMER FAULT
1142	26-Sep-2021	BENGALURU	66	HV1	CHANDAPURA	20:03	20:18	0:14	LINE CLEAR AVAILED
1143	26-Sep-2021	BENGALURU	66	HV2	AUSTIN TOWN	11:10	11:28	0:18	TRANSFORMER FAULT
1144	26-Sep-2021	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	0:21	0:24	0:03	TRANSFORMER FAULT
1145	26-Sep-2021	BENGALURU	66	HV2	VIDHURASHWATHA	10:09	10:15	0:05	LINE CLEAR AVAILED
1146	26-Sep-2021	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	8:14	8:19	0:04	LINE CLEAR AVAILED
1147	26-Sep-2021	BENGALURU	66	HV2	CHANDAPURA	16:34	16:37	0:02	LINE CLEAR AVAILED
1148	26-Sep-2021	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI, BIJJAHALLI	9:50	11:43	1:53	LINE FAULT
1149	26-Sep-2021	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	16:57(25/09/2021)			LINE OPEN, LINE FAULT
1150	26-Sep-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	11:04	11:17	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1151	26-Sep-2021	BENGALURU	66	R R NAGAR - SUBRAMANYAPURA 220	R R NAGAR	16:25	16:28	0:03	LOAD CHANGE OVER
1152	26-Sep-2021	BENGALURU	66	R R NAGAR - VRISHABHAVATHI 220	R R NAGAR	10:35	10:40	0:05	LOAD CHANGE OVER
1153	26-Sep-2021	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	16:43	16:49	0:06	LOAD CHANGE OVER
1154	26-Sep-2021	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	6:30	6:40	0:10	LOAD CHANGE OVER
1155	26-Sep-2021	BENGALURU	66	VICTORIA - NRS 220	VICTORIA	7:06	7:09	0:03	LOAD CHANGE OVER
1156	26-Sep-2021	GULBARGA	66	HOSAHALLI-SML_WND	HOSAHALLI_66	18:40	18:47	0:07	LINE FAULT
1157	26-Sep-2021	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	14:30	16:35	2:05	LINE CLEAR AVAILED
1158	26-Sep-2021	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	20:20	20:45	0:25	LINE CLEAR AVAILED
1159	26-Sep-2021	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	22:55(26.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1160	26-Sep-2021	GULBARGA	110	HATTI-GAMESHA WIND_IPP	HATTI_110	14:40	16:41	2:01	LINE CLEAR AVAILED
1161	26-Sep-2021	GULBARGA	110	HATTI-LINGASUGUR,SOMANAMARDI_IPP	HATTI_110	14:40	16:01	1:21	LINE CLEAR AVAILED
1162	26-Sep-2021	GULBARGA	110	HV1	MUDDAPURA_110	2:00	2:07	0:07	TRANSFORMER FAULT
1163	26-Sep-2021	GULBARGA	110	HV1	HALBARGA_220	15:45	17:05	1:20	LINE CLEAR AVAILED
1164	26-Sep-2021	GULBARGA	110	HV1	ALIPUR_220	9:08	16:47	7:39	LINE CLEAR AVAILED
1165	26-Sep-2021	GULBARGA	110	HV3	VALKAMDINNI_110	9:03	9:08	0:05	TRANSFORMER FAULT
1166	26-Sep-2021	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110,GULBARGA SOUTH_110	9:35	18:19	8:44	NFBC ISSUED
1167	26-Sep-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	7:53	7:57	0:04	LINE FAULT
1168	26-Sep-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	4:30	4:33	0:03	LINE FAULT
1169	26-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1170	26-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
1171	26-Sep-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERD ONA_110,SRNAGAR_110,MALLAPURA_110	10:35	10:45	0:10	LINE FAULT
1172	26-Sep-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERD ONA_110,SRNAGAR_110,MALLAPURA_110	5:08	5:23	0:15	LINE FAULT
1173	26-Sep-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110	5:02	5:20	0:18	LINE FAULT
1174	26-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1175	26-Sep-2021	GULBARGA	220	HV2	SEDAM_220	10:19	10:49	0:30	LINE CLEAR AVAILED
1176	26-Sep-2021	GULBARGA	220	RTPS-SHAHAPUR1	SHAHAPUR_220	21:10	21:29	0:19	LINE FAULT
1177	26-Sep-2021	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_220	3:50	5:28	1:38	LINE FAULT
1178	26-Sep-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:10(26.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1179	26-Sep-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	0:55	6:55	6:00	LINE CLEAR AVAILED
1180	26-Sep-2021	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	22:46	22:54	0:08	LINE FAULT
1181	26-Sep-2021	HASSAN	66	HV1	HNPUA_66	22:47	22:55	0:08	MAIN SUPPLY FAILURE
1182	26-Sep-2021	HASSAN	66	HV2	HNPUA_66	22:47	22:55	0:08	MAIN SUPPLY FAILURE
1183	26-Sep-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	9:45	9:50	0:05	LINE FAULT
1184	26-Sep-2021	HASSAN	110	HV1	NAVUNDA_110	16:44	17:51	1:07	LINE CLEAR AVAILED
1185	26-Sep-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1186	26-Sep-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:33	13:01	0:28	MAIN SUPPLY FAILURE



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1187	26-Sep-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:26	13:00	0:34	MAIN SUPPLY FAILURE
1188	26-Sep-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:26	12:35	0:09	MAIN SUPPLY FAILURE
1189	26-Sep-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:34	12:35	0:01	MAIN SUPPLY FAILURE
1190	26-Sep-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:27	13:01	0:34	MAIN SUPPLY FAILURE
1191	26-Sep-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	8:32 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1192	26-Sep-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	12:32	13:00	0:28	LINE FAULT
1193	26-Sep-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	12:32	13:00	0:28	LINE FAULT
1194	26-Sep-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	9:45	9:58	0:13	LINE FAULT
1195	26-Sep-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN, LINE FAULT
1196	26-Sep-2021	MYSURU	66	BASARALU-HAMPAPURA	NO STATIONS EFFECTED	11:05	18:07	7:01	HAND TRIPPED
1197	26-Sep-2021	MYSURU	66	BOGADHI-GIS	BOGADHI_66	10:42	17:58	7:15	LINE CLEAR AVAILED
1198	26-Sep-2021	MYSURU	66	BOGADHI-HOOTAGALLY	BOGADHI_66	10:42	17:58	7:15	LINE CLEAR AVAILED
1199	26-Sep-2021	MYSURU	66	CR NAGARA-DR PET-1	DR PETE_66	9:14	17:28	8:14	NFBC ISSUED
1200	26-Sep-2021	MYSURU	66	CR NAGARA-DRPET-2	DR PETE_66	9:15	17:29	8:14	NFBC ISSUED
1201	26-Sep-2021	MYSURU	66	CR NAGARA-GUNDLUPETE 2	TERAKANAMBI_66	17:40	18:32	0:51	HAND TRIPPED
1202	26-Sep-2021	MYSURU	66	DATAGALLI-HOOTAGALLY	DATAGALLI_66	10:12	15:49	5:37	NFBC ISSUED
1203	26-Sep-2021	MYSURU	66	DATAGALLI-RK NAGARA	NO STATIONS EFFECTED	9:40	15:53	6:12	HAND TRIPPED
1204	26-Sep-2021	MYSURU	66	DEVNUR(MYS)-RAJEEV NAGARA	DEVNUR(MYS)_66	10:19	17:23	7:04	LINE CLEAR AVAILED
1205	26-Sep-2021	MYSURU	66	DEVNUR(MYS)-VAJMANGALA	DEVNUR(MYS)_66	10:21	17:23	7:01	LINE CLEAR AVAILED
1206	26-Sep-2021	MYSURU	66	GUNDLUPETE-BEGUR-1	NO STATIONS EFFECTED	10:17	18:58	8:40	NFBC ISSUED
1207	26-Sep-2021	MYSURU	66	GUNDLUPETE-BEGUR-2	NO STATIONS EFFECTED	10:15	18:55	8:40	NFBC ISSUED
1208	26-Sep-2021	MYSURU	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	10:21	18:38	8:16	LINE CLEAR AVAILED
1209	26-Sep-2021	MYSURU	66	GUNDLUPETE-CR NAGARA 1	GUNDLUPETE_66	10:40	18:25	7:45	LINE CLEAR AVAILED
1210	26-Sep-2021	MYSURU	66	GUNDLUPETE-HANGALA	BHARGI_66 HANGALA_66	10:10	18:30	8:20	LINE CLEAR AVAILED
1211	26-Sep-2021	MYSURU	66	GUNDLUPETE-KABBALLI	NO STATIONS EFFECTED	10:05	19:28	9:23	NFBC ISSUED
1212	26-Sep-2021	MYSURU	66	HANNUR -AJJIPURA	BANDAHALLI_66 AJJIPURA_66 COWDALLI_66 RAMPURA_66 MARTALLI_66 .	10:35	13:25	2:50	LINE CLEAR AVAILED
1213	26-Sep-2021	MYSURU	66	HANNUR -KOTTANUR	HANNUR_66	10:40	13:25	2:45	LINE CLEAR AVAILED
1214	26-Sep-2021	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	10:45	18:30	7:45	HAND TRIPPED
1215	26-Sep-2021	MYSURU	66	HUNSUR-HOOTAGALLY	NO STATIONS EFFECTED	10:45	18:30	7:45	HAND TRIPPED
1216	26-Sep-2021	MYSURU	66	HV1	KADAKOLA_66	10:25	17:59	7:34	LINE CLEAR AVAILED
1217	26-Sep-2021	MYSURU	66	HV1	NAGAMANGALA_66	8:00	8:45	0:45	LINE CLEAR AVAILED
1218	26-Sep-2021	MYSURU	66	HV1	SANTHESARGUR_66	16:47 (23.09.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1219	26-Sep-2021	MYSURU	66	HV2	KADAKOLA_66	10:25	17:59	7:34	LINE CLEAR AVAILED
1220	26-Sep-2021	MYSURU	66	KOLLEGALA-CR NAGARA	KOLLEGALA_66	9:30	17:47	8:17	NFBC ISSUED
1221	26-Sep-2021	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	10:15	18:01	7:45	NFBC ISSUED
1222	26-Sep-2021	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	10:04	18:13	8:08	NFBC ISSUED
1223	26-Sep-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:50	18:21	8:30	NFBC ISSUED
1224	26-Sep-2021	MYSURU	66	KR NAGARA-BILIKERE	NO STATIONS EFFECTED	11:02	18:22	7:20	HAND TRIPPED
1225	26-Sep-2021	MYSURU	66	KR NAGARACHUNCHANAKATTE	NO STATIONS EFFECTED	11:00	15:00	4:00	LINE CLEAR AVAILED
1226	26-Sep-2021	MYSURU	66	KR NAGARAMYSORE 1	KR NAGARA_66	11:02	14:55	3:53	LINE CLEAR AVAILED
1227	26-Sep-2021	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	11:01	12:57	1:55	NFBC ISSUED
1228	26-Sep-2021	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	11:01	12:57	1:55	NFBC ISSUED
1229	26-Sep-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1230	26-Sep-2021	MYSURU	66	TUBINKERE-MC- 2	BASARALU_66 CHIKKAMANDYA_66 KOPPA_66 HAMPAPURA_66 BASARALU_66 MANDYA_6	10:38	13:54	3:16	LINE CLEAR AVAILED
1231	26-Sep-2021	MYSURU	66	TUBINKERE-MC- 4	BASARALU_66 CHIKKAMANDYA_66 KOPPA_66 HAMPAPURA_66 BASARALU_66 MANDYA_6	10:38	13:54	3:15	LINE CLEAR AVAILED
1232	26-Sep-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18(23.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1233	26-Sep-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1234	26-Sep-2021	TUMKUR	66	CHITRADURGA 220kV- HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	17:02	17:27	0:24	HAND TRIPPED
1235	26-Sep-2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	17:01	17:26	0:25	HAND TRIPPED
1236	26-Sep-2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	17:02	17:26	0:24	HAND TRIPPED
1237	26-Sep-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_66,K ADAJJI_66	14:55	15:07	0:12	LINE FAULT
1238	26-Sep-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:51	11:12	0:21	LINE FAULT
1239	26-Sep-2021	TUMKUR	66	HONNALLI-HONNALLI	HONNALLI_66, KATTIGE_66	16:27	16:37	0:10	LINE FAULT
1240	26-Sep-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	8:38	8:45	0:06	LINE FAULT
1241	26-Sep-2021	TUMKUR	66	PDKOTE-HARIYABBE	PDKOTE_66	8:45	8:49	0:04	LINE FAULT
1242	26-Sep-2021	TUMKUR	66	TR-1	CHITRADURGA_220	16:13	17:26	1:12	HAND TRIPPED
1243	26-Sep-2021	TUMKUR	66	TR-1	HIREHALLI_66	10:22	16:57	6:34	LINE CLEAR AVAILED
1244	26-Sep-2021	TUMKUR	66	TR-1	PAVAGADA_66	13:04	16:03	2:58	LINE CLEAR AVAILED
1245	26-Sep-2021	TUMKUR	66	TR-1	PAVAGADA_220	12:09	12:14	0:05	TRANSFORMER FAULT
1246	26-Sep-2021	TUMKUR	66	TR-1	TUMKUR_66	10:11	17:43	7:32	LINE CLEAR AVAILED
1247	26-Sep-2021	TUMKUR	66	TR-2	CHITRADURGA_220	16:16	17:18	1:02	HAND TRIPPED
1248	26-Sep-2021	TUMKUR	66	TR-2	HIREHALLI_66	10:22	16:57	6:34	LINE CLEAR AVAILED
1249	26-Sep-2021	TUMKUR	66	TR-2	PAVAGADA_66	13:05	16:02	2:57	LINE CLEAR AVAILED
1250	26-Sep-2021	TUMKUR	66	TR-2	TUMKUR_66	10:11	17:37	7:26	LINE CLEAR AVAILED
1251	26-Sep-2021	TUMKUR	220	TR-1	CHITRADURGA_220	16:13	17:09	0:55	TRANSFORMER FAULT
1252	27-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
1253	27-Sep-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
1254	27-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
1255	27-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
1256	27-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
1257	27-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
1258	27-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1259	27-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1260	27-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET 66	10:23 (12.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1261	27-Sep-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI 220	12:55 (19.09.2021)			LINE OPEN, LINE FAULT
1262	27-Sep-2021	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	10:22 (20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1263	27-Sep-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_110	8:35 (22.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1264	27-Sep-2021	BAGALKOT	110	GAJENDRGAD-KUSTAGI	GAJENDRGAD_110	17:28 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1265	27-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	16:06 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1266	27-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	16:07 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1267	27-Sep-2021	BAGALKOT	220	AMBEWADI-NAGJHARI2	AMBEWADI_220	22:41 (25.09.2021)	17:20 (27.09.2021)	42:39HRS	LINE CHARGED
1268	27-Sep-2021	BAGALKOT	66	66/11KV, HV2	STATION NOT AFFECTED HARIHAR HOSPET	12:49 (25.09.2021)	13:45 (27.09.2021)	48:56HRS	TRANSFORMER CHARGED
1269	27-Sep-2021	BAGALKOT	110	ITNAL-SULTANPUR(HIDKAL)	STATION NOT AFFECTED ITANAL 110	11:32 (25.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1270	27-Sep-2021	BAGALKOT	220	AMBEWADI-PONDA1	STATION NOT AFFECTED AMBEWADI 220	19:42 (27.09.2021)			LINE OPEN, LINE FAULT
1271	27-Sep-2021	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL 220	11:52	14:32	2:40	LINE CLEAR AVAILED
1272	27-Sep-2021	BAGALKOT	110	HAVERI-BYADAGI	STATION NOT AFFECTED HAVERI 220	18:20 (27.09.2021)			LINE OPEN, LINE FAULT
1273	27-Sep-2021	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI 220	11:51	15:19	3:28	LINE CLEAR AVAILED
1274	27-Sep-2021	BAGALKOT	110	220/110KV,HV1	STATION NOT AFFECTED MK HUBLI 220	10:20	11:20	1:00	LINE CLEAR AVAILED
1275	27-Sep-2021	BAGALKOT	110	110/11KV,HV1,HV2	MANTUR(GDP)_110	12:57	13:20	0:23	TRANSFORMER FAULT
1276	27-Sep-2021	BAGALKOT	110	110/11KV,HV2	MANTUR(GDP)_110	22:01	22:10	0:09	TRANSFORMER FAULT
1277	27-Sep-2021	BAGALKOT	110	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA 220	12:24	20:21	7:57	NFBC ISSUED
1278	27-Sep-2021	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI 220	12:24	16:33	4:09	LINE CLEAR AVAILED
1279	27-Sep-2021	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI 220	16:33	20:17	3:44	LINE FAULT
1280	27-Sep-2021	BAGALKOT	110	BELGAUM-HUDLI	HUDLI_110	23:24	23:43	0:19	LINE FAULT
1281	27-Sep-2021	BAGALKOT	110	BELGAUM-ANKALAGI	ANKALAGI_110	23:24	23:41	0:17	LINE FAULT
1282	27-Sep-2021	BAGALKOT	110	BAGALKOT-NEEDBIDIHAL	STATION NOT AFFECTED BAGALKOT 220	22:56	23:02	0:06	LINE FAULT
1283	27-Sep-2021	BAGALKOT	110	BAGALKOT-NEEDBIDIHAL	STATION NOT AFFECTED BAGALKOT 220	23:45	23:49	0:04	LINE FAULT
1284	27-Sep-2021	BAGALKOT	110	CHIKKODI-SADALAGA	STATION NOT AFFECTED CHIKKODI 220	15:04	15:05	0:01	HAND TRIPPED
1285	27-Sep-2021	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	ALBAL_110	7:47	10:37	2:50	LINE CLEAR AVAILED
1286	27-Sep-2021	BAGALKOT	110	ALBAL-RAY SOLAR	ALBAL_110	7:47	10:36	2:49	LINE CLEAR AVAILED
1287	27-Sep-2021	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	ALBAL_110	15:55	19:33	3:38	LINE CLEAR AVAILED
1288	27-Sep-2021	BAGALKOT	110	ALBAL-RAY SOLAR	ALBAL_110	15:55	19:32	3:37	LINE CLEAR AVAILED
1289	27-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TUMMINAKATTI 110	10:16	17:29	7:13	HAND TRIPPED
1290	27-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TUMMINAKATTI 110	10:15	17:29	7:14	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1291	27-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED RAIBAG 110	20:08	20:14	0:06	TRANSFORMER FAULT
1292	27-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED PG HUNSHYAL 110	13:30	14:29	0:59	LINE CLEAR AVAILED
1293	27-Sep-2021	BAGALKOT	110	110/33KV, HV3	NIPPANI_110	12:32	12:33	0:01	HAND TRIPPED
1294	27-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NAVALAGUND 110	12:55	15:14	2:19	LINE CLEAR AVAILED
1295	27-Sep-2021	BAGALKOT	110	110/33KV, HV2	STATION NOT AFFECTED SADALAGA 110	10:20 (25.09.2021)	13:33 (27.09.2021)	51:13HRS	TRANSFORMER CHARGED
1296	27-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HIREKERUR 110	13:46	14:26	0:40	LINE CLEAR AVAILED
1297	27-Sep-2021	BAGALKOT	110	DHAVALESHWAR-SAIDAPUR	SAIDAPUR_110	8:30	11:43	3:13	LINE CLEAR AVAILED
1298	27-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI 220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1299	27-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI 220	09:06 (10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1300	27-Sep-2021	BAGALKOT	110	110/11KV,HV1	GIRISAGAR_110	7:15	8:50	1:35	TRANSFORMER FAULT
1301	27-Sep-2021	BAGALKOT	110	CHIKKODI-KHADAKLAT	STATION NOT AFFECTED CHIKKODI 220	11:25	12:15	0:50	HAND TRIPPED
1302	27-Sep-2021	BAGALKOT	110	KSSKN-ATHANI	STATION NOT AFFECTED ATHANI 220	13:41	15:50	2:09	LINE CLEAR AVAILED
1303	27-Sep-2021	BAGALKOT	110	KSSKN-ATHANI	STATION NOT AFFECTED ATHANI 220	15:58	16:12	0:14	HAND TRIPPED
1304	27-Sep-2021	BENGALURU	66	HV1	BG ROAD	12:10	12:11	0:01	LINE CLEAR AVAILED
1305	27-Sep-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD	10:42	10:47	0:05	LINE CLEAR AVAILED
1306	27-Sep-2021	BENGALURU	66	JIGANI LINK ROAD - JIGANI 220	JIGANI LINK ROAD	9:55	10:25	0:30	MAIN SUPPLY FAILURE
1307	27-Sep-2021	BENGALURU	66	GURUVINAPURA - BV HALLI	BV HALLI	6:05	6:50	0:45	LINE FAULT
1308	27-Sep-2021	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	11:41	11:51	0:10	LINE CLEAR AVAILED
1309	27-Sep-2021	BENGALURU	66	HV1	HEBBALA 220	13:09	13:12	0:03	LINE CLEAR AVAILED
1310	27-Sep-2021	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	10:00	17:01	7:01	LINE CLEAR AVAILED
1311	27-Sep-2021	BENGALURU	66	HV2	KODIGEHALLI	19:10	20:10	1:00	LINE CLEAR AVAILED
1312	27-Sep-2021	BENGALURU	220	MYLSANDRA 400 - JIGANI 220	JIGANI 220	9:55	10:54	0:59	LINE FAULT
1313	27-Sep-2021	BENGALURU	220	JIGANI 220 - MYLSANDRA 400	JIGANI 220	9:55	10:54	0:59	LINE FAULT
1314	27-Sep-2021	BENGALURU	220	HV1	JIGANI 220	9:55	10:54	0:59	LINE CLEAR AVAILED
1315	27-Sep-2021	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	9:55	10:54	0:59	LINE CLEAR AVAILED
1316	27-Sep-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	9:39	9:45	0:06	LOAD CHANGE OVER
1317	27-Sep-2021	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRKUR, NANGLI	21:06	21:25	0:19	LINE FAULT
1318	27-Sep-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	11:50	11:55	0:05	LOAD CHANGE OVER
1319	27-Sep-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	16:40	16:45	0:05	LOAD CHANGE OVER
1320	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS	22:20	22:50	0:30	MAIN SUPPLY FAILURE
1321	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	22:20	22:50	0:30	MAIN SUPPLY FAILURE
1322	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	22:20	22:39	0:19	MAIN SUPPLY FAILURE
1323	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	22:20	22:39	0:19	MAIN SUPPLY FAILURE
1324	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	22:20	22:22	0:02	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1325	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	22:20	23:03	0:43	MAIN SUPPLY FAILURE
1326	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	22:20	22:22	0:02	MAIN SUPPLY FAILURE
1327	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA, KYALANUR	22:20	22:39	0:19	MAIN SUPPLY FAILURE
1328	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	22:20	22:50	0:30	MAIN SUPPLY FAILURE
1329	27-Sep-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	22:20	22:50	0:30	MAIN SUPPLY FAILURE
1330	27-Sep-2021	BENGALURU	220	LV2	CHINTAMANI 220	22:20	22:22	0:02	TRANSFORMER FAULT
1331	27-Sep-2021	BENGALURU	220	HV3	CHINTAMANI 220	22:20	22:48	0:28	TRANSFORMER FAULT
1332	27-Sep-2021	BENGALURU	220	LV3	CHINTAMANI 220	22:20	22:50	0:30	TRANSFORMER FAULT
1333	27-Sep-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	14:55	16:35	1:40	LINE CLEAR AVAILED
1334	27-Sep-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	10:33	10:53	0:20	LINE FAULT
1335	27-Sep-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	15:46	15:55	0:09	LINE FAULT
1336	27-Sep-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	15:59	16:04	0:05	LINE FAULT
1337	27-Sep-2021	BENGALURU	66	HV2	TADIGOLU	15:39	16:42	1:02	LINE CLEAR AVAILED
1338	27-Sep-2021	BENGALURU	66	HV2	KANAKAPURA 66	11:02	11:10	0:07	LINE CLEAR AVAILED
1339	27-Sep-2021	BENGALURU	66	KORAMANGALA 220 - HSR 2	NO STATION AFFECTED	16:57(25/09/2021)			LINE OPEN, LINE FAULT
1340	27-Sep-2021	GULBARGA	220	SINDHANOOR-LINGAPUR	SINDHANOOR_220	9:20	12:02	2:42	NFBC ISSUED
1341	27-Sep-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	19:13	19:41	0:28	LINE FAULT
1342	27-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1343	27-Sep-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:10(26.09.2021)	7:00(27.09.2021)	7:50HRS	LINE CHARGED
1344	27-Sep-2021	GULBARGA	220	HV2	KAPNOOR_220	17:01	17:07	0:06	TRANSFORMER FAULT
1345	27-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1346	27-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
1347	27-Sep-2021	GULBARGA	110	HV1	GULBARGA UNIVERSITY_110	7:40	7:45	0:05	TRANSFORMER FAULT
1348	27-Sep-2021	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	22:55(26.09.2021)	6:25 (27.09.2021)	7:30 HRS	LINE CHARGED
1349	27-Sep-2021	GULBARGA	110	SHAHPUR-NALWAR	NALWAR_110	5:55	6:00	0:05	LINE FAULT
1350	27-Sep-2021	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGAWEST_110,GULBARGA SOUTH 110	8:00	17:20	9:20	NFBC ISSUED
1351	27-Sep-2021	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	17:10	18:30	1:20	LINE CLEAR AVAILED
1352	27-Sep-2021	GULBARGA	110	JANAWADA-SANTAPUR	JANAWADA_110	19:15	19:25	0:10	LINE FAULT
1353	27-Sep-2021	GULBARGA	110	TEKKALKOTE-SINDHANOOR	TEKKALKOTE_110	21:19	21:33	0:14	MAIN SUPPLY FAILURE
1354	27-Sep-2021	GULBARGA	110	HV1	GULBARGA UNIVERSITY_110	7:40	7:45	0:05	TRANSFORMER FAULT
1355	27-Sep-2021	GULBARGA	110	GULBARGA UNIVERSITY-GULBARGA SOUTH	GULBARGA UNIVERSITY_110	10:55	13:30	2:35	NFBC ISSUED
1356	27-Sep-2021	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110	10:30	16:15	5:45	NFBC ISSUED
1357	27-Sep-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	20:50	21:00	0:10	MAIN SUPPLY FAILURE
1358	27-Sep-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERD ONA_110,SRNAGAR_110,MALLAPU RA 110	1:17	1:27	0:10	LINE FAULT
1359	27-Sep-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110	0:19	0:29	0:10	LINE FAULT
1360	27-Sep-2021	GULBARGA	110	HJV1	CHINCHOLLI_110	22:05	22:15	0:10	LINE CLEAR AVAILED
1361	27-Sep-2021	GULBARGA	110	HV3	CHINCHOLLI_110	22:05	23:00	0:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1362	27-Sep-2021	GULBARGA	110	SHAHABAD-RAICHUR2	JEAWARGI_110	6:15	12:40	6:25	LINE FAULT
1363	27-Sep-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	3:33	3:43	0:10	LINE FAULT
1364	27-Sep-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	10:22	10:30	0:08	LINE FAULT
1365	27-Sep-2021	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANWADA_110,NSSK SUGAR FACTORY	18:22	19:15	0:53	LINE FAULT
1366	27-Sep-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	19:18	19:20	0:02	LINE FAULT
1367	27-Sep-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR IPP	23:20	23:27	0:07	LINE FAULT
1368	27-Sep-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR IPP	23:50	23:55	0:05	LINE FAULT
1369	27-Sep-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COR EGREEN IPP	0:02	0:14	0:12	LINE FAULT
1370	27-Sep-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COR EGREEN IPP	19:19	19:28	0:09	LINE FAULT
1371	27-Sep-2021	GULBARGA	110	HV2	SHAHAPUR_220	22:45	22:56	0:11	TRANSFORMER FAULT
1372	27-Sep-2021	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGAWEST_110,GULBARGA SOUTH_110	8:00	17:20	9:20	NFBC ISSUED
1373	27-Sep-2021	GULBARGA	66	HV1	BACHIGONDANAHALLI_66	7:00	7:05	0:05	TRANSFORMER FAULT
1374	27-Sep-2021	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1375	27-Sep-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:45(21.09.2021)			LINE OPEN, LINE FAULT
1376	27-Sep-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	8:32 (24.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1377	27-Sep-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	23:15 (27.09.2021)			LINE OPEN, LINE FAULT
1378	27-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	23:15 (27.09.2021)			LINE OPEN, LINE FAULT
1379	27-Sep-2021	HASSAN	220	HV1	HASSAN_220	10:04	13:50	3:46	LINE CLEAR AVAILED
1380	27-Sep-2021	HASSAN	220	HV2	HASSAN_220	14:15	18:23	4:08	LINE CLEAR AVAILED
1381	27-Sep-2021	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	10:02	10:47	0:45	HAND TRIPPED
1382	27-Sep-2021	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	14:13	14:20	0:07	HAND TRIPPED
1383	27-Sep-2021	HASSAN	66	HASSN22-BELUR	HASSAN_220	14:09	18:39	4:30	LINE CLEAR AVAILED
1384	27-Sep-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:02	15:38	5:36	LINE CLEAR AVAILED
1385	27-Sep-2021	HASSAN	66	LV1	HASSAN_220	10:04	13:50	3:46	LINE CLEAR AVAILED
1386	27-Sep-2021	HASSAN	66	HASSN22-MALLALI	HASSAN_220	10:01	15:37	5:36	HAND TRIPPED
1387	27-Sep-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	10:01	10:08	0:07	HAND TRIPPED
1388	27-Sep-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	13:53	14:00	0:07	HAND TRIPPED
1389	27-Sep-2021	HASSAN	66	HASSN22-SKPURA	HASSAN_220	9:36	18:38	9:02	LINE CLEAR AVAILED
1390	27-Sep-2021	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	14:03	14:08	0:05	HAND TRIPPED
1391	27-Sep-2021	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	18:32	18:40	0:08	HAND TRIPPED
1392	27-Sep-2021	HASSAN	220	HV1	ARASIKERE_220	10:17	14:43	4:26	LINE CLEAR AVAILED
1393	27-Sep-2021	HASSAN	220	HV2	ARASIKERE_220	14:45	17:49	3:04	LINE CLEAR AVAILED
1394	27-Sep-2021	HASSAN	110	LV1	ARASIKERE_220	10:17	14:43	4:26	LINE CLEAR AVAILED
1395	27-Sep-2021	HASSAN	110	LV2	ARASIKERE_220	14:45	17:49	3:04	LINE CLEAR AVAILED
1396	27-Sep-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:55	13:42	1:47	LINE CLEAR AVAILED
1397	27-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	11:55	13:42	1:47	NFBC ISSUED
1398	27-Sep-2021	HASSAN	110	HV5	MRSMSG_220	15:28	17:31	2:03	LINE CLEAR AVAILED
1399	27-Sep-2021	HASSAN	110	HV1	ARASIKERE_110	11:00	11:07	0:07	TRANSFORMER FAULT
1400	27-Sep-2021	HASSAN	110	KADUR-NGNHL	KADUR_220	10:20	13:51	3:31	LINE CLEAR AVAILED
1401	27-Sep-2021	HASSAN	110	HV2	NERALAKERE_110	14:22	15:22	1:00	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1402	27-Sep-2021	HASSAN	66	ARAKAL-HASSAN	ARKD_66	12:45	14:08	1:23	LINE CLEAR AVAILED
1403	27-Sep-2021	HASSAN	66	HV1	ARKD_66	12:45	14:08	1:23	LINE CLEAR AVAILED
1404	27-Sep-2021	HASSAN	66	HV2	ARKD_66	12:45	14:08	1:23	LINE CLEAR AVAILED
1405	27-Sep-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	12:45	14:08	1:23	LINE CLEAR AVAILED
1406	27-Sep-2021	HASSAN	66	HV1	DUDDA_66	10:15	10:25	0:10	TRANSFORMER FAULT
1407	27-Sep-2021	HASSAN	66	HV1	DUDDA_66	16:08	16:50	0:42	LINE CLEAR AVAILED
1408	27-Sep-2021	HASSAN	66	GORUR-ARAKALGUD	GORUR_66	10:00	14:12	4:12	MAIN SUPPLY FAILURE
1409	27-Sep-2021	HASSAN	66	GORUR-HASSAN	GORUR_66	10:00	14:12	4:12	MAIN SUPPLY FAILURE
1410	27-Sep-2021	HASSAN	66	HV1	GORUR_66	10:00	14:12	4:12	MAIN SUPPLY FAILURE
1411	27-Sep-2021	HASSAN	66	HV1	MAGGE_66	9:35	9:40	0:05	MAIN SUPPLY FAILURE
1412	27-Sep-2021	HASSAN	66	HV1	MAGGE_66	14:15	14:23	0:08	MAIN SUPPLY FAILURE
1413	27-Sep-2021	HASSAN	66	HV2	MAGGE_66	9:35	9:40	0:05	MAIN SUPPLY FAILURE
1414	27-Sep-2021	HASSAN	66	HV2	MAGGE_66	14:15	14:23	0:08	MAIN SUPPLY FAILURE
1415	27-Sep-2021	HASSAN	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	10:00	10:40	0:40	MAIN SUPPLY FAILURE
1416	27-Sep-2021	HASSAN	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	11:00	12:15	1:15	LINE CLEAR AVAILED
1417	27-Sep-2021	HASSAN	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	12:45	14:20	1:35	MAIN SUPPLY FAILURE
1418	27-Sep-2021	HASSAN	66	HV1	MALLIPATNA_66	10:00	10:40	0:40	MAIN SUPPLY FAILURE
1419	27-Sep-2021	HASSAN	66	HV1	MALLIPATNA_66	11:00	12:15	1:15	LINE CLEAR AVAILED
1420	27-Sep-2021	HASSAN	66	HV1	MALLIPATNA_66	12:45	14:20	1:35	MAIN SUPPLY FAILURE
1421	27-Sep-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:00	10:40	0:40	MAIN SUPPLY FAILURE
1422	27-Sep-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	11:00	12:15	1:15	LINE CLEAR AVAILED
1423	27-Sep-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	12:45	14:20	1:35	MAIN SUPPLY FAILURE
1424	27-Sep-2021	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	15:10	16:31	1:21	LINE CLEAR AVAILED
1425	27-Sep-2021	HASSAN	66	HV1	RAMESHWARNAGARA_66	12:05	17:15	5:10	LINE CLEAR AVAILED
1426	27-Sep-2021	HASSAN	66	HV2	RAMESHWARNAGARA_66	10:45	17:05	6:20	LINE CLEAR AVAILED
1427	27-Sep-2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	15:10	17:28	2:18	LINE CLEAR AVAILED
1428	27-Sep-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	9:35	9:58	0:23	HAND TRIPPED
1429	27-Sep-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	9:35	9:59	0:24	HAND TRIPPED
1430	27-Sep-2021	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	14:06	14:10	0:04	MAIN SUPPLY FAILURE
1431	27-Sep-2021	HASSAN	66	HV1	YESLUR_66	10:00	10:45	0:45	MAIN SUPPLY FAILURE
1432	27-Sep-2021	HASSAN	66	HV1	YESLUR_66	11:05	12:15	1:10	MAIN SUPPLY FAILURE
1433	27-Sep-2021	HASSAN	66	HV1	YESLUR_66	12:45	14:20	1:35	MAIN SUPPLY FAILURE
1434	27-Sep-2021	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	15:05	16:29	1:24	LINE CLEAR AVAILED
1435	27-Sep-2021	MYSURU	66	HV1	BANNIMANTAP_66	7:20	13:28	22:44:00	TRANSFORMER CHARGED
1436	27-Sep-2021	MYSURU	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66 KOPPA_66 BASARALU_66 BESAGARAHALLI_66	1:17	1:34	0:16	LINE FAULT
1437	27-Sep-2021	MYSURU	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66 HONNALLY_MYS_66 ARKALAWADI_66	2:23	2:35	0:11	LINE FAULT
1438	27-Sep-2021	MYSURU	66	HOOTGALLY-FTS1	NO STATIONS EFFECTED	12:30	14:30	2:00	LINE FAULT
1439	27-Sep-2021	MYSURU	66	HOOTGALLY-FTS2	NO STATIONS EFFECTED	12:30	14:29	1:59	LINE FAULT
1440	27-Sep-2021	MYSURU	66	JAKKANALLI-NAGAMANGLA	NAGAMANGALA_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66	3:41	3:50	0:08	LINE FAULT
1441	27-Sep-2021	MYSURU	66	KADAKOLA-SARGUR1	JAIPUR_66 HAMPAPURA(K)_66	6:00	8:21	2:21	LINE FAULT
1442	27-Sep-2021	MYSURU	66	HV1	KIADBMANDYA_66	10:53	12:46	1:53	LINE CLEAR AVAILED
1443	27-Sep-2021	MYSURU	66	HV2	KIADBMANDYA_66	12:54	14:22	1:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1444	27-Sep-2021	MYSURU	66	KR PETE 220-BOOKANAKERE	SHEELUNERE_66 BOOKANAKERE_66 GANJIGERE_66 PANDAVAPURA_66 CHINAKURALI_66 BANANGADI_66	7:23	7:28	0:05	LINE FAULT
1445	27-Sep-2021	MYSURU	66	HV2	MALAVALLI_66	10:54	15:47	4:52	LINE CLEAR AVAILED
1446	27-Sep-2021	MYSURU	66	PARINAMIPURA-THALAKADU	THALAKADU_66 CHANDALLI_66	16:30	16:36	0:06	LINE FAULT
1447	27-Sep-2021	MYSURU	66	HV2	PANDAVAPURA_66	11:11	11:27	0:15	HAND TRIPPED
1448	27-Sep-2021	MYSURU	66	HV2	SANTHEMARAHALLI_66	17:35	17:37	0:01	TRANSFORMER FAULT
1449	27-Sep-2021	MYSURU	66	HV2	VAJAMANGALA_220	2:22	2:44	0:22	TRANSFORMER FAULT
1450	27-Sep-2021	MYSURU	66	HV1	SANTHESARGUR_66	16:47 (23.09.2021)	11:40:00 (28.09.2021)	114:53HRS	TRANSFORMER CHARGED
1451	27-Sep-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	NO STATIONS EFFECTED	15:04:18(23.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1452	27-Sep-2021	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1453	27-Sep-2021	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1454	27-Sep-2021	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR IPP 66	AZURE POWER SOLAR_IPP_66	18:18	23:39	5:20	LINE CLEAR AVAILED
1455	27-Sep-2021	TUMKUR	110	TR-1	TIMMANAHALLI_110	10:37	10:47	0:10	TRANSFORMER FAULT
1456	27-Sep-2021	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR_66	YEDIYUR_66,THIPPUR_66,JIDDEGER E_66	15:53	16:03	0:09	LINE FAULT
1457	27-Sep-2021	TUMKUR	66	TR-1	BELLAVI_66	15:14	15:39	0:25	LINE CLEAR AVAILED
1458	27-Sep-2021	TUMKUR	66	TR-1	BHARAMGIRI_66	14:20	14:25	0:05	TRANSFORMER FAULT
1459	27-Sep-2021	TUMKUR	66	TR-2	BHARAMGIRI_66	14:55	15:01	0:05	TRANSFORMER FAULT
1460	27-Sep-2021	TUMKUR	66	TR-1	BRAHMASANDRA_66	12:13	13:14	1:00	LINE CLEAR AVAILED
1461	27-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:42	5:51	0:09	LINE FAULT
1462	27-Sep-2021	TUMKUR	66	HONNALLI 220kv- KUNDUR66	KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE_66	11:15	11:29	0:14	LINE FAULT
1463	27-Sep-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	16:48	16:59	0:11	LINE FAULT
1464	27-Sep-2021	TUMKUR	66	TR-2	MATHOD_66	11:38	11:49	0:10	TRANSFORMER FAULT
1465	27-Sep-2021	TUMKUR	66	PAVAGADA66-VENKATAPURA66	PAVAGADA_66	13:17	14:05	0:47	LINE CLEAR AVAILED
1466	27-Sep-2021	TUMKUR	66	TR-1	PAVAGADA_66	12:08	14:12	2:03	LINE CLEAR AVAILED
1467	27-Sep-2021	TUMKUR	66	TR-2	PAVAGADA_66	12:58	14:06	1:07	LINE CLEAR AVAILED
1468	27-Sep-2021	TUMKUR	66	TR-1	PDKOTE_66	18:03	18:19	0:16	TRANSFORMER FAULT
1469	27-Sep-2021	TUMKUR	66	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	13:12	14:04	0:52	LINE CLEAR AVAILED
1470	27-Sep-2021	TUMKUR	66	PAVAGADA220-MADHUGIRI 2	PAVAGADA_220	13:12	14:04	0:52	LINE CLEAR AVAILED
1471	27-Sep-2021	TUMKUR	66	SHYLAPURA_66	TR-2	0:20	0:25	0:04	HAND TRIPPED
1472	27-Sep-2021	TUMKUR	66	UCHANGIDURGA- PALLAGATTE	PALLAGATTA_66,BILCHODU_66, SOKKE_66	1:10	1:19	0:09	LINE FAULT