

**400/220/110/66 kV TRANSMISSIONSYSTEM OUTAGES FROM 31.03.2020 TO 06.04.2020**

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	31-Mar-20	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	13:52	14:32	0:40	LINE CLEAR AVAILED
2	31-Mar-20	BAGALKOT	110	110/11KV, HV1	MALGHAN(S)_110	7:36	7:40	0:04	TRANSFORMER FAULT
3	31-Mar-20	BAGALKOT	110	110/11KV, HV2	AREMALLAPUR_110	11:20	12:45	1:25	LINE CLEAR AVAILED
4	31-Mar-20	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	1:26	1:33	0:07	TRANSFORMER FAULT
5	31-Mar-20	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGADA_33	8:49	8:55	0:06	TRANSFORMER FAULT
6	31-Mar-20	BAGALKOT	110	110/33KV, HV2	UTTUR_110, VANTAGODI_33, YADWAD_33	14:48	15:07	0:19	TRANSFORMER FAULT
7	31-Mar-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, HALSANGI_33	22:05	22:19	0:14	TRANSFORMER FAULT
8	31-Mar-20	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	14:29	15:20	0:51	LINE FAULT
9	31-Mar-20	BENGALURU	66	ANEKAL - ATTIBELE	ANEKAL	12:40	12:47	0:07	LOAD CHANGE OVER
10	31-Mar-20	BENGALURU	66	ANEKAL - YARANDANAHALLI	ANEKAL	12:01	12:21	0:20	LOAD CHANGE OVER
11	31-Mar-20	BENGALURU	66	CHINTAMANI 66 - CHINTAMANI 220	CHINTAMANI 66	14:05	14:20	0:15	LINE CLEAR AVAILED
12	31-Mar-20	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY,INFOSYS	11:35	11:45	0:10	LOAD CHANGE OVER
13	31-Mar-20	BENGALURU	66	HV1	CHANDRAPPA CIRCLE	7:11	7:25	0:14	TRANSFORMER FAULT
14	31-Mar-20	BENGALURU	66	HV1	DEVARABISANAHALLI	12:35	13:05	0:30	LINE CLEAR AVAILED
15	31-Mar-20	BENGALURU	66	HV2	DODDABELAVANGALA	10:07	10:20	0:12	LINE CLEAR AVAILED
16	31-Mar-20	BENGALURU	66	HV2	JIGANI LINK ROAD	10:20	10:30	0:10	LINE CLEAR AVAILED
17	31-Mar-20	BENGALURU	66	HV2	DEVARABISANAHALLI	12:30	13:50	1:20	LINE CLEAR AVAILED
18	31-Mar-20	BENGALURU	66	KGF - ANDERSONPET	ANDERSONPET	18:13	21:02	2:48	LINE CLEAR AVAILED
19	31-Mar-20	BENGALURU	66	KGF - BEML (EHT)	BEML (EHT)	19:18	21:05	1:46	LINE CLEAR AVAILED
20	31-Mar-20	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI	18:13	21:02	2:48	LINE CLEAR AVAILED
21	31-Mar-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:21	18:28	0:06	LINE FAULT
22	31-Mar-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	18:05	18:25	0:19	LINE FAULT
23	31-Mar-20	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	12:42	12:52	0:10	LOAD CHANGE OVER
24	31-Mar-20	BENGALURU	66	SURYANAGAR - YARADANAHALLI	SURYANAGAR	12:04	12:22	0:17	LOAD CHANGE OVER
25	31-Mar-20	GULBARGA	110	HV1	DEODURGA_110	12:45	13:05	0:20	LINE CLEAR AVAILED
26	31-Mar-20	GULBARGA	110	HV1	HAGARIBOMMANAHALLI_66	8:00	8:10	0:10	TRANSFORMER FAULT
27	31-Mar-20	GULBARGA	110	JANAWADA-KOLHAR	JANAWADA_110,NSSK SUGAR FACTORY_IPP	19:00	19:15	0:15	MAIN SUPPLY FAILURE
28	31-Mar-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	3:25	3:42	0:17	LINE FAULT
29	31-Mar-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	5:55	6:05	0:10	LINE FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
30	31-Mar-20	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	6:10	6:25	0:15	LINE FAULT
31	31-Mar-20	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	2:50	3:09	0:19	LINE FAULT
32	31-Mar-20	HASSAN	66	BHADRA-LINGADAHALLI	BHADRA	6:45	6:51	0:06	LINE FAULT
33	31-Mar-20	HASSAN	66	BHADRA-LINGADAHALLI	BHADRA	10:18	12:56	2:38	LINE CLEAR AVAILED
34	31-Mar-20	HASSAN	66	BHADRA-LINGADAHALLI	BHADRA	15:33	15:42	0:09	LINE FAULT
35	31-Mar-20	HASSAN	66	HV1	HALEBE	8:26	8:51	0:25	TRANSFORMER FAULT
36	31-Mar-20	HASSAN	66	HV1	KUDLIGE	17:28	19:04	1:36	LINE CLEAR AVAILED
37	31-Mar-20	HASSAN	66	HV2	HOLEHA	10:39	11:22	0:43	LINE CLEAR AVAILED
38	31-Mar-20	HASSAN	110	BANTWA-SALATTUR	BANTWA	3:48	18:21	14:33	LINE FAULT
39	31-Mar-20	HASSAN	110	HV2	MSEZ	14:16	14:35	0:19	TRANSFORMER FAULT
40	31-Mar-20	HASSAN	110	HV2	BARANG	15:41	16:16	0:35	LINE CLEAR AVAILED
41	31-Mar-20	HASSAN	400	UPCL-HASSAN1	UPCL	14:12	23:59	9:47	LINE FAULT
42	31-Mar-20	HASSAN	400	UPCL-HASSAN2	UPCL	0:00	14:23	14:23	LINE CLEAR AVAILED
43	31-Mar-20	MYSURU	66	HV1	HANAGODU_66	12:23	12:34	0:11	TRANSFORMER FAULT
44	31-Mar-20	MYSURU	66	HV1	NANJIANGUDU_66	10:11	11:03	0:52	TRANSFORMER FAULT
45	31-Mar-20	MYSURU	66	HV2	PANDAVAPURA_66	15:39	15:52	0:13	HAND TRIPPED
46	31-Mar-20	MYSURU	66	HV2	SATHEGALA_66	8:17	8:36	0:18	LINE CLEAR AVAILED
47	31-Mar-20	MYSURU	66	KADAKOLA-SARGUR 1	BETTADHAPURA_66,CHUNCH UNKATTE_66,KITTUR_66 & RAVANDUR_66	7:25	7:29	0:03	LINE FAULT
48	31-Mar-20	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66, HULLAHALLI_66, HURA_66 & CHANDRAVADI_66	7:25	7:29	0:03	LINE FAULT
49	31-Mar-20	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66, GVGUDI_66, BILIKERE_66, DMG_HALLI_66 & KRNAGARA_66	6:53	7:03	0:10	LINE FAULT
50	31-Mar-20	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66, GVGUDI_66, BILIKERE_66, DMG_HALLI_66 & KRNAGARA_66	7:05	7:18	0:12	LINE FAULT
51	31-Mar-20	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66, GVGUDI_66, BILIKERE_66, DMG_HALLI_66 & KRNAGARA_66	17:11	17:29	0:17	LINE FAULT
52	31-Mar-20	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66, KITTUR_66, RAVANDUR_66 & CHUNCHUNKATTE_66	6:53	7:07	0:13	LINE FAULT
53	31-Mar-20	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66, KITTUR_66, RAVANDUR_66 & CHUNCHUNKATTE_66	7:12	7:18	0:05	LINE FAULT
54	31-Mar-20	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66, KITTUR_66, RAVANDUR_66 & CHUNCHUNKATTE_66	17:11	17:34	0:22	LINE FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
55	31-Mar-20	MYSURU	66	VAJMANGALA-KADAKOLA 1	MARADIHUNDI_66 & AYRALLI_66	17:22	17:28	0:05	LINE FAULT
56	31-Mar-20	TUMKUR	66	BHAKTHARA HALLI -ANCHEPALYA	BHAKTHARAHALLI_66	6:18	6:34	0:16	HAND TRIPPED
57	31-Mar-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:08	0:18	0:09	LINE FAULT
58	31-Mar-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:54	13:05	0:10	LINE FAULT
59	31-Mar-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:04	16:11	0:06	LINE FAULT
60	31-Mar-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	7:32	10:05	2:32	LINE CLEAR AVAILED
61	31-Mar-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:08	12:21	0:13	LINE FAULT
62	31-Mar-20	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	6:18	6:35	0:16	HAND TRIPPED
63	31-Mar-20	TUMKUR	66	TR-1	HALURAMESHWARA_66	6:46	6:55	0:09	TRANSFORMER FAULT
64	31-Mar-20	TUMKUR	66	TR-1	KATTIGE_66	15:25	15:31	0:06	TRANSFORMER FAULT
65	31-Mar-20	TUMKUR	66	TR-1	PATTANAYAKANAHALLI_66	7:43	7:54	0:10	TRANSFORMER FAULT
66	31-Mar-20	TUMKUR	66	TR-1	PATTANAYAKANAHALLI_66	8:04	8:25	0:21	LINE CLEAR AVAILED
67	31-Mar-20	TUMKUR	66	TR-1	PAVAGADA_220	13:37	13:42	0:05	HAND TRIPPED
68	31-Mar-20	TUMKUR	66	TR-1	YEDIYUR_66	11:26	11:40	0:13	TRANSFORMER FAULT
69	31-Mar-20	TUMKUR	66	TR-2	BEVINAHALLI_66	10:33	11:10	0:36	LINE CLEAR AVAILED
70	31-Mar-20	TUMKUR	66	TR-2	HIREGUNTANUR_66	6:05	10:59	4:53	TRANSFORMER FAULT
71	31-Mar-20	TUMKUR	66	TR-2	MATHOD_66	13:09	13:16	0:06	TRANSFORMER FAULT
72	31-Mar-20	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	14:57	15:37	0:39	HAND TRIPPED
73	31-Mar-20	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	13:51	14:00	0:09	HAND TRIPPED
74	31-Mar-20	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	13:51	14:58	1:07	LINE CLEAR AVAILED
75	31-Mar-20	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	13:51	15:34	1:43	LINE FAULT
76	1-Apr-2020	BENGALURU	66	ELECTRONIC CITY - NAGNATHPURA	ELECTRONIC CITY	6:43	6:49	0:06	LOAD CHANGE OVER
77	1-Apr-2020	BENGALURU	66	HV1	V G DODDI	14:30	14:40	0:10	LINE CLEAR AVAILED
78	1-Apr-2020	BENGALURU	66	HV2	RAGANDODDI	12:38	13:00	0:22	LINE CLEAR AVAILED
79	1-Apr-2020	BENGALURU	66	HV2	HONNIGANAHALLI	7:05	7:17	0:12	TRANSFORMER FAULT
80	1-Apr-2020	BENGALURU	66	NAGNATHAPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	10:08	10:38	0:30	LINE FAULT
81	1-Apr-2020	BENGALURU	220	HOODY 220 - MANYATHA 220	MANYATHA 220	11:39	12:22	0:42	LINE FAULT
82	1-Apr-2020	BENGALURU	220	HV1	MANYATHA 220	17:16	17:20	0:04	LINE CLEAR AVAILED
83	1-Apr-2020	GULBARGA	66	HV1	CJHALLI_66	6:28	6:35	0:07	LOAD CURTAILMENT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
84	1-Apr-2020	GULBARGA	66	HV1	CJHALLI_66	21:55	22:10	0:15	LOAD CURTAILMENT
85	1-Apr-2020	GULBARGA	66	HV2	CJHALLI_66	11:15	11:20	0:05	LINE CLEAR AVAILED
86	1-Apr-2020	GULBARGA	110	CHIKSUGUR-APMC	CHIKSUGUR-110, SHAKTINAGAR_110	11:10	14:02	2:52	MAIN SUPPLY FAILURE
87	1-Apr-2020	GULBARGA	110	HV1	CHINCHOLI_110	22:10	22:16	0:06	LOAD CURTAILMENT
88	1-Apr-2020	GULBARGA	110	HV1	GABUR_110	6:28	6:33	0:05	LOAD CURTAILMENT
89	1-Apr-2020	GULBARGA	110	HV1	MAHAGOAN_110	22:10	22:20	0:10	TRANSFORMER FAULT
90	1-Apr-2020	GULBARGA	110	HV1	PD_HALLI_110	17:25	18:15	0:50	LINE CLEAR AVAILED
91	1-Apr-2020	GULBARGA	110	HV1	PD_HALLI_110	22:10	22:13	0:03	LOAD CURTAILMENT
92	1-Apr-2020	GULBARGA	110	HV2	KAMPLI_GLB_110	6:25	6:30	0:05	LOAD CURTAILMENT
93	1-Apr-2020	GULBARGA	110	HV2	KAMPLI_GLB_110	22:10	22:20	0:10	LOAD CURTAILMENT
94	1-Apr-2020	GULBARGA	110	HV2	HANUMASAGAR_110	22:10	22:20	0:10	LOAD CURTAILMENT
95	1-Apr-2020	GULBARGA	110	HV3	JEWARGI_110	22:10	22:20	0:10	LOAD CURTAILMENT
96	1-Apr-2020	GULBARGA	110	HV3	HANUMASAGAR_110	6:30	6:50	0:20	LOAD CURTAILMENT
97	1-Apr-2020	GULBARGA	110	HV3	HANUMASAGAR_110	22:15	22:25	0:10	LOAD CURTAILMENT
98	1-Apr-2020	GULBARGA	110	KOGALI-ASTRO_SOLAR_IPP	KOGALI_110	13:50	14:10	0:20	LINE CLEAR AVAILED
99	1-Apr-2020	GULBARGA	110	RAICHUR-SINDHANOOR1	SINDHANOOR_110	2:56	3:01	0:05	LINE FAULT
100	1-Apr-2020	GULBARGA	220	RAICHUR-RTPS1, RTPS2	RAICHUR_220	11:10	13:50	2:40	LINE FAULT
101	1-Apr-2020	HASSAN	66	HV1	HAGARE_66	3:00	19:30	16:30	TRANSFORMER FAULT
102	1-Apr-2020	HASSAN	66	HV2	RAMESHWARNAGAR_66	6:28	6:45	0:17	LOAD CURTAILMENT
103	1-Apr-2020	HASSAN	66	HV2	SHRAVANABELAGOLA_66	12:50	14:05	1:15	LINE CLEAR AVAILED
104	1-Apr-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	18:50	18:55	0:05	LINE FAULT
105	1-Apr-2020	HASSAN	110	HV1	KONDENALU_110	6:28	6:39	0:11	LOAD CURTAILMENT
106	1-Apr-2020	HASSAN	110	SAGARA-SORABA	SAGARA_110	6:45	7:10	0:25	HAND TRIPPED
107	1-Apr-2020	HASSAN	110	SAGARA-SORABA	SAGARA_110	10:40	10:50	0:10	HAND TRIPPED
108	1-Apr-2020	HASSAN	110	SAGARA-SORABA	SHIRALKOPPA_220	6:08	6:25	0:17	LINE FAULT
109	1-Apr-2020	HASSAN	110	SAGARA-SORABA	SHIRALKOPPA_220	6:25	10:46	4:21	LINE FAULT
110	1-Apr-2020	HASSAN	110	SORABA-SHR220	SORABA_110	6:10	10:55	4:45	LINE FAULT
111	1-Apr-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	9:41	9:41	LINE FAULT
112	1-Apr-2020	MYSURU	66	CR NAGARA-GUNDLUPETE	TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, BHARGI_66 SINDHUVALLI_66	15:08	17:14	2:06	LINE CLEAR AVAILED
113	1-Apr-2020	MYSURU	66	CR NAGARA-KABBALLI	TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, BHARGI_66 SINDHUVALLI_66	15:08	17:14	2:06	LINE CLEAR AVAILED
114	1-Apr-2020	MYSURU	66	HV1	JAKKANAHALLY_66	9:12	9:22	0:09	TRANSFORMER FAULT
115	1-Apr-2020	MYSURU	66	HV1	JAKKANAHALLY_66	9:22	10:40	1:18	TRANSFORMER FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
116	1-Apr-2020	MYSURU	66	HV1	JAKKANAHALLY_66	10:40	11:43	1:02	TRANSFORMER FAULT
117	1-Apr-2020	MYSURU	66	HV1	JAKKANAHALLY_66	11:47	12:10	0:23	LINE CLEAR AVAILED
118	1-Apr-2020	MYSURU	66	HV1	JAKKANAHALLY_66	12:15	12:39	0:24	LINE CLEAR AVAILED
119	1-Apr-2020	MYSURU	66	HV1	NAGAMANGALA_66	6:27	6:44	0:16	LOAD CURTAILMENT
120	1-Apr-2020	MYSURU	66	HV1	PANDAVAPURA_66	6:27	6:38	0:10	LOAD CURTAILMENT
121	1-Apr-2020	MYSURU	66	HV1	PONNAMPET_66	17:06	17:18	0:12	TRANSFORMER FAULT
122	1-Apr-2020	MYSURU	66	HV1	SATHEGALA_66	6:28	6:42	0:13	LOAD CURTAILMENT
123	1-Apr-2020	MYSURU	66	HV2	HAMPAPURA_66	14:37	14:42	0:04	TRANSFORMER FAULT
124	1-Apr-2020	MYSURU	66	HV2	JAKKANAHALLY_66	11:24	11:36	0:12	TRANSFORMER FAULT
125	1-Apr-2020	MYSURU	66	HV2	KIRUGAVALU_66	6:27	7:29	1:01	LOAD CURTAILMENT
126	1-Apr-2020	MYSURU	66	HV2	MALAVALLI_66	17:07	17:13	0:06	TRANSFORMER FAULT
127	1-Apr-2020	MYSURU	66	HV2	PONNAMPET_66	6:27	6:36	0:08	LOAD CURTAILMENT
128	1-Apr-2020	MYSURU	66	HV2	PONNAMPET_66	17:06	17:15	0:09	TRANSFORMER FAULT
129	1-Apr-2020	MYSURU	66	HV2	SANTHESARAGUR_66	6:28	6:45	0:16	LOAD CURTAILMENT
130	1-Apr-2020	MYSURU	66	HV2	SANTHEMARAHALLI_66	6:28	6:59	0:31	LOAD CURTAILMENT
131	1-Apr-2020	MYSURU	66	HV3	PONNAMPET_66	17:06	17:13	0:07	TRANSFORMER FAULT
132	1-Apr-2020	MYSURU	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	8:28	8:33	0:05	LINE FAULT
133	1-Apr-2020	MYSURU	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	13:26	13:28	0:02	LINE FAULT
134	1-Apr-2020	MYSURU	66	KADAKOLA-SARAGUR 2	B MATKERE_66CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	8:28	8:33	0:05	LINE FAULT
135	1-Apr-2020	MYSURU	66	KADAKOLA-SARAGUR 2	B MATKERE_66CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	13:26	13:28	0:02	LINE FAULT
136	1-Apr-2020	MYSURU	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66, GVGUDI_66, BILIKERE_66, DMG_HALLI_66 & KRNAGARA_66	10:21	10:27	0:06	HAND TRIPPED
137	1-Apr-2020	MYSURU	66	MANDYA-CHIKKMANDYA	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66	16:39	16:52	0:13	LINE FAULT
138	1-Apr-2020	MYSURU	66	MANDYA-KK HALLI	KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	2:48	2:54	0:06	LINE FAULT
139	1-Apr-2020	MYSURU	66	MANDYA-KK HALLI	KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	3:23	5:02	1:39	LINE CLEAR AVAILED

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
140	1-Apr-2020	MYSURU	66	TUBINAKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	7:32	0:00	16:28	LINE FAULT
141	1-Apr-2020	MYSURU	66	TUBINAKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	17:26	17:43	0:16	LINE FAULT
142	1-Apr-2020	MYSURU	66	TUBINAKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	7:32	7:43	0:11	LINE FAULT
143	1-Apr-2020	MYSURU	66	TUBINAKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	17:26	17:43	0:16	LINE FAULT
144	1-Apr-2020	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	12:09	12:25	0:16	LINE FAULT
145	1-Apr-2020	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	KORATAGERE_66	14:23	14:53	0:29	LINE FAULT
146	1-Apr-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	14:23	15:50	1:26	LINE FAULT
147	1-Apr-2020	TUMKUR	66	BELADADARA-ANTHRASANAHALLI	BELADARA_66	14:48	14:55	0:07	MAIN SUPPLY FAILURE
148	1-Apr-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	4:10	4:21	0:10	LINE FAULT
149	1-Apr-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:56	7:06	0:10	LINE FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
150	1-Apr-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:02	10:11	0:08	LINE FAULT
151	1-Apr-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	5:45	6:16	0:30	LINE FAULT
152	1-Apr-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAP PANAHALI_66,HALUVAGALU _66,TELAGI_66	11:58	12:04	0:06	LINE FAULT
153	1-Apr-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAP PANAHALI_66,HALUVAGALU _66,TELAGI_66	12:45	13:02	0:16	LINE FAULT
154	1-Apr-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	12:10	12:21	0:11	LINE FAULT
155	1-Apr-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	16:53	17:03	0:09	LINE FAULT
156	1-Apr-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	19:02	19:06	0:04	LINE FAULT
157	1-Apr-2020	TUMKUR	66	TR-1	BENKIKERE_66	15:18	15:28	0:10	TRANSFORMER FAULT
158	1-Apr-2020	TUMKUR	66	TR-1	TUMKUR_66	14:25	15:01	0:36	HAND TRIPPED
159	1-Apr-2020	TUMKUR	66	TR-1	TUMKUR_66	16:02	16:09	0:06	HAND TRIPPED
160	1-Apr-2020	TUMKUR	66	TR-2	HOSADURGA_66	9:40	11:13	1:32	LINE CLEAR AVAILED
161	1-Apr-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	18:05	21:54	3:48	LINE FAULT
162	1-Apr-2020	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	22:11	22:16	00:05	LOAD CURTAILMENT
163	1-Apr-2020	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_110	10:23	12:09	01:46	LINE CLEAR AVAILED
164	1-Apr-2020	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	22:11	22:15	00:04	LOAD CURTAILMENT
165	1-Apr-2020	BAGALKOT	110	MAMADAPUR-BABALESHWAR	BABALESHWAR_110	06:20	06:50	00:30	LINE FAULT
166	1-Apr-2020	BAGALKOT	110	AB SOLAR-BELLATTI	BELLATTI_110	15:56	16:12	00:16	LINE CLEAR AVAILED
167	1-Apr-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	02:23	02:42	00:19	LINE FAULT
168	1-Apr-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	04:02	04:21	00:19	LINE FAULT
169	1-Apr-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	22:15	22:43	00:28	LINE FAULT
170	1-Apr-2020	BAGALKOT	110	CHIKKODI220-NIPPANI	NIPPANI_110	01:26	01:48	00:22	LINE FAULT
171	1-Apr-2020	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	19:46	19:58	00:12	TRANSFORMER FAULT
172	1-Apr-2020	BAGALKOT	110	110/11KV,HV3	HANGAL_110	22:10	22:19	00:09	TRANSFORMER FAULT
173	1-Apr-2020	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33 , MYTRA SOLAR_33	22:11	22:22	00:11	LOAD CURTAILMENT
174	1-Apr-2020	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	14:52	15:16	00:24	LINE CLEAR AVAILED
175	1-Apr-2020	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	22:08	22:25	00:17	LINE CLEAR AVAILED
176	1-Apr-2020	BAGALKOT	110	MAMADAPUR(B)-TOALBAGI	TODALBAGI_110	02:45	02:51	00:06	LINE FAULT
177	1-Apr-2020	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	06:28	06:45	00:17	LOAD CURTAILMENT
178	1-Apr-2020	BAGALKOT	110	110/11KV,HV2	NIPPANI_110	02:03	23:59	21:56	LINE CLEAR AVAILED
179	1-Apr-2020	BAGALKOT	110	110/11KV,HV1	SANKESHWAR_110	22:11	22:27	00:16	LOAD CURTAILMENT
180	1-Apr-2020	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	18:00	18:25	00:25	TRANSFORMER FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
181	1-Apr-2020	BAGALKOT	110	110/33KV,HV2	SAVALAGI_110,HIREPADASAL AGI_33,KALBILAGI_33,TUNGAL LIS_33	22:11	22:31	00:20	LOAD CURTAILMENT
182	1-Apr-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	17:00	18:24	01:24	LINE CLEAR AVOIDED
183	1-Apr-2020	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	11:41	16:40	04:59	LINE FAULT
184	1-Apr-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	LOKAPUR_110	16:25	17:44	01:19	LINE FAULT
185	2-Apr-2020	BAGALKOT	220	RAVIURJA1-ATHANI	ATHANI_220	15:30	23:59	08:29	LINE CLEAR AVOIDED
186	2-Apr-2020	BAGALKOT	110	ATHANI220-BALIGERI(TAUSHI)	BALIGERI(TAUSHI)_110	18:47	18:57	00:10	LINE FAULT
187	2-Apr-2020	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	12:40	13:46	01:06	LINE CLEAR AVOIDED
188	2-Apr-2020	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	12:41	13:35	00:54	HAND TRIPPED
189	2-Apr-2020	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	15:21	16:18	00:57	HAND TRIPPED
190	2-Apr-2020	BAGALKOT	110	110/11KV, HV1	GULEDAGUDDA_110	08:04	08:13	00:09	TRANSFORMER FAULT
191	2-Apr-2020	BAGALKOT	110	110/33KV, HV2	HANGAL_110,LAXMIPURA_33,BOMMANAHALLI_33,AKKIALUR_33	07:28	07:42	00:14	TRANSFORMER FAULT
192	2-Apr-2020	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	10:40	11:14	00:34	LINE CLEAR AVOIDED
193	2-Apr-2020	BAGALKOT	110	ITANAL-RAIBAG1&2	RAIBAG_110	08:32	11:04	02:32	LINE CLEAR AVOIDED
194	2-Apr-2020	BAGALKOT	110	110/11KV, HV1	SHIROL_110	17:56	18:13	00:17	LINE CLEAR AVOIDED
195	2-Apr-2020	BAGALKOT	110	110/33KV, HV2	UTTUR_110, VANTAGODI_33, YADWAD_33	12:35	12:42	00:07	TRANSFORMER FAULT
196	2-Apr-2020	BAGALKOT	110	110/33KV, HV2	UTTUR_110, VANTAGODI_33, YADWAD_33	14:28	17:22	02:54	TRANSFORMER FAULT
197	2-Apr-2020	BAGALKOT	110	110/11KV, HV2	KANABARGI LAYOUT_110	11:38	12:51	01:13	LINE CLEAR AVOIDED
198	2-Apr-2020	BAGALKOT	110	110/11KV, HV4	VADAGOAN_110	15:33	22:44	07:11	TRANSFORMER FAULT
199	2-Apr-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, HALSANGI_33	05:28	06:09	00:41	TRANSFORMER FAULT
200	2-Apr-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, HALSANGI_33	22:03	22:13	00:10	TRANSFORMER FAULT
201	2-Apr-2020	BAGALKOT	110	CHIKKODI1-RAIBAG	RAIBAG_110	08:33	11:05	02:32	LINE CLEAR AVOIDED
202	2-Apr-2020	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	13:09	13:49	00:40	TRANSFORMER FAULT
203	2-Apr-2020	BENGALURU	66	HV2	SULIBELE	15:07	15:17	00:10	TRANSFORMER FAULT
204	2-Apr-2020	BENGALURU	66	HV1	PALLICHERLU	10:12	10:21	00:08	LINE CLEAR AVOIDED
205	2-Apr-2020	BENGALURU	66	HV1	RANGANDODDI	13:23	15:32	02:08	LINE CLEAR AVOIDED
206	2-Apr-2020	BENGALURU	66	NRS 220 - MYSORE ROAD 2	VIJAYANAGARA	17:36	18:51	01:15	LINE FAULT
207	2-Apr-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	12:12	12:19	00:06	LINE FAULT
208	2-Apr-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:37	15:38	00:01	LINE CLEAR AVOIDED
209	2-Apr-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	14:38	14:48	00:09	LINE FAULT



SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
210	2-Apr-2020	BENGALURU	66	KEMPANAHALLI - BIDADI	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	08:34	09:28	00:53	LINE FAULT
211	2-Apr-2020	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI	11:19	13:15	01:56	LINE CLEAR AVAILED
212	2-Apr-2020	BENGALURU	66	KGF - BEML (EHT)	BEML (EHT)	11:19	13:14	01:55	LINE CLEAR AVAILED
213	2-Apr-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:25	12:30	00:05	LINE FAULT
214	2-Apr-2020	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	15:28	15:40	00:11	LINE CLEAR AVAILED
215	2-Apr-2020	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	17:41	17:52	00:10	LINE CLEAR AVAILED
216	2-Apr-2020	BENGALURU	66	MANYATHA 220 - HOSKOTE 1	MANYATHA 66	11:39	12:22	00:42	MAIN SUPPLY FAILURE
217	2-Apr-2020	GULBARGA	220	HALBURGA-HUMNABAD2	HALBURGA_220	16:11	17:07	00:56	LINE FAULT
218	2-Apr-2020	GULBARGA	110	HV2	GURUGUNTA_110	08:40	08:50	00:10	TRANSFORMER FAULT
219	2-Apr-2020	GULBARGA	110	SINDHANOOR220-SIRUGUPPA	DHAHDESUGUR_110, SIRUGUPPA_110, TEKKALAKOTE_110, NSLSUGARS_IPP	12:55	13:50	00:55	LINE FAULT
220	2-Apr-2020	GULBARGA	110	HV2	YELBURGA_110	08:40	08:50	00:10	TRANSFORMER FAULT
221	2-Apr-2020	GULBARGA	110	HALBURGA-KOLHAR1, KOLHAR2	KOLHAR_110, JANAWADA_110, NSSKSUGARS_IPP	16:11	17:07	00:56	LINE FAULT
222	2-Apr-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	16:01	16:25	00:24	LINE FAULT
223	2-Apr-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:01	16:33	00:32	LINE FAULT
224	2-Apr-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	16:20	16:45	00:25	MAIN SUPPLY FAILURE
225	2-Apr-2020	HASSAN	110	JOG-NK1	MGHE JOG	09:48	13:15	03:27	NFBC ISSUED
226	2-Apr-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:01	16:25	00:24	LINE FAULT
227	2-Apr-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:01	16:32	00:31	LINE FAULT
228	2-Apr-2020	HASSAN	66	HV2	BELUR_66	17:17	17:30	00:13	TRANSFORMER FAULT
229	2-Apr-2020	HASSAN	66	HV2	BELUR_66	20:03	20:09	00:06	HAND TRIPPED
230	2-Apr-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:31	10:36	00:05	LINE FAULT
231	2-Apr-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	08:40	08:58	00:18	LINE FAULT
232	2-Apr-2020	HASSAN	66	DIDIGA-CRPATNA	DIDIGA_66	07:20	07:50	00:30	LINE FAULT
233	2-Apr-2020	HASSAN	66	HV1	HAGARE_66	14:20	18:25	04:05	LINE CLEAR AVAILED
234	2-Apr-2020	HASSAN	66	HV1	HALEBEEDU_66	07:39	08:28	00:49	TRANSFORMER FAULT
235	2-Apr-2020	MYSURU	66	HD KOTE-KADAKOLA	HDKOTE_66 & ANTHARSANTHE_66	07:46	08:01	00:15	LINE FAULT
236	2-Apr-2020	MYSURU	66	HV3	KRPET_66	14:57	17:01	02:03	LINE CLEAR AVAILED
237	2-Apr-2020	MYSURU	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	10:11	11:30	01:19	LINE CLEAR AVAILED

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
238	2-Apr-2020	MYSURU	66	KUSHALANAGARA 220-MYSORE-2	BETTADHAPURA_66,CHUNCH UNKATTE_66, KITTUR_66,RAVANDUR_66, KRNAGARA_66 , BILIKERE_66, GVGUDI_66 & DMG_HALLI_66	10:11	10:45	00:34	LINE FAULT
239	2-Apr-2020	MYSURU	66	MEGALAPURA-SFC	THUMBLA_66, CHIDRAVALLI_66,VYASRAJPU RA_66 (UPTO 11:33:00), GARGESHWARI_66(UPTO 11:33:00) & BGPURA_66( UPTO 10:40:00)	10:28	15:23	04:54	NFBC ISSUED
240	2-Apr-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	BETTADHAPURA_66,CHUNCH UNKATTE_66, KITTUR_66,RAVANDUR_66	14:50	14:55	00:04	LINE FAULT
241	2-Apr-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66, HARADANAHALLI_66, KESLAGERE_66,BGNAGARA_66, BASARALU_66, ADICHUNCHANAGIRI_66 & VADERALLI_66	15:41	15:46	00:05	LINE FAULT
242	2-Apr-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66, HARADANAHALLI_66, KESLAGERE_66,BGNAGARA_66, ADICHUNCHANAGIRI_66 & VADERALLI_66	16:30	16:34	00:03	LINE FAULT
243	2-Apr-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66, HARADANAHALLI_66, KESLAGERE_66,BGNAGARA_66, ADICHUNCHANAGIRI_66 & VADERALLI_66	17:43	17:51	00:08	LINE FAULT
244	2-Apr-2020	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	16:12	17:04	00:52	LOAD CURTAILMENT
245	2-Apr-2020	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	16:12	17:03	00:51	LOAD CURTAILMENT
246	2-Apr-2020	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR (BG NAGAR)	YEDIYUR_66	07:01	07:19	00:17	LINE FAULT
247	2-Apr-2020	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA 1	CHITRADURGA_220	21:19	22:13	00:53	LINE CLEAR AVAILED
248	2-Apr-2020	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	22:03	22:08	00:04	LINE FAULT
249	2-Apr-2020	TUMKUR	66	TR-1	CHITRADURGA_66	22:03	22:08	00:04	TRANSFORMER FAULT
250	2-Apr-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	03:27	04:27	01:00	LINE CLEAR AVAILED
251	2-Apr-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	03:26	04:24	00:57	HAND TRIPPED

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
252	2-Apr-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:08	22:14	00:05	HAND TRIPPED
253	2-Apr-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	03:27	04:24	00:57	HAND TRIPPED
254	2-Apr-2020	TUMKUR	66	HINDASGHATTA-HIRIYUR1	HINDASGHATTA_66	20:28	20:32	00:03	LINE FAULT
255	2-Apr-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	18:05	18:41	00:36	TRANSFORMER FAULT
256	2-Apr-2020	TUMKUR	66	TR-1	VENKATAPURA_66	16:18	17:21	01:02	LINE CLEAR AVAILED
257	3-Apr-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	11:15	11:35	00:20	TRANSFORMER FAULT
258	3-Apr-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	05:58	06:12	00:14	LINE FAULT
259	3-Apr-2020	BAGALKOT	110	110/33KV,HV2	HANAGAL_110,LAXMIPUR_33,BELAGALPET_33,BOMMANALLI_33,AKKIALUR_33	03:03	03:08	00:05	TRANSFORMER FAULT
260	3-Apr-2020	BAGALKOT	110	110/33KV,HV2	HANAGAL_110,LAXMIPUR_33,BELAGALPET_33,BOMMANALLI_33,AKKIALUR_33	04:08	04:12	00:04	TRANSFORMER FAULT
261	3-Apr-2020	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	12:54	15:37	02:43	LINE CLEAR AVAILED
262	3-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110	16:29	16:37	00:08	TRANSFORMER FAULT
263	3-Apr-2020	BAGALKOT	110	110/33KV,HV1	ZALKI_110	21:35	21:40	00:05	TRANSFORMER FAULT
264	3-Apr-2020	BAGALKOT	110	BELGAUM220-BELGAM	BEGAUM_110	18:57	19:08	00:11	LINE FAULT
265	3-Apr-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA,DASAHAWAR A,SANKALGERE,BEVOOR,SHIV ANAHALLI	05:56	06:06	00:10	LINE FAULT
266	3-Apr-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI,CHIKKENAHALLI,SHIVANAHALLI,CHANNAPATNA,SANKALGERE,BEVOOR,DASHAWARA	10:04	10:12	00:08	LINE FAULT
267	3-Apr-2020	BENGALURU	66	ATTUR YELAHANKA - DG4	SAHAKARINAGAR	06:59	07:28	00:29	LINE FAULT
268	3-Apr-2020	BENGALURU	66	SAHAKARINAGAR - MANYATHA TECH PARK 220	SAHAKARINAGAR	15:15	15:20	00:05	LOAD CHANGE OVER
269	3-Apr-2020	BENGALURU	66	KANASAWADI - SRS 220	KANASAWADI	07:05	07:10	00:05	LOAD CHANGE OVER
270	3-Apr-2020	HASSAN	110	HV2	AJJAMPURA_110	12:04	12:51	00:47	HAND TRIPPED
271	3-Apr-2020	HASSAN	110	HV2	ANANDAPURA_110	06:40	07:03	00:23	TRANSFORMER FAULT
272	3-Apr-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:13	16:00	00:47	MAIN SUPPLY FAILURE
273	3-Apr-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:13	15:57	00:44	MAIN SUPPLY FAILURE
274	3-Apr-2020	HASSAN	110	SLVPWR	GURUVAYANAKERE_110	15:15	15:57	00:42	MAIN SUPPLY FAILURE
275	3-Apr-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:13	16:00	00:47	LINE FAULT
276	3-Apr-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:13	15:55	00:42	LINE FAULT
277	3-Apr-2020	HASSAN	110	HV2	KONAJE_110	10:50	11:27	00:37	LINE CLEAR AVAILED
278	3-Apr-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:34	13:59	03:25	LINE CLEAR AVAILED
279	3-Apr-2020	HASSAN	66	HV2	KIADB_66	09:21	12:09	02:48	LINE CLEAR AVAILED
280	3-Apr-2020	MYSURU	66	HV 2	BGNAGARA_66	12:35	13:35	01:00	LINE CLEAR AVAILED

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
281	3-Apr-2020	MYSURU	66	MANDYA - MC3 Chikka Mandya	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 CHIKKA_MANDYA_66 HAMPAPURA_66	12:25	12:30	00:05	LINE FAULT
282	3-Apr-2020	MYSURU	66	HV 1	YETHAMBADI_66	03:05	03:10	00:05	TRANSFORMER FAULT
283	3-Apr-2020	MYSURU	66	220 kV C R NAGARA-KABBALLI	TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, BHARGI_66 SINDHUVALLI_66	17:17	17:24	00:07	LINE FAULT
284	3-Apr-2020	MYSURU	66	220 kV C R NAGARA-GUNDLUPETE	TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, BHARGI_66 SINDHUVALLI_66	17:17	17:23	00:06	LINE FAULT
285	3-Apr-2020	MYSURU	220	CR NAGARA-HV1	CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 KUNTHUR_66 SATHEGALA_66 YELANDUR_66 , CHIDRAVALLI_66 THAYURU_66 TNARASIPURA_66 THUMLA_66 BHARGI_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 SINDHUVALLI_66	18:34	18:43	00:09	LINE FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
286	3-Apr-2020	MYSURU	220	CR NAGARA-HV2	CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 KUNTHUR_66 SATHEGALA_66 YELANDUR_66, CHIDRAVALLI_66 THAYURU_66 TNARASIPURA_66 THUMLA_66 BHARGI_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 SINDHUVALI_66	18:34	18:43	00:09	LINE FAULT
287	3-Apr-2020	MYSURU	66	220 kV C R NAGARA- CHANDAKAVADI	CHANDAKAVADI_66	18:38	20:30	01:52	LINE CLEAR AVAILED
288	3-Apr-2020	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	00:12	00:31	00:18	LINE FAULT
289	3-Apr-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	08:45	08:55	00:10	LINE FAULT
290	3-Apr-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALI	SASUVEHALI_66,CHANNAGI RI_66	11:31	11:40	00:09	LINE FAULT
291	3-Apr-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALI	SASUVEHALI_66,CHANNAGI RI_66	12:13	12:19	00:06	LINE FAULT
292	3-Apr-2020	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	17:30	17:40	00:10	LINE FAULT
293	3-Apr-2020	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66	18:28	18:35	00:07	LINE FAULT
294	3-Apr-2020	TUMKUR	66	TR-2	TAVAREKERE(C)_66	03:04	03:06	00:01	TRANSFORMER FAULT
295	3-Apr-2020	TUMKUR	66	TR-2	TAVAREKERE(C)_66	14:01	14:04	00:02	TRANSFORMER FAULT
296	3-Apr-2020	TUMKUR	66	TR-2	TAVAREKERE(C)_66	15:05	15:18	00:12	TRANSFORMER FAULT
297	3-Apr-2020	TUMKUR	66	TR-1	YEDIYUR_66	14:20	14:40	00:19	TRANSFORMER FAULT
298	3-Apr-2020	TUMKUR	220	HIRIYUR220-MADHUGIRI	HIRIYUR_220	14:23	16:09	01:45	LINE FAULT
299	4-Apr-2020	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	11:37	16:52	5:15	LINE CLEAR AVAILED

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
300	4-Apr-2020	BAGALKOT	110	ANKOLA-KUMATA2	KUMTA_110	9:21	13:34	4:13	LINE CLEAR AVAILED
301	4-Apr-2020	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	16:16	20:21	4:05	LINE FAULT
302	4-Apr-2020	BAGALKOT	110	110/11KV, HV1	BAGALKOT_110	17:35	23:19	5:44	LINE CLEAR AVAILED
303	4-Apr-2020	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	17:35	23:43	6:08	LINE CLEAR AVAILED
304	4-Apr-2020	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	17:07	23:59	6:52	LINE FAULT
305	4-Apr-2020	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	18:21	18:48	0:27	LINE FAULT
306	4-Apr-2020	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	BHUTNAL_110, TAKKALKI_110,TORVI_110, TIKOTA_110	11:15	12:50	1:35	LINE CLEAR AVAILED
307	4-Apr-2020	BAGALKOT	110	110/11KV, HV1	BILAGI_110	9:42	10:30	0:48	TRANSFORMER FAULT
308	4-Apr-2020	BAGALKOT	110	GOPPANAKOPPA-NARAGUND	NARAGUND_110	17:37	23:59	6:22	LINE FAULT
309	4-Apr-2020	BAGALKOT	110	110/33KV, HV1&HV2	HANGAL_110, AKKIALUR_33, BOMMANAHALLI_33, BELAGALPET_33, LAXMIPURA_33	8:01	8:12	0:11	TRANSFORMER FAULT
310	4-Apr-2020	BAGALKOT	110	110/11KV, HV3	HANGAL_110	16:34	16:47	0:13	TRANSFORMER FAULT
311	4-Apr-2020	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	16:34	16:46	0:12	LINE FAULT
312	4-Apr-2020	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	18:09	18:14	0:05	LINE FAULT
313	4-Apr-2020	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	10:13	10:26	0:13	HAND TRIPPED
314	4-Apr-2020	BAGALKOT	110	110/11KV, HV4	KERUR_110	18:11	19:00	0:49	LINE CLEAR AVAILED
315	4-Apr-2020	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	11:43	12:50	1:07	LINE CLEAR AVAILED
316	4-Apr-2020	BAGALKOT	110	BPCL-NARAGUND	NARAGUND_110	18:29	18:39	0:10	HAND TRIPPED
317	4-Apr-2020	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	17:01	18:26	1:25	LINE FAULT
318	4-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	22:06	22:10	0:04	TRANSFORMER FAULT
319	4-Apr-2020	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	6:16	6:42	0:26	HAND TRIPPED
320	4-Apr-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, SOMANTHPURA, THIMAMPALLI	14:17	15:40	1:23	MAIN SUPPLY FAILURE
321	4-Apr-2020	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 2	BAGEPALLI	14:17	15:40	1:23	MAIN SUPPLY FAILURE
322	4-Apr-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	13:45	13:51	0:06	LINE FAULT
323	4-Apr-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	13:54	14:44	0:50	LINE FAULT
324	4-Apr-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:13	15:14	0:01	LINE CLEAR AVAILED
325	4-Apr-2020	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	14:17	15:40	1:23	MAIN SUPPLY FAILURE
326	4-Apr-2020	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR, BAGEPALLI	14:17	15:40	1:23	MAIN SUPPLY FAILURE
327	4-Apr-2020	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	14:17	15:40	1:23	MAIN SUPPLY FAILURE

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
328	4-Apr-2020	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	14:17	15:40	1:23	MAIN SUPPLY FAILURE
329	4-Apr-2020	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	14:17	15:18	1:01	MAIN SUPPLY FAILURE
330	4-Apr-2020	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	14:17	15:18	1:01	MAIN SUPPLY FAILURE
331	4-Apr-2020	BENGALURU	66	HV1	HULLENAHALLI	21:04	21:11	0:06	TRANSFORMER FAULT
332	4-Apr-2020	BENGALURU	66	HV2	NANGALI	16:44	17:09	0:24	LINE CLEAR AVAILED
333	4-Apr-2020	BENGALURU	220	KIADB DB PURA 220 - GOWRIBIDANUR	KIADB DB PURA 220	14:42	15:18	0:36	LINE FAULT
334	4-Apr-2020	BENGALURU	66	MELUR - VIJAYAPURA	MELUR	17:40	17:45	0:05	LOAD CHANGE OVER
335	4-Apr-2020	BENGALURU	66	SIDLAGATTA - MELUR	MELUR	16:06	16:11	0:04	LOAD CHANGE OVER
336	4-Apr-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:43	21:53	0:10	LINE FAULT
337	4-Apr-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:43	21:53	0:10	LINE FAULT
338	4-Apr-2020	GULBARGA	66	ITTAGI-HBHALLI	HAGARIBOMMANAHALLI_66, UPANAYAKANAHALLI_66	3:50	3:57	0:07	LINE FAULT
339	4-Apr-2020	HASSAN	110	HV2	AJJAMPURA_110	14:20	15:45	1:25	TRANSFORMER FAULT
340	4-Apr-2020	HASSAN	110	HV1	SHIVPURA_110	15:05	15:43	0:38	LINE CLEAR AVAILED
341	4-Apr-2020	MYSURU	66	HV2	B G NAGARA -	14:30	15:00	0:30	LINE CLEAR AVAILED
342	4-Apr-2020	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	12:12	14:24	2:12	NFBC ISSUED
343	4-Apr-2020	MYSURU	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	18:14	18:22	0:08	HAND TRIPPED
344	4-Apr-2020	MYSURU	66	HV2	KIRUGAVALU_66	11:40	13:44	2:04	LINE CLEAR AVAILED
345	4-Apr-2020	MYSURU	66	HV2	KIRUGAVALU_66	16:07	22:57	6:50	LINE CLEAR AVAILED
346	4-Apr-2020	MYSURU	66	HV2	KRPET_66	16:53	19:23	2:30	TRANSFORMER FAULT
347	4-Apr-2020	MYSURU	66	HV1	PANDAVAPURA_66	15:10	15:13	0:02	HAND TRIPPED
348	4-Apr-2020	MYSURU	66	TUBINAKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	8:29	8:42	0:13	LINE FAULT
349	4-Apr-2020	MYSURU	66	TUBINAKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	8:29	8:42	0:13	LINE FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
350	4-Apr-2020	MYSURU	66	TUBINAKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	15:14	15:28	0:14	LINE FAULT
351	4-Apr-2020	MYSURU	66	TUBINAKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	15:14	15:28	0:14	LINE FAULT
352	4-Apr-2020	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66, HARADANAHALLI_66, KESLAGERE_66,BGNAGARA_6 6, ADICHUNCHANAGIRI_66 & VADERALLI_66	16:29	16:36	0:06	LINE FAULT
353	4-Apr-2020	TUMKUR	220	TR-2	HIRIYUR_220	5:45	5:57	0:12	TRANSFORMER FAULT
354	4-Apr-2020	TUMKUR	220	TR-1	KBCROSS_220	22:30	23:07	0:37	TRANSFORMER FAULT
355	4-Apr-2020	TUMKUR	220	TR-2	KBCROSS_220	22:30	23:03	0:33	TRANSFORMER FAULT
356	4-Apr-2020	TUMKUR	220	MADHUGIRI 220kV- VENKATAPURA	MADHUGIRI 220kV	14:15	15:16	1:00	LINE FAULT
357	4-Apr-2020	TUMKUR	110	TR-2	TURUVEKERE_110	6:27	6:54	0:26	TRANSFORMER FAULT
358	4-Apr-2020	TUMKUR	110	TR-1	BANDIHALLI_110	8:20	8:40	0:20	LINE CLEAR AVAILED
359	4-Apr-2020	TUMKUR	110	TR-3	GUBBI_110	14:28	15:32	1:03	LINE CLEAR AVAILED
360	4-Apr-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110 , SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	23:02	23:10	0:08	HAND TRIPPED
361	4-Apr-2020	TUMKUR	110	TR-1(LV1SIDE)	KBCROSS_220	22:30	23:04	0:33	TRANSFORMER FAULT
362	4-Apr-2020	TUMKUR	110	TR-2(LV 2)	KBCROSS_220	22:30	23:07	0:37	TRANSFORMER FAULT
363	4-Apr-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALI_110	23:02	23:14	0:12	HAND TRIPPED
364	4-Apr-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	17:17	17:50	0:32	LINE CLEAR AVAILED
365	4-Apr-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NE ELAGUNDA_66	6:40	6:43	0:03	LINE FAULT
366	4-Apr-2020	TUMKUR	66	TR-2	KUNIGAL_66	13:45	16:55	3:10	LINE CLEAR AVAILED
367	4-Apr-2020	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	14:27	14:44	0:16	MAIN SUPPLY FAILURE
368	4-Apr-2020	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	17:57	18:17	0:19	LINE FAULT



SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
369	4-Apr-2020	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	19:52	19:59	0:06	MAIN SUPPLY FAILURE
370	5-Apr-2020	BAGALKOT	220	NARENDRA1-AMBEWADI	AMBEWADI_220	16:49	16:56	0:07	HAND TRIPPED
371	5-Apr-2020	BAGALKOT	220	NARENDRA2-AMBEWADI	AMBEWADI_220	16:12	19:54	3:42	LINE FAULT
372	5-Apr-2020	BAGALKOT	220	NAGIHARI2-AMBEWADI	AMBEWADI_220	18:06	23:59	5:53	LINE FAULT
373	5-Apr-2020	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWADA_110	17:21	18:02	0:41	LINE FAULT
374	5-Apr-2020	BAGALKOT	220	RAVI URJA2-ATHANI	ATHANI_220	11:23	15:18	3:55	LINE CLEAR AVAILED
375	5-Apr-2020	BAGALKOT	220	RAVI URJA1-ATHANI	ATHANI_220	0:00	15:18	15:18	LINE CLEAR AVAILED
376	5-Apr-2020	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	14:28	14:51	0:23	LINE FAULT
377	5-Apr-2020	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	12:35	14:05	1:30	LINE CLEAR AVAILED
378	5-Apr-2020	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	8:00	23:59	15:59	TRANSFORMER FAULT
379	5-Apr-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	12:37	14:09	1:32	LINE CLEAR AVAILED
380	5-Apr-2020	BAGALKOT	220	CHIKKODI-BELGAUM1	BELGAUM_220	0:00	10:24	10:24	LINE CLEAR AVAILED
381	5-Apr-2020	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	14:47	23:59	9:12	LINE FAULT
382	5-Apr-2020	BAGALKOT	110	BELGAUM-NEHARUNAGAR	NEHARUNAGAR_110	14:34	15:39	1:05	LINE FAULT
383	5-Apr-2020	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	0:00	11:49	11:49	LINE CLEAR AVAILED
384	5-Apr-2020	BAGALKOT	220	HAVERI220-HANAGAL	HANAGAL_110	14:16	14:30	0:14	LINE FAULT
385	5-Apr-2020	BAGALKOT	110	110/11KV,HV3	HANAGAL_110	8:48	13:10	4:22	TRANSFORMER FAULT
386	5-Apr-2020	BAGALKOT	220	220/110KV,HV1,LV1	HAVERI_220	8:02	9:55	1:53	LINE CLEAR AVAILED
387	5-Apr-2020	BAGALKOT	110	ITANAL-HIDIKAL	HIDIKAL_110	15:37	15:57	0:20	HAND TRIPPED
388	5-Apr-2020	BAGALKOT	110	110/11KV,HV2	HUNAGUND_33,KARADI_33, AMINAGAD_33,MYTRA SOLAR	15:00	15:08	0:08	TRANSFORMER FAULT
389	5-Apr-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	18:33	18:35	0:02	LINE CLEAR AVAILED
390	5-Apr-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	22:43	22:47	0:04	LINE CLEAR AVAILED
391	5-Apr-2020	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	7:24	8:11	0:47	LINE FAULT
392	5-Apr-2020	BENGALURU	66	GUNDAMGERE - DB PURA 220	GUNDAMGERE	20:15	20:20	0:05	LOAD CHANGE OVER
393	5-Apr-2020	BENGALURU	66	HV1	B G ROAD	11:35	12:09	0:34	TRANSFORMER FAULT
394	5-Apr-2020	BENGALURU	66	HV1	HOSPALYA CIRCLE	20:35	20:44	0:09	TRANSFORMER FAULT
395	5-Apr-2020	BENGALURU	66	HV2	JIGANI LINK ROAD	17:30	17:35	0:05	LINE CLEAR AVAILED
396	5-Apr-2020	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KNEGERI SATELLITE TOWN	13:50	13:55	0:05	LOAD CHANGE OVER
397	5-Apr-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	22:23	22:27	0:03	LINE FAULT
398	5-Apr-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	22:27	22:44	0:17	LINE FAULT
399	5-Apr-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	23:18	23:22	0:03	LINE FAULT
400	5-Apr-2020	BENGALURU	220	MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66	MANYATHA TECH PARK 66	10:15	10:35	0:20	LINE CLEAR AVAILED
401	5-Apr-2020	BENGALURU	66	SIR M V LAYOUT - VRISHABHAVATHI 220	SIR MV LAYOUT,KENGERI SATELLITE TOWN	0:16	1:50	1:34	LINE FAULT
402	5-Apr-2020	BENGALURU	66	SIR M V LAYOUT - VRISHABHAVATHI 220	SIR MV LAYOUT	10:30	11:30	1:00	LINE CLEAR AVAILED

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
403	5-Apr-2020	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	10:10	11:07	0:57	LINE FAULT
404	5-Apr-2020	BENGALURU	66	T K HALLI 220 - MANDYA 2	MANDYA,KK DODDI,KM DODDI	6:33	6:44	0:11	LINE FAULT
405	5-Apr-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY	ELECTRONIC CITY,INFOSYS	17:22	17:32	0:10	LOAD CHANGE OVER
406	5-Apr-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY	ELECTRONIC CITY,INFOSYS	22:25	22:30	0:05	LOAD CHANGE OVER
407	5-Apr-2020	GULBARGA	110	HV2	YELBURGA_110	18:55	19:05	0:10	TRANSFORMER FAULT
408	5-Apr-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	19:54	20:20	0:26	LINE FAULT
409	5-Apr-2020	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, GIRIYAPURA_66, SOVENAHALLI_66,MAGALA_6 6,TBDAM	22:50	23:10	0:20	LINE FAULT
410	5-Apr-2020	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, GIRIYAPURA_66, SOVENAHALLI_66,MAGALA_6 6,TBDAM	5:04	5:15	0:11	LINE FAULT
411	5-Apr-2020	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	16:04	16:10	0:06	TRANSFORMER FAULT
412	5-Apr-2020	GULBARGA	66	HV1	CHORNOOR_66	22:15	22:25	0:10	LINE CLEAR AVAILED
413	5-Apr-2020	GULBARGA	66	HV2	CHORNOOR_66	22:15	22:20	0:05	LINE CLEAR AVAILED
414	5-Apr-2020	GULBARGA	66	HV1	CHORNOOR_66	7:10	7:30	0:20	LINE CLEAR AVAILED
415	5-Apr-2020	GULBARGA	66	CHORNOOR-KUDLIGI	CHORNOOR_66	8:45	9:05	0:20	MAIN SUPPLY FAILURE
416	5-Apr-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:30	18:32	2:02	LINE CLEAR AVAILED
417	5-Apr-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	19:37	23:59	4:22	LINE CLEAR AVAILED
418	5-Apr-2020	HASSAN	220	GOOPALAP-HSN400	GOPALAPURA_220	16:03	19:33	3:30	LINE FAULT
419	5-Apr-2020	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	10:37	11:53	1:16	LINE CLEAR AVAILED
420	5-Apr-2020	HASSAN	66	HASSN22-SKPURA	HASSAN_220	17:08	17:23	0:15	LINE FAULT
421	5-Apr-2020	HASSAN	66	HASSN22-UDDUR	HASSAN_220	17:45	17:50	0:05	HAND TRIPPED
422	5-Apr-2020	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	17:00	17:30	0:30	LINE FAULT
423	5-Apr-2020	HASSAN	66	HV1	HALEBEEDU_66	11:09	12:25	1:16	LINE CLEAR AVAILED
424	5-Apr-2020	HASSAN	66	KAMDLI-HASSAN	KANDLI_66	17:05	17:30	0:25	MAIN SUPPLY FAILURE
425	5-Apr-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	17:05	17:30	0:25	LINE FAULT
426	5-Apr-2020	HASSAN	66	HV1	MAGGE_66	17:08	17:40	0:32	MAIN SUPPLY FAILURE
427	5-Apr-2020	HASSAN	66	HV2	MAGGE_66	17:08	17:40	0:32	MAIN SUPPLY FAILURE
428	5-Apr-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:07	10:36	0:29	LINE FAULT
429	5-Apr-2020	HASSAN	66	HV1	SAKLESHPUR_66	17:08	17:35	0:27	MAIN SUPPLY FAILURE
430	5-Apr-2020	HASSAN	66	HV1	UDAYAPURA_66	10:45	10:50	0:05	TRANSFORMER FAULT
431	5-Apr-2020	HASSAN	66	HV1	UDAYAPURA_66	19:20	19:25	0:05	TRANSFORMER FAULT
432	5-Apr-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	14:42	15:24	0:42	LINE FAULT
433	5-Apr-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	15:24	17:43	2:19	LINE FAULT
434	5-Apr-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	17:43	19:03	1:20	LINE FAULT
435	5-Apr-2020	MYSURU	66	HV2	COWDALLI_66	20:25	20:29	0:04	TRANSFORMER FAULT
436	5-Apr-2020	MYSURU	66	HV2	DODDINADUVADI_66	6:04	6:14	0:10	TRANSFORMER FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
437	5-Apr-2020	MYSURU	66	HAMPAPURA-BASARALU	BASARALU_66, BESAGARAHALLI_66, KOPPA_66	22:37	22:42	0:04	LINE FAULT
438	5-Apr-2020	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	18:49	18:57	0:07	LINE FAULT
439	5-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	11:20	11:21	0:01	LINE FAULT
440	5-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	11:20	11:21	0:01	LINE FAULT
441	5-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	13:38	13:40	0:02	LINE FAULT
442	5-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	13:38	13:40	0:02	LINE FAULT
443	5-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	14:14	14:18	0:04	LINE FAULT
444	5-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	14:13	14:18	0:04	LINE FAULT
445	5-Apr-2020	MYSURU	66	HV2	KIRUGAVALU_66	12:04	15:40	3:35	LINE CLEAR AVAILED
446	5-Apr-2020	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	14:28	14:43	0:14	LINE FAULT
447	5-Apr-2020	MYSURU	66	MADIKERI-SUNTIKOPPA	MADIKERI_66	14:31	14:50	0:18	HAND TRIPPED
448	5-Apr-2020	MYSURU	66	HV5	SFCSHIVA_66	0:37	23:59	23:21	LINE CLEAR AVAILED
449	5-Apr-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	17:44	17:51	0:07	LINE FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
450	5-Apr-2020	MYSURU	66	TK HALLI-MANDYA M2 LINE	KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	6:33	6:45	0:12	LINE FAULT
451	5-Apr-2020	MYSURU	66	MANDYA-KADUKOTHANAHALLI	KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	7:03	7:08	0:05	LINE FAULT
452	5-Apr-2020	MYSURU	66	MANDYA-KADUKOTHANAHALLI	KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	7:18	7:23	0:05	LINE FAULT
453	5-Apr-2020	MYSURU	66	HV1	DUNDANAHALLI_66	11:30	11:35	0:05	TRANSFORMER FAULT
454	5-Apr-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	18:54	21:52	2:58	LINE CLEAR AVAILED
455	5-Apr-2020	TUMKUR	220	TR-1	BIDARE_110	18:20	18:22	0:02	TRANSFORMER FAULT
456	5-Apr-2020	TUMKUR	110	TR-1	TANDAGA_110	5:57	6:08	0:11	TRANSFORMER FAULT
457	5-Apr-2020	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	YEDIYUR_66	12:46	13:01	0:14	LINE FAULT
458	5-Apr-2020	TUMKUR	66	TR-2	HALUVAGALU_66	22:55	23:03	0:07	TRANSFORMER FAULT
459	5-Apr-2020	TUMKUR	66	HARAPPANAHALLI-SUZLON 1	SUZLON_IPP_66	17:39	17:49	0:10	LINE CLEAR AVAILED
460	5-Apr-2020	TUMKUR	66	HARAPPANAHALLI-SUZLON 2	SUZLON_IPP_66	17:39	17:49	0:10	LINE CLEAR AVAILED
461	5-Apr-2020	TUMKUR	66	TR-3	HARIYABBE_66	21:16	21:26	0:10	TRANSFORMER FAULT
462	5-Apr-2020	TUMKUR	66	TR-2	KUNIGAL_66	10:04	11:08	1:04	LINE CLEAR AVAILED
463	5-Apr-2020	TUMKUR	66	TR-2	KUNIGAL_66	16:30	16:55	0:25	LINE CLEAR AVAILED
464	5-Apr-2020	TUMKUR	66	TR-1	YEDIYUR_66	9:33	10:06	0:32	TRANSFORMER FAULT
465	6-Apr-2020	BAGALKOT	110	110/11KV, HV2	AIGALI_110	9:11	9:16	0:05	TRANSFORMER FAULT
466	6-Apr-2020	BAGALKOT	110	110/11KV, HV2	AINAPUR_110	11:44	11:52	0:08	TRANSFORMER FAULT
467	6-Apr-2020	BAGALKOT	110	AMBEWADI-NK2	HALIYAL_110	14:20	15:55	1:35	LINE CLEAR AVAILED
468	6-Apr-2020	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	15:05	15:11	0:06	TRANSFORMER FAULT
469	6-Apr-2020	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	16:05	16:51	0:46	LINE CLEAR AVAILED
470	6-Apr-2020	BAGALKOT	110	BAGALKOT220-LOKAPUR	LOKAPUR_110, SALAHALLI_110	4:29	4:48	0:19	LINE FAULT
471	6-Apr-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	5:43	6:19	0:36	LINE FAULT
472	6-Apr-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	5:43	6:20	0:37	LINE FAULT
473	6-Apr-2020	BAGALKOT	110	110/11KV, HV1	BILAGI_110	11:05	12:01	0:56	LINE CLEAR AVAILED
474	6-Apr-2020	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	7:07	7:22	0:15	TRANSFORMER FAULT
475	6-Apr-2020	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110, RATTIHALLI_110	12:02	12:42	0:40	LINE CLEAR AVAILED
476	6-Apr-2020	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110, RATTIHALLI_110	18:34	18:45	0:11	LINE FAULT
477	6-Apr-2020	BAGALKOT	110	SHIVASAGAR SUGARS- SALAHALLI	SALAHALLI_110	4:50	5:11	0:21	HAND TRIPPED
478	6-Apr-2020	BAGALKOT	220	NAGIHARI3- HUBLI	HUBLI_220	10:40	15:38	4:58	LINE CLEAR AVAILED
479	6-Apr-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	16:22	23:59	7:37	LINE FAULT
480	6-Apr-2020	BAGALKOT	220	HARTI1&2-GADAG	GADAG_220	0:00	9:01	9:01	LINE CLEAR AVAILED
481	6-Apr-2020	BAGALKOT	220	BELGAUM-NARENDRA1	BELAGAUM_220	15:47	21:14	5:27	LINE FAULT
482	6-Apr-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELAGAUM_220	16:19	18:01	1:42	LINE CLEAR AVAILED
483	6-Apr-2020	BAGALKOT	220	BELGAUM-NARENDRA2	BELAGAUM_220	17:58	21:14	3:16	LINE CLEAR AVAILED

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
484	6-Apr-2020	BAGALKOT	110	110/11KV, HV2	RATTIHALLI_110	11:58	12:55	0:57	HAND TRIPPED
485	6-Apr-2020	BAGALKOT	110	110/33KV, HV3	RATTIHALLI_110, MASUR_33, HALLUR_33	12:00	12:55	0:55	HAND TRIPPED
486	6-Apr-2020	BAGALKOT	220	BELGAUM-NARENDRA1	BELAGAUM_220	0:00	11:26	11:26	LINE CLEAR AVAILED
487	6-Apr-2020	BENGALURU	66	ADUGODI - HSR 1	ADUGODI,BOSCH	6:52	7:18	0:26	MAIN SUPPLY FAILURE
488	6-Apr-2020	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI,BOSCH	15:40	15:50	0:10	LOAD CHANGE OVER
489	6-Apr-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHIKKENAHALLI,SHIVANAHALLI,CHANNAPATNA,SANKALGERE,BEVOOR,DASHAWARA	19:07	19:15	0:08	LINE FAULT
490	6-Apr-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	21:26	21:37	0:11	LINE FAULT
491	6-Apr-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	19:38	20:25	0:46	LINE FAULT
492	6-Apr-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	16:17	16:27	0:09	LINE FAULT
493	6-Apr-2020	BENGALURU	66	HSR 220 - ADUGODI 66	ADUGODI,BOSCH	6:51	7:18	0:27	LINE FAULT
494	6-Apr-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	21:44	21:48	0:04	TRANSFORMER FAULT
495	6-Apr-2020	BENGALURU	66	HV1	DEVANAHALLI	23:22	23:30	0:08	TRANSFORMER FAULT
496	6-Apr-2020	BENGALURU	66	HV1	DEVANAHALLI	23:22	23:30	0:07	TRANSFORMER FAULT
497	6-Apr-2020	BENGALURU	66	HV1	DOMMASANDRA	20:16	20:32	0:15	TRANSFORMER FAULT
498	6-Apr-2020	BENGALURU	66	HV1	JIGANI LINK ROAD	21:05	21:10	0:05	LINE CLEAR AVAILED
499	6-Apr-2020	BENGALURU	66	HV1	MITTEMARI 220	20:09	22:24	2:15	MAIN SUPPLY FAILURE
500	6-Apr-2020	BENGALURU	66	HV1	PALLICHERLU	8:25	8:40	0:15	LINE CLEAR AVAILED
501	6-Apr-2020	BENGALURU	66	HV1	HOSPALYA CIRCLE	6:25	6:33	0:08	TRANSFORMER FAULT
502	6-Apr-2020	BENGALURU	220	HV2	HSR 220	6:51	7:10	0:19	TRANSFORMER FAULT
503	6-Apr-2020	BENGALURU	220	HV2	HSR 220	11:52	12:03	0:11	TRANSFORMER FAULT
504	6-Apr-2020	BENGALURU	66	HV2	ANEKAL	8:31	8:32	0:01	LOAD CHANGE OVER
505	6-Apr-2020	BENGALURU	66	HV2	BAIRAKUR	5:50	10:30	4:40	TRANSFORMER FAULT
506	6-Apr-2020	BENGALURU	66	HV2	HOSKOTE 66	20:52	22:57	2:04	TRANSFORMER FAULT
507	6-Apr-2020	BENGALURU	66	HV2	THAYALUR	8:43	8:51	0:08	LINE CLEAR AVAILED
508	6-Apr-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	6:40	6:42	0:02	LINE CLEAR AVAILED
509	6-Apr-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	8:38	10:33	1:54	LINE CLEAR AVAILED
510	6-Apr-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	17:38	18:01	0:23	LINE FAULT
511	6-Apr-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	17:39	18:06	0:27	LINE FAULT
512	6-Apr-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	17:53	18:36	0:43	LINE FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
513	6-Apr-2020	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	14:24	14:30	0:06	LOAD CHANGE OVER
514	6-Apr-2020	BENGALURU	66	SOLDEVANAHALLI - YELAHANAKA 220	SOLDEVANAHALLI	13:34	13:51	0:17	LOAD CHANGE OVER
515	6-Apr-2020	BENGALURU	66	YELAHANKA 220 - RAJANUKUNTE	RAJANUKUNTE	20:21	20:37	0:16	LINE FAULT
516	6-Apr-2020	BENGALURU	66	YELAHANKA 220 - SOLDEVANAHALLI	SOLDEVANAHALLI	13:35	13:51	0:16	LINE FAULT
517	6-Apr-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HALAGURU, DODDALAHALLI, HONNIGANAHALLI	20:22	23:59	3:37	LINE FAULT
518	6-Apr-2020	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	20:04	20:19	0:15	LINE FAULT
519	6-Apr-2020	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	20:24	20:50	0:26	LINE FAULT
520	6-Apr-2020	GULBARGA	220	SINDHANOOR220-LINGAPUR	SINDHANOOR_220	17:30	20:05	2:35	LINE FAULT
521	6-Apr-2020	GULBARGA	110	HV2	CHITAGUPPA_110	5:45	7:20	1:35	TRANSFORMER FAULT
522	6-Apr-2020	GULBARGA	110	GURGUNTA-LINGASUGUR	GURUGUNTA_110,LJVL_IPP,K HEL_IPP	3:20	3:25	0:05	LINE FAULT
523	6-Apr-2020	GULBARGA	110	GURGUNTA-LJVL_IPP	LJVL_IPP	3:20	3:40	0:20	LINE FAULT
524	6-Apr-2020	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	12:50	13:30	0:40	LINE CLEAR AVAILED
525	6-Apr-2020	GULBARGA	66	CJHALLI-KUDLIGI	CJHALLI_66	0:00	1:30	1:30	NFBC ISSUED
526	6-Apr-2020	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	8:10	8:20	0:10	LINE CLEAR AVAILED
527	6-Apr-2020	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	8:25	9:05	0:40	LINE CLEAR AVAILED
528	6-Apr-2020	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	9:05	9:35	0:30	LINE CLEAR AVAILED
529	6-Apr-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:02	11:08	0:06	LINE FAULT
530	6-Apr-2020	HASSAN	110	HV1	ANANDPURA_110	11:43	12:38	0:55	LINE CLEAR AVAILED
531	6-Apr-2020	HASSAN	110	HV1	BANAVARA_110	20:24	23:59	3:35	LINE CLEAR AVAILED
532	6-Apr-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	8:00	13:01	5:01	NFBC ISSUED
533	6-Apr-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	8:00	13:01	5:01	LINE CLEAR AVAILED
534	6-Apr-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	16:02	16:06	0:04	LINE FAULT
535	6-Apr-2020	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	1:05	1:23	0:18	LINE FAULT
536	6-Apr-2020	HASSAN	66	HASSN22-HN PURA	HASSAN_220	14:06	18:22	4:16	LINE FAULT
537	6-Apr-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:32	12:15	0:43	MAIN SUPPLY FAILURE
538	6-Apr-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	11:29	12:12	0:43	LINE CLEAR AVAILED
539	6-Apr-2020	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	9:39	12:33	2:54	LINE FAULT
540	6-Apr-2020	HASSAN	66	HV1	DUDDA_66	8:52	12:36	3:44	TRANSFORMER FAULT
541	6-Apr-2020	HASSAN	66	HV1	HAGARE_66	2:39	12:29	9:50	TRANSFORMER FAULT
542	6-Apr-2020	HASSAN	66	HV2	HOLEHONNUR_66	10:32	11:01	0:29	LINE CLEAR AVAILED
543	6-Apr-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	1:06	1:20	0:14	LINE FAULT
544	6-Apr-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	20:05	20:15	0:10	LINE FAULT

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
545	6-Apr-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	20:18	20:43	0:25	LINE FAULT
546	6-Apr-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	20:59	21:08	0:09	LINE FAULT
547	6-Apr-2020	HASSAN	66	HV1	MAGGE_66	1:06	1:22	0:16	MAIN SUPPLY FAILURE
548	6-Apr-2020	HASSAN	66	HV2	MAGGE_66	1:06	1:22	0:16	MAIN SUPPLY FAILURE
549	6-Apr-2020	HASSAN	66	HV1	SAKLESH PURA_66	11:50	12:07	0:17	TRANSFORMER FAULT
550	6-Apr-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	1:05	1:22	0:17	LINE FAULT
551	6-Apr-2020	MYSURU	66	HV2	AKKIHEBBAL_66	7:55	8:06	0:10	TRANSFORMER FAULT
552	6-Apr-2020	MYSURU	66	HV2	BILIKERE_66	10:22	10:27	0:05	TRANSFORMER FAULT
553	6-Apr-2020	MYSURU	66	HV2	COWDALLI_66	23:19	23:27	0:08	TRANSFORMER FAULT
554	6-Apr-2020	MYSURU	66	HD KOTE-KADAKOLA	ANTHARSANTHE_66, HDKOTE_66	13:58	14:12	0:14	LINE FAULT
555	6-Apr-2020	MYSURU	66	HV1	HUNSUR_66	8:59	12:48	3:48	LINE CLEAR AVAILED
556	6-Apr-2020	MYSURU	66	JAKKANAHALLI-NAGMANGALA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	22:45	22:53	0:08	LINE FAULT
557	6-Apr-2020	MYSURU	66	HV1	KIADBMANDYA_66	14:06	14:07	0:01	HAND TRIPPED
558	6-Apr-2020	MYSURU	66	HV2	KOPPA_66	15:18	15:24	0:05	TRANSFORMER FAULT
559	6-Apr-2020	MYSURU	66	HV 2	MALAVALLI_66	4:03	4:09	0:06	TRANSFORMER FAULT
560	6-Apr-2020	MYSURU	66	HV 2	MALAVALLI_66	16:40	16:49	0:09	TRANSFORMER FAULT
561	6-Apr-2020	MYSURU	66	HV1	PONNAMPET_66	15:42	15:52	0:10	HAND TRIPPED
562	6-Apr-2020	MYSURU	66	HV2	PONNAMPET_66	15:42	15:52	0:09	HAND TRIPPED
563	6-Apr-2020	MYSURU	66	HV3	PONNAMPET_66	15:42	15:52	0:09	HAND TRIPPED
564	6-Apr-2020	MYSURU	66	HV1	SANIVARASANTHE_66	18:55	19:05	0:09	TRANSFORMER FAULT
565	6-Apr-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	15:59	16:04	0:05	LINE FAULT
566	6-Apr-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	17:53	17:58	0:05	LINE FAULT
567	6-Apr-2020	MYSURU	66	VAJMANGALA-KADKOLA 1	AYRALLI_66, MARADIHUNDI_66	18:44	18:49	0:04	LINE FAULT
568	6-Apr-2020	MYSURU	66	VAJMANGALA-KADKOLA 1	AYRALLI_66, MARADIHUNDI_66	23:51	23:59	0:07	LINE FAULT
569	6-Apr-2020	MYSURU	66	MANDYA -KADUKOTHANAHALLI	KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	8:28	8:42	0:14	LINE FAULT
570	6-Apr-2020	MYSURU	66	HV 2	KRPET_66	9:55	10:15	0:20	TRANSFORMER FAULT
571	6-Apr-2020	MYSURU	66	HV 2	BGNAGARA_66	16:05	16:40	0:35	LINE CLEAR AVAILED
572	6-Apr-2020	TUMKUR	220	T-2	ANTHRASANAHALLI_220	11:33	12:49	1:15	TRANSFORMER FAULT
573	6-Apr-2020	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	16:48	19:50	3:01	LINE FAULT
574	6-Apr-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALI_110	2:04	2:53	0:49	HAND TRIPPED
575	6-Apr-2020	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	16:53	17:00	0:07	MAIN SUPPLY FAILURE

SL.NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
576	6-Apr-2020	TUMKUR	110	NITTUR 220kv- KADABA	KADABA_110	17:12	17:22	0:09	MAIN SUPPLY FAILURE
577	6-Apr-2020	TUMKUR	110	NITTUR 220kv- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_1 10, SAMPIGE_110, DODDAGUNI_110	0:22	0:36	0:14	MAIN SUPPLY FAILURE
578	6-Apr-2020	TUMKUR	110	NITTUR 220kv- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_1 10, SAMPIGE_110, DODDAGUNI_110	1:52	2:40	0:48	MAIN SUPPLY FAILURE
579	6-Apr-2020	TUMKUR	110	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	11:43	12:52	1:08	LINE CLEAR AVAILED
580	6-Apr-2020	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	15:35	16:59	1:24	LINE FAULT
581	6-Apr-2020	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	11:42	12:51	1:08	LINE CLEAR AVAILED
582	6-Apr-2020	TUMKUR	66	TR-2	ANTHRASANAHALI_220	12:25	12:50	0:24	TRANSFORMER FAULT
583	6-Apr-2020	TUMKUR	66	ANTHRASANAHALI 220KV- MELEKOTE	MELKOTE_66, BADDIHALI_66	11:42	11:57	0:15	HAND TRIPPED
584	6-Apr-2020	TUMKUR	66	ANTHRASANAHALI 220KV- TUMKUR	TUMKUR_66	11:42	12:02	0:20	HAND TRIPPED
585	6-Apr-2020	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	6:16	6:45	0:29	LINE FAULT
586	6-Apr-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	8:47	9:35	0:48	MAIN SUPPLY FAILURE
587	6-Apr-2020	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	12:31	13:10	0:39	LINE FAULT
588	6-Apr-2020	TUMKUR	66	TR-&TR-2	TUMKUR_66	11:34	12:03	0:28	LINE CLEAR AVAILED