

# 400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 01.01.2019 to 07.01.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
1	1-Jan-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	10:18	14:31	4:13	LINE CLEAR AVAILED
2	1-Jan-19	BAGALKOT	110	SUPA2-AMBEWADI	AMBEWADI_220	10:32	12:26	1:54	LINE CLEAR AVAILED
3	1-Jan-19	BAGALKOT	110	SUPA1-AMBEWADI	AMBEWADI_220	12:37	14:30	1:53	LINE CLEAR AVAILED
4	1-Jan-19	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	8:16	8:27	0:11	TRANSFORMER FAULT
5	1-Jan-19	BAGALKOT	110	GADAG220-DAMBAL2	DAMBAL_110	6:42	11:31	4:49	LINE FAULT
6	1-Jan-19	BAGALKOT	110	BAGEWADI220-MATTIHAL	MATTIHAL_110	0:03	0:13	0:10	HAND TRIPPED
7	1-Jan-19	BAGALKOT	220	BELGAUM1-CHIKKODI	CHIKKODI_220	21:54	23:59	2:05	HAND TRIPPED
8	1-Jan-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110, HORTI_33	23:15	23:16	0:01	TRANSFORMER FAULT
9	1-Jan-19	BAGALKOT	110	110/11KV,HV3	SAVALGI_110	14:30	14:35	0:05	TRANSFORMER FAULT
10	1-Jan-19	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	0:00	8:01	8:01	HAND TRIPPED
11	1-Jan-19	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	12:26	12:34	0:08	HAND TRIPPED
12	1-Jan-19	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	12:36	12:42	0:06	HAND TRIPPED
13	1-Jan-19	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	7:57	8:09	0:12	LINE FAULT
14	1-Jan-19	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	16:43	16:57	0:13	LINE FAULT
15	1-Jan-19	BANGALORE	66	GOWRIBIDANUR - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	13:22	15:05	1:42	LINE FAULT
16	1-Jan-19	BANGALORE	66	GOWRIBIDANUR - BAGEPALLI 2	BAGEPALLI , VIDHURASHWATHA , GUNDLU KOTTUR	13:22	15:05	1:43	LINE CLEAR AVAILED
17	1-Jan-19	BANGALORE	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	11:42	13:05	1:23	LINE CLEAR AVAILED
18	1-Jan-19	BANGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:10	12:20	0:10	LINE FAULT
19	1-Jan-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	14:23	14:30	0:06	LOAD CHANGE OVER
20	1-Jan-19	BANGALORE	66	HV2	SARJAPURA	11:26	12:20	0:53	LINE CLEAR AVAILED
21	1-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	13:47	14:25	0:37	LINE FAULT
22	1-Jan-19	BANGALORE	66	RAJANAKUNTE - YELAHANKA 220	RAJANAKUNTE	15:19	15:26	0:07	LOAD CHANGE OVER
23	1-Jan-19	BANGALORE	66	RAJANKUNTE - D B PURA 220	RAJANKUNTE	18:52	18:56	0:03	LOAD CHANGE OVER
24	1-Jan-19	BANGALORE	66	HV2	APPEAREL PARK	15:57	16:16	0:18	TRANSFORMER FAULT
25	1-Jan-19	BANGALORE	66	HV2	C STATION	8:02	8:07	0:05	LOAD CHANGE OVER
26	1-Jan-19	BANGALORE	66	HV2	C STATION	13:18	13:20	0:02	LOAD CHANGE OVER
27	1-Jan-19	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	6:54	7:39	0:44	LINE FAULT
28	1-Jan-19	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	6:54	7:37	0:42	LINE FAULT
29	1-Jan-19	BANGALORE	220	HV1	HEBBAL 220	6:54	7:39	0:44	TRANSFORMER FAULT
30	1-Jan-19	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	MARALWADI, GODUR, HANUMANTHNAGAR, YEDAMADU	6:32	6:42	0:10	LINE FAULT
31	1-Jan-19	GULBARGA	110	RAJESHWAR-SASTAPUR	RAJESHWAR_110	12:20	13:01	0:41	HAND TRIPPED
32	1-Jan-19	GULBARGA	110	RAJESWAR-WARDA	RAJESHWAR_110	12:21	14:11	1:50	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
33	1-Jan-19	GULBARGA	110	HANUMANAL -HIREGONNAGAR	HANUMANAL_110	8:30	8:35	0:05	LINE FAULT
34	1-Jan-19	GULBARGA	110	BETAGERA-KSHVCMNT_SLR	BETAGERA_110	6:42	7:03	0:21	LINE FAULT
35	1-Jan-19	GULBARGA	66	HIREHADAGAL_ITTAGI	HIREHADAGALI_66	1:34	1:49	0:15	LINE FAULT
36	1-Jan-19	HASSAN	400	UPCL-HASSAN2	UPCL_GEN	0:00	7:37	7:37	LINE CLEAR AVAILED
37	1-Jan-19	HASSAN	400	UPCL-HASSAN2	UPCL_GEN	18:00	23:59	5:59	LINE CLEAR AVAILED
38	1-Jan-19	HASSAN	220	UPCL-ICT1LV	UPCL_GEN	7:00	23:59	16:59	LINE CLEAR AVAILED
39	1-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSSHM_220	12:12	16:08	3:56	LINE FAULT
40	1-Jan-19	HASSAN	220	SHRAVTHY-SHIMOGA1	SHRAVTHY_GEN	12:12	16:07	3:55	LINE FAULT
41	1-Jan-19	HASSAN	110	HV2	KAVOOR_220	9:31	13:40	4:09	LINE CLEAR AVAILED
42	1-Jan-19	HASSAN	110	HV2	KAVOOR_220	13:47	23:59	10:12	LINE CLEAR AVAILED
43	1-Jan-19	HASSAN	66	HV1	DODDAKADNUR_66	11:07	11:15	0:08	TRANSFORMER FAULT
44	1-Jan-19	HASSAN	66	HV1	GENDEHALLI_66	18:15	19:29	1:14	TRANSFORMER FAULT
45	1-Jan-19	HASSAN	66	HNPR2-HASS1	HNPURA_220	12:51	12:55	0:04	LINE FAULT
46	1-Jan-19	HASSAN	66	HV1	MOSALEHOSALLI_66	11:35	11:56	0:21	LINE CLEAR AVAILED
47	1-Jan-19	MYSORE	66	HV2	KOPPA 66-	15:16	16:04	0:47	LINE CLEAR AVAILED
48	1-Jan-19	MYSORE	220	KR PETE 220-YACHANAHALLI	KR PETE 220KV STATION AND ITS DOWN STREAM STATIONS	13:05	13:23	0:18	LINE FAULT
49	1-Jan-19	MYSORE	66	HV1	PANDAVAPURA	10:50	11:33	0:43	LINE CLEAR AVAILED
50	1-Jan-19	MYSORE	66	HV1	PG PALYA-	18:16	18:37	0:20	TRANSFORMER FAULT
51	1-Jan-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	MARDIHUNDI & AYRAHALLI	6:22	6:38	0:15	LINE FAULT
52	1-Jan-19	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	12:46	15:12	2:26	LINE CLEAR AVAILED
53	1-Jan-19	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	15:13	18:26	3:12	LINE CLEAR AVAILED
54	1-Jan-19	TUMKUR	110	TR-1	KALLUR_110	22:09	23:18	1:08	HAND TRIPPED
55	1-Jan-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	23:37	23:45	0:07	LINE FAULT
56	1-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	11:45	14:50	3:05	HAND TRIPPED
57	1-Jan-19	TUMKUR	66	TR-2	CHANNAGIRI_66	22:55	22:59	0:04	TRANSFORMER FAULT
58	1-Jan-19	TUMKUR	66	TR-2	CHELURU_66	10:39	10:50	0:11	TRANSFORMER FAULT
59	1-Jan-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	6:26	6:34	0:08	LINE FAULT
60	1-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:39	17:44	9:04	HAND TRIPPED
61	1-Jan-19	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	CHIKKAJAJUR_66,MAYAKONDA_66,SASALUH ALLA_66	13:06	13:57	0:50	MAIN SUPPLY FAILURE
62	1-Jan-19	TUMKUR	66			9:43	13:06	3:22	MAIN SUPPLY FAILURE
63	1-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	8:42	11:38	2:56	MAIN SUPPLY FAILURE
64	1-Jan-19	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	9:43	13:06	3:22	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
65	1-Jan-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	15:37	15:55	0:18	LINE FAULT
66	1-Jan-19	TUMKUR	66	TR-1	HULIYURDURGA_66	18:59	19:10	0:10	TRANSFORMER FAULT
67	1-Jan-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:40	12:53	1:13	LINE FAULT
68	2-Jan-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	15:23	17:34	2:11	LINE CLEAR AVAILED
69	2-Jan-19	BAGALKOT	110	BAGEWADI220-MAMDAPUR1&2	MAMADAPUR_110	10:00	18:13	8:13	LINE CLEAR AVAILED
70	2-Jan-19	BAGALKOT	110	BAGEWADI220-MUDEBIHAL	MUDEBIHAL_110	16:10	18:31	2:21	LINE CLEAR AVAILED
71	2-Jan-19	BAGALKOT	110	BAGEWADI220-NIDAGUNDI	NIDAGUNDI_110	16:10	16:54	0:44	LINE CLEAR AVAILED
72	2-Jan-19	BAGALKOT	110	110/33KV,HV2	BELGAUM_110,NO 33KV STATION INTERRUPTED	11:33	13:31	1:58	LINE CLEAR AVAILED
73	2-Jan-19	BAGALKOT	110	220/110KV,LV2	BELGAUM_220	2:02	6:51	4:49	HAND TRIPPED
74	2-Jan-19	BAGALKOT	110	CHIKKODI220-SANKESHWARA	SANKESHWARA_110	6:08	6:20	0:12	LINE FAULT
75	2-Jan-19	BAGALKOT	110	BAGEWADI220-MATTIHAL	MATTIHAL_110	10:09	18:33	8:24	LINE CLEAR AVAILED
76	2-Jan-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	6:23	6:24	0:01	LINE FAULT
77	2-Jan-19	BAGALKOT	110	MATRIX WIND-MUKARTHAL	MUKARTHAL_110	16:58	17:21	0:23	MAIN SUPPLY FAILURE
78	2-Jan-19	BAGALKOT	110	110/33KV,HV1	KUMTA_110,ANKOLA 33KV,HONNAVAR 33KV	12:14	13:20	1:06	HAND TRIPPED
79	2-Jan-19	BAGALKOT	110	110/11KV,HV5	INDI_110	14:57	15:39	0:42	LINE CLEAR AVAILED
80	2-Jan-19	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	6:27	6:29	0:02	MAIN SUPPLY FAILURE
81	2-Jan-19	BAGALKOT	110	VISHWANATH SUGARS-HUKKERI	HUKKERI_110	6:27	6:30	0:03	MAIN SUPPLY FAILURE
82	2-Jan-19	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	10:25	12:06	1:41	LINE CLEAR AVAILED
83	2-Jan-19	BAGALKOT	110	110/33KV,HV4	HARIHAR-HOSPET_66,NO 33KV STATION INTERRUPTED	6:38	10:19	3:41	TRANSFORMER FAULT
84	2-Jan-19	BAGALKOT	110	110/33KV,HV3	HARIHAR-HOSPET_66,MUDENUR_33	7:03	14:42	7:39	TRANSFORMER FAULT
85	2-Jan-19	BAGALKOT	110	110/33KV,HV3	HARIHAR-HOSPET_66,MUDENUR_33	14:42	17:15	2:33	TRANSFORMER FAULT
86	2-Jan-19	BAGALKOT	110	ITNAL-RAIBAG	RAIBAG_110	12:40	13:50	1:10	LINE FAULT
87	2-Jan-19	BANGALORE	66	HV1	KONDASPURA	15:18	15:41	0:23	TRANSFORMER FAULT
88	2-Jan-19	BANGALORE	66	HV2	NARASAPURA	14:48	14:58	0:10	TRANSFORMER FAULT
89	2-Jan-19	BANGALORE	66	ADUGODI - HAL 2	KORMANGALA, KC VALLEY, NAL (EHT)	13:25	15:02	1:37	LINE CLEAR AVAILED
90	2-Jan-19	BANGALORE	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	15:17	15:46	0:28	MAIN SUPPLY FAILURE
91	2-Jan-19	BANGALORE	66	HSR LAYOUT 220 - ST JOHNS WOOD	ST JOHNS WOOD	15:17	15:33	0:15	MAIN SUPPLY FAILURE
92	2-Jan-19	BANGALORE	66	HV1	HSR LAYOUT 220	15:17	15:35	0:17	MAIN SUPPLY FAILURE
93	2-Jan-19	BANGALORE	66	HV2	HSR LAYOUT 220	15:17	15:35	0:17	MAIN SUPPLY FAILURE
94	2-Jan-19	BANGALORE	66	HV3	HSR LAYOUT 220	15:17	15:35	0:17	MAIN SUPPLY FAILURE
95	2-Jan-19	BANGALORE	66	HV1	ITI	11:26	11:54	0:28	LINE CLEAR AVAILED
96	2-Jan-19	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	15:17	15:33	0:16	MAIN SUPPLY FAILURE
97	2-Jan-19	BANGALORE	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	15:17	15:31	0:13	LINE FAULT
98	2-Jan-19	BANGALORE	66	HV2	ELECTRONIC CITY	9:43	9:48	0:04	LINE CLEAR AVAILED
99	2-Jan-19	BANGALORE	66	HV2	VR DODDI	14:20	16:42	2:22	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
100	2-Jan-19	BANGALORE	66	HV2	POTTERY ROAD	16:05	16:09	0:04	LINE CLEAR AVAILED
101	2-Jan-19	GULBARGA	220	HV1	RAICHUR_220	16:25	18:15	1:50	HAND TRIPPED
102	2-Jan-19	GULBARGA	220	HV2	RAICHUR_220	16:25	16:30	0:05	HAND TRIPPED
103	2-Jan-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	15:41	16:10	0:29	LINE FAULT
104	2-Jan-19	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110	6:20	6:25	0:05	LINE FAULT
105	2-Jan-19	GULBARGA	110	HV3	KUSTAGI_220	16:35	16:40	0:05	LINE CLEAR AVAILED
106	2-Jan-19	GULBARGA	110	HV3	KUSTAGI_220	3:41	4:49	1:08	TRANSFORMER FAULT
107	2-Jan-19	GULBARGA	110	HV1	SIRWAR_110	18:13	18:20	0:07	TRANSFORMER FAULT
108	2-Jan-19	GULBARGA	110	HV1	SIRWAR_110	19:41	19:59	0:18	LINE CLEAR AVAILED
109	2-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	12:09	13:17	1:08	HAND TRIPPED
110	2-Jan-19	GULBARGA	110	HV2	KOLHAR_110	17:05	17:15	0:10	TRANSFORMER FAULT
111	2-Jan-19	GULBARGA	110	SINDHANOOR-SIRIGUPPA	MANVI_110,MADALAPUR_110	23:21	23:24	0:03	LINE FAULT
112	2-Jan-19	GULBARGA	110	HV3	KUSTAGI_220	18:17	18:32	0:15	LINE CLEAR AVAILED
113	2-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	0:00	1:21	1:21	LINE CLEAR AVAILED
114	2-Jan-19	HASSAN	220	HV2	HNPUA_220	14:08	15:00	0:52	TRANSFORMER FAULT
115	2-Jan-19	HASSAN	66	HNPR2-CRPTN	HNPUA_220	14:08	18:54	4:46	LINE FAULT
116	2-Jan-19	HASSAN	66	HNPR2-CRPTN	HNPUA_220	19:45	19:47	0:02	HAND TRIPPED
117	2-Jan-19	HASSAN	66	HNPR2-HASS1	HNPUA_220	14:19	14:48	0:29	HAND TRIPPED
118	2-Jan-19	HASSAN	66	HNPR2-HASS2	HNPUA_220	14:19	14:48	0:29	HAND TRIPPED
119	2-Jan-19	HASSAN	66	HNPR2-HASS3	HNPUA_220	14:13	14:48	0:35	HAND TRIPPED
120	2-Jan-19	HASSAN	66	HNPR2-HNPR1	HNPUA_220	14:19	14:47	0:28	HAND TRIPPED
121	2-Jan-19	HASSAN	66	LV1	HNPUA_220	14:13	14:35	0:22	HAND TRIPPED
122	2-Jan-19	HASSAN	66	LV2	HNPUA_220	14:08	15:06	0:58	TRANSFORMER FAULT
123	2-Jan-19	HASSAN	66	HNPR2-MYSOR1	HNPUA_220	10:11	11:46	1:35	LINE CLEAR AVAILED
124	2-Jan-19	HASSAN	66	HNPR2-MYSOR1	HNPUA_220	14:13	14:55	0:42	HAND TRIPPED
125	2-Jan-19	HASSAN	66	HNPR2-MYSOR2	HNPUA_220	10:11	11:51	1:40	LINE CLEAR AVAILED
126	2-Jan-19	HASSAN	66	HNPR2-MYSOR2	HNPUA_220	14:13	14:47	0:34	HAND TRIPPED
127	2-Jan-19	HASSAN	220	KEMAR-KAVOOR1	KEMAR_220	10:23	14:34	4:11	LINE CLEAR AVAILED
128	2-Jan-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:11	18:26	7:15	LINE CLEAR AVAILED
129	2-Jan-19	HASSAN	220	MRSSHMKBCRS	MRSMSG_220	10:04	12:48	2:44	LINE CLEAR AVAILED
130	2-Jan-19	HASSAN	220	MSEZ-KBCRS	MSEZ_220	10:23	14:41	4:18	NBFC ISSUED
131	2-Jan-19	HASSAN	220	VARAHI-KEMAR3	VARAHI_GEN	10:57	14:41	3:44	NBFC ISSUED
132	2-Jan-19	HASSAN	220	GOPALAP-HNPUR21	GOPLPURA_220	14:08	14:45	0:37	LINE FAULT
133	2-Jan-19	HASSAN	110	HV1	BHADRAVATY_110	9:52	10:04	0:12	HAND TRIPPED
134	2-Jan-19	HASSAN	110	HV2	KAVOOR_220	0:00	18:20	18:20	LINE CLEAR AVAILED
135	2-Jan-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL-110	8:29	18:07	9:38	LINE CLEAR AVAILED
136	2-Jan-19	HASSAN	110	HV1	SAGARA_110	10:41	11:27	0:46	TRANSFORMER FAULT
137	2-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:56	10:14	2:18	LINE CLEAR AVAILED
138	2-Jan-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	1:00	10:09	9:09	LINE FAULT
139	2-Jan-19	HASSAN	66	HV1	BYCHANAHALLY_66	17:10	17:15	0:05	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
140	2-Jan-19	HASSAN	66	HV1	BYCHANAHALLY_66	18:10	18:20	0:10	HAND TRIPPED
141	2-Jan-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGLR_66	1:43	10:05	8:22	LINE FAULT
142	2-Jan-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADNUR_66	10:35	11:37	1:02	MAIN SUPPLY FAILURE
143	2-Jan-19	HASSAN	66	HV1	DODDAKADNUR_66	10:21	11:51	1:30	MAIN SUPPLY FAILURE
144	2-Jan-19	HASSAN	66	DODDAKA-KRNAGAR	DODDAKADNUR_66	10:35	11:54	1:19	MAIN SUPPLY FAILURE
145	2-Jan-19	HASSAN	66	HV1	HARIHARAPURA_66	14:10	16:31	2:21	MAIN SUPPLY FAILURE
146	2-Jan-19	HASSAN	66	HV1	HARIHARAPURA_66	19:29	19:48	0:19	MAIN SUPPLY FAILURE
147	2-Jan-19	HASSAN	66	HV1	HARIHARAPURA_66	19:49	20:23	0:34	MAIN SUPPLY FAILURE
148	2-Jan-19	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	11:48	12:03	0:15	LINE CLEAR AVAILED
149	2-Jan-19	HASSAN	66	HNPURA-SOMANAHALI	HNPURA_66	10:10	11:50	1:40	MAIN SUPPLY FAILURE
150	2-Jan-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	17:45	17:56	0:11	LINE FAULT
151	2-Jan-19	MYSORE	66	HV1	SANTHESARAGUR_66	14:36	14:45	0:08	TRANSFORMER FAULT
152	2-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	13:48	20:50	7:01	HAND TRIPPED
153	2-Jan-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	11:52	12:06	0:14	LINE FAULT
154	2-Jan-19	TUMKUR	220	TR-1(HV SIDE)	ANTHRASANAHALLI_220	9:17	10:43	1:25	HAND TRIPPED
155	2-Jan-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA	MRSMSG_220	10:06	12:48	2:42	LINE CLEAR AVAILED
156	2-Jan-19	TUMKUR	110	TR-1	KADABA_110	12:42	16:19	3:37	LINE CLEAR AVAILED
157	2-Jan-19	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	9:10	10:43	1:32	HAND TRIPPED
158	2-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	9:10	10:09	0:59	HAND TRIPPED
159	2-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	9:37	16:12	6:35	HAND TRIPPED
160	2-Jan-19	TUMKUR	66	TR-1 & TR-2	BELADARA_66	16:46	17:01	0:14	HAND TRIPPED
161	2-Jan-19	TUMKUR	66	TR-1	CHANNAGIRI_66	12:31	12:35	0:03	TRANSFORMER FAULT
162	2-Jan-19	TUMKUR	66	TR-1	DEVARAHALLI_66	15:33	15:36	0:02	TRANSFORMER FAULT
163	2-Jan-19	TUMKUR	66	DODDASARANGI-ANCHEPALYA	DODDASARANGI_66	10:50	15:29	4:39	HAND TRIPPED
164	2-Jan-19	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	2:56	10:50	7:54	LINE CLEAR AVAILED
165	2-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	9:07	17:38	8:30	HAND TRIPPED
166	2-Jan-19	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	13:45	14:48	1:02	HAND TRIPPED
167	2-Jan-19	TUMKUR	66	HIREGUNTANUR- SIRIGERE	SIRIGERE_66,BRAHMASAGARA_IPP_66	1:46	3:02	1:16	LINE FAULT
168	2-Jan-19	TUMKUR	66	HIREGUNTANUR- SIRIGERE	SIRIGERE_66,BRAHMASAGARA_IPP_66	13:43	14:48	1:04	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
169	2-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	14:10	14:24	0:14	LINE FAULT
170	2-Jan-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJHALLI_66	1:01	1:15	0:14	LINE FAULT
171	2-Jan-19	TUMKUR	66	TR-1	NITRAHALLI_66	12:44	13:15	0:31	LINE CLEAR AVAILED
172	2-Jan-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	18:01	18:05	0:03	HAND TRIPPED
173	2-Jan-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:52	15:49	5:56	LINE FAULT
174	3-Jan-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	9:56	17:42	7:46	LINE CLEAR AVAILED
175	3-Jan-19	BAGALKOT	220	BAGEWADI-BIJAPUR2	BIJAPUR_220	0:42	1:22	0:40	LINE FAULT
176	3-Jan-19	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	16:45	17:58	1:13	LINE CLEAR AVAILED
177	3-Jan-19	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	SOUDATTI_220,MUNVALLY_110,RAMDURG_110,YARAGATTI_110,SOUDATTI_110	12:10	12:24	0:14	LINE CLEAR AVAILED
178	3-Jan-19	BAGALKOT	220	BIDNAL-SOUDATTI	SOUDATTI_220	12:10	12:17	0:07	LINE CLEAR AVAILED
179	3-Jan-19	BAGALKOT	220	MAHALINGAPURA-SOUDATTI	SOUDATTI_220	12:10	14:35	2:25	LINE CLEAR AVAILED
180	3-Jan-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,33KV HORTI	10:16	10:17	0:01	TRANSFORMER FAULT
181	3-Jan-19	BAGALKOT	110	NAGJHARI1-HUBLI220	HUBLI_220	10:53	11:27	0:34	HAND TRIPPED
182	3-Jan-19	BAGALKOT	110	110/11KV,HV3	HUBLI_220	15:04	16:21	1:17	HAND TRIPPED
183	3-Jan-19	BAGALKOT	110	SATTI SUGARS-P G HUNSYAL	P G HUNSYAL_110	4:49	4:54	0:05	LINE FAULT
184	3-Jan-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	12:59	13:03	0:04	TRANSFORMER FAULT
185	3-Jan-19	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	18:21	23:59	5:38	HAND TRIPPED
186	3-Jan-19	BANGALORE	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	14:20	14:28	0:08	LOAD CHANGE OVER
187	3-Jan-19	BANGALORE	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	16:15	16:36	0:21	LOAD CHANGE OVER
188	3-Jan-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:23	6:30	0:06	LINE FAULT
189	3-Jan-19	BANGALORE	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	7:20	7:38	0:17	LINE FAULT
190	3-Jan-19	BANGALORE	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	7:38	7:40	0:01	LINE FAULT
191	3-Jan-19	BANGALORE	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	7:40	9:43	2:03	LINE CLEAR AVAILED
192	3-Jan-19	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	13:05	13:09	0:04	LOAD CURTAILMENT
193	3-Jan-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	13:09	13:23	0:13	LOAD CURTAILMENT
194	3-Jan-19	BANGALORE	66	GOWRIBIDANUR - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	12:38	13:16	0:38	LOAD CURTAILMENT
195	3-Jan-19	BANGALORE	66	GOWRIBIDANUR - BAGEPALLI 2	BAGEPALLI , VIDHURASHWATHA , GUNDLU KOTTUR	12:38	13:16	0:38	LOAD CURTAILMENT
196	3-Jan-19	BANGALORE	66	KOLAR - VEMAGAL	VEMAGAL , KYALANUR	4:45	5:01	0:16	LINE FAULT
197	3-Jan-19	BANGALORE	66	KOLAR - VEMAGAL	VEMAGAL , KYALANUR	5:01	8:04	3:02	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
198	3-Jan-19	BANGALORE	66	HV2	NELAMANGALA	11:21	11:23	0:01	TRANSFORMER FAULT
199	3-Jan-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:19	14:32	0:13	LOAD CHANGE OVER
200	3-Jan-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:10	16:12	0:02	LOAD CHANGE OVER
201	3-Jan-19	BANGALORE	66	HV2	SARJAPURA 220	14:20	14:28	0:08	LOAD CHANGE OVER
202	3-Jan-19	BANGALORE	66	HV2	SARJAPURA 220	16:12	16:20	0:08	LOAD CHANGE OVER
203	3-Jan-19	BANGALORE	66	HV3	YERANDANAHALLI 220	13:02	13:31	0:29	LINE CLEAR AVAILED
204	3-Jan-19	BANGALORE	66	HV2	YERANDANAHALLI 220	20:25	21:34	1:09	TRANSFORMER FAULT
205	3-Jan-19	BANGALORE	220	SOMANAHALLI 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220, KHODAYS 220	6:58	7:28	0:30	LINE FAULT
206	3-Jan-19	BANGALORE	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220	6:58	7:39	0:40	LINE FAULT
207	3-Jan-19	BANGALORE	220	HV2	SUBRAMANYAPURA 220	6:58	7:28	0:30	MAIN SUPPLY FAILURE
208	3-Jan-19	BANGALORE	220	HV3	SUBRAMANYAPURA 220	6:58	7:29	0:30	MAIN SUPPLY FAILURE
209	3-Jan-19	BANGALORE	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	6:58	11:59	5:01	MAIN SUPPLY FAILURE
210	3-Jan-19	BANGALORE	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	12:01	12:42	0:41	LOAD CHANGE OVER
211	3-Jan-19	BANGALORE	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	13:48	13:53	0:05	LOAD CHANGE OVER
212	3-Jan-19	BANGALORE	66	SUBRAMANYAPRUA 220 - RR NAGAR	RR NAGAR	6:58	7:45	0:46	MAIN SUPPLY FAILURE
213	3-Jan-19	BANGALORE	66	KHODAYS 220 - RBI	RBI	17:29	17:30	0:01	LOAD CHANGE OVER
214	3-Jan-19	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	12:35	12:40	0:05	LOAD CHANGE OVER
215	3-Jan-19	BANGALORE	66	RBI - KHODAYS 220	RBI	7:45	8:00	0:15	LOAD CHANGE OVER
216	3-Jan-19	BANGALORE	66	KHODAYS 220 - RBI	RBI	6:58	7:42	0:43	MAIN SUPPLY FAILURE
217	3-Jan-19	BANGALORE	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	16:25	17:06	0:41	LOAD CHANGE OVER
218	3-Jan-19	BANGALORE	66	PLATINUM CITY - SAHAKARINAGAR	PLATINUM CITY	17:07	17:40	0:33	LOAD CHANGE OVER
219	3-Jan-19	BANGALORE	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	12:49	13:00	0:11	LOAD CHANGE OVER
220	3-Jan-19	BANGALORE	66	SUBRAMANYAPRUA 220 - PADMANABHANAGAR	PADMANABHANAGAR	6:58	7:58	0:59	MAIN SUPPLY FAILURE
221	3-Jan-19	BANGALORE	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2	11:02	11:19	0:17	LINE CLEAR AVAILED
222	3-Jan-19	BANGALORE	66	ELECTRONIC CITY P2 S2 - BIOCON (EHT)	BIOCON (EHT)	11:02	11:19	0:17	MAIN SUPPLY FAILURE
223	3-Jan-19	BANGALORE	66	KHODAYS 220 - SUBRAMANYAPURA 2	KHODAYS 220	12:27	12:40	0:12	LOAD CHANGE OVER
224	3-Jan-19	BANGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	6:58	7:45	0:47	MAIN SUPPLY FAILURE
225	3-Jan-19	BANGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	7:48	8:31	0:42	MAIN SUPPLY FAILURE
226	3-Jan-19	BANGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	12:27	12:34	0:07	LOAD CHANGE OVER
227	3-Jan-19	BANGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	17:25	17:27	0:01	LOAD CHANGE OVER
228	3-Jan-19	BANGALORE	66	HV1	KHODAYS 220	7:48	8:26	0:38	MAIN SUPPLY FAILURE
229	3-Jan-19	BANGALORE	66	HV1	KHODAYS 220	12:27	12:31	0:03	LOAD CHANGE OVER
230	3-Jan-19	BANGALORE	66	HV1	KHODAYS 220	17:25	17:29	0:04	LOAD CHANGE OVER
231	3-Jan-19	BANGALORE	66	HV2	KHODAYS 220	6:58	7:40	0:41	MAIN SUPPLY FAILURE
232	3-Jan-19	BANGALORE	66	HV2	KHODAYS 220	7:48	8:25	0:37	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
233	3-Jan-19	BANGALORE	66	HV2	KHODAYS 220	12:27	12:31	0:04	LOAD CHANGE OVER
234	3-Jan-19	BANGALORE	66	HV2	KHODAYS 220	17:25	17:29	0:04	LOAD CHANGE OVER
235	3-Jan-19	BANGALORE	66	KHODAYS 220 - ELITA PROMINEDE	ELITA PROMENEDE	6:58	7:43	0:45	MAIN SUPPLY FAILURE
236	3-Jan-19	BANGALORE	66	KHODAYS 220 - ELITA PROMINEDE	ELITA PROMENEDE	7:48	8:30	0:42	MAIN SUPPLY FAILURE
237	3-Jan-19	BANGALORE	66	KHODAYS 220 - ELITA PROMINEDE	ELITA PROMENEDE	12:26	12:32	0:06	LOAD CHANGE OVER
238	3-Jan-19	BANGALORE	66	KHODAYS 220 - ELITA PROMINEDE	ELITA PROMENEDE	17:24	17:26	0:01	LOAD CHANGE OVER
239	3-Jan-19	BANGALORE	66	BRIGADE MEDOWS - SHOBHA FOREST VIEW	SHOBHA FOREST VIEW, KHODAYS 220	7:45	8:16	0:31	LINE FAULT
240	3-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	6:58	9:03	2:05	MAIN SUPPLY FAILURE
241	3-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	6:58	7:46	0:47	MAIN SUPPLY FAILURE
242	3-Jan-19	BANGALORE	66	SARAKKI - JAYADEVA	SARAKKI	12:39	12:50	0:10	LOAD CHANGE OVER
243	3-Jan-19	BANGALORE	66	HV1	KORMANGALA	11:04	11:06	0:02	LINE CLEAR AVAILED
244	3-Jan-19	BANGALORE	66	HV2	KORMANGALA	11:50	12:26	0:36	LINE CLEAR AVAILED
245	3-Jan-19	BANGALORE	66	AREHALLI - BANASHANKARI	AREHALLI	12:32	12:40	0:08	LOAD CHANGE OVER
246	3-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	6:58	8:23	1:24	MAIN SUPPLY FAILURE
247	3-Jan-19	BANGALORE	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	10:33	10:55	0:22	LINE CLEAR AVAILED
248	3-Jan-19	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHPUR_220	3:50	3:58	0:08	LINE FAULT
249	3-Jan-19	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHPUR_220	6:05	7:56	1:51	LINE FAULT
250	3-Jan-19	GULBARGA	220	HV2	RAICHUR_220	9:15	14:12	4:57	LINE CLEAR AVAILED
251	3-Jan-19	GULBARGA	220	HV1	RAICHUR_220	14:04	18:55	4:51	LINE CLEAR AVAILED
252	3-Jan-19	GULBARGA	110	HV2	BETAGERA_110	10:57	11:02	0:05	TRANSFORMER FAULT
253	3-Jan-19	GULBARGA	110	HV2	BETAGERA_110	11:19	11:24	0:05	TRANSFORMER FAULT
254	3-Jan-19	GULBARGA	110	HV1	HANUMANAL_110	8:40	10:40	2:00	HAND TRIPPED
255	3-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	9:23	9:34	0:11	TRANSFORMER FAULT
256	3-Jan-19	GULBARGA	110	HV4	SEDAM_220	13:40	14:56	1:16	LINE CLEAR AVAILED
257	3-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	22:36	22:42	0:06	TRANSFORMER FAULT
258	3-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	23:06	23:41	0:35	TRANSFORMER FAULT
259	3-Jan-19	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110,DEODURGA_110	8:39	23:59	15:20	LINE CLEAR AVAILED
260	3-Jan-19	GULBARGA	66	ITTAGI-HBHALLI	UPANAYAKANAHALLI_66,HAGARIBOMMAN AHALLI_66	19:06	19:33	0:27	LINE CLEAR AVAILED
261	3-Jan-19	GULBARGA	66	ITTAGI-HBHALLI	UPANAYAKANAHALLI_66,HAGARIBOMMAN AHALLI_66	19:55	20:10	0:15	LINE CLEAR AVAILED
262	3-Jan-19	GULBARGA	66	HV1,HV2	ITTAGI_220	13:32	19:23	5:51	LINE CLEAR AVAILED
263	3-Jan-19	GULBARGA	66	ITTAGI-KOGALI	KOGALI_66	19:53	20:05	0:12	LINE CLEAR AVAILED
264	3-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	0:00	6:42	6:42	LINE CLEAR AVAILED
265	3-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	21:51	23:59	2:08	LINE CLEAR AVAILED
266	3-Jan-19	HASSAN	220	HV1	HASSAN_220	15:24	23:59	8:35	LINE CLEAR AVAILED
267	3-Jan-19	HASSAN	220	HV1	MRSSHM_220	17:55	23:59	6:04	LINE CLEAR AVAILED
268	3-Jan-19	HASSAN	220	HV1	MRSSHM_220	15:10	19:16	4:06	LINE CLEAR AVAILED
269	3-Jan-19	HASSAN	220	HV1	SHRALKOPPA_220	10:39	14:16	3:37	LINE CLEAR AVAILED



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
270	3-Jan-19	HASSAN	110	HV2	MRSSHM_220	19:03	19:16	0:13	HAND TRIPPED
271	3-Jan-19	HASSAN	110	HV3	MRSSHM_220	18:50	19:02	0:12	HAND TRIPPED
272	3-Jan-19	HASSAN	110	HV4	MRSSHM_220	18:36	18:49	0:13	HAND TRIPPED
273	3-Jan-19	HASSAN	110	LV1	MRSSHM_220	15:09	17:55	2:46	HAND TRIPPED
274	3-Jan-19	HASSAN	110	HV2	HALADY_110	12:41	18:52	6:11	LINE CLEAR AVAILED
275	3-Jan-19	HASSAN	110	HV4	BAIKAMPADI_110	7:00	11:45	4:45	MAIN SUPPLY FAILURE
276	3-Jan-19	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	7:30	11:44	4:14	LINE CLEAR AVAILED
277	3-Jan-19	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	7:30	23:59	16:29	LINE CLEAR AVAILED
278	3-Jan-19	HASSAN	110	HV4	MANIPAL_110	6:16	12:18	6:02	TRANSFORMER FAULT
279	3-Jan-19	HASSAN	110	HV4	MANIPAL_110	14:25	14:27	0:02	HAND TRIPPED
280	3-Jan-19	HASSAN	110	SAGARA-SORABA	SAGARA_110	14:52	15:00	0:08	HAND TRIPPED
281	3-Jan-19	HASSAN	110	SHRLKP-BARANG	SHRALKOPPA_220	10:16	14:22	4:06	LINE CLEAR AVAILED
282	3-Jan-19	HASSAN	110	SHRLKP-KITTADAHALLI	SHRALKOPPA_220	10:20	14:52	4:32	LINE CLEAR AVAILED
283	3-Jan-19	HASSAN	110	SHRLKP-KITTADAHALLI	SHRALKOPPA_220	14:54	23:59	9:05	LINE CLEAR AVAILED
284	3-Jan-19	HASSAN	110	HV1	SHRALKOPPA_220	10:38	14:19	3:41	LINE CLEAR AVAILED
285	3-Jan-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHRALKOPPA_220	10:14	10:17	0:03	LINE CLEAR AVAILED
286	3-Jan-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHRALKOPPA_220	10:35	14:23	3:48	LINE CLEAR AVAILED
287	3-Jan-19	HASSAN	66	HASSAN22-ARAKALGUD	HASSAN_220	15:50	16:44	0:54	LINE CLEAR AVAILED
288	3-Jan-19	HASSAN	66	HASSAN22-HN PURA	HASSAN_220	15:24	20:20	4:56	LINE CLEAR AVAILED
289	3-Jan-19	HASSAN	66	LV1	HASSAN_220	15:24	20:20	4:56	LINE CLEAR AVAILED
290	3-Jan-19	HASSAN	66	HASSAN22-SKPURA	HASSAN_220	15:24	16:41	1:17	LINE CLEAR AVAILED
291	3-Jan-19	HASSAN	66	HASSAN22-SKPURA	HASSAN_220	18:36	18:52	0:16	LINE FAULT
292	3-Jan-19	HASSAN	66	HASSAN22-UDDURKOPLU	HASSAN_220	10:27	10:39	0:12	LINE CLEAR AVAILED
293	3-Jan-19	HASSAN	66	HASSAN22-UDDURKOPLU	HASSAN_220	14:57	15:07	0:10	LINE CLEAR AVAILED
294	3-Jan-19	HASSAN	66	LV2	MRSSHM_220	19:02	19:03	0:01	HAND TRIPPED
295	3-Jan-19	HASSAN	66	LV3	MRSSHM_220	18:49	18:50	0:01	HAND TRIPPED
296	3-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:08	18:27	11:19	LINE CLEAR AVAILED
297	3-Jan-19	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	16:49	17:50	1:01	MAIN SUPPLY FAILURE
298	3-Jan-19	HASSAN	66	HV1	BELUR_66	10:10	17:45	7:35	LINE CLEAR AVAILED
299	3-Jan-19	HASSAN	66	HV1	BELUR_66	18:25	22:55	4:30	MAIN SUPPLY FAILURE
300	3-Jan-19	HASSAN	66	HV1	BELUR_66	23:30	23:35	0:05	HAND TRIPPED
301	3-Jan-19	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:10	13:35	3:25	LINE CLEAR AVAILED
302	3-Jan-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	10:00	23:36	13:36	MAIN SUPPLY FAILURE
303	3-Jan-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	9:57	23:36	13:39	MAIN SUPPLY FAILURE
304	3-Jan-19	HASSAN	66	HNPR2-HASS2	HNPUA_220	16:50	17:10	0:20	LINE CLEAR AVAILED
305	3-Jan-19	HASSAN	66	HNPR2-HASS2	HNPUA_220	17:10	20:00	2:50	LINE CLEAR AVAILED
306	3-Jan-19	HASSAN	66	HNPR2-HASS2	HNPUA_220	20:00	20:20	0:20	HAND TRIPPED
307	3-Jan-19	HASSAN	66	HNPR2-MYSOR1	HNPUA_220	5:06	5:12	0:06	LINE FAULT
308	3-Jan-19	HASSAN	66	HNPR2-MYSOR1	HNPUA_220	6:31	6:41	0:10	LINE FAULT
309	3-Jan-19	HASSAN	66	KANDLI-HASSAN	KANDLI_66	18:30	18:50	0:20	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
310	3-Jan-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	10:54	11:59	1:05	LINE CLEAR AVAILED
311	3-Jan-19	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	12:19	12:22	0:03	HAND TRIPPED
312	3-Jan-19	HASSAN	66	RMWNGR-HASSAN	RMWNGARA_66	15:15	17:30	2:15	HAND TRIPPED
313	3-Jan-19	HASSAN	66	SAKALESH-HASSAN	SAKALESHPURA_66	10:54	11:59	1:05	NBFC ISSUED
314	3-Jan-19	HASSAN	66	SAKALESH-HASSAN	SAKALESHPURA_66	15:15	16:40	1:25	MAIN SUPPLY FAILURE
315	3-Jan-19	HASSAN	66	SALAGAME-HIREMANGLUR	SALAGAME_66	18:35	22:40	4:05	LINE CLEAR AVAILED
316	3-Jan-19	HASSAN	66	SALAGAME-UDURKOPPLU	SALAGAME_66	17:22	23:59	6:37	LINE CLEAR AVAILED
317	3-Jan-19	HASSAN	66	HV2	SHANTHIGRAMA_66	11:49	12:25	0:36	LINE CLEAR AVAILED
318	3-Jan-19	HASSAN	66	UDDURKOP-HASSAN2	UDDURKOPPALU_66	15:14	17:34	2:20	NBFC ISSUED
319	3-Jan-19	HASSAN	66	KIADB H-HASAN I\C	KIADB H_66	17:38	20:40	3:02	MAIN SUPPLY FAILURE
320	3-Jan-19	HASSAN	66	KIADB H-HASAN I\C	KIADB H_66	21:20	23:59	2:39	LINE CLEAR AVAILED
321	3-Jan-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	12:10	13:36	1:26	LINE CLEAR AVAILED
322	3-Jan-19	MYSORE	66	HV2	DODDABYADARAHALLI_66	11:00	12:05	1:05	LINE CLEAR AVAILED
323	3-Jan-19	MYSORE	66	HV1	KADAKOLA_220	15:38	17:06	1:28	LINE CLEAR AVAILED
324	3-Jan-19	MYSORE	66	HV1	K_HONNALGERE_66	10:46	11:23	0:37	LINE CLEAR AVAILED
325	3-Jan-19	MYSORE	66	HV1	KRNAGARA_66	6:27	7:14	0:47	TRANSFORMER FAULT
326	3-Jan-19	MYSORE	66	HV2	KRNAGARA_66	6:27	7:14	0:47	TRANSFORMER FAULT
327	3-Jan-19	MYSORE	66	HV1	KRNAGARA_66	8:35	8:46	0:11	HAND TRIPPED
328	3-Jan-19	MYSORE	66	HV2	KRNAGARA_66	8:35	8:46	0:11	HAND TRIPPED
329	3-Jan-19	MYSORE	66	HV1	KRNAGARA_66	9:20	10:19	0:59	HAND TRIPPED
330	3-Jan-19	MYSORE	66	HV2	KRNAGARA_66	9:20	10:19	0:59	HAND TRIPPED
331	3-Jan-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66 BHERYA_66 BILIKERE_66 GVGUDI_66	6:26	6:36	0:10	LINE FAULT
332	3-Jan-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66 BHERYA_66 BILIKERE_66 GVGUDI_66	8:34	8:45	0:11	LINE FAULT
333	3-Jan-19	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	MIRLE_66 BHERYA_66 BILIKERE_66 GVGUDI_66	9:17	10:15	0:57	LINE FAULT
334	3-Jan-19	MYSORE	220	HV2	MADHUVANAHALLI_220	12:03	17:12	5:08	LINE CLEAR AVAILED
335	3-Jan-19	MYSORE	66	HV2	SANTHEBACHALLI_66	16:46	17:29	0:42	LINE CLEAR AVAILED
336	3-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	8:54	21:17	12:23	HAND TRIPPED
337	3-Jan-19	MYSORE	66	HV1	SINDHUVALI_66	14:41	15:18	0:36	LINE CLEAR AVAILED
338	3-Jan-19	TUMKUR	66	TR-1	BAGUR_66	12:04	12:13	0:08	TRANSFORMER FAULT
339	3-Jan-19	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	13:15	13:23	0:07	HAND TRIPPED
340	3-Jan-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	13:58	14:33	0:35	LINE FAULT
341	3-Jan-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	6:42	6:56	0:14	LINE FAULT
342	3-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:34	17:33	8:58	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
343	3-Jan-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	12:06	12:13	0:06	LINE FAULT
344	3-Jan-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	13:03	13:09	0:05	LINE FAULT
345	3-Jan-19	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	14:42	14:48	0:06	HAND TRIPPED
346	3-Jan-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	12:37	12:40	0:03	HAND TRIPPED
347	3-Jan-19	TUMKUR	66	TR-2	HONNALI_66	9:07	16:10	7:03	LINE CLEAR AVAILED
348	3-Jan-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	7:20	7:32	0:12	LINE FAULT
349	3-Jan-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	11:21	11:30	0:09	LINE FAULT
350	3-Jan-19	TUMKUR	66	TR-1	KATTIGE_66	12:11	12:43	0:31	LINE CLEAR AVAILED
351	3-Jan-19	TUMKUR	66	TR-1	KATTIGE_66	14:16	14:26	0:09	TRANSFORMER FAULT
352	3-Jan-19	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND ENERGY_IPP_66	18:07	20:58	2:50	LINE CLEAR AVAILED
353	3-Jan-19	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	12:37	13:25	0:48	LOAD CURTAILMENT
354	3-Jan-19	TUMKUR	66	TR-1	MALLASANDRA_66	11:16	11:22	0:05	TRANSFORMER FAULT
355	3-Jan-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	12:43	12:49	0:05	MAIN SUPPLY FAILURE
356	3-Jan-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	12:43	12:49	0:05	MAIN SUPPLY FAILURE
357	3-Jan-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:01	14:22	2:20	LINE FAULT
358	3-Jan-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	14:26	15:13	0:47	LINE FAULT
359	3-Jan-19	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE_66	18:17	19:07	0:49	LINE CLEAR AVAILED
360	3-Jan-19	TUMKUR	66	TR-1	YNHOSKOTE_66	8:35	8:38	0:03	TRANSFORMER FAULT
361	4-Jan-19	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	14:00	17:48	3:48	HAND TRIPPED
362	4-Jan-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	6:27	6:34	0:07	LINE FAULT
363	4-Jan-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	13:04	13:08	0:04	TRANSFORMER FAULT
364	4-Jan-19	BAGALKOT	110	SOLAR -MUKARTHAL	MUKARTHAL_110	20:32	20:40	0:08	LINE FAULT
365	4-Jan-19	BAGALKOT	110	BPCL-NARAGUND	NARAGUND_110	18:25	19:20	0:55	LINE FAULT
366	4-Jan-19	BAGALKOT	110	BPCL-NARAGUND	NARAGUND_110	19:28	21:54	2:26	LINE FAULT
367	4-Jan-19	BAGALKOT	110	BPCL-NARAGUND	NARAGUND_110	22:01	22:28	0:27	LINE FAULT
368	4-Jan-19	BAGALKOT	110	110/11KV,HV3	SOUDATTI_110	15:22	18:27	3:05	TRANSFORMER FAULT
369	4-Jan-19	BAGALKOT	220	NAGZARI3-HUBLI	HUBLI_220	11:29	12:48	1:19	LINE CLEAR AVAILED
370	4-Jan-19	BAGALKOT	66	66/33KV,HV4	HARIHAR-HOSPET_66	17:37	18:00	0:23	LOAD CURTAILMENT
371	4-Jan-19	BANGALORE	66	CHANDAPURA - DOMMASANDRA	CHANDAPURA	16:48	17:00	0:12	LOAD CHANGE OVER
372	4-Jan-19	BANGALORE	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	17:55	17:58	0:03	LOAD CHANGE OVER
373	4-Jan-19	BANGALORE	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI, YELDUR	7:38	8:04	0:26	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
374	4-Jan-19	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI	11:03	11:08	0:05	LINE FAULT
375	4-Jan-19	BANGALORE	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	13:08	13:13	0:04	LINE FAULT
376	4-Jan-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	7:42	8:07	0:25	LOAD CURTAILMENT
377	4-Jan-19	BANGALORE	66	HV1	NELAMANGALA 66	14:10	14:12	0:02	TRANSFORMER FAULT
378	4-Jan-19	BANGALORE	66	HV2	VOLVO	7:32	8:02	0:29	TRANSFORMER FAULT
379	4-Jan-19	BANGALORE	66	YEDUMADU - HANUMANTHNAGAR	HANUMANTHNAGAR, MARALWADI	14:39	14:48	0:08	LOAD CHANGE OVER
380	4-Jan-19	BANGALORE	66	HV2	KOLAR 220	2:25	3:00	0:35	LINE CLEAR AVAILED
381	4-Jan-19	BANGALORE	66	HV1	AREHALLI	15:44	15:48	0:04	LOAD CHANGE OVER
382	4-Jan-19	BANGALORE	66	HV1	AREHALLI	12:53	12:58	0:05	LOAD CHANGE OVER
383	4-Jan-19	BANGALORE	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGARA,YEDUMADU	14:40	14:50	0:10	LOAD CHANGE OVER
384	4-Jan-19	BANGALORE	66	HV1	HOODY 220	11:02	14:04	3:02	LINE CLEAR AVAILED
385	4-Jan-19	BANGALORE	66	JAYADEVA - NIMHANS 220	JAYADEVA,ADUGODI,BOSCH(EHT)	12:22	12:32	0:10	LOAD CHANGE OVER
386	4-Jan-19	BANGALORE	66	JAYADEVA - SARAKKI 1	JAYADEVA,ADUGODI,BOSCH(EHT)	14:20	14:28	0:08	LOAD CHANGE OVER
387	4-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, HUKUNDA, KODIHALLI, HUNSENAHALLI	11:13	11:20	0:07	LOAD CHANGE OVER
388	4-Jan-19	BANGALORE	66	HV1	MATHIKERE	12:35	12:40	0:05	LOAD CHANGE OVER
389	4-Jan-19	BANGALORE	66	HV1	MATHIKERE	15:00	15:03	0:03	LOAD CHANGE OVER
390	4-Jan-19	BANGALORE	66	RR NAGAR - SUBRAMANYA PURA 220	RR NAGAR	8:40	10:05	1:25	MAIN SUPPLY FAILURE
391	4-Jan-19	BANGALORE	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	11:15	11:20	0:05	LOAD CHANGE OVER
392	4-Jan-19	BANGALORE	220	HV2	YARANDANAHALLI 220	9:48	10:15	0:27	TRANSFORMER FAULT
393	4-Jan-19	BANGALORE	66	HV3	YARANDANAHALLI 220	16:00	16:06	0:06	LOAD CHANGE OVER
394	4-Jan-19	BANGALORE	66	HV3	YARANDANAHALLI 220	18:55	20:48	1:53	TRANSFORMER FAULT
395	4-Jan-19	BANGALORE	66	A STATION 220 - A STATION 1	A STATION 66	12:30	12:32	0:02	LOAD CHANGE OVER
396	4-Jan-19	BANGALORE	66	A STATION 220 - A STATION 1	A STATION 66	14:40	14:44	0:04	LOAD CHANGE OVER
397	4-Jan-19	BANGALORE	220	HV2	EPIP 220	7:45	8:39	0:54	TRANSFORMER FAULT
398	4-Jan-19	BANGALORE	66	EPIP 220 - SHAMRAJ TECH PARK	SHAMRAJTECH PARK, KACHAMARANAHALLI	7:45	8:40	0:55	MAIN SUPPLY FAILURE
399	4-Jan-19	BANGALORE	66	HV1	HSR LAYOUT 220	6:57	7:01	0:04	TRANSFORMER FAULT
400	4-Jan-19	BANGALORE	66	HSR LAYOUT 220 - EPIP 220	EPIP 220	7:46	7:59	0:13	LINE FAULT
401	4-Jan-19	GULBARGA	220	HV2	RAICHUR_220	8:58	9:15	0:17	LINE CLEAR AVAILED
402	4-Jan-19	GULBARGA	220	HV1	RAICHUR_220	8:58	18:37	9:39	LINE CLEAR AVAILED
403	4-Jan-19	GULBARGA	220	HV1	MALLAT_220	8:53	18:25	9:32	LINE CLEAR AVAILED
404	4-Jan-19	GULBARGA	220	HV2	MALLAT_220	11:15	14:40	3:25	LINE CLEAR AVAILED
405	4-Jan-19	GULBARGA	110	BETAGERA-KSHVCMNT_SLR	BETAGERA_110	7:03	7:13	0:10	LINE FAULT
406	4-Jan-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	11:52	12:30	0:38	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
407	4-Jan-19	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	7:24	8:07	0:43	LOAD CURTAILMENT
408	4-Jan-19	GULBARGA	110	HV2	YELBURGA_110	7:40	7:54	0:14	TRANSFORMER FAULT
409	4-Jan-19	GULBARGA	110	HV4	SINDHANOOR_110	11:17	12:45	1:28	LINE CLEAR AVAILED
410	4-Jan-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:28	1:33	0:05	LINE FAULT
411	4-Jan-19	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	2:32	2:44	0:12	LINE FAULT
412	4-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	0:00	7:12	7:12	LINE CLEAR AVAILED
413	4-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	17:23	23:59	6:36	LINE CLEAR AVAILED
414	4-Jan-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:11	23:59	13:48	NBFC ISSUED
415	4-Jan-19	HASSAN	110	KAVOOR-EMAR	KAVOOR_220	7:44	14:59	7:15	LINE CLEAR AVAILED
416	4-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	19:07	21:18	2:11	LINE FAULT
417	4-Jan-19	HASSAN	220	SHRAVTY-SHIMOGA1	SHARAVATY_GEN	19:07	21:55	2:48	LINE FAULT
418	4-Jan-19	HASSAN	220	HV2	SHIRALKOPPA_220	10:48	14:05	3:17	LINE CLEAR AVAILED
419	4-Jan-19	HASSAN	110	LV2	SHIRALKOPPA_220	10:48	14:05	3:17	LINE CLEAR AVAILED
420	4-Jan-19	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	15:16	23:59	8:43	LINE CLEAR AVAILED
421	4-Jan-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:05	14:04	1:59	LINE CLEAR AVAILED
422	4-Jan-19	HASSAN	110	HV1	BIRUR_110	10:14	16:36	6:22	LINE CLEAR AVAILED
423	4-Jan-19	HASSAN	110	HV2	GERUMARA_110	17:36	18:08	0:32	LOAD CURTAILMENT
424	4-Jan-19	HASSAN	110	HV2	HALADY_110	11:47	12:08	0:21	LINE CLEAR AVAILED
425	4-Jan-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	15:57	23:59	8:02	LINE FAULT
426	4-Jan-19	HASSAN	110	HV1	SAGARA_110	18:31	18:55	0:24	TRANSFORMER FAULT
427	4-Jan-19	HASSAN	66	HV1	BAGUR_66	9:45	10:00	0:15	TRANSFORMER FAULT
428	4-Jan-19	HASSAN	66	HV1	BAGUR_66	12:39	14:27	1:48	LINE CLEAR AVAILED
429	4-Jan-19	HASSAN	66	HV2	BASAVAGATTA_66	17:36	17:47	0:11	TRANSFORMER FAULT
430	4-Jan-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADNUR_66	12:29	13:25	0:56	LINE CLEAR AVAILED
431	4-Jan-19	HASSAN	66	HV1	HANGARAHALLY_66	17:37	17:44	0:07	TRANSFORMER FAULT
432	4-Jan-19	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	10:47	14:14	3:27	LINE CLEAR AVAILED
433	4-Jan-19	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	10:12	14:07	3:55	LINE CLEAR AVAILED
434	4-Jan-19	HASSAN	66	HASSN220-HNPURA	HASSAN_220	14:03	16:26	2:23	LINE CLEAR AVAILED
435	4-Jan-19	HASSAN	66	HNPR2-HASS2	HNPURA_220	10:55	14:02	3:07	NBFC ISSUED
436	4-Jan-19	HASSAN	66	HNPR2-MYSOR1	HNPURA_220	10:46	10:54	0:08	HAND TRIPPED
437	4-Jan-19	HASSAN	66	KIADB HA-HASAN I\C	KIADBH_66	0:00	16:34	16:34	LINE CLEAR AVAILED
438	4-Jan-19	HASSAN	66	HV2	MAGGE_66	13:54	14:08	0:14	LINE CLEAR AVAILED
439	4-Jan-19	HASSAN	66	HV2	MATNAVILE_66	19:16	19:22	0:06	TRANSFORMER FAULT
440	4-Jan-19	HASSAN	66	HV1	MATNAVILE_66	17:40	17:45	0:05	TRANSFORMER FAULT
441	4-Jan-19	HASSAN	66	HV2	TAVARECHETANAHALLY_66	8:07	8:23	0:16	TRANSFORMER FAULT
442	4-Jan-19	MYSORE	66	HV2	ADDIHALLI_66	17:37	17:50	0:13	LOAD CURTAILMENT
443	4-Jan-19	MYSORE	66	HV1	BGNAGARA_66	17:37	17:43	0:06	LOAD CURTAILMENT
444	4-Jan-19	MYSORE	66	HV1	BGPURA_66	11:02	12:34	1:32	LINE CLEAR AVAILED
445	4-Jan-19	MYSORE	66	HV1	BGPURA_66	17:36	17:50	0:14	LOAD CURTAILMENT
446	4-Jan-19	MYSORE	66	HV1	BILIKERE_66	17:37	17:49	0:11	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
447	4-Jan-19	MYSORE	66	CR NAGARA-KABBALLI	HARVEY_66	7:30	23:59	16:28	LINE CLEAR AVAILED
448	4-Jan-19	MYSORE	66	CR NAGARA-GUNDLUPETE	GUNDULPET_66 BOMMALAPURA_66 HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66 BHARGI_66 SINDHUVALLI_66	9:34	9:43	0:08	LINE FAULT
449	4-Jan-19	MYSORE	66	CR NAGARA-GUNDLUPETE	GUNDULPET_66 BOMMALAPURA_66 HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66 BHARGI_66 SINDHUVALLI_66	9:51	10:06	0:14	LINE FAULT
450	4-Jan-19	MYSORE	66	HV1	DODDINADUVADI_66	17:37	17:42	0:04	LOAD CURTAILMENT
451	4-Jan-19	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66 SINDHUVALLI_66	9:59	10:59	1:00	LOAD CURTAILMENT
452	4-Jan-19	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	9:59	10:27	0:28	LOAD CURTAILMENT
453	4-Jan-19	MYSORE	66	GUNDLUPETE-HANGLA	HANGLA_66 BHARGI_66	9:59	10:35	0:36	LOAD CURTAILMENT
454	4-Jan-19	MYSORE	66	HV2	JAIPUR_66	17:36	17:50	0:14	LOAD CURTAILMENT
455	4-Jan-19	MYSORE	66	HV1	KADAKOLA_220	14:53	15:48	0:55	LINE CLEAR AVAILED
456	4-Jan-19	MYSORE	66	HV1	K_HONNALGERE_66	12:22	12:26	0:04	HAND TRIPPED
457	4-Jan-19	MYSORE	66	HV2	KMDODDI_66	17:36	17:44	0:07	LOAD CURTAILMENT
458	4-Jan-19	MYSORE	66	HV1	KRPET_220	7:49	8:01	0:12	TRANSFORMER FAULT
459	4-Jan-19	MYSORE	66	KR PETE 220-MADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	8:47	8:56	0:08	LINE FAULT
460	4-Jan-19	MYSORE	66	HV1	MADDUR_66	17:44	17:52	0:07	LOAD CURTAILMENT
461	4-Jan-19	MYSORE	66	HV1	MALAVALLI_66	12:04	17:34	5:30	TRANSFORMER FAULT
462	4-Jan-19	MYSORE	66	HV2	MALAVALLI_66	12:04	13:14	1:10	TRANSFORMER FAULT
463	4-Jan-19	MYSORE	66	MALAVALLI-MANDYA 2	MALAVALLI_66 HADLI_66	13:11	13:13	0:02	HAND TRIPPED
464	4-Jan-19	MYSORE	66	HV1	MEGALAPURA_66	11:28	12:20	0:52	LINE CLEAR AVAILED
465	4-Jan-19	MYSORE	66	HV1	MEGALAPURA_66	17:35	17:43	0:07	LOAD CURTAILMENT
466	4-Jan-19	MYSORE	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	14:08	14:16	0:08	LINE FAULT
467	4-Jan-19	MYSORE	66	HV2	SANTHESARAGUR_66	17:37	17:52	0:14	LOAD CURTAILMENT
468	4-Jan-19	MYSORE	66	HV1	SANTHEBACHALLI_66	12:30	15:05	2:35	LINE CLEAR AVAILED
469	4-Jan-19	MYSORE	66	HV2	SANTHEBACHALLI_66	15:14	16:32	1:17	LINE CLEAR AVAILED
470	4-Jan-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	17:38	17:49	0:11	LOAD CURTAILMENT
471	4-Jan-19	MYSORE	66	HV4	SFCSHIVA_66	9:34	23:59	14:24	LINE CLEAR AVAILED
472	4-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	9:58	23:59	14:00	HAND TRIPPED
473	4-Jan-19	MYSORE	66	HV6 (6.3 MVA)	SFCSHIVA_66	17:05	17:10	0:05	TRANSFORMER FAULT
474	4-Jan-19	MYSORE	66	SINDHUVALLI-KADAKOLA	SINDHUVALLI_66	10:17	11:00	0:43	LOAD CHANGE OVER
475	4-Jan-19	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	11:13	13:59	1:43	LINE CLEAR AVAILED
476	4-Jan-19	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	15:24	16:09	2:43	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
477	4-Jan-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	7:40	8:12	3:43	LOAD CURTAILMENT
478	4-Jan-19	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	11:13	12:16	4:43	HAND TRIPPED
479	4-Jan-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	12:16	13:09	5:43	HAND TRIPPED
480	4-Jan-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	11:13	11:37	6:43	HAND TRIPPED
481	4-Jan-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	15:26	16:13	7:43	HAND TRIPPED
482	4-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	10:17	10:19	8:43	HAND TRIPPED
483	4-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	10:14	10:16	9:43	HAND TRIPPED
484	4-Jan-19	TUMKUR	66	TR-2	BELLAVI_66	11:21	11:56	10:43	LINE CLEAR AVAILED
485	4-Jan-19	TUMKUR	66	TR-2	BEVINAHALLI_66	12:00	12:43	11:43	LINE CLEAR AVAILED
486	4-Jan-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	13:00	13:50	12:43	LINE CLEAR AVAILED
487	4-Jan-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	15:35	15:43	13:43	TRANSFORMER FAULT
488	4-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:04	17:52	14:43	HAND TRIPPED
489	4-Jan-19	TUMKUR	66	TR-2	HALURAMESHWARA_66	10:57	14:58	15:43	LINE CLEAR AVAILED
490	4-Jan-19	TUMKUR	66	TR-1	HALUVAGALU_66	13:31	14:59	16:43	LINE CLEAR AVAILED
491	4-Jan-19	TUMKUR	66	TR-2	HULIYURDURGA_66	11:01	11:15	17:43	LINE CLEAR AVAILED
492	4-Jan-19	TUMKUR	66	TR-2	HULIYURDURGA_66	11:52	12:02	18:43	TRANSFORMER FAULT
493	4-Jan-19	TUMKUR	66	TR-2	MAVINAKATTE_66	0:09	0:52	19:43	TRANSFORMER FAULT
494	5-Jan-19	BAGALKOT	110	110/11KV,HV-1	ACHANUR_110	16:40	16:46	0:06	LOAD CURTAILMENT
495	5-Jan-19	BAGALKOT	110	110/11KV,HV-1	AINAPUR_110	16:40	16:43	0:03	LOAD CURTAILMENT
496	5-Jan-19	BAGALKOT	110	110/11KV,HV-1	ATHARGA_110	16:40	16:57	0:17	LOAD CURTAILMENT
497	5-Jan-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI 2	BAGALKOT_220	12:50	14:50	2:00	LINE CLEAR AVAILED
498	5-Jan-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1	BAGALKOT_220	15:22	16:58	1:36	LINE CLEAR AVAILED
499	5-Jan-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	16:40	16:59	0:19	TRANSFORMER FAULT
500	5-Jan-19	BAGALKOT	110	110/33KV,HV1	HANGAL_110,33KV PALA	16:42	16:46	0:04	LOAD CURTAILMENT
501	5-Jan-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,33KV KOLIGUDDA ,SULTANPUR	11:54	15:24	3:30	HAND TRIPPED
502	5-Jan-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,33KV KOLIGUDDA ,SULTANPUR	16:40	16:43	0:03	LOAD CURTAILMENT
503	5-Jan-19	BAGALKOT	110	KARWAR-KUMTA	KUMTA_110	11:24	11:34	0:10	LINE FAULT
504	5-Jan-19	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	0:00	11:40	11:40	HAND TRIPPED
505	5-Jan-19	BAGALKOT	110	110/11KV, HV2	SAVALAGI_110	16:40	16:54	0:14	LOAD CURTAILMENT
506	5-Jan-19	BAGALKOT	110	SHIRAHATTI-LAXMESHWAR	LAXMESHWAR_110	13:28	14:53	1:25	LINE CLEAR AVAILED
507	5-Jan-19	BAGALKOT	110	110/11KV, HV2	SANKESHWARA_110	16:40	16:46	0:06	LOAD CURTAILMENT
508	5-Jan-19	BAGALKOT	110	110/11KV, HV2	SANKESHWARA_110	16:46	17:00	0:14	LINE CLEAR AVAILED
509	5-Jan-19	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	16:39	16:49	0:10	LOAD CURTAILMENT
510	5-Jan-19	BAGALKOT	110	110/11KV, HV2	MLGHAN(B)_110	13:05	13:07	0:02	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
511	5-Jan-19	BAGALKOT	220	BELGAUM1-CHIKKODI	CHIKKODI_220	21:02	23:59	2:57	HAND TRIPPED
512	5-Jan-19	BAGALKOT	220	NAGZARI2-HUBLI	HUBLI_220	13:13	13:17	0:04	LINE FAULT
513	5-Jan-19	BAGALKOT	110	110/33KV, HV4	HARIHAR-HOSPET_66	16:42	16:55	0:13	LOAD CURTAILMENT
514	5-Jan-19	BAGALKOT	110	ZALKI-CHADCHAN	CHADCHAN_110	9:59	10:09	0:10	LINE FAULT
515	5-Jan-19	BAGALKOT	110	ZALKI-CHADCHAN	CHADCHAN_110	12:17	12:49	0:32	LINE FAULT
516	5-Jan-19	BAGALKOT	110	ZALKI-CHADCHAN	CHADCHAN_110	13:07	13:23	0:16	LINE FAULT
517	5-Jan-19	BAGALKOT	110	ZALKI-CHADCHAN	CHADCHAN_110	14:08	14:12	0:04	LINE FAULT
518	5-Jan-19	BAGALKOT	110	ZALKI-CHADCHAN	CHADCHAN_110	14:29	15:25	0:56	LINE FAULT
519	5-Jan-19	BAGALKOT	110	110/11KV,HV1	ZALKI_110	9:59	10:24	0:25	TRANSFORMER FAULT
520	5-Jan-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110,HORTI_33	9:59	10:15	0:16	TRANSFORMER FAULT
521	5-Jan-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110,HORTI_33	12:42	12:50	0:08	TRANSFORMER FAULT
522	5-Jan-19	BANGALORE	66	ANDERSONPET - KGF	ANDERSONPET	10:11	10:13	0:02	LINE CLEAR AVAILED
523	5-Jan-19	BANGALORE	66	HV1	ANDERSONPET	10:29	10:32	0:03	LINE CLEAR AVAILED
524	5-Jan-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	9:52	9:58	0:06	LINE FAULT
525	5-Jan-19	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	17:19	17:29	0:09	LOAD CURTAILMENT
526	5-Jan-19	BANGALORE	66	DB PURA 220 - CB PURA 1	TUBUGERE	9:25	19:38	10:13	LINE CLEAR AVAILED
527	5-Jan-19	BANGALORE	66	D PALYA - GUDIBANDE	MANDIKAL, GUDIBANDE, PERESANDRA	15:41	15:57	0:16	LINE FAULT
528	5-Jan-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	15:16	16:00	0:43	LINE FAULT
529	5-Jan-19	BANGALORE	66	HV2	NANGALI	20:56	21:06	0:09	TRANSFORMER FAULT
530	5-Jan-19	BANGALORE	66	HV2	THIMMAMPALLI	13:59	15:12	1:13	LINE CLEAR AVAILED
531	5-Jan-19	BANGALORE	66	HV2	THIMMAMPALLI	15:16	15:22	0:06	LINE CLEAR AVAILED
532	5-Jan-19	BANGALORE	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	8:10	8:15	0:05	LOAD CHANGE OVER
533	5-Jan-19	BANGALORE	66	HV1	HEJJALA	16:27	18:08	1:41	LINE CLEAR AVAILED
534	5-Jan-19	BANGALORE	66	HV2	HEJJALA	13:33	16:27	2:53	LINE CLEAR AVAILED
535	5-Jan-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	10:01	10:10	0:09	LINE FAULT
536	5-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	7:31	7:39	0:08	LINE FAULT
537	5-Jan-19	BANGALORE	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	14:17	14:36	0:19	LOAD CHANGE OVER
538	5-Jan-19	BANGALORE	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE, RBI	14:17	14:35	0:18	LOAD CHANGE OVER
539	5-Jan-19	BANGALORE	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	14:17	14:34	0:16	LOAD CHANGE OVER
540	5-Jan-19	BANGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	14:17	14:35	0:17	LOAD CHANGE OVER
541	5-Jan-19	BANGALORE	66	HV1	KHODAYS 220	14:18	14:34	0:15	LOAD CHANGE OVER
542	5-Jan-19	BANGALORE	66	HV2	KHODAYS 220	14:18	14:34	0:16	LOAD CHANGE OVER



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
543	5-Jan-19	BANGALORE	66	HV1	NAGANATHPURA 220	10:09	11:58	1:48	TRANSFORMER FAULT
544	5-Jan-19	BANGALORE	66	HV1	NAGANATHPURA 220	14:53	15:22	0:29	LINE CLEAR AVAILED
545	5-Jan-19	BANGALORE	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	18:30	18:42	0:12	LOAD CHANGE OVER
546	5-Jan-19	BANGALORE	66	HV2	SIR MV LAYOUT	14:53	17:11	2:17	LINE CLEAR AVAILED
547	5-Jan-19	BANGALORE	66	HV1	SOLADEVANAHALLI	9:33	9:36	0:02	LINE CLEAR AVAILED
548	5-Jan-19	BANGALORE	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	12:44	13:15	0:31	LOAD CHANGE OVER
549	5-Jan-19	BANGALORE	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	12:44	13:08	0:24	LOAD CHANGE OVER
550	5-Jan-19	BANGALORE	220	HV2	TK HALLI 220	12:02	12:12	0:10	TRANSFORMER FAULT
551	5-Jan-19	BANGALORE	220	HV2	TK HALLI 220	12:50	12:55	0:05	TRANSFORMER FAULT
552	5-Jan-19	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	12:02	12:12	0:10	LINE FAULT
553	5-Jan-19	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	12:50	16:35	3:45	MAIN SUPPLY FAILURE
554	5-Jan-19	BANGALORE	66	TK HALLI 220 - IGGALURU	IGGALURU, AKKURMOLE	12:02	12:12	0:10	LINE FAULT
555	5-Jan-19	BANGALORE	66	TK HALLI 220 - IGGALURU	IGGALURU, AKKURMOLE	12:50	12:58	0:08	MAIN SUPPLY FAILURE
556	5-Jan-19	BANGALORE	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, DODDALAHALLI	12:02	12:12	0:10	MAIN SUPPLY FAILURE
557	5-Jan-19	BANGALORE	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, DODDALAHALLI	12:50	12:58	0:08	MAIN SUPPLY FAILURE
558	5-Jan-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	12:02	12:12	0:10	MAIN SUPPLY FAILURE
559	5-Jan-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	12:50	12:58	0:08	MAIN SUPPLY FAILURE
560	5-Jan-19	BANGALORE	66	HV1	TK HALLI 220	12:02	12:12	0:10	MAIN SUPPLY FAILURE
561	5-Jan-19	BANGALORE	66	HV2	TK HALLI 220	12:50	12:58	0:08	MAIN SUPPLY FAILURE
562	5-Jan-19	BANGALORE	66	HV2	TK HALLI 220	14:29	17:30	3:00	LINE CLEAR AVAILED
563	5-Jan-19	BANGALORE	220	SOMANAHALLI 220 - SUBRAMANYAPURA 220	KHODAYS 220	14:22	14:29	0:06	LOAD CHANGE OVER
564	5-Jan-19	BANGALORE	66	HV1	HSR LAYOUT 220	13:34	16:09	2:35	LINE CLEAR AVAILED
565	5-Jan-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 1	RBI	12:44	14:20	1:36	LINE FAULT
566	5-Jan-19	BANGALORE	66	HV2	HEBBAL 220	12:32	12:48	0:16	LINE CLEAR AVAILED
567	5-Jan-19	BANGALORE	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	12:15	13:42	1:26	LINE CLEAR AVAILED
568	5-Jan-19	BANGALORE	66	HOODY 220 - GRAPHITE INDIA (EHT)	GRAPHITE INDIA (EHT)	12:15	13:45	1:29	LINE CLEAR AVAILED
569	5-Jan-19	BANGALORE	66	HOODY 220 - HAL 1 & 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	12:15	13:41	1:26	LINE CLEAR AVAILED
570	5-Jan-19	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	12:15	13:42	1:26	LINE CLEAR AVAILED
571	5-Jan-19	BANGALORE	66	HOODY 220 - HP (EHT)	HP (EHT)	12:15	13:45	1:29	LINE CLEAR AVAILED
572	5-Jan-19	BANGALORE	66	HOODY 220 - ITI	ITI, BANASWADI	12:15	13:40	1:24	LINE CLEAR AVAILED
573	5-Jan-19	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	12:15	12:49	0:33	LINE CLEAR AVAILED
574	5-Jan-19	BANGALORE	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	12:15	13:41	1:25	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
575	5-Jan-19	BANGALORE	66	POTTERY ROAD - HEBBAL 220	POTTERY ROAD, ITC (EHT)	13:42	13:45	0:03	LINE CLEAR AVAILED
576	5-Jan-19	BANGALORE	66	HV1	HOODY 220	12:15	13:42	1:26	LINE CLEAR AVAILED
577	5-Jan-19	BANGALORE	66	HV2	HOODY 220	12:15	13:42	1:26	LINE CLEAR AVAILED
578	5-Jan-19	GULBARGA	220	HV1	RAICHURSA_220	9:50	18:23	8:33	LINE CLEAR AVAILED
579	5-Jan-19	GULBARGA	220	HV2	LINGASUGUR_220	15:06	19:40	4:34	LINE CLEAR AVAILED
580	5-Jan-19	GULBARGA	110	HV2	BETAGERA_110	15:31	15:35	0:04	TRANSFORMER FAULT
581	5-Jan-19	GULBARGA	110	HV1	GANADAL_110	16:42	16:45	0:03	LOAD CURTAILMENT
582	5-Jan-19	GULBARGA	110	HV1	HANUMASAGAR_110	16:40	16:50	0:10	LOAD CURTAILMENT
583	5-Jan-19	GULBARGA	110	HV1	HANUMASAGAR_110	7:52	8:10	0:18	TRANSFORMER FAULT
584	5-Jan-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	6:39	6:47	0:08	LINE FAULT
585	5-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	9:06	9:21	0:15	TRANSFORMER FAULT
586	5-Jan-19	GULBARGA	110	HV1,HV2,HV4	LINGASUGUR_220	11:55	14:45	2:50	LINE CLEAR AVAILED
587	5-Jan-19	GULBARGA	110	HV1,HV2	RAICHUR_220	9:48	10:14	0:26	LINE CLEAR AVAILED
588	5-Jan-19	GULBARGA	110	TEKALKOTE-RNWSLR	TEKKALAKOTE_110	2:10	4:50	2:40	LINE FAULT
589	5-Jan-19	GULBARGA	110	HV1	GANADAL_110	17:19	17:25	0:06	LOAD CURTAILMENT
590	5-Jan-19	GULBARGA	110	HV2	CHINCHOLI_110	16:40	16:50	0:10	LOAD CURTAILMENT
591	5-Jan-19	GULBARGA	110	HV2	CHINCHOLI_110	16:54	17:15	0:21	LOAD CURTAILMENT
592	5-Jan-19	GULBARGA	110	HV3	YELBURGA_110	16:40	17:09	0:29	LOAD CURTAILMENT
593	5-Jan-19	GULBARGA	110	HV2	HATTI_110	17:19	17:24	0:05	LOAD CURTAILMENT
594	5-Jan-19	GULBARGA	110	HV2	KOLHAR_110	17:25	17:40	0:15	LOAD CURTAILMENT
595	5-Jan-19	GULBARGA	110	RAJESHWAR-SASTAPUR	RAJESHWAR_110	17:20	17:35	0:15	LINE FAULT
596	5-Jan-19	GULBARGA	110	HV1	RAJESHWAR_110	17:20	17:50	0:30	LOAD CURTAILMENT
597	5-Jan-19	GULBARGA	110	HV2	RAJESHWAR_110	17:20	17:55	0:35	LOAD CURTAILMENT
598	5-Jan-19	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	11:40	11:45	0:05	TRANSFORMER FAULT
599	5-Jan-19	GULBARGA	66	KOGALI-ATRSOLR	KOGALI_66	11:17	11:24	0:07	LINE CLEAR AVAILED
600	5-Jan-19	GULBARGA	66	HV1	HAMPASAGAR_66	12:25	14:09	1:44	LINE CLEAR AVAILED
601	5-Jan-19	GULBARGA	66	HV2	HAMPASAGAR_66	12:25	14:55	2:30	LINE CLEAR AVAILED
602	5-Jan-19	GULBARGA	66	HV2	HAMPASAGAR_66	15:40	16:25	0:45	LINE CLEAR AVAILED
603	5-Jan-19	GULBARGA	66	CHORNOOR-KUDLIGI	CHORNOOR_66	10:14	11:39	1:25	LINE CLEAR AVAILED
604	5-Jan-19	GULBARGA	66	CHORNOOR-KUDLIGI	CHORNOOR_66	16:20	16:43	0:23	LINE CLEAR AVAILED
605	5-Jan-19	GULBARGA	66	HV2	CHORNOOR_66	10:18	17:09	6:51	LINE CLEAR AVAILED
606	5-Jan-19	HASSAN	400	UPCL-HASSAN2	UPCL_GEN	17:32	23:59	6:27	LINE CLEAR AVAILED
607	5-Jan-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:52	14:52	4:00	LINE CLEAR AVAILED
608	5-Jan-19	HASSAN	220	GERSOPA-TALGUPA1	GERUSOPPA_GEN	10:43	14:22	3:39	LINE CLEAR AVAILED
609	5-Jan-19	HASSAN	220	GERSOPA-TALGUPA2	GERUSOPPA_GEN	10:53	14:52	3:59	LINE CLEAR AVAILED
610	5-Jan-19	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	10:42	14:22	3:40	LINE CLEAR AVAILED
611	5-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:58	19:59	7:01	LINE FAULT
612	5-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:37	12:58	0:21	LINE FAULT
613	5-Jan-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	15:06	17:10	2:04	LINE CLEAR AVAILED
614	5-Jan-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	11:28	14:24	2:56	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
615	5-Jan-19	HASSAN	220	SHRAVTY-SHIMOGA1	SHARAVATHY_GEN	16:12	20:00	3:48	LINE FAULT
616	5-Jan-19	HASSAN	220	SHRAVTY-SHIMOGA4	SHARAVATHY_GEN	16:12	20:00	3:48	LINE FAULT
617	5-Jan-19	HASSAN	220	VARAHI-SHIMOGA1	VARAHI_GEN	15:03	17:11	2:08	LINE CLEAR AVAILED
618	5-Jan-19	HASSAN	220	VARAHI-SHMG3	VARAHI_GEN	7:18	14:23	7:05	LINE FAULT
619	5-Jan-19	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	9:56	12:30	2:34	LINE CLEAR AVAILED
620	5-Jan-19	HASSAN	110	HV2	BARANGI_110	11:01	11:43	0:42	LINE CLEAR AVAILED
621	5-Jan-19	HASSAN	110	HV1	BIRUR_110	16:42	16:53	0:11	LOAD CURTAILMENT
622	5-Jan-19	HASSAN	110	HV2	GANDASI_110	16:47	17:15	0:28	LOAD CURTAILMENT
623	5-Jan-19	HASSAN	110	HV2	GERUMARA_110	16:54	17:15	0:21	LOAD CURTAILMENT
624	5-Jan-19	HASSAN	110	HV2	KEMAR_220	13:04	14:05	1:01	LINE CLEAR AVAILED
625	5-Jan-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	0:00	10:13	10:13	LINE FAULT
626	5-Jan-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	8:29	17:46	9:17	LINE CLEAR AVAILED
627	5-Jan-19	HASSAN	66	HV2	CHIKMAGALUR_66	11:06	16:56	5:50	LINE CLEAR AVAILED
628	5-Jan-19	HASSAN	66	HV1	HANGRANAHALLI_66	16:54	17:03	0:09	LOAD CURTAILMENT
629	5-Jan-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	21:45	21:59	0:14	LINE FAULT
630	5-Jan-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	10:35	10:40	0:05	HAND TRIPPED
631	5-Jan-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	12:45	13:10	0:25	LINE CLEAR AVAILED
632	5-Jan-19	HASSAN	66	HV1	SIGEBAGE_66	13:26	14:23	0:57	LINE CLEAR AVAILED
633	5-Jan-19	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	14:02	14:22	0:20	LINE FAULT
634	5-Jan-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	16:40	16:45	0:05	LOAD CURTAILMENT
635	5-Jan-19	HASSAN	66	KIADB H-RAMESHWARNAGAR	KIADB_66	0:00	11:01	11:01	LINE CLEAR AVAILED
636	5-Jan-19	HASSAN	66	KIADB H-RAMESHWARNAGAR	KIADB_66	13:00	17:04	4:04	LOAD CURTAILMENT
637	5-Jan-19	HASSAN	66	HV2	BASAVAGHATTA_66	16:54	17:07	0:13	LOAD CURTAILMENT
638	5-Jan-19	MYSORE	66	HV2	ADDIHALLI_66	16:54	17:04	0:10	LOAD CURTAILMENT
639	5-Jan-19	MYSORE	66	HV2	AKKIHEBBAL_66	16:39	16:49	0:09	LOAD CURTAILMENT
640	5-Jan-19	MYSORE	66	HV1	BGNAGARA_66	16:55	17:09	0:14	LOAD CURTAILMENT
641	5-Jan-19	MYSORE	66	HV1	BGPURA_66	16:54	17:06	0:12	LOAD CURTAILMENT
642	5-Jan-19	MYSORE	66	HV1	BILIKERE_66	16:54	17:06	0:12	LOAD CURTAILMENT
643	5-Jan-19	MYSORE	66	HV1	BOOKANAKERE_66	15:05	16:27	1:21	LINE CLEAR AVAILED
644	5-Jan-19	MYSORE	66	HV2	BOOKANAKERE_66	16:39	16:55	0:15	LOAD CURTAILMENT
645	5-Jan-19	MYSORE	66	HV2	CHINAKURALI_66	16:40	16:50	0:10	LOAD CURTAILMENT
646	5-Jan-19	MYSORE	66	HV1	DODDINADUVADI_66	16:54	17:03	0:08	LOAD CURTAILMENT
647	5-Jan-19	MYSORE	66	HV2	DODDARAYAPET_66	16:54	17:15	0:20	LOAD CURTAILMENT
648	5-Jan-19	MYSORE	66	HV2	HANNUR_66	16:40	16:55	0:14	LOAD CURTAILMENT
649	5-Jan-19	MYSORE	66	HV2	HDKOTE_66	16:54	17:10	0:15	LOAD CURTAILMENT
650	5-Jan-19	MYSORE	66	HOOTAGALLI-HUNSUR	HOSURGATE_66	14:48	17:08	2:19	LINE CLEAR AVAILED
651	5-Jan-19	MYSORE	66	HV2	HOOTAGALLY_220	12:26	13:15	0:48	LINE CLEAR AVAILED
652	5-Jan-19	MYSORE	66	HV2	JAIPUR_66	16:54	17:11	0:16	LOAD CURTAILMENT
653	5-Jan-19	MYSORE	66	HV1	K_HONNALGERE_66	12:00	12:28	0:27	HAND TRIPPED
654	5-Jan-19	MYSORE	66	HV1	K_HONNALGERE_66	12:36	13:29	0:53	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
655	5-Jan-19	MYSORE	66	HV2	K_HONNALGERE_66	12:00	12:28	0:27	HAND TRIPPED
656	5-Jan-19	MYSORE	66	HV2	K_HONNALGERE_66	12:36	13:29	0:53	HAND TRIPPED
657	5-Jan-19	MYSORE	66	HV1	K_HONNALGERE_66	16:29	16:36	0:07	HAND TRIPPED
658	5-Jan-19	MYSORE	66	HV2	K_HONNALGERE_66	16:29	16:36	0:07	HAND TRIPPED
659	5-Jan-19	MYSORE	66	HV2	K_HONNALGERE_66	13:33	13:34	0:01	HAND TRIPPED
660	5-Jan-19	MYSORE	66	HV1	KIADBMANDYA_66	9:15	9:50	0:35	TRANSFORMER FAULT
661	5-Jan-19	MYSORE	66	HV2	KIADBMANDYA_66	9:15	9:51	0:36	TRANSFORMER FAULT
662	5-Jan-19	MYSORE	66	HV1	KIADBMANDYA_66	9:53	11:11	1:18	TRANSFORMER FAULT
663	5-Jan-19	MYSORE	66	HV2	KIADBMANDYA_66	9:53	10:02	0:08	TRANSFORMER FAULT
664	5-Jan-19	MYSORE	66	HV2	KIRUGAVALU_66	16:40	17:10	0:29	LOAD CURTAILMENT
665	5-Jan-19	MYSORE	66	HV2	KMDODDI_66	16:55	17:09	0:14	LOAD CURTAILMENT
666	5-Jan-19	MYSORE	66	HV2	KOLLEGALA_66	16:55	17:16	0:20	LOAD CURTAILMENT
667	5-Jan-19	MYSORE	66	HV1	MADDUR_66	16:54	17:05	0:10	LOAD CURTAILMENT
668	5-Jan-19	MYSORE	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	23:33	23:56	0:23	LINE FAULT
669	5-Jan-19	MYSORE	66	HV1	MEGALAPURA_66	16:55	17:01	0:06	LOAD CURTAILMENT
670	5-Jan-19	MYSORE	66	HV1	NAGAMANGALA_66	16:50	16:55	0:05	LOAD CURTAILMENT
671	5-Jan-19	MYSORE	66	HV1	PGPALYA_66	14:51	15:05	0:13	TRANSFORMER FAULT
672	5-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	12:14	18:26	6:11	HAND TRIPPED
673	5-Jan-19	MYSORE	66	HV2	TUBINAKERE_220	11:30	12:01	0:30	TRANSFORMER FAULT
674	5-Jan-19	MYSORE	66	HV1	YELANDUR_66	16:39	16:45	0:05	LOAD CURTAILMENT
675	5-Jan-19	TUMKUR	220	TR-1(HV SIDE )	THALLAKK_220	11:47	14:11	2:24	LINE CLEAR AVAILED
676	5-Jan-19	TUMKUR	110	HONNAVALLI 110-ADANSOLAR_IPP_110	ADANSOLAR_IPP_110	12:35	12:40	0:04	HAND TRIPPED
677	5-Jan-19	TUMKUR	110	TR-1	GUBBI_110	11:04	13:16	2:11	LINE CLEAR AVAILED
678	5-Jan-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	17:15	17:23	0:07	LOAD CURTAILMENT
679	5-Jan-19	TUMKUR	66	TR-2	BADDIHALLI_66	6:49	11:34	4:45	LINE CLEAR AVAILED
680	5-Jan-19	TUMKUR	66	TR-1	CHANNAGIRI_66	7:57	8:03	0:05	TRANSFORMER FAULT
681	5-Jan-19	TUMKUR	66	CHITRADURGA 220kV- SUZLON 2	SUZLON1_IPP_66, SUZLON2_IPP_66	18:26	19:05	0:39	LINE FAULT
682	5-Jan-19	TUMKUR	66	CHITRADURGA 220kV- SUZLON1	SUZLON1_IPP_66, SUZLON2_IPP_66	18:10	19:11	1:00	LINE FAULT
683	5-Jan-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:33	6:57	0:24	LINE FAULT
684	5-Jan-19	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	10:31	13:29	2:57	HAND TRIPPED
685	5-Jan-19	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	13:26	13:29	0:03	HAND TRIPPED
686	5-Jan-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:27	9:40	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
687	5-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:31	17:55	9:23	HAND TRIPPED
688	5-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	18:07	18:37	0:30	HAND TRIPPED
689	5-Jan-19	TUMKUR	66	TR-1	KATTIGE_66	8:06	8:24	0:17	TRANSFORMER FAULT
690	5-Jan-19	TUMKUR	66	MADHUGIRI 220kV- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	12:11	12:17	0:05	LINE FAULT
691	5-Jan-19	TUMKUR	66	NAGALAMADIKE- MUNIRAJ SOLAR_IPP_66	MUNIRAJ SOLAR_IPP_66	18:19	20:16	1:56	LINE CLEAR AVAILED
692	5-Jan-19	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	17:51	18:02	0:11	HAND TRIPPED
693	5-Jan-19	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE_66	17:55	18:05	0:09	HAND TRIPPED
694	5-Jan-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	12:11	12:21	0:09	LINE FAULT
695	5-Jan-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	18:43	21:44	3:00	LINE FAULT
696	5-Jan-19	TUMKUR	66	NAYAKANAHATTI66-THALLAKK	NAYAKANAHATTI_66	13:41	14:05	0:23	LINE FAULT
697	5-Jan-19	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	11:46	14:16	2:29	LINE CLEAR AVAILED
698	5-Jan-19	TUMKUR	66	TR-2(LV2)	THALLAKK_220	13:41	13:58	0:16	TRANSFORMER FAULT
699	5-Jan-19	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	DIAMOND_IPP_66	11:45	12:13	0:27	HAND TRIPPED
700	5-Jan-19	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEI DIAMOND SOLAR_IPP_66	11:45	13:33	1:48	HAND TRIPPED
701	5-Jan-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:45	14:20	2:34	HAND TRIPPED
702	6-Jan-19	BAGALKOT	110	110/11KV,HV-2	AREMALLAPUR_110	11:03	12:28	1:25	LINE CLEAR AVAILED
703	6-Jan-19	BAGALKOT	220	220/110KV,HV1&LV1	BELAGUM_220	10:23	14:25	4:02	LINE CLEAR AVAILED
704	6-Jan-19	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	2:23	15:42	13:19	TRANSFORMER FAULT
705	6-Jan-19	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	11:58	12:00	0:02	TRANSFORMER FAULT
706	6-Jan-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,33KV KOLIGUDDA ,SULTANPUR	11:58	12:02	0:04	TRANSFORMER FAULT
707	6-Jan-19	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110,33KV ALAGAWADI	11:58	12:01	0:03	TRANSFORMER FAULT
708	6-Jan-19	BAGALKOT	110	KARWAR-KUMTA	KUMTA_110	14:30	15:55	1:25	LINE CLEAR AVAILED
709	6-Jan-19	BAGALKOT	110	P G HUNSYAL-NAGANUR	NAGANUR_110	8:42	8:49	0:07	LINE FAULT
710	6-Jan-19	BAGALKOT	110	SATTI SUGARS-P G HUNSYAL	P G HUNSYAL_110	8:42	8:49	0:07	HAND TRIPPED
711	6-Jan-19	BAGALKOT	220	BELGAUM1-CHIKKODI	CHIKKODI_220	0:00	8:59	8:59	HAND TRIPPED
712	6-Jan-19	BANGALORE	66	ANDERSONPET - KGF	ANDERSONPET	10:11	10:13	0:02	LINE CLEAR AVAILED
713	6-Jan-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	8:32	9:04	0:32	LINE FAULT
714	6-Jan-19	BANGALORE	66	A STATION 220 - VICTORIA	VICTORIA	9:12	9:17	0:04	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
715	6-Jan-19	BANGALORE	66	HV1	BYADARAHALLI	9:33	9:38	0:05	LINE CLEAR AVAILED
716	6-Jan-19	BANGALORE	66	HV2	BYADARAHALLI	10:32	10:37	0:05	LINE CLEAR AVAILED
717	6-Jan-19	BANGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	8:24	8:27	0:03	LOAD CHANGE OVER
718	6-Jan-19	BANGALORE	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	9:20	9:26	0:06	LOAD CHANGE OVER
719	6-Jan-19	BANGALORE	66	PLATINUM CITY - SAHAKARINAGAR	PLATINUM CITY	13:50	13:55	0:05	LOAD CHANGE OVER
720	6-Jan-19	BANGALORE	66	RAJANAKUNTE - DB PURA 220	RAJANAKUNTE	17:50	17:55	0:05	LOAD CHANGE OVER
721	6-Jan-19	BANGALORE	66	RBI - ELITE PROMENEDE	RBI	9:20	9:25	0:05	LOAD CHANGE OVER
722	6-Jan-19	BANGALORE	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	8:42	8:43	0:01	LOAD CHANGE OVER
723	6-Jan-19	BANGALORE	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	7:40	7:45	0:05	LOAD CHANGE OVER
724	6-Jan-19	BANGALORE	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	11:44	11:49	0:04	LOAD CHANGE OVER
725	6-Jan-19	BANGALORE	66	SHOBHA APARTMENT - CESSNO	SHOBHA APARTMENT	13:43	13:46	0:02	LOAD CHANGE OVER
726	6-Jan-19	BANGALORE	66	HEBBAL 220 - C STATION 1 & 2	C STATION	17:26	17:45	0:18	LINE CLEAR AVAILED
727	6-Jan-19	BANGALORE	66	HV1	C STATION	16:42	17:45	1:02	LINE CLEAR AVAILED
728	6-Jan-19	BANGALORE	66	HV2	C STATION	17:30	17:45	0:14	LINE CLEAR AVAILED
729	6-Jan-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	8:32	9:04	0:32	LINE FAULT
730	6-Jan-19	BANGALORE	66	DABUSPET 220 - HIREHALLI	HIREHALLI	9:20	9:38	0:18	LOAD CHANGE OVER
731	6-Jan-19	BANGALORE	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	7:49	7:54	0:04	LOAD CHANGE OVER
732	6-Jan-19	BANGALORE	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	18:18	18:20	0:02	LOAD CHANGE OVER
733	6-Jan-19	BANGALORE	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU	9:19	9:27	0:08	LOAD CHANGE OVER
734	6-Jan-19	BANGALORE	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU	18:12	18:16	0:03	LOAD CHANGE OVER
735	6-Jan-19	BANGALORE	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU	18:19	18:21	0:01	LOAD CHANGE OVER
736	6-Jan-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	7:46	7:55	0:08	LINE FAULT
737	6-Jan-19	BANGALORE	66	HV1	GUNDLU KOTTUR	8:31	8:32	0:01	TRANSFORMER FAULT
738	6-Jan-19	BANGALORE	66	HV1	KGF	2:07	2:19	0:11	TRANSFORMER FAULT
739	6-Jan-19	BANGALORE	66	HV1	KGF	2:19	2:50	0:30	TRANSFORMER FAULT
740	6-Jan-19	BANGALORE	66	KGF - BEML (EHT)	BEML (EHT)	9:05	21:30	12:25	LINE CLEAR AVAILED
741	6-Jan-19	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	13:51	13:59	0:07	LOAD CHANGE OVER
742	6-Jan-19	BANGALORE	66	TG HALLI - ANCHEPALYA 220	TG HALLI	4:00	4:20	0:20	LINE CLEAR AVAILED
743	6-Jan-19	BANGALORE	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	9:27	9:32	0:05	LOAD CHANGE OVER
744	6-Jan-19	BANGALORE	66	WELCAST STEEL - SAHAKARINAGAR	WELCAST STEEL	13:48	13:53	0:05	LOAD CHANGE OVER
745	6-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	6:19	6:36	0:17	LINE FAULT
746	6-Jan-19	BANGALORE	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	17:35	17:40	0:05	LOAD CHANGE OVER
747	6-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	6:47	7:00	0:12	LINE FAULT
748	6-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	17:09	17:15	0:05	LINE CLEAR AVAILED
749	6-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 8	RAJANKUNTE	13:38	14:01	0:22	LINE FAULT
750	6-Jan-19	BANGALORE	66	KANASWADI - DB PURA 220	KANASWADI	12:15	12:20	0:05	LOAD CHANGE OVER
751	6-Jan-19	BANGALORE	66	KANASWADI - YELAHANKA 220	KANASWADI	18:00	18:05	0:05	LOAD CHANGE OVER
752	6-Jan-19	GULBARGA	220	SINDHANOOR-LINGAPUR	SIDHANOOR_220	4:07	10:30	6:23	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
753	6-Jan-19	GULBARGA	220	HV1	SIDHANOOR_220	9:15	12:49	3:34	LINE CLEAR AVAILED
754	6-Jan-19	GULBARGA	220	HV2	SIDHANOOR_220	12:50	17:05	4:15	LINE CLEAR AVAILED
755	6-Jan-19	GULBARGA	110	SINDHANOOR220-PGLR_WIND	SIDHANOOR_220	5:50	6:06	0:16	LINE FAULT
756	6-Jan-19	GULBARGA	110	HV1	SIRWAR_110	17:25	19:16	1:51	TRANSFORMER FAULT
757	6-Jan-19	HASSAN	220	HV1	HASSAN_220	0:00	19:58	19:58	LINE CLEAR AVAILED
758	6-Jan-19	HASSAN	220	HV1	HASSAN_220	9:39	11:54	2:15	LINE CLEAR AVAILED
759	6-Jan-19	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	9:56	12:30	2:34	LINE CLEAR AVAILED
760	6-Jan-19	HASSAN	110	KADUR-AJAMPURA	KADUR_220	10:23	11:29	1:06	LINE CLEAR AVAILED
761	6-Jan-19	HASSAN	66	HASSN22-HN PURA	HASSAN_220	12:40	16:18	3:38	LINE FAULT
762	6-Jan-19	HASSAN	66	HASSN22-HASSAN	HASSAN_220	12:10	12:15	0:05	HAND TRIPPED
763	6-Jan-19	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	12:10	12:18	0:08	HAND TRIPPED
764	6-Jan-19	HASSAN	66	HASSN22-ARKALG2	HASSAN_220	11:44	11:57	0:13	HAND TRIPPED
765	6-Jan-19	HASSAN	66	HASSN22-CRP2	HASSAN_220	11:44	11:57	0:13	HAND TRIPPED
766	6-Jan-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	10:45	13:45	3:00	MAIN SUPPLY FAILURE
767	6-Jan-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	10:45	13:45	3:00	MAIN SUPPLY FAILURE
768	6-Jan-19	HASSAN	66	HV1	SAKALESH PURA_66	10:44	11:35	0:51	LINE CLEAR AVAILED
769	6-Jan-19	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	10:48	11:13	0:25	NBFC ISSUED
770	6-Jan-19	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	12:07	13:28	1:21	NBFC ISSUED
771	6-Jan-19	HASSAN	66	HV1	SALAGAME_66	17:29	17:34	0:05	TRANSFORMER FAULT
772	6-Jan-19	HASSAN	66	HV1	SALAGAME_66	10:49	11:13	0:24	HAND TRIPPED
773	6-Jan-19	HASSAN	66	HV1	SALAGAME_66	13:15	13:28	0:13	HAND TRIPPED
774	6-Jan-19	HASSAN	66	HV2	SALAGAME_66	10:49	11:14	0:25	HAND TRIPPED
775	6-Jan-19	HASSAN	66	HV2	SALAGAME_66	13:15	13:28	0:13	HAND TRIPPED
776	6-Jan-19	MYSORE	66	KOLLEGALA-CR NAGARA	KOLLEGALA_66	10:00	14:13	4:13	NBFC ISSUED
777	6-Jan-19	MYSORE	66	KOLLEGALA-SATHEGALA	KOLLEGALA_66	10:55	14:13	3:17	NBFC ISSUED
778	6-Jan-19	MYSORE	66	KOLLEGALA-TALAKADU	KOLLEGALA_66	10:44	14:13	3:28	NBFC ISSUED
779	6-Jan-19	MYSORE	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	9:49	10:37	0:48	HAND TRIPPED
780	6-Jan-19	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	KOLLEGALA_66	11:09	14:12	3:02	LINE CLEAR AVAILED
781	6-Jan-19	MYSORE	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	0:20	0:31	0:11	HAND TRIPPED
782	6-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	7:16	15:24	8:07	HAND TRIPPED
783	6-Jan-19	MYSORE	66	HV1	VAJAMANGALA_220	7:42	9:08	1:26	LINE CLEAR AVAILED
784	6-Jan-19	TUMKUR	66	ANTHRASANA HALLI 220KV- MELEKOTE	MELKOTE_66, BADDI HALLI_66	10:04	10:23	0:19	LINE FAULT
785	6-Jan-19	TUMKUR	66	ANTHRASANA HALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	18:25	18:28	0:02	HAND TRIPPED
786	6-Jan-19	TUMKUR	66	BADDI HALLI- MELEKOTE	BADDI HALLI_66	10:43	10:46	0:03	HAND TRIPPED
787	6-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:11	17:37	9:25	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
788	6-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	12:38	13:00	0:21	LINE FAULT
789	6-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	8:14	8:25	0:11	HAND TRIPPED
790	6-Jan-19	TUMKUR	66	KEMPANAHALLI - AGALAKOTE	AGALKOTE_66	13:06	13:42	0:35	LINE CLEAR AVAILED
791	6-Jan-19	TUMKUR	66	NAGALAMADIKE- RNS INFRA SOLAR_IPP_66	RNS INFRA SOLAR_IPP_66	19:33	19:43	0:09	LINE FAULT
792	6-Jan-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	17:46	17:50	0:03	HAND TRIPPED
793	7-Jan-19	BAGALKOT	110	110/11KV,HV-2	AREMALLAPUR_110	17:44	18:21	0:37	LINE CLEAR AVAILED
794	7-Jan-19	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	6:17	12:20	6:03	LINE FAULT
795	7-Jan-19	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPANAKOPPA_110	13:13	13:19	0:06	HAND TRIPPED
796	7-Jan-19	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPANAKOPPA_110	13:46	13:52	0:06	HAND TRIPPED
797	7-Jan-19	BAGALKOT	110	110/11KV,HV-1	GOPANAKOPPA_110	12:41	14:41	2:00	HAND TRIPPED
798	7-Jan-19	BAGALKOT	110	GOPANAKOPPA-MR NAGAR 1&2	GOPANAKOPPA_110	13:06	13:11	0:05	HAND TRIPPED
799	7-Jan-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	8:24	11:10	2:46	HAND TRIPPED
800	7-Jan-19	BAGALKOT	110	SUVARNASOUDA-MACHE	MACHE_110	0:43	0:58	0:15	MAIN SUPPLY FAILURE
801	7-Jan-19	BAGALKOT	110	110/33KV, HV3	SANKESHWAR_110,HEBBAL_33,KANAGAL_33	10:55	11:08	0:13	LINE CLEAR AVAILED
802	7-Jan-19	BAGALKOT	110	110/11KV, HV2	MUNAVALLI_110	20:00	20:04	0:04	TRANSFORMER FAULT
803	7-Jan-19	BAGALKOT	110	110/11KV,HV2	MKHUBLI_220	15:24	16:41	1:17	LINE CLEAR AVAILED
804	7-Jan-19	BAGALKOT	110	110/11KV,HV2	MKHUBLI_220	17:35	17:38	0:03	HAND TRIPPED
805	7-Jan-19	BAGALKOT	110	110/33KV, HV4	LAKMANAHALLI_110, ALNAVAR_33	12:15	12:21	0:06	TRANSFORMER FAULT
806	7-Jan-19	BAGALKOT	110	110/11KV, HV1	KAGAWAD_110	11:13	13:23	2:10	LINE CLEAR AVAILED
807	7-Jan-19	BAGALKOT	110	110/33KV, HV1&HV2	JAMKHANDI_110, HIPPARGI_33, MUNDAGANUR_33	10:24	15:03	4:39	LINE CLEAR AVAILED
808	7-Jan-19	BAGALKOT	110	INDI220-INDI	INDI_110	14:48	14:52	0:04	LINE CLEAR AVAILED
809	7-Jan-19	BAGALKOT	220	VAISHALI1-BIJAPUR	BIJAPUR_220	11:31	17:42	6:11	LINE CLEAR AVAILED
810	7-Jan-19	BANGALORE	66	HV1	CHAKAVELU	9:58	10:05	0:06	LINE CLEAR AVAILED
811	7-Jan-19	BANGALORE	66	HV2	CHAKAVELU	13:46	13:50	0:03	LINE CLEAR AVAILED
812	7-Jan-19	BANGALORE	66	DALASANUR - SRINIVASPURA	DALASANUR	15:30	15:35	0:05	LOAD CHANGE OVER
813	7-Jan-19	BANGALORE	66	DALASANUR - MALLASANDRA	DALASANUR	11:40	14:05	2:25	LINE CLEAR AVAILED
814	7-Jan-19	BANGALORE	66	HV2	GUDIBANDE	14:16	14:28	0:11	LINE CLEAR AVAILED
815	7-Jan-19	BANGALORE	66	HV1	GUNDLU KOTTUR	7:30	7:40	0:10	TRANSFORMER FAULT
816	7-Jan-19	BANGALORE	66	HV1	GUNDLU KOTTUR	5:42	5:44	0:02	TRANSFORMER FAULT
817	7-Jan-19	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	15:51	18:19	2:28	LINE CLEAR AVAILED
818	7-Jan-19	BANGALORE	66	MALLASANDRA - KOLAR 220	MALLASANDRA	11:30	15:03	3:33	LINE CLEAR AVAILED
819	7-Jan-19	BANGALORE	66	HV2	NANGALI	12:01	12:40	0:39	LINE CLEAR AVAILED
820	7-Jan-19	BANGALORE	66	YELAHANKA 220 - DG 3	ATTUR YELAHANKA, MANYATHA TECH PARK, ABBIGERE	9:11	9:22	0:11	LINE FAULT
821	7-Jan-19	BANGALORE	220	HV1	YELAHANKA 220	10:02	10:05	0:02	TRANSFORMER FAULT
822	7-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 8	RAJANKUNTE	10:02	10:22	0:20	MAIN SUPPLY FAILURE



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
823	7-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLDEVANAHALLI	10:02	10:16	0:13	MAIN SUPPLY FAILURE
824	7-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 5	KHB	10:02	10:04	0:01	MAIN SUPPLY FAILURE
825	7-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 4	SAHAKARINAGAR, RAILWAYS (EHT)	10:02	10:07	0:04	MAIN SUPPLY FAILURE
826	7-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE7	KANASWADI	10:02	10:04	0:01	MAIN SUPPLY FAILURE
827	7-Jan-19	BANGALORE	66	ABBIGERE - WELCAST	ABBIGERE	11:43	11:48	0:04	LOAD CHANGE OVER
828	7-Jan-19	BANGALORE	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	9:22	9:38	0:16	MAIN SUPPLY FAILURE
829	7-Jan-19	BANGALORE	66	EPIP 220 - CHANDAPURA 2	SHAM RAJU TECH PARK, KACHAMARANAHALLI	15:25	15:27	0:02	LOAD CHANGE OVER
830	7-Jan-19	BANGALORE	66	EPIP 220 - CHANDAPURA 2	SHAM RAJU TECH PARK, KACHAMARANAHALLI	18:18	18:23	0:05	LOAD CHANGE OVER
831	7-Jan-19	BANGALORE	66	HV3	HEBBAL 220	12:04	12:31	0:27	LINE CLEAR AVAILED
832	7-Jan-19	BANGALORE	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA, ALEMBIC GLASS(EHT)	15:27	15:37	0:10	LINE CLEAR AVAILED
833	7-Jan-19	BANGALORE	66	HV2	KHODAYS 220	12:23	12:28	0:04	LINE CLEAR AVAILED
834	7-Jan-19	BANGALORE	66	RAJANAKUNTE - YELAHANKA 220	RAJANAKUNTE	10:22	10:24	0:01	MAIN SUPPLY FAILURE
835	7-Jan-19	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	11:27	11:30	0:03	LOAD CHANGE OVER
836	7-Jan-19	BANGALORE	66	RBI - ELITE PROMENEDE	RBI	16:00	16:05	0:05	LOAD CHANGE OVER
837	7-Jan-19	BANGALORE	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	15:45	15:48	0:03	LOAD CHANGE OVER
838	7-Jan-19	BANGALORE	66	HV3	YERANDANAHALLI 220	13:08	15:31	2:23	LINE CLEAR AVAILED
839	7-Jan-19	BANGALORE	66	HV2	YERANDANAHALLI 220	14:38	19:00	4:22	TRANSFORMER FAULT
840	7-Jan-19	BANGALORE	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	9:22	9:40	0:18	MAIN SUPPLY FAILURE
841	7-Jan-19	BANGALORE	66	HV1	SARJAPURA 220	10:00	10:10	0:10	TRANSFORMER FAULT
842	7-Jan-19	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	15:00	15:05	0:05	LOAD CHANGE OVER
843	7-Jan-19	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	16:10	16:15	0:05	LOAD CHANGE OVER
844	7-Jan-19	GULBARGA	220	HV1	HALBARGA_220	6:25	6:42	0:17	TRANSFORMER FAULT
845	7-Jan-19	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	18:30	23:59	5:29	LINE CLEAR AVAILED
846	7-Jan-19	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	5:12	5:44	0:32	LINE FAULT
847	7-Jan-19	GULBARGA	110	SINDHANOOR-PGLR_WIND	SIDHANOOR_220	5:17	5:38	0:21	LINE FAULT
848	7-Jan-19	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110	6:25	6:40	0:15	LINE FAULT
849	7-Jan-19	GULBARGA	110	BETAGERA-KESHAVCMNT_SLR	BETAGERA_110	18:08	20:41	2:33	LINE CLEAR AVAILED
850	7-Jan-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110,BTPS WATER WORKS_IPP	22:23	22:34	0:11	LINE FAULT
851	7-Jan-19	GULBARGA	66	HV1	CHORNOOR_66	11:59	12:15	0:16	LINE CLEAR AVAILED
852	7-Jan-19	GULBARGA	66	ITTAGI-KUDILIGI1,2	KUDILIGI_66,KOGALI_66,CJHALLI_66,BANVE KAL_66,HOSAHALLI_66,CHORNOOR_66,HAN ASI_66,GUDEKOTE_66	11:56	13:50	1:54	LINE CLEAR AVAILED
853	7-Jan-19	GULBARGA	66	ITTAGI-SUZLON2	ITTAGI_220	11:56	14:23	2:27	LINE FAULT
854	7-Jan-19	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	9:55	12:49	2:54	LINE CLEAR AVAILED
855	7-Jan-19	HASSAN	110	KGURUPUR-AVOOR	GURUPURA_220	0:00	12:15	12:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
856	7-Jan-19	HASSAN	110	KGURUPUR-AVOOR	GURUPURA_220	13:26	23:59	10:33	LINE CLEAR AVAILED
857	7-Jan-19	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_66	12:19	13:22	1:03	LINE CLEAR AVAILED
858	7-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:08	20:12	13:04	LINE CLEAR AVAILED
859	7-Jan-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	11:25	17:50	6:25	MAIN SUPPLY FAILURE
860	7-Jan-19	HASSAN	66	HV1	GENDEHALLY_66	14:26	14:55	0:29	LINE CLEAR AVAILED
861	7-Jan-19	HASSAN	66	HV1	HOLALUR_66	14:42	15:20	0:38	LINE CLEAR AVAILED
862	7-Jan-19	HASSAN	66	UDDURKKO-SUZLON1	UDDURKOPPLU_66	16:05	17:31	1:26	LINE CLEAR AVAILED
863	7-Jan-19	HASSAN	66	UDDURKKO-SUZLON2	UDDURKOPPLU_66	6:33	18:05	11:32	LINE FAULT
864	7-Jan-19	HASSAN	66	HV1	MALLAPURA_66	14:45	15:25	0:40	MAIN SUPPLY FAILURE
865	7-Jan-19	HASSAN	66	HV2	MALLAPURA_66	14:45	15:25	0:40	MAIN SUPPLY FAILURE
866	7-Jan-19	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	14:45	15:25	0:40	MAIN SUPPLY FAILURE
867	7-Jan-19	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:20	17:50	6:30	LINE CLEAR AVAILED
868	7-Jan-19	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	9:05	17:50	8:45	LINE CLEAR AVAILED
869	7-Jan-19	MYSORE	66	HV1	HONNALLY_MYS_66	11:40	12:08	0:28	HAND TRIPPED
870	7-Jan-19	MYSORE	66	HV2	HONNALLY_MYS_66	11:44	12:08	0:24	HAND TRIPPED
871	7-Jan-19	MYSORE	66	KABBALLY-GUNDLUPETE	HARVEY_66	12:16	14:04	1:47	LINE CLEAR AVAILED
872	7-Jan-19	MYSORE	66	HV1	MADIKERI_66	10:36	11:55	1:18	LINE CLEAR AVAILED
873	7-Jan-19	MYSORE	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	13:05	13:13	0:08	LINE FAULT
874	7-Jan-19	MYSORE	66	HV2	MANDYA_66	20:23	20:49	0:26	TRANSFORMER FAULT
875	7-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	0:40	7:39	6:58	HAND TRIPPED
876	7-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	14:11	21:14	7:02	HAND TRIPPED
877	7-Jan-19	MYSORE	66	HV1	VAJAMANGALA_220	11:38	12:42	1:04	LINE CLEAR AVAILED
878	7-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	13:26	14:03	0:36	LINE CLEAR AVAILED
879	7-Jan-19	TUMKUR	66	TR-1	BAGUR_66	9:28	9:39	0:10	TRANSFORMER FAULT
880	7-Jan-19	TUMKUR	66	TR-1	BAGUR_66	10:05	10:12	0:06	TRANSFORMER FAULT
881	7-Jan-19	TUMKUR	66	TR-1	BAGUR_66	12:28	12:43	0:15	TRANSFORMER FAULT
882	7-Jan-19	TUMKUR	66	TR-1	BAGUR_66	17:21	17:28	0:07	TRANSFORMER FAULT
883	7-Jan-19	TUMKUR	66	TR-1	BAGUR_66	21:16	21:30	0:13	TRANSFORMER FAULT
884	7-Jan-19	TUMKUR	66	TR-1	BAGUR_66	21:57	22:04	0:06	TRANSFORMER FAULT
885	7-Jan-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	12:02	13:21	1:18	LINE CLEAR AVAILED
886	7-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:45	17:47	10:01	HAND TRIPPED
887	7-Jan-19	TUMKUR	66	H D PURA- MMCLWINDMILL	MMCLWINDMILL_IPP_66	9:30	10:50	1:20	HAND TRIPPED
888	7-Jan-19	TUMKUR	66	TR-2	HINDASGHATTA_66	14:17	14:47	0:30	LINE CLEAR AVAILED
889	7-Jan-19	TUMKUR	66	TR-2	HIREHALLY_66	16:36	16:50	0:13	TRANSFORMER FAULT
890	7-Jan-19	TUMKUR	66	TR-1 & TR-2	HULIYURDURGA_66	14:26	15:59	1:33	LINE CLEAR AVAILED
891	7-Jan-19	TUMKUR	66	TR-1	MALLASANDRA_66	10:03	10:09	0:05	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station Name	Open_At	Closed_At	Duration	REASON
892	7-Jan-19	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	10:16	10:25	0:08	LINE FAULT
893	7-Jan-19	TUMKUR	66	NAGALAMADIKE- ATRIA_IPP_66	ATRIA_IPP_66	10:49	10:53	0:03	HAND TRIPPED
894	7-Jan-19	TUMKUR	66	TR-1	SASALUHALLA_66	7:06	7:16	0:10	TRANSFORMER FAULT