

400/220/110/66 kV TRANSMISSION OUTAGES FROM 13.07.21 TO 19.7.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	13-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVOIDED
2	13-Jul-2021	BAGALKOT	110	110/11KV, HV1	MUGALKOD_110	00:34 (11.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
3	13-Jul-2021	BAGALKOT	110	110/11KV, HV1	TUMMINKATTI_110	15:51	16:36	0:45	LINE CLEAR AVOIDED
4	13-Jul-2021	BAGALKOT	110	110/11KV, HV1	TILUVALLI_110	9:06	11:10	2:04	TRANSFORMER FAULT
5	13-Jul-2021	BAGALKOT	110	110/11KV, HV3	TILUVALLI_110	1:43	2:01	0:18	TRANSFORMER FAULT
6	13-Jul-2021	BAGALKOT	110	110/11KV, LV2	MKHUBLI_220	4:19	7:02	2:43	LINE CLEAR AVOIDED
7	13-Jul-2021	BAGALKOT	110	110/11KV,HV 1	ACHANUR_110	2:47 (10.07.2021)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
8	13-Jul-2021	BAGALKOT	110	110/11KV,HV1	GULEDGUDD_110	12:30	12:36	0:06	HAND TRIPPED
9	13-Jul-2021	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	12:38	12:46	0:08	TRANSFORMER FAULT
10	13-Jul-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	13:18	15:22	2:04	LINE CLEAR AVOIDED
11	13-Jul-2021	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	11:43	13:26	1:43	LINE CLEAR AVOIDED
12	13-Jul-2021	BAGALKOT	110	110/33KV, HV2	TILUVALLI_110	9:06	11:08	2:02	TRANSFORMER FAULT
13	13-Jul-2021	BAGALKOT	110	ACHANUR-SIGIKERI	ACHANUR_110	18:30	18:48	0:18	HAND TRIPPED
14	13-Jul-2021	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	5:55	6:37	0:42	LINE FAULT
15	13-Jul-2021	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	11:21	13:41	2:20	LINE CLEAR AVOIDED
16	13-Jul-2021	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	5:55	6:37	0:42	LINE FAULT
17	13-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
18	13-Jul-2021	BAGALKOT	110	AMBEWADI- KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
19	13-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVOIDED
20	13-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
21	13-Jul-2021	BAGALKOT	110	KULAGERI CROSS-MRN SUGARS	KULAGERI CROSS_110	13:38	14:40	1:02	LINE FAULT
22	13-Jul-2021	BAGALKOT	110	NAVALGUND- KONNUR	KONNUR_110	13:39	14:18	0:39	LINE FAULT
23	13-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
24	13-Jul-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
25	13-Jul-2021	BAGALKOT	110	RON- GAMESHA	RON_110	12:16	12:26	0:10	HAND TRIPPED
26	13-Jul-2021	BAGALKOT	110	SUARNASOUDA- MACHE	MACHE_110	4:49	6:57	2:08	LINE FAULT
27	13-Jul-2021	BAGALKOT	110	UMAMACHAGI-KIRUVATTI	STATION NOT AFFECTED UMMACHAGI_110	8:33 (06.07.2021)	12:52 (13.07.2021)	4:19 hrs	LINE CHARGED
28	13-Jul-2021	BAGALKOT	110	VAJRAMATTI220- KATARKI	KATARKI_110	5:29	5:38	0:09	LINE FAULT
29	13-Jul-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:14 (11.07.2021)			LINE OPEN,LINE CLEAR AVOIDED
30	13-Jul-2021	BAGALKOT	220	BELGAUM- NARENDRA2(KANABARGI2)	BELGAUM_220	4:43	13:39	8:56	LINE CLEAR AVOIDED
31	13-Jul-2021	BAGALKOT	220	CHIKKODI- BELGAUM2	CHKKODI_220	4:41	8:17	3:36	LINE CLEAR AVOIDED
32	13-Jul-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
33	13-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
34	13-Jul-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	18:01 (12.07.2021)			LINE OPEN,LINE CLEAR AVAILED
35	13-Jul-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	16:18 (12.07.1011)			LINE OPEN,LINE CLEAR AVAILED
36	13-Jul-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
37	13-Jul-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
38	13-Jul-2021	BENGALURU	66	BAGHMANE WORLD TECH PARK - ITI 220	BAGHMANE WORLD TECH PARK	19:42	19:55	0:13	LOAD CHANGE OVER
39	13-Jul-2021	BENGALURU	66	EPIP 220 - CHANDAPURA	DIVYASHREE TECH PARK, KACHMARANAHALLI, MINOR IRRIGATION	18:05	18:28	0:23	LINE FAULT
40	13-Jul-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	18:09	18:43	0:34	LINE FAULT
41	13-Jul-2021	BENGALURU	66	HV1	ELITA PROMENENDE	11:16	11:40	0:24	LINE CLEAR AVAILED
42	13-Jul-2021	BENGALURU	66	HV1	TEKAL	15:21	15:40	0:18	LINE CLEAR AVAILED
43	13-Jul-2021	BENGALURU	66	HV1	KOLAR 220	13:15	13:50	0:35	LINE CLEAR AVAILED
44	13-Jul-2021	BENGALURU	66	HV1	GODUR	15:50	16:15	0:24	LINE CLEAR AVAILED
45	13-Jul-2021	BENGALURU	66	HV2	TEKAL	14:40	15:20	0:40	LINE CLEAR AVAILED
46	13-Jul-2021	BENGALURU	66	HV2	SOMAYAJJANAHALLI	15:05	15:10	0:05	LINE CLEAR AVAILED
47	13-Jul-2021	BENGALURU	66	HV2	SARIJAPURA 220	13:31	16:29	2:58	MAIN SUPPLY FAILURE
48	13-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
49	13-Jul-2021	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	9:40	12:11	2:31	LINE FAULT
50	13-Jul-2021	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	21:45	21:54	0:09	LOAD CHANGE OVER
51	13-Jul-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	18:23	18:30	0:07	LINE FAULT
52	13-Jul-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:23	18:30	0:07	LINE FAULT
53	13-Jul-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	18:50	19:02	0:12	LINE FAULT
54	13-Jul-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	18:50	19:02	0:12	LINE FAULT
55	13-Jul-2021	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	16:20	16:26	0:06	LINE CLEAR AVAILED
56	13-Jul-2021	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	13:33	13:38	0:04	MAIN SUPPLY FAILURE
57	13-Jul-2021	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:19	16:25	0:06	LINE CLEAR AVAILED
58	13-Jul-2021	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:34	13:38	0:04	MAIN SUPPLY FAILURE
59	13-Jul-2021	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	17:09	17:52	0:43	LINE CLEAR AVAILED
60	13-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06- 2021)			LINE OPEN,LINE FAULT
61	13-Jul-2021	BENGALURU	220	HV1	SARIJAPURA 220	13:31	16:24	2:52	LINE CLEAR AVAILED
62	13-Jul-2021	BENGALURU	220	NELMANGALA 400 - DABUSPETE 2	NO STATION AFFECTED	11:03	17:53	6:50	LINE CLEAR AVAILED
63	13-Jul-2021	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
64	13-Jul-2021	GULBARGA	110	HV1	HATTI_110	18:15	18:19	0:04	LINE CLEAR AVAILED
65	13-Jul-2021	GULBARGA	110	HV2	HATTI_110	18:15	18:32	0:17	LINE CLEAR AVAILED
66	13-Jul-2021	GULBARGA	110	HV3	HATTI_110	17:50	18:19	0:29	TRANSFORMER FAULT
67	13-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	18:17	18:22	0:05	LINE CLEAR AVAILED
68	13-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	23:45	23:55	0:10	LINE FAULT
69	13-Jul-2021	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	4:06	5:00	0:54	LINE FAULT
70	13-Jul-2021	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	22:03	22:36	0:33	LINE FAULT
71	13-Jul-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	4:06	4:10	0:04	MAIN SUPPLY FAILURE
72	13-Jul-2021	GULBARGA	110	PDHALLI-ALIPUR	PDHALLI_110	15:51	18:30	2:39	LINE CLEAR AVAILED
73	13-Jul-2021	GULBARGA	110	PDHALLI-CLN SLR	PDHALLI_110	19:19	19:21	0:02	LINE CLEAR AVAILED
74	13-Jul-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:59	21:14	0:15	LINE FAULT
75	13-Jul-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	3:10	3:18	0:08	LINE FAULT
76	13-Jul-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	3:44	4:04	0:20	LINE FAULT
77	13-Jul-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	23:29	23:55	0:26	LINE FAULT
78	13-Jul-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	22:20	22:25	0:05	LINE FAULT
79	13-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATI_IPP,COREGREENSUGAR_IPP	0:22	0:37	0:15	LINE FAULT
80	13-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATI_IPP,COREGREENSUGAR_IPP	1:58	2:10	0:12	LINE FAULT
81	13-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATI_IPP,COREGREENSUGAR_IPP	4:56	5:06	0:10	LINE FAULT
82	13-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATI_IPP,COREGREENSUGAR_IPP	10:14	10:20	0:06	LINE CLEAR AVAILED
83	13-Jul-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	15:46	15:58	0:12	LINE FAULT
84	13-Jul-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:28	20:38	0:10	LINE FAULT
85	13-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	17:25(13.07.2021)			LINE OPEN,LINE CLEAR AVAILED
86	13-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	1:06	1:16	0:10	LINE FAULT
87	13-Jul-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	14:32	15:02	0:30	LINE FAULT
88	13-Jul-2021	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	23:12(13.07.2021)			LINE OPEN,LINE FAULT
89	13-Jul-2021	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	1:17(12.07.2021)			LINE OPEN,LINE CLEAR AVAILED
90	13-Jul-2021	HASSAN	66	ARAKAL-HASSAN	ARKD_66	11:51	12:06	0:15	LINE FAULT
91	13-Jul-2021	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	11:54	12:41	0:47	LINE FAULT
92	13-Jul-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	12:43	12:45	0:02	HAND TRIPPED
93	13-Jul-2021	HASSAN	66	HV1	BELUR_66	16:15	16:27	0:12	HAND TRIPPED
94	13-Jul-2021	HASSAN	66	HV1	BYACHANAHALLI_66	12:35	12:50	0:15	TRANSFORMER FAULT
95	13-Jul-2021	HASSAN	66	HV1	HASSAN_66	7:24	8:04	0:40	LINE CLEAR AVAILED
96	13-Jul-2021	HASSAN	66	HV1	KUDLIGERE_66	11:53	13:27	1:34	LINE CLEAR AVAILED
97	13-Jul-2021	HASSAN	66	HV1	SINGAPURA_66	11:35	11:57	0:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
98	13-Jul-2021	HASSAN	66	HV2	BELUR_66	16:15	16:20	0:05	HAND TRIPPED
99	13-Jul-2021	HASSAN	66	HV2	HASSAN_66	6:10	11:30	5:20	TRANSFORMER FAULT
100	13-Jul-2021	HASSAN	66	HV2	UDAYAPURA_66	13:50	14:09	0:19	LINE CLEAR AVAILED
101	13-Jul-2021	HASSAN	66	HV3	BALEHONNUR_66	13:38	14:00	0:22	HAND TRIPPED
102	13-Jul-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:53	13:27	1:34	LINE CLEAR AVAILED
103	13-Jul-2021	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	11:53	13:27	1:34	LINE CLEAR AVAILED
104	13-Jul-2021	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	11:54	12:41	0:47	LINE FAULT
105	13-Jul-2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	7:10	7:22	0:12	LINE FAULT
106	13-Jul-2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	11:22	14:20	2:58	LINE CLEAR AVAILED
107	13-Jul-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:35	10:40	0:05	LINE FAULT
108	13-Jul-2021	HASSAN	110	HV1	ARASIKERE_220	11:11	12:34	1:23	LINE CLEAR AVAILED
109	13-Jul-2021	HASSAN	110	HV1	GAJNUR_110	5:40	6:45	1:05	TRANSFORMER FAULT
110	13-Jul-2021	HASSAN	110	HV2	MSEZ_220	10:16	14:10	3:54	LINE CLEAR AVAILED
111	13-Jul-2021	HASSAN	110	HV2	HALADY_110	12:00	13:57	1:57	LINE CLEAR AVAILED
112	13-Jul-2021	HASSAN	110	HV2	KARAYA_110	11:18	12:09	0:51	LINE CLEAR AVAILED
113	13-Jul-2021	HASSAN	110	HV2	KULASHEKARA_110	15:40	18:07	2:27	LINE CLEAR AVAILED
114	13-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
115	13-Jul-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	10:34	11:33	0:59	LINE FAULT
116	13-Jul-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	10:34	11:33	0:59	LINE FAULT
117	13-Jul-2021	MYSURU	66	HV1	CHINAKURALI_66	14:57	15:00	0:02	HAND TRIPPED
118	13-Jul-2021	MYSURU	66	HV1	KRNAGARA_66	11:45	13:15	1:29	LINE CLEAR AVAILED
119	13-Jul-2021	MYSURU	66	HV1	PONNAMPET_66	11:30	15:45	4:15	LINE CLEAR AVAILED
120	13-Jul-2021	MYSURU	66	HV2	HANNUR_66	12:07	12:26	0:18	LINE CLEAR AVAILED
121	13-Jul-2021	MYSURU	66	HV2	HULLAHALLI_66	15:46	16:38	0:51	LINE CLEAR AVAILED
122	13-Jul-2021	MYSURU	66	HV2	KRNAGARA_66	13:15	14:18	1:03	LINE CLEAR AVAILED
123	13-Jul-2021	MYSURU	66	HV2	PONNAMPET_66	13:07	15:27	2:20	LINE CLEAR AVAILED
124	13-Jul-2021	MYSURU	66	HV3	PONNAMPET_66	15:35	16:33	0:58	LINE CLEAR AVAILED
125	13-Jul-2021	MYSURU	66	JAKKANALLI-NAGMANGLA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	11:49	11:55	0:05	LINE FAULT
126	13-Jul-2021	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	0:02	0:10	0:08	HAND TRIPPED
127	13-Jul-2021	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	7:51	8:02	0:10	HAND TRIPPED
128	13-Jul-2021	MYSURU	66	MADHUVANALLI-MAMBALLI	NO STATIONS EFFECTED	1:20	1:42	0:22	LINE FAULT
129	13-Jul-2021	MYSURU	66	MADHUVANALLI-MAMBALLI	NO STATIONS EFFECTED	4:15	4:19	0:04	LINE FAULT
130	13-Jul-2021	MYSURU	66	MADHUVANALLI-PG PALYA	PGPALYA_66	8:15	11:31	3:16	LINE CLEAR AVAILED
131	13-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
132	13-Jul-2021	MYSURU	66	THANDYA-KADAKOLA	NO STATIONS EFFECTED	1:22	1:30	0:08	LINE FAULT
133	13-Jul-2021	MYSURU	220	KADAKOLA-BEGURU2	NO STATIONS EFFECTED	11:06	17:00	5:54	LINE CLEAR AVAILED
134	13-Jul-2021	MYSURU	220	MADHUVANALLI-HEBBANI	NO STATIONS EFFECTED	10:44	15:02	4:18	LINE CLEAR AVAILED
135	13-Jul-2021	TUMKUR	66	BALENAHALLI-220KV SRS CHITRADURGA	BALENAHALLI_66	12:56	16:03	3:07	MAIN SUPPLY FAILURE
136	13-Jul-2021	TUMKUR	66	BALENAHALLI66- FEFCWINDWIND_IPP_66	FEFCWINDWIND_IPP_66	12:56	13:37	0:40	MAIN SUPPLY FAILURE
137	13-Jul-2021	TUMKUR	66	CHITRADURGA 220KV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	12:53	15:47	2:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
138	13-Jul-2021	TUMKUR	66	CHITRADURGA 220kV-HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR 66	12:51	16:13	3:21	LINE CLEAR AVAILED
139	13-Jul-2021	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	12:58	15:49	2:51	LINE CLEAR AVAILED
140	13-Jul-2021	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	12:52	15:43	2:50	LINE CLEAR AVAILED
141	13-Jul-2021	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 1	CHITRADURGA_66	15:15	15:56	0:41	MAIN SUPPLY FAILURE
142	13-Jul-2021	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 2	CHITRADURGA_66	12:53	15:52	2:59	MAIN SUPPLY FAILURE
143	13-Jul-2021	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 1	MEGMICON 1_IPP_66	15:41	16:12	0:31	MAIN SUPPLY FAILURE
144	13-Jul-2021	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 1	MEGMICON 1_IPP_66	22:36	23:40	1:04	MAIN SUPPLY FAILURE
145	13-Jul-2021	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 2	MEGMICON 1_IPP_66	15:41	16:12	0:31	MAIN SUPPLY FAILURE
146	13-Jul-2021	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 2	MEGMICON 1_IPP_66	17:27	17:45	0:17	MAIN SUPPLY FAILURE
147	13-Jul-2021	TUMKUR	66	CHITRADURGA 66kV-MEGMICON 2	MEGMICON 1_IPP_66	22:34	23:37	1:03	MAIN SUPPLY FAILURE
148	13-Jul-2021	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	PANDARAHALLI_66	21:35	22:49	1:14	MAIN SUPPLY FAILURE
149	13-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:08	15:45	2:37	LINE CLEAR AVAILED
150	13-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	2:34	2:42	0:07	LINE FAULT
151	13-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:08	9:44	0:36	LINE FAULT
152	13-Jul-2021	TUMKUR	66	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	2:57	3:37	0:39	HAND TRIPPED
153	13-Jul-2021	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	12:51	13:10	0:19	LINE CLEAR AVAILED
154	13-Jul-2021	TUMKUR	66	TR-1	CHITRADURGA_66	12:55	15:11	2:15	MAIN SUPPLY FAILURE
155	13-Jul-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	19:28	19:34	0:06	TRANSFORMER FAULT
156	13-Jul-2021	TUMKUR	66	TR-2	CHITRADURGA_66	12:56	15:11	2:14	MAIN SUPPLY FAILURE
157	13-Jul-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	8:34	8:45	0:10	TRANSFORMER FAULT
158	13-Jul-2021	TUMKUR	66	TR-2	LINGADAHALLI_66	17:36	19:10	1:34	LINE CLEAR AVAILED
159	13-Jul-2021	TUMKUR	66	TURUVANUR66-CHITRADURGA220	TURUVANUR_66	13:26	16:18	2:51	LINE CLEAR AVAILED
160	13-Jul-2021	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	16:18	16:24	0:06	LINE CLEAR AVAILED
161	13-Jul-2021	TUMKUR	110	TR-2	TURUVEKERE_110	15:15	15:44	0:29	LINE CLEAR AVAILED
162	13-Jul-2021	TUMKUR	110	TURUVEKERE110-KBCROSS	TURUVEKERE_110	15:14	15:20	0:05	LINE CLEAR AVAILED
163	13-Jul-2021	TUMKUR	220	CHITRADURGA 220kV-THALLAK	CHITRADURGA_220	12:59	18:19	5:19	LINE CLEAR AVAILED
164	13-Jul-2021	TUMKUR	220	THALLAK 220kV-CHITRADURGA	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA 66	12:59	16:07	3:08	LINE CLEAR AVAILED
165	13-Jul-2021	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	12:56	17:30	4:33	LINE CLEAR AVAILED
166	13-Jul-2021	TUMKUR	220	TR-3 (HV SIDE)	CHITRADURGA_220	12:57	15:44	2:47	LINE CLEAR AVAILED
167	14-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
168	14-Jul-2021	BAGALKOT	110	110/11KV, HV1	MUGALKOD_110	00:34 (11.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
169	14-Jul-2021	BAGALKOT	110	110/11KV,HV 1	ACHANUR_110	2:47 (10.07.2021)	13:22 (14.07.2021)	10:35 hrs	TRANSFORMER CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
170	14-Jul-2021	BAGALKOT	110	110/11KV,HV1	MURUDESHWAR_110	12:42	13:42	1:00	LINE CLEAR AVAIED
171	14-Jul-2021	BAGALKOT	110	110/11KV,HV2	ALBAL_110	16:00	18:52	2:52	LINE CLEAR AVAIED
172	14-Jul-2021	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	17:12	17:27	0:15	LINE CLEAR AVAIED
173	14-Jul-2021	BAGALKOT	110	110/11KV,HV3,HV4	RSNG_33,KUPPELLURU_33,GU DADUR _33,HALGERI_33MAIDUR_33 STATION NOT AFFECTED RANEENNUR_220	10:18	17:58	7:40	LINE CLEAR AVAIED
174	14-Jul-2021	BAGALKOT	110	110/11KV,HV4	KULIGOD_110	15:33	17:05	1:32	LINE CLEAR AVAIED
175	14-Jul-2021	BAGALKOT	110	110/33KV, HV3	TILUVALLI_110	18:35 (13.07.2021)	14:20 (14.07.2021)	19:45 hrs	TRANSFORMER CHARGED
176	14-Jul-2021	BAGALKOT	110	110/33KV, HV3	TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN,LINE CLEAR AVAIED
177	14-Jul-2021	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	6:19	6:26	0:07	LINE FAULT
178	14-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAIED
179	14-Jul-2021	BAGALKOT	110	AMBEWADI- KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAIED
180	14-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAIED
181	14-Jul-2021	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED BIDNAL_220	2:31	11:44	9:13	LINE FAULT
182	14-Jul-2021	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND	7:18 (14.07.2021)			LINE OPEN,LINE FAULT
183	14-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAIED
184	14-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAIED
185	14-Jul-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
186	14-Jul-2021	BAGALKOT	110	RAY SOLAR-ALBAL	ALBAL_110	16:00	18:52	2:52	LINE CLEAR AVAIED
187	14-Jul-2021	BAGALKOT	110	RON-GAJENDRAGAD1&2	RON_110	13:31	13:35	0:04	HAND TRIPPED
188	14-Jul-2021	BAGALKOT	110	RON-GAMESH	RON_110	13:31	13:40	0:09	HAND TRIPPED
189	14-Jul-2021	BAGALKOT	110	SAIPRIYA SUGAR-ALBAL	ALBAL_110	16:00	18:52	2:52	LINE CLEAR AVAIED
190	14-Jul-2021	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	13:57	18:53	4:56	LINE FAULT
191	14-Jul-2021	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	6:15	6:18	0:03	LINE FAULT
192	14-Jul-2021	BAGALKOT	110	VAJRAMATTI220- KATARKI	KATARKI_110	6:22	6:56	0:34	LINE FAULT
193	14-Jul-2021	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	23:59 (14.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
194	14-Jul-2021	BAGALKOT	220	AMBEWADI- (PONDA1)XELDOM	STATION NOT AFFECTED AMBEWADI_220	20:47 (14.07.2021)			LINE OPEN,LINE FAULT
195	14-Jul-2021	BAGALKOT	220	BELGAUM- NARENDRA1	BELGAUM_220	23:36	23:57	0:21	LINE FAULT
196	14-Jul-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:14 (11.07.2021)			LINE OPEN,LINE CLEAR AVAIED
197	14-Jul-2021	BAGALKOT	220	CHIKKODI- GHATAPRABHA(MUGALKOD2)	CHIKKODI_220	10:38	14:02	3:24	LINE CLEAR AVAIED
198	14-Jul-2021	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	3:19	15:48	12:29	LINE FAULT
199	14-Jul-2021	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	12:20	15:18	2:58	LINE CLEAR AVAIED
200	14-Jul-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAIED
201	14-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
202	14-Jul-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	18:01 (12.07.2021)			LINE OPEN,LINE CLEAR AVAILED
203	14-Jul-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	16:18 (12.07.1011)			LINE OPEN,LINE CLEAR AVAILED
204	14-Jul-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
205	14-Jul-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
206	14-Jul-2021	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	10:31	10:40	0:09	LOAD CHANGE OVER
207	14-Jul-2021	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	17:15	17:20	0:05	LOAD CHANGE OVER
208	14-Jul-2021	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	12:06	12:12	0:06	LOAD CHANGE OVER
209	14-Jul-2021	BENGALURU	66	HV1	HOSKOTE 66	22:09	23:59	1:49	TRANSFORMER FAULT
210	14-Jul-2021	BENGALURU	66	HV1	IRGAMPALLI	11:37	13:05	1:27	LINE CLEAR AVAILED
211	14-Jul-2021	BENGALURU	66	HV1	MAASTHI	10:30	11:26	0:56	LINE CLEAR AVAILED
212	14-Jul-2021	BENGALURU	66	HV1	N G HULKUR	12:05	12:25	0:20	LINE CLEAR AVAILED
213	14-Jul-2021	BENGALURU	66	HV1	N G HULKUR	12:30	18:32	6:02	LINE CLEAR AVAILED
214	14-Jul-2021	BENGALURU	66	HV2	HEBBALA 220	11:26	11:36	0:10	TRANSFORMER FAULT
215	14-Jul-2021	BENGALURU	66	HV2	GANJIGUNTE	17:52	18:00	0:07	TRANSFORMER FAULT
216	14-Jul-2021	BENGALURU	66	HV2	IRGAMPALLI	10:28	10:33	0:04	LINE CLEAR AVAILED
217	14-Jul-2021	BENGALURU	66	HV2	VIDHURASHWATHA	0:55	1:01	0:06	TRANSFORMER FAULT
218	14-Jul-2021	BENGALURU	66	HV2	VIJAYAPURA	8:30	8:35	0:05	LINE CLEAR AVAILED
219	14-Jul-2021	BENGALURU	66	HV2	N G HULKUR	12:05	12:25	0:20	LINE CLEAR AVAILED
220	14-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)	15:35(14-7-21)	0:29 hrs	TRANSFORMER CHARGED
221	14-Jul-2021	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:28	10:36	0:08	LINE CLEAR AVAILED
222	14-Jul-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	10:09	10:23	0:13	LINE FAULT
223	14-Jul-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:09	10:22	0:12	LINE FAULT
224	14-Jul-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:30	11:49	0:18	LINE CLEAR AVAILED
225	14-Jul-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:30	11:34	0:04	LINE CLEAR AVAILED
226	14-Jul-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	18:05	18:19	0:14	LINE CLEAR AVAILED
227	14-Jul-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), ELECTRONIC CITY, INFOSYS (EHT)	18:05	18:20	0:15	LINE CLEAR AVAILED
228	14-Jul-2021	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, PADMANABHANAGAR	6:50	6:59	0:09	LINE FAULT
229	14-Jul-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	12:58	13:05	0:07	LOAD CHANGE OVER
230	14-Jul-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	18:19	18:24	0:05	LOAD CHANGE OVER
231	14-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
232	14-Jul-2021	BENGALURU	220	HSR LAYOUT 220 - NAGNATHPURA 220	NAGANATHPURA 220	18:05	18:18	0:13	LINE FAULT
233	14-Jul-2021	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	18:00	18:05	0:05	LINE CLEAR AVAILED
234	14-Jul-2021	GULBARGA	110	HALBARGA-HUMNABAD2	ALAND_110,KADAGANCHI_110	5:13	5:21	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
235	14-Jul-2021	GULBARGA	110	HALBARGA-HUMNABAD2	ALAND_110,KADAGANCHI_110	19:02	19:14	0:12	LINE FAULT
236	14-Jul-2021	GULBARGA	110	HALBARGA-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS_IPP	5:15	5:24	0:09	LINE FAULT
237	14-Jul-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGA ON_110,KAMALNAGAR_110	2:45	2:51	0:06	LINE FAULT
238	14-Jul-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGA ON_110,KAMALNAGAR_110	5:35	5:39	0:04	LINE FAULT
239	14-Jul-2021	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
240	14-Jul-2021	GULBARGA	110	HV3	JEWARGI_110	6:55	7:15	0:20	TRANSFORMER FAULT
241	14-Jul-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	2:50	3:10	0:20	LINE FAULT
242	14-Jul-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:40	5:50	0:10	LINE FAULT
243	14-Jul-2021	GULBARGA	110	JEEWARGI-SHAHBAD	JEEWARGI_110	4:10	4:15	0:05	MAIN SUPPLY FAILURE
244	14-Jul-2021	GULBARGA	110	JEEWARGI-SHAHPUR	JEEWARGI_110	22:05	22:10	0:05	MAIN SUPPLY FAILURE
245	14-Jul-2021	GULBARGA	110	LV2	SHAHAPUR_220	15:54	18:06	2:12	LINE CLEAR AVAILED
246	14-Jul-2021	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	19:45	20:05	0:20	LINE CLEAR AVAILED
247	14-Jul-2021	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	23:28	23:40	0:12	LINE FAULT
248	14-Jul-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	6:55	7:16	0:21	LINE FAULT
249	14-Jul-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:30	22:45	0:15	LINE FAULT
250	14-Jul-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	23:05	23:15	0:10	LINE FAULT
251	14-Jul-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	1:45	1:52	0:07	LINE FAULT
252	14-Jul-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	4:49	5:07	0:18	LINE FAULT
253	14-Jul-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	6:08	6:18	0:10	MAIN SUPPLY FAILURE
254	14-Jul-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	6:12	6:35	0:23	LINE FAULT
255	14-Jul-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	4:03	4:25	0:22	LINE FAULT
256	14-Jul-2021	GULBARGA	110	SHAHABAD-RAICHUR2	JEWARGI_110,NALWAR_110	20:12	20:24	0:12	LINE FAULT
257	14-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATI_IPP,COREGREENSUGAR_IPP	5:01	5:12	0:11	LINE FAULT
258	14-Jul-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:52	22:02	0:10	LINE FAULT
259	14-Jul-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	1:48	1:55	0:07	LINE FAULT
260	14-Jul-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	3:23	3:31	0:08	LINE FAULT
261	14-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	17:25(13.07.2021)	15:25(14.07.2021)	22:00HRS	LINE CHARGED
262	14-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	19:35	19:45	0:10	LINE FAULT
263	14-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	20:45	20:55	0:10	LINE FAULT
264	14-Jul-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	22:32	22:40	0:08	LINE FAULT
265	14-Jul-2021	GULBARGA	110	VALKAMDINNI-MALLAT	VALKAMDINNI_110	18:06	18:15	0:09	LINE CLEAR AVAILED
266	14-Jul-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	20:10	20:15	0:05	MAIN SUPPLY FAILURE
267	14-Jul-2021	GULBARGA	220	HV1	SHAHABAD_220	6:55	7:15	0:20	TRANSFORMER FAULT
268	14-Jul-2021	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	3:52	4:11	0:19	LINE FAULT
269	14-Jul-2021	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	1:12	1:27	0:15	LINE FAULT
270	14-Jul-2021	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	1:46	7:12	5:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
271	14-Jul-2021	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	23:12(13.07.2021)	7:18(14.07.2021)	8:06HRS	LINE CHARGED
272	14-Jul-2021	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	1:17(12.07.2021)	06:32(14.07.2021)	53:15HRS	LINE CHARGED
273	14-Jul-2021	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	3:42	7:59	4:17	LINE FAULT
274	14-Jul-2021	HASSAN	66	DODDAMA-ARAKALGUD	DODDAMAGGE_66	12:00	12:25	0:25	LINE CLEAR AVAILED
275	14-Jul-2021	HASSAN	66	DODDAMA-ARAKALGUD	DODDAMAGGE_66	13:30	15:30	2:00	LINE CLEAR AVAILED
276	14-Jul-2021	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMAGALUR_66	11:04	15:30	4:26	LINE CLEAR AVAILED
277	14-Jul-2021	HASSAN	66	HIREMAN-CKM220	HIREMAGALUR_66	11:04	13:20	2:16	LINE CLEAR AVAILED
278	14-Jul-2021	HASSAN	66	HIREMAN-RDL	HIREMAGALUR_66	11:04	13:20	2:16	LINE CLEAR AVAILED
279	14-Jul-2021	HASSAN	66	HV1	CHIKMAGALUR_66	11:00	16:47	5:47	LINE CLEAR AVAILED
280	14-Jul-2021	HASSAN	66	HV1	HADAVANANAHALLY_66	12:45	16:10	3:25	LINE CLEAR AVAILED
281	14-Jul-2021	HASSAN	66	HV1	HIREMAGALUR_66	11:04	13:20	2:16	LINE CLEAR AVAILED
282	14-Jul-2021	HASSAN	66	HV1	MAGGE_66	11:12	12:33	1:21	LINE CLEAR AVAILED
283	14-Jul-2021	HASSAN	66	HV2	MAGGE_66	10:08(14.7.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
284	14-Jul-2021	HASSAN	66	HV2	CHIKMAGALUR_66	11:00	17:24	6:24	LINE CLEAR AVAILED
285	14-Jul-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	14:15	14:24	0:09	LINE FAULT
286	14-Jul-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	17:55 (14.07.2021)			LINE OPEN,LINE FAULT
287	14-Jul-2021	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	8:07	8:34	0:27	MAIN SUPPLY FAILURE
288	14-Jul-2021	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	8:07	8:34	0:27	MAIN SUPPLY FAILURE
289	14-Jul-2021	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	12:20	13:54	1:34	LINE CLEAR AVAILED
290	14-Jul-2021	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	12:20	13:58	1:38	LINE CLEAR AVAILED
291	14-Jul-2021	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	12:15	14:00	1:45	LINE CLEAR AVAILED
292	14-Jul-2021	HASSAN	110	HV1	HALADY_110	12:20	14:35	2:15	LINE CLEAR AVAILED
293	14-Jul-2021	HASSAN	110	HV1	NAVUNDA_110	20:54	21:01	0:07	TRANSFORMER FAULT
294	14-Jul-2021	HASSAN	110	HV2	HALADY_110	12:20	13:55	1:35	LINE CLEAR AVAILED
295	14-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
296	14-Jul-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:33	12:36	2:03	LINE CLEAR AVAILED
297	14-Jul-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:07	9:25	0:18	LINE FAULT
298	14-Jul-2021	HASSAN	110	LV1	ARASIKERE_220	8:07	15:12	7:05	TRANSFORMER FAULT
299	14-Jul-2021	HASSAN	110	LV1	ARASIKERE_220	12:23	15:12	2:49	LINE CLEAR AVAILED
300	14-Jul-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	16:12	16:22	0:10	LINE CLEAR AVAILED
301	14-Jul-2021	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	10:33	12:39	2:06	LINE CLEAR AVAILED
302	14-Jul-2021	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	16:12	16:22	0:10	LINE CLEAR AVAILED
303	14-Jul-2021	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	12:03	14:13	2:10	LINE CLEAR AVAILED
304	14-Jul-2021	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	12:03	14:13	2:10	NFBC ISSUED
305	14-Jul-2021	HASSAN	220	HV1	ARASIKERE_220	8:07	15:12	7:05	TRANSFORMER FAULT
306	14-Jul-2021	HASSAN	220	HV1	ARASIKERE_220	12:23	15:12	2:49	LINE CLEAR AVAILED
307	14-Jul-2021	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	16:52	20:54	4:02	LINE FAULT
308	14-Jul-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	20:01 (14.07.2021)			LINE OPEN,LINE FAULT
309	14-Jul-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	16:52	20:54	4:02	LINE FAULT
310	14-Jul-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	20:01 (14.07.2021)			LINE OPEN,LINE FAULT
311	14-Jul-2021	MYSURU	66	DKMAIDANA-KADAKOLA	NO STATIONS EFFECTED	9:48	14:38	4:49	NFBC ISSUED
312	14-Jul-2021	MYSURU	66	HV1	HANAGODU_66	7:30	8:09	0:39	TRANSFORMER FAULT
313	14-Jul-2021	MYSURU	66	KUSHALNAGARA-MADIKERI	MADIKERI_66	16:20	18:29	2:09	LINE FAULT
314	14-Jul-2021	MYSURU	66	KUSHALNAGARA-SUNTIKOPPA	SUNTIKOPPA_66	16:20	18:29	2:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
315	14-Jul-2021	MYSURU	66	KUSHALNAGARA-SUNTIKOPPA	SUNTIKOPPA_66	21:51	21:56	0:05	LINE FAULT
316	14-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
317	14-Jul-2021	MYSURU	66	PIRIYAPATNA-HANGOD	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	22:14	22:22	0:07	LINE FAULT
318	14-Jul-2021	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	19:31	20:31	1:00	LINE CLEAR AVAILED
319	14-Jul-2021	TUMKUR	66	ANTHRASANAHALI 220KV-KORA	KORA_66, THOVINAKERE_66	4:58	5:07	0:09	LINE FAULT
320	14-Jul-2021	TUMKUR	66	BALENAHALI66-CHITRADURGA	BALENAHALI_66	7:45	8:13	0:28	LINE FAULT
321	14-Jul-2021	TUMKUR	66	BALENAHALI-CHALKERE	BALENAHALI_66	7:45	8:14	0:28	LINE FAULT
322	14-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:30	19:36	2:05	LINE CLEAR AVAILED
323	14-Jul-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	6:20	6:41	0:21	HAND TRIPPED
324	14-Jul-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	6:06	6:34	0:27	LINE FAULT
325	14-Jul-2021	TUMKUR	66	THALLAK 220kv-NAYAKANHATTI	CHITRADURGA_220	10:11	10:21	0:10	HAND TRIPPED
326	14-Jul-2021	TUMKUR	66	THALLAK 220kv-NAYAKANHATTI	CHITRADURGA_220	14:11	14:18	0:07	HAND TRIPPED
327	14-Jul-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	6:51	6:58	0:06	HAND TRIPPED
328	14-Jul-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	7:03	7:10	0:06	LINE FAULT
329	14-Jul-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:18	9:23	0:05	HAND TRIPPED
330	14-Jul-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:57	11:59	0:01	LINE FAULT
331	14-Jul-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUN SOLAR2	6:51	6:58	0:06	HAND TRIPPED
332	14-Jul-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUN SOLAR2	7:01	7:10	0:08	LINE FAULT
333	14-Jul-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUN SOLAR2	9:18	9:22	0:04	HAND TRIPPED
334	14-Jul-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	16:05	16:11	0:05	TRANSFORMER FAULT
335	14-Jul-2021	TUMKUR	66	TR-1	KATTIGE_66	0:08	0:19	0:10	TRANSFORMER FAULT
336	14-Jul-2021	TUMKUR	66	TR-1	KATTIGE_66	15:19	15:32	0:13	TRANSFORMER FAULT
337	14-Jul-2021	TUMKUR	66	TR-1	KATTIGE_66	15:39	15:56	0:16	TRANSFORMER FAULT
338	14-Jul-2021	TUMKUR	66	TR-1	KUNDUR_66	6:09	6:15	0:05	TRANSFORMER FAULT
339	14-Jul-2021	TUMKUR	66	TR-1	MATHOD_66	18:04	18:09	0:05	TRANSFORMER FAULT
340	14-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_66	11:04	11:17	0:13	LINE CLEAR AVAILED
341	14-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_220	16:04	16:17	0:13	TRANSFORMER FAULT
342	14-Jul-2021	TUMKUR	66	TR-2	HARIYABBE_66	6:06	6:46	0:39	TRANSFORMER FAULT
343	14-Jul-2021	TUMKUR	66	TR-2	HIRIYUR_220	20:36	20:40	0:03	TRANSFORMER FAULT
344	14-Jul-2021	TUMKUR	66	TR-2	MALEBENNUR_66	11:02	11:13	0:10	TRANSFORMER FAULT
345	14-Jul-2021	TUMKUR	66	TR-2	MALEBENNUR_66	12:53	12:58	0:04	TRANSFORMER FAULT
346	14-Jul-2021	TUMKUR	66	TR-2	PAVAGADA_66	11:04	11:18	0:14	LINE CLEAR AVAILED
347	14-Jul-2021	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	9:44	14:08	4:23	LINE CLEAR AVAILED
348	14-Jul-2021	TUMKUR	66	TR-3	HARIYABBE_66	6:28	6:43	0:14	HAND TRIPPED
349	14-Jul-2021	TUMKUR	66	TR-3	HARIYABBE_66	9:08	9:36	0:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
350	14-Jul-2021	TUMKUR	66	TR-3	THALLAKK_220	6:59	9:14	2:15	LINE CLEAR AVAIED
351	14-Jul-2021	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	13:17	16:48	3:30	LINE CLEAR AVAIED
352	14-Jul-2021	TUMKUR	110	HONNAVALLI 110-DMKURKE	DMKURKE_110	8:07	8:58	0:50	MAIN SUPPLY FAILURE
353	14-Jul-2021	TUMKUR	110	TR-1	CHIKKNAYAKANAHALLI_110	13:03	13:32	0:28	TRANSFORMER FAULT
354	14-Jul-2021	TUMKUR	110	TR-1	HALKURKE_110	14:20	17:25	3:05	LINE CLEAR AVAIED
355	14-Jul-2021	TUMKUR	110	TR-1	HUNASEGHATTA_110	13:17	16:48	3:30	LINE CLEAR AVAIED
356	14-Jul-2021	TUMKUR	110	TURUVEKERE110-KBCROSS	TURUVEKERE_110	17:34	18:01	0:27	LINE CLEAR AVAIED
357	14-Jul-2021	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	2:17	9:36	7:19	LINE FAULT
358	14-Jul-2021	TUMKUR	400	GUTUR_400-NARENDRA2	GUTTUR_400	1:20	9:28	8:07	LINE FAULT
359	15-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAIED
360	15-Jul-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
361	15-Jul-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAIED
362	15-Jul-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAIED
363	15-Jul-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
364	15-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
365	15-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAIED
366	15-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAIED
367	15-Jul-2021	BAGALKOT	110	AMBEWADI- KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAIED
368	15-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAIED
369	15-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAIED
370	15-Jul-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:14 (11.07.2021)			LINE OPEN,LINE CLEAR AVAIED
371	15-Jul-2021	BAGALKOT	110	110/11KV, HV1	MUGALKOD_110	00:34 (11.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
372	15-Jul-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	18:01 (12.07.2021)			LINE OPEN,LINE CLEAR AVAIED
373	15-Jul-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	16:18 (12.07.1011)			LINE OPEN,LINE CLEAR AVAIED
374	15-Jul-2021	BAGALKOT	110	110/33KV, HV3	TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN,LINE CLEAR AVAIED
375	15-Jul-2021	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	23:59 (14.07.2021)	12:02 (15.07.2021)	12:03HRS	TRANSFORMER CHARGED
376	15-Jul-2021	BAGALKOT	220	AMBEWADI- (PONDA1)XELDOM	STATION NOT AFFECTED AMBEWADI_220	20:47 (14.07.2021)	16:11 (15.07.2021)	19:24HRS	LINE CHARGED
377	15-Jul-2021	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND	7:18 (14.07.2021)	15:43 (15.07.2021)	32:25HRS	LINE CHARGED
378	15-Jul-2021	BAGALKOT	110	SIRSI- JOG2	SIRSI_110	11:53	19:34	7:41	LINE FAULT
379	15-Jul-2021	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	SIDDAPUR_110	16:38	16:55	0:17	LINE CLEAR AVAIED
380	15-Jul-2021	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	SIDDAPUR_110	17:36	19:04	1:28	LINE CLEAR AVAIED
381	15-Jul-2021	BAGALKOT	110	110/11KV, HV2	SAVANUR_110	10:30	19:25	8:55	LINE CLEAR AVAIED
382	15-Jul-2021	BAGALKOT	110	MAMADAPUR(B)- BABLESHWAR	BABLESHWAR_110	7:02	7:17	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
383	15-Jul-2021	BAGALKOT	110	MAMADAPUR(B)- BELGAUM SUGARS	MAMADAPR(B)	7:02	7:17	0:15	LINE FAULT
384	15-Jul-2021	BAGALKOT	110	MAHALINGAPUR- BANAhatti	BANAhatti_110	13:51	16:47	2:56	LINE CLEAR AVAILED
385	15-Jul-2021	BAGALKOT	110	KERUR- KONNUR	KERUR_110	12:34	14:05	1:31	LINE FAULT
386	15-Jul-2021	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	11:00	13:54	2:54	LINE CLEAR AVAILED
387	15-Jul-2021	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	14:01	17:53	3:52	LINE CLEAR AVAILED
388	15-Jul-2021	BAGALKOT	110	110/11KV, HV3	JAMKHANDI_110	15:41	17:53	2:12	LINE CLEAR AVAILED
389	15-Jul-2021	BAGALKOT	110	ITANAL- BPCL	ITANAL_110	7:17	7:28	0:11	LINE FAULT
390	15-Jul-2021	BAGALKOT	110	ITANAL- HIDIKAL2 (KABBUR2)	ITANAL_110	7:17	7:28	0:11	LINE FAULT
391	15-Jul-2021	BAGALKOT	110	110/11KV, HV1	HANGAL_110	12:13	12:30	0:17	LINE CLEAR AVAILED
392	15-Jul-2021	BAGALKOT	110	GHATAPRABHA220- SHIRGOAN	SHIRGOAN_110	5:56	6:04	0:08	LINE FAULT
393	15-Jul-2021	BAGALKOT	110	110/33KV, HV2	ANKOLA_110, ANKOLA_33, VAJRAKOSH_33	13:24	15:24	2:00	LINE CLEAR AVAILED
394	15-Jul-2021	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	9:56	17:25	7:29	LINE CLEAR AVAILED
395	15-Jul-2021	BAGALKOT	110	YELLAMANAWADI- ALBAL	ALBAL_110	6:57	9:41	2:44	LINE CLEAR AVAILED
396	15-Jul-2021	BAGALKOT	110	YELLAMANAWADI- ALBAL	ALBAL_110	15:50	17:44	1:54	LINE CLEAR AVAILED
397	15-Jul-2021	BAGALKOT	220	AMBEWADI- NAGJHARI1	AMBEWADI_220	12:03	12:32	0:29	HAND TRIPPED
398	15-Jul-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	11:41	11:43	0:02	LOAD CHANGE OVER
399	15-Jul-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	13:52	13:54	0:02	LOAD CHANGE OVER
400	15-Jul-2021	BENGALURU	66	HV2	EPIP 220	6:20	7:00	0:40	TRANSFORMER FAULT
401	15-Jul-2021	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	13:37	13:43	0:06	LINE CLEAR AVAILED
402	15-Jul-2021	BENGALURU	66	HV2	HSR LAYOUT 220	13:17	13:26	0:09	LINE CLEAR AVAILED
403	15-Jul-2021	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	HSR LAYOUT 220	15:25	15:27	0:02	LOAD CHANGE OVER
404	15-Jul-2021	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	15:25	15:27	0:02	LOAD CHANGE OVER
405	15-Jul-2021	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	15:25	15:27	0:02	LOAD CHANGE OVER
406	15-Jul-2021	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	JAKKASANDRA, ADUGODI	15:25	15:27	0:02	LOAD CHANGE OVER
407	15-Jul-2021	BENGALURU	220	HV1	HSR LAYOUT 220	15:25	15:27	0:02	LOAD CHANGE OVER
408	15-Jul-2021	BENGALURU	220	HV3	HSR LAYOUT 220	15:25	15:27	0:02	LOAD CHANGE OVER
409	15-Jul-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	12:59	13:02	0:03	LOAD CHANGE OVER
410	15-Jul-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	18:19	18:24	0:05	LOAD CHANGE OVER
411	15-Jul-2021	BENGALURU	66	HV1	ST.JOHN	15:28	15:48	0:20	TRANSFORMER FAULT
412	15-Jul-2021	BENGALURU	66	T K HALLI 220 - SIMSHA	NO STATION AFFECTED	1:58	2:12	0:14	LINE FAULT
413	15-Jul-2021	BENGALURU	66	HV2	ITI 220	1:53	3:56	2:03	TRANSFORMER FAULT
414	15-Jul-2021	BENGALURU	66	HV2	ITI 220	4:22	4:30	0:08	TRANSFORMER FAULT
415	15-Jul-2021	BENGALURU	66	CHIKKABALLAPURA I/A - CHIKKABALLAPURA URBAN	CHIKKABALLAPURA URBAN	10:40	14:55	4:15	LINE CLEAR AVAILED
416	15-Jul-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	NO STATION AFFECTED	16:30	16:50	0:20	MAIN SUPPLY FAILURE
417	15-Jul-2021	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA	16:30	16:50	0:20	MAIN SUPPLY FAILURE
418	15-Jul-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	16:30	16:50	0:20	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
419	15-Jul-2021	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKAL, D PALYA, GUDIBANDE	16:30	16:50	0:20	MAIN SUPPLY FAILURE
420	15-Jul-2021	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI,	16:30	16:50	0:20	MAIN SUPPLY FAILURE
421	15-Jul-2021	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA,	16:30	16:50	0:20	MAIN SUPPLY FAILURE
422	15-Jul-2021	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	16:30	16:50	0:20	MAIN SUPPLY FAILURE
423	15-Jul-2021	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	16:30	16:50	0:20	MAIN SUPPLY FAILURE
424	15-Jul-2021	BENGALURU	220	HV1	GOWRIBIDANUR 220	16:30	16:50	0:20	MAIN SUPPLY FAILURE
425	15-Jul-2021	BENGALURU	220	HV2	GOWRIBIDANUR 220	16:30	16:50	0:20	MAIN SUPPLY FAILURE
426	15-Jul-2021	BENGALURU	220	HV3	GOWRIBIDANUR 220	16:30	16:50	0:20	MAIN SUPPLY FAILURE
427	15-Jul-2021	BENGALURU	66	HV1	GOWRIBIDANUR 220	16:30	16:50	0:20	MAIN SUPPLY FAILURE
428	15-Jul-2021	BENGALURU	66	HV2	GOWRIBIDANUR 220	16:30	16:50	0:20	MAIN SUPPLY FAILURE
429	15-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - HIRIYUR 400	GOWRIBIDANUR 220	16:30	16:50	0:20	LINE FAULT
430	15-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	16:30	16:50	0:20	LINE FAULT
431	15-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	16:30	16:50	0:20	LINE FAULT
432	15-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	16:30	16:50	0:20	MAIN SUPPLY FAILURE
433	15-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	16:30	16:50	0:20	MAIN SUPPLY FAILURE
434	15-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 1	NO STATION AFFECTED	16:30	16:46	0:16	MAIN SUPPLY FAILURE
435	15-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2	RVNL	16:30	16:46	0:16	MAIN SUPPLY FAILURE
436	15-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	KIADB DB PURA 220	16:30	16:46	0:16	MAIN SUPPLY FAILURE
437	15-Jul-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	16:30	16:48	0:18	MAIN SUPPLY FAILURE
438	15-Jul-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	16:30	16:49	0:19	MAIN SUPPLY FAILURE
439	15-Jul-2021	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	16:30	16:48	0:18	MAIN SUPPLY FAILURE
440	15-Jul-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	16:30	16:49	0:19	MAIN SUPPLY FAILURE
441	15-Jul-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	16:30	16:48	0:18	MAIN SUPPLY FAILURE
442	15-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	16:30	16:49	0:19	MAIN SUPPLY FAILURE
443	15-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	16:30	16:48	0:18	MAIN SUPPLY FAILURE
444	15-Jul-2021	BENGALURU	220	HV1	MITTEMARI 220	16:30	16:46	0:16	MAIN SUPPLY FAILURE
445	15-Jul-2021	BENGALURU	220	HV2	MITTEMARI 220	16:30	16:46	0:16	MAIN SUPPLY FAILURE
446	15-Jul-2021	BENGALURU	66	HV1	MITTEMARI 220	16:30	16:48	0:18	TRANSFORMER FAULT
447	15-Jul-2021	BENGALURU	66	KIADB DB PURA 220 - INDO MM (EHT)	INDO MM (EHT)	16:30	16:57	0:27	MAIN SUPPLY FAILURE
448	15-Jul-2021	BENGALURU	66	KIADB DB PURA 220 - APPEAREL PARK	APPEAREL PARK	16:30	16:57	0:27	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
449	15-Jul-2021	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT)	HIMAT SINGHA FACTORY (EHT)	16:30	16:57	0:27	MAIN SUPPLY FAILURE
450	15-Jul-2021	BENGALURU	220	HV1	KIADB DB PURA 220	16:30	16:57	0:27	MAIN SUPPLY FAILURE
451	15-Jul-2021	BENGALURU	220	HV2	KIADB DB PURA 220	16:30	16:57	0:27	MAIN SUPPLY FAILURE
452	15-Jul-2021	BENGALURU	66	HV1	KIADB DB PURA 220	16:30	16:57	0:27	MAIN SUPPLY FAILURE
453	15-Jul-2021	BENGALURU	66	HV2	KIADB DB PURA 220	16:30	16:57	0:27	MAIN SUPPLY FAILURE
454	15-Jul-2021	BENGALURU	66	HV3	KIADB DB PURA 220	16:30	16:57	0:27	MAIN SUPPLY FAILURE
455	15-Jul-2021	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	8:05	8:15	0:10	LOAD CHANGE OVER
456	15-Jul-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	7:15	7:29	0:14	LINE FAULT
457	15-Jul-2021	BENGALURU	220	HV1	MALUR 220	2:15	3:09	0:54	TRANSFORMER FAULT
458	15-Jul-2021	BENGALURU	220	LV1	MALUR 220	2:15	3:11	0:56	TRANSFORMER FAULT
459	15-Jul-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	2:15	3:16	1:01	LINE FAULT
460	15-Jul-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	2:15	3:16	1:01	LINE FAULT
461	15-Jul-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	2:15	3:16	1:01	MAIN SUPPLY FAILURE
462	15-Jul-2021	BENGALURU	66	MALUR 220 - KGF 2	NO STATION AFFECTED	5:54	6:24	0:30	LINE CLEAR AVAILED
463	15-Jul-2021	BENGALURU	66	HV2	TEKAL	14:07	15:28	1:21	LINE CLEAR AVAILED
464	15-Jul-2021	BENGALURU	66	HV1	HOSKOTE 66	15:09	15:47	0:38	LINE CLEAR AVAILED
465	15-Jul-2021	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI	12:21	16:03	3:42	LINE CLEAR AVAILED
466	15-Jul-2021	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI	16:15	18:18	2:02	LINE CLEAR AVAILED
467	15-Jul-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	0:18	0:24	0:06	LINE FAULT
468	15-Jul-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	0:35	0:41	0:06	LINE FAULT
469	15-Jul-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	1:37	1:49	0:12	LINE FAULT
470	15-Jul-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	3:11	3:19	0:08	LINE FAULT
471	15-Jul-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	12:37	12:49	0:12	LINE FAULT
472	15-Jul-2021	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	3:39	3:44	0:04	LINE FAULT
473	15-Jul-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	5:17	5:24	0:07	LINE FAULT
474	15-Jul-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	14:15	14:33	0:17	LINE FAULT
475	15-Jul-2021	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 1	SURYANAGAR, ANEKAL	5:51	6:45	0:54	LINE FAULT
476	15-Jul-2021	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 2	ANEKAL	5:51	6:47	0:56	LINE FAULT
477	15-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
478	15-Jul-2021	GULBARGA	400	BTSP-HIRYUR2	HIRIYUR_400	3:42	7:59	4:17	LINE FAULT
479	15-Jul-2021	GULBARGA	220	RAICHUR-JURALA1	RAICHUR_220	8:30	9:57	1:27	LINE CLEAR AVAILED
480	15-Jul-2021	GULBARGA	110	HV1	JEWARGI_110	10:30	10:40	0:10	LINE CLEAR AVAILED
481	15-Jul-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	6:50	7:10	0:20	MAIN SUPPLY FAILURE
482	15-Jul-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	1:21	17:23	16:02	LINE CLEAR AVAILED
483	15-Jul-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	1:22	1:42	0:20	LINE FAULT
484	15-Jul-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	5:59	6:05	0:06	LINE FAULT
485	15-Jul-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	22:22	22:56	0:34	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
486	15-Jul-2021	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	11:00	11:20	0:20	LINE FAULT
487	15-Jul-2021	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	19:41	20:30	0:49	LINE FAULT
488	15-Jul-2021	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	21:37(15.07.2021)			LINE OPEN,LINE FAULT
489	15-Jul-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_220	12:30	16:50	4:20	LINE CLEAR AVAILED
490	15-Jul-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	14:10	16:51	2:41	LINE CLEAR AVAILED
491	15-Jul-2021	GULBARGA	110	SHAHAPUR- WARDHASOLAR_IPP	SHAHAPUR_220	19:10	21:47	2:37	LINE CLEAR AVAILED
492	15-Jul-2021	GULBARGA	110	HV2	DEODURGA_110	16:45	16:55	0:10	TRANSFORMER FAULT
493	15-Jul-2021	GULBARGA	110	HV2	GINIGERA_110	11:15	12:40	1:25	LINE CLEAR AVAILED
494	15-Jul-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERADONA_110,SR NAGAR_110,MALLAPUR_110	23:35	23:45	0:10	LINE FAULT
495	15-Jul-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_ 110, MANVI_110	15:32	17:17	1:45	LINE CLEAR AVAILED
496	15-Jul-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_1 10,NSL SUGARS_IPP	22:30	22:33	0:03	LINE FAULT
497	15-Jul-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	20:01 (14.07.2021)	11:37 (15.07.2021)	15:36hrs	LINE CHARGED
498	15-Jul-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	20:01 (14.07.2021)	11:37 (15.07.2021)	15:36hrs	LINE CHARGED
499	15-Jul-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	17:55 (14.07.2021)	11:32 (15.07.2021)	17:37hrs	LINE CHARGED
500	15-Jul-2021	HASSAN	220	HV1	KADUR_220	11:21	12:15	0:54	LINE CLEAR AVAILED
501	15-Jul-2021	HASSAN	220	HV2	KADUR_220	12:25	13:00	0:35	LINE CLEAR AVAILED
502	15-Jul-2021	HASSAN	110	LV1	KADUR_220	11:21	12:15	0:54	LINE CLEAR AVAILED
503	15-Jul-2021	HASSAN	110	LV2	KADUR_220	12:25	13:00	0:35	LINE CLEAR AVAILED
504	15-Jul-2021	HASSAN	110	HV2	NITTUR_110	6:32	14:01	7:29	TRANSFORMER FAULT
505	15-Jul-2021	HASSAN	110	HV2	NITTUR_110	15:35	17:05	1:30	LINE CLEAR AVAILED
506	15-Jul-2021	HASSAN	110	HV1	NITTUR_110	10:21	10:47	0:26	LINE CLEAR AVAILED
507	15-Jul-2021	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	14:49	15:24	0:35	LINE FAULT
508	15-Jul-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	0:20	0:53	0:33	LINE FAULT
509	15-Jul-2021	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	0:20	0:40	0:20	LINE FAULT
510	15-Jul-2021	HASSAN	66	ARAKAL-HASSAN	ARKD_66	10:30	17:03	6:33	LINE CLEAR AVAILED
511	15-Jul-2021	HASSAN	66	HV1	ARKD_66	10:30	17:03	6:33	LINE CLEAR AVAILED
512	15-Jul-2021	HASSAN	66	HV2	ARKD_66	9:30	16:00	6:30	LINE CLEAR AVAILED
513	15-Jul-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	10:30	17:03	6:33	LINE CLEAR AVAILED
514	15-Jul-2021	HASSAN	66	HV2	CHIKMAGALUR_66	11:51	12:00	0:09	LINE CLEAR AVAILED
515	15-Jul-2021	HASSAN	66	HV1	DODDAKADANUR_66	13:00	13:15	0:15	MAIN SUPPLY FAILURE
516	15-Jul-2021	HASSAN	66	HV1	GANGUR_66	12:55	13:45	0:50	LINE CLEAR AVAILED
517	15-Jul-2021	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	13:40	14:15	0:35	LINE CLEAR AVAILED
518	15-Jul-2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	13:10	13:15	0:05	HAND TRIPPED
519	15-Jul-2021	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	12:30	12:40	0:10	HAND TRIPPED
520	15-Jul-2021	HASSAN	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	10:36	17:00	6:24	MAIN SUPPLY FAILURE
521	15-Jul-2021	HASSAN	66	HV1	MALLIPATNA_66	10:36	17:00	6:24	MAIN SUPPLY FAILURE
522	15-Jul-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:36	17:00	6:24	MAIN SUPPLY FAILURE
523	15-Jul-2021	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	13:56	14:21	0:25	MAIN SUPPLY FAILURE
524	15-Jul-2021	HASSAN	66	HV1	MOSALEHOSAHALLI_66	13:56	14:21	0:25	MAIN SUPPLY FAILURE
525	15-Jul-2021	HASSAN	66	HV1	YESLUR_66	10:36	17:07	6:31	MAIN SUPPLY FAILURE
526	15-Jul-2021	HASSAN	66	YESLUR-SNVRSNT	YESLUR_66	10:36	17:07	6:31	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
527	15-Jul-2021	MYSURU	66	HV2	BILIKERE_66	11:06	13:33	2:26	LINE CLEAR AVAIED
528	15-Jul-2021	MYSURU	66	HV1	DODDINADUVADI_66	9:55	10:00	0:04	TRANSFORMER FAULT
529	15-Jul-2021	MYSURU	66	HV1	DODDINADUVADI_66	13:33	14:16	0:43	LINE CLEAR AVAIED
530	15-Jul-2021	MYSURU	66	FTS-HOOTGALLY 2	NO STATIONS EFFECTED	18:51	19:05	0:14	HAND TRIPPED
531	15-Jul-2021	MYSURU	66	MADHUVANALLI-KOLLEGALA1	NO STATIONS EFFECTED	6:39	6:43	0:03	LINE FAULT
532	15-Jul-2021	MYSURU	66	HV2	MALAVALLI_66	13:04	13:34	0:30	LINE CLEAR AVAIED
533	15-Jul-2021	MYSURU	66	HV2	RKNAGARA_66	12:32	13:10	0:37	LINE CLEAR AVAIED
534	15-Jul-2021	MYSURU	66	SHANIVARASANTE-MALLIPTNA	SANIVARASANTHE_66	10:31	15:45	5:13	LINE CLEAR AVAIED
535	15-Jul-2021	MYSURU	66	SHANIVARASANTE-YESSLUR	SANIVARASANTHE_66	10:31	15:45	5:13	LINE CLEAR AVAIED
536	15-Jul-2021	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	1:58	2:03	0:05	LINE FAULT
537	15-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAIED
538	15-Jul-2021	TUMKUR	400	GUTTUR 400KV-BEERANAHALLI2	GUTTUR 400KV	11:23	19:36	8:13	LINE CLEAR AVAIED
539	15-Jul-2021	TUMKUR	400	GUTUR_400-NARENDRA2	GUTTUR_400	1:22	8:37	7:15	LINE FAULT
540	15-Jul-2021	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	0:51	8:09	7:18	LINE FAULT
541	15-Jul-2021	TUMKUR	220	KB CROSS 220kv-NELAMANGALA	NELAMANGALA	12:30	18:01	5:30	NFBC ISSUED
542	15-Jul-2021	TUMKUR	110	TR-1	TURUVEKERE_110	13:17	16:24	3:07	LINE CLEAR AVAIED
543	15-Jul-2021	TUMKUR	66	TR-1	BADAVANAHALLI_66	10:25	11:06	0:40	LINE CLEAR AVAIED
544	15-Jul-2021	TUMKUR	66	CHITRADURGA 220kv-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP_66	20:01	20:24	0:23	LINE FAULT
545	15-Jul-2021	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	7:55	8:04	0:09	LINE FAULT
546	15-Jul-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1 IPP_66	INFOSYS-1_IPP_66	11:51	11:55	0:04	LINE FAULT
547	15-Jul-2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	RAMCO CEMENT_EHT_66	11:43	11:51	0:08	MAIN SUPPLY FAILURE
548	15-Jul-2021	TUMKUR	66	MATHOD-KANCHIPURA_66	MATHOD_66	6:10	6:15	0:05	LINE FAULT
549	15-Jul-2021	TUMKUR	66	MATHOD-HIRIYUR_66	MATHOD_66	13:30	13:35	0:05	LINE FAULT
550	15-Jul-2021	TUMKUR	66	TR-1	MATHOD_66	18:10	18:35	0:25	TRANSFORMER FAULT
551	15-Jul-2021	TUMKUR	66	TR-1	MATHOD_66	18:35	18:40	0:04	TRANSFORMER FAULT
552	15-Jul-2021	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	3:30	3:39	0:09	LINE FAULT
553	15-Jul-2021	TUMKUR	66	TR-1	SHYLAPURA_66	15:35	19:20	3:45	LINE CLEAR AVAIED
554	15-Jul-2021	TUMKUR	66	TR-2	SHYLAPURA_66	11:10	15:30	4:19	LINE CLEAR AVAIED
555	15-Jul-2021	TUMKUR	66	SHYLAPURA-PR PURA	SHYLAPURA_66	18:47	19:25	0:38	HAND TRIPPED
556	15-Jul-2021	TUMKUR	66	TR-2	THALLAKK_220	12:29	12:39	0:09	TRANSFORMER FAULT
557	15-Jul-2021	TUMKUR	66	TR-2	THALLAKK_220	13:58	14:14	0:16	TRANSFORMER FAULT
558	15-Jul-2021	TUMKUR	66	THALLAK 220KV- SEI DIAMOND SOLAR IPP_66	MYLANAHALLI_66, DYAVARANAHALLI_66	12:29	12:40	0:10	LINE FAULT
559	16-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAIED
560	16-Jul-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
561	16-Jul-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAIED
562	16-Jul-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
563	16-Jul-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
564	16-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
565	16-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
566	16-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
567	16-Jul-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
568	16-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
569	16-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
570	16-Jul-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:14 (11.07.2021)			LINE OPEN,LINE CLEAR AVAILED
571	16-Jul-2021	BAGALKOT	110	110/11KV, HV1	MUGALKOD_110	00:34 (11.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
572	16-Jul-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	18:01 (12.07.2021)			LINE OPEN,LINE CLEAR AVAILED
573	16-Jul-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	16:18 (12.07.1011)			LINE OPEN,LINE CLEAR AVAILED
574	16-Jul-2021	BAGALKOT	110	110/33KV, HV3	TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
575	16-Jul-2021	BAGALKOT	220	BAGEWADI-ALMATTI2 (ADPH2)	STATION NOT AFFECTED BAGEWADI_220	8:48	9:04	0:16	LINE FAULT
576	16-Jul-2021	BAGALKOT	220	220/110KV, HV1 & LV1	STATION NOT AFFECTED KARWAR_220	13:14	18:20	5:06	TRANSFORMER FAULT
577	16-Jul-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	16:15 (16.07.2021)			LINE OPEN,LINE CLEAR AVAILED
578	16-Jul-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	16:15 (16.07.2021)			LINE OPEN,LINE CLEAR AVAILED
579	16-Jul-2021	BAGALKOT	110	GAJENDRAGAD-KUSHTAGI220	STATION NOT AFFECTED GAJENDRAGAD_110	13:20 (12.07.2021)	16:15 (16.07.2021)	89HRS	LINE CHARGED
580	16-Jul-2021	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	5:35	5:48	0:13	LINE FAULT
581	16-Jul-2021	BAGALKOT	110	HIDAKALDAM-ANKALGI	STATION NOT AFFETCED HIDAKALDAM_110	10:33	13:58	3:25	NFBC ISSUED
582	16-Jul-2021	BAGALKOT	110	HIREHAL-RON	STATION NOT AFFETCED HIREHAL_110	12:25 (08.07.2021)	16:09 (16.07.2021)		LINE OPEN,LINE CLEAR AVAILED
583	16-Jul-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFETCED ITNAL_110	15:26	15:50	0:24	TRANSFORMER FAULT
584	16-Jul-2021	BAGALKOT	110	KADANKOPPA-AMBEWADI220(KAVALWADA)	STATION NOT AFFETCED KADANKOPPA_110	12:54	12:55	0:01	LINE CLEAR AVAILED
585	16-Jul-2021	BAGALKOT	110	110/11KV, HV2	SIRSI_110	13:15	13:43	0:28	LINE CLEAR AVAILED
586	16-Jul-2021	BAGALKOT	110	RON- GAMESH	RON_110	16:16	16:18	0:02	HAND TRIPPED
587	16-Jul-2021	BAGALKOT	110	110/11KV, HV2	RATTIHALI_110	11:29	11:36	0:07	LINE CLEAR AVAILED
588	16-Jul-2021	BAGALKOT	110	NAVALGUND- KONNUR	NAVALGUND_110	6:57	7:56	0:59	LINE FAULT
589	16-Jul-2021	BAGALKOT	110	NAVALGUND- KONNUR	NAVALGUND_110	11:02	16:16	5:14	LINE CLEAR AVAILED
590	16-Jul-2021	BAGALKOT	110	NARAGUND- BPCL	NARAGUND_110	11:00	16:39	5:39	LINE CLEAR AVAILED
591	16-Jul-2021	BAGALKOT	110	NAREGAL- RON	NAREGAL_110	15:13 (16.07.2021)			LINE OPEN,LINE FAULT
592	16-Jul-2021	BAGALKOT	110	KNM SOLAR- MUDDEBIHAL	MUDDEBIHAL_110	11:18	11:28	0:10	HAND TRIPPED
593	16-Jul-2021	BAGALKOT	110	KNM SOLAR- MUDDEBIHAL	MUDDEBIHAL_110	11:32	12:05	0:33	LINE CLEAR AVAILED
594	16-Jul-2021	BAGALKOT	110	BAGEWADI- MUDDEBIHAL	MUDDEBIHAL_110	11:37	12:05	0:28	LINE CLEAR AVAILED
595	16-Jul-2021	BENGALURU	66	ADUGODI - JAKKASANDRA	ADUGODI	11:12	14:40	3:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
596	16-Jul-2021	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	HSR LAYOUT 220	20:00	20:40	0:40	LOAD CHANGE OVER
597	16-Jul-2021	BENGALURU	220	HSR LAYOUT 220 - MYLSANDRA 400	NO STATION AFFECTED	20:00	20:23	0:23	LINE FAULT
598	16-Jul-2021	BENGALURU	220	HV1	HSR LAYOUT 220	20:00	20:40	0:40	LINE CLEAR AVAILED
599	16-Jul-2021	BENGALURU	220	HV3	HSR LAYOUT 220	20:00	20:40	0:40	LINE CLEAR AVAILED
600	16-Jul-2021	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	20:00	20:42	0:42	LINE CLEAR AVAILED
601	16-Jul-2021	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	20:00	20:42	0:42	LINE CLEAR AVAILED
602	16-Jul-2021	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	JAKKASANDRA, ADUGODI	20:00	20:42	0:42	LINE CLEAR AVAILED
603	16-Jul-2021	BENGALURU	66	HV1	HSR LAYOUT 220	20:00	20:42	0:42	LINE CLEAR AVAILED
604	16-Jul-2021	BENGALURU	66	HV3	HSR LAYOUT 220	20:00	20:42	0:42	LINE CLEAR AVAILED
605	16-Jul-2021	BENGALURU	66	HV1	HSR LAYOUT 220	20:42	21:05	0:23	TRANSFORMER FAULT
606	16-Jul-2021	BENGALURU	66	HV1	KADUGODI	21:17	21:25	0:08	TRANSFORMER FAULT
607	16-Jul-2021	BENGALURU	66	HV2	KENGERI SATELLITE TOWN	14:39	14:45	0:06	LINE CLEAR AVAILED
608	16-Jul-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	11:00	14:55	3:55	LINE CLEAR AVAILED
609	16-Jul-2021	BENGALURU	220	MYLSANDRA 400 - HSR LAYOUT 220	NO STATION AFFECTED	20:00	21:49	1:49	LINE FAULT
610	16-Jul-2021	BENGALURU	66	HV1	BAGHMANE WORLD TECH PARK	12:51	12:56	0:05	LINE CLEAR AVAILED
611	16-Jul-2021	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 220	BAGHMANE WORLD TECH PARK	16:00	16:06	0:06	LOAD CHANGE OVER
612	16-Jul-2021	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	10:15	10:20	0:05	MAIN SUPPLY FAILURE
613	16-Jul-2021	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	17:35	17:40	0:05	LOAD CHANGE OVER
614	16-Jul-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	16:16	16:29	0:12	LINE FAULT
615	16-Jul-2021	BENGALURU	66	HBR LAYOUT - YELLARBANDE	HBR LAYOUT	17:16	17:23	0:07	LOAD CHANGE OVER
616	16-Jul-2021	BENGALURU	66	KGF - BEML (EHT)	BEML (EHT)	7:30	7:42	0:12	LOAD CHANGE OVER
617	16-Jul-2021	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI	7:30	7:42	0:12	LOAD CHANGE OVER
618	16-Jul-2021	BENGALURU	220	HV2	CHINTAMANI 220	13:06	13:51	0:44	LINE CLEAR AVAILED
619	16-Jul-2021	BENGALURU	66	HV3	KGF	13:51	14:40	0:48	LINE CLEAR AVAILED
620	16-Jul-2021	BENGALURU	66	HV2	Y HUNSENHALLI	9:55	15:00	5:04	LINE CLEAR AVAILED
621	16-Jul-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	16:17	16:44	0:26	LINE FAULT
622	16-Jul-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	15:28	15:46	0:18	LINE FAULT
623	16-Jul-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	15:46	15:55	0:08	LINE FAULT
624	16-Jul-2021	BENGALURU	66	HV1	DOMMASANDRA	11:24	11:31	0:06	TRANSFORMER FAULT
625	16-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	11:17	12:17	0:59	LINE CLEAR AVAILED
626	16-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	12:48	13:10	0:22	LINE CLEAR AVAILED
627	16-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	13:27	14:10	0:43	LINE CLEAR AVAILED
628	16-Jul-2021	BENGALURU	66	HV1	NG HULKUR	14:30	15:05	0:35	LINE CLEAR AVAILED
629	16-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
630	16-Jul-2021	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	3:55(16.07.2021)			LINE OPEN,LINE CLEAR AVAILED
631	16-Jul-2021	GULBARGA	220	HV2	KAPNOOR_220	12:13	14:00	1:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
632	16-Jul-2021	GULBARGA	220	HV2	SEDAM_220	12:17	14:30	2:13	LINE CLEAR AVAILED
633	16-Jul-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	11:00	12:11	1:11	LINE CLEAR AVAILED
634	16-Jul-2021	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	21:37(15.07.2021)	6:40(16.07.2021)	9:03 HRS	LINE CHARGED
635	16-Jul-2021	GULBARGA	110	BHALKI-LADHA	LADHA_110	5:10	5:20	0:10	MAIN SUPPLY FAILURE
636	16-Jul-2021	GULBARGA	110	BHALKI-LADHA	LADHA_110	5:35	6:05	0:30	MAIN SUPPLY FAILURE
637	16-Jul-2021	GULBARGA	110	LADHA-RENEW SLR	LADHA_110	5:35	6:31	0:56	MAIN SUPPLY FAILURE
638	16-Jul-2021	GULBARGA	110	YELBURGA-PRPJS LR_IPP	YELBURGA_110	0:52	3:05	2:13	LINE FAULT
639	16-Jul-2021	GULBARGA	110	YELBURGA-PRPJS LR_IPP	YELBURGA_110	3:57	4:38	0:41	LINE FAULT
640	16-Jul-2021	GULBARGA	110	HV1	NIRNA_110	1:25	1:30	0:05	TRANSFORMER FAULT
641	16-Jul-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	6:15	6:30	0:15	LINE FAULT
642	16-Jul-2021	GULBARGA	110	KOLHAR-HALBARGA1	KOLHAR_110,JANAWADA_110, NSSK SUGAR FACTORY_IPP	12:30	12:35	0:05	LINE FAULT
643	16-Jul-2021	GULBARGA	110	KOLHAR-HALBARGA1	KOLHAR_110,JANAWADA_110, NSSK SUGAR FACTORY_IPP	13:30	13:35	0:05	LINE FAULT
644	16-Jul-2021	GULBARGA	110	KOLHAR-HALBARGA2	KOLHAR_110,JANAWADA_110, NSSK SUGAR FACTORY_IPP	12:35	12:50	0:15	LINE FAULT
645	16-Jul-2021	GULBARGA	110	KOLHAR-HALBARGA2	KOLHAR_110,JANAWADA_110, NSSK SUGAR FACTORY_IPP	14:35	14:40	0:05	LINE FAULT
646	16-Jul-2021	GULBARGA	110	KOLHAR-JANAWADA	JANAWADA_110,NSSK SUGAR FACTORY_IPP	15:40	15:45	0:05	LINE FAULT
647	16-Jul-2021	GULBARGA	110	KOLHAR-SHAHI SLR	KOLHAR_110	12:30	12:35	0:05	LINE FAULT
648	16-Jul-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	1:45	1:58	0:13	LINE FAULT
649	16-Jul-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGA ON_110,KAMALNAGAR_110	3:23	3:33	0:10	LINE FAULT
650	16-Jul-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERADONA_110,SR NAGAR_110,MALLAPUR_110	2:40	2:50	0:10	LINE FAULT
651	16-Jul-2021	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	5:30	7:30	2:00	LINE FAULT
652	16-Jul-2021	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110 VADAVATTI	20:26	20:31	0:05	LINE FAULT
653	16-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	0:15	0:25	0:10	LINE FAULT
654	16-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	4:00	4:12	0:12	LINE FAULT
655	16-Jul-2021	GULBARGA	110	HATTI-SMNMRD	HATTI_110	10:45	16:08	5:23	LINE CLEAR AVAILED
656	16-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
657	16-Jul-2021	HASSAN	66	HV2	MAGGE_66	10:08(14.7.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
658	16-Jul-2021	HASSAN	220	MRSSHM-ANTRSNH	MRS MG_220	11:21	12:30	1:09	LINE FAULT
659	16-Jul-2021	HASSAN	220	MRSSHM-SHARAVATHY2	MRS MG_220	12:47	14:27	1:40	LINE FAULT
660	16-Jul-2021	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	12:47	14:27	1:40	LINE FAULT
661	16-Jul-2021	HASSAN	220	GOPALAP-BASTIPURA	GOPALPURA_220	15:37	17:05	1:28	LINE FAULT
662	16-Jul-2021	HASSAN	220	GOPALAP-HNPUR21	GOPALPURA_220	15:37	17:05	1:28	LINE FAULT
663	16-Jul-2021	HASSAN	220	GOPALAP-HNPUR22	GOPALPURA_220	15:37	17:05	1:28	LINE FAULT
664	16-Jul-2021	HASSAN	220	GOPALAP-HSN400	GOPALPURA_220	15:37	17:05	1:28	LINE FAULT
665	16-Jul-2021	HASSAN	220	HV1	GOPALPURA_220	15:37	17:10	1:33	TRANSFORMER FAULT
666	16-Jul-2021	HASSAN	110	HV1	KADUR_220	2:33	11:05	8:32	TRANSFORMER FAULT
667	16-Jul-2021	HASSAN	110	HV1	KADUR_220	11:04	12:30	1:26	LINE CLEAR AVAILED
668	16-Jul-2021	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	13:20	16:52	3:32	LINE FAULT
669	16-Jul-2021	HASSAN	66	ARAKAL-HASSAN	ARAKALGUD_66	6:50	7:20	0:30	LINE FAULT
670	16-Jul-2021	HASSAN	66	ARAKAL-HASSAN	ARAKALGUD_66	8:02	8:12	0:10	LINE FAULT
671	16-Jul-2021	HASSAN	66	HV2	HALLYMYSORE_66	6:50	7:25	0:35	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
672	16-Jul-2021	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	15:37	17:11	1:34	MAIN SUPPLY FAILURE
673	16-Jul-2021	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	15:37	17:11	1:34	MAIN SUPPLY FAILURE
674	16-Jul-2021	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	6:01	6:06	0:05	LINE FAULT
675	16-Jul-2021	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	15:37	17:10	1:33	MAIN SUPPLY FAILURE
676	16-Jul-2021	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	15:37	17:13	1:36	MAIN SUPPLY FAILURE
677	16-Jul-2021	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	15:37	17:10	1:33	MAIN SUPPLY FAILURE
678	16-Jul-2021	HASSAN	66	Lv1	HOLENARASIPURA_220	15:37	17:07	1:30	MAIN SUPPLY FAILURE
679	16-Jul-2021	HASSAN	66	Lv2	HOLENARASIPURA_220	15:37	17:10	1:33	MAIN SUPPLY FAILURE
680	16-Jul-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	6:48	6:53	0:05	LINE FAULT
681	16-Jul-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	15:37	17:13	1:36	MAIN SUPPLY FAILURE
682	16-Jul-2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	15:37	17:13	1:36	MAIN SUPPLY FAILURE
683	16-Jul-2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	15:37	17:13	1:36	MAIN SUPPLY FAILURE
684	16-Jul-2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	15:37	17:13	1:36	MAIN SUPPLY FAILURE
685	16-Jul-2021	HASSAN	66	HV1	HNPURA_66	15:38	17:10	1:32	MAIN SUPPLY FAILURE
686	16-Jul-2021	HASSAN	66	HV2	HNPURA_66	15:38	17:10	1:32	MAIN SUPPLY FAILURE
687	16-Jul-2021	HASSAN	66	HV1	MAGGE_66	11:57	12:22	0:25	LINE CLEAR AVAILED
688	16-Jul-2021	HASSAN	66	HV1	MALALI_66	6:02	6:07	0:05	MAIN SUPPLY FAILURE
689	16-Jul-2021	HASSAN	66	HV1	MALALI_66	15:40	17:20	1:40	MAIN SUPPLY FAILURE
690	16-Jul-2021	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLY_66	12:34	13:15	0:41	LINE CLEAR AVAILED
691	16-Jul-2021	HASSAN	66	HV1	MOSALEHOSAHALLY_66	12:34	13:15	0:41	LINE CLEAR AVAILED
692	16-Jul-2021	HASSAN	66	HV1 CB	NAGARTHI_66KV	15:39	17:12	1:33	MAIN SUPPLY FAILURE
693	16-Jul-2021	HASSAN	66	SALAGAM-UDDURKOPLU	SALAGAME_66	4:39	14:29	9:50	LINE FAULT
694	16-Jul-2021	HASSAN	66	HV1	SINGAPURA_66	11:01	12:31	1:30	LINE CLEAR AVAILED
695	16-Jul-2021	MYSURU	220	CR NAGARA-BEGUR 1	NO STATIONS EFFECTED	15:54	16:03	0:09	LINE FAULT
696	16-Jul-2021	MYSURU	220	CR NAGARA-BEGUR 2	NO STATIONS EFFECTED	15:54	16:03	0:09	LINE FAULT
697	16-Jul-2021	MYSURU	220	HV1	CRNAGAR_220	15:54	16:04	0:10	TRANSFORMER FAULT
698	16-Jul-2021	MYSURU	220	HV2	CRNAGAR_220	15:54	16:04	0:10	TRANSFORMER FAULT
699	16-Jul-2021	MYSURU	66	DB HALLI-TUBINKERE	DODDABYADARAHALLI_66	10:20	15:30	5:09	LINE CLEAR AVAILED
700	16-Jul-2021	MYSURU	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	12:42	14:44	2:01	LINE CLEAR AVAILED
701	16-Jul-2021	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	12:42	14:44	2:01	LINE CLEAR AVAILED
702	16-Jul-2021	MYSURU	66	GUNDALPETE-BEGUR1	NO STATIONS EFFECTED	8:55	9:05	0:09	LINE FAULT
703	16-Jul-2021	MYSURU	66	HV1	JAKKANAHALLY_66	17:45	17:55	0:10	TRANSFORMER FAULT
704	16-Jul-2021	MYSURU	66	HV1	JAKKANAHALLY_66	18:30	19:25	0:55	TRANSFORMER FAULT
705	16-Jul-2021	MYSURU	66	KIRUGAVALU-MALIYURU	MALIYURU_66	11:30	11:39	0:09	LINE FAULT
706	16-Jul-2021	MYSURU	66	KIRUGAVALU-MALIYURU	MALIYURU_66	11:50	12:16	0:26	LINE FAULT
707	16-Jul-2021	MYSURU	66	HV2	MADDUR_66	14:06	15:30	1:24	LINE CLEAR AVAILED
708	16-Jul-2021	MYSURU	66	TUBINKERE-G UKKADA	NO STATIONS EFFECTED	11:34	12:51	1:17	LINE CLEAR AVAILED
709	16-Jul-2021	MYSURU	220	HV1	VAJAMANGALA_220	12:37	13:32	0:54	LINE CLEAR AVAILED
710	16-Jul-2021	MYSURU	66	VAJMANGLA-KADKOLA 1	MARADIHUNDI_66 AYRALLI_66	5:55	6:02	0:07	LINE FAULT
711	16-Jul-2021	MYSURU	66	CHINNAKURLI-HUYGONALLI	BANANGADI_66 CHINAKURALI_66	12:52	16:00	3:07	LINE CLEAR AVAILED
712	16-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
713	16-Jul-2021	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	0:29	7:56	7:27	LINE FAULT
714	16-Jul-2021	TUMKUR	220	ANTHRASANAHALLI 220kv-SHIMOGA	ANTHRASANAHALLI_220	11:21	12:27	1:06	LINE FAULT
715	16-Jul-2021	TUMKUR	110	TR-3	GUBBI_110	17:15	18:03	0:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
716	16-Jul-2021	TUMKUR	66	ANTHRASANAHALI 220kV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	11:21	11:51	0:30	LINE FAULT
717	16-Jul-2021	TUMKUR	66	TR-2	BADDIHALI_66	12:12	12:58	0:46	LINE CLEAR AVAILED
718	16-Jul-2021	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP_66	13:14	13:35	0:21	HAND TRIPPED
719	16-Jul-2021	TUMKUR	66	DAVANGERE SRS-DAVANGERE	DAVANAGERE_66	11:09	11:57	0:47	HAND TRIPPED
720	16-Jul-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	19:06	19:17	0:11	LINE FAULT
721	16-Jul-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:49	12:00	0:10	HAND TRIPPED
722	16-Jul-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:26	18:51	0:24	HAND TRIPPED
723	16-Jul-2021	TUMKUR	66	JAVAGONDANAHALLI-INFOSYS-1 IPP_66	INFOSYS-1_IPP_66	10:40	10:43	0:03	LINE FAULT
724	16-Jul-2021	TUMKUR	66	TR-1	KORATAGERE_66	11:13	11:37	0:24	LINE CLEAR AVAILED
725	16-Jul-2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	7:41	7:50	0:08	LINE FAULT
726	16-Jul-2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	14:46	15:03	0:16	HAND TRIPPED
727	16-Jul-2021	TUMKUR	66	TR-1	MATHOD_66	10:41	10:47	0:05	TRANSFORMER FAULT
728	16-Jul-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	12:11	12:13	0:01	HAND TRIPPED
729	16-Jul-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	14:15	14:31	0:16	LINE CLEAR AVAILED
730	16-Jul-2021	TUMKUR	66	TR-2	SHYLAPURA_66	12:58	13:12	0:14	LINE CLEAR AVAILED
731	16-Jul-2021	TUMKUR	66	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	10:26	13:15	2:49	LINE CLEAR AVAILED
732	17-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
733	17-Jul-2021	BAGALKOT	110	RANEBENNUR220-HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
734	17-Jul-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
735	17-Jul-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
736	17-Jul-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
737	17-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
738	17-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
739	17-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
740	17-Jul-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
741	17-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
742	17-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
743	17-Jul-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:14 (11.07.2021)			LINE OPEN,LINE CLEAR AVAILED
744	17-Jul-2021	BAGALKOT	110	110/11KV, HV1	MUGALKOD_110	00:34 (11.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
745	17-Jul-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	18:01 (12.07.2021)			LINE OPEN,LINE CLEAR AVAILED
746	17-Jul-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	16:18 (12.07.1011)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
747	17-Jul-2021	BAGALKOT	110	110/33KV, HV3	TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
748	17-Jul-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	16:15 (16.07.2021)	18:25 (17.07.2021)	26:10HRS	LINE CHARGED
749	17-Jul-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON_110	16:15 (16.07.2021)	18:25 (17.07.2021)	26:10HRS	LINE CHARGED
750	17-Jul-2021	BAGALKOT	110	NAREGAL- RON	NAREGAL_110	15:13 (16.07.2021)	13:40 (17.07.2021)	22:27HRS	LINE CHARGED
751	17-Jul-2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	3:23	4:10	0:47	TRANSFORMER FAULT
752	17-Jul-2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	11:02	11:32	0:30	HAND TRIPPED
753	17-Jul-2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	16:00	17:33	1:33	LINE CLEAR AVAILED
754	17-Jul-2021	BAGALKOT	220	220/110KV,HV2&LV2	BAGALKOT_220	11:08	17:55	6:47	LINE CLEAR AVAILED
755	17-Jul-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	6:12	6:35	0:23	LINE FAULT
756	17-Jul-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR CITY	18:53	22:01	3:08	TRANSFORMER FAULT
757	17-Jul-2021	BAGALKOT	110	ITANAL-HIDIKAL2	ITANAL_110	12:30	13:21	0:51	HAND TRIPPED
758	17-Jul-2021	BAGALKOT	110	HUNGAUND- KUDALASANGAM	KUDLASANGAM_110	5:54	13:22	7:28	LINE CLEAR AVAILED
759	17-Jul-2021	BAGALKOT	110	MAMADAPUR-SHIRABUR	SHIRABUR_110	6:38	6:43	0:05	HAND TRIPPED
760	17-Jul-2021	BAGALKOT	220	BIDNAL-HIREBENDIGERI 1&2	BIDNAL_220	6:10	9:19	3:09	NFBC ISSUED
761	17-Jul-2021	BAGALKOT	110	110/11KV,HV1	VAJRAMATTI_110	8:32	9:40	1:08	TRANSFORMER FAULT
762	17-Jul-2021	BAGALKOT	110	TODALBAGI-JAMAKHANDI SUGARS	STATION NOT AFFECTED TODALBAGI_110	10:50	11:34	0:44	LINE CLEAR AVAILED
763	17-Jul-2021	BAGALKOT	110	HIREHAL-RON	RON_110	13:35	17:45	4:10	LINE CLEAR AVAILED
764	17-Jul-2021	BAGALKOT	110	RAIBAG-MUGALKOD1	STATION NOT AFFECTED RAIBAG_110	16:03	16:40	0:37	LINE CLEAR AVAILED
765	17-Jul-2021	BAGALKOT	110	110/11KV,HV1	VAJRAMATTI_110	20:36	20:41	0:05	TRANSFORMER FAULT
766	17-Jul-2021	BAGALKOT	220	KUDUCHI-CHIKKODI1	STATION NOT AFFECTED KUDUCHI_220	10:25	13:23	2:58	LINE CLEAR AVAILED
767	17-Jul-2021	BAGALKOT	110	MUGALKOD-ITNAL2	STATION NOT AFFECTED MUGALKOD_220	12:35	13:21	0:46	LINE CLEAR AVAILED
768	17-Jul-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	10:40	10:47	0:07	LOAD CHANGE OVER
769	17-Jul-2021	BENGALURU	66	HV1	JAYADEVA	13:23	17:39	4:16	TRANSFORMER FAULT
770	17-Jul-2021	BENGALURU	66	HV2	NATIONAL COLLEGE	10:55	10:58	0:03	LINE CLEAR AVAILED
771	17-Jul-2021	BENGALURU	66	HV1	NATIONAL COLLEGE	16:38	16:42	0:04	LINE CLEAR AVAILED
772	17-Jul-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	9:06	9:55	0:49	LINE CLEAR AVAILED
773	17-Jul-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	15:38	16:31	0:53	LINE CLEAR AVAILED
774	17-Jul-2021	BENGALURU	66	HV2	DODDABELAVANGALA	11:15	11:29	0:14	TRANSFORMER FAULT
775	17-Jul-2021	BENGALURU	66	HV2	DODDABELAVANGALA	14:43	15:15	0:31	LINE CLEAR AVAILED
776	17-Jul-2021	BENGALURU	66	HV1	MAASTHI	11:03	11:30	0:27	LINE CLEAR AVAILED
777	17-Jul-2021	BENGALURU	66	HV2	SARIJAPURA 220	19:10	19:20	0:10	TRANSFORMER FAULT
778	17-Jul-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	8:00	8:25	0:25	LINE FAULT
779	17-Jul-2021	BENGALURU	66	DODALAHALLI - GRT SOLAR IPP	NO STATION AFFECTED	11:57	12:20	0:23	LINE FAULT
780	17-Jul-2021	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:59	16:50	6:51	LINE CLEAR AVAILED
781	17-Jul-2021	BENGALURU	66	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	5:44	5:51	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
782	17-Jul-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	19:10	20:14	1:04	LINE FAULT
783	17-Jul-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	19:10	20:05	0:55	LINE FAULT
784	17-Jul-2021	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	17:52	17:56	0:04	LOAD CHANGE OVER
785	17-Jul-2021	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	8:04	8:18	0:14	LINE FAULT
786	17-Jul-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	8:04	8:25	0:21	LINE FAULT
787	17-Jul-2021	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	10:35	10:40	0:05	LOAD CHANGE OVER
788	17-Jul-2021	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	17:30	17:35	0:05	LOAD CHANGE OVER
789	17-Jul-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	4:00	4:20	0:20	LINE FAULT
790	17-Jul-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:00	16:32	6:32	LINE CLEAR AVAILED
791	17-Jul-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:51	18:59	0:08	LINE FAULT
792	17-Jul-2021	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALI	23:58(17/07/2021)			LINE OPEN,LINE FAULT
793	17-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
794	17-Jul-2021	GULBARGA	400	BTSPS-HIRYUR2	HIRIYUR_400	3:55(16.07.2021)			LINE OPEN,LINE CLEAR AVAILED
795	17-Jul-2021	GULBARGA	220	HV2	RAICHUR_220	10:49	10:56	0:07	TRANSFORMER FAULT
796	17-Jul-2021	GULBARGA	220	HV1	RAICHUR_220	15:45	15:56	0:11	LINE CLEAR AVAILED
797	17-Jul-2021	GULBARGA	220	HV2	RAICHUR_220	16:43	17:13	0:30	LINE CLEAR AVAILED
798	17-Jul-2021	GULBARGA	220	LINGAPUR-JVSL1	JINDAL_220	10:24	16:15	5:51	NFBC ISSUED
799	17-Jul-2021	GULBARGA	220	LINGASUGUR-RTPS2	RTPS_220	5:06	5:18	0:12	LINE FAULT
800	17-Jul-2021	GULBARGA	220	LINGASUGUR-RTPS1	RTPS_220	5:19	5:30	0:11	LINE FAULT
801	17-Jul-2021	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
802	17-Jul-2021	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	2:15	2:34	0:19	LINE FAULT
803	17-Jul-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	5:25	5:58	0:33	LINE FAULT
804	17-Jul-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	1:46	2:05	0:19	LINE FAULT
805	17-Jul-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	3:11	3:29	0:18	LINE FAULT
806	17-Jul-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSL SUGAR FACTORY, CHOWDAPUR_110	5:42	5:48	0:06	LINE FAULT
807	17-Jul-2021	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	0:45	0:50	0:05	LINE FAULT
808	17-Jul-2021	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	20:53	21:25	0:32	LINE FAULT
809	17-Jul-2021	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	21:03	21:16	0:13	LINE FAULT
810	17-Jul-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	22:21	22:27	0:06	LINE FAULT
811	17-Jul-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	5:29	6:10	0:41	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
812	17-Jul-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110,NANDUR_110	5:45	5:50	0:05	LINE FAULT
813	17-Jul-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:55	12:05	0:10	LINE FAULT
814	17-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	5:05	5:15	0:10	LINE FAULT
815	17-Jul-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110,SR NAGAR_110,MALLAPUR_110	5:20	5:38	0:18	LINE FAULT
816	17-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	21:33	21:43	0:10	LINE FAULT
817	17-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	23:55(17.07.21)			LINE OPEN,LINE FAULT
818	17-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	4:20	4:25	0:05	LINE FAULT
819	17-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	5:08	5:14	0:06	LINE FAULT
820	17-Jul-2021	GULBARGA	110	HV1	BACHIGONDANAHALLI	19:46	19:48	0:02	TRANSFORMER FAULT
821	17-Jul-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	22:18	22:25	0:07	LINE FAULT
822	17-Jul-2021	GULBARGA	110	ITTAGI-HANASI	HANSI_66	21:45	22:20	0:35	MAIN SUPPLY FAILURE
823	17-Jul-2021	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
824	17-Jul-2021	GULBARGA	220	HV2	KUDLIGI_220	21:45	22:10	0:25	TRANSFORMER FAULT
825	17-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATI_IP P,COREGREENSUGAR_IPP	3:15	3:38	0:23	LINE FAULT
826	17-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATI_IP P,COREGREENSUGAR_IPP	19:39	20:03	0:24	LINE FAULT
827	17-Jul-2021	GULBARGA	110	KUSHTAGI-ILKAL	ILKAL_110	5:51	6:28	0:37	LINE FAULT
828	17-Jul-2021	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	23:11	23:18	0:07	LINE FAULT
829	17-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
830	17-Jul-2021	HASSAN	66	HV2	MAGGE_66	10:08(14.7.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
831	17-Jul-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:42(17.7.2021)			LINE OPEN,LINE FAULT
832	17-Jul-2021	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	12:42	17:25	4:43	NFBC ISSUED
833	17-Jul-2021	HASSAN	220	MRSSHM-VARAHI2	MRSMSG_220	4:45	10:53	6:08	LINE FAULT
834	17-Jul-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	11:02	14:48	3:46	LINE FAULT
835	17-Jul-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:02	14:48	3:46	LINE FAULT
836	17-Jul-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:00	11:17	0:17	HAND TRIPPED
837	17-Jul-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:00	11:17	0:17	HAND TRIPPED
838	17-Jul-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:00	11:17	0:17	HAND TRIPPED
839	17-Jul-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:00	11:17	0:17	HAND TRIPPED
840	17-Jul-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:00	11:17	0:17	HAND TRIPPED
841	17-Jul-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	4:45	10:56	6:11	LINE FAULT
842	17-Jul-2021	HASSAN	110	LV1	KADUR_220	10:12	13:10	2:58	LINE CLEAR AVAILED
843	17-Jul-2021	HASSAN	110	HV1	KAVOOR_220	9:25	17:46	8:21	LINE CLEAR AVAILED
844	17-Jul-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	19:48	20:08	0:20	LINE FAULT
845	17-Jul-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	1:03	1:20	0:17	LINE FAULT
846	17-Jul-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:35	12:53	0:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
847	17-Jul-2021	HASSAN	66	HV1	DIDIGA_66	16:34	18:22	1:48	TRANSFORMER FAULT
848	17-Jul-2021	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	6:30	6:35	0:05	LINE FAULT
849	17-Jul-2021	HASSAN	66	HV2	RAMNATHPURA_66	12:28	13:10	0:42	LINE CLEAR AVAILED
850	17-Jul-2021	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	12:28	13:10	0:42	LINE CLEAR AVAILED
851	17-Jul-2021	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:26	13:12	0:46	LINE CLEAR AVAILED
852	17-Jul-2021	HASSAN	66	HV1	MALLAPURA_66	10:45	16:09	5:24	LINE CLEAR AVAILED
853	17-Jul-2021	HASSAN	66	HV2	MALLAPURA_66	10:45	16:09	5:24	LINE CLEAR AVAILED
854	17-Jul-2021	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	10:45	16:09	5:24	LINE CLEAR AVAILED
855	17-Jul-2021	MYSURU	66	HV1	HEBBAL_66	11:32	11:54	0:21	TRANSFORMER FAULT
856	17-Jul-2021	MYSURU	66	HV1	HONNALLY_MYS_66	14:52	16:33	1:41	LINE CLEAR AVAILED
857	17-Jul-2021	MYSURU	66	KHONALAGERE-IGLOOR	K_HONNALGERE_66	9:11	9:39	0:27	LINE CLEAR AVAILED
858	17-Jul-2021	MYSURU	66	HV1	MADIKERI_66	9:59	12:13	2:14	LINE CLEAR AVAILED
859	17-Jul-2021	MYSURU	66	HV2	MADIKERI_66	12:13	14:40	2:26	LINE CLEAR AVAILED
860	17-Jul-2021	MYSURU	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	11:45	17:22	5:37	LINE CLEAR AVAILED
861	17-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
862	17-Jul-2021	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	4:16	8:29	4:13	LINE CLEAR AVAILED
863	17-Jul-2021	TUMKUR	400	GUTTUR 400KV- NARENDRA2	GUTUR_400	1:40	7:18	5:37	LINE FAULT
864	17-Jul-2021	TUMKUR	110	TR-1	TALKERE_110	13:50	14:14	0:24	LINE CLEAR AVAILED
865	17-Jul-2021	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	13:30	14:11	0:40	TRANSFORMER FAULT
866	17-Jul-2021	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	15:15	19:47	4:32	TRANSFORMER FAULT
867	17-Jul-2021	TUMKUR	66	TR-1	BENKIKERE_66	7:04	7:08	0:04	TRANSFORMER FAULT
868	17-Jul-2021	TUMKUR	66	TR-2	CHITRAHALLI_66	12:13	12:30	0:16	LINE CLEAR AVAILED
869	17-Jul-2021	TUMKUR	66	TR-1	CHITRAHALLI_66	11:38	12:00	0:21	LINE CLEAR AVAILED
870	17-Jul-2021	TUMKUR	66	DAVANGERE SRS-CHITRADURGA1	CHITRADURGA_220	12:59	13:12	0:12	LINE FAULT
871	17-Jul-2021	TUMKUR	66	DAVANGERE SRS-CHITRADURGA2	CHITRADURGA_220	12:59	13:12	0:12	LINE FAULT
872	17-Jul-2021	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:59	13:13	0:13	LINE FAULT
873	17-Jul-2021	TUMKUR	66	TR-2	HIRIYUR_66	13:10	14:05	0:55	LINE CLEAR AVAILED
874	17-Jul-2021	TUMKUR	66	HONNALLI 220kv-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	4:31	4:42	0:10	LINE FAULT
875	17-Jul-2021	TUMKUR	66	TR-1	KUNDUR_66	12:46	17:30	4:43	LINE CLEAR AVAILED
876	17-Jul-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	8:24	8:45	0:20	LINE FAULT
877	17-Jul-2021	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	13:00	13:20	0:20	LINE FAULT
878	17-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_66	9:37	10:00	0:22	TRANSFORMER FAULT
879	17-Jul-2021	TUMKUR	66	TR-1	SOKKE_66	14:15	14:40	0:24	LINE CLEAR AVAILED
880	17-Jul-2021	TUMKUR	66	TR-1	HONNALLI_66	12:05	17:41	5:36	MAIN SUPPLY FAILURE
881	17-Jul-2021	TUMKUR	66	TR-2	HONNALLI_66	12:05	17:42	5:37	MAIN SUPPLY FAILURE
882	17-Jul-2021	TUMKUR	66	TR-3	HONNALLI_66	12:05	17:41	5:36	MAIN SUPPLY FAILURE
883	17-Jul-2021	TUMKUR	66	TR-2	NYAMATHI_66	11:15	18:10	6:55	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
884	17-Jul-2021	TUMKUR	66	TR-2	NYAMATHI_66	18:36	20:52	2:15	LINE CLEAR AVAIED
885	18-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAIED
886	18-Jul-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
887	18-Jul-2021	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAIED
888	18-Jul-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAIED
889	18-Jul-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
890	18-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
891	18-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAIED
892	18-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAIED
893	18-Jul-2021	BAGALKOT	110	AMBEWADI- KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAIED
894	18-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAIED
895	18-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAIED
896	18-Jul-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	18:14 (11.07.2021)			LINE OPEN,LINE CLEAR AVAIED
897	18-Jul-2021	BAGALKOT	110	110/11KV, HV1	MUGALKOD_110	00:34 (11.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
898	18-Jul-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	18:01 (12.07.2021)			LINE OPEN,LINE CLEAR AVAIED
899	18-Jul-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	16:18 (12.07.1011)			LINE OPEN,LINE CLEAR AVAIED
900	18-Jul-2021	BAGALKOT	110	110/33KV, HV3	TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN,LINE CLEAR AVAIED
901	18-Jul-2021	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_220	6:29	6:56	0:27	LINE FAULT
902	18-Jul-2021	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	14:11	17:41	3:30	TRANSFORMER FAULT
903	18-Jul-2021	BAGALKOT	110	110/11KV,HV1	UDYAMBAG_110	8:55	9:33	0:38	LINE CLEAR AVAIED
904	18-Jul-2021	BENGALURU	66	ADUGODI - JAKKASANDRA	ADUGODI	6:33	6:43	0:10	LINE FAULT
905	18-Jul-2021	BENGALURU	66	HV2	ADUGODI	6:33	10:22	3:49	TRANSFORMER FAULT
906	18-Jul-2021	BENGALURU	66	HV3	ADUGODI	6:43	9:14	2:31	TRANSFORMER FAULT
907	18-Jul-2021	BENGALURU	66	HV1	B G ROAD	10:37	10:43	0:06	TRANSFORMER FAULT
908	18-Jul-2021	BENGALURU	66	B G ROAD - JIGANI	JIGANI	6:08	6:27	0:19	LINE FAULT
909	18-Jul-2021	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	11:07	11:15	0:08	LOAD CHANGE OVER
910	18-Jul-2021	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	16:45	16:50	0:05	LOAD CHANGE OVER
911	18-Jul-2021	BENGALURU	66	HV2	ELECTRONIC CITY P2 S1	0:05	0:53	0:48	LINE CLEAR AVAIED
912	18-Jul-2021	BENGALURU	66	HV3	HEBBALA 220	14:17	14:18	0:01	LINE CLEAR AVAIED
913	18-Jul-2021	BENGALURU	66	HV2	IISc	18:35	18:48	0:13	TRANSFORMER FAULT
914	18-Jul-2021	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	10:15	10:20	0:05	LOAD CHANGE OVER
915	18-Jul-2021	BENGALURU	66	SARAKKI - JAYADEVA	JAYADEVA	16:40	16:46	0:06	LOAD CHANGE OVER
916	18-Jul-2021	BENGALURU	66	HV2	MATHIKERE	12:49	12:53	0:04	LINE CLEAR AVAIED
917	18-Jul-2021	BENGALURU	66	HV2	NRS 220	4:53	10:47	5:54	TRANSFORMER FAULT
918	18-Jul-2021	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALLI	10:52	11:46	0:54	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
919	18-Jul-2021	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALLI	12:47	13:30	0:43	LINE FAULT
920	18-Jul-2021	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALLI	15:45	16:08	0:23	LINE CLEAR AVAILED
921	18-Jul-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:16	11:24	0:08	LINE FAULT
922	18-Jul-2021	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	6:33	6:42	0:09	LINE FAULT
923	18-Jul-2021	BENGALURU	66	JAKKASANDRA - ADUGODI	ADUGODI	6:33	6:56	0:23	LINE FAULT
924	18-Jul-2021	BENGALURU	66	V R DODDI - SOMANAHALLI 220	V R DODDI	7:00	7:30	0:30	LOAD CHANGE OVER
925	18-Jul-2021	BENGALURU	66	V R DODDI - T K HALLI 220	V R DODDI	18:05	18:30	0:25	LOAD CHANGE OVER
926	18-Jul-2021	BENGALURU	66	HV1	V R DODDI	11:05	11:25	0:20	LINE CLEAR AVAILED
927	18-Jul-2021	BENGALURU	66	HV1	V R DODDI	18:30	18:35	0:05	LINE CLEAR AVAILED
928	18-Jul-2021	BENGALURU	66	HV2	KIADB DB PURA 220	10:17	10:59	0:41	LINE CLEAR AVAILED
929	18-Jul-2021	BENGALURU	66	HV2	DODDABELAVANGALA	9:02	9:18	0:15	TRANSFORMER FAULT
930	18-Jul-2021	BENGALURU	66	HV1	GODUR	17:13	17:50	0:37	LINE CLEAR AVAILED
931	18-Jul-2021	BENGALURU	66	HV2	IRGAMPALLI	21:01	21:07	0:06	TRANSFORMER FAULT
932	18-Jul-2021	BENGALURU	66	HV2	MAASTHI	12:55	15:04	2:09	LINE CLEAR AVAILED
933	18-Jul-2021	BENGALURU	66	HV1	TUBUGERE	9:35	10:58	1:23	LINE CLEAR AVAILED
934	18-Jul-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	8:01	8:07	0:06	LINE FAULT
935	18-Jul-2021	BENGALURU	66	KIADB HARDWARE PARK 220 - SHELL (EHT)	SHELL (EHT)	11:06	12:28	1:22	LINE FAULT
936	18-Jul-2021	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:57	17:15	7:17	LINE CLEAR AVAILED
937	18-Jul-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	1:24	1:55	0:30	LINE CLEAR AVAILED
938	18-Jul-2021	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	13:50	13:55	0:05	LOAD CHANGE OVER
939	18-Jul-2021	BENGALURU	66	DOMMASANDRA - EPIP 220	DOMMASANDRA	8:10	8:20	0:10	LOAD CHANGE OVER
940	18-Jul-2021	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	8:00	8:09	0:09	LINE FAULT
941	18-Jul-2021	BENGALURU	220	YELAHANKA 220 - YCCP 1	NO STATION AFFECTED	12:19	13:35	1:16	LINE CLEAR AVAILED
942	18-Jul-2021	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	16:53	17:03	0:10	LINE FAULT
943	18-Jul-2021	BENGALURU	66	HV2	KIADB DB PURA 220	10:15	11:00	0:45	LINE CLEAR AVAILED
944	18-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 1	NO STATION AFFECTED	16:00	16:20	0:20	LINE FAULT
945	18-Jul-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2	RVNL	16:00	16:20	0:20	LINE FAULT
946	18-Jul-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:00	17:11	7:11	LINE CLEAR AVAILED
947	18-Jul-2021	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALLI	23:58(17/07/2021)	1:29(18/07/2021)	1:31HR	LINE CHARGED
948	18-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
949	18-Jul-2021	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	3:55(16.07.2021)			LINE OPEN,LINE CLEAR AVAILED
950	18-Jul-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	21:50	22:07	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
951	18-Jul-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	22:09(18.7.21)			LINE OPEN,LINE FAULT
952	18-Jul-2021	GULBARGA	220	SHAHABAD-KAPANOOR	SHAHABAD_220	6:10	6:22	0:12	LINE FAULT
953	18-Jul-2021	GULBARGA	220	LINGASUGUR-RTPS1	RTPS_220	0:02	2:20	2:18	LINE FAULT
954	18-Jul-2021	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	6:10	6:22	0:12	LINE FAULT
955	18-Jul-2021	GULBARGA	220	KAPNOOR-HUMNABAD1,2	HUMNABAD_220	7:24	14:16	6:52	LINE CLEAR AVAILED
956	18-Jul-2021	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
957	18-Jul-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	0:20	0:30	0:10	LINE FAULT
958	18-Jul-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	0:35	0:50	0:15	LINE FAULT
959	18-Jul-2021	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	2:15	2:40	0:25	LINE FAULT
960	18-Jul-2021	GULBARGA	110	MARAGUTTI-CLN SLR	MARAGUTTI_110	19:50	22:39	2:49	LINE CLEAR AVAILED
961	18-Jul-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	7:00	14:45	7:45	MAIN SUPPLY FAILURE
962	18-Jul-2021	GULBARGA	110	LADHA-SASTHAPUR	LADHA_110	20:10	20:25	0:15	MAIN SUPPLY FAILURE
963	18-Jul-2021	GULBARGA	110	HV1	MALLAPURA_110	20:03	20:43	0:40	LINE CLEAR AVAILED
964	18-Jul-2021	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	7:00	17:20	10:20	NFBC ISSUED
965	18-Jul-2021	GULBARGA	110	RAJESHWAR-WARDHA SLR	RAJESHWAR_110	7:00	15:00	8:00	LINE CLEAR AVAILED
966	18-Jul-2021	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	10:10	10:30	0:20	MAIN SUPPLY FAILURE
967	18-Jul-2021	GULBARGA	110	RAJESHWAR-SASTHAPUR	RAJESHWAR_110	20:10	20:30	0:20	MAIN SUPPLY FAILURE
968	18-Jul-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	5:20	5:50	0:30	MAIN SUPPLY FAILURE
969	18-Jul-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	7:00	14:40	7:40	MAIN SUPPLY FAILURE
970	18-Jul-2021	GULBARGA	110	SHAHABAD-RAICHUR2	JEWARGI_110,NALWAR_110	0:20	0:30	0:10	MAIN SUPPLY FAILURE
971	18-Jul-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	0:35	0:40	0:05	MAIN SUPPLY FAILURE
972	18-Jul-2021	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORAWAR TEMPLE_110	2:48	2:55	0:07	MAIN SUPPLY FAILURE
973	18-Jul-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	3:02	3:12	0:10	MAIN SUPPLY FAILURE
974	18-Jul-2021	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORAWAR TEMPLE_110	3:20	3:25	0:05	MAIN SUPPLY FAILURE
975	18-Jul-2021	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORAWAR TEMPLE_110	5:00	8:15	3:15	MAIN SUPPLY FAILURE
976	18-Jul-2021	GULBARGA	110	SHAHABAD-FARATHABAD	FARATHABAD_110,GULBARGA NORTH_110	5:34	8:15	2:41	MAIN SUPPLY FAILURE
977	18-Jul-2021	GULBARGA	110	SINDHANOOR-THUVIHAL	THURVIHAL_110	0:13	0:57	0:44	MAIN SUPPLY FAILURE
978	18-Jul-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,Y ERADONA_110,SR NAGAR_110,MALLAPUR_110	1:19	1:21	0:02	MAIN SUPPLY FAILURE
979	18-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	2:19	2:34	0:15	MAIN SUPPLY FAILURE
980	18-Jul-2021	GULBARGA	110	SINDHANOOR-THUVIHAL	THURVIHAL_110	9:20	9:27	0:07	LINE CLEAR AVAILED
981	18-Jul-2021	GULBARGA	110	SINDHANOOR-SIRAGUPPA	DHADESUGUR_110,SIRAGUPPA_110, TEKKALKOTE_110	22:39	22:49	0:10	MAIN SUPPLY FAILURE
982	18-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	23:55(17.07.2021)	00:53(18.07.2021)	00:58HRS	LINE CHARGED
983	18-Jul-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	5:27	5:30	0:03	LINE FAULT
984	18-Jul-2021	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110 VADAVATTI	20:21	20:32	0:11	LINE FAULT
985	18-Jul-2021	GULBARGA	110	ITTAGI-BACHIGONDANAHALLI	BACHIGONDANAHALLI_66	20:10	20:15	0:05	MAIN SUPPLY FAILURE
986	18-Jul-2021	GULBARGA	110	HUMNABAD-CHITGUPPA	CHIGUPPA_110	7:20	14:54	7:34	MAIN SUPPLY FAILURE
987	18-Jul-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED	7:20	14:50	7:30	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
988	18-Jul-2021	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	14:39	14:56	0:17	LINE CLEAR AVAILED
989	18-Jul-2021	GULBARGA	110	KAVITAL-GMSH	KAVITAL_110	1:09	1:16	0:07	LINE CLEAR AVAILED
990	18-Jul-2021	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
991	18-Jul-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	5:25	5:55	0:30	LINE FAULT
992	18-Jul-2021	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	7:29	14:09	6:40	LINE CLEAR AVAILED
993	18-Jul-2021	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	7:28	20:30	13:02	LINE CLEAR AVAILED
994	18-Jul-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	15:19(18.07.2021)			LINE OPEN,LINE FAULT
995	18-Jul-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGA ON_110,KAMALNAGA_110	1:12	1:17	0:05	LINE FAULT
996	18-Jul-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGA ON_110,KAMALNAGA_110	2:55	3:02	0:07	LINE FAULT
997	18-Jul-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGA ON_110,KAMALNAGA_110	7:44	14:43	6:59	LINE CLEAR AVAILED
998	18-Jul-2021	GULBARGA	110	HALBARGA-CHIDRI2	CHIDRI_110	7:28	14:40	7:12	LINE CLEAR AVAILED
999	18-Jul-2021	GULBARGA	110	HALBARGA-KOLHAR1,2	KOLHAR_110,JANAWADA_110, NSSK SUGAR FACTORY_IPP	7:50	14:43	6:53	LINE CLEAR AVAILED
1000	18-Jul-2021	GULBARGA	110	HALBARGA-ACME SOLAR_IPP	HALBARGA_220	8:11	14:43	6:32	LINE CLEAR AVAILED
1001	18-Jul-2021	GULBARGA	110	HALBARGA-CHIDRI1	CHIDRI_110,HABSIKOTE_110	8:30	14:05	5:35	LINE CLEAR AVAILED
1002	18-Jul-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALU_110,KUDITINI_110,KURUGOD_110,SHATHVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_110,METRI_110,RBNSFACTORY_110	6:04	6:13	0:09	LINE FAULT
1003	18-Jul-2021	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA	5:43	5:47	0:04	LINE FAULT
1004	18-Jul-2021	GULBARGA	110	HUMNABAD-SASTHAPUR	SASTHAPUR_110,RAJESHWAR_110,MANTHAL_110	7:45	17:32	9:47	NFBC ISSUED
1005	18-Jul-2021	GULBARGA	220	HUMNABAD-HALBARGA1&2	HALBARGA_220	7:30	14:19	6:49	LINE CLEAR AVAILED
1006	18-Jul-2021	GULBARGA	220	HV1 & HV2	HUMNABAD_220	7:30	14:33	7:03	LINE CLEAR AVAILED
1007	18-Jul-2021	GULBARGA	220	HV2	HUMNABAD_220	18:38(18.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1008	18-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	3:46	4:06	0:20	LINE FAULT
1009	18-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	20:13	20:42	0:29	LINE FAULT
1010	18-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	21:52	21:58	0:06	LINE FAULT
1011	18-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1012	18-Jul-2021	HASSAN	66	HV2	MAGGE_66	10:08(14.7.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1013	18-Jul-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	20:00 (18.07.2021)			LINE OPEN,LINE FAULT
1014	18-Jul-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:42(17.7.2021)	15:13(18.7.2021)	22:31hrs	LINE CHARGED
1015	18-Jul-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	13:29	13:39	0:10	LINE FAULT
1016	18-Jul-2021	HASSAN	110	HV2	ESSUR_110	18:46	20:36	1:50	TRANSFORMER FAULT
1017	18-Jul-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	13:30	13:40	0:10	LINE FAULT
1018	18-Jul-2021	HASSAN	110	HV1	KARAYA_110	21:12	22:25	1:13	LINE CLEAR AVAILED
1019	18-Jul-2021	HASSAN	110	HV2	NERALAKERE_110	22:15	22:28	0:13	TRANSFORMER FAULT
1020	18-Jul-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:01	11:37	0:36	LINE CLEAR AVAILED
1021	18-Jul-2021	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	15:00	15:05	0:05	LINE FAULT
1022	18-Jul-2021	HASSAN	66	HV1	HNPURA_66	15:00	15:10	0:10	MAIN SUPPLY FAILURE
1023	18-Jul-2021	HASSAN	66	HV2	HNPURA_66	15:00	15:10	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1024	18-Jul-2021	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	15:00	15:09	0:09	MAIN SUPPLY FAILURE
1025	18-Jul-2021	HASSAN	66	HV1	MALLIPATNA_66	7:57	8:46	0:49	LINE CLEAR AVAILED
1026	18-Jul-2021	MYSURU	66	CR NAGARA-KABHALLY	NO STATIONS EFFECTED	8:07	8:17	0:09	LINE FAULT
1027	18-Jul-2021	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	11:20	11:32	0:12	LINE FAULT
1028	18-Jul-2021	MYSURU	66	MADHUVANALLY-KOLLEGALA1	NO STATIONS EFFECTED	10:19	10:22	0:03	LINE FAULT
1029	18-Jul-2021	MYSURU	66	HV2	TUBINAKERE_220	10:57	11:08	0:10	TRANSFORMER FAULT
1030	18-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
1031	18-Jul-2021	TUMKUR	220	PAVAGADA 220kV- GREEN KO	HEBBUR_66, BHAKTARAHALLI_66	6:02	8:09	2:07	LINE FAULT
1032	18-Jul-2021	TUMKUR	220	PAVAGADA 220kV-MADHUGIRI 2	PAVAGADA_220	6:02	7:22	1:19	LINE FAULT
1033	18-Jul-2021	TUMKUR	110	TR-2	BANDIHALLI_110	14:40	18:02	3:22	LINE CLEAR AVAILED
1034	18-Jul-2021	TUMKUR	66	ANCHEPALYA 220kV-YEDIYUR(BG NAGAR)	YEDIYUR_66	15:49	15:57	0:07	LINE FAULT
1035	18-Jul-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	9:40	9:45	0:05	LINE FAULT
1036	18-Jul-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	12:38	12:44	0:05	TRANSFORMER FAULT
1037	18-Jul-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	15:45	16:59	1:14	TRANSFORMER FAULT
1038	18-Jul-2021	TUMKUR	66	CHITRADURGA 220kV-CHALLAKERE(BALENAHALLI)	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	13:56	14:11	0:14	HAND TRIPPED
1039	18-Jul-2021	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP_66	15:13	16:12	0:59	HAND TRIPPED
1040	18-Jul-2021	TUMKUR	66	TR-1	CHITRAHALLI_66	13:16	14:09	0:52	TRANSFORMER FAULT
1041	18-Jul-2021	TUMKUR	66	TR-1	CHITRAHALLI_66	14:26	14:30	0:04	TRANSFORMER FAULT
1042	18-Jul-2021	TUMKUR	66	DAVANGERE SRS-DAVANGERE	DAVANAGERE_66	2:45	2:52	0:06	HAND TRIPPED
1043	18-Jul-2021	TUMKUR	66	DAVANGERE SRS-DAVANGERE	DAVANAGERE_66	9:15	9:19	0:03	HAND TRIPPED
1044	18-Jul-2021	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:47	13:17	0:30	LINE FAULT
1045	18-Jul-2021	TUMKUR	66	TR-1	HIRIYUR_66	1:28	1:35	0:06	TRANSFORMER FAULT
1046	18-Jul-2021	TUMKUR	66	TR-1	HIRIYUR_66	6:14	6:21	0:06	TRANSFORMER FAULT
1047	18-Jul-2021	TUMKUR	66	TR-1	HIRIYUR_66	6:23	6:32	0:09	TRANSFORMER FAULT
1048	18-Jul-2021	TUMKUR	66	TR-1	HIRIYUR_66	11:56	12:01	0:05	TRANSFORMER FAULT
1049	18-Jul-2021	TUMKUR	66	TR-1	HIRIYUR_66	12:26	12:36	0:09	TRANSFORMER FAULT
1050	18-Jul-2021	TUMKUR	66	TR-1	HIRIYUR_66	13:57	14:00	0:02	TRANSFORMER FAULT
1051	18-Jul-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:02	13:11	0:09	LINE FAULT
1052	18-Jul-2021	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	9:22	9:37	0:15	LINE FAULT
1053	18-Jul-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66	12:45	13:05	0:20	MAIN SUPPLY FAILURE
1054	18-Jul-2021	TUMKUR	66	TR-1	LOKEKERE_66	15:15	15:36	0:20	TRANSFORMER FAULT
1055	19-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
1056	19-Jul-2021	BAGALKOT	110	RANEBENNUR220-HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1057	19-Jul-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
1058	19-Jul-2021	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
1059	19-Jul-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
1060	19-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
1061	19-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI 110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
1062	19-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B) 110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1063	19-Jul-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI 220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1064	19-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI 220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1065	19-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA 110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1066	19-Jul-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	STATION NOT AFFECTED BELGAUM 220	18:14 (11.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1067	19-Jul-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD 110	00:34 (11.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1068	19-Jul-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI 220	18:01 (12.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1069	19-Jul-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI 220	16:18 (12.07.1011)			LINE OPEN,LINE CLEAR AVAILED
1070	19-Jul-2021	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL 110	11:06 (14.07.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1071	19-Jul-2021	BAGALKOT	110	110/11KV,HV1	AIGALI 110	8:14	18:24	10:10	TRANSFORMER FAULT
1072	19-Jul-2021	BAGALKOT	110	110/11KV,HV1	AIGALI 110	20:05	20:45	0:40	TRANSFORMER FAULT
1073	19-Jul-2021	BAGALKOT	110	110/11KV,HV1	AIGALI 110	21:05 (19.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1074	19-Jul-2021	BAGALKOT	110	BELGAUM220-ANKALAGI	STATION NOT AFFECTED BELGAUM 220	4:16	4:27	0:11	LINE FAULT
1075	19-Jul-2021	BAGALKOT	110	DAVALESHWAR-SAIDAPUR	SAIDAPUR 110	7:40	7:54	0:14	LINE FAULT
1076	19-Jul-2021	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI 110	12:45	12:59	0:14	TRANSFORMER FAULT
1077	19-Jul-2021	BAGALKOT	110	VAJRAMATTI220-JAMBAGI	JAMBAGI 110	6:18	6:36	0:18	LINE FAULT
1078	19-Jul-2021	BAGALKOT	110	220/110KV,HV1,LV1,	MK HUBLI 220	16:25	17:54	1:29	LINE CLEAR AVAILED
1079	19-Jul-2021	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI 110	16:49	17:05	0:16	TRANSFORMER FAULT
1080	19-Jul-2021	BAGALKOT	220	AMBEWADI-NAGZARI2	STATION NOT AFFECTED AMBEWADI 220	02:26 (19.07.2021)			LOAD CURTAILMENT
1081	19-Jul-2021	BAGALKOT	220	AMBEWADI-NARENDRDRA2	STATION NOT AFFECTED AMBEWADI 220	2:31 (19.07.2021)			LOAD CURTAILMENT
1082	19-Jul-2021	BAGALKOT	110	SIRSI-JOG2	STATION NOT AFFECTED SIRSI 110	11:49	12:27	0:38	HAND TRIPPED
1083	19-Jul-2021	BAGALKOT	110	SIRSI- SIDDAPUR (JOG1)	STATION NOT AFFECTED SIRSI 110	12:10	12:23	0:13	HAND TRIPPED
1084	19-Jul-2021	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL 110	16:59 (19.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1085	19-Jul-2021	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL 110	17:00 (19.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1086	19-Jul-2021	BENGALURU	66	HV2	BANASHANKARI	6:02	6:14	0:12	TRANSFORMER FAULT
1087	19-Jul-2021	BENGALURU	220	HV2	BIDADI 220	10:31	10:47	0:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1088	19-Jul-2021	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	10:31	12:02	1:31	LINE FAULT
1089	19-Jul-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	10:31	10:48	0:17	LINE CLEAR AVOIDED
1090	19-Jul-2021	BENGALURU	66	HV1	BIDADI 220	10:31	10:49	0:18	LINE CLEAR AVOIDED
1091	19-Jul-2021	BENGALURU	66	HV2	BIDADI 220	10:31	10:49	0:18	LINE CLEAR AVOIDED
1092	19-Jul-2021	BENGALURU	66	HV3	BIDADI 220	10:31	10:49	0:18	LINE CLEAR AVOIDED
1093	19-Jul-2021	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	13:37	13:43	0:06	LINE FAULT
1094	19-Jul-2021	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	13:37	13:49	0:12	LINE FAULT
1095	19-Jul-2021	BENGALURU	66	HV1	KADUGODI	14:44	15:00	0:16	TRANSFORMER FAULT
1096	19-Jul-2021	BENGALURU	66	HV2	KADUGODI	22:18	22:21	0:03	TRANSFORMER FAULT
1097	19-Jul-2021	BENGALURU	66	HV2	REMCO	15:53	16:06	0:13	TRANSFORMER FAULT
1098	19-Jul-2021	BENGALURU	66	HV1	REMCO	15:53	16:06	0:13	TRANSFORMER FAULT
1099	19-Jul-2021	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	18:43	18:54	0:11	LINE FAULT
1100	19-Jul-2021	BENGALURU	66	HV1	CHIKKENAHALLI	18:32	18:56	0:24	LINE CLEAR AVOIDED
1101	19-Jul-2021	BENGALURU	66	HV2	DALASNUR	10:00	10:23	0:23	LINE CLEAR AVOIDED
1102	19-Jul-2021	BENGALURU	220	HV1	KIADB DB PURA 220	16:48	17:08	0:19	LINE CLEAR AVOIDED
1103	19-Jul-2021	BENGALURU	220	HV2	KIADB DB PURA 220	16:12	16:46	0:33	LINE CLEAR AVOIDED
1104	19-Jul-2021	BENGALURU	66	HV2	GUDEMARANAHALLI	0:55	1:10	0:15	TRANSFORMER FAULT
1105	19-Jul-2021	BENGALURU	66	HV1	MAASTHI	14:51	15:35	0:44	LINE CLEAR AVOIDED
1106	19-Jul-2021	BENGALURU	66	DODALAHALLI - GRT SOLAR IPP	NO STATION AFFECTED	1:32	1:45	0:13	LINE FAULT
1107	19-Jul-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:56	18:10	0:14	LINE FAULT
1108	19-Jul-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	17:56	18:25	0:29	LINE FAULT
1109	19-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
1110	19-Jul-2021	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	3:55(16.07.2021)	10:37(19.07.2021)	78:42HRS	LINE CHARGED
1111	19-Jul-2021	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	11:37	16:43	5:06	NFBC ISSUED
1112	19-Jul-2021	GULBARGA	400	BTPS-HIRYUR2	HIRIYUR_400	23:11(19.07.2021)			LINE OPEN,LINE CLEAR AVOIDED
1113	19-Jul-2021	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1114	19-Jul-2021	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	4:21(19.07.2021)			LINE OPEN,LINE FAULT
1115	19-Jul-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	22:09(18.7.21)	12:18(19.7.21)	14:17HRS	LINE CHARGED
1116	19-Jul-2021	GULBARGA	220	HV2	HUMNABAD_220	18:38(18.07.2021)	18:57(19.07.2021)	24:19HRS	TRANSFORMER CHARGED
1117	19-Jul-2021	GULBARGA	220	HUMNABAD-KAPNOOR2	KAPNOOR_220	14:15(18.07.2021)	17:27(19.07.2021)	27:12HRS	LINE CHARGED
1118	19-Jul-2021	GULBARGA	220	HV1	HUMNABAD_220	18:04	18:11	0:07	TRANSFORMER FAULT
1119	19-Jul-2021	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1120	19-Jul-2021	GULBARGA	110	SHAHABAD-RAICHUR2	JEWARGI_110,NALWAR_110	7:40	20:20	12:40	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1121	19-Jul-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	1:58	2:03	0:05	LINE FAULT
1122	19-Jul-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	6:50	16:25	9:35	LINE CLEAR AVAILED
1123	19-Jul-2021	GULBARGA	110	PDHALLI-BASAI_IPP	PD_HALLI_110	5:24	5:43	0:19	LINE FAULT
1124	19-Jul-2021	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	5:24	5:40	0:16	MAIN SUPPLY FAILURE
1125	19-Jul-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	11:45	11:50	0:05	MAIN SUPPLY FAILURE
1126	19-Jul-2021	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	2:53	3:08	0:15	MAIN SUPPLY FAILURE
1127	19-Jul-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	3:30	3:45	0:15	MAIN SUPPLY FAILURE
1128	19-Jul-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	11:25	11:35	0:10	MAIN SUPPLY FAILURE
1129	19-Jul-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	11:40	11:50	0:10	MAIN SUPPLY FAILURE
1130	19-Jul-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	12:00	12:05	0:05	MAIN SUPPLY FAILURE
1131	19-Jul-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	12:10	12:15	0:05	MAIN SUPPLY FAILURE
1132	19-Jul-2021	GULBARGA	110	HV2	HATTI_110	1:39	1:58	0:19	TRANSFORMER FAULT
1133	19-Jul-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	15:19(18.07.2021)	12:34(19.07.2021)	21:15HRS	LINE CHARGED
1134	19-Jul-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:18	20:23	0:05	LINE FAULT
1135	19-Jul-2021	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	3:05	3:25	0:20	LINE FAULT
1136	19-Jul-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	5:48	5:52	0:04	LINE FAULT
1137	19-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	3:48	7:14	3:26	LINE FAULT
1138	19-Jul-2021	GULBARGA	110	SINDHANOOR-THUVIHAL	THURVIHAL_110	2:25	2:35	0:10	LINE FAULT
1139	19-Jul-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRAGUPPA_110,TEKKALKOTE_110	2:59	3:09	0:10	LINE FAULT
1140	19-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	5:47	6:02	0:15	LINE FAULT
1141	19-Jul-2021	GULBARGA	110	YELBURGA-TALTSR	YELBURGA_110	11:42	12:46	1:04	LINE CLEAR AVAILED
1142	19-Jul-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:46	2:54	0:08	LINE FAULT
1143	19-Jul-2021	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	3:33	3:57	0:24	LINE FAULT
1144	19-Jul-2021	GULBARGA	110	HUMNABAD-MANEKHELI	MANEKHELI_110	3:43	3:57	0:14	LINE FAULT
1145	19-Jul-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	23:13	23:41	0:28	LINE FAULT
1146	19-Jul-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	17:00	18:25	1:25	LINE FAULT
1147	19-Jul-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	18:25	20:20	1:55	LINE CLEAR AVAILED
1148	19-Jul-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	14:35	16:15	1:40	LINE CLEAR AVAILED
1149	19-Jul-2021	GULBARGA	110	NALWAR-CLN SLR,WARDA SLR	NALWAR_110	14:35	16:15	1:40	LINE CLEAR AVAILED
1150	19-Jul-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	3:39	3:44	0:05	MAIN SUPPLY FAILURE
1151	19-Jul-2021	GULBARGA	110	LV2	HALBARGA_220	16:55	17:45	0:50	LINE CLEAR AVAILED
1152	19-Jul-2021	GULBARGA	110	HV3	HALBARGA_220	16:57	17:02	0:05	LINE CLEAR AVAILED
1153	19-Jul-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	3:30	3:38	0:08	LINE FAULT
1154	19-Jul-2021	GULBARGA	66	HV1	KOGALI_66	10:35	10:40	0:05	TRANSFORMER FAULT
1155	19-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1156	19-Jul-2021	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1157	19-Jul-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	20:00 (18.07.2021)	11:19 (19.07.2021)	15:19hrs	LINE CHARGED
1158	19-Jul-2021	HASSAN	66	HV2	MAGGE_66	10:08(14.7.2021)	14:32 (19.7.2021)	124:24hrs	TRANSFORMER CHARGED
1159	19-Jul-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:02	8:08	6:06	LINE CLEAR AVAILED
1160	19-Jul-2021	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	9:05	15:41	6:36	LINE CLEAR AVAILED
1161	19-Jul-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:28	12:38	2:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1162	19-Jul-2021	HASSAN	110	HV2	MSEZ_220	18:42	18:55	0:13	TRANSFORMER FAULT
1163	19-Jul-2021	HASSAN	220	SHRAVITY-SHIMOGA 2	sharavathy_gen	9:05	15:41	6:36	LINE CLEAR AVAILED
1164	19-Jul-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:03	12:39	2:36	NFBC ISSUED
1165	19-Jul-2021	HASSAN	110	HV3	BANTWAL_110	9:45	18:22	8:37	LINE CLEAR AVAILED
1166	19-Jul-2021	HASSAN	110	HV4	BANTWAL_110	9:45	18:22	8:37	LINE CLEAR AVAILED
1167	19-Jul-2021	HASSAN	110	HV2	HULICAL_110	16:06	16:50	0:44	LINE CLEAR AVAILED
1168	19-Jul-2021	HASSAN	110	HV1	KADUR_220	7:50	12:40	4:50	TRANSFORMER FAULT
1169	19-Jul-2021	HASSAN	110	HV1	KADUR_220	13:33	13:55	0:22	HAND TRIPPED
1170	19-Jul-2021	HASSAN	110	HV1	MANIPAL_110	9:36	11:12	1:36	LINE CLEAR AVAILED
1171	19-Jul-2021	HASSAN	110	HV2	NERALAKERE_110	6:33	8:49	2:16	TRANSFORMER FAULT
1172	19-Jul-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	20:30	20:50	0:20	LINE FAULT
1173	19-Jul-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	23:40	23:49	0:09	LINE FAULT
1174	19-Jul-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	18:09	19:09	1:00	HAND TRIPPED
1175	19-Jul-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	22:00	22:23	0:23	LINE FAULT
1176	19-Jul-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	9:22	9:40	0:18	LINE FAULT
1177	19-Jul-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	9:06	9:41	0:35	LINE FAULT
1178	19-Jul-2021	HASSAN	66	HV1	RAMPURA_66	16:35	16:55	0:20	LINE CLEAR AVAILED
1179	19-Jul-2021	HASSAN	66	SAKALE-HASSAN1	SAKLEDSPURA_66	9:20	9:48	0:28	LINE FAULT
1180	19-Jul-2021	HASSAN	66	SAKALE-HASSAN2	SAKLEDSPURA_66	9:20	9:40	0:20	MAIN SUPPLY FAILURE
1181	19-Jul-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATANAHALLY_66	17:55	18:15	0:20	LINE FAULT
1182	19-Jul-2021	MYSURU	66	HV1	CHANDAKAVADI-	18:08	18:23	0:15	TRANSFORMER FAULT
1183	19-Jul-2021	MYSURU	66	PERIAPATNA-HANGUD	POMMANPETE_66,VIRAJPETE_66 & HANGUD_66	3:44	8:43	4:59	LINE FAULT
1184	19-Jul-2021	MYSURU	66	PARINAMIPURA-TALKDU	THALAKADU_66, CHANDALLY_66	5:46	5:51	0:04	LINE FAULT
1185	19-Jul-2021	MYSURU	66	HEBBANI-VADKEPURA	VADKEPURA_66 , KIRUGAVALU_66 ,MALIYUR_66	13:33	13:40	0:07	LINE FAULT
1186	19-Jul-2021	MYSURU	66	HEBBANI-MEGHALAPURA	CHIDRAVALI_66,BG PURA_66,VYASRAJPURA_66,GARGESHWARI_66, THUMBALA_66	16:19	16:29	0:10	LINE FAULT
1187	19-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
1188	19-Jul-2021	TUMKUR	220	TR-2	ANTHRASANAHALI_220	15:18	17:01	1:43	LINE CLEAR AVAILED
1189	19-Jul-2021	TUMKUR	110	TR-2	HONNAVALI_110	1:15	1:25	0:10	TRANSFORMER FAULT
1190	19-Jul-2021	TUMKUR	110	HONNAVALI 110-KADUR220(ARASEKERE)	HONNAVALI_110	1:10	1:25	0:14	LINE FAULT
1191	19-Jul-2021	TUMKUR	110	HONNAVALI 110-DMKURKE	DMKURKE_110	1:24	1:29	0:04	LINE FAULT
1192	19-Jul-2021	TUMKUR	66	ANTHRASANAHALI 220KV-KORA	KORA_66, THOVINAKERE_66	6:02	6:19	0:17	LINE FAULT
1193	19-Jul-2021	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALI_220	15:18	17:01	1:43	LINE CLEAR AVAILED
1194	19-Jul-2021	TUMKUR	66	CHITRADURGA 220kv-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA IPP_66	0:04	0:54	0:49	HAND TRIPPED
1195	19-Jul-2021	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	0:10	0:47	0:37	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON	
1196	19-Jul-2021	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	1:50	2:02	0:12	LINE FAULT	
1197	19-Jul-2021	TUMKUR	66	TR-2	GUTTUR_66	9:26	9:37	0:11	TRANSFORMER FAULT	
1198	19-Jul-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	6:45	6:55	0:10	TRANSFORMER FAULT	
1199	19-Jul-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:20	15:33	0:13	HAND TRIPPED	
1200	19-Jul-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	14:57	15:01	0:03	LINE FAULT	
1201	19-Jul-2021	TUMKUR	66	KORA- ANTHRASANAHALLI	KADEHALLI_110	6:02	6:42	0:40	MAIN SUPPLY FAILURE	
1202	19-Jul-2021	TUMKUR	66	TR-1	KEREBILCHI_66	17:40	17:44	0:03	TRANSFORMER FAULT	
1203	19-Jul-2021	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA	KALLAMBELLA_66, SIRA_66	10:27	10:37	0:09	LINE FAULT	
1204	19-Jul-2021	TUMKUR	66	TR-1	MADADAKERE_66	15:43	17:55	2:12	LINE CLEAR AVAILED	
1205	19-Jul-2021	TUMKUR	66	TR-2	MADADAKERE_66	15:43	17:55	2:11	LINE CLEAR AVAILED	
1206	19-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_66	10:24	10:31	0:07	TRANSFORMER FAULT	
1207	19-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_66	19:01	19:10	0:09	TRANSFORMER FAULT	
1208	19-Jul-2021	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	9:45	9:57	0:12	TRANSFORMER FAULT	
1209	19-Jul-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	THALLAK 220kV	9:45	10:12	0:26	LINE FAULT	
1210	19-Jul-2021	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	CHALLAKERE_66, SANIKERE_66	9:45	9:59	0:13	LINE FAULT	
1211	19-Jul-2021	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP 66	MYLANAHALLI_66, DYAVARANAHALLI_66	9:45	10:03	0:17	LINE FAULT	
1212	19-Jul-2021	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND IPP 66	DIAMOND_IPP_66	9:45	10:04	0:18	LINE FAULT	
1213	19-Jul-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:45	10:05	0:19	LINE FAULT	
1214	19-Jul-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	9:45	10:06	0:20	LINE FAULT	
1215	19-Jul-2021	TUMKUR	66	THALLAK 220kV- THALLAK	SEI VENUS DIAMOND_IPP_66	9:45	10:11	0:25	LINE FAULT	