

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 21.07.2020 TO 22.7.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	21-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
2	21-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
3	21-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
4	21-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
5	21-Jul-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
6	21-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
7	21-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
8	21-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
9	21-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
10	21-Jul-2020	BAGALKOT	220	GUTTUR- RANEENNUR	STATION NOT AFFECTED RANEENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
11	21-Jul-2020	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:48 (13.07.02020)			LINE OPEN ,LINE CLEAR AVAILED
12	21-Jul-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:38 (15.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
13	21-Jul-2020	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	17:39 (15.07.2020)	18:25 (21.07.2020)	144:45hrs	LINE CHARGED
14	21-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:40 (15.07.2020)			LINE OPEN ,LINE FAULT
15	21-Jul-2020	BAGALKOT	220	HARTI1&2- GADAG	GADAG_220	19:59 (15.07.2020)			LOAD CURTAILMENT
16	21-Jul-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	BAGEWADI_220	11:02 (16.07.2020)			LOAD CURTAILMENT
17	21-Jul-2020	BAGALKOT	110	JAMBAGI-MUDHOL	STATION NOT AFFECTED MUDHOL_110	12:08 (17.07.2020)			LINE OPEN ,LINE FAULT
18	21-Jul-2020	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
19	21-Jul-2020	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN ,LINE CLEAR AVAILED
20	21-Jul-2020	BAGALKOT	220	BELGUAM220-CHIKKODI2	BELGAUM_220	(20.07.2020 15:54)	10:34 (21.07.2020)	18:40hrs	LINE CHARGED
21	21-Jul-2020	BAGALKOT	110	HAVERI 1-GUTTAL	STATION NOT AFFECTED GUTTAL_110	16:40 (20.07.2020)	12:02 (21.07.2020)	7:20hrs	LINE CHARGED
22	21-Jul-2020	BAGALKOT	110	ITNAL-HIDAKAL	HIDAKAL_110	18:05 (20.07.2020)	18:27 (21.02.2020)	24:22hrs	LINE CHARGED
23	21-Jul-2020	BAGALKOT	220	SIRSI220-UMMACHAGI	UMMACHAGI_110	11:29 (20.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
24	21-Jul-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	21:38 (20.07.2020)	07:03 (21.07.2020)	9:25hrs	TRANSFORMER CHARGED
25	21-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:56 (20.02.2020)			LINE OPEN ,LINE CLEAR AVAILED
26	21-Jul-2020	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:02	18:27	1:25	LINE CLEAR AVAILED
27	21-Jul-2020	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	9:30	11:17	1:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
28	21-Jul-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	6:55	7:00	0:05	LINE FAULT
29	21-Jul-2020	BAGALKOT	110	BAGEWADI-SINDAGI	SINDAGI_110	19:30	19:42	0:12	LINE FAULT
30	21-Jul-2020	BAGALKOT	220	220/11KV,HV2 & LV2	CHIKKODI_220	10:28	12:06	1:38	LINE CLEAR AVAILED
31	21-Jul-2020	BAGALKOT	110	110/11KV, HV1 & HV2	DAVALESHWAR_110	6:56	13:44	6:48	LINE CLEAR AVAILED
32	21-Jul-2020	BAGALKOT	110	110/11KV, HV4	GOPANAKOPPA	10:51	12:12	1:21	LINE CLEAR AVAILED
33	21-Jul-2020	BAGALKOT	110	ZALKI- CHADCHAN	CHADCHAN_110	5:52	7:23	1:31	LINE CLEAR AVAILED
34	21-Jul-2020	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	7:01	7:04	0:03	HAND TRIPPED
35	21-Jul-2020	BAGALKOT	110	ESALE1&2 (SIRSI220)_ SIRSI	SIRSI_110	10:17	11:23	1:06	LINE CLEAR AVAILED
36	21-Jul-2020	BAGALKOT	220	NAGJHARI1&2- HUBLI	HUBLI_220	9:13	16:17	7:04	LINE CLEAR AVAILED
37	21-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	12:38 (21.07.2020)			LINE OPEN ,LINE FAULT
38	21-Jul-2020	BAGALKOT	110	110/11KV, HV1	MUNAVALLI_110	17:10	18:10	1:00	LINE CLEAR AVAILED
39	21-Jul-2020	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIEREBAGEWADI_110	0:04	0:15	0:11	HAND TRIPPED
40	21-Jul-2020	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	0:18	6:07	5:49	HAND TRIPPED
41	21-Jul-2020	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	11:47	13:06	1:19	LINE CLEAR AVAILED
42	21-Jul-2020	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	14:28	16:44	2:16	LINE CLEAR AVAILED
43	21-Jul-2020	BAGALKOT	110	MAY FAIR SOLAR-HIREHAL	HIREHAL_110	18:51	19:34	0:43	LINE CLEAR AVAILED
44	21-Jul-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	13:42	14:17	0:35	LINE CLEAR AVAILED
45	21-Jul-2020	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	6:31	7:07	0:36	LINE FAULT
46	21-Jul-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	12:05	15:34	3:29	HAND TRIPPED
47	21-Jul-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
48	21-Jul-2020	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	19:30	20:00	00:30	MAIN SUPPLY FAILURE
49	21-Jul-2020	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	12:20	12:38	00:18	MAIN SUPPLY FAILURE
50	21-Jul-2020	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	12:20	12:38	00:18	MAIN SUPPLY FAILURE
51	21-Jul-2020	BENGALURU	66	GOKULA - MATHIKERE	MATHIKERE	12:20	12:38	00:18	MAIN SUPPLY FAILURE
52	21-Jul-2020	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	12:20	12:38	00:18	MAIN SUPPLY FAILURE
53	21-Jul-2020	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	13:45	13:49	00:04	LOAD CHANGE OVER
54	21-Jul-2020	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	14:04	14:08	00:04	LOAD CHANGE OVER
55	21-Jul-2020	BENGALURU	66	SRS PEENYA 220 - GOKULA 1 & 2	NO STATION AFFECTED	12:31	13:35	01:04	LINE FAULT
56	21-Jul-2020	BENGALURU	66	HSR LAYOUT 220 - SHOBHA CITY	SHOBHA CITY	16:31	16:41	00:10	LINE CLEAR AVAILED
57	21-Jul-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	06:23	06:31	00:08	LINE FAULT
58	21-Jul-2020	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	13:55	13:57	00:02	LOAD CHANGE OVER
59	21-Jul-2020	BENGALURU	220	HV3	SUBRAMANYAPURA 220	19:29	20:14	00:45	TRANSFORMER FAULT
60	21-Jul-2020	BENGALURU	66	HV1	VIJAYANAGARA	13:25	13:32	00:07	LOAD CHANGE OVER
61	21-Jul-2020	BENGALURU	66	HV1	SHAMARAJU TECH PARK	11:57	12:22	00:25	TRANSFORMER FAULT
62	21-Jul-2020	BENGALURU	66	R R NAGAR - SUBRAMANYAPURA 220	R R NAGAR	19:28	19:55	00:27	MAIN SUPPLY FAILURE
63	21-Jul-2020	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	08:27	09:05	00:38	LINE CLEAR AVAILED
64	21-Jul-2020	BENGALURU	66	HOSKOTE 220 - BOODIGERE	BOODIGERE	00:00	00:12	00:11	LINE FAULT
65	21-Jul-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	17:46	17:50	00:04	LINE FAULT
66	21-Jul-2020	BENGALURU	66	HV1	BAIRAKURU	13:28	13:40	00:12	LINE CLEAR AVAILED
67	21-Jul-2020	BENGALURU	66	HV1	BAIRAKURU	13:44	13:54	00:09	LINE CLEAR AVAILED
68	21-Jul-2020	BENGALURU	66	HV2	BAIRAKURU	14:46	15:04	00:17	LINE CLEAR AVAILED
69	21-Jul-2020	BENGALURU	66	HV1	CHAKAVELU	09:58	11:12	01:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
70	21-Jul-2020	BENGALURU	66	HV1	DOMMASANDRA	16:50	16:59	00:09	LINE CLEAR AVAILED
71	21-Jul-2020	BENGALURU	66	HV1	HOSPALYA CIRCLE	01:47	02:05	00:18	TRANSFORMER FAULT
72	21-Jul-2020	BENGALURU	66	HV1	HOSPALYA CIRCLE	09:42	09:50	00:08	TRANSFORMER FAULT
73	21-Jul-2020	BENGALURU	66	HV2	JIGANI LINK ROAD	14:48	15:39	00:50	LINE CLEAR AVAILED
74	21-Jul-2020	BENGALURU	66	HV2	KUNDANA	15:46	17:36	01:50	LINE CLEAR AVAILED
75	21-Jul-2020	BENGALURU	66	HV1	MALLASANDRA	15:01	15:45	00:43	LINE CLEAR AVAILED
76	21-Jul-2020	BENGALURU	66	HV1	NANGALI	10:43	11:30	00:46	LINE CLEAR AVAILED
77	21-Jul-2020	BENGALURU	66	HV2	NANGALI	12:46	14:22	01:35	LINE CLEAR AVAILED
78	21-Jul-2020	BENGALURU	66	HV2	THAYALUR	13:14	13:29	00:14	TRANSFORMER FAULT
79	21-Jul-2020	BENGALURU	66	HV1	VIJAYANAGARA	22:34(20/07/2020)	13:15(21/07/2020)	14:41hrs	TRANSFORMER CHARGED
80	21-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			LINE OPEN ,LINE CLEAR AVAILED
81	21-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN ,LINE FAULT
82	21-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
83	21-Jul-2020	BENGALURU	66	NIMHANS 220 - BMT	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN ,LINE FAULT
84	21-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN ,LINE FAULT
85	21-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
86	21-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN ,LINE CLEAR AVAILED
87	21-Jul-2020	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	20:35(17.7.2020)			LINE OPEN ,LINE FAULT
88	21-Jul-2020	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	11:21	11:43	00:22	LINE FAULT
89	21-Jul-2020	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	12:55	15:44	02:49	NFBC ISSUED
90	21-Jul-2020	GULBARGA	220	HV1	KUSTAGI_220	10:10	10:20	00:10	TRANSFORMER FAULT
91	21-Jul-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	03:43	03:54	00:11	LINE FAULT
92	21-Jul-2020	GULBARGA	220	RTPS-RAICHUR1	RAICHUR_220	14:44	15:30	00:46	LINE FAULT
93	21-Jul-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	11:20	11:45	00:25	LINE FAULT
94	21-Jul-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	12:05	15:47	03:42	LINE FAULT
95	21-Jul-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	5:30(20.07.2020)	15:53(21.07.2020)	34:23HRS	LINE CHARGED
96	21-Jul-2020	GULBARGA	110	CHITAGUPPA-ACMESLR_IPP	CHITAGUPPA_110	12:30	14:45	02:15	LINE CLEAR AVAILED
97	21-Jul-2020	GULBARGA	110	HV1	KOLHAR_110	13:20	16:18	02:58	TRANSFORMER OPEN,LINE CLEAR AVAILED
98	21-Jul-2020	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSWA TERWORKS	04:10	04:45	00:35	LINE FAULT
99	21-Jul-2020	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	05:25	06:15	00:50	LINE FAULT
100	21-Jul-2020	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSWA TERWORKS	10:15	10:25	00:10	LINE FAULT
101	21-Jul-2020	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	07:28	07:48	00:20	LINE FAULT
102	21-Jul-2020	GULBARGA	110	HV3	BEVOOR_110	16:05	16:40	00:35	LINE CLEAR AVAILED
103	21-Jul-2020	GULBARGA	110	SIDHANOOR220-SIRUGUPPA	SIRUGUPPA_110,DHADESUGUR_110,T EKKALKOTE_110,NSLSUGAR-IPP	20:20	20:30	00:10	LINE FAULT
104	21-Jul-2020	GULBARGA	110	SIDHANOOR220-SINDHANOOR1	MASKI_110,MUDDAPUR_110	21:05	21:15	00:10	LINE FAULT
105	21-Jul-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSWA TERWORKS	21:15	21:25	00:10	LINE FAULT
106	21-Jul-2020	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	22:20	22:30	00:10	LINE FAULT
107	21-Jul-2020	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	18:55	19:00	00:05	HAND TRIPPED
108	21-Jul-2020	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	05:25	05:35	00:10	LINE FAULT
109	21-Jul-2020	GULBARGA	110	MALLAT-MADLAPUR	MADALAPUR_110,MANVI_110	19:03	19:13	00:10	LINE FAULT
110	21-Jul-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	23:10	23:29	00:19	LINE FAULT
111	21-Jul-2020	GULBARGA	110	MALLAT-MADLAPUR	MADALAPUR_110,MANVI_110	05:32	05:42	00:10	LINE FAULT
112	21-Jul-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	18:04	18:28	00:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
113	21-Jul-2020	GULBARGA	110	HV1	RAJESHWAR_110	12:50	14:05	01:15	LINE CLEAR AVAILED
114	21-Jul-2020	GULBARGA	110	HV2	RAJESHWAR_110	14:08	16:00	01:52	LINE CLEAR AVAILED
115	21-Jul-2020	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110, MANTHAL_110	15:02	15:27	00:25	LINE CLEAR AVAILED
116	21-Jul-2020	GULBARGA	110	RAJESHWAR-SASTHAPUR	SASTHAPUR_110, MANTHAL_110	16:20	16:33	00:13	LINE CLEAR AVAILED
117	21-Jul-2020	GULBARGA	66	HV1	KUDLIGI_66	15:42	16:20	00:38	LINE CLEAR AVAILED
118	21-Jul-2020	GULBARGA	66	HV1	KOTTUR_66	17:37	17:46	00:09	TRANSFORMER FAULT
119	21-Jul-2020	GULBARGA	66	HOSAHALLI-SML_WIND_IPP	HOSAHALLI_66	08:13	08:29	00:16	LINE FAULT
120	21-Jul-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	17:32 (16.07.2020)	16:13 (21.07.020)	118:40 hrs	LINE CHARGED
121	21-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:19 (20.07.2020)	7:36 (21.07.2020)	7:56 hrs	LINE CHARGED
122	21-Jul-2020	HASSAN	66	UDDURKO-SUZLON	UDDURKOPLU_66	11:30(20.07.2020)	14:46 (21.07.2020)	23:59 hrs	LINE CHARGED
123	21-Jul-2020	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	16:06 (18.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
124	21-Jul-2020	HASSAN	220	HV2	HOLENARASIPURA_220	16:52 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
125	21-Jul-2020	HASSAN	66	Lv2	HOLENARASIPURA_220	16:52 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
126	21-Jul-2020	HASSAN	220	HV2	HASSAN_220	10:29	14:29	04:00	LINE CLEAR AVAILED
127	21-Jul-2020	HASSAN	220	HASSN220-NITTUR	HASSAN_220	10:40	13:50	03:10	LINE CLEAR AVAILED
128	21-Jul-2020	HASSAN	220	HASSN220-CHKMGLRE	HASSAN_220	11:36	13:49	02:13	MAIN SUPPLY FAILURE
129	21-Jul-2020	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	10:10	15:17	05:07	LINE CLEAR AVAILED
130	21-Jul-2020	HASSAN	66	HASSN220-BELUR	HASSAN_220	10:17	10:19	00:02	HAND TRIPPED
131	21-Jul-2020	HASSAN	66	HASSN220-CHIKAMAGLUR2	HASSAN_220	11:36	12:28	00:52	MAIN SUPPLY FAILURE
132	21-Jul-2020	HASSAN	66	HASSN220-HSN66	HASSAN_220	09:43	09:48	00:05	HAND TRIPPED
133	21-Jul-2020	HASSAN	66	HASSN220-HSN66	HASSAN_220	11:36	12:00	00:24	MAIN SUPPLY FAILURE
134	21-Jul-2020	HASSAN	66	HASSN220-HSN66	HASSAN_220	14:30	14:36	00:06	HAND TRIPPED
135	21-Jul-2020	HASSAN	66	LV2	HASSAN_220	10:29	14:36	04:07	LINE CLEAR AVAILED
136	21-Jul-2020	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	10:10	10:19	00:09	HAND TRIPPED
137	21-Jul-2020	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	11:36	12:15	00:39	MAIN SUPPLY FAILURE
138	21-Jul-2020	HASSAN	66	HASSN220-SKPURA	HASSAN_220	11:36	12:03	00:27	MAIN SUPPLY FAILURE
139	21-Jul-2020	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	14:40	14:46	00:06	HAND TRIPPED
140	21-Jul-2020	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	17:00	17:27	00:27	HAND TRIPPED
141	21-Jul-2020	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	17:00	17:27	00:27	HAND TRIPPED
142	21-Jul-2020	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	17:36	20:58	03:22	MAIN SUPPLY FAILURE
143	21-Jul-2020	HASSAN	66	HV1	HOLENARASIPURA_220	17:49	20:38	02:49	HAND TRIPPED
144	21-Jul-2020	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	17:41	17:46	00:05	HAND TRIPPED
145	21-Jul-2020	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	16:59	17:44	00:45	MAIN SUPPLY FAILURE
146	21-Jul-2020	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	16:52	17:44	00:52	MAIN SUPPLY FAILURE
147	21-Jul-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	01:50	09:47	07:57	LINE FAULT
148	21-Jul-2020	HASSAN	220	MRSSHM-CHKMGLRE	MRSMSG_220	11:36	11:57	00:21	LINE FAULT
149	21-Jul-2020	HASSAN	110	HV5	MRSMSG_220	10:54	12:28	01:34	HAND TRIPPED
150	21-Jul-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	01:49	09:47	07:58	LINE FAULT
151	21-Jul-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	09:51	09:58	00:07	HAND TRIPPED
152	21-Jul-2020	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	10:09	10:21	00:12	LINE FAULT
153	21-Jul-2020	HASSAN	110	HV3	HIRIYADKA_110	10:05	12:15	02:10	LINE CLEAR AVAILED
154	21-Jul-2020	HASSAN	110	HV1	HOSANGADI_110	09:59	13:00	03:01	LINE CLEAR AVAILED
155	21-Jul-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	09:54	13:08	03:14	LINE CLEAR AVAILED
156	21-Jul-2020	HASSAN	110	KEMAR-MOODAB	KEMAR_220	11:54	14:12	02:18	LINE CLEAR AVAILED
157	21-Jul-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	11:48	11:53	00:05	HAND TRIPPED
158	21-Jul-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	13:14	13:18	00:04	HAND TRIPPED
159	21-Jul-2020	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	11:54	13:11	01:17	NFBC ISSUED
160	21-Jul-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	16:03	16:13	00:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
161	21-Jul-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:30	15:48	02:18	LINE CLEAR AVAILED
162	21-Jul-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:25	12:30	01:05	NFBC ISSUED
163	21-Jul-2020	HASSAN	66	HV1	ALDUR_66	11:40	12:05	00:25	HAND TRIPPED
164	21-Jul-2020	HASSAN	66	HV4	BALEHONNUR_66	17:25	17:26	00:01	HAND TRIPPED
165	21-Jul-2020	HASSAN	66	HV4	BALEHONNUR_66	17:50	18:43	00:53	HAND TRIPPED
166	21-Jul-2020	HASSAN	66	HV1	DODDAKADANUR_66	15:53	16:36	00:43	LINE CLEAR AVAILED
167	21-Jul-2020	HASSAN	66	HV1	GANGUR_66	13:45	14:20	00:35	LINE CLEAR AVAILED
168	21-Jul-2020	HASSAN	66	HV1	HALLIMYSORE_66	17:40	17:45	00:05	MAIN SUPPLY FAILURE
169	21-Jul-2020	HASSAN	66	HV1	HNPURA_66	16:53	17:40	00:47	MAIN SUPPLY FAILURE
170	21-Jul-2020	HASSAN	66	HV2	HNPURA_66	16:53	17:40	00:47	MAIN SUPPLY FAILURE
171	21-Jul-2020	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	16:53	17:40	00:47	MAIN SUPPLY FAILURE
172	21-Jul-2020	HASSAN	66	HV1	MAGGE_66	11:35	12:05	00:30	MAIN SUPPLY FAILURE
173	21-Jul-2020	HASSAN	66	HV2	MAGGE_66	11:35	12:05	00:30	MAIN SUPPLY FAILURE
174	21-Jul-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	17:02	17:33	00:31	MAIN SUPPLY FAILURE
175	21-Jul-2020	HASSAN	66	HV1	MALALI_66	17:01	17:33	00:32	MAIN SUPPLY FAILURE
176	21-Jul-2020	HASSAN	66	HV2	MATTAVALI_66	13:48	14:46	00:58	LINE CLEAR AVAILED
177	21-Jul-2020	HASSAN	66	HV2	RAMNATHPURA_66	10:51	17:59	07:08	LINE CLEAR AVAILED
178	21-Jul-2020	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	18:20	18:30	00:10	HAND TRIPPED
179	21-Jul-2020	HASSAN	66	HV2	RAMPURA_66	16:00	17:44	01:44	LINE CLEAR AVAILED
180	21-Jul-2020	MYSURU	220	CR NAGARA-MADHUVANAHALLI 2	NO STATIONS EFFECTED	15:19	15:35	0:15	LINE FAULT
181	21-Jul-2020	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	2:35	2:45	0:09	LINE FAULT
182	21-Jul-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	2:35	2:44	0:08	LINE FAULT
183	21-Jul-2020	MYSURU	66	HD KOTE-TARAKA	ANTHARSANTHE_66	19:08	19:18	0:09	LINE FAULT
184	21-Jul-2020	MYSURU	220	KADAKOLA-BASTIPURA 1	NO STATIONS EFFECTED	10:18	17:25	7:07	NFBC ISSUED
185	21-Jul-2020	MYSURU	66	KUSHALNAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66	10:59	12:46	1:46	LINE CLEAR AVAILED
186	21-Jul-2020	MYSURU	66	HV1	PANDAVAPURA_66	10:32	10:40	0:08	HAND TRIPPED
187	21-Jul-2020	MYSURU	66	PIRYAPATNA-HANAGODU	HANAGODU_66 PONNAMPET_66	9:31	9:44	0:13	LINE FAULT
188	21-Jul-2020	MYSURU	66	SHANIVARSANTHE-YESSLUR	NO STATIONS EFFECTED	10:49	15:46	4:56	LINE CLEAR AVAILED
189	21-Jul-2020	MYSURU	66	HV2	THALAKADU_66	8:14	8:45	0:30	LINE CLEAR AVAILED
190	21-Jul-2020	MYSURU	66	HV1	TARIPURA_66	12:45	14:15	1:29	TRANSFORMER FAULT
191	21-Jul-2020	MYSURU	66	TUBINKERE-MC-2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	6:02	6:10	0:08	LINE FAULT
192	21-Jul-2020	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	6:02	6:10	0:08	LINE FAULT
193	21-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
194	21-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN ,LINE FAULT
195	21-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
196	21-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
197	21-Jul-2020	TUMKUR	110	TR-1	KGTEMPLE_110	11:58	12:28	0:30	LINE CLEAR AVAILED
198	21-Jul-2020	TUMKUR	110	TR-1	TALKERE_110	12:33	13:38	1:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
199	21-Jul-2020	TUMKUR	220	TR-3	DAVANGERE_SRS_220	13:34	16:15	2:40	LINE CLEAR AVAILED
200	21-Jul-2020	TUMKUR	66	TR-1	BADAVANAHALLI_66	16:04	17:00	0:56	LINE CLEAR AVAILED
201	21-Jul-2020	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:48	12:04	0:16	HAND TRIPPED
202	21-Jul-2020	TUMKUR	66	TR-2	DAVANGERE_SRS_220	11:57	12:09	0:12	HAND TRIPPED
203	21-Jul-2020	TUMKUR	66	TR-3	DAVANGERE_SRS_220	13:34	16:16	2:41	HAND TRIPPED
204	21-Jul-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:09	10:32	0:23	HAND TRIPPED
205	21-Jul-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:09	12:28	2:19	HAND TRIPPED
206	21-Jul-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:12	6:25	0:12	HAND TRIPPED
207	21-Jul-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:48	12:15	0:27	HAND TRIPPED
208	21-Jul-2020	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJHALLI_66	12:38	12:46	0:07	HAND TRIPPED
209	21-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:46	13:00	0:13	LINE FAULT
210	21-Jul-2020	TUMKUR	66	TR-2	HOLALKERE_66	15:28	15:34	0:05	TRANSFORMER FAULT
211	21-Jul-2020	TUMKUR	66	TR-2	KOLALA_66	19:04	19:20	0:16	HAND TRIPPED
212	21-Jul-2020	TUMKUR	66	TR-1	MADHUGIRI_220	11:37	11:40	0:03	LINE CLEAR AVAILED
213	21-Jul-2020	TUMKUR	66	TR-2	MANGALWADA_66	17:11	17:16	0:04	TRANSFORMER FAULT
214	21-Jul-2020	TUMKUR	66	TR-1	NAGALMADIKE_66	15:01	15:18	0:16	LINE CLEAR AVAILED
215	21-Jul-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	16:46	16:52	0:05	LINE CLEAR AVAILED
216	21-Jul-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	8:01	17:33	9:32	HAND TRIPPED
217	21-Jul-2020	TUMKUR	66	SASALUHALLA-CKJRKUTT	SASALUHALLA_66	1:23	1:31	0:08	MAIN SUPPLY FAILURE
218	21-Jul-2020	TUMKUR	66	SASALUHALLA-CKJRKUTT	SASALUHALLA_66	6:02	6:58	0:55	MAIN SUPPLY FAILURE
219	21-Jul-2020	TUMKUR	66	SASALUHALLA-MAYAKONDA	MAYAKONDA_66	6:08	19:07	12:58	HAND TRIPPED
220	21-Jul-2020	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	19:08	20:04	0:55	LINE FAULT
221	22-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
222	22-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
223	22-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
224	22-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
225	22-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
226	22-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
227	22-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)	10:41 (22.07.2020)	641:55hrs	LINE CHARGED
228	22-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
229	22-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
230	22-Jul-2020	BAGALKOT	220	GUTTUR- RANEENNUR	STATION NOT AFFECTED RANEENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
231	22-Jul-2020	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:48 (13.07.02020)			LINE OPEN ,LINE CLEAR AVAILED
232	22-Jul-2020	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	17:38 (15.07.2020)	14:45 (22.07.2020)	165:07hrs	LINE CHARGED
233	22-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:40 (15.07.2020)			LINE OPEN ,LINE FAULT
234	22-Jul-2020	BAGALKOT	220	HARTI1&2- GADAG	STATION NOT AFFECTED GADAG_220	19:59 (15.07.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
235	22-Jul-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI 220	11:02 (16.07.2020)			LOAD CURTAILMENT
236	22-Jul-2020	BAGALKOT	110	JAMBAGI-MUDHOL	STATION NOT AFFECTED MUDHOL 110	12:08 (17.07.2020)	14:28 (22.07.2020)	122:20hrs	LINE CHARGED
237	22-Jul-2020	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD 110	7:40 19.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
238	22-Jul-2020	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	18:46 (19.07.0.2020			LINE OPEN ,LINE CLEAR AVAILED
239	22-Jul-2020	BAGALKOT	220	SIRSI220-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI 110	11:29 (20.07.2020)	10:40 (22.07.2020)	47:11hrs	LINE CHARGED
240	22-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM 110	18:56 (20.02.2020)			LINE OPEN ,LINE CLEAR AVAILED
241	22-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	12:38 (21.07.2020)			LINE OPEN ,LINE FAULT
242	22-Jul-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:0 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
243	22-Jul-2020	BAGALKOT	110	110/33KV,HV2	ATHANI_110 & JAMBAGI,MURAGUNDI 33	13:54	14:03	0:09	TRANSFORMER FAULT
244	22-Jul-2020	BAGALKOT	110	110/33KV,HV2	ATHANI_110 & JAMBAGI,MURAGUNDI 33	16:14	16:40	0:26	LINE CLEAR AVAILED
245	22-Jul-2020	BAGALKOT	110	110/33KV,HV2	ATHANI_110 & JAMBAGI,MURAGUNDI 33	16:54	17:13	0:19	TRANSFORMER FAULT
246	22-Jul-2020	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	15:43	16:52	1:09	LINE CLEAR AVAILED
247	22-Jul-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	11:52	12:21	0:29	LINE CLEAR AVAILED
248	22-Jul-2020	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	16:51	17:59	1:08	LINE CLEAR AVAILED
249	22-Jul-2020	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	13:06	13:25	0:19	LINE CLEAR AVAILED
250	22-Jul-2020	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	20:55	21:12	0:17	MAIN SUPPLY FAILURE
251	22-Jul-2020	BAGALKOT	110	BELGAUM-HUKKERI	HUKKERI_110	7:48	8:08	0:20	LINE FAULT
252	22-Jul-2020	BAGALKOT	110	BELGAUM-ANKALAGI	ANKALAGI_110	7:48	8:06	0:18	LINE FAULT
253	22-Jul-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM 220	11:27 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
254	22-Jul-2020	BAGALKOT	220	220/110KV,HV2	MAHALINGAPUR_220	19:43	21:04	1:21	TRANSFORMER FAULT
255	22-Jul-2020	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220,BANAHATTI_11 ODAVALESHWAR_110,TERDAL_110,RA BAKAVI_110,GSML1_110	23:54 (22.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
256	22-Jul-2020	BAGALKOT	220	220/110KV,HV3	MAHALINGAPUR_220	1:48	2:38	0:50	TRANSFORMER FAULT
257	22-Jul-2020	BAGALKOT	110	MAHALINGAPUR-DAVALESHAWER	STATION NOT AFFECTED DAVALESHWER_110	20:54 (22.07.2020)			MAIN SUPPLY FAILURE
258	22-Jul-2020	BAGALKOT	110	ITNAL- HIDIKAL	STATION NOT AFFECTED HIDAKAL_110	00:40 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
259	22-Jul-2020	BAGALKOT	110	VAJJARMATTI220-JAMAKHANDI	JAMKHANDI_110	1:48	20:00	18:12	MAIN SUPPLY FAILURE
260	22-Jul-2020	BAGALKOT	110	MAHALIGAPUR(NAVALAGI)- JAMAKHANDI	STATION NOT AFFECTED JAMKHANDI_110	19:53 (22.07.2020)			MAIN SUPPLY FAILURE
261	22-Jul-2020	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	VAJRAMATTI_220	1:50	2:45	0:55	LINE FAULT
262	22-Jul-2020	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR2	VAJRAMATTI_220	1:50	2:46	0:56	LINE FAULT
263	22-Jul-2020	BAGALKOT	110	VAJRAMATTI220- KATARKI	KATARKI_110	2:08	2:46	0:38	HAND TRIPPED
264	22-Jul-2020	BAGALKOT	110	VAJRAMATTI220- MANTUR	MANTUR_110, SHIROL_110	2:09	2:46	0:37	HAND TRIPPED
265	22-Jul-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:55	13:28	0:33	LINE CLEAR AVAILED
266	22-Jul-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	13:33	14:24	0:51	TRANSFORMER FAULT
267	22-Jul-2020	BAGALKOT	110	RANEBENNUR- GUTTAL	GUTTAL_110	14:06	14:35	0:29	LINE FAULT
268	22-Jul-2020	BAGALKOT	110	110/33KV, HV2	MURDESHWAR_110,KASARKOD_33,BA TGAL 33	13:23	13:31	0:08	LINE CLEAR AVAILED
269	22-Jul-2020	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(G)_110	2:21	10:39	8:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
270	22-Jul-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	10:40 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
271	22-Jul-2020	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:45	14:42	2:57	LINE CLEAR AVAILED
272	22-Jul-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	17:02	18:34	01:32	LINE CLEAR AVAILED
273	22-Jul-2020	BENGALURU	66	HV1	BAIRAKURU	11:57	13:21	01:24	LINE CLEAR AVAILED
274	22-Jul-2020	BENGALURU	66	HV2	MELUR	12:44	12:50	00:05	LINE CLEAR AVAILED
275	22-Jul-2020	BENGALURU	66	HONNIGANAHALLI - KANAKAPURA 220	HONNIGANAHALLI	13:18	15:29	02:11	LINE CLEAR AVAILED
276	22-Jul-2020	BENGALURU	66	HV1	AMARJYOTHI	01:28	01:36	00:08	LOAD CHANGE OVER
277	22-Jul-2020	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	06:20	06:25	00:05	LOAD CHANGE OVER
278	22-Jul-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI	12:21	13:01	00:40	LINE FAULT
279	22-Jul-2020	BENGALURU	66	HV1	JAYANAGARA	10:52	10:55	00:03	LINE CLEAR AVAILED
280	22-Jul-2020	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	06:10	06:15	00:05	LOAD CHANGE OVER
281	22-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			LINE OPEN ,LINE CLEAR AVAILED
282	22-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN ,LINE FAULT
283	22-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
284	22-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN ,LINE FAULT
285	22-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN ,LINE FAULT
286	22-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
287	22-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN ,LINE CLEAR AVAILED
288	22-Jul-2020	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	20:35(17.7.2020)			LINE OPEN ,LINE FAULT
289	22-Jul-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	00:48	01:29	00:41	LINE FAULT
290	22-Jul-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	01:48	02:24	00:36	LINE FAULT
291	22-Jul-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	02:24	13:36	11:12	LINE CLEAR AVAILED
292	22-Jul-2020	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	11:56	12:24	00:28	LINE FAULT
293	22-Jul-2020	GULBARGA	220	RTPS-LINGASUGUR3	RTPS_220	02:20	13:30	11:10	LINE CLEAR AVAILED
294	22-Jul-2020	GULBARGA	220	ALIPUR-RAGALPADU	NEELGUNDA_220	20:47	21:43	00:56	LINE FAULT
295	22-Jul-2020	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	20:33	20:41	00:08	LINE FAULT
296	22-Jul-2020	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	05:30	05:35	00:05	LINE FAULT
297	22-Jul-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	00:25	00:42	00:17	LINE FAULT
298	22-Jul-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	05:12	05:18	00:06	LINE FAULT
299	22-Jul-2020	GULBARGA	110	HV1	PDHALLI_110	09:30	10:05	00:35	LINE CLEAR AVAILED
300	22-Jul-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTPSWA TERWORKS	02:05	02:15	00:10	LINE FAULT
301	22-Jul-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURUDI CROSS_110	05:45	05:55	00:10	LINE FAULT
302	22-Jul-2020	GULBARGA	110	HV2	YEDRAMI_110	14:00	14:05	00:05	TRANSFORMER FAULT
303	22-Jul-2020	GULBARGA	110	HV1	KEMBHAVI_110	08:25	09:15	00:50	LINE CLEAR AVAILED
304	22-Jul-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	19:22	19:38	00:16	LINE FAULT
305	22-Jul-2020	GULBARGA	110	SIDHANOOR220-NIRLOOTI	NIRLOOTI_110	22:43	23:03	00:20	LINE FAULT
306	22-Jul-2020	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	23:09	23:21	00:12	LINE FAULT
307	22-Jul-2020	GULBARGA	66	HV1	KOTTUR_66	15:30	15:35	00:05	TRANSFORMER FAULT
308	22-Jul-2020	GULBARGA	66	HV1	HANASI_66	17:18	17:39	00:21	TRANSFORMER FAULT
309	22-Jul-2020	GULBARGA	66	KUDLIGI-ITTAGI	KUDLIGI_66,KOGALI_66	21:45	22:15	00:30	MAIN SUPPLY FAILURE
310	22-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:06 (18.07.2020)	6:56(22.07.2020)	86:50hrs	LINE CHARGED
311	22-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:51 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
312	22-Jul-2020	HASSAN	220	HV2	HOLENARASIPURA_220	16:52 (21.07.2020)	12:52(22.07.2020)	19:00hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
313	22-Jul-2020	HASSAN	66	Lv2	HOLENARASIPURA_220	16:52 (21.07.2020)	12:52(22.07.2020)	19:00hrs	LINE CHARGED
314	22-Jul-2020	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	12:43	18:09	05:26	LINE FAULT
315	22-Jul-2020	HASSAN	220	KEMAR-Varahi1	KEMAR	15:38	16:18	00:40	LINE FAULT
316	22-Jul-2020	HASSAN	220	KEMAR-Varahi2	KEMAR	11:37	15:38	04:01	LINE FAULT
317	22-Jul-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	10:08	14:28	04:20	LINE CLEAR AVAIED
318	22-Jul-2020	HASSAN	220	MRSSHM-VARAH1	MRSSHM	09:13	11:33	02:20	LINE CLEAR AVAIED
319	22-Jul-2020	HASSAN	220	VARAH1-KEMAR1	varahi_gen	15:39	16:19	00:40	LINE FAULT
320	22-Jul-2020	HASSAN	220	VARAH1-KEMAR2	varahi_gen	11:37	13:17	01:40	LINE CLEAR AVAIED
321	22-Jul-2020	HASSAN	220	VARAH1-KEMAR2	varahi_gen	15:39	16:07	00:28	LINE FAULT
322	22-Jul-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	09:12	11:33	02:21	LINE CLEAR AVAIED
323	22-Jul-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR	12:43	14:45	02:02	LINE FAULT
324	22-Jul-2020	HASSAN	110	SHRLKP-BARANG	SHRLKP_220	10:23	11:29	01:06	LINE CLEAR AVAIED
325	22-Jul-2020	HASSAN	110	HV2	BARANGi_110	12:39	13:52	01:13	LINE CLEAR AVAIED
326	22-Jul-2020	HASSAN	110	HV1	BARANGi_110	10:35	12:35	02:00	LINE CLEAR AVAIED
327	22-Jul-2020	HASSAN	110	HV2	BIRUR_110	20:20	20:56	00:36	TRANSFORMER FAULT
328	22-Jul-2020	HASSAN	110	HV1	GANDASI_110	10:59	11:02	00:03	HAND TRIPPED
329	22-Jul-2020	HASSAN	110	HV2	GANDASI_110	10:59	11:02	00:03	HAND TRIPPED
330	22-Jul-2020	HASSAN	110	JOG-JLT3	mghejog_gen	10:34	12:39	02:05	LINE CLEAR AVAIED
331	22-Jul-2020	HASSAN	110	JOG-JLT4	mghejog_gen	10:34	15:11	04:37	LINE CLEAR AVAIED
332	22-Jul-2020	HASSAN	110	JOG-JST1	mghejog_gen	10:32	11:44	01:12	LINE CLEAR AVAIED
333	22-Jul-2020	HASSAN	110	JOG110-LPH	JOG_110	10:21	12:31	02:10	LINE CLEAR AVAIED
334	22-Jul-2020	HASSAN	110	KADUR-YGTI	KADUR_220	19:08	19:44	00:36	LINE FAULT
335	22-Jul-2020	HASSAN	110	HV1	SINGATGere_110	11:23	11:50	00:27	LINE CLEAR AVAIED
336	22-Jul-2020	HASSAN	110	SINGATG-YAGATI	SINGATGere_110	11:26	11:40	00:14	LINE CLEAR AVAIED
337	22-Jul-2020	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	12:58	13:12	00:14	HAND TRIPPED
338	22-Jul-2020	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	12:57	13:12	00:15	HAND TRIPPED
339	22-Jul-2020	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	12:58	13:12	00:14	HAND TRIPPED
340	22-Jul-2020	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	12:58	13:12	00:14	HAND TRIPPED
341	22-Jul-2020	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	13:18	13:24	00:06	HAND TRIPPED
342	22-Jul-2020	HASSAN	66	HV1	HOLENARASIPURA_220	11:56	13:13	01:17	LINE CLEAR AVAIED
343	22-Jul-2020	HASSAN	66	Lv1	HOLENARASIPURA_220	13:00	13:11	00:11	LINE CLEAR AVAIED
344	22-Jul-2020	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	12:58	13:12	00:14	HAND TRIPPED
345	22-Jul-2020	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	12:58	13:12	00:14	HAND TRIPPED
346	22-Jul-2020	HASSAN	66	MRSSHM-HOLUR	MRSSHM	12:43	12:50	00:07	LINE FAULT
347	22-Jul-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:02	13:25	00:23	MAIN SUPPLY FAILURE
348	22-Jul-2020	HASSAN	66	BANDISH-HNPURA	BANDISHETTIHALLY_66	15:50	16:40	00:50	LINE FAULT
349	22-Jul-2020	HASSAN	66	HV1	DODDAKADANUR_66	10:03	10:54	00:51	TRANSFORMER FAULT
350	22-Jul-2020	HASSAN	66	HV1	DODDAKADANUR_66	12:55	13:15	00:20	MAIN SUPPLY FAILURE
351	22-Jul-2020	HASSAN	66	HV1	HALEBEEDU_66	14:13	14:42	00:29	LINE CLEAR AVAIED
352	22-Jul-2020	HASSAN	66	HASSN220-BELUR	HASSAN_220	11:20	11:38	00:18	LINE CLEAR AVAIED
353	22-Jul-2020	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	11:05	14:38	03:33	LINE CLEAR AVAIED
354	22-Jul-2020	HASSAN	66	HV1	HNPURA_66	12:58	13:12	00:14	MAIN SUPPLY FAILURE
355	22-Jul-2020	HASSAN	66	HV2	HNPURA_66	12:58	13:12	00:14	MAIN SUPPLY FAILURE
356	22-Jul-2020	HASSAN	66	HV1	MALALI_66	13:00	13:15	00:15	MAIN SUPPLY FAILURE
357	22-Jul-2020	HASSAN	66	HV2	MATTANAVILE_66	12:17	13:03	00:46	TRANSFORMER FAULT
358	22-Jul-2020	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	15:50	16:36	00:46	LINE FAULT
359	22-Jul-2020	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	15:49	16:45	00:56	LINE FAULT
360	22-Jul-2020	HASSAN	66	SALAGAM-HIREMANGLUR	SALGAM_66	09:40	09:55	00:15	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
361	22-Jul-2020	HASSAN	66	SALAGAM-HIREMANGLUR	SALGAM_66	10:48	10:56	00:08	MAIN SUPPLY FAILURE
362	22-Jul-2020	HASSAN	66	SALAGAM-HIREMANGLUR	SALGAM_66	14:40	14:52	00:12	MAIN SUPPLY FAILURE
363	22-Jul-2020	HASSAN	66	SALAGAM-UDURKOPPLU	SALGAM_66	09:40	11:00	01:20	MAIN SUPPLY FAILURE
364	22-Jul-2020	HASSAN	66	HV2	UDAYAPURA_66	12:08	12:24	00:16	LINE CLEAR AVAILED
365	22-Jul-2020	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	09:40	11:00	01:20	HAND TRIPPED
366	22-Jul-2020	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	14:33	14:46	00:13	HAND TRIPPED
367	22-Jul-2020	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	11:15	14:40	03:25	NFBC ISSUED
368	22-Jul-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	11:15	14:41	03:26	NFBC ISSUED
369	22-Jul-2020	MYSURU	66	HV1	COWDALI_66	13:11	13:47	0:35	LINE CLEAR AVAILED
370	22-Jul-2020	MYSURU	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	10:11	10:57	0:46	LINE CLEAR AVAILED
371	22-Jul-2020	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	DUNDANAHALLI_66	12:38	12:46	0:08	LINE CLEAR AVAILED
372	22-Jul-2020	MYSURU	66	ELAVALA-HOOTAGALLI	ELAVALA_66	13:01	13:56	0:54	NFBC ISSUED
373	22-Jul-2020	MYSURU	66	ELAVALA-HUNSUR	GAVADAGERE_66	14:27	15:16	0:49	LINE CLEAR AVAILED
374	22-Jul-2020	MYSURU	66	HV2	ELAVALA_66	8:23	12:47	4:24	LINE CLEAR AVAILED
375	22-Jul-2020	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	18:27	19:52	1:25	LINE CLEAR AVAILED
376	22-Jul-2020	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	17:44	22:01	4:17	LINE FAULT
377	22-Jul-2020	MYSURU	66	HV1	KIKKERI_66	12:20	17:50	5:29	LINE CLEAR AVAILED
378	22-Jul-2020	MYSURU	66	HV2	KIKKERI_66	14:40	17:46	3:06	LINE CLEAR AVAILED
379	22-Jul-2020	MYSURU	66	HV3	KIKKERI_66	10:10	17:50	7:40	LINE CLEAR AVAILED
380	22-Jul-2020	MYSURU	66	KIRUGAVLU-MALIYUR	KIRUGAVALU_66 VADKEPURA_66	7:07	7:27	0:20	LINE FAULT
381	22-Jul-2020	MYSURU	66	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	14:09	14:47	0:38	NFBC ISSUED
382	22-Jul-2020	MYSURU	220	HV1	KUSHALNAGARA_220	10:52	11:02	0:10	TRANSFORMER FAULT
383	22-Jul-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	6:26	6:30	0:04	LINE FAULT
384	22-Jul-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	13:21	13:28	0:06	LINE FAULT
385	22-Jul-2020	MYSURU	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	6:29	6:40	0:11	LINE FAULT
386	22-Jul-2020	MYSURU	66	HV3	PONNAMPET_66	9:04	10:58	1:54	LINE CLEAR AVAILED
387	22-Jul-2020	MYSURU	66	HV1	PONNAMPET_66	11:08	11:17	0:09	LINE CLEAR AVAILED
388	22-Jul-2020	MYSURU	66	SHANIVARASANTHE-YESSLUR	NO STATIONS EFFECTED	11:32	11:40	0:08	LINE FAULT
389	22-Jul-2020	MYSURU	66	HV2	SANIVARASANTHE_66	11:25	11:40	0:15	TRANSFORMER FAULT
390	22-Jul-2020	MYSURU	66	HV1	TARIPURA_66	12:15	13:06	0:50	LINE CLEAR AVAILED
391	22-Jul-2020	MYSURU	66	THAYURU-TN PURA	TNARASIPURA_66	12:15	12:25	0:10	LINE FAULT
392	22-Jul-2020	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	8:27	8:33	0:06	LINE FAULT
393	22-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
394	22-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN ,LINE FAULT
395	22-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
396	22-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
397	22-Jul-2020	TUMKUR	220	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	23:26(22.07.2020)			LOAD CURTAILMENT
398	22-Jul-2020	TUMKUR	110	TR-1	BANDIHALLI_110	10:31	11:04	0:33	LINE CLEAR AVAILED
399	22-Jul-2020	TUMKUR	66	TR-1	BRAHMASANDRA_66	17:50	17:57	0:07	TRANSFORMER FAULT
400	22-Jul-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	18:43	19:05	0:21	LINE FAULT
401	22-Jul-2020	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	18:43	18:59	0:16	LINE FAULT
402	22-Jul-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	19:33	19:37	0:03	HAND TRIPPED
403	22-Jul-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	13:07	15:06	1:59	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
404	22-Jul-2020	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	11:38	11:44	0:05	LINE FAULT
405	22-Jul-2020	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	18:48	19:03	0:14	HAND TRIPPED
406	22-Jul-2020	TUMKUR	66	TR-2	LINGADAHALLY_66	10:51	11:07	0:16	HAND TRIPPED
407	22-Jul-2020	TUMKUR	66	THALLAK 220KV-GOWRASAMUDRA	CHALLAKERE_66, SANIKERE_66	15:33	17:25	1:51	LINE CLEAR AVAILED
408	23-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
409	23-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
410	23-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
411	23-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
412	23-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
413	23-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
414	23-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)	18:31 (23.07.2020)	666:11HRS	TRANSFORMER CHARGED
415	23-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)	11:29 (23.07.2020)	497:13HRS	LINE CHARGED
416	23-Jul-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)	12:06 (23.06.2020)	475:50HRS	LINE CHARGED
417	23-Jul-2020	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:48 (13.07.02020)			LINE OPEN ,LINE CLEAR AVAILED
418	23-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:40 (15.07.2020)	21:30 (23.07.2020)	195:50HRS	LINE CHARGED
419	23-Jul-2020	BAGALKOT	220	HARTI1&2- GADAG	STATION NOT AFFECTED GADAG_220	19:59 (15.07.2020)	12:42 (23.07.2020)	184:53HRS	LINE CHARGED
420	23-Jul-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	11:02 (16.07.2020)			LOAD CURTAILMENT
421	23-Jul-2020	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
422	23-Jul-2020	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN ,LINE CLEAR AVAILED
423	23-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:56 (20.02.2020)	10:10 (23.07.2020)	63:14HRS	LINE CHARGED
424	23-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	12:38 (21.07.2020)	21:29 (23.07.2020)	56:51HRS	LINE CHARGED
425	23-Jul-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
426	23-Jul-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	11:27 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
427	23-Jul-2020	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220,BANAHATTI_11 ODAVALESHWAR_110,TERDAL_110,RA BAKAVI_110,GSM1_110	23:54 (22.07.2020)	0:03 (23.07.2020)	0:09HRS	TRANSFORMER CHARGED
428	23-Jul-2020	BAGALKOT	110	MAHALINGAPUR-DAVALESHAWER	STATION NOT AFFECTED DAVALESHWER_110	20:54 (22.07.2020)	8:44 (23.07.2020)	11:50HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
429	23-Jul-2020	BAGALKOT	110	ITNAL- HIDIKAL	STATION NOT AFFECTED HIDAKAL_110	00:40 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
430	23-Jul-2020	BAGALKOT	110	MAHALIGAPUR(NAVALAGI)- JAMAKHANDI	STATION NOT AFFECTED JAMKHANDI_110	19:53 (22.07.2020)			LOAD CURTAILMENT
431	23-Jul-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	10:40 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
432	23-Jul-2020	BAGALKOT	110	110/11KV, HV1	ANANDANAGAR_110	11:33	13:03	1:30	LINE CLEAR AVAILED
433	23-Jul-2020	BAGALKOT	110	110/33KV, HV2	ANKOLA_110	10:25	10:37	0:12	TRANSFORMER FAULT
434	23-Jul-2020	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	STATION NOT EFFECTED BANAHATTI_110	1:19	7:11	5:52	MAIN SUPPLY FAILURE
435	23-Jul-2020	BAGALKOT	110	BELGAUM220-HUKKERI	HUKKERI_110	5:53	6:16	0:23	LINE FAULT
436	23-Jul-2020	BAGALKOT	110	BELGAUM220-HUKKERI	HUKKERI_110	5:53	6:30	0:37	LINE FAULT
437	23-Jul-2020	BAGALKOT	110	BELGAUM220-VADAGAON	VADAGAON_110	14:38	14:46	0:08	LINE FAULT
438	23-Jul-2020	BAGALKOT	110	BAGEWADI220- MAMADAPUR-1	MAMADAPUR_110	14:58	15:11	0:13	LINE FAULT
439	23-Jul-2020	BAGALKOT	110	BYADAGI-RANEENNUR	BYADAGI_110	11:28	12:51	1:23	HAND TRIPPED
440	23-Jul-2020	BAGALKOT	220	AMBEWADI220-XELDOM220	AMBEWADI_220	11:36	12:32	0:56	LINE FAULT
441	23-Jul-2020	BAGALKOT	110	GHATAPRABHA-HIDAKAL DAM	GHATAPRABHA_110	9:50	18:25	8:35	LINE CLEAR AVAILED
442	23-Jul-2020	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	14:38	14:51	0:13	LINE FAULT
443	23-Jul-2020	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	7:04	7:30	0:26	LINE FAULT
444	23-Jul-2020	BAGALKOT	220	VAJRAMATTI- KAVATAGI_LIS	VAJRAMATTI_220	10:35	17:04	6:29	LINE CLEAR AVAILED
445	23-Jul-2020	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	10:55 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
446	23-Jul-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	10:57	21:19	10:22	NFBC ISSUED
447	23-Jul-2020	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	21:29 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
448	23-Jul-2020	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	11:11	15:19	4:08	LINE CLEAR AVAILED
449	23-Jul-2020	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	11:09	15:20	4:11	LINE CLEAR AVAILED
450	23-Jul-2020	BAGALKOT	220	SHARAVATHI1&2-SIRSI	SIRSI_220	10:45	21:22	10:37	LINE CLEAR AVAILED
451	23-Jul-2020	BAGALKOT	220	220/110KV,HV1,LV1	SIRSI_220	10:49	21:24	10:35	LINE CLEAR AVAILED
452	23-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI_220	21:26 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
453	23-Jul-2020	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110	20:14	20:27	0:13	LINE FAULT
454	23-Jul-2020	BAGALKOT	110	VAJRAMATTI220-SHIRAGUPPI	SHIRAGUPPI_110	20:14	20:27	0:13	LINE FAULT
455	23-Jul-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	12:06	12:27	0:21	MAIN SUPPLY FAILURE
456	23-Jul-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI-220	0:03	7:02	6:59	HAND TRIPPED
457	23-Jul-2020	BAGALKOT	110	220/110KV,LV1	MK HUBLI-220	1:17	6:03	4:46	HAND TRIPPED
458	23-Jul-2020	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220,BANAHATTI_11 ODAVALESHWAR_110,TERDAL_110,RA BAKAVI_110,GSM11_110	0:26	1:46	1:20	TRANSFORMER FAULT
459	23-Jul-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINAGAD_33,KARA DI_33,MYTRA SOLAR_110	14:41	14:47	0:06	TRANSFORMER FAULT
460	23-Jul-2020	BAGALKOT	220	HAVERI-NARENDRA2	HAVERI_220	12:37	16:27	3:50	LINE CLEAR AVAILED
461	23-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:02 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
462	23-Jul-2020	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	10:10	18:01	7:51	NFBC ISSUED
463	23-Jul-2020	BAGALKOT	220	DHONI1&2-GADAG	STATION NOT AFFECTED GADAG_220	12:20 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
464	23-Jul-2020	BAGALKOT	220	HARTI1&2- GADAG	STATION NOT AFFECTED GADAG_220	13:08 (23.07.2020)			LOAD CURTAILMENT
465	23-Jul-2020	BAGALKOT	220	CHIKKODI-BELGAUM	CHIKKODI_220	11:08	13:37	2:29	LINE CLEAR AVAILED
466	23-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	19:15 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
467	23-Jul-2020	BAGALKOT	110	110/11KV,HV1&2	GHATAPRABHA_110	10:00	18:28	8:28	LINE CLEAR AVAILED
468	23-Jul-2020	BAGALKOT	110	110/33KV,HV1&2	GHATAPRABHA_110,MANTUR_33	10:00	18:08	8:08	LINE CLEAR AVAILED
469	23-Jul-2020	BAGALKOT	110	110/33KV,HV3	GHATAPRABHA_110,GOKAK MILLS_33,KALLOLLI_33	10:00	18:25	8:25	LINE CLEAR AVAILED
470	23-Jul-2020	BENGALURU	66	HV2	BMTC	16:04	16:06	00:02	LINE CLEAR AVAILED
471	23-Jul-2020	BENGALURU	66	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	18:04	19:26	01:22	MAIN SUPPLY FAILURE
472	23-Jul-2020	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	06:50	07:02	00:12	LINE FAULT
473	23-Jul-2020	BENGALURU	66	HV1	BANASAWADI	18:04	18:20	00:16	MAIN SUPPLY FAILURE
474	23-Jul-2020	BENGALURU	66	HV3	BANASAWADI	18:04	18:20	00:16	MAIN SUPPLY FAILURE
475	23-Jul-2020	BENGALURU	66	HV1	BANASAWADI	20:06	20:12	00:06	LOAD CHANGE OVER
476	23-Jul-2020	BENGALURU	66	HV3	BANASAWADI	20:06	20:12	00:06	LOAD CHANGE OVER
477	23-Jul-2020	BENGALURU	66	IISC - HEBBAL 220	IISC	18:04	18:24	00:20	MAIN SUPPLY FAILURE
478	23-Jul-2020	BENGALURU	66	C STATION - HEBBALA 220	C STATION	18:04	18:36	00:32	MAIN SUPPLY FAILURE
479	23-Jul-2020	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	MANYATHA TECH PARK 220	18:04	18:34	00:30	MAIN SUPPLY FAILURE
480	23-Jul-2020	BENGALURU	66	MANYATHA TECH PARK 220 - PEENYA 2	SAHAKARINAGAR	18:04	18:34	00:30	MAIN SUPPLY FAILURE
481	23-Jul-2020	BENGALURU	66	SHOBHA CITY - MANYATHA TECH PARK 220	SHOBHA CITY	18:04	18:19	00:15	MAIN SUPPLY FAILURE
482	23-Jul-2020	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 1	MANYATHA TECH PARK 66	18:04	18:34	00:30	MAIN SUPPLY FAILURE
483	23-Jul-2020	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	13:15	13:18	00:03	LOAD CHANGE OVER
484	23-Jul-2020	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	14:00	14:05	00:05	LOAD CHANGE OVER
485	23-Jul-2020	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	17:13	17:20	00:07	LINE FAULT
486	23-Jul-2020	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	08:38	08:41	00:03	LOAD CHANGE OVER
487	23-Jul-2020	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	18:04	18:47	00:43	MAIN SUPPLY FAILURE
488	23-Jul-2020	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	19:53	19:58	00:05	LOAD CHANGE OVER
489	23-Jul-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	21:16	21:42	00:26	LINE FAULT
490	23-Jul-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	09:53	10:02	00:09	LINE CLEAR AVAILED
491	23-Jul-2020	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	15:49	15:56	00:06	LINE CLEAR AVAILED
492	23-Jul-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	09:52	10:02	00:10	LINE CLEAR AVAILED
493	23-Jul-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:48	15:56	00:08	LINE CLEAR AVAILED
494	23-Jul-2020	BENGALURU	220	YELAHANKA 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 220, HEBBAL 220	18:04	21:46	03:41	LINE FAULT
495	23-Jul-2020	BENGALURU	66	HV2	KGF	18:38	18:58	00:20	LINE CLEAR AVAILED
496	23-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			LINE OPEN ,LINE CLEAR AVAILED
497	23-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN ,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
498	23-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
499	23-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN ,LINE FAULT
500	23-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN ,LINE FAULT
501	23-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
502	23-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN ,LINE CLEAR AVAILED
503	23-Jul-2020	GULBARGA	220	ITTAGI-BMMISPAT	ITTAGI_220	10:20	15:01	04:41	LINE CLEAR AVAILED
504	23-Jul-2020	GULBARGA	220	HV2	SIDHANOOR_220	10:20	16:48	06:28	LINE CLEAR AVAILED
505	23-Jul-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	03:35	15:50	12:15	LINE FAULT
506	23-Jul-2020	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	15:21	16:01	00:40	LINE FAULT
507	23-Jul-2020	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	20:35(17.7.2020)	22:25(23.7.2020)	145:50HRS	LINE CHARGED
508	23-Jul-2020	GULBARGA	110	KAPNOOR--MADIYAL	MADIYAL_110, NSLSUGARS_IPP, CHOWDAPUR_110	00:25	00:42	00:17	LINE FAULT
509	23-Jul-2020	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	06:52	07:00	00:08	LINE FAULT
510	23-Jul-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	04:30	04:40	00:10	LINE FAULT
511	23-Jul-2020	GULBARGA	110	SINDHANOOR- SUZLON_IPP	SIDHANOOR_220	04:51	05:02	00:11	LINE FAULT
512	23-Jul-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	05:16	05:26	00:10	LINE FAULT
513	23-Jul-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	13:36	13:46	00:10	LINE FAULT
514	23-Jul-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	15:55	16:05	00:10	LINE FAULT
515	23-Jul-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	19:06	19:40	00:34	LINE FAULT
516	23-Jul-2020	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	05:31	05:41	00:10	LINE FAULT
517	23-Jul-2020	GULBARGA	110	MALLAT-BYAGWAT2	MANVI_110, MADLAPUR_110	05:48	05:58	00:10	LINE FAULT
518	23-Jul-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	19:12	19:32	00:20	LINE FAULT
519	23-Jul-2020	GULBARGA	110	HV2	DEODURGA_110	15:05	15:15	00:10	TRANSFORMER FAULT
520	23-Jul-2020	GULBARGA	110	HV2	DEODURGA_110	17:20	17:30	00:10	TRANSFORMER FAULT
521	23-Jul-2020	GULBARGA	110	HV2	HATTI_110	12:47	12:57	00:10	LINE CLEAR AVAILED
522	23-Jul-2020	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	08:05	08:20	00:15	LINE FAULT
523	23-Jul-2020	GULBARGA	110	PDHALLI-CLEANSOLAR_IPP	PDHALLI_110	05:48	06:12	00:24	LINE FAULT
524	23-Jul-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	06:50	07:06	00:16	LINE FAULT
525	23-Jul-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1,2	HIREHADAGALI_66, MAGALA_66, GIRIYAPUR_66, SOVENAHALLI_66, TUNGBABHADRA	16:06	17:45	01:39	LINE FAULT
526	23-Jul-2020	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66, HOLAGUNDI_66	19:16	19:25	00:09	LINE FAULT
527	23-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:51 (22.07.2020)	6:35 (23.07.2020)	6:43 hrs	LINE CHARGED
528	23-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:35 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
529	23-Jul-2020	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	18:40 (23.07.2020)			LINE OPEN ,LINE FAULT
530	23-Jul-2020	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	03:20	20:16	16:56	LINE FAULT
531	23-Jul-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:03	12:21	02:18	NFBC ISSUED
532	23-Jul-2020	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	01:56	12:47	10:51	LINE FAULT
533	23-Jul-2020	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	11:56	18:18	06:22	LINE FAULT
534	23-Jul-2020	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	10:45	21:22	10:37	HAND TRIPPED
535	23-Jul-2020	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	10:46	21:23	10:37	HAND TRIPPED
536	23-Jul-2020	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:56	18:18	06:22	LINE FAULT
537	23-Jul-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:56	12:33	00:37	MAIN SUPPLY FAILURE
538	23-Jul-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:03	12:22	02:19	LINE CLEAR AVAILED
539	23-Jul-2020	HASSAN	110	HV2	BHADRAVATHI_110	17:06	18:16	01:10	LINE CLEAR AVAILED
540	23-Jul-2020	HASSAN	110	HV1	HIRIYADKA_110	12:08	12:14	00:06	LINE CLEAR AVAILED
541	23-Jul-2020	HASSAN	110	HV3	HIRIYADKA_110	11:25	11:51	00:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
542	23-Jul-2020	HASSAN	110	HV1	NAVUNDA_110	07:30	09:15	01:45	TRANSFORMER FAULT
543	23-Jul-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	08:19	08:25	00:06	LINE FAULT
544	23-Jul-2020	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:35	19:00	00:25	LINE FAULT
545	23-Jul-2020	HASSAN	66	HV1	HNPURA_66	18:37	18:57	00:20	MAIN SUPPLY FAILURE
546	23-Jul-2020	HASSAN	66	HV2	HNPURA_66	18:37	18:57	00:20	MAIN SUPPLY FAILURE
547	23-Jul-2020	HASSAN	66	HV2	HOLALUR_66	10:52	11:18	00:26	LINE CLEAR AVAILED
548	23-Jul-2020	HASSAN	66	HV2	HOLEHONNUR_66	10:40	17:46	07:06	LINE CLEAR AVAILED
549	23-Jul-2020	HASSAN	66	HV2	MAGGE_66	11:44	12:16	00:32	LINE CLEAR AVAILED
550	23-Jul-2020	MYSURU	66	HV1	BGPURA_66	9:00	9:11	0:11	TRANSFORMER FAULT
551	23-Jul-2020	MYSURU	66	HV2	BGPURA_66	9:00	9:11	0:11	TRANSFORMER FAULT
552	23-Jul-2020	MYSURU	66	HV1	BOGADHI_66	11:07	13:17	2:10	LINE CLEAR AVAILED
553	23-Jul-2020	MYSURU	66	HV2	BOGADHI_66	13:18	14:48	1:29	LINE CLEAR AVAILED
554	23-Jul-2020	MYSURU	66	ELWALA-HOOTAGALLY	NO STATIONS EFFECTED	11:13	12:44	1:30	LINE CLEAR AVAILED
555	23-Jul-2020	MYSURU	66	HV2	ELAVALA_66	12:10	12:45	0:35	LINE CLEAR AVAILED
556	23-Jul-2020	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	6:16	6:26	0:09	LINE FAULT
557	23-Jul-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	6:16	6:26	0:09	LINE FAULT
558	23-Jul-2020	MYSURU	220	KADAKOLA-CR NAGARA 1	NO STATIONS EFFECTED	9:35	12:27	2:52	LINE CLEAR AVAILED
559	23-Jul-2020	MYSURU	220	KADAKOLA-CR NAGARA 2	NO STATIONS EFFECTED	9:35	12:28	2:53	LINE CLEAR AVAILED
560	23-Jul-2020	MYSURU	66	HV2	KOLLEGALA_66	14:29	15:16	0:46	LINE CLEAR AVAILED
561	23-Jul-2020	MYSURU	66	KOLLEGALA-TALAKADU	THALAKADU_66 PARINAMIPURA_66 CHANDALLI_66	6:03	6:08	0:05	LINE FAULT
562	23-Jul-2020	MYSURU	66	KUNTHUR-DODDRAIPETE	NO STATIONS EFFECTED	6:14	6:19	0:05	LINE FAULT
563	23-Jul-2020	MYSURU	66	HV1	RAMAPURA_MYS_66	17:02	17:18	0:16	HAND TRIPPED
564	23-Jul-2020	MYSURU	66	HV1	RAMAPURA_MYS_66	19:31	19:49	0:17	HAND TRIPPED
565	23-Jul-2020	MYSURU	66	HV1	SINDHUVALLI_66	10:00	13:07	3:07	LINE CLEAR AVAILED
566	23-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
567	23-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN ,LINE FAULT
568	23-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
569	23-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
570	23-Jul-2020	TUMKUR	220	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	23:26(22.07.2020)	9:13(23.7.20)	9:40hrs	LINE CHARGED
571	23-Jul-2020	TUMKUR	110	TR-2	HULIYAR_110	19:46	20:55	1:08	LINE CLEAR AVAILED
572	23-Jul-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	18:31	18:41	0:10	LINE FAULT
573	23-Jul-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	14:48	15:00	0:12	LINE FAULT
574	23-Jul-2020	TUMKUR	66	TR-2	HANAGAL_66	16:10	16:23	0:13	TRANSFORMER FAULT
575	23-Jul-2020	TUMKUR	66	TR-2	IDHALLY_66	14:03	14:41	0:37	LINE CLEAR AVAILED
576	23-Jul-2020	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	6:00	6:31	0:30	LINE FAULT
577	23-Jul-2020	TUMKUR	66	TR-1	MAYAKONDA_66	14:39	19:01	4:22	LINE CLEAR AVAILED
578	23-Jul-2020	TUMKUR	66	PALLAGATTE-DVGSOKKE	PALLAGATTE_66	13:01	13:11	0:10	LINE CLEAR AVAILED
579	23-Jul-2020	TUMKUR	66	PAVAGADA220-MADHUGIRI 2	PAVAGADA_220	16:16	16:20	0:03	LINE FAULT
580	23-Jul-2020	TUMKUR	66	TR-3	HARIYABBE_66	16:25	16:27	0:01	LINE CLEAR AVAILED
581	23-Jul-2020	TUMKUR	66	TR-3	HARIYABBE_66	16:57	17:01	0:03	LINE CLEAR AVAILED
582	23-Jul-2020	TUMKUR	66	TR-2	LINGADAHALLI TMK2_66	11:42	12:10	0:27	LINE CLEAR AVAILED
583	24-Jul-2020	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
584	24-Jul-2020	BAGALKOT	110	110/11KV, HV1	SHIRGUPPI_110	21:12 (24.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
585	24-Jul-2020	BAGALKOT	110	110/11KV, HV2	UTTUR_110, YADWAD_33, VANTAGODI	16:41	16:50	0:09	TRANSFORMER FAULT
586	24-Jul-2020	BAGALKOT	110	110/11KV,HV1	HIDIKAL DAM_110	16:14	16:32	0:18	LINE CLEAR AVAILED
587	24-Jul-2020	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	11:22	15:34	4:12	LINE CLEAR AVAILED
588	24-Jul-2020	BAGALKOT	110	110/33KV,HV 2	ANKOLA_110 &SEA BIRD&MASTIKATTA 33	22:50	22:56	0:06	TRANSFORMER FAULT
589	24-Jul-2020	BAGALKOT	110	110/33KV,HV 2	ANKOLA_110 &SEA BIRD&MASTIKATTA 33	23:12	23:22	0:10	TRANSFORMER FAULT
590	24-Jul-2020	BAGALKOT	110	110/33KV,HV 2	ANKOLA_110 &SEA BIRD&MASTIKATTA 33	23:57 (24.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
591	24-Jul-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	10:40 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
592	24-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:02 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
593	24-Jul-2020	BAGALKOT	110	ATHANI220-THAVASI	THAVASI_110	5:42	5:49	0:07	LINE FAULT
594	24-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
595	24-Jul-2020	BAGALKOT	110	CHIKKODI-SADALAGA	SADALAGA_110	6:45	7:16	0:31	LINE FAULT
596	24-Jul-2020	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 (19.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
597	24-Jul-2020	BAGALKOT	110	GAMESHA- RON	RON_110	15:09	15:33	0:24	HAND TRIPPED
598	24-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
599	24-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	19:15 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
600	24-Jul-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
601	24-Jul-2020	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:48 (13.07.02020)			LINE OPEN ,LINE CLEAR AVAILED
602	24-Jul-2020	BAGALKOT	110	ITNAL- HIDIKAL	STATION NOT AFFECTED HIDAKAL_110	00:40 (22.07.2020)	16:00 (24.07.2020)	63:20 hrs	LINE CHARGED
603	24-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
604	24-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
605	24-Jul-2020	BAGALKOT	110	MAHALIGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMKHANDI_110	19:53 (22.07.2020)			LOAD CURTAILMENT
606	24-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI_220	21:26 (23.07.2020)	16:02 (24.07.2020)	18:36HRS	LINE CHARGED
607	24-Jul-2020	BAGALKOT	110	SUVARNASOUDA- MACHE	MACHE_110	3:43	4:02	0:19	LINE FAULT
608	24-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
609	24-Jul-2020	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDAKAL_110, ITANAL_110	2:41	3:35	0:54	TRANSFORMER FAULT
610	24-Jul-2020	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDAKAL_110, ITANAL_110	11:49	13:19	1:30	LINE CLEAR AVAILED
611	24-Jul-2020	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	13:01	15:08	2:07	LINE FAULT
612	24-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
613	24-Jul-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	11:02 (16.07.2020)	15:19 (24.07.2020)	195:57 hrs	LINE CHARGED
614	24-Jul-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
615	24-Jul-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	11:27 (22.07.2020)	10:56 (24.07.2020)	47:29 hrs	LINE CHARGED
616	24-Jul-2020	BAGALKOT	220	CHIKKODI- GHATAPRABHA	CHIKKODI_220	10:58	14:02	3:04	LINE CLEAR AVAILED
617	24-Jul-2020	BAGALKOT	220	DHONI1&2-GADAG	STATION NOT AFFECTED GADAG_220	12:20 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
618	24-Jul-2020	BAGALKOT	220	GUTTUR- RANEENNUR	RANEENNUR_220	7:25 (24.07.2020)			LOAD CURTAILMENT
619	24-Jul-2020	BAGALKOT	220	HARTI1&2- GADAG	STATION NOT AFFECTED GADAG_220	13:08 (23.07.2020)	15:19 (24.07.2020)	26:11 hrs	LINE CHARGED
620	24-Jul-2020	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	10:55 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
621	24-Jul-2020	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	21:29 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
622	24-Jul-2020	BAGALKOT	220	NAGJHARI1- HUBLI	HUBLI_220	10:11	12:24	2:13	LINE CLEAR AVAILED
623	24-Jul-2020	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	11:33	14:41	3:08	LINE CLEAR AVAILED
624	24-Jul-2020	BAGALKOT	220	SHARAVATHY1&2- SIRSI	SIRSI_220	16:05	19:57	3:52	LINE CLEAR AVAILED
625	24-Jul-2020	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	14:06	19:56	5:50	LINE FAULT
626	24-Jul-2020	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	13:07	20:04	6:57	LINE FAULT
627	24-Jul-2020	BENGALURU	66	ATTIBELE - SARIAPURA 220	ATTIBELE	11:40	11:05	00:25	LOAD CHANGE OVER
628	24-Jul-2020	BENGALURU	66	AUDGODI - HSR LAYOUT 1	ADUGODI, JAKKASANDRA	11:38	11:50	00:12	LOAD CHANGE OVER
629	24-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
630	24-Jul-2020	BENGALURU	66	C STATION - A STATION 220	C STATION	07:01	07:03	00:02	LOAD CHANGE OVER
631	24-Jul-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	12:37	12:44	00:06	LINE CLEAR AVAILED
632	24-Jul-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	13:45	13:50	00:05	LINE CLEAR AVAILED
633	24-Jul-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	12:37	12:44	00:06	LINE CLEAR AVAILED
634	24-Jul-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	13:46	13:50	00:04	LINE CLEAR AVAILED
635	24-Jul-2020	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	12:37	12:44	00:06	LINE CLEAR AVAILED
636	24-Jul-2020	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	13:46	13:50	00:04	LINE CLEAR AVAILED
637	24-Jul-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:37	12:44	00:06	LINE CLEAR AVAILED
638	24-Jul-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:45	13:50	00:04	LINE CLEAR AVAILED
639	24-Jul-2020	BENGALURU	66	HV1	MALLASANDRA	12:23	13:04	00:40	TRANSFORMER FAULT
640	24-Jul-2020	BENGALURU	66	HV2	C STATION	10:53	12:20	01:26	TRANSFORMER FAULT
641	24-Jul-2020	BENGALURU	66	HV2	CHANDAPURA	13:21	13:28	00:06	LINE CLEAR AVAILED
642	24-Jul-2020	BENGALURU	66	HV2	BAIRAKURU	11:30	12:58	01:28	LINE CLEAR AVAILED
643	24-Jul-2020	BENGALURU	66	HV2	KIADB DB PURA 220	09:40	09:58	00:18	TRANSFORMER FAULT
644	24-Jul-2020	BENGALURU	66	IISC - NRS 220	IISC	10:21	10:30	00:09	LOAD CHANGE OVER
645	24-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN ,LINE FAULT
646	24-Jul-2020	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	09:46	17:56	08:09	LINE CLEAR AVAILED
647	24-Jul-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	15:48	17:44	01:56	LINE CLEAR AVAILED
648	24-Jul-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	07:00	07:22	00:21	LINE FAULT
649	24-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN ,LINE FAULT
650	24-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN ,LINE FAULT
651	24-Jul-2020	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	10:18	10:25	00:07	LINE CLEAR AVAILED
652	24-Jul-2020	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HONNIGANAHALLI	06:52	07:05	00:13	LINE FAULT
653	24-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			LINE OPEN ,LINE CLEAR AVAILED
654	24-Jul-2020	GULBARGA	66	HV1	HANASI_66	11:25	12:05	00:40	LINE CLEAR AVAILED
655	24-Jul-2020	GULBARGA	66	HV2	CHORNOOR_66	08:05	08:50	00:45	LINE CLEAR AVAILED
656	24-Jul-2020	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	05:25	05:50	00:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
657	24-Jul-2020	GULBARGA	110	HV2	DEODURGA_110	07:45	07:55	00:10	TRANSFORMER FAULT
658	24-Jul-2020	GULBARGA	110	HV3	TEKKALKOTE_110	18:10	18:30	00:20	TRANSFORMER FAULT
659	24-Jul-2020	GULBARGA	110	JANAWADA-SANTHPUR	SANTHAPUR_110	05:45	06:05	00:20	LINE FAULT
660	24-Jul-2020	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	20:24	20:34	00:10	LINE FAULT
661	24-Jul-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWA_110	05:20	08:35	03:15	LINE FAULT
662	24-Jul-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	06:13	06:24	00:11	LINE FAULT
663	24-Jul-2020	GULBARGA	110	PDHALLI-CLEANSOLAR_IPP	PDHALLI_110	07:45	07:56	00:11	LINE FAULT
664	24-Jul-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110, KORWARTEMPLE_110	04:44	05:53	01:09	LINE FAULT
665	24-Jul-2020	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110, HUNASAGI_110	00:24	00:37	00:13	LINE FAULT
666	24-Jul-2020	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP, ASKI_110, HUNASAGI_110	21:32	21:46	00:14	LINE FAULT
667	24-Jul-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	02:15	02:35	00:20	LINE FAULT
668	24-Jul-2020	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR	15:10	15:50	00:40	LINE CLEAR AVAILED
669	24-Jul-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	01:38	06:54	05:16	LINE FAULT
670	24-Jul-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:55	11:50	00:55	NFBC ISSUED
671	24-Jul-2020	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	18:40 (23.07.2020)	15:21 (24.07.2020)	20:40 hrs	LINE CHARGED
672	24-Jul-2020	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	15:55	16:24	00:29	LINE CLEAR AVAILED
673	24-Jul-2020	HASSAN	66	HV2	HOLEHONNUR_66	12:05	13:05	01:00	LINE CLEAR AVAILED
674	24-Jul-2020	HASSAN	110	HV1	BHADRAVATHI_110	11:10	13:48	02:38	LINE CLEAR AVAILED
675	24-Jul-2020	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	11:15	13:19	02:04	LINE CLEAR AVAILED
676	24-Jul-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	09:57	12:30	02:33	NFBC ISSUED
677	24-Jul-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	18:13	18:18	00:05	HAND TRIPPED
678	24-Jul-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMG_220	10:11	11:57	01:46	LINE FAULT
679	24-Jul-2020	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	11:15	13:19	02:04	LINE CLEAR AVAILED
680	24-Jul-2020	HASSAN	220	SHRAVITY-SHIMOAGA1	sharavathy_gen	10:11	11:57	01:46	LINE FAULT
681	24-Jul-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	16:05	19:55	03:50	NFBC ISSUED
682	24-Jul-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	09:57	12:30	02:33	LINE CLEAR AVAILED
683	24-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA-2	TALAGUPPA_400	01:03	06:27	05:24	HAND TRIPPED
684	24-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:35 (23.07.2020)	6:14 (24.07.2020)	6:35 hrs	LINE CHARGED
685	24-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:02 (24.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
686	24-Jul-2020	MYSURU	66	HV1	ELAVALA_66	15:32	19:45	4:13	LINE CLEAR AVAILED
687	24-Jul-2020	MYSURU	66	HV1	KIRUGAVLU-	21:57 (24.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
688	24-Jul-2020	MYSURU	66	HV1	MEGALAPURA_66	13:05	13:10	0:05	TRANSFORMER FAULT
689	24-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
690	24-Jul-2020	MYSURU	66	HV2	ELAVALA_66	11:42	15:38	3:56	LINE CLEAR AVAILED
691	24-Jul-2020	MYSURU	66	HV2	MEGALAPURA_66	11:40	16:55	5:14	LINE CLEAR AVAILED
692	24-Jul-2020	MYSURU	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66, B MATKERE_66 , HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66 SANTHESARAGUR_66	8:15	8:21	0:06	LINE FAULT
693	24-Jul-2020	MYSURU	66	KR PETE 220-KR PETE 2	NO STATIONS EFFECTED	12:34	14:04	1:29	LINE CLEAR AVAILED
694	24-Jul-2020	MYSURU	66	MALAVALLI-KADKOTHNALLI	MALAVALLI_66 HADLI_66	8:14	19:01	10:47	NFBC ISSUED
695	24-Jul-2020	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	10:03	10:17	0:13	LINE FAULT
696	24-Jul-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:34	16:45	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
697	24-Jul-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:01	18:16	0:14	LINE FAULT
698	24-Jul-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:23	6:28	0:05	LINE FAULT
699	24-Jul-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	15:41	16:43	1:02	LINE CLEAR AVAILED
700	24-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN ,LINE FAULT
701	24-Jul-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	13:13	14:17	1:03	LINE CLEAR AVAILED
702	24-Jul-2020	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	10:24	10:44	0:20	MAIN SUPPLY FAILURE
703	24-Jul-2020	TUMKUR	66	PAVAGADA220-MADHUGIRI 2	PAVAGADA_220	11:42	12:40	0:58	LINE FAULT
704	24-Jul-2020	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	RANGENAHALLI_66	21:44	21:47	0:03	LINE FAULT
705	24-Jul-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	21:46	22:12	0:25	LINE FAULT
706	24-Jul-2020	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66	16:27	17:08	0:40	LINE FAULT
707	24-Jul-2020	TUMKUR	66	THOVINAKERE-KORA	THOVINAKERE_66	12:22	14:12	1:50	LINE CLEAR AVAILED
708	24-Jul-2020	TUMKUR	66	TR-1	KUKKAWADA_66	10:08	10:41	0:32	LINE CLEAR AVAILED
709	24-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	8:46	9:08	0:22	TRANSFORMER FAULT
710	24-Jul-2020	TUMKUR	66	TR-1	PAVAGADA_220	10:58	11:05	0:06	TRANSFORMER FAULT
711	24-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
712	24-Jul-2020	TUMKUR	66	TR-2	BADDIHALLI_66	11:35	11:57	0:22	LINE CLEAR AVAILED
713	24-Jul-2020	TUMKUR	66	TR-2	BADDIHALLI_66	12:04	12:10	0:05	LINE CLEAR AVAILED
714	24-Jul-2020	TUMKUR	66	TR-2	IDHALLY_66	10:08	19:14	9:06	LINE CLEAR AVAILED
715	24-Jul-2020	TUMKUR	66	TR-2	THOVINAKERE_66	12:21	14:12	1:50	LINE CLEAR AVAILED
716	24-Jul-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	12:21	12:26	0:05	HAND TRIPPED
717	24-Jul-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	15:32	15:36	0:03	HAND TRIPPED
718	24-Jul-2020	TUMKUR	110	TR-1	AMMASANDRA_110	9:13	14:28	5:15	LINE CLEAR AVAILED
719	24-Jul-2020	TUMKUR	110	TR-1	AMMASANDRA_110	18:52	19:10	0:17	HAND TRIPPED
720	24-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
721	24-Jul-2020	TUMKUR	110	TR-3	AMMASANDRA_110	9:13	14:28	5:15	LINE CLEAR AVAILED
722	25-Jul-2020	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN ,LINE CLEAR AVAILED
723	25-Jul-2020	BAGALKOT	110	110/11KV, HV1	STATION NOT EFFECTED SHIRGUPPI_110	21:12 (24.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
724	25-Jul-2020	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	11:21	13:39	2:18	LINE CLEAR AVAILED
725	25-Jul-2020	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	17:05	17:11	0:06	TRANSFORMER FAULT
726	25-Jul-2020	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	18:48	19:00	0:12	TRANSFORMER FAULT
727	25-Jul-2020	BAGALKOT	110	110/33KV, HV1	JAMKHANDI_110, HIPARGI_33	11:33	11:42	0:09	LINE CLEAR AVAILED
728	25-Jul-2020	BAGALKOT	110	110/33KV,HV 2	STATION NOT EFFECTED ANKOLA_110 &SEA BIRD&MASTIKATTA_33	23:57 (24.07.2020)	12:03 (25.07.2020)	15:03	LINE CLEAR AVAILED
729	25-Jul-2020	BAGALKOT	110	110/33KV,HV 2	HUNGUND_110 &KARADI,AMINAGAD_33	13:07	13:10	0:03	TRANSFORMER FAULT
730	25-Jul-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	1:34	7:29	5:55	HAND TRIPPED
731	25-Jul-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	10:40 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
732	25-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:02 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
733	25-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
734	25-Jul-2020	BAGALKOT	110	CHIKKODI-ANKALI	ANKALI_110	6:45	7:09	0:24	LINE FAULT
735	25-Jul-2020	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 (19.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
736	25-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
737	25-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	19:15 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
738	25-Jul-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
739	25-Jul-2020	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:48 (13.07.02020)			LINE OPEN ,LINE CLEAR AVAILED
740	25-Jul-2020	BAGALKOT	110	ILKAL1-HIUNGUND	HUNGUND_110	6:02	6:42	0:40	LINE FAULT
741	25-Jul-2020	BAGALKOT	110	ILKAL2-HIUNGUND	STATION NOT AFFECTED HUNGUND_110	6:02 (25.07.2020)			LINE OPEN ,LINE FAULT
742	25-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
743	25-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
744	25-Jul-2020	BAGALKOT	110	MAHALIGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMKHANDI_110	19:53 (22.07.2020)			LOAD CURTAILMENT
745	25-Jul-2020	BAGALKOT	110	MAREGUDDI- MUNDUGANUR	MUNDUGANUR_110	6:40	7:03	0:23	LINE FAULT
746	25-Jul-2020	BAGALKOT	110	RANEENNUR- AREMALLAPUR (HONNATTI)	HONNATTI_110	6:23	6:42	0:19	LINE FAULT
747	25-Jul-2020	BAGALKOT	110	SADALAGA- BORAGOAN	BORAGOAN_110	7:02	7:37	0:35	HAND TRIPPED
748	25-Jul-2020	BAGALKOT	110	UTTUR- RANNABELAGALI	RANNABELAGALI_110	16:41	17:02	0:21	LINE FAULT
749	25-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
750	25-Jul-2020	BAGALKOT	110	VPPL- SADALAGA	SADALAGA_110	6:45	10:15	15:03	LINE FAULT
751	25-Jul-2020	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT_220	1:24	11:15	9:51	LOAD CURTAILMENT
752	25-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
753	25-Jul-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
754	25-Jul-2020	BAGALKOT	220	BIDMNAL-SOUDATTI	BIDNAL_220	10:22	15:40	5:18	LINE CLEAR AVAILED
755	25-Jul-2020	BAGALKOT	220	DHONI1&2-GADAG	STATION NOT AFFECTED GADAG_220	12:20 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
756	25-Jul-2020	BAGALKOT	220	GUTTUR- RANEENNUR	STATION NOT EFFECTED RANEENNUR_220	7:25 (24.07.2020)			LOAD CURTAILMENT
757	25-Jul-2020	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	10:55 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
758	25-Jul-2020	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	21:29 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
759	25-Jul-2020	BENGALURU	66	AUDGODI - JAKKASANDRA	ADUGODI	06:12	06:20	00:08	LOAD CHANGE OVER
760	25-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
761	25-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN ,LINE FAULT
762	25-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN ,LINE FAULT
763	25-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN ,LINE FAULT
764	25-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			LINE OPEN ,LINE CLEAR AVAILED
765	25-Jul-2020	GULBARGA	110	ALIPUR-BELLARYNORTH	BELLARYNORTH_110, SOMASAMUDRA_110, MOKA_110, PDHALLI_110, BISIHALLI_110	04:48	04:58	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
766	25-Jul-2020	GULBARGA	110	HV2	DEODURGA_110	08:00	08:05	00:05	TRANSFORMER FAULT
767	25-Jul-2020	GULBARGA	110	HV3	HATTI_110	06:12	06:28	00:16	TRANSFORMER FAULT
768	25-Jul-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	05:10	05:23	00:13	LINE FAULT
769	25-Jul-2020	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	02:49	02:55	00:06	LINE FAULT
770	25-Jul-2020	GULBARGA	110	SEDAM-VICATSAGAR	SEDAM_220	06:04	06:22	00:18	LINE FAULT
771	25-Jul-2020	GULBARGA	110	SHAHBAD-RAICHUR1	JEWARGI_110	05:20	05:24	00:04	LINE FAULT
772	25-Jul-2020	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	04:47	04:55	00:08	LINE FAULT
773	25-Jul-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	10:45	10:55	00:10	LINE FAULT
774	25-Jul-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	KURDICROSS_110	23:30	23:50	00:20	LINE FAULT
775	25-Jul-2020	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110, SIRUGUPPA_110, TEKKALKOTE_110, NSLSUGARS_IPP	09:54	10:05	00:11	LINE FAULT
776	25-Jul-2020	GULBARGA	220	HV2	HUMNABAD_220	17:10	19:15	02:05	LINE CLEAR AVAILED
777	25-Jul-2020	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR	01:30	04:40	03:10	LINE CLEAR AVAILED
778	25-Jul-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SIDHANOOR_220	01:30	01:43	00:13	LINE FAULT
779	25-Jul-2020	HASSAN	66	HV2	MAGGE_66	11:07	11:50	00:43	LINE CLEAR AVAILED
780	25-Jul-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	12:19	14:41	02:22	LINE CLEAR AVAILED
781	25-Jul-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	12:19	14:49	02:30	LINE CLEAR AVAILED
782	25-Jul-2020	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	16:54	18:30	01:36	LINE CLEAR AVAILED
783	25-Jul-2020	HASSAN	110	HV3	HIRIYADKA_110	22:42	22:48	00:06	TRANSFORMER FAULT
784	25-Jul-2020	HASSAN	110	SAGARA-JST1	SAGARA_110	13:20	15:35	02:15	HAND TRIPPED
785	25-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:32 (25.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
786	25-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:02 (24.07.2020)	6:10 (25.07.2020)	7:17 hrs	LINE CHARGED
787	25-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
788	25-Jul-2020	MYSURU	66	HV1	KIRUGAVALU_66	21:57 (24.07.2020)	12:48 (25.07.2020)	14:50 hrs	TRANSFORMER CHARGED
789	25-Jul-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	11:27	11:56	0:28	HAND TRIPPED
790	25-Jul-2020	MYSURU	66	VAJAMANGALA-JYOTHINAGARA	DKMAIDANA_66 JYOTHINAGARA_66	16:00	16:18	0:18	LINE FAULT
791	25-Jul-2020	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	10:18	16:39	6:21	NFBC ISSUED
792	25-Jul-2020	TUMKUR	66	ANTHRASANA HALLI 220KV- MELEKOTE	DODDASARANGI_66,MELKOTE_66, BADDIHALLI_66, HONNUDIKE_66, HIREHALLY_66	10:23	17:44	7:21	LINE CLEAR AVAILED
793	25-Jul-2020	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	10:38	18:09	7:31	LINE CLEAR AVAILED
794	25-Jul-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	10:42	11:04	0:22	LINE FAULT
795	25-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN ,LINE FAULT
796	25-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN ,LINE FAULT
797	25-Jul-2020	TUMKUR	66	HONNALLI 220KV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	13:46	16:36	2:50	LINE CLEAR AVAILED
798	25-Jul-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:00	16:36	1:36	LINE CLEAR AVAILED
799	25-Jul-2020	TUMKUR	66	TR-1	BANUVALLI_66	11:42	16:39	4:57	LINE CLEAR AVAILED
800	25-Jul-2020	TUMKUR	66	TR-1	DAVANAGERE_66	10:58	11:48	0:49	LINE CLEAR AVAILED
801	25-Jul-2020	TUMKUR	66	TR-1	HARIHAR_66	9:17	9:27	0:10	TRANSFORMER FAULT
802	25-Jul-2020	TUMKUR	66	TR-1	IDHALLY_66	8:46	9:22	0:36	LINE CLEAR AVAILED
803	25-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
804	25-Jul-2020	TUMKUR	66	TR-2	CHITRADURGA_220	15:51	19:04	3:13	LINE CLEAR AVAILED
805	25-Jul-2020	TUMKUR	66	TR-2	DAVANAGERE_66	10:58	11:48	0:49	LINE CLEAR AVAILED
806	25-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
807	25-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
808	25-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
809	26-Jul-2020	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	18:46 (19.07.0.2020)			LINE OPEN ,LINE CLEAR AVAILED
810	26-Jul-2020	BAGALKOT	110	110/11KV, HV1	STATION NOT EFFECTED SHIRGUPPI 110	21:12 (24.07.2020)	11:15 (26.07.2020)	14:03	TRANSFORMER CHARGED
811	26-Jul-2020	BAGALKOT	110	110/11KV,HV4	GHATAPRABAHA 110	15:37	16:08	0:31	LINE CLEAR AVAILED
812	26-Jul-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI 110	10:40 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
813	26-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM 110	18:02 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
814	26-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	15:16 (20.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
815	26-Jul-2020	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD 110	7:40 19.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
816	26-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA 110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
817	26-Jul-2020	BAGALKOT	110	GSML1- MAHALINGAPUR	MAHALINGAPUR_220	9:25	18:05	8:40	LINE CLEAR AVAILED
818	26-Jul-2020	BAGALKOT	110	GSML2- MAHALINGAPUR	MAHALINGAPUR_220	8:30	18:05	9:35	LINE CLEAR AVAILED
819	26-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI 110	19:15 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
820	26-Jul-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:0 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
821	26-Jul-2020	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI 220	11:48 (13.07.02020)			LINE OPEN ,LINE CLEAR AVAILED
822	26-Jul-2020	BAGALKOT	110	ILKAL2-HIUNGUND	STATION NOT AFFECTED HUNGUND 110	6:02 (25.07.2020)	14:02 (26.07.2020)	18:00 hrs	LINE CHARGED
823	26-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
824	26-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR 110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
825	26-Jul-2020	BAGALKOT	110	MAHALIGAPUR(NAVALAGI)-JAMAKHANDI	STATION NOT AFFECTED JAMKHANDI 110	19:53 (22.07.2020)			LOAD CURTAILMENT
826	26-Jul-2020	BAGALKOT	110	MAHALINGPUR-HIDIKAL	HIDIKAL_110	22:52	23:33	0:41	LINE FAULT
827	26-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
828	26-Jul-2020	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDAKAL_110, ITANAL 110	22:53	23:14	0:21	TRANSFORMER FAULT
829	26-Jul-2020	BAGALKOT	220	BAGALKOT-GADAG 1	STATION NOT AFFECTED BAGALKOT 220	2:06 (26.07.2020)			LOAD CURTAILMENT
830	26-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
831	26-Jul-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI 220	17:26 (24.07.2020)			LOAD CURTAILMENT
832	26-Jul-2020	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	10:56 (26.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
833	26-Jul-2020	BAGALKOT	220	DHONI1&2-GADAG	STATION NOT AFFECTED GADAG 220	12:20 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
834	26-Jul-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT EFFECTED RANEBENNUR 220	7:25 (24.07.2020)			LOAD CURTAILMENT
835	26-Jul-2020	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI 220	10:55 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
836	26-Jul-2020	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI 220	21:29 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
837	26-Jul-2020	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	12:19	15:39	3:20	LINE CLEAR AVAILED
838	26-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
839	26-Jul-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	06:56	07:04	00:07	LINE FAULT
840	26-Jul-2020	BENGALURU	66	HV1	MUDIYANUR	09:05	09:10	00:04	TRANSFORMER FAULT
841	26-Jul-2020	BENGALURU	66	HV1	MUDIYANUR	09:12	11:28	02:16	TRANSFORMER FAULT
842	26-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN ,LINE FAULT
843	26-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)	13:59(26/07/2020)	528:12Hrs	LINE CHARGED
844	26-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN ,LINE FAULT
845	26-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			LINE OPEN ,LINE CLEAR AVAILED
846	26-Jul-2020	GULBARGA	66	CJHALLI-KUDLIGI	CJHALLI_66	11:00	11:05	00:05	LINE FAULT
847	26-Jul-2020	GULBARGA	66	CJHALLI-KUDLIGI	CJHALLI_66	13:30	13:35	00:05	LINE FAULT
848	26-Jul-2020	GULBARGA	66	CJHALLI-KUDLIGI	CJHALLI_66	15:25	15:45	00:20	LINE FAULT
849	26-Jul-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110, NIRNA_110	05:56	06:11	00:15	LINE FAULT
850	26-Jul-2020	GULBARGA	110	HV2	HATTI_110	12:48	14:27	01:39	TRANSFORMER FAULT
851	26-Jul-2020	GULBARGA	110	JANAWADA-SANTHPUR	SANTHAPUR_110	05:15	05:20	00:05	LINE FAULT
852	26-Jul-2020	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	05:50	05:55	00:05	LINE FAULT
853	26-Jul-2020	GULBARGA	110	KUSTAGI-ILKAL	ILKAL_110	12:16	12:38	00:22	LINE FAULT
854	26-Jul-2020	GULBARGA	110	SHAHBAD-CHITAPUR	CHITAPUR_110, KORWARTEMPLE_110	05:15	05:20	00:05	LINE FAULT
855	26-Jul-2020	GULBARGA	110	SHAHBAD-WADI	WADI_110	19:36	19:45	00:09	LINE FAULT
856	26-Jul-2020	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	05:11	05:18	00:07	LINE FAULT
857	26-Jul-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	KURDICROSS_110	07:20	07:40	00:20	LINE FAULT
858	26-Jul-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	KURDICROSS_110	20:20	20:30	00:10	LINE FAULT
859	26-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN ,LINE CLEAR AVAILED
860	26-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
861	26-Jul-2020	HASSAN	66	HV1	KUDLIGERE_66	12:05	12:15	00:10	TRANSFORMER FAULT
862	26-Jul-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	09:45	09:50	00:05	HAND TRIPPED
863	26-Jul-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	18:15	18:20	00:05	HAND TRIPPED
864	26-Jul-2020	HASSAN	110	HV2	BHADRAVATHI_110	11:59	13:52	01:53	LINE CLEAR AVAILED
865	26-Jul-2020	HASSAN	220	ARK2-HSN	ARASIKERE_220	09:12	14:28	05:16	NFBC ISSUED
866	26-Jul-2020	HASSAN	220	HV2	GOPALPURA_220	16:28 (26.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
867	26-Jul-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	09:22	14:17	04:55	NFBC ISSUED
868	26-Jul-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	09:50	13:53	04:03	LINE CLEAR AVAILED
869	26-Jul-2020	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	14:20	14:31	00:11	LINE FAULT
870	26-Jul-2020	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	11:19	14:51	03:32	LINE FAULT
871	26-Jul-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	14:19	14:30	00:11	LINE FAULT
872	26-Jul-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	11:18	14:51	03:33	LINE FAULT
873	26-Jul-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	17:22 (26.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
874	26-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	NO STN AFFECTED	0:32 (25.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
875	26-Jul-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:22 (26.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
876	26-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:23 (26.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
877	26-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
878	26-Jul-2020	MYSURU	66	HV2	THALAKADU_66	8:09	10:09	1:59	LINE CLEAR AVAILED
879	26-Jul-2020	MYSURU	66	MADHUVANAHALLI-KOLLEGALA 1	NO STATIONS EFFECTED	16:50	16:56	0:06	LINE FAULT
880	26-Jul-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	15:02	15:07	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
881	26-Jul-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	6:35	6:39	0:04	LINE FAULT
882	26-Jul-2020	MYSURU	66	VAJAMANAGALA-KADAKOLA 2	NO STATIONS EFFECTED	6:04	6:24	0:19	LINE FAULT
883	26-Jul-2020	MYSURU	66	VAJAMANGALA-DEVANOOOR (MYS)	DEVANOORMYS_66 FTS_66 RAJEEVNAGARA_66	16:00	16:18	0:18	LINE FAULT
884	26-Jul-2020	MYSURU	220	HV1	TUBINKERE-	15:15	15:50	0:35	TRANSFORMER FAULT
885	26-Jul-2020	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	8:19	10:07	1:47	LINE FAULT
886	26-Jul-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	10:22	17:29	7:07	LINE CLEAR AVAILED
887	26-Jul-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUND A_66	14:46	15:01	0:15	LINE FAULT
888	26-Jul-2020	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	10:31	10:43	0:11	HAND TRIPPED
889	26-Jul-2020	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	10:27	17:39	7:11	LINE CLEAR AVAILED
890	26-Jul-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	8:27	9:02	0:35	HAND TRIPPED
891	26-Jul-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	14:04	14:20	0:15	HAND TRIPPED
892	26-Jul-2020	TUMKUR	66	TR-1	CHITRADURGA_220	15:58	17:05	1:06	LINE CLEAR AVAILED
893	26-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	12:18	12:45	0:26	LINE CLEAR AVAILED
894	26-Jul-2020	TUMKUR	66	TR-1	KORA_66	10:41	17:35	6:53	LINE CLEAR AVAILED
895	26-Jul-2020	TUMKUR	66	TR-2	CHITRADURGA_220	14:14	19:01	4:46	LINE CLEAR AVAILED
896	26-Jul-2020	TUMKUR	66	TR-2	IDHALLY_66	13:04	14:56	1:52	LINE CLEAR AVAILED
897	26-Jul-2020	TUMKUR	66	TR-2	KORA_66	10:41	17:35	6:53	LINE CLEAR AVAILED
898	26-Jul-2020	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	9:13	14:27	5:13	LINE CLEAR AVAILED
899	27-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN ,LINE FAULT
900	27-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
901	27-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
902	27-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
903	27-Jul-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN ,LINE CLEAR AVAILED
904	27-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN ,LINE CLEAR AVAILED
905	27-Jul-2020	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:48 (13.07.02020)	16:58 (27.07.2020)	365:10hrs	LINE CHARGED
906	27-Jul-2020	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
907	27-Jul-2020	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020			LINE OPEN ,LINE CLEAR AVAILED
908	27-Jul-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
909	27-Jul-2020	BAGALKOT	110	MAHALIGAPUR(NAVALAGI)- JAMAKHANDI	STATION NOT AFFECTED JAMKHANDI_110	19:53 (22.07.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
910	27-Jul-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	10:40 (22.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
911	27-Jul-2020	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	10:55 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
912	27-Jul-2020	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	21:29 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
913	27-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:02 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
914	27-Jul-2020	BAGALKOT	220	DHONI1&2-GADAG	STATION NOT AFFECTED GADAG_220	12:20 (23.07.2020)	13:17 (27.07.2020)	96:57hrs	LINE CHARGED
915	27-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	19:15 (23.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
916	27-Jul-2020	BAGALKOT	220	GUTTUR- RANEENNUR	STATION NOT EFFECTED RANEENNUR_220	7:25 (24.07.2020)	6:34 (27.07.2020)	71:09hrs	LINE CHARGED
917	27-Jul-2020	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
918	27-Jul-2020	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	10:56 (26.07.2020)	10:40 (27.07.2020)	23:44hrs	LINE CHARGED
919	27-Jul-2020	BAGALKOT	220	BAGALKOT-GADAG 1	STATION NOT AFFECTED BAGALKOT_220	2:06 (26.07.2020)			LOAD CURTAILMENT
920	27-Jul-2020	BAGALKOT	110	ANNIGERI- GADAG	STATION NOT AFFECTED ANNIGERI_110	13:49	16:08	2:19	LINE FAULT
921	27-Jul-2020	BAGALKOT	110	110/11KV, HV1	GUTTAL_110	11:08	12:43	1:35	LINE CLEAR AVAILED
922	27-Jul-2020	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	12:18 (27.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
923	27-Jul-2020	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	HIDIKAL_110	7:10	7:16	0:06	HAND TRIPPED
924	27-Jul-2020	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	HIDIKAL_110	10:57	10:59	0:02	HAND TRIPPED
925	27-Jul-2020	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	HIDIKAL_110	16:38	16:44	0:06	HAND TRIPPED
926	27-Jul-2020	BAGALKOT	110	110/11KV, HV1A	JAMKHANDI_110	20:22	20:42	0:20	TRANSFORMER FAULT
927	27-Jul-2020	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	22:20	22:50	0:30	TRANSFORMER FAULT
928	27-Jul-2020	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	14:17	14:51	0:34	LINE CLEAR AVAILED
929	27-Jul-2020	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	14:42	15:35	0:53	LINE CLEAR AVAILED
930	27-Jul-2020	BAGALKOT	220	BELLIGAVI(SHIRALKOPPA)- RANEENNUR	RANEENNUR_220	6:17	11:20	5:03	LINE FAULT
931	27-Jul-2020	BAGALKOT	110	RANEENNUR- RATTIHALI (TUMMINKATTI)	TUMMINKATTI_110	6:34	10:10	3:36	LINE FAULT
932	27-Jul-2020	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	10:31	14:16	3:45	TRANSFORMER FAULT
933	27-Jul-2020	BAGALKOT	110	SODATTI220- MUNAVALLI	MUNAVALLI_110	3:47	4:08	0:21	LINE FAULT
934	27-Jul-2020	BAGALKOT	110	UTTUR- RANNABELAGALI	RANNABELAGALI_110	10:31	10:43	0:12	LINE FAULT
935	27-Jul-2020	BAGALKOT	110	VAJRAMATTI220- MALLIGERI	MALLIGERI_110	10:32	18:05	7:33	LINE CLEAR AVAILED
936	27-Jul-2020	BAGALKOT	220	BELGAUM- NARENDRA2	BELGAUM_220	00:37	5:52	5:15	HAND TRIPPED
937	27-Jul-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	10:44	12:42	1:58	NFBC ISSUED
938	27-Jul-2020	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	16:12	16:19	00:07	LOAD CHANGE OVER
939	27-Jul-2020	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	21:52	21:59	00:07	LOAD CHANGE OVER
940	27-Jul-2020	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - NAGANATHPUTRA 220	ELECTRONIC CITY P2 S2, BIOCON(EHT)	14:11	15:09	00:58	MAIN SUPPLY FAILURE
941	27-Jul-2020	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - KEONIC CITY	ELECTRONIC CITY P2 S2, BIOCON(EHT)	16:12	16:29	00:17	MAIN SUPPLY FAILURE
942	27-Jul-2020	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - KEONIC CITY	ELECTRONIC CITY P2 S2, BIOCON(EHT)	17:28	18:06	00:38	LOAD CHANGE OVER
943	27-Jul-2020	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	NO STATION AFFECTED	14:14	18:09	03:55	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
944	27-Jul-2020	BENGALURU	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	13:00	14:00	01:00	LINE CLEAR AVAILED
945	27-Jul-2020	BENGALURU	66	LEELA VENTURE - ADUGODI 1	LEELA VENTURE	13:05	14:24	01:19	LINE CLEAR AVAILED
946	27-Jul-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:33	12:38	00:05	LINE FAULT
947	27-Jul-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:33	12:48	00:15	LINE FAULT
948	27-Jul-2020	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	JIGANI 220, YARANDANAHALLI 220	15:45	21:01	05:16	LINE FAULT
949	27-Jul-2020	BENGALURU	220	JIGANI 220 - SOMANAHALLI 220	JIGANI 220	15:45	16:30	00:45	MAIN SUPPLY FAILURE
950	27-Jul-2020	BENGALURU	220	JIGANI 220 - JIGANI 66	JIGANI 220	17:50	18:18	00:28	LOAD CHANGE OVER
951	27-Jul-2020	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	15:47	16:17	00:30	MAIN SUPPLY FAILURE
952	27-Jul-2020	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	15:47	16:27	00:40	MAIN SUPPLY FAILURE
953	27-Jul-2020	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	15:47	16:25	00:38	MAIN SUPPLY FAILURE
954	27-Jul-2020	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 2	ANEKAL	15:47	16:38	00:51	MAIN SUPPLY FAILURE
955	27-Jul-2020	BENGALURU	66	YERANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	15:47	16:33	00:46	MAIN SUPPLY FAILURE
956	27-Jul-2020	BENGALURU	220	HV2	YERANDANAHALLI 220	15:47	16:15	00:28	MAIN SUPPLY FAILURE
957	27-Jul-2020	BENGALURU	220	HV3	YERANDANAHALLI 220	15:47	16:41	00:54	MAIN SUPPLY FAILURE
958	27-Jul-2020	BENGALURU	66	HV1	YERANDANAHALLI 220	15:47	16:25	00:38	MAIN SUPPLY FAILURE
959	27-Jul-2020	BENGALURU	66	HV3	YERANDANAHALLI 220	15:47	16:25	00:38	MAIN SUPPLY FAILURE
960	27-Jul-2020	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	21:14	21:32	00:18	LINE CLEAR AVAILED
961	27-Jul-2020	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	21:13	21:31	00:18	LINE CLEAR AVAILED
962	27-Jul-2020	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 2	ANEKAL	21:12	21:21	00:09	LINE CLEAR AVAILED
963	27-Jul-2020	BENGALURU	66	YERANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	21:13	21:32	00:19	LINE CLEAR AVAILED
964	27-Jul-2020	BENGALURU	66	HV1	YERANDANAHALLI 220	21:15	21:30	00:15	LINE CLEAR AVAILED
965	27-Jul-2020	BENGALURU	66	HV3	YERANDANAHALLI 220	21:15	21:30	00:15	LINE CLEAR AVAILED
966	27-Jul-2020	BENGALURU	220	YERANDANAHALLI 220 - SOMANAHALLI 220	YERANDANAHALLI 220	15:47	16:15	00:28	LINE FAULT
967	27-Jul-2020	BENGALURU	66	HV1	YEDUMADU	15:35	16:02	00:27	LINE CLEAR AVAILED
968	27-Jul-2020	BENGALURU	66	HV2	YEDUMADU	14:56	15:35	00:38	LINE CLEAR AVAILED
969	27-Jul-2020	BENGALURU	66	HV1	SM MANGALA	11:22	14:36	03:13	LINE CLEAR AVAILED
970	27-Jul-2020	BENGALURU	66	HV2	SM MANGALA	14:04	14:35	00:30	LINE CLEAR AVAILED
971	27-Jul-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:20	15:47	02:27	MAIN SUPPLY FAILURE
972	27-Jul-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:20	15:47	02:30	MAIN SUPPLY FAILURE
973	27-Jul-2020	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:20	15:47	03:30	MAIN SUPPLY FAILURE
974	27-Jul-2020	BENGALURU	220	HV1	VIKAS TECH PARK 220	13:18	15:47	04:30	MAIN SUPPLY FAILURE
975	27-Jul-2020	BENGALURU	220	HV2	VIKAS TECH PARK 220	13:18	15:47	05:30	MAIN SUPPLY FAILURE
976	27-Jul-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:45	13:29	00:44	MAIN SUPPLY FAILURE
977	27-Jul-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:45	13:31	00:46	MAIN SUPPLY FAILURE
978	27-Jul-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:45	13:29	00:44	MAIN SUPPLY FAILURE
979	27-Jul-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	12:45	13:18	00:32	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
980	27-Jul-2020	BENGALURU	220	MALUR 220 - HOODY	SARJAPURA 220, VIKAS TECH PARK 220	12:45	18:01	05:16	LINE FAULT
981	27-Jul-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	12:56	13:18	00:21	MAIN SUPPLY FAILURE
982	27-Jul-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	15:07	16:29	01:21	MAIN SUPPLY FAILURE
983	27-Jul-2020	BENGALURU	66	JIGANI LINK ROAD - SOMANAHALLI 220	JIGANI LINK ROAD	21:18	21:30	00:11	LOAD CHANGE OVER
984	27-Jul-2020	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	16:47	17:33	00:46	LINE FAULT
985	27-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			LINE OPEN ,LINE CLEAR AVAILED
986	27-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN ,LINE FAULT
987	27-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
988	27-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN ,LINE FAULT
989	27-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN ,LINE FAULT
990	27-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN ,LINE CLEAR AVAILED
991	27-Jul-2020	GULBARGA	220	HV2	RAICHUR_220	11:20	12:10	00:50	LINE CLEAR AVAILED
992	27-Jul-2020	GULBARGA	220	HV1	KUSTAGI_220	09:15	09:35	00:20	LINE CLEAR AVAILED
993	27-Jul-2020	GULBARGA	110	HV2	HATTI_110	15:01	15:12	00:11	LINE CLEAR AVAILED
994	27-Jul-2020	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	05:40	05:45	00:05	LINE FAULT
995	27-Jul-2020	GULBARGA	110	HV1	MADIYAL_110	14:15	14:20	00:05	TRANSFORMER FAULT
996	27-Jul-2020	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110	06:17	06:25	00:08	LINE FAULT
997	27-Jul-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	04:10	04:15	00:05	LINE FAULT
998	27-Jul-2020	GULBARGA	110	HV3	HALLIKHED_110	09:40	10:10	00:30	LINE CLEAR AVAILED
999	27-Jul-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	00:40	00:51	00:11	LINE FAULT
1000	27-Jul-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110, BTPSWATERWORKS	02:29	02:39	00:10	LINE FAULT
1001	27-Jul-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110, BTPSWATERWORKS	15:40	15:50	00:10	LINE FAULT
1002	27-Jul-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110, VADAVATTI_110	02:33	02:39	00:06	LINE FAULT
1003	27-Jul-2020	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110, VADAVATTI_110	10:33	11:02	00:29	LINE CLEAR AVAILED
1004	27-Jul-2020	GULBARGA	66	HANASI-ITTAGI	HANASI_66	13:40	15:15	01:35	LINE CLEAR AVAILED
1005	27-Jul-2020	GULBARGA	66	ITTAGI-SUZLON1_IPP	ITTAGI_220	19:00	19:15	00:15	LINE FAULT
1006	27-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:32 (25.07.2020)	9:13 (27.07.2020)	33:45 hrs	LINE CHARGED
1007	27-Jul-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	17:22 (26.07.2020)	6:45 (27.07.2020)	13:22 hrs	LINE CHARGED
1008	27-Jul-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:22 (26.07.2020)	6:45 (27.07.2020)	24:07 hrs	LINE CHARGED
1009	27-Jul-2020	HASSAN	220	HV2	GOPALPURA_220	16:28 (26.07.2020)	16:10 (27.07.2020)	32:38 hrs	LINE CHARGED
1010	27-Jul-2020	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	0:23 (26.07.2020)			LINE OPEN ,LINE CLEAR AVAILED
1011	27-Jul-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	11:02	14:40	03:38	LINE CLEAR AVAILED
1012	27-Jul-2020	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	09:38	12:01	02:23	HAND TRIPPED
1013	27-Jul-2020	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	16:28	17:16	00:48	HAND TRIPPED
1014	27-Jul-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	09:36	12:00	02:24	LINE CLEAR AVAILED
1015	27-Jul-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	16:28	17:17	00:49	LINE CLEAR AVAILED
1016	27-Jul-2020	HASSAN	110	HV2	BARANGI_110	08:05	08:36	00:31	LINE CLEAR AVAILED
1017	27-Jul-2020	HASSAN	110	HV2	BHADRAVATHI_110	11:56	14:00	02:04	LINE CLEAR AVAILED
1018	27-Jul-2020	HASSAN	110	HV2	MANIPAL_110	11:43	12:28	00:45	LINE CLEAR AVAILED
1019	27-Jul-2020	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	13:26	13:56	00:30	LINE FAULT
1020	27-Jul-2020	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	13:18	14:33	01:15	LINE CLEAR AVAILED
1021	27-Jul-2020	HASSAN	66	HV1	KUDLIGERE_66	11:43	13:30	01:47	LINE CLEAR AVAILED
1022	27-Jul-2020	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:31	13:56	00:25	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1023	27-Jul-2020	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	13:26	14:14	00:48	LINE FAULT
1024	27-Jul-2020	HASSAN	66	HV1	SINGAPURA_66	12:15	12:55	00:40	LINE CLEAR AVAILED
1025	27-Jul-2020	HASSAN	66	HV2	SINGAPURA_66	13:07	13:30	00:23	LINE CLEAR AVAILED
1026	27-Jul-2020	MYSURU	66	HV1	BETTADHAPURA_66	14:07	14:49	0:41	LINE CLEAR AVAILED
1027	27-Jul-2020	MYSURU	66	HV2	BETTADHAPURA_66	14:07	14:55	0:47	LINE CLEAR AVAILED
1028	27-Jul-2020	MYSURU	66	GUDDENAHALLI-JAKKANAHALLI	GUDDENAHALLI_66	14:53	15:22	0:28	LINE FAULT
1029	27-Jul-2020	MYSURU	66	HV2	HAMPAPURA_66	18:27	18:39	0:11	TRANSFORMER FAULT
1030	27-Jul-2020	MYSURU	66	HANNUR-KUNTHUR	NO STATIONS EFFECTED	16:56	16:59	0:03	HAND TRIPPED
1031	27-Jul-2020	MYSURU	66	HV1	HARADANAHALLI(JAK)_66	11:45	14:32	2:47	LINE CLEAR AVAILED
1032	27-Jul-2020	MYSURU	66	HV2	HARADANAHALLI(JAK)_66	14:30	17:25	2:55	LINE CLEAR AVAILED
1033	27-Jul-2020	MYSURU	66	HV2	HARVEY_66	12:31	12:40	0:09	HAND TRIPPED
1034	27-Jul-2020	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEEKERE_66	12:32	12:39	0:07	LINE FAULT
1035	27-Jul-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	12:26	13:08	0:41	LINE CLEAR AVAILED
1036	27-Jul-2020	MYSURU	66	HV2	MEGALAPURA_66	12:40	13:22	0:42	LINE CLEAR AVAILED
1037	27-Jul-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	19:05	19:09	0:04	LINE FAULT
1038	27-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
1039	27-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN ,LINE FAULT
1040	27-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
1041	27-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
1042	27-Jul-2020	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	11:35	12:52	1:17	LINE CLEAR AVAILED
1043	27-Jul-2020	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 1	ANTHRASANAHALLI_220	15:07	17:58	2:50	LINE FAULT
1044	27-Jul-2020	TUMKUR	110	TR-1	BANDIHALLI_110	9:44	10:50	1:05	LINE CLEAR AVAILED
1045	27-Jul-2020	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	11:35	12:53	1:17	LINE CLEAR AVAILED
1046	27-Jul-2020	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	14:43	17:21	2:37	LINE FAULT
1047	27-Jul-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	18:59	19:13	0:13	LINE FAULT
1048	27-Jul-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:59	19:17	0:17	LINE FAULT
1049	27-Jul-2020	TUMKUR	66	HARAPPANAHALLI-ITTAGI	HARAPPANAHALLI_66	18:52	19:12	0:19	HAND TRIPPED
1050	27-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:33	6:37	0:04	LINE FAULT
1051	27-Jul-2020	TUMKUR	66	TR-1	MATHOD_66	6:19	6:24	0:04	TRANSFORMER FAULT
1052	27-Jul-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI(PR PURA)	RANGENAHALLI_66	7:33	17:47	10:13	HAND TRIPPED
1053	27-Jul-2020	TUMKUR	66	SASALUHALLA-CKJRKUTT	SASALUHALLA_66	11:27	13:11	1:44	LINE CLEAR AVAILED