

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 22.10.2019 TO 28.10.2019

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	22-Oct-19	BAGALKOT	220	220/110KV,HV1&LV1	BELGAUM_220,VADAGAON_110,B ELGAUM_110,KANABARGI LAYOUT_110,UCHAGAON_110,UD YAMABAGHA_110,ANKALAGI_110, HUDALI_110,ISLAMPUR_110	3:56	4:32	0:36	TRANSFORMER FAULT
2	22-Oct-19	BAGALKOT	220	220/110KV,HV2&LV2	BELGAUM_220	3:56	4:18	0:22	TRANSFORMER FAULT
3	22-Oct-19	BAGALKOT	220	MUDASHINGI-CHIKKODI	CHIKKODI_220	7:59	18:34	10:35	LINE FAULT
4	22-Oct-19	BAGALKOT	220	TALANDAGI-CHIKKODI	CHIKKODI_220	9:26	20:02	10:36	LINE CLEAR AVAILED
5	22-Oct-19	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	3:42	3:50	0:08	LINE FAULT
6	22-Oct-19	BAGALKOT	110	RON1-GAJENDRAGAD	GAJENDRAGAD_110	0:00	10:17	10:17	LINE CLEAR AVAILED
7	22-Oct-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	17:34	18:23	0:49	LINE CLEAR AVAILED
8	22-Oct-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	21:58	22:11	0:13	LINE FAULT
9	22-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	0:00	8:08	8:08	LINE CLEAR AVAILED
10	22-Oct-19	BAGALKOT	110	110/33KV,HV3	GOKAK_110,RIDHISIDDI_33,GOKAK SUGARS_33	17:34	18:37	1:03	LINE CLEAR AVAILED
11	22-Oct-19	BAGALKOT	110	110/11KV,HV1&HV2	GOKAK_110	17:34	18:37	1:03	LINE CLEAR AVAILED
12	22-Oct-19	BAGALKOT	110	110/33KV,HV3	GOKAK_110,RIDHISIDDI_33,GOKAK SUGARS_33	21:58	22:15	0:17	TRANSFORMER FAULT
13	22-Oct-19	BAGALKOT	110	110/11KV,HV1&HV2	GOKAK_110	21:58	22:10	0:12	TRANSFORMER FAULT
14	22-Oct-19	BAGALKOT	110	110/11KV,HV1	GOPPANAKOPPA_110	12:35	14:47	2:12	LINE CLEAR AVAILED
15	22-Oct-19	BAGALKOT	220	220/110KV,HV2&LV2	HAVERI_220	10:38	16:42	6:04	LINE CLEAR AVAILED
16	22-Oct-19	BAGALKOT	110	MAHALINGAPUR220- HIDIKAL	HIDIKAL_110	12:37	23:59	11:22	LINE CLEAR AVAILED
17	22-Oct-19	BAGALKOT	110	RAIBAG-HIDIKAL	HIDIKAL_110	17:51	18:12	0:21	MAIN SUPPLY FAILURE
18	22-Oct-19	BAGALKOT	110	SHIRAGUPPI SUGARS- KAGAWADA	KAGAWADA_110	4:41	4:53	0:12	LINE FAULT
19	22-Oct-19	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	11:21	11:44	0:23	LINE CLEAR AVAILED
20	22-Oct-19	BAGALKOT	110	KARWAR220-SOLARIS	KARWAR_220	0:00	18:26	18:26	LINE CLEAR AVAILED
21	22-Oct-19	BAGALKOT	110	110/33KV,HV2	LAKAMANAHALLI_110,HALANAVA R_33	0:00	16:23	16:23	LINE CLEAR AVAILED
22	22-Oct-19	BAGALKOT	110	LAXMESHVAR-BELLATTI	BELLATTI_110	0:00	1:16	1:16	LINE CLEAR AVAILED
23	22-Oct-19	BAGALKOT	110	110/11KV,HV2	YELPARHATTI_110	15:15	15:57	0:42	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
24	22-Oct-19	BAGALKOT	110	UGAR KHUD-KAGAWAD	KAGAWAD_110	4:34	4:37	0:03	LINE FAULT
25	22-Oct-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	0:00	7:00	7:00	LINE CLEAR AVAILED
26	22-Oct-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	11:41	15:34	3:53	LINE CLEAR AVAILED
27	22-Oct-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	0:00	15:11	15:11	LINE CLEAR AVAILED
28	22-Oct-19	BAGALKOT	110	110/33KV,HV3	SINDAGI_110,GOLAGERI_33KV,KALKERI_33KV	14:38	15:08	0:30	LINE CLEAR AVAILED
29	22-Oct-19	BAGALKOT	110	110/33KV,HV4	SINDAGI_110	14:38	15:08	0:30	LINE CLEAR AVAILED
30	22-Oct-19	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	3:38	5:51	2:13	LINE FAULT
31	22-Oct-19	BAGALKOT	220	NARENDRA-BELGAUM2	NARENDRA_220	3:38	5:52	2:14	LINE FAULT
32	22-Oct-19	BAGALKOT	110	RAIBAG-ITNAL1&2	ITNAL_110	12:54	17:50	4:56	LINE CLEAR AVAILED
33	22-Oct-19	BAGALKOT	110	110/11KV,HV1	PG HUNSHYAL_110	22:24	23:59	1:35	LINE CLEAR AVAILED
34	22-Oct-19	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)_110	9:03	13:31	4:28	LINE CLEAR AVAILED
35	22-Oct-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:00	9:05	9:05	LINE CLEAR AVAILED
36	22-Oct-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	23:14	23:59	0:45	HAND TRIPPED
37	22-Oct-19	BAGALKOT	110	110/11KV,HV1	MK HUBLI_110	15:50	16:20	0:30	LINE CLEAR AVAILED
38	22-Oct-19	BAGALKOT	110	110/11KV,HV2	MK HUBLI_110	16:25	16:45	0:20	LINE CLEAR AVAILED
39	22-Oct-19	BAGALKOT	220	220/110KV,HV1,LV1	MAHALINGAPUR_220	10:25	14:25	4:00	LINE CLEAR AVAILED
40	22-Oct-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	16:20	23:59	7:39	LINE CLEAR AVAILED
41	22-Oct-19	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220	12:45	16:30	3:45	LINE CLEAR AVAILED
42	22-Oct-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	6:27	6:48	0:21	LINE FAULT
43	22-Oct-19	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABAKAVI_110	16:28	18:05	1:37	LINE CLEAR AVAILED
44	22-Oct-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:36	23:59	0:23	HAND TRIPPED
45	22-Oct-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	8:52	16:43	7:51	LINE CLEAR AVAILED
46	22-Oct-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_220	16:33	18:19	1:46	LINE CLEAR AVAILED
47	22-Oct-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	8:51	16:43	7:52	NFBC ISSUED
48	22-Oct-19	HASSAN	110	ALKOLA-MRS	ALKOLA_110	12:08	15:05	2:57	LINE CLEAR AVAILED
49	22-Oct-19	HASSAN	110	HV1	GERUMARA_110	13:57	14:51	0:54	LINE CLEAR AVAILED
50	22-Oct-19	HASSAN	110	HV2	GERUMARA_110	13:20	13:53	0:33	LINE CLEAR AVAILED
51	22-Oct-19	HASSAN	110	KAVOOR-AMR	KAVOOR_220	10:32	13:14	2:42	LINE CLEAR AVAILED
52	22-Oct-19	HASSAN	110	MRSSHM-SS1	MRSMSG_220	12:07	15:05	2:58	LINE CLEAR AVAILED
53	22-Oct-19	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	12:30	13:38	1:08	LINE CLEAR AVAILED
54	22-Oct-19	HASSAN	110	HV1	SHIVAPURA_110	15:01	15:35	0:34	LINE CLEAR AVAILED
55	22-Oct-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:03	14:05	0:02	HAND TRIPPED
56	22-Oct-19	HASSAN	66	CHANNARA-CRPATNA1	CHANNARAYAPATNA_66	12:12	14:18	2:06	LINE CLEAR AVAILED
57	22-Oct-19	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	12:29	15:54	3:25	LINE FAULT
58	22-Oct-19	HASSAN	66	HASSN220-MALLALI	HASSAN_220	18:04	18:38	0:34	HAND TRIPPED
59	22-Oct-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	8:34	8:43	0:09	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
60	22-Oct-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	8:45	8:55	0:10	LINE FAULT
61	22-Oct-19	HASSAN	66	HV2	HNPURA_66	11:40	12:50	1:10	LINE CLEAR AVAILED
62	22-Oct-19	HASSAN	66	HV1	KANDLI_66	11:18	12:29	1:11	LINE CLEAR AVAILED
63	22-Oct-19	HASSAN	66	HV2	KANDLI_66	12:14	13:08	0:54	LINE CLEAR AVAILED
64	22-Oct-19	MYSORE	66	HV1	HOOTAGALLY_220	12:52	12:56	0:04	HAND TRIPPED
65	22-Oct-19	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 KESLAGERE_66 BASARALU_66 SHIVALLY_66 ADICHUNCHANAGIRI_66 VADERALLI_66	2:32	2:40	0:08	LINE FAULT
66	22-Oct-19	TUMKUR	66	DAVANGERE SRS-GUTTUR66	GUTTUR_66	23:28	23:37	0:09	LINE FAULT
67	22-Oct-19	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	15:38	16:00	0:22	LINE CLEAR AVAILED
68	22-Oct-19	TUMKUR	66	NITRAHALLI 66 -CLEAN SOLAR	CLEANMAXSOLAR_IPP_66	15:32	17:50	2:18	LINE CLEAR AVAILED
69	22-Oct-19	TUMKUR	66	TR-2	NITRAHALLI_66	15:32	17:10	1:37	LINE CLEAR AVAILED
70	22-Oct-19	TUMKUR	66	TR-2	NITRAHALLI_66	21:02	21:15	0:13	HAND TRIPPED
71	23-Oct-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	0:58	1:10	0:12	LINE FAULT
72	23-Oct-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	5:32	5:46	0:14	LINE FAULT
73	23-Oct-19	BAGALKOT	220	220/110KV,HV1&LV1	BELGAUM_220	8:02	8:31	0:29	LINE CLEAR AVAILED
74	23-Oct-19	BAGALKOT	110	BELGAUM220-ANKALAGI(HUDLI)	ANKALAGI_110	7:29	8:35	1:06	LINE CLEAR AVAILED
75	23-Oct-19	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	5:32	13:10	7:38	LINE FAULT
76	23-Oct-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	0:00	7:29	7:29	LINE CLEAR AVAILED
77	23-Oct-19	BAGALKOT	220	GADAG-BAGALKOT2	GADAG_220	7:09	8:13	1:04	LINE FAULT
78	23-Oct-19	BAGALKOT	110	GADAG220-DAMBAL	DAMBAL_110	7:08	11:12	4:04	LINE FAULT
79	23-Oct-19	BAGALKOT	110	110/33KV,HV2	GADAG_110,HULAKOTI_33,LAKUNDI_33,HIDIKAL1&2_33	12:45	12:55	0:10	TRANSFORMER FAULT
80	23-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	0:59	1:31	0:32	LINE FAULT
81	23-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	14:15	23:59	9:44	LINE CLEAR AVAILED
82	23-Oct-19	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWADA	KAGAWADA_110	1:00	1:10	0:10	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
83	23-Oct-19	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWADA	KAGAWADA_110	5:30	5:40	0:10	LINE FAULT
84	23-Oct-19	BAGALKOT	110	110/11KV,HV1	KHANAPUR_110	12:45	19:40	6:55	LINE CLEAR AVAILED
85	23-Oct-19	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	16:50	18:55	2:05	MAIN SUPPLY FAILURE
86	23-Oct-19	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	14:20	15:29	1:09	LINE CLEAR AVAILED
87	23-Oct-19	BAGALKOT	110	110/33KV,HV2	GADAG_110,HULAKOTI_33,LAKUNDI_33,HIDIKAL1&2_33	15:15	15:20	0:05	TRANSFORMER FAULT
88	23-Oct-19	BAGALKOT	110	110/11KV,HV2	ZALKI_110	22:51	23:59	1:08	TRANSFORMER FAULT
89	23-Oct-19	BAGALKOT	110	KIRUVATTI-UMMACHAG	UMMACHAGI_110	10:55	18:19	7:24	NFBC ISSUED
90	23-Oct-19	BAGALKOT	110	SOUDATTI 220-UDIKERI	UDIKERI_110	9:05	10:51	1:46	LINE CLEAR AVAILED
91	23-Oct-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	0:00	7:35	7:35	LINE CLEAR AVAILED
92	23-Oct-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	8:09	8:21	0:12	LINE FAULT
93	23-Oct-19	BAGALKOT	110	110/33KV,HV3	RANEENNUR_220,RSNG_33KV,KUPPELUR_33KV	10:15	17:17	7:02	LINE CLEAR AVAILED
94	23-Oct-19	BAGALKOT	110	110/33KV,HV4	RANEENNUR_220,GUDURMAIDUR_33KV,HALGERI_33KV	10:16	17:17	7:01	LINE CLEAR AVAILED
95	23-Oct-19	BAGALKOT	110	110/11KV,HV1	PG HUNSHYAL_110	0:00	8:18	8:18	LINE CLEAR AVAILED
96	23-Oct-19	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	2:45	5:53	3:08	LINE FAULT
97	23-Oct-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:00	6:25	6:25	LINE CLEAR AVAILED
98	23-Oct-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	22:55	23:59	1:04	HAND TRIPPED
99	23-Oct-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	0:18	8:31	8:13	LINE CLEAR AVAILED
100	23-Oct-19	BAGALKOT	110	110/33KV,HV3	SINDAGI_110,MYTRA SOLAR_33	14:13	17:30	3:17	LINE CLEAR AVAILED
101	23-Oct-19	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	10:48	11:46	0:58	LINE CLEAR AVAILED
102	23-Oct-19	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	12:06	13:03	0:57	LINE CLEAR AVAILED
103	23-Oct-19	BENGALURU	66	JAYADEVA-NIMHANS 220	JAYADEVA	17:36	17:41	0:05	LINE FAULT
104	23-Oct-19	BENGALURU	66	NGEF-BAGHMANE WORLD TECH PARK	NGEF,NGEF (EHT)	12:17	14:40	2:23	LINE CLEAR AVAILED
105	23-Oct-19	BENGALURU	66	HV2	NIMHANS	12:23	14:39	2:16	LINE CLEAR AVAILED
106	23-Oct-19	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 1 & 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	15:40	16:25	0:45	LINE CLEAR AVAILED
107	23-Oct-19	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	18:08	18:56	0:48	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
108	23-Oct-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	17:21	17:49	0:28	LINE FAULT
109	23-Oct-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	15:35	15:40	0:05	LINE CLEAR AVAILED
110	23-Oct-19	BENGALURU	66	KOLAR 220 - NARASAPURA	NARASAPURA	15:35	15:40	0:05	LINE CLEAR AVAILED
111	23-Oct-19	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	15:35	15:40	0:05	LINE CLEAR AVAILED
112	23-Oct-19	BENGALURU	220	MALUR 220 - HOODY 220	MALUR 220	7:02	7:09	0:07	LOAD CHANGE OVER
113	23-Oct-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	7:02	7:15	0:13	LOAD CHANGE OVER
114	23-Oct-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	7:02	7:15	0:13	LOAD CHANGE OVER
115	23-Oct-19	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	7:02	7:15	0:13	LOAD CHANGE OVER
116	23-Oct-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	7:02	7:15	0:13	LOAD CHANGE OVER
117	23-Oct-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	7:02	7:20	0:18	LOAD CHANGE OVER
118	23-Oct-19	BENGALURU	66	HV2	NARASAPURA	12:24	13:00	0:36	LINE CLEAR AVAILED
119	23-Oct-19	BENGALURU	66	SIDLAGHATTA-CHINTAMANI 220	SIDLAGHATTA, MELUR	9:54	9:59	0:05	LINE CLEAR AVAILED
120	23-Oct-19	GULBARGA	110	BETAGERA-KESHAVCMNT_SLR_IPP	BETAGERA_110	7:07	7:17	0:10	LINE FAULT
121	23-Oct-19	GULBARGA	110	DAMBAL-BETAGERA	BETAGERA_110	7:17	7:22	0:05	LINE FAULT
122	23-Oct-19	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	10:50	14:14	3:24	MAIN SUPPLY FAILURE
123	23-Oct-19	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	11:30	14:14	2:44	NFBC ISSUED
124	23-Oct-19	GULBARGA	110	HV1	PD_HALLI_110	14:14	15:38	1:24	LINE CLEAR AVAILED
125	23-Oct-19	GULBARGA	110	HV2	SHORAPUR_110	9:51	10:04	0:13	TRANSFORMER FAULT
126	23-Oct-19	GULBARGA	110	LV1, LV2	ALIPUR_220	10:44	14:04	3:20	LINE CLEAR AVAILED
127	23-Oct-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANAGALLU_110, KUDITINI_110, KURUGOD_110, SHATHAVAHANA_I PP, AGARWAL_IPP, SUZLON_IPP, KAMALPUR_110, MATRI_110, RBNS FACTORY	15:56	16:13	0:17	LINE FAULT
128	23-Oct-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KARAGATI_110, SRERAMNAGAR_110, GANGAVATHI_110, VENKATAGIRI_110	11:35	11:45	0:10	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
129	23-Oct-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KARAGATI_110,SRERAMNAGAR_110,GANGAVATHI_110,VENKATAGIRI_110	14:00	16:30	2:30	LINE CLEAR AVAILED
130	23-Oct-19	GULBARGA	110	SINDHANOOR-RAIHCUR1	SINDHANOOR_110	19:10	19:20	0:10	LINE FAULT
131	23-Oct-19	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	10:04	10:07	0:03	LINE CLEAR AVAILED
132	23-Oct-19	GULBARGA	66	ITTAGI-SUZLON1_IPP, SUZLON2_IPP	ITTAGI_220	11:18	14:28	3:10	LINE CLEAR AVAILED
133	23-Oct-19	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66,KUDLIGI_66,HANASI_66,	14:48	14:54	0:06	LINE FAULT
134	23-Oct-19	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANAVEKAL_66,CHORNOOR_66	14:48	14:54	0:06	LINE FAULT
135	23-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	8:57	8:57	LINE CLEAR AVAILED
136	23-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:15	23:59	1:44	LINE CLEAR AVAILED
137	23-Oct-19	HASSAN	220	HASSN22-CHIKMGLRE	HASSAN_220	15:45	16:30	0:45	LINE CLEAR AVAILED
138	23-Oct-19	HASSAN	220	ARSK2-SHMG	ARSK2	13:38	18:15	4:37	LINE CLEAR AVAILED
139	23-Oct-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:15	11:57	1:42	LINE CLEAR AVAILED
140	23-Oct-19	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	13:38	18:15	4:37	LINE CLEAR AVAILED
141	23-Oct-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	12:34	16:50	4:16	LINE CLEAR AVAILED
142	23-Oct-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	20:46	20:55	0:09	LINE FAULT
143	23-Oct-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	19:30	19:48	0:18	LINE CLEAR AVAILED
144	23-Oct-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:14	11:57	1:43	NFBC ISSUED
145	23-Oct-19	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	20:46	20:55	0:09	LINE FAULT
146	23-Oct-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	19:30	19:48	0:18	LINE CLEAR AVAILED
147	23-Oct-19	HASSAN	110	HV2	GANDSI_110	11:47	13:22	1:35	LINE CLEAR AVAILED
148	23-Oct-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	11:48	14:04	2:16	LINE CLEAR AVAILED
149	23-Oct-19	HASSAN	110	HV2	KONAJE_110	10:32	13:29	2:57	LINE CLEAR AVAILED
150	23-Oct-19	HASSAN	110	HV3	KONAJE_110	10:32	12:39	2:07	LINE CLEAR AVAILED
151	23-Oct-19	HASSAN	110	MRSSHM-MPM	MRSMSG_220	8:49	12:31	3:42	LINE CLEAR AVAILED
152	23-Oct-19	HASSAN	110	HV1	CHANDRAGUTTI_110	11:43	14:00	2:17	LINE CLEAR AVAILED
153	23-Oct-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	15:51	15:53	0:02	HAND TRIPPED
154	23-Oct-19	HASSAN	66	HV1	HARIHARAPURA_66	14:16	14:22	0:06	MAIN SUPPLY FAILURE
155	23-Oct-19	HASSAN	66	HARIHAR-KADUVINKOTE	HARIHARAPURA_66	14:16	14:21	0:05	MAIN SUPPLY FAILURE
156	23-Oct-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	14:04	14:19	0:15	HAND TRIPPED
157	23-Oct-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	14:37	19:04	4:27	LINE CLEAR AVAILED
158	23-Oct-19	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	15:00	19:27	4:27	NFBC ISSUED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
159	23-Oct-19	HASSAN	66	HV2	UDAYAPURA_66	13:57	14:10	0:13	TRANSFORMER FAULT
160	23-Oct-19	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	11:51	14:38	2:47	LINE CLEAR AVAILED
161	23-Oct-19	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	11:35	13:20	1:45	LINE CLEAR AVAILED
162	23-Oct-19	HASSAN	66	HASSN22-BELUR	HASSAN_220	10:05	13:28	3:23	LINE CLEAR AVAILED
163	23-Oct-19	HASSAN	66	HASSN22-SUZLON	HASSAN_220	10:05	10:35	0:30	LINE CLEAR AVAILED
164	23-Oct-19	HASSAN	66	HASSN22-SUZLON	HASSAN_220	13:35	13:45	0:10	HAND TRIPPED
165	23-Oct-19	HASSAN	66	HASSN22-CRP1	HASSAN_220	10:05	12:50	2:45	LINE CLEAR AVAILED
166	23-Oct-19	HASSAN	66	HASSN22-SKP2	HASSAN_220	11:06	12:45	1:39	LINE CLEAR AVAILED
167	23-Oct-19	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	10:05	13:45	3:40	LINE CLEAR AVAILED
168	23-Oct-19	HASSAN	66	LV2	HASSAN_220	10:05	13:25	3:20	LINE CLEAR AVAILED
169	23-Oct-19	MYSORE	66	HV1	ARAKERE_66	12:26	13:00	0:33	LINE CLEAR AVAILED
170	23-Oct-19	MYSORE	66	CHIKKMANDYA-HAMPAPURA	BESAGARAHALLI_66, HAMPAPURA_66, KOPPA_66	7:11	7:28	0:17	LINE FAULT
171	23-Oct-19	MYSORE	66	HV2	GUNDULPET_66	11:42	12:28	0:46	LINE CLEAR AVAILED
172	23-Oct-19	MYSORE	66	HAMPAPURA(K)-SARAGURU 1	HAMPAPURA(K)_66	12:10	13:25	1:15	HAND TRIPPED
173	23-Oct-19	MYSORE	66	HV1	JAKKANAHALLY_66	6:40	19:40	13:00	LINE CLEAR AVAILED
174	23-Oct-19	MYSORE	66	HV1	JAKKANAHALLY_66	20:00	20:15	0:15	LINE CLEAR AVAILED
175	23-Oct-19	MYSORE	66	HV1	K_HONNALGERE_66	12:24	14:10	1:45	LINE CLEAR AVAILED
176	23-Oct-19	MYSORE	66	HV3	KRPET_66	11:46	12:27	0:41	LINE CLEAR AVAILED
177	23-Oct-19	MYSORE	66	HV1	RAVANDUR_66	15:52	16:05	0:12	LINE CLEAR AVAILED
178	23-Oct-19	TUMKUR	220	KB CROSS 220kV-SHIMOGA1	KBCROSS_220	12:34	16:52	4:17	LINE CLEAR AVAILED
179	23-Oct-19	TUMKUR	66	TR-2	BENNEHALLI_66	6:06	6:18	0:11	TRANSFORMER FAULT
180	23-Oct-19	TUMKUR	66	DAVANGERE SRS-GUTTUR66	GUTTUR_66	0:50	0:56	0:05	LINE FAULT
181	23-Oct-19	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	8:53	11:01	2:08	LINE FAULT
182	23-Oct-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	14:31	14:38	0:06	HAND TRIPPED
183	23-Oct-19	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAG UNDA_66	12:26	13:38	1:11	LINE FAULT
184	24-Oct-19	BAGALKOT	110	KIADB BIJAPUR-BHUTHNAL	BHUTHNAL_110	6:00	6:50	0:50	MAIN SUPPLY FAILURE
185	24-Oct-19	BAGALKOT	110	KIADB BIJAPUR-BHUTHNAL	BHUTHNAL_110	8:56	13:54	4:58	LINE CLEAR AVAILED
186	24-Oct-19	BAGALKOT	110	BHUTHNAL-TIKOTA	TIKOTA_110	8:56	13:54	4:58	LINE CLEAR AVAILED
187	24-Oct-19	BAGALKOT	110	BHUTHNAL-THORVI	THORVI_110	8:56	13:54	4:58	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
188	24-Oct-19	BAGALKOT	110	BHUTHNAL-TAKKALKI	TAKKALKI_110	8:56	13:54	4:58	LINE CLEAR AVAILED
189	24-Oct-19	BAGALKOT	110	110/11KV,HV1&HV2	BHUTHNAL_110	9:00	16:33	7:33	LINE CLEAR AVAILED
190	24-Oct-19	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	12:50	23:59	11:09	LINE FAULT
191	24-Oct-19	BAGALKOT	220	BIJAPUR-BAGEWADI1	BIJAPUR_220	6:03	23:59	17:56	LINE FAULT
192	24-Oct-19	BAGALKOT	220	BIJAPUR-BAGEWADI2	BIJAPUR_220	6:03	6:50	0:47	HAND TRIPPED
193	24-Oct-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	17:26	17:26	LINE CLEAR AVAILED
194	24-Oct-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	18:13	23:59	5:46	LINE FAULT
195	24-Oct-19	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	19:08	23:59	4:51	LINE CLEAR AVAILED
196	24-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	0:00	9:02	9:02	LINE CLEAR AVAILED
197	24-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	14:33	23:59	9:26	LINE CLEAR AVAILED
198	24-Oct-19	BAGALKOT	220	220/110KV,HV2&LV2	HAVERI_220	11:58	17:03	5:05	LINE CLEAR AVAILED
199	24-Oct-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	MAHALINGAPUR_220	10:11	16:49	6:38	LINE CLEAR AVAILED
200	24-Oct-19	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	11:24	11:48	0:24	LINE CLEAR AVAILED
201	24-Oct-19	BAGALKOT	110	GAMESH-KULIGOD	KULIGOD_110	12:38	12:41	0:03	HAND TRIPPED
202	24-Oct-19	BAGALKOT	66	66/33KV,HV4	HARIHAR HOSPET_66,AREMALLAPUR_33	7:10	7:30	0:20	LOAD CURTAILMENT
203	24-Oct-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	10:41	18:25	7:44	LINE CLEAR AVAILED
204	24-Oct-19	BAGALKOT	220	HUBLI-BIDNAL2	HUBLI_220	12:51	13:26	0:35	LINE FAULT
205	24-Oct-19	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	0:00	9:20	9:20	LINE CLEAR AVAILED
206	24-Oct-19	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	18:56	23:59	5:03	LINE CLEAR AVAILED
207	24-Oct-19	BAGALKOT	220	220/110KV,HV1	RANEBENNUR_220	13:15	20:05	6:50	LINE CLEAR AVAILED
208	24-Oct-19	BAGALKOT	110	110/11KV,HV2	RANEBENNUR_220	11:15	17:38	6:23	LINE CLEAR AVAILED
209	24-Oct-19	BAGALKOT	110	HIREKERUR-RATTIHAL	RATTIHAL_110	20:14	23:59	3:45	LINE CLEAR AVAILED
210	24-Oct-19	BAGALKOT	110	BALAGI SUGARS-MUDDEBIHAL	MUDDEBIHAL_110	11:51	13:11	1:20	LINE CLEAR AVAILED
211	24-Oct-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:00	9:14	9:14	LINE CLEAR AVAILED
212	24-Oct-19	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110,LINGADALLI_33KV,DEVAR GENNUR_33KV	13:07	13:29	0:22	LINE CLEAR AVAILED
213	24-Oct-19	BAGALKOT	110	MUNAVALLI-ARATGAL	ARATGAL_110	11:56	12:40	0:44	LINE CLEAR AVAILED
214	24-Oct-19	BAGALKOT	110	SIRSI1-KUMTA	KUMTA_110	16:12	17:17	1:05	HAND TRIPPED
215	24-Oct-19	BAGALKOT	110	110/33KV.HV1	KUMTA_110,HONNAVAR_33KV,AN KOLA_33KV	22:07	23:59	1:52	TRANSFORMER FAULT
216	24-Oct-19	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	13:30	13:35	0:05	LOAD CHANGE OVER
217	24-Oct-19	BENGALURU	66	GOKULA-HEBBAL 220	GOKULA, BEL (EHT), HMT (EHT)	15:13	15:16	0:03	LOAD CHANGE OVER
218	24-Oct-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	13:25	13:30	0:05	LOAD CHANGE OVER
219	24-Oct-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	15:12	15:18	0:06	LOAD CHANGE OVER

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
220	24-Oct-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	1:23	2:44	1:21	LINE FAULT
221	24-Oct-19	BENGALURU	66	SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	18:20	18:40	0:20	LINE FAULT
222	24-Oct-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	22:02	22:04	0:02	LOAD CHANGE OVER
223	24-Oct-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	13:16	13:20	0:04	LOAD CHANGE OVER
224	24-Oct-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	15:23	15:27	0:04	LOAD CHANGE OVER
225	24-Oct-19	BENGALURU	66	HV2	NRS	12:59	13:04	0:05	LOAD CHANGE OVER
226	24-Oct-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	12:45	12:50	0:05	LOAD CHANGE OVER
227	24-Oct-19	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	15:10	15:15	0:05	LOAD CHANGE OVER
228	24-Oct-19	BENGALURU	66	V R DODDI-T K HALLI 220	V R DODDI	12:10	12:15	0:05	LOAD CHANGE OVER
229	24-Oct-19	BENGALURU	66	V R DODDI-SOMANAHALLI 220	V R DODDI	17:05	17:10	0:05	LOAD CHANGE OVER
230	24-Oct-19	BENGALURU	66	AGALAKOTE-ANCHEPALYA 220	AGALAKOTE	9:15	13:40	4:25	LINE CLEAR AVAILED
231	24-Oct-19	BENGALURU	66	HV1	HOSKOTE	13:19	14:45	1:26	LINE CLEAR AVAILED
232	24-Oct-19	BENGALURU	66	HV1	MELUR	0:59	1:20	0:21	TRANSFORMER FAULT
233	24-Oct-19	BENGALURU	66	WELCAST - SRS PEENYA 220	WELCAST	12:18	12:24	0:06	LOAD CHANGE OVER
234	24-Oct-19	BENGALURU	66	WELCAST-DG3	WELCAST	15:08	15:13	0:05	LOAD CHANGE OVER
235	24-Oct-19	GULBARGA	110	VALAKMDINNI-SINDHANOOR	VALKAMDINNI_110	9:25	9:30	0:05	LINE CLEAR AVAILED
236	24-Oct-19	GULBARGA	110	VALAKMDINNI-SINDHANOOR	VALKAMDINNI_110	11:05	11:10	0:05	LINE CLEAR AVAILED
237	24-Oct-19	GULBARGA	110	HV2	CHINCHOLI_110	7:10	7:20	0:10	LOAD CURTAILMENT
238	24-Oct-19	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGANORTH2	GULBARGAUNIVERSITY_110	16:35	17:10	0:35	LINE CLEAR AVAILED
239	24-Oct-19	GULBARGA	110	HV1	GULBARGAUNIVERSITY_110	17:30	18:10	0:40	LINE CLEAR AVAILED
240	24-Oct-19	GULBARGA	220	LINGASUGUR-MALLAT	LINGASUGUR_220	13:24	14:32	1:08	LINE FAULT
241	24-Oct-19	HASSAN	220	HASSN220-NITTUR	HASSAN_220	13:15	14:42	1:27	LINE CLEAR AVAILED
242	24-Oct-19	HASSAN	220	HV2	HASSAN_220	12:50	14:40	1:50	LINE CLEAR AVAILED
243	24-Oct-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	12:02	20:54	8:52	LINE CLEAR AVAILED
244	24-Oct-19	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	10:00	18:54	8:54	LINE CLEAR AVAILED
245	24-Oct-19	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	10:30	23:59	13:29	LINE CLEAR AVAILED
246	24-Oct-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	9:42	18:53	9:11	LINE CLEAR AVAILED
247	24-Oct-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	12:02	20:54	8:52	LINE FAULT
248	24-Oct-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:27	12:30	2:03	NFBC ISSUED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
249	24-Oct-19	HASSAN	110	BANTWAL-SALATTUR	BANTWAL_110	10:36	13:56	3:20	NFBC ISSUED
250	24-Oct-19	HASSAN	110	HV1	GURUVAYANAKERE_110	9:20	15:45	6:25	LINE CLEAR AVAILED
251	24-Oct-19	HASSAN	110	HV2	GURUVAYANAKERE_110	9:20	15:45	6:25	LINE CLEAR AVAILED
252	24-Oct-19	HASSAN	110	HV3	GURUVAYANAKERE_110	9:20	15:45	6:25	LINE CLEAR AVAILED
253	24-Oct-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	9:20	15:45	6:25	LINE CLEAR AVAILED
254	24-Oct-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	9:20	15:45	6:25	LINE CLEAR AVAILED
255	24-Oct-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	9:23	15:44	6:21	NFBC ISSUED
256	24-Oct-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	9:23	15:43	6:20	NFBC ISSUED
257	24-Oct-19	HASSAN	110	HV2	KONAJE_110	13:35	14:05	0:30	MAIN SUPPLY FAILURE
258	24-Oct-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	13:38	14:28	0:50	MAIN SUPPLY FAILURE
259	24-Oct-19	HASSAN	110	HV2	KUNDAPURA_110	11:16	11:38	0:22	LINE CLEAR AVAILED
260	24-Oct-19	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	19:55	20:05	0:10	LINE CLEAR AVAILED
261	24-Oct-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	14:41	17:14	2:33	NFBC ISSUED
262	24-Oct-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	10:30	13:39	3:09	NFBC ISSUED
263	24-Oct-19	HASSAN	110	HV1	PUTTUR_110	9:45	14:25	4:40	LINE CLEAR AVAILED
264	24-Oct-19	HASSAN	110	HV2	PUTTUR_110	9:44	14:26	4:42	LINE CLEAR AVAILED
265	24-Oct-19	HASSAN	110	HV3	PUTTUR_110	13:47	14:01	0:14	LINE CLEAR AVAILED
266	24-Oct-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:20	16:57	4:37	LINE FAULT
267	24-Oct-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:59	13:45	1:46	LINE CLEAR AVAILED
268	24-Oct-19	HASSAN	66	HV2	HNPURA_66	12:26	12:35	0:09	HAND TRIPPED
269	24-Oct-19	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	13:08	13:20	0:12	MAIN SUPPLY FAILURE
270	24-Oct-19	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	13:09	15:03	1:54	MAIN SUPPLY FAILURE
271	24-Oct-19	HASSAN	66	UDURKO-SUZLON2	UDDURKOPLU_66	12:44	17:39	4:55	LINE FAULT
272	24-Oct-19	HASSAN	66	HASSN220-BELUR	HASSAN_220	12:50	14:40	1:50	LINE CLEAR AVAILED
273	24-Oct-19	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	12:50	13:16	0:26	LINE CLEAR AVAILED
274	24-Oct-19	HASSAN	66	HASSN220-SUZLON1	HASSAN_220	14:42	14:50	0:08	HAND TRIPPED
275	24-Oct-19	HASSAN	66	HASSN220-SUZLON1	HASSAN_220	12:55	13:16	0:21	LINE CLEAR AVAILED
276	24-Oct-19	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	5:50	5:57	0:07	LINE FAULT
277	24-Oct-19	MYSORE	66	HV1	DUNDANAHALLI_66	12:30	12:59	0:29	HAND TRIPPED
278	24-Oct-19	MYSORE	66	HV2	DUNDANAHALLI_66	12:30	12:59	0:29	HAND TRIPPED
279	24-Oct-19	MYSORE	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	10:41	10:51	0:10	LINE FAULT
280	24-Oct-19	MYSORE	66	KUSHALANAGARA 220-PERİYAPATNA-1	HANAGODU_66 PERİYAPATNA_66 PONNAMPET_66 VIRAJPET_66	11:37	12:01	0:24	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
281	24-Oct-19	MYSORE	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	11:37	12:01	0:24	LINE FAULT
282	24-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	11:36	11:47	0:11	TRANSFORMER FAULT
283	24-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	12:04	12:14	0:10	TRANSFORMER FAULT
284	24-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	13:00	13:06	0:06	TRANSFORMER FAULT
285	24-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	15:32	15:46	0:14	TRANSFORMER FAULT
286	24-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	15:55	16:10	0:15	TRANSFORMER FAULT
287	24-Oct-19	MYSORE	66	MAMBALLI-MADHUVANAHALLI	MAMBALLI_66	7:25	7:40	0:15	LINE FAULT
288	24-Oct-19	MYSORE	220	HV2	MADHUVANAHALLI_220	15:26	16:19	0:52	LINE CLEAR AVAILED
289	24-Oct-19	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 1	HANAGODU_66 PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66	10:40	11:00	0:20	LINE FAULT
290	24-Oct-19	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 2	HANAGODU_66 PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66	10:40	11:00	0:20	LINE FAULT
291	24-Oct-19	MYSORE	66	HV1	RAVANDUR_66	14:10	15:30	1:20	LINE CLEAR AVAILED
292	24-Oct-19	MYSORE	66	HV2	SANTHEBACHALLI_66	14:50	16:50	2:00	LINE CLEAR AVAILED
293	24-Oct-19	TUMKUR	66	TR-2	BENNEHALLI_66	17:10	17:14	0:03	LINE CLEAR AVAILED
294	25-Oct-19	BAGALKOT	110	ANKOLA-KUMTA	KUMTA_110	6:01	14:21	8:20	LINE FAULT
295	25-Oct-19	BAGALKOT	110	MAMDAPUR-BABLESHWAR	BABLESHWAR_110	15:55	17:15	1:20	LINE CLEAR AVAILED
296	25-Oct-19	BAGALKOT	110	110/11KV, HV1&HV2	BABLESHWAR_110	15:55	17:15	1:20	LINE CLEAR AVAILED
297	25-Oct-19	BAGALKOT	110	MAMDAPUR-BABLESHWAR	BABLESHWAR_110	17:20	17:25	0:05	HAND TRIPPED
298	25-Oct-19	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	BHUTNAL_110, TIKOTA_110, TAKKALKI_110, TORVI_110	9:00	13:55	4:55	LINE CLEAR AVAILED
299	25-Oct-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	3:30	5:53	2:23	LINE FAULT
300	25-Oct-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	7:01	17:08	10:07	LINE FAULT
301	25-Oct-19	BAGALKOT	220	HARTHI2-BIDNAL	BIDNAL_220	15:32	23:59	8:27	LINE CLEAR AVAILED
302	25-Oct-19	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:00	15:05	15:05	LINE CLEAR AVAILED
303	25-Oct-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	15:04	15:04	LINE CLEAR AVAILED
304	25-Oct-19	BAGALKOT	110	110/33KV,HV4	GADAG_110,HULAKOTI_33,LAKUN DI_33,TDPL_33	15:46	15:50	0:04	TRANSFORMER FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
305	25-Oct-19	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINGAD_33,SOLAR IPP_33,KARADI_33	6:07	6:14	0:07	TRANSFORMER FAULT
306	25-Oct-19	BAGALKOT	110	110/11KV,HV2	KAGAWADA_110	10:31	17:22	6:51	LINE CLEAR AVAILED
307	25-Oct-19	BAGALKOT	110	110/11KV,HV2	KUMTA_110	6:00	7:45	1:45	TRANSFORMER FAULT
308	25-Oct-19	BAGALKOT	110	110/33KV,HV1	KUMTA_110,HONNAVAR_33,ANKOLA_33	0:00	8:04	8:04	LINE CLEAR AVAILED
309	25-Oct-19	BAGALKOT	110	110/33KV,HV1	KUMTA_110,HONNAVAR_33,ANKOLA_33	13:49	15:06	1:17	TRANSFORMER FAULT
310	25-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	0:00	9:02	9:02	LINE CLEAR AVAILED
311	25-Oct-19	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	12:16	17:27	5:11	LINE FAULT
312	25-Oct-19	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110,LINGADAHALLI LIS_33,DEVARA GENNUR_33	4:29	5:51	1:22	TRANSFORMER FAULT
313	25-Oct-19	BAGALKOT	110	BALAJI SUGARS-MUDDEBUHAL	MUDDEBUHAL_110	3:29	4:31	1:02	LINE FAULT
314	25-Oct-19	BAGALKOT	110	KNM SOLAR-MUDDEBUHAL	MUDDEBUHAL_110	3:29	4:30	1:01	LINE FAULT
315	25-Oct-19	BAGALKOT	110	BAGEWADI220-MUDDEBUHAL	MUDDEBUHAL_110	3:29	4:28	0:59	LINE FAULT
316	25-Oct-19	BAGALKOT	110	NARENDRA-BELUR1&2	BELUR_110	12:49	13:26	0:37	LINE FAULT
317	25-Oct-19	BAGALKOT	110	110/11KV,HV2	NAVALGUND_110	13:01	17:34	4:33	LINE CLEAR AVAILED
318	25-Oct-19	BAGALKOT	220	220/110KV,HV2&LV2	RANEBENNUR_220	10:46	15:45	4:59	LINE CLEAR AVAILED
319	25-Oct-19	BAGALKOT	110	RANEBENNUR220-HIREKERUR	HIREKERUR_110	10:10	10:12	0:02	HAND TRIPPED
320	25-Oct-19	BAGALKOT	110	RANEBENNUR220-RATTIHALLI	RATTIHALLI_110	10:12	15:55	5:43	LINE CLEAR AVAILED
321	25-Oct-19	BAGALKOT	110	110/11KV,HV1&HV2	RANEBENNUR_220	10:13	10:46	0:33	HAND TRIPPED
322	25-Oct-19	BAGALKOT	110	110/11KV,HV3&HV4	RANEBENNUR_220,RSNG_33,KUPELLUR_33,GUDURMAIDUR_33,HALAGERI_33	10:13	10:46	0:33	HAND TRIPPED
323	25-Oct-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	3:13	6:57	3:44	LINE CLEAR AVAILED
324	25-Oct-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	3:14	6:56	3:42	LINE CLEAR AVAILED
325	25-Oct-19	BAGALKOT	110	TODALBAGI-33KV GRK SOLAR	SOLAR GRK_33KV	17:45	18:05	0:20	HAND TRIPPED
326	25-Oct-19	BAGALKOT	110	SIRSI-KUMATA 2	SIRSI_110	6:01	13:16	7:15	LINE FAULT
327	25-Oct-19	BAGALKOT	220	SHARAVATHY 2-SIRSI	SIRSI_220	0:00	17:19	17:19	LINE CLEAR AVAILED
328	25-Oct-19	BAGALKOT	220	SHARAVATHY 2-SIRSI	SIRSI_220	17:23	18:09	0:46	HAND TRIPPED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
329	25-Oct-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALAWADA_110	10:55	18:29	7:34	LINE FAULT
330	25-Oct-19	BAGALKOT	110	HIREKERUR-RATTIHALLI	RATTIHALLI_110	0:00	9:36	9:36	LINE CLEAR AVAILED
331	25-Oct-19	BAGALKOT	110	HIREKERUR-RATTIHALLI	RATTIHALLI_110	15:55	23:59	8:04	LINE CLEAR AVAILED
332	25-Oct-19	BENGALURU	66	HV1	BMTC	12:34	13:50	1:16	LINE CLEAR AVAILED
333	25-Oct-19	BENGALURU	66	HV2	SUBRAMANYAPURA 66	11:35	11:38	0:03	LINE CLEAR AVAILED
334	25-Oct-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:49	11:02	0:13	LINE FAULT
335	25-Oct-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:46	16:30	0:44	LINE CLEAR AVAILED
336	25-Oct-19	BENGALURU	66	HV1	PATHPALYA	11:31	12:30	0:59	LINE CLEAR AVAILED
337	25-Oct-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	8:50	9:51	1:01	LINE FAULT
338	25-Oct-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:51	23:59	14:08	LINE FAULT
339	25-Oct-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	11:57	19:18	7:21	LINE CLEAR AVAILED
340	25-Oct-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:44	18:34	7:50	LINE FAULT
341	25-Oct-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	18:40	19:18	0:38	HAND TRIPPED
342	25-Oct-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	19:24	23:59	4:35	LINE CLEAR AVAILED
343	25-Oct-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	19:24	19:57	0:33	HAND TRIPPED
344	25-Oct-19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	19:56	20:00	0:04	HAND TRIPPED
345	25-Oct-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	19:56	20:00	0:04	HAND TRIPPED
346	25-Oct-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	5:04	13:54	8:50	LINE FAULT
347	25-Oct-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	8:44	14:03	5:19	LINE FAULT
348	25-Oct-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	15:31	23:59	8:28	LINE FAULT
349	25-Oct-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	8:50	23:59	15:09	LINE FAULT
350	25-Oct-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:44	18:36	7:52	LINE FAULT
351	25-Oct-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	18:36	19:18	0:42	LINE FAULT
352	25-Oct-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	19:20	23:59	4:39	LINE CLEAR AVAILED
353	25-Oct-19	HASSAN	110	HV1	NITTUR_110	19:55	20:05	0:10	MAIN SUPPLY FAILURE
354	25-Oct-19	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	19:55	20:05	0:10	MAIN SUPPLY FAILURE
355	25-Oct-19	HASSAN	110	HV3	PUTTUR_110	14:18	14:33	0:15	TRANSFORMER FAULT
356	25-Oct-19	HASSAN	110	HV3	PUTTUR_110	15:07	15:11	0:04	LINE CLEAR AVAILED
357	25-Oct-19	HASSAN	110	HV3	BHADRAVATHI_110	9:30	16:10	6:40	LINE CLEAR AVAILED
358	25-Oct-19	HASSAN	110	HV1	GURUVAYANAKERE_110	8:52	9:30	0:38	MAIN SUPPLY FAILURE
359	25-Oct-19	HASSAN	110	HV2	GURUVAYANAKERE_110	8:52	9:30	0:38	MAIN SUPPLY FAILURE

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
360	25-Oct-19	HASSAN	110	HV3	GURUVAYANAKERE_110	8:52	9:30	0:38	MAIN SUPPLY FAILURE
361	25-Oct-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	8:52	9:30	0:38	MAIN SUPPLY FAILURE
362	25-Oct-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	8:52	9:30	0:38	MAIN SUPPLY FAILURE
363	25-Oct-19	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	8:52	9:30	0:38	MAIN SUPPLY FAILURE
364	25-Oct-19	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	8:51	9:33	0:42	MAIN SUPPLY FAILURE
365	25-Oct-19	HASSAN	110	HV1	KULASHEKARA_110	13:29	14:41	1:12	LINE CLEAR AVAILED
366	25-Oct-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	19:56	20:06	0:10	MAIN SUPPLY FAILURE
367	25-Oct-19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	19:57	20:01	0:04	MAIN SUPPLY FAILURE
368	25-Oct-19	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	19:57	20:01	0:04	MAIN SUPPLY FAILURE
369	25-Oct-19	HASSAN	66	HV1	SIGEBAGI_66	10:09	13:01	2:52	LINE CLEAR AVAILED
370	25-Oct-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66, HOSURGATE_66	14:43	15:05	0:21	LINE FAULT
371	25-Oct-19	MYSORE	66	HV2	KOPPA_66	13:50	14:45	0:55	LINE CLEAR AVAILED
372	25-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	1:20	1:25	0:05	TRANSFORMER FAULT
373	25-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	10:58	11:05	0:07	TRANSFORMER FAULT
374	25-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	13:46	13:50	0:04	TRANSFORMER FAULT
375	25-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	14:00	14:13	0:13	TRANSFORMER FAULT
376	25-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	23:20	23:25	0:05	TRANSFORMER FAULT
377	25-Oct-19	MYSORE	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	4:26	4:40	0:14	LINE FAULT
378	25-Oct-19	MYSORE	66	KUSHALANAGARA 220-PERIYAPATNA-1	HANAGODU_66, PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66	4:26	4:40	0:14	LINE FAULT
379	25-Oct-19	MYSORE	66	KUSHALANAGARA 220-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	7:26	9:30	2:04	LINE CLEAR AVAILED
380	25-Oct-19	MYSORE	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	14:04	14:18	0:14	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
381	25-Oct-19	MYSORE	66	KUSHALANAGARA 220-PERIYAPATNA-1	HANAGODU_66, PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66	14:04	14:18	0:14	LINE FAULT
382	25-Oct-19	MYSORE	66	HV3	SFCSHIVA_66	9:41	10:35	0:53	LINE CLEAR AVAILED
383	25-Oct-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66, TARIPURA_66	5:57	6:25	0:28	LINE FAULT
384	25-Oct-19	MYSORE	66	TUBINAKERE-G UKKADA	GARUDANAUKADDA_66, SRIRANGAPATNA_66	5:57	6:13	0:16	HAND TRIPPED
385	25-Oct-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66 KESLAGERE_66	5:57	6:13	0:16	HAND TRIPPED
386	25-Oct-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66, PANDAVAPURA_66	5:57	6:13	0:16	HAND TRIPPED
387	25-Oct-19	MYSORE	66	HV2	TUBINAKERE_220	5:57	6:12	0:15	HAND TRIPPED
388	25-Oct-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	10:47	10:54	0:07	LINE FAULT
389	25-Oct-19	MYSORE	66	HV2	VIRAJPET_66	8:12	8:35	0:23	LINE CLEAR AVAILED
390	25-Oct-19	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	16:49	16:50	0:01	LINE CLEAR AVAILED
391	25-Oct-19	TUMKUR	66	TR-2	BELLAVI_66	16:49	16:50	0:01	LINE CLEAR AVAILED
392	25-Oct-19	TUMKUR	66	DYAVARANAHALLI-CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	20:21	20:34	0:13	LINE FAULT
393	25-Oct-19	TUMKUR	66	TR-2	HINDASGHATTA_66	12:40	13:32	0:52	LINE CLEAR AVAILED
394	25-Oct-19	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:36	14:42	0:06	LINE FAULT
395	26-Oct-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	11:34	16:47	5:13	LINE FAULT
396	26-Oct-19	BAGALKOT	220	ATHANI-MAHALINGAPUR	ATHANI_220	19:32	20:20	0:48	LINE FAULT
397	26-Oct-19	BAGALKOT	110	110/11KV, HV4	BAILHONGAL_110	16:36	17:03	0:27	LINE CLEAR AVAILED
398	26-Oct-19	BAGALKOT	110	110/33KV, HV3	BELUR_110, UAS_33, UDL_33, TATA MMCL_33	16:23	19:25	3:02	TRANSFORMER FAULT
399	26-Oct-19	BAGALKOT	110	SUZLON1-DAMBAL	DAMBAL_110	17:15	17:50	0:35	HAND TRIPPED
400	26-Oct-19	BAGALKOT	110	ENERGAON-DAMBAL	DAMBAL_110	17:15	17:50	0:35	HAND TRIPPED
401	26-Oct-19	BAGALKOT	110	DAMABAL-MUNDARGI2	MUNDARGI_110	17:50	20:45	2:55	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
402	26-Oct-19	BAGALKOT	110	DAMABAL-MUNDARGI1	MUNDARGI_110	17:35	18:50	1:15	LINE CLEAR AVAILED
403	26-Oct-19	BAGALKOT	110	GADAG220-DAMBAL	DAMBAL_110	16:57	17:46	0:49	LINE FAULT
404	26-Oct-19	BAGALKOT	220	HARTHI2-BIDNAL	BIDNAL_220	0:00	15:19	15:19	LINE CLEAR AVAILED
405	26-Oct-19	BAGALKOT	110	GADAG220-SAMBAPUR ROAD	SAMBAPUR ROAD_110	16:57	17:45	0:48	LINE FAULT
406	26-Oct-19	BAGALKOT	220	220/110KV,HV1&LV1	GADAG_220	16:57	17:32	0:35	TRANSFORMER FAULT
407	26-Oct-19	BAGALKOT	110	HUNGUND-JINDAL	HUNGUND_110,JINDAL_110	23:33	23:59	0:26	LINE FAULT
408	26-Oct-19	BAGALKOT	110	HUNGUND-KUDAL SANGAM	KUDAL SANGAM_110	23:33	23:55	0:22	LINE FAULT
409	26-Oct-19	BAGALKOT	110	110/11KV,HV2	KAGAWADA_110	13:56	14:04	0:08	TRANSFORMER FAULT
410	26-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	22:07	23:59	1:52	LINE CLEAR AVAILED
411	26-Oct-19	BAGALKOT	110	DAMABAL-MUNDARGI	MUNDARGI_110	16:59	18:00	1:01	LINE FAULT
412	26-Oct-19	BAGALKOT	110	VIJAYA SUGARS-MUNDARGI	MUNDARGI_110	16:59	18:16	1:17	HAND TRIPPED
413	26-Oct-19	BAGALKOT	110	VIJAYA SUGARS-MUNDARGI	MUNDARGI_110	17:40	20:46	3:06	LINE CLEAR AVAILED
414	26-Oct-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	13:37	23:59	10:22	LINE CLEAR AVAILED
415	26-Oct-19	BAGALKOT	220	HUBLI-NAGJHARI 2	HUBLI_220	12:49	17:09	4:20	LINE FAULT
416	26-Oct-19	BAGALKOT	220	SHARAVATHY 2-SIRSI	SIRSI_220	13:50	23:59	10:09	LINE CLEAR AVAILED
417	26-Oct-19	BENGALURU	66	ANEKAL - ATTIBELE	ANEKAL, SURYANAGAR	12:13	12:32	0:19	LOAD CHANGE OVER
418	26-Oct-19	BENGALURU	66	ANEKAL - YERANDANAHALLI	ANEKAL, SURYANAGAR	18:18	18:38	0:20	LOAD CHANGE OVER
419	26-Oct-19	BENGALURU	66	HV2	JIGANI 66	17:25	17:30	0:05	LINE CLEAR AVAILED
420	26-Oct-19	BENGALURU	66	HV3	JIGANI 66	17:25	17:30	0:05	LINE CLEAR AVAILED
421	26-Oct-19	BENGALURU	66	HV2	JIGANI 66	13:05	13:17	0:12	MAIN SUPPLY FAILURE
422	26-Oct-19	BENGALURU	66	HV3	JIGANI 66	13:05	13:17	0:12	MAIN SUPPLY FAILURE
423	26-Oct-19	BENGALURU	66	HV1	JIGANI 66	18:17	18:45	0:28	MAIN SUPPLY FAILURE
424	26-Oct-19	BENGALURU	66	HV2	JIGANI 66	18:17	18:45	0:28	MAIN SUPPLY FAILURE
425	26-Oct-19	BENGALURU	66	HV3	JIGANI 66	18:17	18:45	0:28	MAIN SUPPLY FAILURE
426	26-Oct-19	BENGALURU	220	YARANDANAHALLI 220 - SOMANAHALLI 220	YERANDANAHALLI 220	18:26	18:32	0:06	LOAD CHANGE OVER

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
427	26-Oct-19	BENGALURU	220	HV1	YERANDANAHALLI 220	18:26	18:32	0:06	MAIN SUPPLY FAILURE
428	26-Oct-19	BENGALURU	220	HV2	YERANDANAHALLI 220	18:26	18:32	0:06	MAIN SUPPLY FAILURE
429	26-Oct-19	BENGALURU	220	HV3	YERANDANAHALLI 220	18:26	18:32	0:06	MAIN SUPPLY FAILURE
430	26-Oct-19	BENGALURU	66	HV2	KADUBISANAHALLI	10:25	18:08	7:43	LINE CLEAR AVAILED
431	26-Oct-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:00	15:55	1:55	LINE CLEAR AVAILED
432	26-Oct-19	BENGALURU	66	RAJANAKUNTE -DB PURA 220	RAJANAKUNTE	21:20	21:25	0:05	LOAD CHANGE OVER
433	26-Oct-19	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	18:07	18:30	0:22	LINE FAULT
434	26-Oct-19	BENGALURU	66	HV1	ATTUR YELAHANKA	12:23	13:05	0:41	TRANSFORMER FAULT
435	26-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	3:33	3:48	0:15	HAND TRIPPED
436	26-Oct-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	3:33	3:54	0:21	MAIN SUPPLY FAILURE
437	26-Oct-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	3:33	5:41	2:08	MAIN SUPPLY FAILURE
438	26-Oct-19	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	3:34	4:13	0:39	MAIN SUPPLY FAILURE
439	26-Oct-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	3:34	4:13	0:39	MAIN SUPPLY FAILURE
440	26-Oct-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	4:19	16:19	12:00	LINE CLEAR AVAILED
441	26-Oct-19	HASSAN	110	HV2	KAVOOR_220	3:34	3:52	0:18	MAIN SUPPLY FAILURE
442	26-Oct-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	0:00	11:54	11:54	LINE FAULT
443	26-Oct-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	0:00	16:26	16:26	LINE CLEAR AVAILED
444	26-Oct-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	16:45	17:21	0:36	HAND TRIPPED
445	26-Oct-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:21	12:26	0:05	HAND TRIPPED
446	26-Oct-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	3:33	4:07	0:34	LINE FAULT
447	26-Oct-19	HASSAN	110	HV1	KEMAR_220	3:33	4:11	0:38	MAIN SUPPLY FAILURE
448	26-Oct-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	3:36	23:59	20:23	MAIN SUPPLY FAILURE
449	26-Oct-19	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	3:33	4:09	0:36	MAIN SUPPLY FAILURE
450	26-Oct-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	3:37	23:59	20:22	MAIN SUPPLY FAILURE

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
451	26-Oct-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	3:37	3:58	0:21	MAIN SUPPLY FAILURE
452	26-Oct-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	3:33	3:55	0:22	MAIN SUPPLY FAILURE
453	26-Oct-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	3:50	5:41	1:51	MAIN SUPPLY FAILURE
454	26-Oct-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	5:00	8:28	3:28	LINE FAULT
455	26-Oct-19	HASSAN	220	MRSSHM-VARAHI1	MRSMSG_220	9:49	14:30	4:41	NFBC ISSUED
456	26-Oct-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	3:33	4:16	0:43	MAIN SUPPLY FAILURE
457	26-Oct-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	3:33	4:15	0:42	MAIN SUPPLY FAILURE
458	26-Oct-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	4:18	16:38	12:20	LINE CLEAR AVAIED
459	26-Oct-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	3:33	23:59	20:26	MAIN SUPPLY FAILURE
460	26-Oct-19	HASSAN	220	MSEZ-KEMAR2	PUTTUR_220	3:36	4:00	0:24	MAIN SUPPLY FAILURE
461	26-Oct-19	HASSAN	110	HV1	PUTTUR_220	3:34	3:59	0:25	MAIN SUPPLY FAILURE
462	26-Oct-19	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	3:35	4:02	0:27	MAIN SUPPLY FAILURE
463	26-Oct-19	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	3:54	23:59	20:05	MAIN SUPPLY FAILURE
464	26-Oct-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	3:34	4:02	0:28	MAIN SUPPLY FAILURE
465	26-Oct-19	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	3:38	4:03	0:25	MAIN SUPPLY FAILURE
466	26-Oct-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	0:00	11:54	11:54	LINE FAULT
467	26-Oct-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:22	12:26	0:04	LINE CLEAR AVAIED
468	26-Oct-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	0:00	16:29	16:29	LINE CLEAR AVAIED
469	26-Oct-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	16:46	17:22	0:36	LINE CLEAR AVAIED
470	26-Oct-19	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	9:49	14:30	4:41	LINE CLEAR AVAIED
471	26-Oct-19	HASSAN	110	HV1	BAIKAMPADI_110	3:33	4:07	0:34	MAIN SUPPLY FAILURE
472	26-Oct-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	3:36	4:42	1:06	MAIN SUPPLY FAILURE
473	26-Oct-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	3:36	4:10	0:34	MAIN SUPPLY FAILURE
474	26-Oct-19	HASSAN	110	HV2	KONAJE_110	3:34	4:04	0:30	MAIN SUPPLY FAILURE

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
475	26-Oct-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	3:34	4:13	0:39	MAIN SUPPLY FAILURE
476	26-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	0:05	0:10	0:05	TRANSFORMER FAULT
477	26-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	0:32	0:38	0:06	TRANSFORMER FAULT
478	26-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	2:38	2:48	0:10	TRANSFORMER FAULT
479	26-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	2:58	3:11	0:13	TRANSFORMER FAULT
480	26-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	8:40	9:35	0:55	TRANSFORMER FAULT
481	26-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	10:52	11:12	0:20	TRANSFORMER FAULT
482	26-Oct-19	MYSORE	66	HV1	KUSHALANAGARA_66	13:47	14:00	0:13	TRANSFORMER FAULT
483	26-Oct-19	MYSORE	66	PERIYAPATNA-HANAGODU	HANAGODU_66, PONNAMPET_66, VIRAJPET_66	5:15	5:35	0:20	LINE FAULT
484	26-Oct-19	MYSORE	66	HV1	THALAKADU_66	2:29	2:35	0:05	MAIN SUPPLY FAILURE
485	26-Oct-19	MYSORE	66	HV2	THALAKADU_66	2:29	2:35	0:05	MAIN SUPPLY FAILURE
486	26-Oct-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66, TARIPURA_66	5:33	5:36	0:03	LINE FAULT
487	26-Oct-19	MYSORE	66	TUBINAKERE-G UKKADA	GARUDANAUKADDA_66, SRIRANGAPATNA_66	5:33	5:50	0:17	HAND TRIPPED
488	26-Oct-19	MYSORE	66	TUBINAKERE- NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 SHIVALLY_66 KESLAGERE_66	5:33	5:50	0:17	HAND TRIPPED
489	26-Oct-19	MYSORE	66	TUBINAKERE- PANDAVAPURA	DODDABYADARAHALLI_66, PANDAVAPURA_66	5:33	5:49	0:16	HAND TRIPPED
490	26-Oct-19	MYSORE	66	HV2	TUBINAKERE_220	5:33	5:57	0:24	HAND TRIPPED
491	27-Oct-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	5:48	6:07	0:19	LINE FAULT
492	27-Oct-19	BAGALKOT	110	BIJAPUR220-BIJAPUR CITY	BIJAPUR CITY_110	6:27	6:35	0:08	LINE FAULT

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
493	27-Oct-19	BAGALKOT	110	RANEBENNUR220-BYADAGI	BYADAGI_110	13:41	17:18	3:37	LINE CLEAR AVAILED
494	27-Oct-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	14:18	23:59	9:41	LINE CLEAR AVAILED
495	27-Oct-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	14:33	23:59	9:26	LINE CLEAR AVAILED
496	27-Oct-19	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	5:48	6:19	0:31	LINE FAULT
497	27-Oct-19	BAGALKOT	110	GHATAPRABHA220-PG HUNSYAL	PG HUNSYAL_110	4:48	4:58	0:10	LINE FAULT
498	27-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	0:00	8:40	8:40	LINE CLEAR AVAILED
499	27-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	15:49	23:59	8:10	LINE CLEAR AVAILED
500	27-Oct-19	BAGALKOT	110	HUNGUND-JINDAL	HUNGUND_110,JINDAL_110	0:00	13:41	13:41	LINE CLEAR AVAILED
501	27-Oct-19	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINAGAD_33,SOLAR_33,KARADI_33	16:08	16:15	0:07	TRANSFORMER FAULT
502	27-Oct-19	BAGALKOT	110	110/33KV,HV4	KANABARGI LAYOUT_110,KAKATI_33,SUZLAON_33	11:25	12:03	0:38	LINE CLEAR AVAILED
503	27-Oct-19	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	5:07	5:09	0:02	HAND TRIPPED
504	27-Oct-19	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	6:56	8:14	1:18	LINE FAULT
505	27-Oct-19	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	8:24	8:29	0:05	HAND TRIPPED
506	27-Oct-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	0:37	7:11	6:34	LINE CLEAR AVAILED
507	27-Oct-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	13:18	18:24	5:06	LINE CLEAR AVAILED
508	27-Oct-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	22:31	23:59	1:28	LINE CLEAR AVAILED
509	27-Oct-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALIGAPUR_220	12:18	13:11	0:53	LINE FAULT
510	27-Oct-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	10:02	10:35	0:33	TRANSFORMER FAULT
511	27-Oct-19	BAGALKOT	220	NAGJHARI 2-HUBLI 220	HUBLI_220	16:36	17:22	0:46	HAND TRIPPED
512	27-Oct-19	BAGALKOT	110	HUBLI220-PHCOMPOUND	PHCOMPOUND_110	13:50	23:59	10:09	LINE FAULT
513	27-Oct-19	BAGALKOT	110	110/33KV ,HV1	HUBLI_220	19:06	23:59	4:53	TRANSFORMER FAULT
514	27-Oct-19	BENGALURU	66	JIGANI LINK ROAD - YERANDANAHALLI 220	JIGANI LINK ROAD	16:32	18:20	1:48	LOAD CHANGE OVER
515	27-Oct-19	BENGALURU	66	JIGANI LINK ROAD - SOMANAHALLI 220	JIGANI LINK ROAD	16:20	16:30	0:10	LOAD CHANGE OVER
516	27-Oct-19	BENGALURU	66	HV2	JIGANI 66	7:17	8:23	1:06	LINE CLEAR AVAILED
517	27-Oct-19	BENGALURU	66	HV3	JIGANI 66	7:17	8:23	1:06	LINE CLEAR AVAILED
518	27-Oct-19	BENGALURU	66	HV2	JIGANI 66	12:35	12:40	0:05	LINE CLEAR AVAILED
519	27-Oct-19	BENGALURU	66	HV3	JIGANI 66	12:35	12:40	0:05	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
520	27-Oct-19	BENGALURU	66	HV2	JIGANI 66	16:20	16:35	0:15	MAIN SUPPLY FAILURE
521	27-Oct-19	BENGALURU	66	HV3	JIGANI 66	16:20	16:35	0:15	MAIN SUPPLY FAILURE
522	27-Oct-19	BENGALURU	66	HV1	JIGANI 66	16:20	16:35	0:15	MAIN SUPPLY FAILURE
523	27-Oct-19	BENGALURU	66	HV2	JIGANI 66	18:10	18:25	0:15	LINE CLEAR AVAILED
524	27-Oct-19	BENGALURU	66	HV3	JIGANI 66	18:10	18:25	0:15	LINE CLEAR AVAILED
525	27-Oct-19	BENGALURU	66	HV2	JIGANI 66	23:15	23:23	0:08	LINE CLEAR AVAILED
526	27-Oct-19	BENGALURU	66	HV3	JIGANI 66	23:15	23:23	0:08	LINE CLEAR AVAILED
527	27-Oct-19	BENGALURU	66	ATTIBELE - SARJAPURA 220		15:45	15:50	0:05	LOAD CHANGE OVER
528	27-Oct-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	16:55	17:15	0:20	LINE FAULT
529	27-Oct-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	RBI	4:55	5:08	0:13	LINE FAULT
530	27-Oct-19	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	7:27	8:22	0:55	LINE FAULT
531	27-Oct-19	BENGALURU	66	HV3	YERANDANAHALLI 220	18:38	18:42	0:04	LOAD CHANGE OVER
532	27-Oct-19	BENGALURU	66	HV1	BMTC	16:45	16:50	0:05	TRANSFORMER FAULT
533	27-Oct-19	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	14:40	14:45	0:05	LOAD CHANGE OVER
534	27-Oct-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:32	21:55	0:23	LINE FAULT
535	27-Oct-19	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1	PATHPALYA, THIMAMPALLI, SOMANATHAPURA	18:10	18:15	0:05	LINE FAULT
536	27-Oct-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:17	16:39	16:22	LINE CLEAR AVAILED
537	27-Oct-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	14:54	23:59	9:05	LINE FAULT
538	27-Oct-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	10:41	13:04	2:23	LINE FAULT
539	27-Oct-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	3:33	4:09	0:36	MAIN SUPPLY FAILURE
540	27-Oct-19	HASSAN	220	VARAH1-KEMAR2	varahi_gen	14:52	23:59	9:07	LINE FAULT
541	27-Oct-19	HASSAN	220	VARAH1-SHMG3	varahi_gen	10:41	13:04	2:23	LINE FAULT
542	27-Oct-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:41	10:49	0:08	LINE FAULT
543	27-Oct-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	12:18	12:32	0:14	LINE FAULT
544	27-Oct-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	16:43	16:54	0:11	LINE FAULT
545	27-Oct-19	MYSORE	66	HV1	KRPET_220	18:25	18:35	0:10	TRANSFORMER FAULT
546	27-Oct-19	MYSORE	66	HV1	PANDAVAPURA_66	22:10	22:17	0:07	HAND TRIPPED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
547	27-Oct-19	MYSORE	66	HV1	PANDAVAPURA_66	22:23	23:13	0:50	TRANSFORMER FAULT
548	27-Oct-19	MYSORE	66	HV1	THALAKADU_66	6:25	6:37	0:12	MAIN SUPPLY FAILURE
549	27-Oct-19	MYSORE	66	HV2	THALAKADU_66	6:25	6:37	0:12	MAIN SUPPLY FAILURE
550	27-Oct-19	MYSORE	66	HV1	KRPET_220	18:25	18:35	0:10	TRANSFORMER FAULT
551	27-Oct-19	MYSORE	66	HV1	PANDAVAPURA_66	22:10	22:17	0:07	HAND TRIPPED
552	27-Oct-19	MYSORE	66	HV1	PANDAVAPURA_66	22:23	23:13	0:50	TRANSFORMER FAULT
553	27-Oct-19	MYSORE	66	HV1	THALAKADU_66	6:25	6:37	0:12	MAIN SUPPLY FAILURE
554	27-Oct-19	MYSORE	66	HV2	THALAKADU_66	6:25	6:37	0:12	MAIN SUPPLY FAILURE
555	28-Oct-19	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	15:38	15:39	0:01	HAND TRIPPED
556	28-Oct-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	8:16	8:16	LINE CLEAR AVAILED
557	28-Oct-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	0:00	8:26	8:26	LINE CLEAR AVAILED
558	28-Oct-19	BAGALKOT	110	110/33KV,HV3	GHATAPRABHA_110,GOKAK MILLS_33,KALLOLLI_33	13:57	14:14	0:17	TRANSFORMER FAULT
559	28-Oct-19	BAGALKOT	110	110/33KV,HV4	GHATAPRABHA_110,GANDAPUR_33,MANTUR_33	13:57	14:13	0:16	TRANSFORMER FAULT
560	28-Oct-19	BAGALKOT	110	110/11KV,HV1	GHATAPRABHA_110	14:00	14:25	0:25	TRANSFORMER FAULT
561	28-Oct-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	21:56	22:05	0:09	LINE FAULT
562	28-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	0:00	8:09	8:09	LINE CLEAR AVAILED
563	28-Oct-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	16:06	23:59	7:53	LINE CLEAR AVAILED
564	28-Oct-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	11:13	13:04	1:51	LINE CLEAR AVAILED
565	28-Oct-19	BAGALKOT	220	MK HUBLI-NARENDRA2	MK HUBLI_220	13:58	20:52	6:54	LINE FAULT
566	28-Oct-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	0:00	6:31	6:31	LINE CLEAR AVAILED
567	28-Oct-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	17:24	23:59	6:35	LINE FAULT
568	28-Oct-19	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	17:24	23:59	6:35	LINE FAULT
569	28-Oct-19	BAGALKOT	110	UMMACHAGI-ESALE (SIRSI)	UMMACHAGI_110	18:02	23:59	5:57	LINE FAULT
570	28-Oct-19	BAGALKOT	220	HUBLI-NARENDRA 2	HUBLI_220	12:42	17:59	5:17	LINE FAULT
571	28-Oct-19	BAGALKOT	110	110/33KV ,HV1	HUBLI_220	0:00	12:13	12:13	LINE CLEAR AVAILED

Sl.No.	Date	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
572	28-Oct-19	BENGALURU	66	HV3	ELECTRONIC CITY	10:21	10:30	0:09	TRANSFORMER FAULT
573	28-Oct-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	9:22	9:48	0:26	LINE FAULT
574	28-Oct-19	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	12:30	12:35	0:05	LOAD CHANGE OVER
575	28-Oct-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	7:03	7:37	0:34	LINE FAULT
576	28-Oct-19	BENGALURU	66	HV1	TELECOM LAYOUT	16:06	16:16	0:10	LINE CLEAR AVAILED
577	28-Oct-19	BENGALURU	66	HV2	TELECOM LAYOUT	16:06	16:16	0:10	LINE CLEAR AVAILED
578	28-Oct-19	GULBARGA	110	SINDHANOOR-PGLR_WIND_IPP	SIDHANOOR_220	4:45	4:53	0:08	LINE FAULT
579	28-Oct-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110, MUDDAPURA_110	6:05	6:15	0:10	LINE FAULT
580	28-Oct-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110, MUDDAPURA_110	22:10	22:20	0:10	LINE FAULT
581	28-Oct-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	0:00	12:25	12:25	LINE FAULT
582	28-Oct-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:37	17:50	5:13	LINE FAULT
583	28-Oct-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	10:22	13:38	3:16	LINE CLEAR AVAILED
584	28-Oct-19	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	10:18	13:38	3:20	LINE CLEAR AVAILED
585	28-Oct-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	0:00	12:24	12:24	LINE FAULT
586	28-Oct-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:34	17:50	5:16	LINE FAULT
587	28-Oct-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	16:18	16:26	0:08	LINE FAULT
588	28-Oct-19	HASSAN	110	HV2	PUTUR_110	14:54	18:15	3:21	LINE CLEAR AVAILED
589	28-Oct-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	12:02	14:19	2:17	LINE CLEAR AVAILED
590	28-Oct-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:50	11:23	0:33	LINE CLEAR AVAILED
591	28-Oct-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	12:03	12:11	0:08	HAND TRIPPED
592	28-Oct-19	MYSORE	66	KADAKOLA-SARAGURU 2	DOORA_66, HURA_66, HULLAHALLI_66, CHANDRAVDI_66, B MATKERE_66, SANTHESARAGUR_66	6:42	6:49	0:07	LINE FAULT
593	28-Oct-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	6:45	6:51	0:06	LINE FAULT
594	28-Oct-19	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	10:33	10:35	0:02	HAND TRIPPED