

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 22.12.2020 TO 28.12.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	22-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
2	22-Dec-2020	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	15:53	18:01	2:08	LINE CLEAR AVAILED
3	22-Dec-2020	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
4	22-Dec-2020	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED KULIGOD_110	13:39 (20.12.2020)			TRANSFORMER OPEN, LINE CLEAR AVAILED
5	22-Dec-2020	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	04:57	13:15	8:18	TRANSFORMER FAULT
6	22-Dec-2020	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	12:09	12:45	0:36	LINE CLEAR AVAILED
7	22-Dec-2020	BAGALKOT	110	110/11KV,HV1(HV4)	GOPPANAKOPPA_110	08:18	09:47	1:29	LINE CLEAR AVAILED
8	22-Dec-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110	1:07	1:11	0:04	TRANSFORMER FAULT
9	22-Dec-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110	01:11	01:17	0:06	TRANSFORMER FAULT
10	22-Dec-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110	01:21	1:33	0:12	TRANSFORMER FAULT
11	22-Dec-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110	11:03	11:09	0:06	TRANSFORMER FAULT
12	22-Dec-2020	BAGALKOT	110	110/33KV, HV2	SADALAGA_110, BHOJ_33	12:24	13:23	0:59	LINE CLEAR AVAILED
13	22-Dec-2020	BAGALKOT	110	110/33KV, HV3	NIPPANI_110, BENADI_33	23:13	23:15	0:02	TRANSFORMER FAULT
14	22-Dec-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, HALSANGI_33	15:04	15:16	0:12	TRANSFORMER FAULT
15	22-Dec-2020	BAGALKOT	110	BIDNAL- NAVALGUND	NAVALGUND_110	11:50	11:52	0:02	HAND TRIPPED
16	22-Dec-2020	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	22:07	22:34	0:27	LINE FAULT
17	22-Dec-2020	BAGALKOT	110	CHIKKODI220-NIPPANI	NIPPANI_110	22:07	22:40	0:33	LINE FAULT
18	22-Dec-2020	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	22:07	22:42	0:35	LINE FAULT
19	22-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
20	22-Dec-2020	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	05:35	06:13	0:38	LINE FAULT
21	22-Dec-2020	BAGALKOT	110	HUBLI- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	10:21 (19.12.2020)			LINE OPEN,LINE CLEAR AVAILED
22	22-Dec-2020	BAGALKOT	110	HUBLI- KALGHATAGI (SIRSI)	STATION NOT AFFECTED HUBLI_220	10:21 (19.12.2020)			LINE OPEN,LINE CLEAR AVAILED
23	22-Dec-2020	BAGALKOT	110	HUBLI-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	10:13 (19.12.2020)			LINE OPEN,LINE CLEAR AVAILED
24	22-Dec-2020	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	10:26 (19.12.2020)			LINE OPEN,LINE CLEAR AVAILED
25	22-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
26	22-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
27	22-Dec-2020	BAGALKOT	110	KUDACHI- CHIKKODI	KUDACHI_220	16:30	16:37	0:07	LINE CLEAR AVAILED
28	22-Dec-2020	BAGALKOT	110	KUDACHI- GHATAPRABHA	KUDACHI_220	16:40	16:42	0:02	LINE CLEAR AVAILED
29	22-Dec-2020	BAGALKOT	110	KUDACHI- MAHALINGAPUR	KUDACHI_220	16:44	16:46	0:02	LINE CLEAR AVAILED
30	22-Dec-2020	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN,LINE FAULT
31	22-Dec-2020	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABKAVI_110	12:45	12:58	0:13	LINE FAULT
32	22-Dec-2020	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
33	22-Dec-2020	BAGALKOT	110	SIRSI- JOG2	STATION NOT AFFECTED SIRSI_110	10:09	11:05	0:56	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
34	22-Dec-2020	BAGALKOT	110	SUARNASOUDA- MACHE	MACHE_110	14:07	14:18	0:11	LINE FAULT
35	22-Dec-2020	BAGALKOT	220	220/110KV, HV3&LV3	STATION NOT AFFECTED HUBLI_220	09:30	13:16	3:46	LINE CLEAR AVOIDED
36	22-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVOIDED
37	22-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA2	STATION NOT AFFECTED BAGEWADI_220	10:04	19:24	9:20	LINE CLEAR AVOIDED
38	22-Dec-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	21:43 (21.12.2020)	7:54 (22.12.2020)	10:11hrs	LINE CHARGED
39	22-Dec-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	20:10 (22.12.2020)			LOAD CURTAILMENT
40	22-Dec-2020	BAGALKOT	220	BELGAUM-NARENDRA 1	STATION NOT AFFECTED BELGAUM_220	19:55 (21.12.2020)	12:02 (22.12.2020)	16:07hrs	LINE CHARGED
41	22-Dec-2020	BAGALKOT	220	BELGAUM-NARENDRA 1	STATION NOT AFFECTED BELGAUM_220	19:45 (22.12.2020)			LINE OPEN,LINE CLEAR AVOIDED
42	22-Dec-2020	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN,LINE CLEAR AVOIDED
43	22-Dec-2020	BAGALKOT	220	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	12:45	12:58	0:13	LINE CLEAR AVOIDED
44	22-Dec-2020	BAGALKOT	220	NARENDRA- KANABARGI1 (BELGAUM1)	NARENDRA_220	19:46 (22.12.2020)			LINE OPEN,LINE CLEAR AVOIDED
45	22-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
46	22-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
47	22-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVOIDED
48	22-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
49	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	10:35	10:40	00:10	LINE CLEAR AVOIDED
50	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	17:35	17:50	00:15	LINE CLEAR AVOIDED
51	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	10:35	10:40	00:10	LINE CLEAR AVOIDED
52	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	17:35	17:50	00:15	LINE CLEAR AVOIDED
53	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:35	10:40	00:10	LINE CLEAR AVOIDED
54	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	17:35	17:50	00:15	LINE CLEAR AVOIDED
55	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	10:35	10:40	00:10	LINE CLEAR AVOIDED
56	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	17:35	17:50	00:15	LINE CLEAR AVOIDED
57	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	10:35	10:40	00:10	LINE CLEAR AVOIDED
58	22-Dec-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:35	17:50	00:15	LINE CLEAR AVOIDED
59	22-Dec-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	06:23	07:40	01:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
60	22-Dec-2020	BENGALURU	66	HOSKOTE 220 - DG 4	GRINDWELL(EHT)	11:30	13:11	01:41	LINE CLEAR AVOIDED
61	22-Dec-2020	BENGALURU	66	HV1	DOMMASANDRA	17:56	18:08	00:12	LINE CLEAR AVOIDED
62	22-Dec-2020	BENGALURU	66	HV1	JIGANI 66	11:37	11:40	00:03	LINE CLEAR AVOIDED
63	22-Dec-2020	BENGALURU	66	HV1	SIDDALAGATTA	11:21	11:30	00:08	TRANSFORMER FAULT
64	22-Dec-2020	BENGALURU	66	HV2	KHODAYS 220	15:57	16:01	00:03	LINE CLEAR AVOIDED
65	22-Dec-2020	BENGALURU	66	HV2	JIGANI 66	15:10	15:55	00:45	LINE CLEAR AVOIDED
66	22-Dec-2020	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	09:10	09:50	00:40	LINE CLEAR AVOIDED
67	22-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVOIDED
68	22-Dec-2020	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	07:10	07:15	00:05	MAIN SUPPLY FAILURE
69	22-Dec-2020	GULBARGA	110	HV2	SINDHANOOR_110	16:19	16:26	00:07	TRANSFORMER FAULT
70	22-Dec-2020	GULBARGA	110	ITTAGGI-HOLAGUNDI	HOLAGUNDI_66	17:20	19:46	02:26	MAIN SUPPLY FAILURE
71	22-Dec-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERAD ONA_110, SRERAMNAGAR_110,MALLAPURA_110	22:55	23:05	00:10	LINE FAULT
72	22-Dec-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURDI CROSS_110	01:30	01:40	00:10	LINE FAULT
73	22-Dec-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERAD ONA_110, SRERAMNAGAR_110,MALLAPURA_110	00:45	00:55	00:10	LINE FAULT
74	22-Dec-2020	HASSAN	66	CRPATNA2-HNPURA	CRPATNA_220	08:26	16:05	07:39	LINE CLEAR AVOIDED
75	22-Dec-2020	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	18:01	18:07	00:06	LINE FAULT
76	22-Dec-2020	HASSAN	66	HV1	CRPATNA_220	11:11	12:25	01:14	TRANSFORMER FAULT
77	22-Dec-2020	HASSAN	66	HV1	HNPURA_66	18:01	18:08	00:07	MAIN SUPPLY FAILURE
78	22-Dec-2020	HASSAN	66	HV1	SINGAPURA_66	08:26	16:05	07:39	LINE CLEAR AVOIDED
79	22-Dec-2020	HASSAN	66	HV2	HNPURA_66	18:01	18:08	00:07	MAIN SUPPLY FAILURE
80	22-Dec-2020	HASSAN	66	HV2	SINGAPURA_66	08:26	16:05	07:39	LINE CLEAR AVOIDED
81	22-Dec-2020	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
82	22-Dec-2020	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
83	22-Dec-2020	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN, LINE CLEAR AVOIDED
84	22-Dec-2020	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	08:26	16:05	07:39	LINE CLEAR AVOIDED
85	22-Dec-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	03:23	03:36	00:13	LINE FAULT
86	22-Dec-2020	HASSAN	220	MRSSHIM-VARAH12	MRSMSG_220	18:18	21:01	02:43	LINE FAULT
87	22-Dec-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	18:18	21:15	02:57	LINE FAULT
88	22-Dec-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:44(19.12.2020)	7:39 (22.12.2020)	55:54 hrs	LINE CHARGED
89	22-Dec-2020	MYSURU	66	HOOTAGALLI-HAMPAPURA(KAGGERE)	KAGGERE HAMPAPURA_66	4:15	4:25	0:10	LINE FAULT
90	22-Dec-2020	MYSURU	66	HV2	DODDINADUVADI_66	7:20	7:35	0:14	TRANSFORMER FAULT
91	22-Dec-2020	MYSURU	66	HV5	SFCSHIVA_66	7:26	9:30	2:03	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
92	22-Dec-2020	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN,LINE CLEAR AVAILED
93	22-Dec-2020	MYSURU	220	HV1	KADAKOLA_220	6:12	6:52	0:40	TRANSFORMER FAULT
94	22-Dec-2020	MYSURU	220	HV2	KADAKOLA_220	6:12	7:05	0:53	TRANSFORMER FAULT
95	23-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
96	23-Dec-2020	BAGALKOT	110	110/11KV, HV1	GOPPANAKOPPA_110	11:52	12:23	0:31	LINE CLEAR AVAILED
97	23-Dec-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_110	13:19	14:59	1:40	LINE CLEAR AVAILED
98	23-Dec-2020	BAGALKOT	110	110/11KV, HV1	SODATTI_110, UDIKERI_33, CHULKI_33	08:00	09:24	1:24	LINE CLEAR AVAILED
99	23-Dec-2020	BAGALKOT	110	110/11KV, HV2	GAJENDRAGAD_110	01:36	01:54	0:18	TRANSFORMER FAULT
100	23-Dec-2020	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	12:10	13:04	0:54	LINE CLEAR AVAILED
101	23-Dec-2020	BAGALKOT	110	110/11KV, HV2	RON_110	15:18	16:29	1:11	LINE CLEAR AVAILED
102	23-Dec-2020	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
103	23-Dec-2020	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED KULIGOD_110	13:39 (20.12.2020)	19:05 (23.12.2020)	101:26 hrs	TRANSFORMER CHARGED
104	23-Dec-2020	BAGALKOT	110	110/33KV, HV4	VADAGOAN_110	11:34	11:38	0:04	LINE CLEAR AVAILED
105	23-Dec-2020	BAGALKOT	110	110/33KV,HV3	RON_110, MUSHIGERI_33	16:28	17:22	0:54	LINE CLEAR AVAILED
106	23-Dec-2020	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED BIDNAL_220	10:28	18:01	7:33	LINE CLEAR AVAILED
107	23-Dec-2020	BAGALKOT	110	ANKOLA-KUMTA2	STATION NOT AFFECTED KUMTA_110	04:03	11:46	7:43	LINE FAULT
108	23-Dec-2020	BAGALKOT	110	BAGEWADI220- CHIMMALAGI LIS	CHIMMALAGI LIS_110	22:40	22:45	0:05	LINE FAULT
109	23-Dec-2020	BAGALKOT	110	BAGEWADI220-UKKALI	UKKALI_110	6:58	07:13	0:15	LINE FAULT
110	23-Dec-2020	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	11:34	11:37	0:03	HAND TRIPPED
111	23-Dec-2020	BAGALKOT	110	BIDNAL220- ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	10:13	18:15	8:02	LINE CLEAR AVAILED
112	23-Dec-2020	BAGALKOT	110	BIDNAL220- GADAG ROAD	STATION NOT AFFECTED GADAG ROAD_110	10:13	18:39	8:26	LINE CLEAR AVAILED
113	23-Dec-2020	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	10:13	18:19	8:06	LINE CLEAR AVAILED
114	23-Dec-2020	BAGALKOT	110	BIDNAL220- PH COMPOUND	STATION NOT AFFECTED PH COMPOUND_110	10:21	10:28	0:07	LINE CLEAR AVAILED
115	23-Dec-2020	BAGALKOT	110	BIDNAL220- PH COMPOUND	STATION NOT AFFECTED PH COMPOUND_110	18:01	18:06	0:05	LINE CLEAR AVAILED
116	23-Dec-2020	BAGALKOT	110	GADAGROAD- GOPPANAKOPPA	STATION NOT AFFECTED GADAGROAD_110	8:48	18:40	9:52	LINE CLEAR AVAILED
117	23-Dec-2020	BAGALKOT	110	GAMESHA- KULIGOD	KULIGOD_110	09:36	17:32	7:56	LINE CLEAR AVAILED
118	23-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
119	23-Dec-2020	BAGALKOT	110	HAVERI220- HANGAL	HANGAL_110	12:03	12:58	0:55	LINE CLEAR AVAILED
120	23-Dec-2020	BAGALKOT	110	HUBLI- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	10:21 (19.12.2020)	17:00 (23.12.2020)	102:39 hrs	LINE CHARGED
121	23-Dec-2020	BAGALKOT	110	HUBLI- KALGHATAGI (SIRSI)	STATION NOT AFFECTED HUBLI_220	10:21 (19.12.2020)	16:57 (23.12.2020)	102:36 hrs	LINE CHARGED
122	23-Dec-2020	BAGALKOT	110	HUBLI-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	10:13 (19.12.2020)	18:12 (23.12.2020)	103:59 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
123	23-Dec-2020	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	10:26 (19.12.2020)	17:05 (23.12.2020)	102:39 hrs	LINE CHARGED
124	23-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
125	23-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
126	23-Dec-2020	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN,LINE FAULT
127	23-Dec-2020	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
128	23-Dec-2020	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED BIDNAL_220	10:29	17:53	7:24	LINE CLEAR AVAILED
129	23-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
130	23-Dec-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	20:10 (22.12.2020)	7:45 (23.12.2020)	11:35 hrs	LINE CHARGED
131	23-Dec-2020	BAGALKOT	220	BELGAUM-NARENDRA 1	STATION NOT AFFECTED BELGAUM_220	19:45 (22.12.2020)	11:13 (23.12.2020)	15:28 hrs	LINE CHARGED
132	23-Dec-2020	BAGALKOT	220	BIDNAL-TADAS2	STATION NOT AFFECTED BIDNAL_220	9:00 (23.12.2020)			LINE OPEN,LINE CLEAR AVAILED
133	23-Dec-2020	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN,LINE CLEAR AVAILED
134	23-Dec-2020	BAGALKOT	220	NARENDRA- KANABARGI1 (BELGAUM1)	STATION NOT AFFECTED NARENDRA_220	19:46 (22.12.2020)	11:32 (23.12.2020)	15:46 hrs	LINE CHARGED
135	23-Dec-2020	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	14:01	14:40	0:39	LINE FAULT
136	23-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
137	23-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
138	23-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
139	23-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
140	23-Dec-2020	BENGALURU	66	HV2	DODDABELAVANGALA	18:02	18:31	00:29	TRANSFORMER FAULT
141	23-Dec-2020	BENGALURU	66	HV2	DODDABELAVANGALA	18:31	18:38	00:07	TRANSFORMER FAULT
142	23-Dec-2020	BENGALURU	66	HV2	DODDABELAVANGALA	18:38	18:53	00:15	TRANSFORMER FAULT
143	23-Dec-2020	BENGALURU	66	SOBHA FOREST - SOMANAHLI 220	SOBHA FOREST, BRIGADE MEADOWS	17:42	17:55	00:13	LOAD CHANGE OVER
144	23-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
145	23-Dec-2020	GULBARGA	110	LINGASUGUR-LATUR GAMESHA IPP	LINGASUGUR_220	15:00	17:50	02:50	LINE CLEAR AVAILED
146	23-Dec-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110, VALKAMDINNI_110	16:24	16:30	00:06	LINE FAULT
147	23-Dec-2020	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	10:55	14:40	03:45	LINE CLEAR AVAILED
148	23-Dec-2020	HASSAN	66	HIREMAN-CKM220	HIREMANGALUR_66	12:10	14:40	02:30	LINE CLEAR AVAILED
149	23-Dec-2020	HASSAN	66	HIREMAN-RDL	HIREMANGALUR_66	10:33	14:43	04:10	LINE CLEAR AVAILED
150	23-Dec-2020	HASSAN	66	HV1	BAGUR_66	10:00	12:50	02:50	LINE CLEAR AVAILED
151	23-Dec-2020	HASSAN	66	HV1	CHIKMAGALUR_66	10:32	14:42	04:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
152	23-Dec-2020	HASSAN	66	HV1	HIREMANGALUR_66	11:53	17:01	05:08	LINE CLEAR AVAILED
153	23-Dec-2020	HASSAN	66	HV1	HOLEHONNUR_66	11:36	12:02	00:26	LINE CLEAR AVAILED
154	23-Dec-2020	HASSAN	66	HV2	BAGUR_66	10:00	12:50	02:50	LINE CLEAR AVAILED
155	23-Dec-2020	HASSAN	66	HV2	CHIKMAGALUR_66	10:32	14:42	04:10	LINE CLEAR AVAILED
156	23-Dec-2020	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
157	23-Dec-2020	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
158	23-Dec-2020	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
159	23-Dec-2020	HASSAN	110	HV1	MANIPAL_110	12:25	13:00	00:35	LINE CLEAR AVAILED
160	23-Dec-2020	HASSAN	110	HV2	KONAJE_110	10:41	15:40	04:59	LINE CLEAR AVAILED
161	23-Dec-2020	HASSAN	110	KADUR-YGTI	KADUR_220	17:18	17:48	00:30	HAND TRIPPED
162	23-Dec-2020	HASSAN	110	LV2	MSEZ_220	09:51	14:58	05:07	LINE CLEAR AVAILED
163	23-Dec-2020	HASSAN	220	HV2	MSEZ_220	09:51	14:58	05:07	LINE CLEAR AVAILED
164	23-Dec-2020	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	11:34	12:57	01:23	LINE FAULT
165	23-Dec-2020	MYSURU	66	CR NAGARA-DR PETE 1	NO STATIONS EFFECTED	7:00	7:06	0:06	LINE FAULT
166	23-Dec-2020	MYSURU	66	HOOTAGALLI-HAMPAPURA(KAGGERE)	KAGGERE HAMPAPURA_66	23:05	23:20	0:15	LINE FAULT
167	23-Dec-2020	MYSURU	66	KUSHALNAGARA 220-RAMANTHAPURA1	ALUR SIDDAPURA_66 KANAGAL_66	18:10	18:15	0:04	LINE FAULT
168	23-Dec-2020	MYSURU	66	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	15:43 (23.12.2020)			LINE OPEN,LINE FAULT
169	23-Dec-2020	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN,LINE CLEAR AVAILED
170	23-Dec-2020	MYSURU	220	HOOTAGALLI-VAJMANGALA	NO STATIONS EFFECTED	11:05	14:25	3:20	NFBC ISSUED
171	23-Dec-2020	TUMKUR	66	CHITRADURGA 220kV-HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	6:39	6:54	0:15	LINE FAULT
172	23-Dec-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:18	16:28	0:09	LINE FAULT
173	23-Dec-2020	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	2:20	2:25	0:05	LINE FAULT
174	23-Dec-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	12:37	12:44	0:06	LINE FAULT
175	23-Dec-2020	TUMKUR	66	MADHUGIRI 220kV-KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	13:14	13:49	0:35	LINE FAULT
176	23-Dec-2020	TUMKUR	66	NEELAGUNDA 220kV-PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHANGIDURGA_66, PALLAGATTE_66, SOKKE_66	15:26	15:40	0:13	LINE FAULT
177	23-Dec-2020	TUMKUR	66	SIRA- BUKKAPATNA	SIRA_66	2:28	2:29	0:01	MAIN SUPPLY FAILURE
178	23-Dec-2020	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	2:28	2:29	0:01	MAIN SUPPLY FAILURE
179	23-Dec-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	7:33	7:37	0:04	TRANSFORMER FAULT
180	23-Dec-2020	TUMKUR	66	TR-2	KORA_66	15:09	15:29	0:19	TRANSFORMER FAULT
181	23-Dec-2020	TUMKUR	66	TR-2	KORA_66	15:35	15:48	0:12	TRANSFORMER FAULT
182	23-Dec-2020	TUMKUR	66	TR-2	LINGADAHALLI_TMK2_66	21:05	21:08	0:03	TRANSFORMER FAULT
183	23-Dec-2020	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110, AMMASANDRA_110, SAMPIGE_110	12:15	12:25	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
184	23-Dec-2020	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	12:15	12:26	0:11	HAND TRIPPED
185	23-Dec-2020	TUMKUR	110	TR-1	KGTEMPLE_110	14:35	16:28	1:53	LINE CLEAR AVAILED
186	23-Dec-2020	TUMKUR	110	TR-1	SAMPIGE_110	12:15	12:26	0:11	HAND TRIPPED
187	23-Dec-2020	TUMKUR	110	TR-1	TALKERE_110	9:49	10:59	1:09	TRANSFORMER FAULT
188	23-Dec-2020	TUMKUR	110	TR-2	SAMPIGE_110	12:15	13:59	1:44	LINE CLEAR AVAILED
189	23-Dec-2020	TUMKUR	220	TR-1	PAVAGADA_220	11:00	11:29	0:29	LINE CLEAR AVAILED
190	24-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
191	24-Dec-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_110	14:25	14:28	0:03	LINE CLEAR AVAILED
192	24-Dec-2020	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	12:06	13:04	0:58	LINE CLEAR AVAILED
193	24-Dec-2020	BAGALKOT	110	110/11KV, HV1	KALGHATAGI_110	11:19	13:57	2:38	LINE CLEAR AVAILED
194	24-Dec-2020	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	12:49	12:58	0:09	LINE CLEAR AVAILED
195	24-Dec-2020	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	20:23	20:38	0:15	TRANSFORMER FAULT
196	24-Dec-2020	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
197	24-Dec-2020	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33	14:00	14:06	0:06	TRANSFORMER FAULT
198	24-Dec-2020	BAGALKOT	110	BELGAUM-NEHRU NAGAR	NEHRU NAGAR_110	14:09	15:35	1:26	LINE CLEAR AVAILED
199	24-Dec-2020	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	12:35	12:47	0:12	LINE FAULT
200	24-Dec-2020	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	11:59	12:39	0:40	LINE CLEAR AVAILED
201	24-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
202	24-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
203	24-Dec-2020	BAGALKOT	110	ITANAL- RAIBAG1	RAIBAG_110	12:34	13:12	0:38	LINE CLEAR AVAILED
204	24-Dec-2020	BAGALKOT	110	ITANAL- RAIBAG2	RAIBAG_110	12:34	13:12	0:38	LINE CLEAR AVAILED
205	24-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
206	24-Dec-2020	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN,LINE FAULT
207	24-Dec-2020	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
208	24-Dec-2020	BAGALKOT	220	220/110KV,HV2 & LV2	BELGAUM_220	14:07	15:32	1:25	TRANSFORMER FAULT
209	24-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
210	24-Dec-2020	BAGALKOT	220	BELGAUM- NARENDRA	BELGAUM_220	14:07	18:11	4:04	LINE FAULT
211	24-Dec-2020	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	15:01	17:14	2:13	LINE CLEAR AVAILED
212	24-Dec-2020	BAGALKOT	220	BIDNAL-TADAS 1	BIDNAL_220	16:48	17:27	0:39	LINE CLEAR AVAILED
213	24-Dec-2020	BAGALKOT	220	BIDNAL-TADASINKOPPA2	STATION NOT AFFECTED BIDNAL_220	9:00 (23.12.2020)			LINE OPEN,LINE CLEAR AVAILED
214	24-Dec-2020	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN,LINE CLEAR AVAILED
215	24-Dec-2020	BAGALKOT	220	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	4:36	6:27	1:51	LINE FAULT
216	24-Dec-2020	BAGALKOT	220	NARENDRA- KANABARGI1 (BELGAUM1)	NARENDRA_220	14:07	18:11	4:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
217	24-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
218	24-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
219	24-Dec-2020	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	16:38	16:39	00:01	LOAD CHANGE OVER
220	24-Dec-2020	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	14:15	14:20	00:05	LOAD CHANGE OVER
221	24-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
222	24-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
223	24-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
224	24-Dec-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	12:55	14:20	01:25	LINE CLEAR AVAILED
225	24-Dec-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	04:37	05:10	00:33	LINE FAULT
226	24-Dec-2020	GULBARGA	220	RTPS-LINGASUGUR3	LINGUSUGUR_220	04:33	05:44	01:11	LINE FAULT
227	24-Dec-2020	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	14:30	14:35	00:05	LINE FAULT
228	24-Dec-2020	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:05	12:15	01:10	LINE CLEAR AVAILED
229	24-Dec-2020	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
230	24-Dec-2020	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
231	24-Dec-2020	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
232	24-Dec-2020	HASSAN	110	HV2	KONAJE_110	10:10	13:30	03:20	LINE CLEAR AVAILED
233	24-Dec-2020	HASSAN	110	LV1	MSEZ_220	10:05	14:33	04:28	LINE CLEAR AVAILED
234	24-Dec-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	13:54	14:00	00:06	HAND TRIPPED
235	24-Dec-2020	HASSAN	110	MRSSHM-SS1	MRSMSG_220	14:00	14:04	00:04	HAND TRIPPED
236	24-Dec-2020	HASSAN	110	MRSSHM-SS2	MRSMSG_220	13:59	14:00	00:01	HAND TRIPPED
237	24-Dec-2020	HASSAN	220	HV1	MSEZ_220	10:05	14:33	04:28	LINE CLEAR AVAILED
238	24-Dec-2020	MYSURU	66	CR NAGARA-DR PETE 1	NO STATIONS EFFECTED	6:13	6:30	0:17	LINE FAULT
239	24-Dec-2020	MYSURU	66	CR NAGARA-DR PETE 1	NO STATIONS EFFECTED	7:52	8:20	0:28	LINE FAULT
240	24-Dec-2020	MYSURU	66	CR NAGARA-DR PETE 1	NO STATIONS EFFECTED	8:27	8:47	0:20	LINE FAULT
241	24-Dec-2020	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	11:09	15:07	3:58	LINE CLEAR AVAILED
242	24-Dec-2020	MYSURU	66	DR PETE -KUNTHUR	SANTHEMARAHALLI_66	12:50	15:10	2:20	NFBC ISSUED
243	24-Dec-2020	MYSURU	66	HV1	TUBINAKERE_220	11:30	12:00	0:30	LINE CLEAR AVAILED
244	24-Dec-2020	MYSURU	66	HV1	BANNUR_66	23:50 (24.12.2020)	1:10		LINE OPEN,LINE CLEAR AVAILED
245	24-Dec-2020	MYSURU	66	KR PETE 220-CR PATNA	KRISHNAPURA_66 ANEGOLAL_66	21:26	21:33	0:07	LINE FAULT
246	24-Dec-2020	MYSURU	66	KUNTHUR-DR PETE	SANTHEMARAHALLI_66	12:44	15:10	2:25	NFBC ISSUED
247	24-Dec-2020	MYSURU	66	MADHUVANAHALLI- KOLLEGALA	NO STATIONS EFFECTED	15:43 (23.12.2020)	14:33	22:50 hrs	LINE CHARGED
248	24-Dec-2020	MYSURU	66	MADHUVANAHALLI- MAMBALLI	MAMBALLI_66	16:48	16:53	0:05	LINE FAULT
249	24-Dec-2020	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN,LINE CLEAR AVAILED
250	24-Dec-2020	MYSURU	220	HV 1	KADAKOLA_220	6:31	7:12	0:41	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
251	24-Dec-2020	MYSURU	220	HV 2	KADAKOLA_220	6:31	7:28	0:57	TRANSFORMER FAULT
252	24-Dec-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	6:24	7:00	0:35	LINE FAULT
253	24-Dec-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	9:33	11:30	1:57	LINE FAULT
254	24-Dec-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	5:52	6:01	0:09	LINE FAULT
255	24-Dec-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	6:29	6:48	0:19	LINE FAULT
256	24-Dec-2020	TUMKUR	66	BEVINAHALLI- JAVAGONDANAHALLI	BEVINAHALLI_66	10:51	11:04	0:12	LINE FAULT
257	24-Dec-2020	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	8:12	8:35	0:22	LINE FAULT
258	24-Dec-2020	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	8:35	10:57	2:22	LINE FAULT
259	24-Dec-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	7:12	7:18	0:06	MAIN SUPPLY FAILURE
260	24-Dec-2020	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	14:09	14:16	0:06	LINE FAULT
261	24-Dec-2020	TUMKUR	66	TR-1	CHALLAKERE_66	16:22	16:30	0:07	TRANSFORMER FAULT
262	24-Dec-2020	TUMKUR	66	TR-1	CHITRADURGA_66	13:27	13:55	0:27	LINE CLEAR AVAILED
263	24-Dec-2020	TUMKUR	66	TR-1	MATHOD_66	13:09	13:12	0:03	TRANSFORMER FAULT
264	24-Dec-2020	TUMKUR	66	TR-1	RAMPURA_66	12:13	12:31	0:17	TRANSFORMER FAULT
265	24-Dec-2020	TUMKUR	66	TR-1	SOKKE_66	15:22	15:53	0:31	MAIN SUPPLY FAILURE
266	24-Dec-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	10:58	11:02	0:04	TRANSFORMER FAULT
267	24-Dec-2020	TUMKUR	66	TR-2	KOLALA_66	17:44	18:43	0:59	TRANSFORMER FAULT
268	24-Dec-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:29	14:50	1:20	LINE CLEAR AVAILED
269	25-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
270	25-Dec-2020	BAGALKOT	110	110/11KV, HV1	SIRSI_110	11:36	12:00	0:24	LINE CLEAR AVAILED
271	25-Dec-2020	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
272	25-Dec-2020	BAGALKOT	110	110/11KV, HV4	KERUR_110	10:02	11:30	1:28	LINE CLEAR AVAILED
273	25-Dec-2020	BAGALKOT	110	110/11KV,HV2	DHAVALESHWAR_110	16:22	16:52	0:30	HAND TRIPPED
274	25-Dec-2020	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	8:31	8:43	0:12	TRANSFORMER FAULT
275	25-Dec-2020	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	10:43	11:23	0:40	TRANSFORMER FAULT
276	25-Dec-2020	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	8:31	8:43	0:12	TRANSFORMER FAULT
277	25-Dec-2020	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33	6:51	6:54	0:03	TRANSFORMER FAULT
278	25-Dec-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED, HALSANGI_33	12:38	15:25	2:47	LINE CLEAR AVAILED
279	25-Dec-2020	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	10:32	10:48	0:16	LINE FAULT
280	25-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
281	25-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
282	25-Dec-2020	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	10:46	10:51	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
283	25-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
284	25-Dec-2020	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN,LINE FAULT
285	25-Dec-2020	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
286	25-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
287	25-Dec-2020	BAGALKOT	220	BELGAUM- NARENDRA	BELGAUM_220	11:07	19:20	8:13	NFBC ISSUED
288	25-Dec-2020	BAGALKOT	220	BIDNAL-TADASINKOPPA2	STATION NOT AFFECTED BIDNAL_220	9:00 (23.12.2020)			LINE OPEN,LINE CLEAR AVAILED
289	25-Dec-2020	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN,LINE CLEAR AVAILED
290	25-Dec-2020	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	12:20	14:17	1:57	LINE CLEAR AVAILED
291	25-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
292	25-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
293	25-Dec-2020	BENGALURU	66	ACHALU - KANAKAPURA 220	ACHALU, HONNIGANAHALLI, DODDALAHALLI	12:00	12:25	00:25	LINE FAULT
294	25-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
295	25-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
296	25-Dec-2020	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	12:00	13:00	01:00	MAIN SUPPLY FAILURE
297	25-Dec-2020	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	15:25	15:35	00:10	LOAD CHANGE OVER
298	25-Dec-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	12:05	12:25	00:15	LINE FAULT
299	25-Dec-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	12:35	15:32	02:57	LINE CLEAR AVAILED
300	25-Dec-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	11:25	11:39	00:14	LOAD CHANGE OVER
301	25-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
302	25-Dec-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	14:06	17:05	02:59	LINE FAULT
303	25-Dec-2020	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	05:52	05:56	00:04	LINE FAULT
304	25-Dec-2020	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	07:58	12:26	04:28	LINE CLEAR AVAILED
305	25-Dec-2020	GULBARGA	110	HALBARGA-CHIDRI2	CHIDRI_110	11:20	12:20	01:00	LINE CLEAR AVAILED
306	25-Dec-2020	GULBARGA	110	HATTI-GAMESH_IPP	GAMESH_IPP	18:20	18:26	00:06	LINE FAULT
307	25-Dec-2020	GULBARGA	110	HV2	GULBARGA UNIVERSITY_110	21:40	22:05	00:25	LINE CLEAR AVAILED
308	25-Dec-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	00:37	00:42	00:05	LINE FAULT
309	25-Dec-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	01:55	02:00	00:05	LINE FAULT
310	25-Dec-2020	GULBARGA	110	MALLAT-BYAGAWAT1,2	BYAGAWAT_110,VALKAMDINNI_110 ,MANVI_110,MADALAPUR_110	03:13	03:26	00:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
311	25-Dec-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	23:05	23:15	00:10	LINE FAULT
312	25-Dec-2020	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:26	18:36	00:10	LINE FAULT
313	25-Dec-2020	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
314	25-Dec-2020	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
315	25-Dec-2020	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
316	25-Dec-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	11:02	11:07	00:05	LINE FAULT
317	25-Dec-2020	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	13:32	18:18	04:46	LINE FAULT
318	25-Dec-2020	HASSAN	110	HV3	PUTTUR_110	08:03	08:13	00:10	TRANSFORMER FAULT
319	25-Dec-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	09:46	09:50	00:04	LINE FAULT
320	25-Dec-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:21	10:25	00:04	LINE FAULT
321	25-Dec-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	11:20	11:30	00:10	LINE FAULT
322	25-Dec-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	12:02	12:07	00:05	LINE FAULT
323	25-Dec-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	14:35	14:45	00:10	LINE FAULT
324	25-Dec-2020	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	15:56	16:11	00:15	LINE FAULT
325	25-Dec-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	10:21	10:25	00:04	HAND TRIPPED
326	25-Dec-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	11:20	11:30	00:10	HAND TRIPPED
327	25-Dec-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	10:21	10:25	00:04	HAND TRIPPED
328	25-Dec-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	11:20	11:30	00:10	HAND TRIPPED
329	25-Dec-2020	HASSAN	110	SAGARA-IDLE	SAGARA_110	10:45	10:50	00:05	HAND TRIPPED
330	25-Dec-2020	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:42	10:49	00:07	HAND TRIPPED
331	25-Dec-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	17:36	20:43	03:07	LINE FAULT
332	25-Dec-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	17:36	20:43	03:07	LINE FAULT
333	25-Dec-2020	MYSURU	66	HOOTAGALLI-HAMPAPURA(KAGGERE)	KAGGERE HAMPAPURA_66	1:26	1:40	0:14	LINE FAULT
334	25-Dec-2020	MYSURU	66	HV1	BANNUR_66	15:45	17:17	1:32	LINE CLEAR AVAILED
335	25-Dec-2020	MYSURU	66	HV1	BANNUR_66	23:50 (24.12.2020)	1:10(25.12.20)	01:20 hrs	LINE CHARGED
336	25-Dec-2020	MYSURU	66	KR PETE 220-MADESHWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	12:52	12:57	0:05	LINE FAULT
337	25-Dec-2020	MYSURU	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYASRAJPURA_66 CHIDRAVALLI_66 BGPURA_66	6:30	6:45	0:14	LINE FAULT
338	25-Dec-2020	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN,LINE CLEAR AVAILED
339	25-Dec-2020	MYSURU	66	VAJMANGALA-KADAKOLA 1	NO STATIONS EFFECTED	6:16	6:39	0:22	LINE FAULT
340	25-Dec-2020	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	7:22	7:39	0:17	LINE FAULT
341	25-Dec-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:10	8:20	0:09	LINE FAULT
342	25-Dec-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:02	11:25	0:22	LINE FAULT
343	25-Dec-2020	TUMKUR	66	JAVAGONDANAHALLI-BEVINAHALLI	JAVAGONDANAHALLI_66	7:02	7:20	0:18	LINE FAULT
344	25-Dec-2020	TUMKUR	66	TR-1	HANAGAL_66	11:45	11:47	0:02	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
345	25-Dec-2020	TUMKUR	66	TR-1	TAVAREKERE(C)_66	5:55	6:01	0:05	HAND TRIPPED
346	25-Dec-2020	TUMKUR	66	TR-2	AVAREGERE_66	11:22	12:41	1:18	LINE CLEAR AVAILED
347	25-Dec-2020	TUMKUR	66	TR-2	HOLALKERE_66	15:39	15:43	0:04	TRANSFORMER FAULT
348	25-Dec-2020	TUMKUR	66	TR-2	KORA_66	14:28	14:57	0:29	TRANSFORMER FAULT
349	25-Dec-2020	TUMKUR	110	HONNAVALI 110- ARASIKERE220	HONNAVALI_110	13:33	13:47	0:13	MAIN SUPPLY FAILURE
350	25-Dec-2020	TUMKUR	110	HONNAVALI 110- ARASIKERE220	HONNAVALI_110	14:48	18:19	3:30	MAIN SUPPLY FAILURE
351	26-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
352	26-Dec-2020	BAGALKOT	110	110/11KV, HV2	RON_110	01:40	01:50	0:10	TRANSFORMER FAULT
353	26-Dec-2020	BAGALKOT	110	110/11KV, HV2	MATTIHAL_110, KOLAR W/S_33, KARJOL LIS_33	23:43	23:45	0:02	TRANSFORMER FAULT
354	26-Dec-2020	BAGALKOT	110	110/11KV, HV2	KADANKOPPA_110	22:07	22:41	0:34	HAND TRIPPED
355	26-Dec-2020	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
356	26-Dec-2020	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	9:25	9:34	0:09	TRANSFORMER FAULT
357	26-Dec-2020	BAGALKOT	110	110/33KV, HV1	KADANKOPPA_110, KALGHATAGI_33, DUMMAWADA_33	22:07	22:44	0:37	HAND TRIPPED
358	26-Dec-2020	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR_33	12:42	12:52	0:10	TRANSFORMER FAULT
359	26-Dec-2020	BAGALKOT	110	BAGEWADI-MUDDABIHAL	MUDDABIHAL_110	7:15	07:22	0:07	LINE FAULT
360	26-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
361	26-Dec-2020	BAGALKOT	110	HAVERI-BYADAGI	BYDAGI_110	11:04	13:01	1:57	LINE CLEAR AVAILED
362	26-Dec-2020	BAGALKOT	110	HUBLI- KADANKOPPA	KADANKOPPA_110	20:53	21:58	1:05	LINE FAULT
363	26-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
364	26-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
365	26-Dec-2020	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN,LINE FAULT
366	26-Dec-2020	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
367	26-Dec-2020	BAGALKOT	220	220/110KV ,HV1 & LV1	HAVERI_220	11:09	12:53	1:44	LINE CLEAR AVAILED
368	26-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
369	26-Dec-2020	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	21:15 (26.12.2020)			LINE OPEN,LINE CLEAR AVAILED
370	26-Dec-2020	BAGALKOT	220	BELGAUM- NARENDRA	BELGAUM_220	21:13 (26.12.2020)			LINE OPEN,LINE CLEAR AVAILED
371	26-Dec-2020	BAGALKOT	220	BIDNAL-TADASINKOPPA2	STATION NOT AFFECTED BIDNAL_220	9:00 (23.12.2020)	15:17 (26.12.2020)	78:17 hrs	LINE CHARGED
372	26-Dec-2020	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN,LINE CLEAR AVAILED
373	26-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
374	26-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
375	26-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
376	26-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
377	26-Dec-2020	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	16:44	16:50	00:06	LINE FAULT
378	26-Dec-2020	BENGALURU	66	HV1	ISRO LAYOUT	10:15	10:32	00:17	LINE CLEAR AVAILED
379	26-Dec-2020	BENGALURU	66	HV1	ISRO LAYOUT	07:55	08:12	00:17	TRANSFORMER FAULT
380	26-Dec-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD	17:58	18:17	00:19	LINE FAULT
381	26-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
382	26-Dec-2020	GULBARGA	110	HATTI-GAMESH_IPP	GAMESH_IPP	12:22	17:30	05:08	LINE CLEAR AVAILED
383	26-Dec-2020	GULBARGA	110	HV2	GULBARGA UNIVERSITY_110	10:45	12:05	01:20	LINE CLEAR AVAILED
384	26-Dec-2020	HASSAN	66	BAGUR-UDAYAPUR	BAGUR_66	12:10	12:25	00:15	MAIN SUPPLY FAILURE
385	26-Dec-2020	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	03:45	04:03	00:18	LINE FAULT
386	26-Dec-2020	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
387	26-Dec-2020	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
388	26-Dec-2020	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
389	26-Dec-2020	HASSAN	66	MRSSHM-DVG2	MRSMG_220	11:31	11:40	00:09	LINE FAULT
390	26-Dec-2020	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	12:04	12:09	00:05	LINE FAULT
391	26-Dec-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	12:10	12:25	00:15	LINE FAULT
392	26-Dec-2020	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66	8:48	8:54	0:05	LINE FAULT
393	26-Dec-2020	MYSURU	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66 MUGUR_66 JANNUR_66 THAYURU_66 TNARASIPURA_66	18:07	18:14	0:06	LINE FAULT
394	26-Dec-2020	MYSURU	66	HV2	SANTHEMARAHALLI_66	12:52	13:03	0:10	LINE CLEAR AVAILED
395	26-Dec-2020	MYSURU	66	HV2	SANTHEMARAHALLI_66	16:31	17:50	1:19	LINE CLEAR AVAILED
396	26-Dec-2020	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN,LINE CLEAR AVAILED
397	26-Dec-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	17:54	17:59	0:05	LINE FAULT
398	26-Dec-2020	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	6:03:28 PM(26.12.2020)			LINE OPEN,LINE CLEAR AVAILED
399	26-Dec-2020	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_66	10:13	14:15	4:01	LINE CLEAR AVAILED
400	26-Dec-2020	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_66	10:13	14:14	4:00	LINE CLEAR AVAILED
401	26-Dec-2020	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 1	CHITRADURGA_66	10:13	14:23	4:09	LINE CLEAR AVAILED
402	26-Dec-2020	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 2	CHITRADURGA_66	10:13	14:17	4:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
403	26-Dec-2020	TUMKUR	66	CHITRADURGA 66KV- MEGMICON 1	MEGMICON 1_IPP_66	10:12	14:35	4:22	LINE CLEAR AVAILED
404	26-Dec-2020	TUMKUR	66	CHITRADURGA 66KV- PANDARAHALLI 2	CHITRADURGA_66	10:11	14:19	4:07	LINE CLEAR AVAILED
405	26-Dec-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:15	18:24	0:09	MAIN SUPPLY FAILURE
406	26-Dec-2020	TUMKUR	66	TR-1	CHITRADURGA_66	10:14	15:00	4:46	LINE CLEAR AVAILED
407	26-Dec-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	17:25	17:28	0:03	TRANSFORMER FAULT
408	26-Dec-2020	TUMKUR	66	TR-2	CHITRADURGA_66	10:13	15:00	4:47	LINE CLEAR AVAILED
409	26-Dec-2020	TUMKUR	66	TR-2	GUTTUR_66	9:27	10:46	1:19	TRANSFORMER FAULT
410	26-Dec-2020	TUMKUR	66	TR-2	KOLALA_66	16:00	17:19	1:19	TRANSFORMER FAULT
411	26-Dec-2020	TUMKUR	66	TR-2	NAYAKANAHATTI_66	15:14	15:17	0:03	HAND TRIPPED
412	26-Dec-2020	TUMKUR	110	TR-3	AMMASANDRA_110	3:35	4:32	0:56	LINE CLEAR AVAILED
413	27-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
414	27-Dec-2020	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
415	27-Dec-2020	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	17:02	17:22	0:20	LINE CLEAR AVAILED
416	27-Dec-2020	BAGALKOT	110	110/33KV, HV1	KADANKOPPA_110, KALGHATAGI_33, DUMMAWADA_33	14:25	17:19	2:54	LINE CLEAR AVAILED
417	27-Dec-2020	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33	12:44	12:49	0:05	TRANSFORMER FAULT
418	27-Dec-2020	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR_33	13:30	13:35	0:05	TRANSFORMER FAULT
419	27-Dec-2020	BAGALKOT	110	110/33KV,HV2	HANAGALL_110 & BOMMANALLI&LAXMIPUR_33	10:49	10:51	0:02	TRANSFORMER FAULT
420	27-Dec-2020	BAGALKOT	110	110/33KV,HV2	HANAGALL_110 & BOMMANALLI&LAXMIPUR_33	11:30	11:33	0:03	TRANSFORMER FAULT
421	27-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
422	27-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
423	27-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
424	27-Dec-2020	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN,LINE FAULT
425	27-Dec-2020	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
426	27-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
427	27-Dec-2020	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	21:15 (26.12.2020)	7:56 (27.12.2020)	10:41 hrs	LINE CHARGED
428	27-Dec-2020	BAGALKOT	220	BELGAUM- NARENDRA	BELGAUM_220	21:13 (26.12.2020)	7:49 (27.12.2020)	10:36 hrs	LINE CHARGED
429	27-Dec-2020	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN,LINE CLEAR AVAILED
430	27-Dec-2020	BAGALKOT	220	GHATAPRABHA-NARENDRA 2	GHATAPRABHA_220	20:27 (27.12.2020)			LINE OPEN,LINE CLEAR AVAILED
431	27-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
432	27-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
433	27-Dec-2020	BENGALURU	66	ARMY WELFARE - KADUGODI	ARMY WELFARE, KONDASPURA	07:13	08:17	01:04	LINE FAULT
434	27-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
435	27-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
436	27-Dec-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	17:05	17:15	00:10	LINE CLEAR AVAILED
437	27-Dec-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	19:34	19:37	00:03	LINE CLEAR AVAILED
438	27-Dec-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	19:33	19:38	00:04	LINE CLEAR AVAILED
439	27-Dec-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	17:05	17:15	00:10	LINE CLEAR AVAILED
440	27-Dec-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	19:33	19:40	00:06	LINE CLEAR AVAILED
441	27-Dec-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	17:05	17:15	00:10	LINE CLEAR AVAILED
442	27-Dec-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	06:02	06:10	00:07	LINE FAULT
443	27-Dec-2020	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	09:40	09:43	00:03	LOAD CHANGE OVER
444	27-Dec-2020	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	08:28	08:48	00:20	MAIN SUPPLY FAILURE
445	27-Dec-2020	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	04:58	05:05	00:07	TRANSFORMER FAULT
446	27-Dec-2020	BENGALURU	66	HV1	VIJAYANAGARA	18:24	18:30	00:06	MAIN SUPPLY FAILURE
447	27-Dec-2020	BENGALURU	66	HV1	VIJAYANAGARA	20:10	20:15	00:05	LOAD CHANGE OVER
448	27-Dec-2020	BENGALURU	66	HV2	KUNDANA	07:28	07:50	00:21	LINE CLEAR AVAILED
449	27-Dec-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	05:50	06:04	00:14	LINE FAULT
450	27-Dec-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	06:42	06:53	00:11	LINE FAULT
451	27-Dec-2020	BENGALURU	66	REMCO - NRS 220	NO STATION AFFECTED	18:24	20:09	01:45	LINE FAULT
452	27-Dec-2020	BENGALURU	66	REMCO - VRISHABHAVATHI 220	REMCO	18:24	18:59	00:35	LINE FAULT
453	27-Dec-2020	BENGALURU	66	VIDYANAGARA - HENNUR CROSS	NO STATION AFFECTED	08:20	09:27	01:07	LINE FAULT
454	27-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
455	27-Dec-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	01:14	01:29	00:15	MAIN SUPPLY FAILURE
456	27-Dec-2020	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	13:10	13:15	00:05	MAIN SUPPLY FAILURE
457	27-Dec-2020	GULBARGA	110	HV2	KAPANOOR_220	01:20	02:18	00:58	TRANSFORMER FAULT
458	27-Dec-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,ASKI_110,HUNSAGI_110	23:11	23:20	00:09	LINE FAULT
459	27-Dec-2020	GULBARGA	220	RTPS-LINGASUGUR1,2	LINGASUGUR_220	01:17	01:35	00:18	LINE FAULT
460	27-Dec-2020	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	08:08	11:40	03:32	LINE CLEAR AVAILED
461	27-Dec-2020	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	22:06(26.12.2020)	7:47:00 AM(27.12.2020)	9:41 hrs	LINE CHARGED
462	27-Dec-2020	HASSAN	66	HV1	GORUR_66	10:54	11:12	00:18	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
463	27-Dec-2020	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
464	27-Dec-2020	HASSAN	66	LV3	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
465	27-Dec-2020	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
466	27-Dec-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:44	10:54	00:10	LINE FAULT
467	27-Dec-2020	HASSAN	110	HV1	ALKOLA_110	10:07	17:24	07:17	LINE CLEAR AVAILED
468	27-Dec-2020	HASSAN	110	MANIPLA-HIRIYADKA	MANIPAL_110	17:49	18:01	00:12	HAND TRIPPED
469	27-Dec-2020	MYSURU	66	MADHUVANAHALLI-MAMBALLY	MAMBALLI_66	6:52	6:57	0:05	LINE FAULT
470	27-Dec-2020	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)	21:39	250:27 hrs	LINE CHARGED
471	27-Dec-2020	TUMKUR	66	ANCHEPALYA 220KV- VIJAYA STEEL	ANCHEPALYA_220	18:03:28 (26.12.2020)	18:21:15 (27.12.2020)	24:24 hrs	LINE CHARGED
472	27-Dec-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:10	18:20	0:10	MAIN SUPPLY FAILURE
473	27-Dec-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGU NDA_66	2:21	2:44	0:22	LINE FAULT
474	27-Dec-2020	TUMKUR	66	TR-1	KATTIGE_66	14:39	15:52	1:12	TRANSFORMER FAULT
475	27-Dec-2020	TUMKUR	66	TR-1	RAMPURA_66	15:50	16:01	0:11	TRANSFORMER FAULT
476	27-Dec-2020	TUMKUR	66	TR-2	KOLALA_66	13:55	14:16	0:21	TRANSFORMER FAULT
477	28-Dec-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
478	28-Dec-2020	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN,LINE CLEAR AVAILED
479	28-Dec-2020	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
480	28-Dec-2020	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN,LINE CLEAR AVAILED
481	28-Dec-2020	BAGALKOT	110	RANEBENNUR220-HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
482	28-Dec-2020	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN,LINE CLEAR AVAILED
483	28-Dec-2020	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
484	28-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
485	28-Dec-2020	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
486	28-Dec-2020	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN,LINE FAULT
487	28-Dec-2020	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN,LINE CLEAR AVAILED
488	28-Dec-2020	BAGALKOT	220	GHATAPRABHA-NARENDRA 2	GHATAPRABHA_220	20:27 (27.12.2020)	7:52 (28.12.2020)	11:25hrs	LINE CHARGED
489	28-Dec-2020	BAGALKOT	110	110/11KV,HV3	BAILHONGAL_110	12:32	12:46	0:14	HAND TRIPPED
490	28-Dec-2020	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	14:33	14:46	0:13	LINE FAULT
491	28-Dec-2020	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	11:36	14:14	2:38	LINE CLEAR AVAILED
492	28-Dec-2020	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	9:10(28.12.20)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
493	28-Dec-2020	BAGALKOT	220	220/110KV,HV2 &LV2	GADAG_220	15:02	17:45	2:43	LINE CLEAR AVAILED
494	28-Dec-2020	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	11:34	15:42	4:08	TRANSFORMER FAULT
495	28-Dec-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & AMINAGAD &KARADI_33	12:58	13:13	0:15	TRANSFORMER FAULT
496	28-Dec-2020	BAGALKOT	110	110/11KV, HV1	YELPARHATTI_110	11:28	16:45	5:17	LINE CLEAR AVAILED
497	28-Dec-2020	BAGALKOT	220	HUBLI- BIDNAL	HUBLI_220	11:35	16:15	4:40	LINE CLEAR AVAILED
498	28-Dec-2020	BAGALKOT	110	RANEBENNUR- BYADAGI (GUTTAL)	STATION NOT AFFECTED GUTTAL_110	12:06	18:16	6:10	LINE CLEAR AVAILED
499	28-Dec-2020	BAGALKOT	110	CHIKKODI220- RAIBAG2	RAIBAG_110	4:04	4:17	0:13	LINE FAULT
500	28-Dec-2020	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	14:38	15:03	0:25	TRANSFORMER FAULT
501	28-Dec-2020	BAGALKOT	220	220/110KV, HV1&LV1	MK HUBLI_220	13:56	14:30	0:34	LINE CLEAR AVAILED
502	28-Dec-2020	BAGALKOT	110	HUNGUND- KUDALSANGAM	KUDALSANGAM_110	10:29	10:39	0:10	HAND TRIPPED
503	28-Dec-2020	BAGALKOT	110	HUNGUND- KUDALSANGAM	KUDALSANGAM_110	12:56	13:15	0:19	HAND TRIPPED
504	28-Dec-2020	BAGALKOT	110	110/11KV, HV1	KUDALSANGAM_110	12:56	13:15	0:19	HAND TRIPPED
505	28-Dec-2020	BAGALKOT	220	GUTTURI1- HAVERI	HAVERI_220	20:18	21:29	1:11	LINE CLEAR AVAILED
506	28-Dec-2020	BENGALURU	66	HV1	BYADARHALLI	11:53	11:58	00:05	TRANSFORMER FAULT
507	28-Dec-2020	BENGALURU	66	HV1	BYADARHALLI	13:47	13:53	00:06	TRANSFORMER FAULT
508	28-Dec-2020	BENGALURU	66	HV2	ELECTRONIC CITY	10:42	10:50	00:08	LINE CLEAR AVAILED
509	28-Dec-2020	BENGALURU	66	HAL 220 - ADUGODI 2	NO STATION AFFECTED	15:45	16:48	01:03	LINE FAULT
510	28-Dec-2020	BENGALURU	66	HAL 220 - ADUGODI 2	NO STATION AFFECTED	16:49	19:14	02:25	LINE FAULT
511	28-Dec-2020	BENGALURU	66	HV2	AMAR JYOTHI	15:43	17:19	01:36	MAIN SUPPLY FAILURE
512	28-Dec-2020	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	11:43	11:56	00:13	LOAD CHANGE OVER
513	28-Dec-2020	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	16:09	16:15	00:06	LOAD CHANGE OVER
514	28-Dec-2020	BENGALURU	66	HV2	KUMBALAGODU	15:29	15:34	00:05	TRANSFORMER FAULT
515	28-Dec-2020	BENGALURU	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	11:29	12:04	00:35	LINE FAULT
516	28-Dec-2020	BENGALURU	220	HV1	VRISHABHAVATHI 220	12:45	13:08	00:23	TRANSFORMER FAULT
517	28-Dec-2020	BENGALURU	66	ARMY WELFARE - KONDASPURA	KONDASPURA	13:09	13:29	00:20	LINE CLEAR AVAILED
518	28-Dec-2020	BENGALURU	66	HV1	BAIRKURU	13:35	15:10	01:35	LINE CLEAR AVAILED
519	28-Dec-2020	BENGALURU	66	HV2	BAIRKURU	15:25	17:30	02:05	LINE CLEAR AVAILED
520	28-Dec-2020	BENGALURU	66	HV1	BAIRKURU	17:20	17:30	00:10	LINE CLEAR AVAILED
521	28-Dec-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	11:53	14:20	02:27	LINE CLEAR AVAILED
522	28-Dec-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	12:01	13:29	01:27	LINE CLEAR AVAILED
523	28-Dec-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	12:11	13:29	01:18	LINE CLEAR AVAILED
524	28-Dec-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	12:02	12:17	00:14	LINE CLEAR AVAILED
525	28-Dec-2020	BENGALURU	66	HV1	TUBUGERE	12:25	12:30	00:04	LINE CLEAR AVAILED
526	28-Dec-2020	BENGALURU	66	HV2	TUBUGERE	14:40	14:45	00:05	LINE CLEAR AVAILED
527	28-Dec-2020	BENGALURU	66	HV2	MAASTHI	12:27	14:36	02:08	LINE CLEAR AVAILED
528	28-Dec-2020	BENGALURU	66	WELCAST STEEL - ABBIGERE	WELCAST STEEL	03:13	03:28	00:15	LOAD CHANGE OVER
529	28-Dec-2020	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	10:15	10:20	00:05	LOAD CHANGE OVER
530	28-Dec-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
531	28-Dec-2020	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN,LINE CLEAR AVAILED
532	28-Dec-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN,LINE FAULT
533	28-Dec-2020	GULBARGA	400	JINDAL-BTPS	JINDAL_400	16:37(28.12.20)			LINE OPEN,LINE CLEAR AVAILED
534	28-Dec-2020	GULBARGA	220	HV2	HUMNABAD_220	22:55(28.12.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
535	28-Dec-2020	GULBARGA	110	ALIPUR-MUNIRBAD	TORANGALLU_110,KUDITINI_110,KU RUGOD_110,METRI_110	01:37	01:44	00:07	LINE FAULT
536	28-Dec-2020	GULBARGA	110	HV1	HANUMANAL_110	12:15	12:45	00:30	LINE CLEAR AVAILED
537	28-Dec-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,SIRIGUPPA_110, DHADESUGUR_110,TEKKALKOTE_110	15:10	15:20	00:10	LINE FAULT
538	28-Dec-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110	02:15	02:22	00:07	LINE FAULT
539	28-Dec-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	02:28	02:36	00:08	LINE FAULT
540	28-Dec-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	03:20	03:29	00:09	LINE FAULT
541	28-Dec-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	04:05	04:12	00:07	LINE FAULT
542	28-Dec-2020	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI,MADLAPUR,KURDICROSS_110	23:30	23:45	00:15	LINE FAULT
543	28-Dec-2020	GULBARGA	110	SHAHAPUR-WARDHA SLOAR	SHAHAPUR_220	19:00	23:01	4:01	LINE CLEAR AVAILED
544	28-Dec-2020	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
545	28-Dec-2020	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
546	28-Dec-2020	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN,LINE CLEAR AVAILED
547	28-Dec-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	17:47 (28.12.2020)			LINE OPEN,LINE FAULT
548	28-Dec-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	17:47 (28.12.2020)			LINE OPEN,LINE FAULT
549	28-Dec-2020	HASSAN	110	JOG-JLT4	mghejog_gen	11:11 (28.12.2020)			LINE OPEN,LINE CLEAR AVAILED
550	28-Dec-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	00:10	06:50	06:40	LINE CLEAR AVAILED
551	28-Dec-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	11:26	12:26	01:00	LINE CLEAR AVAILED
552	28-Dec-2020	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	01:55	07:13	05:18	LINE FAULT
553	28-Dec-2020	HASSAN	220	KADUR-SHIMOGA	KADUR_220	01:55	02:30	00:35	LINE FAULT
554	28-Dec-2020	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	01:55	07:16	05:21	LINE FAULT
555	28-Dec-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	15:23	15:29	00:06	LINE FAULT
556	28-Dec-2020	HASSAN	110	HV1	BAIKAMPADI_110	14:36	17:33	02:57	LINE CLEAR AVAILED
557	28-Dec-2020	HASSAN	110	HV1	BAIKAMPADI_110	17:35	17:40	00:05	MAIN SUPPLY FAILURE
558	28-Dec-2020	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	13:29	15:47	02:18	NFBC ISSUED
559	28-Dec-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:29	15:47	02:18	NFBC ISSUED
560	28-Dec-2020	HASSAN	66	HV2	HIRISAVE_66	10:39	11:17	00:38	TRANSFORMER FAULT
561	28-Dec-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	13:28	15:45	02:17	LINE CLEAR AVAILED
562	28-Dec-2020	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	13:37	15:45	02:08	MAIN SUPPLY FAILURE
563	28-Dec-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	11:34	12:07	00:33	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
564	28-Dec-2020	HASSAN	66	HV2	UDAYAPURA_66	12:20	12:25	00:05	TRANSFORMER FAULT
565	28-Dec-2020	MYSURU	66	HV1	CHINAKURALI_66	10:49	15:05	4:15	LINE CLEAR AVAILED
566	28-Dec-2020	MYSURU	66	HV2	CHINAKURALI_66	10:35	15:05	4:30	LINE CLEAR AVAILED
567	28-Dec-2020	MYSURU	66	HV2	DUNDANAHALLI_66	11:20	11:41	0:21	LINE CLEAR AVAILED
568	28-Dec-2020	MYSURU	66	HV1	HUNSUR_66	17:27	17:39	0:12	TRANSFORMER FAULT
569	28-Dec-2020	MYSURU	66	HV1	KHBCOLONY_66	9:16	16:25	7:09	LINE CLEAR AVAILED
570	28-Dec-2020	MYSURU	66	HV2	KHBCOLONY_66	16:27	17:46	1:19	LINE CLEAR AVAILED
571	28-Dec-2020	TUMKUR	400	GUTTUR- KAIGA	GUTTUR_66	13:02	18:39	5:37	LINE FAULT
572	28-Dec-2020	TUMKUR	220	TR-3	HIRIYUR_220	18:24	18:27	0:03	HAND TRIPPED
573	28-Dec-2020	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	10:10	13:05	2:55	LINE CLEAR AVAILED
574	28-Dec-2020	TUMKUR	66	ANCHEPALYA 220- VIJAYASTEELS	ANCHEPALYA_220	6:41	16:29	9:47	LINE CLEAR AVAILED
575	28-Dec-2020	TUMKUR	66	ANCHEPALYA 220- YEDIYUR	YEDIYUR_66	11:09	11:26	0:17	LINE FAULT
576	28-Dec-2020	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	10:49	14:14	3:24	LINE CLEAR AVAILED
577	28-Dec-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	21:25	21:42	0:16	TRANSFORMER FAULT
578	28-Dec-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	9:16	9:18	0:01	TRANSFORMER FAULT
579	28-Dec-2020	TUMKUR	66	HONNALLI 220- SASVEHALI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	15:26	15:39	0:12	LINE FAULT
580	28-Dec-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	8:25	8:37	0:11	TRANSFORMER FAULT