

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 27.08.2019 TO 02.09.2019**

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	27-Aug-19	BAGALKOT	110	SOUDATTI220-SOUDATTI1	SOUDATTI_110	9:07	13:23	4:16	LINE CLEAR AVAILED
2	27-Aug-19	BAGALKOT	110	SOUDATTI220-RAMADURG1	RAMADURG_110	9:05	13:24	4:19	LINE CLEAR AVAILED
3	27-Aug-19	BAGALKOT	110	110/11KV,HV1	SIRSI_110	11:23	11:25	0:02	HAND TRIPPED
4	27-Aug-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	10:11	17:34	7:23	LINE CLEAR AVAILED
5	27-Aug-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	10:20	10:28	0:08	HAND TRIPPED
6	27-Aug-19	BAGALKOT	110	110/11KV,HV2	SADALAGA_110	15:30	16:22	0:52	LINE CLEAR AVAILED
7	27-Aug-19	BAGALKOT	110	HUNAGUND-KUDALSANGAM	KUDALSANGAM_110	11:30	12:00	0:30	LINE CLEAR AVAILED
8	27-Aug-19	BAGALKOT	110	110/11KV,HV1	KUDUCHI_220	9:13	9:14	0:01	TRANSFORMER FAULT
9	27-Aug-19	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,KARADI_33,AMINGAD_110	10:21	10:24	0:03	TRANSFORMER FAULT
10	27-Aug-19	BAGALKOT	220	220/110KV,HV2	CHIKKODI_220	12:06	14:21	2:15	LINE CLEAR AVAILED
11	27-Aug-19	BAGALKOT	110	BELGAUM220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	5:42	6:03	0:21	LINE FAULT
12	27-Aug-19	BAGALKOT	110	110/33KV,HV2	ANKALAGI_110,KANAGAV_33,NESARGI_33	12:41	16:55	4:14	LINE CLEAR AVAILED
13	27-Aug-19	BAGALKOT	220	PONDAI 1-AMBEWADI	AMBEWADI_220	15:49	23:59	8:10	LINE CLEAR AVAILED
14	27-Aug-19	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	9:05	9:09	0:04	TRANSFORMER FAULT
15	27-Aug-19	BENGALURU	66	HV2	ISRO LAYOUT	21:40	22:00	0:20	LINE CLEAR AVAILED
16	27-Aug-19	BENGALURU	66	HV1	KANAKAPURA 66	10:50	10:55	0:05	LINE CLEAR AVAILED
17	27-Aug-19	BENGALURU	66	HV1	KANAKAPURA 66	16:00	16:05	0:05	LINE CLEAR AVAILED
18	27-Aug-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	MANDIKALLU, PERESANDRA, SOMENAHALLI	9:50	10:10	0:20	LOAD CHANGE OVER
19	27-Aug-19	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	MANDIKALLU, PERESANDRA, SOMENAHALLI	20:31	20:40	0:09	LOAD CHANGE OVER
20	27-Aug-19	BENGALURU	66	VIJAYAPURA - MELUR	JANGAMAKOTE	15:30	15:45	0:15	LOAD CHANGE OVER
21	27-Aug-19	BENGALURU	66	MELUR - VIJAYAPURA	JANGAMAKOTE	17:29	18:10	0:41	LOAD CHANGE OVER
22	27-Aug-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	15:37	15:47	0:10	LOAD CHANGE OVER
23	27-Aug-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	15:26	15:45	0:19	LOAD CHANGE OVER
24	27-Aug-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	15:37	15:47	0:10	LOAD CHANGE OVER
25	27-Aug-19	BENGALURU	66	APPAREL PARK - DB PURA 220	DODDABELAVANGALA, GUNDAMGERE	17:17	17:23	0:06	LOAD CHANGE OVER
26	27-Aug-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	17:07	17:11	0:04	LOAD CHANGE OVER
27	27-Aug-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	17:07	17:11	0:04	LOAD CHANGE OVER
28	27-Aug-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	15:37	15:47	0:10	LOAD CHANGE OVER
29	27-Aug-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	17:07	17:11	0:04	LOAD CHANGE OVER
30	27-Aug-19	BENGALURU	66	HV2	NRS 220	13:19	13:23	0:04	LOAD CHANGE OVER
31	27-Aug-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 1	AREHALLI	10:46	10:57	0:10	LOAD CHANGE OVER
32	27-Aug-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	10:46	10:57	0:10	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
33	27-Aug-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	16:08	16:12	0:04	LOAD CHANGEOVER
34	27-Aug-19	GULBARGA	110	HUMNABAD220-BHALKI	BHALKI_110,LADHA_110, DUBALGUNDI_110, MGSSK_SUGARS	6:40	7:20	0:40	LINE FAULT
35	27-Aug-19	GULBARGA	110	HUMNABAD220-CHITAGUPPA	CHITAGUPPA_110	9:50	10:10	0:20	LINE FAULT
36	27-Aug-19	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110, SHAKTHI NAGAR_110	12:54	12:59	0:05	LINE FAULT
37	27-Aug-19	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL	4:24	4:33	0:09	LINE FAULT
38	27-Aug-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,CORE GREEN SUGUR_IPP	12:00	14:20	2:20	LINE CLEAR AVAILED
39	27-Aug-19	GULBARGA	66	HV1, HV2	KOTTUR_110	10:30	11:25	0:55	LINE CLEAR AVAILED
40	27-Aug-19	GULBARGA	110	GABBUR-BPSLR	GABBUR_110	19:04	19:10	0:06	LINE FAULT
41	27-Aug-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	18:53	19:01	0:08	LINE FAULT
42	27-Aug-19	MYSORE	66	CR NAGARA-DR PETE 1	DODDARAYAPET_66	11:09	14:20	3:11	LINE CLEAR AVAILED
43	27-Aug-19	MYSORE	66	CR NAGARA-DR PETE 2	DODDARAYAPET_66	11:10	13:32	2:22	LINE CLEAR AVAILED
44	27-Aug-19	MYSORE	66	DR PETE-CR NAGARA 2	DODDARAYAPET_66	11:15	14:51	3:36	LINE CLEAR AVAILED
45	27-Aug-19	MYSORE	66	DUNDANAHALLI-HULIYURU DURGA	DUNDANAHALLI_66	13:11	14:27	1:16	LINE CLEAR AVAILED
46	27-Aug-19	MYSORE	66	HV1	HOOTAGALLY_220	9:05	9:10	0:04	HAND TRIPPED
47	27-Aug-19	MYSORE	66	HV2	HOOTAGALLY_220	9:05	9:10	0:04	HAND TRIPPED
48	27-Aug-19	MYSORE	220	HV2	HOOTAGALLY_220	9:45	13:05	3:19	LINE CLEAR AVAILED
49	27-Aug-19	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI(HEBBUR)	MAGADI_66, TGHALLI_66, VGDODDI_66	9:51	17:35	7:43	LINE CLEAR AVAILED
50	27-Aug-19	TUMKUR	66	TR-2	HALURAMESHWARA_66	11:57	12:03	0:05	HAND TRIPPED
51	28-Aug-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,DHULKHED_33KV,HALASANGI _33KV,NEVARGI_33	10:03	10:19	0:16	TRANSFORMER FAULT
52	28-Aug-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,DHULKHED_33KV,HALASANGI _33KV,NEVARGI_33	10:36	10:50	0:14	TRANSFORMER FAULT
53	28-Aug-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,DHULKHED_33KV,HALASANGI _33KV,NEVARGI_33	12:59	13:09	0:10	TRANSFORMER FAULT
54	28-Aug-19	BAGALKOT	220	220/110KV,HV1,LV1	SOUDATTI_220	10:26	14:29	4:03	LINE CLEAR AVAILED
55	28-Aug-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	8:38	17:45	9:07	LINE FAULT
56	28-Aug-19	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	14:39	17:47	3:08	LINE CLEAR AVAILED
57	28-Aug-19	BAGALKOT	110	110/33KV,HV2	SADALAGA_110,BHOJ_33KV	15:26	16:21	0:55	LINE CLEAR AVAILED
58	28-Aug-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	8:06	8:37	0:31	LINE CLEAR AVAILED
59	28-Aug-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	8:46	10:37	1:51	LINE CLEAR AVAILED
60	28-Aug-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	9:42	19:09	9:27	LINE CLEAR AVAILED
61	28-Aug-19	BAGALKOT	220	SHARAVATHI1&2-SIRSI	SIRSI_220	10:26	13:44	3:18	LINE CLEAR AVAILED
62	28-Aug-19	BAGALKOT	220	220/110KV,HV1	SIRSI_220	10:26	13:44	3:18	LINE CLEAR AVAILED
63	28-Aug-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	14:39	23:59	9:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
64	28-Aug-19	BAGALKOT	110	110/33KV,HV3	MAMADPUR(B)_110,DEVARGENNUR_33KV	11:46	11:54	0:08	HAND TRIPPED
65	28-Aug-19	BAGALKOT	110	110/11KV,HV1	DAVALESHWAR_110	13:04	17:31	4:27	LINE CLEAR AVAILED
66	28-Aug-19	BAGALKOT	110	GHATAPRABHA220-HIDIKAL DAM	HIDIKAL DAM_110	13:15	15:09	1:54	LINE CLEAR AVAILED
67	28-Aug-19	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	12:00	12:24	0:24	LINE CLEAR AVAILED
68	28-Aug-19	BAGALKOT	110	BAGEWADI-SINDAGI	SINDAGI_110	12:00	12:10	0:10	LINE CLEAR AVAILED
69	28-Aug-19	BAGALKOT	220	220/110KV, HV3	BAGEWADI_220	12:00	22:25	10:25	LINE CLEAR AVAILED
70	28-Aug-19	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	22:04	22:15	0:11	LINE FAULT
71	28-Aug-19	BAGALKOT	110	HAVERI220-SAVNUR	SAVNUR_110	6:31	6:49	0:18	LINE FAULT
72	28-Aug-19	BAGALKOT	110	110/11KV,HV4	KERUR_110	11:26	13:05	1:39	LINE CLEAR AVAILED
73	28-Aug-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	16:41	17:41	1:00	LINE CLEAR AVAILED
74	28-Aug-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	8:35	9:10	0:35	LINE FAULT
75	28-Aug-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	9:25	10:27	1:02	LINE CLEAR AVAILED
76	28-Aug-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	11:11	12:38	1:27	LINE CLEAR AVAILED
77	28-Aug-19	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	8:35	9:24	0:49	MAIN SUPPLY FAILURE
78	28-Aug-19	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	12:40	12:46	0:06	LOAD CHANGEOVER
79	28-Aug-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	19:25	19:57	0:32	LOAD CURTAILMENT
80	28-Aug-19	BENGALURU	66	HV1	KYALANUR	12:19	13:30	1:11	LINE CLEAR AVAILED
81	28-Aug-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR 220	MANDIKALLU, PERESANDRA, SOMENAHALLI	9:50	9:59	0:09	LOAD CHANGEOVER
82	28-Aug-19	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	MANDIKALLU, PERESANDRA, SOMENAHALLI	18:09	18:15	0:06	LOAD CHANGEOVER
83	28-Aug-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	18:32	19:08	0:36	LINE FAULT
84	28-Aug-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2		18:32	19:10	0:38	LINE FAULT
85	28-Aug-19	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), AMARJYOTHI	15:40	15:46	0:06	LOAD CHANGEOVER
86	28-Aug-19	BENGALURU	66	ADUGODI - HSR LAYOUT 220 220	ADUGODI, BOSCH (EHT), AMARJYOTHI	14:22	15:10	0:48	LINE CLEAR AVAILED
87	28-Aug-19	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	15:02	15:09	0:07	LOAD CHANGEOVER
88	28-Aug-19	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	14:04	16:34	2:30	LINE CLEAR AVAILED
89	28-Aug-19	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	HSR LAYOUT 220	14:20	15:18	0:58	LINE FAULT
90	28-Aug-19	BENGALURU	66	JAYANAGARA - NATIONAL COLLEGE	NATIONAL	11:32	13:26	1:54	LINE FAULT
91	28-Aug-19	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	11:32	12:19	0:47	LINE FAULT
92	28-Aug-19	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	11:38	12:22	0:44	MAIN SUPPLY FAILURE
93	28-Aug-19	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	15:48	15:54	0:05	LOAD CHANGEOVER
94	28-Aug-19	BENGALURU	66	HV1	NRS 220	14:08	16:34	2:26	LINE CLEAR AVAILED
95	28-Aug-19	BENGALURU	66	HV2	NRS 220	14:06	16:34	2:28	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
96	28-Aug-19	BENGALURU	66	HV2	NRS 220	23:06	23:13	0:06	LOAD CHANGEOVER
97	28-Aug-19	BENGALURU	66	HV3	NRS 220	14:06	16:34	2:27	LINE CLEAR AVAILED
98	28-Aug-19	BENGALURU	66	HV4	NRS 220	14:07	16:34	2:27	LINE CLEAR AVAILED
99	28-Aug-19	BENGALURU	66	HV5	NRS 220	14:07	16:34	2:27	LINE CLEAR AVAILED
100	28-Aug-19	BENGALURU	66	HV1	NATIONAL COLLEGE	10:46	10:54	0:08	TRANSFORMER FAULT
101	28-Aug-19	BENGALURU	66	HV1	POTTERY ROAD	11:16	12:11	0:54	LINE CLEAR AVAILED
102	28-Aug-19	BENGALURU	66	HV1	TK HALLI 220	12:18	13:55	1:36	LINE CLEAR AVAILED
103	28-Aug-19	GULBARGA	110	LV1	SINDHANOOR_220	0:59	1:12	0:13	TRANSFORMER FAULT
104	28-Aug-19	GULBARGA	110	SINDHANOOR220-RAICHUR1	SINDHANOOR_110	0:59	1:14	0:15	LINE FAULT
105	28-Aug-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110, BTPS WATER WORKS	0:59	1:17	0:18	LINE FAULT
106	28-Aug-19	GULBARGA	110	SINDHANOOR220-NIRLOOTI_IPP	SINDHANOOR_220	0:59	1:15	0:16	LINE FAULT
107	28-Aug-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPURA_110	5:36	5:50	0:14	LINE FAULT
108	28-Aug-19	GULBARGA	110	HALBURGA-BHALKI	BHALKI_110,LADHA_110, DUBALGUNDI_110, MGSSK_SUGARS	0:35	0:54	0:19	LINE FAULT
109	28-Aug-19	GULBARGA	110	KAPNOOR220-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	11:29	11:36	0:07	LINE FAULT
110	28-Aug-19	GULBARGA	110	HV1	KUDITINI_110	11:56	11:59	0:03	LINE CLEAR AVAILED
111	28-Aug-19	GULBARGA	110	HV2	SHORAPUR_110	7:58	8:06	0:08	TRANSFORMER FAULT
112	28-Aug-19	GULBARGA	110	KEMBHAVI-SHAHPUR220	KEMBHAVI_110, UGARSUGARS_IPP	4:06	4:13	0:07	LINE FAULT
113	28-Aug-19	GULBARGA	110	KEMBHAVI-UGAR SUGARS_IPP	UGARSUGARS_IPP	4:06	4:40	0:34	LINE FAULT
114	28-Aug-19	GULBARGA	110	KEMBHAVI-SHAHPUR220	KEMBHAVI_110, UGARSUGARS_IPP	5:35	5:41	0:06	LINE FAULT
115	28-Aug-19	GULBARGA	110	KEMBHAVI-UGAR SUGARS_IPP	UGARSUGARS_IPP	5:35	8:34	2:59	LINE FAULT
116	28-Aug-19	GULBARGA	110	HV1	SHAHAPUR_220	0:12	0:30	0:18	TRANSFORMER FAULT
117	28-Aug-19	GULBARGA	110	SHAHAPUR220-KHANAPUR	KHANAPUR_110	4:46	5:03	0:17	LINE FAULT
118	28-Aug-19	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIRHADAGALLI_66	7:55	8:10	0:15	LINE FAULT
119	28-Aug-19	GULBARGA	66	ITTAGI-HIREHADAGALLI1	HIRHADAGALLI_66	8:04	8:10	0:06	LINE FAULT
120	28-Aug-19	GULBARGA	66	ITTAGI-HIREHADAGALLI2	HIRHADAGALLI_66	11:08	13:12	2:04	LINE CLEAR AVAILED
121	28-Aug-19	GULBARGA	66	ITTAGI-HIREHADAGALLI1	HIRHADAGALLI_66	13:22	13:24	0:02	LINE CLEAR AVAILED
122	28-Aug-19	GULBARGA	66	ITTAGI-BENNEHALI	BENNEHALI_66	13:26	13:28	0:02	LINE CLEAR AVAILED
123	28-Aug-19	GULBARGA	66	LV2	ITTAGI_220	18:37	18:45	0:08	TRANSFORMER FAULT
124	28-Aug-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGU	0:00	8:52	8:52	LINE CLEAR AVAILED
125	28-Aug-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGU	13:00	23:59	10:59	LINE CLEAR AVAILED
126	28-Aug-19	HASSAN	220	KADUR-DABUSET	KADUR	12:56	14:41	1:45	LINE FAULT
127	28-Aug-19	HASSAN	220	SHRAVITY-SIRISI 1	SHRAVTY	13:24	13:44	0:20	HAND TRIPPED
128	28-Aug-19	HASSAN	220	SHRAVITY-SIRISI 2	SHRAVTY	13:25	13:44	0:19	HAND TRIPPED
129	28-Aug-19	HASSAN	220	MRSSHM-VARAH12	MRSSHM	0:00	13:31	13:31	LINE CLEAR AVAILED
130	28-Aug-19	HASSAN	110	MRSSHM-MPM	MRSSHM	11:25	11:35	0:10	LINE CLEAR AVAILED
131	28-Aug-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR	12:02	14:19	2:17	NFBC ISSUED
132	28-Aug-19	HASSAN	110	HV2	MOODAB	11:12	11:36	0:24	LINE CLEAR AVAILED
133	28-Aug-19	HASSAN	66	HV1	BASAVAGT	12:20	15:28	3:08	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
134	28-Aug-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA	12:23	12:31	0:08	LINE FAULT
135	28-Aug-19	HASSAN	66	HV1	JUTTANA	13:25	13:57	0:32	LINE CLEAR AVAILED
136	28-Aug-19	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAM	16:41	17:06	0:25	LINE FAULT
137	28-Aug-19	MYSORE	220	HV2	MADHUVANAHALLI_220	13:09	14:05	0:55	HAND TRIPPED
138	28-Aug-19	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	13:50	14:07	0:16	LINE CLEAR AVAILED
139	28-Aug-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	13:50	14:46	0:56	LINE CLEAR AVAILED
140	28-Aug-19	TUMKUR	110	TR-2	NITTUR_220	11:51	15:19	3:27	LINE CLEAR AVAILED
141	28-Aug-19	TUMKUR	110	TR-1	BANDIHALLI_110	11:12	11:51	0:38	LINE CLEAR AVAILED
142	28-Aug-19	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	10:22	11:01	0:38	HAND TRIPPED
143	28-Aug-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	12:27	15:09	2:42	LINE CLEAR AVAILED
144	28-Aug-19	TUMKUR	66	TR-1( HV SIDE)	DAVANGERE_SRS_220	6:58	7:13	0:15	TRANSFORMER FAULT
145	28-Aug-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	8:41	16:41	7:59	LINE CLEAR AVAILED
146	28-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	8:41	16:40	7:59	LINE CLEAR AVAILED
147	28-Aug-19	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR )	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	7:57	8:06	0:08	LINE FAULT
148	28-Aug-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	8:10	8:36	0:26	HAND TRIPPED
149	28-Aug-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	8:10	18:12	10:01	LINE CLEAR AVAILED
150	28-Aug-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	6:06	6:22	0:16	LINE FAULT
151	28-Aug-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	11:09	11:36	0:26	HAND TRIPPED
152	28-Aug-19	TUMKUR	66	TR-2	RANGANATHAPURA_66	17:15	17:30	0:14	LINE CLEAR AVAILED
153	29-Aug-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33KV,NEVARGI_3 3KV,DHULKED_33KV	8:17	8:27	0:10	LINE CLEAR AVAILED
154	29-Aug-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33KV,NEVARGI_3 3KV,DHULKED_33KV	9:42	9:47	0:05	TRANSFORMER FAULT
155	29-Aug-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33KV,NEVARGI_3 3KV,DHULKED_33KV	11:29	11:36	0:07	TRANSFORMER FAULT
156	29-Aug-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33KV,NEVARGI_3 3KV,DHULKED_33KV	12:12	12:21	0:09	TRANSFORMER FAULT
157	29-Aug-19	BAGALKOT	110	BEGLAUM-VADAGOAN	VADAGOAN_110	8:24	16:33	8:09	NFBC ISSUED
158	29-Aug-19	BAGALKOT	110	110/11KV,HV1	UCHAGAON_110	11:58	13:24	1:26	LINE CLEAR AVAILED
159	29-Aug-19	BAGALKOT	110	JAMKHANDI-TODALBAGI	TODALBAGI_110	11:19	11:35	0:16	HAND TRIPPED
160	29-Aug-19	BAGALKOT	220	220/110KV,HV2&LV2	SOUDATTI_220	11:39	18:21	6:42	LINE CLEAR AVAILED
161	29-Aug-19	BAGALKOT	110	SOUDATTI220-RAMDURGA2	RAMDURGA_110	9:52	14:35	4:43	LINE CLEAR AVAILED
162	29-Aug-19	BAGALKOT	110	SOUDATTI220-SOUDATTI2	SOUDATTI_110	9:53	15:17	5:24	LINE CLEAR AVAILED
163	29-Aug-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	15:40	16:27	0:47	LINE CLEAR AVAILED
164	29-Aug-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	10:14	18:20	8:06	LINE CLEAR AVAILED
165	29-Aug-19	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	11:04	13:42	2:38	LINE CLEAR AVAILED
166	29-Aug-19	BAGALKOT	110	110/11KV,HV1	LAXMESHVAR_110	6:49	7:03	0:14	LOAD CURTAILMENT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
167	29-Aug-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	6:55	7:11	0:16	LOAD CURTAILMENT
168	29-Aug-19	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	11:14	13:39	2:25	LINE CLEAR AVAILED
169	29-Aug-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA	7:28	8:10	0:42	LOAD CURTAILMENT
170	29-Aug-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI	6:55	7:28	0:33	LOAD CURTAILMENT
171	29-Aug-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	15:08	15:10	0:02	LOAD CHANGEOVER
172	29-Aug-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	16:52	16:54	0:02	LOAD CHANGEOVER
173	29-Aug-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	6:50	7:42	0:52	LOAD CURTAILMENT
174	29-Aug-19	BENGALURU	66	HV2	MAASTHI	15:15	16:22	1:07	LINE CLEAR AVAILED
175	29-Aug-19	BENGALURU	66	HV2	MAASTHI	18:34	18:41	0:07	TRANSFORMER FAULT
176	29-Aug-19	BENGALURU	66	MANDIKALLU - GOWRIBIDANUR	MANDIKALLU, PERESANDRA, SOMENAHALLI	6:47	7:31	0:44	LOAD CHANGEOVER
177	29-Aug-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	MANDIKALLU, PERESANDRA, SOMENAHALLI	20:47	20:50	0:03	LOAD CHANGEOVER
178	29-Aug-19	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	17:48	17:50	0:02	LOAD CHANGEOVER
179	29-Aug-19	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	18:38	18:40	0:02	LOAD CHANGEOVER
180	29-Aug-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	20:45	21:21	0:35	LINE FAULT
181	29-Aug-19	BENGALURU	66	HV1	KADUBISANAHALLI	13:00	13:38	0:38	LINE CLEAR AVAILED
182	29-Aug-19	BENGALURU	66	HV1	TELECOM LAYOUT	15:18	17:33	2:15	LINE CLEAR AVAILED
183	29-Aug-19	BENGALURU	66	HV1	TELECOM LAYOUT	20:01	20:49	0:48	LINE CLEAR AVAILED
184	29-Aug-19	BENGALURU	66	HV2	TELECOM LAYOUT	15:18	16:13	0:55	LINE CLEAR AVAILED
185	29-Aug-19	GULBARGA	400	YTPS-BPS2	YTPS_400	6:17	18:18	12:01	NFBC ISSUED
186	29-Aug-19	GULBARGA	110	SHAHAPUR220-YADGIR	YADGIR_110	0:30	12:27	11:57	LINE FAULT
187	29-Aug-19	GULBARGA	110	LV1	SHAHAPUR_220	0:19	0:41	0:22	TRANSFORMER FAULT
188	29-Aug-19	GULBARGA	110	SHAHAPUR220-SHORAPUR	SHORAPUR_110	0:19	0:45	0:26	LINE FAULT
189	29-Aug-19	GULBARGA	110	SHAHAPUR220-KEMBHAVI2	KBJNL	0:19	0:43	0:24	LINE FAULT
190	29-Aug-19	GULBARGA	110	SHAHAPUR220-SHAHPUR1	SHAHAPUR_110	0:19	0:46	0:27	LINE FAULT
191	29-Aug-19	GULBARGA	110	SHAHAPUR220-KEMBHAVI1	KEMBHAVI_110, UGARSUGARS_IPP	3:29	3:38	0:09	LINE FAULT
192	29-Aug-19	GULBARGA	110	HV1	KEMBHAVI_110	6:55	7:40	0:45	LOAD CURTAILMENT
193	29-Aug-19	GULBARGA	110	KEMBHAVI-UGAR SUGARS_IPP	UGARSUGARS_IPP	3:29	6:10	2:41	LINE FAULT
194	29-Aug-19	GULBARGA	110	HV2	HANUMASAGAR_110	7:05	7:21	0:16	LOAD CURTAILMENT
195	29-Aug-19	HASSAN	220	GERSOPA-TALGUPA1	GERSOPA	19:12	23:59	4:47	LINE FAULT
196	29-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSSHM	9:43	17:28	7:45	LINE CLEAR AVAILED
197	29-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSSHM	22:10	23:59	1:49	LINE FAULT
198	29-Aug-19	HASSAN	220	MRSSHM-KBCRS	MRSSHM	9:34	20:04	10:30	LINE CLEAR AVAILED
199	29-Aug-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSSHM	19:12	23:59	4:47	LINE FAULT
200	29-Aug-19	HASSAN	220	MRSSHM-VARAH12	MRSSHM	22:21	23:54	1:33	LINE CLEAR AVAILED
201	29-Aug-19	HASSAN	220	HV2	PUTTUR	10:57	14:48	3:51	LINE CLEAR AVAILED
202	29-Aug-19	HASSAN	220	VARAHI-SHIMOGA2	VARAHI	22:22	23:57	1:35	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
203	29-Aug-19	HASSAN	110	LV2	PUTTUR	10:57	14:48	3:51	LINE CLEAR AVAILED
204	29-Aug-19	HASSAN	110	HV2	AJAMPU	13:17	14:03	0:46	LINE CLEAR AVAILED
205	29-Aug-19	HASSAN	110	HV3	BANTWA	10:15	15:27	5:12	LINE CLEAR AVAILED
206	29-Aug-19	HASSAN	110	HV	KITTADA	11:05	13:50	2:45	LINE CLEAR AVAILED
207	29-Aug-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL	19:32	22:43	3:11	LINE FAULT
208	29-Aug-19	HASSAN	110	HV4	MANIPAL	16:50	17:04	0:14	HAND TRIPPED
209	29-Aug-19	HASSAN	66	MRSSHM-BD-1	MRSSHM	13:15	14:50	1:35	LINE FAULT
210	29-Aug-19	HASSAN	66	BHADRA-SHMGA 1	BHADRA	13:15	14:50	1:35	LINE FAULT
211	29-Aug-19	HASSAN	66	CHANNARA-HIRESAVE	CHANNARA	9:59	12:24	2:25	LINE CLEAR AVAILED
212	29-Aug-19	HASSAN	66	MOSALEH-BIOMASS	MOSALEH	11:56	12:01	0:05	LINE CLEAR AVAILED
213	29-Aug-19	HASSAN	66	MOSALEH-HNPRA	MOSALEH	11:56	12:01	0:05	LINE CLEAR AVAILED
214	29-Aug-19	HASSAN	66	HV1	MOSALEH	11:56	12:05	0:09	LINE CLEAR AVAILED
215	29-Aug-19	MYSORE	66	HV2	DEVANOORNGUDU_66	7:22	7:43	0:20	TRANSFORMER FAULT
216	29-Aug-19	MYSORE	66	HV2	ELAVALA_66	11:34	14:37	3:03	LINE CLEAR AVAILED
217	29-Aug-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66, GAVADAGERE_66	6:51	7:14	0:23	HAND TRIPPED
218	29-Aug-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66, HANAGODU_66, HOSURGATE_66, HUNSUR_66	6:51	7:14	0:23	HAND TRIPPED
219	29-Aug-19	MYSORE	66	HOOTAGALLI-KHB	KHBCOLONY_66	6:50	7:15	0:25	HAND TRIPPED
220	29-Aug-19	MYSORE	66	HV1	KOPPA_66	13:21	14:41	1:19	LINE CLEAR AVAILED
221	29-Aug-19	MYSORE	66	HV2	KOPPA_66	12:11	13:36	1:24	LINE CLEAR AVAILED
222	29-Aug-19	MYSORE	66	HV1	NANJANGUDU_66	10:21	11:12	0:51	LINE CLEAR AVAILED
223	29-Aug-19	TUMKUR	220	TR-3(HV SIDE)	CHITRADURGA_220	17:40	18:08	0:27	LINE CLEAR AVAILED
224	29-Aug-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA 1	MRSMSG_220	9:33	20:03	10:30	LINE CLEAR AVAILED
225	29-Aug-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	15:42	15:54	0:11	LINE FAULT
226	29-Aug-19	TUMKUR	66	TR-1	CHANNAGIRI_66	10:19	10:27	0:07	TRANSFORMER FAULT
227	29-Aug-19	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	18:06	19:36	1:30	LINE CLEAR AVAILED
228	29-Aug-19	TUMKUR	66	TR-3(HV SIDE)	CHITRADURGA_220	17:39	18:13	0:33	HAND TRIPPED
229	29-Aug-19	TUMKUR	66	TR-2(HV SIDE)	CHITRADURGA_220	18:06	18:33	0:27	HAND TRIPPED
230	29-Aug-19	TUMKUR	66	TR-3(LV SIDE)	CHITRADURGA_220	17:40	18:11	0:30	HAND TRIPPED
231	29-Aug-19	TUMKUR	66	CHITRADURGA 220kV- SUZLON 1	SUZLON1_IPP_66,	18:06	18:19	0:13	HAND TRIPPED
232	29-Aug-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:06	18:17	0:10	HAND TRIPPED
233	29-Aug-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	19:19	20:00	0:40	LINE FAULT
234	29-Aug-19	TUMKUR	66	TR-1	DYAVARANAHALLI_66	19:19	19:54	0:35	TRANSFORMER FAULT
235	29-Aug-19	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	19:19	19:56	0:37	LINE FAULT
236	29-Aug-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	19:19	19:52	0:33	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
237	29-Aug-19	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	15:01	15:13	0:11	LINE FAULT
238	29-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	9:41	9:45	0:03	HAND TRIPPED
239	29-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	10:28	10:33	0:04	HAND TRIPPED
240	29-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	15:44	15:50	0:06	HAND TRIPPED
241	29-Aug-19	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	10:06	10:08	0:02	HAND TRIPPED
242	29-Aug-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	15:14	15:16	0:01	MAIN SUPPLY FAILURE
243	29-Aug-19	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	15:14	15:16	0:01	MAIN SUPPLY FAILURE
244	29-Aug-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	15:00	15:14	0:14	MAIN SUPPLY FAILURE
245	30-Aug-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	0:00	10:21	10:21	LINE CLEAR AVAILED
246	30-Aug-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	0:00	10:21	10:21	LINE CLEAR AVAILED
247	30-Aug-19	BAGALKOT	220	NAGJHARI1&2-AMBEWADI	AMBEWADI_220	10:52	11:13	0:21	LINE FAULT
248	30-Aug-19	BAGALKOT	220	220/110KV,HV1&LV1	CHIKKODI_220	11:02	13:32	2:30	LINE CLEAR AVAILED
249	30-Aug-19	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	12:44	13:07	0:23	LINE CLEAR AVAILED
250	30-Aug-19	BAGALKOT	110	110/11KV,HV1	ZALKI_110	19:32	19:40	0:08	TRANSFORMER FAULT
251	30-Aug-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	12:54	14:49	1:55	LINE CLEAR AVAILED
252	30-Aug-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	10:52	11:59	1:07	LINE FAULT
253	30-Aug-19	BAGALKOT	220	220/110KV,HV1,LV1	SOUDATTI_220	12:43	14:04	1:21	LINE CLEAR AVAILED
254	30-Aug-19	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	13:50	13:55	0:05	LINE CLEAR AVAILED
255	30-Aug-19	BENGALURU	66	HV2	BRIGADE METRO POLIS	3:18	3:45	0:26	TRANSFORMER FAULT
256	30-Aug-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	BAGEPALLI, VIDURASHWATHA, GUNDLU KOTTUR	16:30	16:48	0:18	LINE CLEAR AVAILED
257	30-Aug-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI	6:45	7:01	0:16	LOAD CURTAILMENT
258	30-Aug-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	6:45	7:35	0:50	LOAD CURTAILMENT
259	30-Aug-19	BENGALURU	66	HV1	KEMBODI	6:45	7:25	0:40	MAIN SUPPLY FAILURE
260	30-Aug-19	BENGALURU	66	HV2	KEMBODI	6:45	7:25	0:40	MAIN SUPPLY FAILURE
261	30-Aug-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	6:45	7:27	0:42	LOAD CURTAILMENT
262	30-Aug-19	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	23:45	23:59	0:14	LINE CLEAR AVAILED
263	30-Aug-19	GULBARGA	220	SEDAM-CLEANMAX_IPP	SEDAM_220	16:23	16:47	0:24	LINE FAULT
264	30-Aug-19	GULBARGA	110	GURGUNTA-LINGASUGUR	GURGUNTA_110	0:05	0:35	0:30	LINE FAULT
265	30-Aug-19	GULBARGA	110	GURGUNTA-LINGASUGUR	GURGUNTA_110	2:20	2:25	0:05	LINE FAULT
266	30-Aug-19	GULBARGA	110	GURGUNTA-KHEL_IPP, LJVL_IPP	KHEL_IPP, LJVL_IPP	0:05	0:45	0:40	LINE FAULT
267	30-Aug-19	GULBARGA	110	GURGUNTA-KHEL_IPP, LJVL_IPP	KHEL_IPP, LJVL_IPP	2:20	2:50	0:30	LINE FAULT
268	30-Aug-19	GULBARGA	110	GURGUNTA-LINGASUGUR	GURGUNTA_110	5:55	6:05	0:10	LINE FAULT
269	30-Aug-19	GULBARGA	110	GURGUNTA-LINGASUGUR	GURGUNTA_110	6:45	6:55	0:10	LINE FAULT
270	30-Aug-19	GULBARGA	110	KAPNOOR220-HUMNABAD1	MAHAGOAN_110,MARGUTTI_110	11:43	11:49	0:06	LINE FAULT
271	30-Aug-19	GULBARGA	110	KEMEBHAVI-UGARSUGARS_IPP	UGARSUGARS_IPP	3:32	5:10	1:38	LINE CLEAR AVAILED
272	30-Aug-19	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	6:45	7:31	0:46	LINE CLEAR AVAILED
273	30-Aug-19	GULBARGA	110	HV2	SHORAPUR_110	8:11	8:21	0:10	TRANSFORMER FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
274	30-Aug-19	GULBARGA	110	SEDAM-VICATSAGAR CEMENTS	VICATSAGAR CEMENTS	5:55	6:25	0:30	LINE FAULT
275	30-Aug-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110, MUDDAPURA_110	21:00	21:17	0:17	LINE FAULT
276	30-Aug-19	GULBARGA	110	HATTI-GAMESHA_IPP	HATTI_110	17:49	17:51	0:02	LINE FAULT
277	30-Aug-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	9:07	16:46	7:39	LINE CLEAR AVAILED
278	30-Aug-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	9:07	16:48	7:41	LINE CLEAR AVAILED
279	30-Aug-19	HASSAN	110	HV1	BAIKAMPADY_110	11:01	11:04	0:03	MAIN SUPPLY FAILURE
280	30-Aug-19	HASSAN	110	HV2	BAIKAMPADY_110	11:01	11:04	0:03	MAIN SUPPLY FAILURE
281	30-Aug-19	HASSAN	110	HV3	BAIKAMPADY_110	11:01	11:04	0:03	MAIN SUPPLY FAILURE
282	30-Aug-19	HASSAN	110	HV4	BAIKAMPADY_110	11:01	11:05	0:04	MAIN SUPPLY FAILURE
283	30-Aug-19	HASSAN	110	HV1	BAIKAMPADY_110	13:00	13:02	0:02	MAIN SUPPLY FAILURE
284	30-Aug-19	HASSAN	110	HV2	BAIKAMPADY_110	13:00	13:02	0:02	MAIN SUPPLY FAILURE
285	30-Aug-19	HASSAN	110	HV3	BAIKAMPADY_110	13:00	13:02	0:02	MAIN SUPPLY FAILURE
286	30-Aug-19	HASSAN	110	HV4	BAIKAMPADY_110	13:00	13:02	0:02	MAIN SUPPLY FAILURE
287	30-Aug-19	HASSAN	110	HULICA-KVR	HULICAL_110	20:53	21:00	0:07	HAND TRIPPED
288	30-Aug-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	11:00	11:02	0:02	HAND TRIPPED
289	30-Aug-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	13:00	13:01	0:01	HAND TRIPPED
290	30-Aug-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:10	10:35	0:25	MAIN SUPPLY FAILURE
291	30-Aug-19	HASSAN	66	HV1	CHANNARAYAPATNA_66	12:15	14:28	2:13	LINE CLEAR AVAILED
292	30-Aug-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	9:55	10:25	0:30	LINE CLEAR AVAILED
293	30-Aug-19	HASSAN	66	HASSN220-HN PURA	HASSAN_220	11:05	12:15	1:10	LINE CLEAR AVAILED
294	30-Aug-19	MYSORE	220	HV1	HOOTAGALLY_220	16:34	19:11	2:36	LINE CLEAR AVAILED
295	30-Aug-19	MYSORE	66	HV1	SANTHESARAGUR_66	16:04	16:24	0:19	LINE CLEAR AVAILED
296	30-Aug-19	MYSORE	66	HV2	SANTHE SARAGURU-	15:00	15:38	0:37	LINE CLEAR AVAILED
297	30-Aug-19	MYSORE	66	HV2	SANTHE SARAGURU-	18:19	18:28	0:08	TRANSFORMER FAULT
298	30-Aug-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	MRSMSG_220	9:04	16:48	7:44	LINE CLEAR AVAILED
299	30-Aug-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_400	1:06	19:29	18:23	LINE CLEAR AVAILED
300	30-Aug-19	TUMKUR	110	TR-1	BIDARE_110	12:42	13:39	0:57	LINE CLEAR AVAILED
301	30-Aug-19	TUMKUR	110	BIDARE- NITTUR	BIDARE_110	12:42	13:39	0:56	LINE CLEAR AVAILED
302	30-Aug-19	TUMKUR	66	TR-1	DYAVARANAHALLI_66	10:05	10:34	0:29	LINE CLEAR AVAILED
303	30-Aug-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	19:14	19:33	0:19	HAND TRIPPED
304	30-Aug-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	19:15	19:32	0:17	HAND TRIPPED
305	30-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	19:15	19:32	0:17	HAND TRIPPED
306	30-Aug-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	19:15	19:32	0:17	HAND TRIPPED
307	30-Aug-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	19:15	19:31	0:16	HAND TRIPPED
308	30-Aug-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	9:05	9:20	0:15	HAND TRIPPED
309	30-Aug-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	11:03	11:53	0:50	HAND TRIPPED
310	30-Aug-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	20:14	20:15	0:01	HAND TRIPPED
311	30-Aug-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	13:35	13:40	0:04	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
312	30-Aug-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	14:32	14:44	0:12	HAND TRIPPED
313	30-Aug-19	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	15:58	16:08	0:09	HAND TRIPPED
314	30-Aug-19	TUMKUR	66	TR-2	NAYAKANAHATTI_66	16:45	17:04	0:19	LINE CLEAR AVAILED
315	30-Aug-19	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	HIREMALLANAHOLE_66	13:25	13:49	0:24	MAIN SUPPLY FAILURE
316	30-Aug-19	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	15:56	16:12	0:16	LINE FAULT
317	30-Aug-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	15:56	16:12	0:16	LINE FAULT
318	30-Aug-19	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	13:29	13:35	0:06	HAND TRIPPED
319	30-Aug-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	13:29	13:34	0:04	HAND TRIPPED
320	30-Aug-19	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	13:31	13:46	0:14	TRANSFORMER FAULT
321	30-Aug-19	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	13:32	13:46	0:13	TRANSFORMER FAULT
322	30-Aug-19	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI 1	NAYAKANHATTI_66, HIREMALLANAHOLE_66	13:29	13:45	0:16	HAND TRIPPED
323	30-Aug-19	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	13:30	13:43	0:13	HAND TRIPPED
324	30-Aug-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:29	13:48	0:18	HAND TRIPPED
325	30-Aug-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	13:29	13:46	0:16	HAND TRIPPED
326	31-Aug-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	11:24	17:31	6:07	LINE FAULT
327	31-Aug-19	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:08	12:11	0:03	TRANSFORMER FAULT
328	31-Aug-19	BAGALKOT	110	110/11KV,HV1	YELLAPARHATTI_110	15:34	16:24	0:50	LINE CLEAR AVAILED
329	31-Aug-19	BAGALKOT	110	110/11KV,HV1	TIKOTA_110	20:42	20:44	0:02	TRANSFORMER FAULT
330	31-Aug-19	BAGALKOT	110	BAGEWADI220-MATTIHAL	MATTIHAL_110	12:55	13:17	0:22	LINE FAULT
331	31-Aug-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	8:55	9:00	0:05	LOAD CHANGEOVER
332	31-Aug-19	BENGALURU	66	HV1	KHODAYS 220	8:55	9:00	0:05	LOAD CHANGEOVER
333	31-Aug-19	BENGALURU	66	HV2	KHODAYS	8:55	9:00	0:05	LOAD CHANGEOVER
334	31-Aug-19	BENGALURU	66	DEVARBISANAHALLI - CESSNO PARK	DEVARBISANAHALLI	13:45	13:50	0:05	LOAD CHANGEOVER
335	31-Aug-19	BENGALURU	220	HV2	MITTEMARI 220	12:12	12:18	0:06	TRANSFORMER FAULT
336	31-Aug-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	PERESANDRA, SOMENAHALLI, MANDIKALLU	12:12	12:18	0:06	MAIN SUPPLY FAILURE
337	31-Aug-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	PERESANDRA, SOMENAHALLI, MANDIKALLU	21:00	21:10	0:10	LOAD CHANGEOVER
338	31-Aug-19	BENGALURU	66	MANDKALLU - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI, MANDIKALLU	9:10	9:15	0:05	LOAD CHANGEOVER
339	31-Aug-19	BENGALURU	66	HV1	GOLF LINKS	11:50	11:55	0:05	LINE CLEAR AVAILED
340	31-Aug-19	BENGALURU	66	DEVARBISANAHALLI - HSR LAYOUT 220	DEVARBISANAHALLI	12:57	13:04	0:07	LOAD CHANGEOVER
341	31-Aug-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	17:24	17:43	0:18	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
342	31-Aug-19	GULBARGA	220	SINDHANOOR220-LINGAPUR, LINGASUGUR	SIDHANOOR_220	15:15	15:30	0:15	LINE FAULT
343	31-Aug-19	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	23:06	23:59	0:53	LINE CLEAR AVAILED
344	31-Aug-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110, BTPS WATER WORKS	9:18	9:27	0:09	LINE FAULT
345	31-Aug-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110, BTPS WATER WORKS	9:41	10:06	0:25	LINE FAULT
346	31-Aug-19	GULBARGA	110	HV1	SHAHAPUR_220	3:53	4:08	0:15	TRANSFORMER FAULT
347	31-Aug-19	GULBARGA	110	BHALKI-BHALKISUGARS	BHALKI SUGARS_IPP	23:37	23:45	0:08	LINE FAULT
348	31-Aug-19	GULBARGA	110	SHAHAPUR220-SHORAPUR	SHORAPUR_110	22:40	23:05	0:25	LINE FAULT
349	31-Aug-19	GULBARGA	110	SHAHAPUR220-SHORAPUR	SHORAPUR_110	23:22	23:59	0:37	LINE FAULT
350	31-Aug-19	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110, KONKAL_110	6:05	6:25	0:20	LINE FAULT
351	31-Aug-19	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	6:05	6:25	0:20	LINE FAULT
352	31-Aug-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110, KADAGANCHI_110	6:40	6:51	0:11	LINE FAULT
353	31-Aug-19	HASSAN	220	ARSK2-HSN	ARASIKERE_220	8:53	18:28	9:35	LINE CLEAR AVAILED
354	31-Aug-19	HASSAN	220	KADUR-DABUSET	KADUR_220	10:40	18:24	7:44	LINE CLEAR AVAILED
355	31-Aug-19	HASSAN	220	KADUR-DABUSET	KADUR_220	18:35	18:40	0:05	HAND TRIPPED
356	31-Aug-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	12:17	16:09	3:52	LINE CLEAR AVAILED
357	31-Aug-19	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	8:14	18:44	10:30	LINE CLEAR AVAILED
358	31-Aug-19	HASSAN	110	MRSSHM-MPM	MRSMSG_220	13:38	14:21	0:43	LINE CLEAR AVAILED
359	31-Aug-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	12:25	12:54	0:29	LINE FAULT
360	31-Aug-19	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	11:49	13:26	1:37	LINE CLEAR AVAILED
361	31-Aug-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	11:48	13:28	1:40	LINE CLEAR AVAILED
362	31-Aug-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	11:50	13:27	1:37	LINE CLEAR AVAILED
363	31-Aug-19	HASSAN	66	HV2	BASAVAGHATTA_66	9:59	12:19	2:20	LINE CLEAR AVAILED
364	31-Aug-19	MYSORE	66	HV1	HOOTAGALLY_220	12:47	12:50	0:02	HAND TRIPPED
365	31-Aug-19	MYSORE	66	HV2	HOOTAGALLY_220	12:47	12:50	0:02	HAND TRIPPED
366	31-Aug-19	MYSORE	66	HV2	KMDODDI_66	12:05	13:28	1:22	LINE CLEAR AVAILED
367	31-Aug-19	MYSORE	220	HV1	KUSHALNAGARA_220	10:02	11:21	1:18	LINE CLEAR AVAILED
368	31-Aug-19	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	12:08	13:49	1:40	LINE CLEAR AVAILED
369	31-Aug-19	TUMKUR	110	TR-1	KADABA_110	12:54	13:09	0:15	LINE CLEAR AVAILED
370	31-Aug-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	13:02	13:28	0:26	LINE FAULT
371	31-Aug-19	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	12:53	13:11	0:17	LINE CLEAR AVAILED
372	31-Aug-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	13:02	13:28	0:26	LINE FAULT
373	31-Aug-19	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	12:08	13:49	1:40	LINE CLEAR AVAILED
374	31-Aug-19	TUMKUR	110	TR-1	KADABA_110	12:54	13:09	0:15	LINE CLEAR AVAILED
375	31-Aug-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	13:02	13:28	0:26	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
376	31-Aug-19	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	12:53	13:11	0:17	LINE CLEAR AVAILED
377	31-Aug-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	13:02	13:28	0:26	LINE FAULT
378	1-Sep-19	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,SEABIRD_33	16:15	16:52	0:37	TRANSFORMER FAULT
379	1-Sep-19	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,SEABIRD_33	19:17	19:35	0:18	TRANSFORMER FAULT
380	1-Sep-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	9:13	10:20	1:07	LINE CLEAR AVAILED
381	1-Sep-19	BAGALKOT	110	GADAG220-DAMBAL2	DAMBAL_110	16:37	17:30	0:53	LINE CLEAR AVAILED
382	1-Sep-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	1:05	1:18	0:13	LINE FAULT
383	1-Sep-19	BAGALKOT	110	110/11KV,HV2	ITNAL_110	21:31	22:01	0:30	TRANSFORMER FAULT
384	1-Sep-19	BAGALKOT	110	110/11KV,HV3	RATTIHALI_110	10:43	10:58	0:15	TRANSFORMER FAULT
385	1-Sep-19	BAGALKOT	110	PG HUNSYAL-MUDALAGI	MUDALAGI_110	2:08	2:30	0:22	LINE FAULT
386	1-Sep-19	BAGALKOT	110	110/11KV,HV2	MATTIHAL_110	12:26	12:37	0:11	LINE CLEAR AVAILED
387	1-Sep-19	BAGALKOT	110	110/11KV,HV1	MATTIHAL_110	11:15	12:40	1:25	LINE CLEAR AVAILED
388	1-Sep-19	BENGALURU	66	KACHAMARANAHALLI - SHAMRAJU TECH PARK	KACHAMARANAHALLI	12:30	12:40	0:10	LOAD CHANGEVER
389	1-Sep-19	BENGALURU	66	KACHAMARANAHALLI - DOMMASANDRA	KACHAMARANAHALLI	16:45	16:55	0:10	LOAD CHANGEVER
390	1-Sep-19	BENGALURU	66	SHAMRAJU TECH PARK - KACHAMARANAHALLI	KACHAMARANAHALLI	16:55	17:35	0:40	LINE FAULT
391	1-Sep-19	BENGALURU	66	MANDKALLU - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI, MANDIKALLU	10:00	10:08	0:08	LOAD CHANGEVER
392	1-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	PERESANDRA, SOMENAHALLI, MANDIKALLU	18:06	18:10	0:04	LOAD CHANGEVER
393	1-Sep-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	7:52	8:08	0:16	LINE FAULT
394	1-Sep-19	BENGALURU	66	SHAMRAJU TECH PARK - EPIP 220	SHAMRAJU TECH PARK	13:02	16:35	3:33	LINE CLEAR AVAILED
395	1-Sep-19	GULBARGA	220	KAPNOOR-HUMNABAD2	HUMNABAD_220	0:00	7:31	7:31	LINE CLEAR AVAILED
396	1-Sep-19	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110, KADAGANCHI_110	6:19	6:32	0:13	LINE FAULT
397	1-Sep-19	GULBARGA	110	SHAHAPUR220-SHORAPUR	SHORAPUR_110	0:00	0:07	0:07	LINE FAULT
398	1-Sep-19	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	0:25	1:12	0:47	LINE FAULT
399	1-Sep-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_GLB_110	4:40	4:52	0:12	LINE FAULT
400	1-Sep-19	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL	6:18	6:52	0:34	LINE FAULT
401	1-Sep-19	GULBARGA	110	SHAHPUR220-SHAHPUR	SHAHPUR_110	6:18	7:00	0:42	LINE FAULT
402	1-Sep-19	GULBARGA	110	SHAHPUR220-YADGIR	YADGIR_110	6:28	10:56	4:28	LINE FAULT
403	1-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	10:54	10:54	LINE CLEAR AVAILED
404	1-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	12:40	15:15	2:35	LINE CLEAR AVAILED
405	1-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	15:29	23:09	7:40	LINE CLEAR AVAILED
406	1-Sep-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	12:45	12:45	LINE CLEAR AVAILED
407	1-Sep-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:10	23:59	5:49	LINE CLEAR AVAILED
408	1-Sep-19	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	16:43	19:35	2:52	LINE FAULT
409	1-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	16:43	19:34	2:51	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
410	1-Sep-19	HASSAN	110	HV1	BAIKAMPADI_110	8:25	12:57	4:32	TRANSFORMER FAULT
411	1-Sep-19	HASSAN	110	HV3	BAIKAMPADI_110	10:37	11:32	0:55	LINE CLEAR AVAILED
412	1-Sep-19	HASSAN	66	BALLUPE-HASSAN2	BALLUPETE_66	3:05	3:15	0:10	LINE FAULT
413	1-Sep-19	HASSAN	66	BALLUPE-SAKLESH PURA	BALLUPETE_66	3:05	4:05	1:00	LINE FAULT
414	1-Sep-19	HASSAN	66	BALLUPE-SAKLESH PURA	BALLUPETE_66	4:12	13:20	9:08	LINE FAULT
415	1-Sep-19	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	11:30	13:05	1:35	LINE CLEAR AVAILED
416	1-Sep-19	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	3:20	3:40	0:20	LINE FAULT
417	1-Sep-19	HASSAN	66	SAKALE-HASSAN2	SAKLESH PURA_66	3:05	3:25	0:20	LINE FAULT
418	1-Sep-19	HASSAN	66	SAKALE-HASSAN2	SAKLESH PURA_66	3:30	4:00	0:30	MAIN SUPPLY FAILURE
419	1-Sep-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	3:30	3:44	0:14	MAIN SUPPLY FAILURE
420	1-Sep-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	3:30	3:44	0:14	MAIN SUPPLY FAILURE
421	1-Sep-19	MYSORE	66	BILIKERE-GV GUDI	GVGUDI_66	7:27	7:33	0:06	LINE FAULT
422	1-Sep-19	MYSORE	66	DR PETE-MAHUVANAHALLI (KUNTHUR)	KUNTHUR_66, MUGUR_66, JANNUR_66, THAYURU_66, SANTHEMARAHALLI_66	0:21	0:28	0:06	LINE FAULT
423	1-Sep-19	MYSORE	66	KR PETE 220-MADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	13:31	13:38	0:07	LINE FAULT
424	1-Sep-19	MYSORE	66	MADHUVANAHALLI-KUNTHUR	KUNTHUR_66, MUGUR_66, JANNUR_66, THAYURU_66, SANTHEMARAHALLI_66	9:38	9:44	0:06	LINE FAULT
425	2-Sep-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	2:26	2:45	0:19	LINE FAULT
426	2-Sep-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	12:33	15:51	3:18	LINE FAULT
427	2-Sep-19	BAGALKOT	110	110/33KV,HV2	GANESHGUDI_110,JERDA_33	4:22	7:06	2:44	TRANSFORMER FAULT
428	2-Sep-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	5:55	6:10	0:15	LINE FAULT
429	2-Sep-19	BAGALKOT	110	GHATAPRABHA220-PG HUNSYAL	PG HUNSYAL_110	2:09	2:18	0:09	LINE FAULT
430	2-Sep-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA	GHATAPRABHA_110	17:09	17:29	0:20	LINE FAULT
431	2-Sep-19	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	17:09	17:33	0:24	LINE FAULT
432	2-Sep-19	BAGALKOT	110	SADALAGA-BORGAON	BORGAON_110	5:21	6:22	1:01	LINE FAULT
433	2-Sep-19	BENGALURU	66	EPIP 220 - CHANDAPURA	SHAMRAJ TECH PARK, KACHMARANAHALLI	17:02	17:26	0:24	LINE FAULT
434	2-Sep-19	BENGALURU	66	HV1	AMARJYOTHI	6:11	6:25	0:13	TRANSFORMER FAULT
435	2-Sep-19	BENGALURU	220	HV1	EPIP 220	17:23	19:16	1:53	TRANSFORMER FAULT
436	2-Sep-19	BENGALURU	66	HV3	EPIP 220	17:23	18:17	0:54	MAIN SUPPLY FAILURE
437	2-Sep-19	BENGALURU	66	HV1	VIJAYANAGARA	15:30	15:38	0:07	LOAD CHANGEOVER
438	2-Sep-19	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	17:02	18:16	1:14	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
439	2-Sep-19	BENGALURU	66	KONDASPURA - ARMY WELFARE ORGANIZATION	KONDASPURA	18:16	18:40	0:24	MAIN SUPPLY FAILURE
440	2-Sep-19	BENGALURU	66	MANDKALLU - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI, MANDIKALLU	10:15	10:23	0:08	LOAD CHANGEOVER
441	2-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	PERESANDRA, SOMENAHALLI, MANDIKALLU	18:00	18:10	0:10	LOAD CHANGEOVER
442	2-Sep-19	GULBARGA	110	BHALKI-HALBURGA	BHALKI_110	13:40	13:50	0:10	LINE FAULT
443	2-Sep-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_GLB_110	19:29	19:41	0:12	LINE FAULT
444	2-Sep-19	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_GLB_110	21:27	21:34	0:07	LINE FAULT
445	2-Sep-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	11:37	11:47	0:10	LINE FAULT
446	2-Sep-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	12:30	12:35	0:05	LINE FAULT
447	2-Sep-19	MYSORE	66	BG NAGARA-YEDIYURU	ADICHUNCHANAGIRI_66, VADERALLI_66	4:55	5:11	0:16	LINE FAULT
448	2-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	21:14	23:57	2:42	LINE FAULT