

# 400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 08.01.2019 to 14.01.2019

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
1	8-Jan-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI 2	BAGALKOT_220	16:32	16:50	0:18	MAIN SUPPLY FAILURE
2	8-Jan-19	BAGALKOT	220	BAGALKOT-GADAG 1	BAGALKOT_220	16:32	18:05	1:33	MAIN SUPPLY FAILURE
3	8-Jan-19	BAGALKOT	110	BAGALKOT220-BAGALKOT 2	BAGALKOT_110	16:32	16:33	0:01	MAIN SUPPLY FAILURE
4	8-Jan-19	BAGALKOT	110	BAGALKOT-NAVANAGAR 1	NAVANAGAR_110	16:32	16:47	0:15	MAIN SUPPLY FAILURE
5	8-Jan-19	BAGALKOT	110	BAGALKOT- GULEDGUDD	GULEDGUDD_110	16:32	16:33	0:01	MAIN SUPPLY FAILURE
6	8-Jan-19	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	16:32	16:34	0:02	MAIN SUPPLY FAILURE
7	8-Jan-19	BAGALKOT	110	BAGALKOT-LOKAPUR 1	LOKAPUR_110	16:32	16:34	0:02	MAIN SUPPLY FAILURE
8	8-Jan-19	BAGALKOT	110	BAGALKOT-KATARAKI	NEERBUDIHAI_110	16:32	16:34	0:02	MAIN SUPPLY FAILURE
9	8-Jan-19	BAGALKOT	110	BIDNAL-PH COMPOUND	PH COMPOUND_110	11:32	14:34	3:02	HAND TRIPPED
10	8-Jan-19	BAGALKOT	110	110/11KV,HV-2	GUTTAL_110	12:17	12:35	0:18	HAND TRIPPED
11	8-Jan-19	BAGALKOT	110	JAMBAGI-VAJRAMATTI	MUDHOL_110	16:13	17:05	0:52	MAIN SUPPLY FAILURE
12	8-Jan-19	BAGALKOT	110	JAMBAGI-MUDHOL	HALAKI_110	15:57	17:09	1:12	MAIN SUPPLY FAILURE
13	8-Jan-19	BAGALKOT	110	110/11KV HV-1	JAMBAGI_110	15:57	17:05	1:08	MAIN SUPPLY FAILURE
14	8-Jan-19	BAGALKOT	110	110/11KV,HV-1	LOKAPUR_110	10:13	18:29	8:16	HAND TRIPPED
15	8-Jan-19	BAGALKOT	110	110/33KV,HV-3	LOKAPUR_110,&33KV BHATAKURKI,RSSKN	13:28	14:18	0:50	HAND TRIPPED
16	8-Jan-19	BAGALKOT	220	BIJAPUR-VAISHALI 2	BIJAPUR_220	10:51	16:41	5:50	HAND TRIPPED
17	8-Jan-19	BAGALKOT	220	BIJAPUR-VAISHALI 1	BIJAPUR_220	16:56	17:42	0:46	HAND TRIPPED
18	8-Jan-19	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	21:49	23:59	2:10	HAND TRIPPED
19	8-Jan-19	BAGALKOT	110	110/11KV, HV1	YELLAPARHATTI_110	13:41	14:05	0:24	LINE CLEAR AVAILED
20	8-Jan-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATT2	MAHALINGAPUR_220	0:53	23:59	23:06	LINE FAULT
21	8-Jan-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATT1	MAHALINGAPUR_220	14:02	21:59	7:57	LINE CLEAR AVAILED
22	8-Jan-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	15:55	23:59	8:04	HAND TRIPPED
23	8-Jan-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	VAJRAMATTI_220	15:57	16:50	0:53	LINE FAULT
24	8-Jan-19	BAGALKOT	110	VAJRAMATTI220-MALLIGERI	MALLIGERI_110	15:57	17:09	1:12	LINE FAULT
25	8-Jan-19	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	15:57	17:02	1:05	LINE FAULT
26	8-Jan-19	BAGALKOT	110	VAJRAMATTI220-MANTUR	MANTUR_110	15:57	17:01	1:04	LINE FAULT
27	8-Jan-19	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	16:51	17:11	0:20	HAND TRIPPED
28	8-Jan-19	BAGALKOT	220	VAJRAMATTI220-KAVATAGI LIS	VAJRAMATTI_220	17:45	17:50	0:05	HAND TRIPPED
29	8-Jan-19	BAGALKOT	220	VAJRAMATTI220-KAVATAGI LIS	VAJRAMATTI_220	18:13	18:17	0:04	HAND TRIPPED
30	8-Jan-19	BAGALKOT	110	HUBLI220-PH COMPOUND	PH COMPOUND_110	12:43	14:29	1:46	LINE CLEAR AVAILED
31	8-Jan-19	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	13:23	13:42	0:19	LINE CLEAR AVAILED
32	8-Jan-19	BAGALKOT	110	GMNAVAR-SALAHALLI	SALAHALLI_110	16:39	16:51	0:12	MAIN SUPPLY FAILURE
33	8-Jan-19	BAGALKOT	110	110/11KV, HV2	RON_110	14:13	14:41	0:28	TRANSFORMER FAULT
34	8-Jan-19	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	14:12	18:31	4:19	LINE CLEAR AVAILED
35	8-Jan-19	BAGALKOT	110	DHARWAD BIO-NAVALGUND	NAVALGUND_110	12:14	13:08	0:54	LINE CLEAR AVAILED

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
36	8-Jan-19	BAGALKOT	110	220/110KV, LV1	SOUDATTI_220, RAMDURG_110, MUNVALLI_110, SOUDATTI_110, YARGATTI_110	13:43	13:51	0:08	TRANSFORMER FAULT
37	8-Jan-19	BAGALKOT	110	220/110KV, LV2	SOUDATTI_220, RAMDURG_110, MUNVALLI_110, SOUDATTI_110, YARGATTI_110	13:43	13:58	0:15	TRANSFORMER FAULT
38	8-Jan-19	BAGALKOT	110	110/11KV, HV1	SOUDATTI_220	13:43	13:52	0:09	TRANSFORMER FAULT
39	8-Jan-19	BAGALKOT	110	SOUDATTI220-SOUDATTI2	SOUDATTI_110	13:43	15:44	2:01	LINE CLEAR AVAILED
40	8-Jan-19	BAGALKOT	110	110/11KV, HV1	MUNDARGI_110	17:05	17:19	0:14	LINE CLEAR AVAILED
41	8-Jan-19	BAGALKOT	110	110/11KV, HV3	MUDALAGI_110	10:36	17:34	6:58	LINE CLEAR AVAILED
42	8-Jan-19	BAGALKOT	110	MKHUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	0:43	12:38	11:55	LINE FAULT
43	8-Jan-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	0:43	10:56	10:13	TRANSFORMER FAULT
44	8-Jan-19	BANGALORE	66	HV2	CB PURA I/A	11:03	12:19	1:16	LINE CLEAR AVAILED
45	8-Jan-19	BANGALORE	66	HV2	DODDABELAVANGALA	7:14	8:02	0:47	HAND TRIPPED
46	8-Jan-19	BANGALORE	66	HV1	GUNDLU KOTTUR	4:45	5:01	0:15	TRANSFORMER FAULT
47	8-Jan-19	BANGALORE	66	HV2	BRINDAVAN	12:38	12:57	0:18	LINE CLEAR AVAILED
48	8-Jan-19	BANGALORE	66	HV3	BRINDAVAN	10:15	10:20	0:05	LINE CLEAR AVAILED
49	8-Jan-19	BANGALORE	66	HV2	DEVARABISANAHALLI	11:48	12:01	0:12	LINE CLEAR AVAILED
50	8-Jan-19	BANGALORE	66	HV2	DEVARABISANAHALLI	14:21	14:46	0:25	LINE CLEAR AVAILED
51	8-Jan-19	BANGALORE	66	HV2	ELECTRONIC CITY P2 S2	11:54	13:40	1:46	TRANSFORMER FAULT
52	8-Jan-19	BANGALORE	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2	11:54	12:19	0:24	LINE FAULT
53	8-Jan-19	BANGALORE	66	ELECTRONIC CITY P2 S2 - BIOCON (EHT)	BIOCON (EHT)	11:54	12:27	0:33	MAIN SUPPLY FAILURE
54	8-Jan-19	BANGALORE	66	JAYADEVA - ADUGODI	ADUGODI	9:16	9:40	0:23	LINE FAULT
55	8-Jan-19	BANGALORE	66	HV3	ADUGODI	9:16	9:40	0:23	MAIN SUPPLY FAILURE
56	8-Jan-19	BANGALORE	66	HV1	HAL 220	11:49	12:00	0:11	LINE CLEAR AVAILED
57	8-Jan-19	BANGALORE	66	HV1	YARANDANAHALLI 220	15:10	17:15	2:05	LINE CLEAR AVAILED
58	8-Jan-19	BANGALORE	66	HV2	YARANDANAHALLI 220	17:22	19:05	1:43	LINE CLEAR AVAILED
59	8-Jan-19	BANGALORE	66	HV1	RMV	4:12	4:40	0:28	TRANSFORMER FAULT
60	8-Jan-19	BANGALORE	66	HV2	RMV	4:18	4:36	0:18	LINE CLEAR AVAILED
61	8-Jan-19	BANGALORE	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	4:18	4:35	0:17	LINE CLEAR AVAILED
62	8-Jan-19	BANGALORE	66	HV2	SRS PEENYA 220	18:30	18:35	0:04	LINE CLEAR AVAILED
63	8-Jan-19	BANGALORE	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	13:16	13:20	0:04	LINE CLEAR AVAILED
64	8-Jan-19	BANGALORE	66	HV2	SOMAYAJJANAHALLI	13:58	14:27	0:28	LINE CLEAR AVAILED
65	8-Jan-19	GULBARGA	220	HV1	RAICHUR_220	11:00	13:31	2:31	LINE CLEAR AVAILED
66	8-Jan-19	GULBARGA	220	HV2	RAICHUR_220	11:20	11:25	0:05	TRANSFORMER FAULT
67	8-Jan-19	GULBARGA	220	SIDHANOOR220-LINGAPUR	SIDHANOOR_220	9:15	15:36	6:21	LINE CLEAR AVAILED
68	8-Jan-19	GULBARGA	110	HV1	BETAGERA_110	7:50	9:25	1:35	LINE CLEAR AVAILED
69	8-Jan-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	12:30	12:31	0:01	LINE FAULT
70	8-Jan-19	GULBARGA	110	HALBURGA_ACMVSLR	HALBURGA_220	11:44	11:54	0:10	LINE FAULT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
71	8-Jan-19	GULBARGA	110	HALBURGA_ACMVSLR	HALBURGA_220	12:15	12:18	0:03	LINE FAULT
72	8-Jan-19	GULBARGA	110	HV3	YADGIR_110	21:24	21:41	0:17	TRANSFORMER FAULT
73	8-Jan-19	GULBARGA	110	HV2	BISIHALLI_110	16:32	16:47	0:15	LINE CLEAR AVAILED
74	8-Jan-19	GULBARGA	110	HV1	GULBARGASOUTH_110	13:30	13:40	0:10	LINE CLEAR AVAILED
75	8-Jan-19	GULBARGA	110	HV2	GULBARGASOUTH_110	13:40	13:50	0:10	LINE CLEAR AVAILED
76	8-Jan-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	12:13	13:21	1:08	LINE CLEAR AVAILED
77	8-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	23:17	23:59	0:42	LINE CLEAR AVAILED
78	8-Jan-19	HASSAN	400	UPCL-HASSAN2	UPCL_GEN	0:00	8:40	8:40	LINE CLEAR AVAILED
79	8-Jan-19	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	10:05	16:13	6:08	LINE CLEAR AVAILED
80	8-Jan-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	9:56	11:16	1:20	LINE CLEAR AVAILED
81	8-Jan-19	HASSAN	220	GERSOPA-TALGUPA1	GERUSOPPA_GEN	12:51	23:59	11:08	LINE FAULT
82	8-Jan-19	HASSAN	220	GERSOPA-TALGUPA2	GERUSOPPA_GEN	9:56	16:00	6:04	LINE CLEAR AVAILED
83	8-Jan-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	14:01	21:01	7:00	NFBC ISSUED
84	8-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:51	23:59	11:08	LINE CLEAR AVAILED
85	8-Jan-19	HASSAN	220	UPCL-KEMAR2	UPCL_GEN	14:01	21:01	7:00	LINE CLEAR AVAILED
86	8-Jan-19	HASSAN	110	ARSK2-BANAVARA	ARSIKERE_220	18:25	18:30	0:05	HAND TRIPPED
87	8-Jan-19	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	8:26	11:26	3:00	LINE CLEAR AVAILED
88	8-Jan-19	HASSAN	110	HV1	GURUPURA_110	10:24	12:20	1:56	LINE CLEAR AVAILED
89	8-Jan-19	HASSAN	110	HV1	GURUPURA_110	12:22	12:28	0:06	TRANSFORMER FAULT
90	8-Jan-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	8:27	17:11	8:44	LINE CLEAR AVAILED
91	8-Jan-19	HASSAN	66	HV2	BELUR_66	4:00	4:53	0:53	MAIN SUPPLY FAILURE
92	8-Jan-19	HASSAN	66	HV1	DODDAKADANUR_66	9:01	9:07	0:06	TRANSFORMER FAULT
93	8-Jan-19	HASSAN	66	HV2	TAVARECHANAHALLI_66	12:47	16:17	3:30	TRANSFORMER FAULT
94	8-Jan-19	MYSORE	66	HV1	BANNUR_66	12:21	12:56	0:34	HAND TRIPPED
95	8-Jan-19	MYSORE	66	HV1	BOOKANAKERE_66	17:02	18:11	1:08	LINE CLEAR AVAILED
96	8-Jan-19	MYSORE	66	HV2	BOOKANAKERE_66	17:02	18:11	1:08	LINE CLEAR AVAILED
97	8-Jan-19	MYSORE	66	HV1	HANAGODU_66	15:44	15:59	0:14	TRANSFORMER FAULT
98	8-Jan-19	MYSORE	66	HV2	HANAGODU_66	14:46	15:44	0:58	LINE CLEAR AVAILED
99	8-Jan-19	MYSORE	220	HV1	KADAKOLA_220	10:30	19:35	9:04	LINE CLEAR AVAILED
100	8-Jan-19	MYSORE	66	HV1	KRPET_220	12:20	12:24	0:04	TRANSFORMER FAULT
101	8-Jan-19	MYSORE	66	HV1	SFCSHIVA_66	15:18	17:28	2:10	HAND TRIPPED
102	8-Jan-19	MYSORE	66	HV2	SFCSHIVA_66	15:18	17:28	2:10	HAND TRIPPED
103	8-Jan-19	MYSORE	66	HV3	SFCSHIVA_66	15:18	17:27	2:09	HAND TRIPPED
104	8-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	5:28	19:45	14:16	HAND TRIPPED
105	8-Jan-19	TUMKUR	110	HONNAVALLI 110-ADANSOLAR_IPP_110	ADANSOLAR_IPP_110	18:01	18:11	0:09	LINE FAULT
106	8-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	12:56	13:11	0:14	LINE FAULT
107	8-Jan-19	TUMKUR	66	TR-1	BAGUR_66	10:16	10:26	0:10	TRANSFORMER FAULT
108	8-Jan-19	TUMKUR	66	TR-1	BAGUR_66	10:51	10:56	0:05	TRANSFORMER FAULT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
109	8-Jan-19	TUMKUR	66	TR-1	BAGUR_66	11:43	12:04	0:21	TRANSFORMER FAULT
110	8-Jan-19	TUMKUR	66	TR-1	BAGUR_66	18:08	18:13	0:05	TRANSFORMER FAULT
111	8-Jan-19	TUMKUR	66	TR-1	CHALLAKERE_66	14:20	14:32	0:12	HAND TRIPPED
112	8-Jan-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	CHITRADURGA_66	15:53	16:24	0:30	LINE FAULT
113	8-Jan-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	CHITRADURGA_66	15:53	16:20	0:27	LINE FAULT
114	8-Jan-19	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	11:15	11:39	0:24	TRANSFORMER FAULT
115	8-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:31	17:38	9:06	HAND TRIPPED
116	8-Jan-19	TUMKUR	66	TR-1	HALUVAGALU_66	16:03	16:29	0:25	LINE CLEAR AVAILED
117	8-Jan-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	12:50	13:08	0:18	LOAD CURTAILMENT
118	8-Jan-19	TUMKUR	66	TR-1	HIREGUNTANUR_66	14:27	14:33	0:05	LINE CLEAR AVAILED
119	8-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	8:41	8:47	0:05	HAND TRIPPED
120	8-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	15:56	16:11	0:14	LINE FAULT
121	8-Jan-19	TUMKUR	66	TR-1 & TR-2	IDHALLY_66	13:11	13:50	0:38	LINE CLEAR AVAILED
122	8-Jan-19	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI 1	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	6:30	6:40	0:10	LINE FAULT
123	8-Jan-19	TUMKUR	66	MYLANAHALLI-THALLAK	MYLANAHALLI_66	10:12	10:23	0:10	HAND TRIPPED
124	8-Jan-19	TUMKUR	66	TR-1	MYLANAHALLI_66	14:03	14:22	0:18	LINE CLEAR AVAILED
125	8-Jan-19	TUMKUR	66	TR-2	RAMPURA_66	14:27	14:31	0:04	HAND TRIPPED
126	9-Jan-19	BAGALKOT	110	110/11KV,HV-4	GAJENDRAGAD_110	18:41	18:57	0:16	HAND TRIPPED
127	9-Jan-19	BAGALKOT	220	ALAMATTI 1-BAGALKOT	BAGALKOT_220	8:04	12:47	4:43	HAND TRIPPED
128	9-Jan-19	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	8:04	8:14	0:10	HAND TRIPPED
129	9-Jan-19	BAGALKOT	220	BAGALKOT -VAJRAMATTI 1	BAGALKOT_220	14:49	23:59	9:10	LINE CLEAR AVAILED
130	9-Jan-19	BAGALKOT	220	BELGAUM-KANABARGI 2	BELGAUM_220	11:56	23:59	12:03	LINE CLEAR AVAILED
131	9-Jan-19	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	0:00	8:53	8:53	HAND TRIPPED
132	9-Jan-19	BAGALKOT	220	KADRA 1-KARAWAR	KARAWAR_220	10:45	12:44	1:59	LINE CLEAR AVAILED
133	9-Jan-19	BAGALKOT	110	220/110KV, LV-1	KARAWAR_220	11:32	13:02	1:30	LINE CLEAR AVAILED
134	9-Jan-19	BAGALKOT	110	110/33KV,HV-1	KUMATA_110 &33KV ANKOLA,MARAKAL	11:49	14:18	2:29	HAND TRIPPED
135	9-Jan-19	BAGALKOT	110	110/33KV,HV-4	LAKAMANAHALLI_110&33KV NAGADI,ARAVATTIGE	11:03	11:08	0:05	TRANSFORMER FAULT
136	9-Jan-19	BAGALKOT	110	110/33KV,HV-4	LAKAMANAHALLI_110&33KV NAGADI,ARAVATTIGE	11:23	11:33	0:10	TRANSFORMER FAULT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
137	9-Jan-19	BAGALKOT	110	110/33KV,HV-4	LAKAMANAHALLI_110&33KV NAGADI,ARAVATTIGE	11:41	11:47	0:06	TRANSFORMER FAULT
138	9-Jan-19	BAGALKOT	110	110/33KV,HV-4	LAKAMANAHALLI_110&33KV NAGADI,ARAVATTIGE	20:49	20:50	0:01	TRANSFORMER FAULT
139	9-Jan-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	8:26	19:59	11:33	NFBC ISSUED
140	9-Jan-19	BAGALKOT	110	110/11KV, HV1	YELLAPARHATTI_110	12:27	12:39	0:12	LINE CLEAR AVAILED
141	9-Jan-19	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	12:52	12:59	0:07	TRANSFORMER FAULT
142	9-Jan-19	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	10:22	13:02	2:40	HAND TRIPPED
143	9-Jan-19	BAGALKOT	110	110/11KV,HV3	MUDHOL_110	10:26	10:42	0:16	LINE CLEAR AVAILED
144	9-Jan-19	BAGALKOT	110	MANALI SUGARS-MALGHAN	MALGHAN(S)_110	6:34	6:40	0:06	LINE FAULT
145	9-Jan-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	13:33	15:06	1:33	LINE CLEAR AVAILED
146	9-Jan-19	BAGALKOT	110	110/11KV, HV2	MAMDAPUR(B)_110	10:39	12:33	1:54	LINE CLEAR AVAILED
147	9-Jan-19	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	9:09	9:43	0:34	LINE CLEAR AVAILED
148	9-Jan-19	BANGALORE	66	HV1	AUSTIN TOWN	11:15	11:27	0:11	LINE CLEAR AVAILED
149	9-Jan-19	BANGALORE	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	6:42	6:47	0:04	LOAD CHANGEOVER
150	9-Jan-19	BANGALORE	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	9:18	9:24	0:05	LOAD CHANGEOVER
151	9-Jan-19	BANGALORE	66	HV3	ELECTRONIC CITY	7:16	7:56	0:40	TRANSFORMER FAULT
152	9-Jan-19	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	14:55	15:44	0:49	LINE FAULT
153	9-Jan-19	BANGALORE	66	HV2	MELEHALLI	12:15	12:32	0:17	LINE CLEAR AVAILED
154	9-Jan-19	BANGALORE	66	RAJANAKUNTE - YELAHANKA 220	RAJANAKUNTE	13:05	13:35	0:30	LINE FAULT
155	9-Jan-19	BANGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	7:11	7:25	0:13	LINE FAULT
156	9-Jan-19	BANGALORE	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	6:32	6:52	0:20	LINE FAULT
157	9-Jan-19	BANGALORE	220	HV3	HSR LAYOUT 220	6:32	7:21	0:48	MAIN SUPPLY FAILURE
158	9-Jan-19	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENTS	6:32	7:21	0:49	MAIN SUPPLY FAILURE
159	9-Jan-19	BANGALORE	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI, GLOBAL TECH PARK, VIKAS TECH PARK 220	6:32	7:21	0:49	MAIN SUPPLY FAILURE
160	9-Jan-19	BANGALORE	66	HSR LAYOUT 220 - ST JOHNS WOOD	ST JOHNS WOOD	6:32	7:21	0:49	MAIN SUPPLY FAILURE
161	9-Jan-19	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENTS	9:47	9:54	0:07	LOAD CHANGEOVER
162	9-Jan-19	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENTS	12:20	12:28	0:08	LOAD CHANGEOVER
163	9-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	5:25	6:16	0:51	MAIN SUPPLY FAILURE
164	9-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	5:25	6:16	0:51	MAIN SUPPLY FAILURE
165	9-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK, GTP (EHT)	5:25	5:50	0:25	MAIN SUPPLY FAILURE
166	9-Jan-19	BANGALORE	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	5:25	6:16	0:51	MAIN SUPPLY FAILURE
167	9-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	6:32	9:05	2:32	MAIN SUPPLY FAILURE
168	9-Jan-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	6:32	9:05	2:32	MAIN SUPPLY FAILURE

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
169	9-Jan-19	BANGALORE	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK, GTP (EHT)	6:32	7:34	1:01	MAIN SUPPLY FAILURE
170	9-Jan-19	BANGALORE	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK, GTP (EHT)	9:05	9:07	0:02	LOAD CHANGEOVER
171	9-Jan-19	BANGALORE	66	ATTIBELE - ANEKAL	ATTIBELE	9:00	9:05	0:05	LOAD CHANGEOVER
172	9-Jan-19	BANGALORE	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	9:15	9:18	0:03	LOAD CHANGEOVER
173	9-Jan-19	BANGALORE	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU, THIMMAMPALLI, SOMANATHPURA	9:03	18:31	9:27	LINE CLEAR AVAILED
174	9-Jan-19	BANGALORE	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	9:03	18:28	9:24	LINE CLEAR AVAILED
175	9-Jan-19	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	9:03	18:28	9:25	LINE CLEAR AVAILED
176	9-Jan-19	BANGALORE	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	9:03	18:28	9:25	LINE CLEAR AVAILED
177	9-Jan-19	BANGALORE	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	9:03	18:30	9:26	LINE CLEAR AVAILED
178	9-Jan-19	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	9:03	18:28	9:24	LINE CLEAR AVAILED
179	9-Jan-19	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	9:03	18:28	9:25	LINE CLEAR AVAILED
180	9-Jan-19	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	9:03	18:28	9:24	LINE CLEAR AVAILED
181	9-Jan-19	BANGALORE	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	9:03	18:28	9:24	LINE CLEAR AVAILED
182	9-Jan-19	BANGALORE	220	HV1	CHINTAMANI 220	9:04	18:16	9:11	LINE CLEAR AVAILED
183	9-Jan-19	BANGALORE	220	HV2	CHINTAMANI 220	9:04	18:16	9:11	LINE CLEAR AVAILED
184	9-Jan-19	BANGALORE	220	CHINTAMANI 220 - PGCIL 1 & 2	CHINTAMANI 220	9:14	18:15	9:01	LINE CLEAR AVAILED
185	9-Jan-19	BANGALORE	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	9:05	9:10	0:05	LOAD CHANGEOVER
186	9-Jan-19	BANGALORE	66	KACHMARANAHALLI - SHAMRAJ TECH PARK	KACHMARANAHALLI, DOMMASANDRA	8:00	8:25	0:25	MAIN SUPPLY FAILURE
187	9-Jan-19	BANGALORE	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA	11:47	12:27	0:40	LINE CLEAR AVAILED
188	9-Jan-19	BANGALORE	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	12:34	12:43	0:08	LOAD CURTAILMENT
189	9-Jan-19	BANGALORE	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI, SOMENAHALLI, SADLI, JULUPALYA	18:36	18:50	0:13	LINE CLEAR AVAILED
190	9-Jan-19	BANGALORE	66	THIMMAMPALLI - BAGEPALLI	THIMMAMPALLI	9:03	9:31	0:27	LINE FAULT
191	9-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE7	KANASWADI	7:51	8:04	0:13	LINE FAULT
192	9-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE8	RAJANKUNTE	10:34	10:45	0:11	LINE FAULT
193	9-Jan-19	BANGALORE	66	DB PURA 220 - DG 1	AIR(EHT)	14:43	14:46	0:03	LOAD CHANGEOVER
194	9-Jan-19	BANGALORE	66	DB PURA 220 - DG 1	AIR(EHT)	16:39	16:47	0:08	LOAD CHANGEOVER
195	9-Jan-19	BANGALORE	66	DB PURA 220 - D CROSS	D CROSS	15:02	15:09	0:07	LOAD CHANGEOVER

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
196	9-Jan-19	BANGALORE	66	DB PURA 220 - D CROSS	D CROSS	16:39	16:47	0:08	LOAD CHANGEOVER
197	9-Jan-19	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	15:11	15:25	0:14	LOAD CHANGEOVER
198	9-Jan-19	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	16:20	16:34	0:14	LOAD CHANGEOVER
199	9-Jan-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	5:27	9:01	3:34	MAIN SUPPLY FAILURE
200	9-Jan-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:27	9:01	3:34	MAIN SUPPLY FAILURE
201	9-Jan-19	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	5:27	9:01	3:34	MAIN SUPPLY FAILURE
202	9-Jan-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	5:27	8:35	3:07	MAIN SUPPLY FAILURE
203	9-Jan-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	10:35	17:20	6:45	LINE CLEAR AVAILED
204	9-Jan-19	BANGALORE	66	MALUR 220 - MALUR 66	MALUR 66	5:27	9:01	3:33	MAIN SUPPLY FAILURE
205	9-Jan-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:05	12:10	0:05	LINE FAULT
206	9-Jan-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	14:10	14:15	0:05	LINE FAULT
207	9-Jan-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:15	16:20	0:05	LINE FAULT
208	9-Jan-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	17:05	17:19	0:13	LINE FAULT
209	9-Jan-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	5:25	7:10	1:45	MAIN SUPPLY FAILURE
210	9-Jan-19	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	5:25	6:40	1:15	MAIN SUPPLY FAILURE
211	9-Jan-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	5:25	7:05	1:40	MAIN SUPPLY FAILURE
212	9-Jan-19	BANGALORE	220	HV1	SARJAPURA 220	5:25	7:03	1:38	MAIN SUPPLY FAILURE
213	9-Jan-19	BANGALORE	220	HV2	SARJAPURA 220	5:25	7:03	1:38	MAIN SUPPLY FAILURE
214	9-Jan-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	SARJAPURA 220	8:53	8:54	0:01	LOAD CHANGEOVER
215	9-Jan-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220	5:25	7:03	1:38	LOAD CHANGEOVER
216	9-Jan-19	BANGALORE	220	KOLAR 220 - PGCIL 1 & 2	KOLAR 220	5:28	8:48	3:19	LINE CLEAR AVAILED
217	9-Jan-19	BANGALORE	220	HV1	KOLAR 220	5:28	8:48	3:19	MAIN SUPPLY FAILURE
218	9-Jan-19	BANGALORE	220	HV2	KOLAR 220	5:28	8:48	3:19	MAIN SUPPLY FAILURE
219	9-Jan-19	BANGALORE	66	KOLAR 20 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	2:50	4:10	1:20	LOAD CURTAILMENT
220	9-Jan-19	BANGALORE	66	KOLAR 20 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:20	11:59	1:39	LINE CLEAR AVAILED

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
221	9-Jan-19	BANGALORE	66	KOLAR 20 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:13	15:18	0:05	LINE FAULT
222	9-Jan-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	5:27	8:48	3:21	MAIN SUPPLY FAILURE
223	9-Jan-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	3:45	5:00	1:15	LOAD CURTAILMENT
224	9-Jan-19	BANGALORE	66	KOLAR 220 - BANGARPET 2	BANGARPET	3:47	8:48	5:00	LOAD CURTAILMENT
225	9-Jan-19	BANGALORE	66	KOLAR 220 - BANGARPET 2	BANGARPET	9:03	12:00	2:56	LINE FAULT
226	9-Jan-19	BANGALORE	66	HV1	KOLAR 220	5:28	8:49	3:20	MAIN SUPPLY FAILURE
227	9-Jan-19	BANGALORE	66	HV2	KOLAR 220	5:28	8:48	3:19	MAIN SUPPLY FAILURE
228	9-Jan-19	BANGALORE	66	HV1	KOLAR 220	10:31	11:07	0:36	LINE CLEAR AVAILED
229	9-Jan-19	BANGALORE	66	HV1	KOLAR 220	12:23	13:41	1:18	LINE CLEAR AVAILED
230	9-Jan-19	BANGALORE	66	HV2	KOLAR 220	10:32	11:04	0:32	LOAD CHANGEOVER
231	9-Jan-19	BANGALORE	66	HV2	KOLAR 220	12:23	13:41	1:17	LOAD CHANGEOVER
232	9-Jan-19	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	2:44	3:48	1:03	LOAD CURTAILMENT
233	9-Jan-19	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	5:26	8:48	3:22	MAIN SUPPLY FAILURE
234	9-Jan-19	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:27	12:00	1:33	LINE CLEAR AVAILED
235	9-Jan-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	2:42	3:48	1:05	LOAD CURTAILMENT
236	9-Jan-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	5:26	8:48	3:22	MAIN SUPPLY FAILURE
237	9-Jan-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:27	12:01	1:34	LINE CLEAR AVAILED
238	9-Jan-19	BANGALORE	66	KOLAR 220 - DALASNUR	MALLASANDRA, DRDO (EHT), DAALSUR	3:45	5:25	1:39	LOAD CURTAILMENT
239	9-Jan-19	BANGALORE	66	KOLAR 220 - DALASNUR	MALLASANDRA, DRDO (EHT), DAALSUR	5:25	8:48	3:23	MAIN SUPPLY FAILURE
240	9-Jan-19	BANGALORE	66	KOLAR 220 - DALASNUR	MALLASANDRA, DRDO (EHT), DALASNUR	10:30	12:16	1:45	LINE CLEAR AVAILED
241	9-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	3:48	5:25	1:36	LOAD CURTAILMENT
242	9-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	5:25	8:48	3:23	MAIN SUPPLY FAILURE
243	9-Jan-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:28	12:01	1:33	LINE CLEAR AVAILED
244	9-Jan-19	BANGALORE	66	GUNDAMGERE - DB PURA 220	GUNDAMGERE	11:45	11:50	0:05	LINE CLEAR AVAILED
245	9-Jan-19	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	0:00	21:29	21:29	LINE CLEAR AVAILED
246	9-Jan-19	GULBARGA	110	RAICHUR-SHAHPUR2	RAICHUR_220	4:38	4:45	0:07	LINE FAULT
247	9-Jan-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	9:24	9:30	0:06	LOAD CHANGEOVER



Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
248	9-Jan-19	GULBARGA	66	KOGALI-ITTAGGI	KOGALI_66	18:12	18:26	0:14	LINE CLEAR AVAILED
249	9-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	22:58	22:59	0:01	LINE CLEAR AVAILED
250	9-Jan-19	HASSAN	220	GERSOPPA-TALGUPA1	GERSOPA_GEN	0:00	13:47	13:47	LINE FAULT
251	9-Jan-19	HASSAN	220	GERSOPPA-TALGUPA1	GERSOPA_GEN	13:51	18:26	4:35	LINE FAULT
252	9-Jan-19	HASSAN	220	HASSN220-CHIKKAMAGLUR	HASSAN_220	14:36	14:46	0:10	HAND TRIPPED
253	9-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	0:00	13:47	13:47	LINE CLEAR AVAILED
254	9-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	13:51	18:18	4:27	LINE FAULT
255	9-Jan-19	HASSAN	110	HV2	ALKOLA_110	9:34	10:18	0:44	TRANSFORMER FAULT
256	9-Jan-19	HASSAN	110	HV2	KADUR_220	10:59	11:32	0:33	LINE CLEAR AVAILED
257	9-Jan-19	HASSAN	110	HV1	KONAJE_110	14:11	16:05	1:54	LINE CLEAR AVAILED
258	9-Jan-19	HASSAN	110	HV2	KONAJE_110	9:31	14:10	4:39	LINE CLEAR AVAILED
259	9-Jan-19	HASSAN	110	HV3	KONAJE_110	10:00	13:56	3:56	LINE CLEAR AVAILED
260	9-Jan-19	HASSAN	110	HV3	KONAJE_110	14:35	14:40	0:05	LINE CLEAR AVAILED
261	9-Jan-19	HASSAN	110	HV3	KONAJE_110	15:33	16:39	1:06	LINE CLEAR AVAILED
262	9-Jan-19	HASSAN	110	HV3	KONAJE_110	17:48	17:50	0:02	LINE CLEAR AVAILED
263	9-Jan-19	HASSAN	110	HV1	NITTUR_110	23:57	23:59	0:02	TRANSFORMER FAULT
264	9-Jan-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:20	14:42	1:22	LINE CLEAR AVAILED
265	9-Jan-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:38	12:45	0:07	HAND TRIPPED
266	9-Jan-19	HASSAN	110	HV2	SORABA_110	11:38	11:59	0:21	TRANSFORMER FAULT
267	9-Jan-19	HASSAN	66	BHADRA-LINGADAHALLI	BHADRA_GEN	9:47	15:56	6:09	LINE CLEAR AVAILED
268	9-Jan-19	HASSAN	66	HASSAN220-MALLALI	HASSAN_220	11:10	11:19	0:09	HAND TRIPPED
269	9-Jan-19	HASSAN	66	HV2	HASSAN_66	19:10	20:03	0:53	TRANSFORMER FAULT
270	9-Jan-19	HASSAN	66	MOSALEH-BIOMASS	MOSALEHOSALLI_66	11:33	17:58	6:25	NFBC ISSUED
271	9-Jan-19	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSALLI_66	14:56	15:46	0:50	LINE CLEAR AVAILED
272	9-Jan-19	HASSAN	66	HV1	MOSALEHOSALLI_66	14:56	15:46	0:50	LINE CLEAR AVAILED
273	9-Jan-19	HASSAN	66	HV2	SBELAGOLA_66	11:45	12:04	0:19	LINE CLEAR AVAILED
274	9-Jan-19	HASSAN	66	HV2	SHANTHIGRAMA_66	13:33	17:44	4:11	LINE CLEAR AVAILED
275	9-Jan-19	HASSAN	66	HV2	TAVARECHETNALLY_66	13:46	14:29	0:43	TRANSFORMER FAULT
276	9-Jan-19	MYSORE	66	HOOTAGALLY-DATAGALLI	DATTAGALLY_66 RKNAGARA_66	7:29	7:43	0:13	LINE FAULT
277	9-Jan-19	MYSORE	220	HV2	KADAKOLA_220	9:34	14:42	5:08	LINE CLEAR AVAILED
278	9-Jan-19	MYSORE	66	HV2	KIKKERI_66	12:14	12:28	0:13	LINE CLEAR AVAILED
279	9-Jan-19	MYSORE	66	HV2	KIKKERI_66	14:52	15:24	0:32	LINE CLEAR AVAILED
280	9-Jan-19	MYSORE	66	MADHUVANAHALLI-KUNTHURU	KUNTHUR_66	19:40	20:06	0:26	LINE FAULT
281	9-Jan-19	MYSORE	66	HV1	SANTHESARAGUR_66	13:21	13:23	0:01	HAND TRIPPED
282	9-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	3:13	15:32	12:18	HAND TRIPPED
283	9-Jan-19	MYSORE	66	HV5	SFCSHIVA_66	20:27	23:59	3:31	HAND TRIPPED
284	9-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:23	18:34	8:11	LINE CLEAR AVAILED
285	9-Jan-19	TUMKUR	66	TR-1	BADAVANAHALLI_66	12:05	13:32	1:26	LINE CLEAR AVAILED

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
286	9-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TM2_66	8:18	17:34	9:15	HAND TRIPPED
287	9-Jan-19	TUMKUR	66	TR-2	HALURAMESHWARA_66	16:03	16:59	0:55	LINE CLEAR AVAILED
288	9-Jan-19	TUMKUR	66	TR-3	HALUVAGALU_66	10:51	11:37	0:45	LINE CLEAR AVAILED
289	9-Jan-19	TUMKUR	66	TR-1	HIRIYUR_66	16:02	17:48	1:46	LINE CLEAR AVAILED
290	9-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	6:51	6:54	0:02	LINE FAULT
291	9-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	9:08	9:11	0:03	MAIN SUPPLY FAILURE
292	9-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	12:15	12:19	0:03	MAIN SUPPLY FAILURE
293	9-Jan-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	6:26	6:40	0:14	LINE FAULT
294	9-Jan-19	TUMKUR	66	TR-1& TR-2	IDHALLY_66	12:51	13:18	0:27	LINE CLEAR AVAILED
295	9-Jan-19	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	18:35	18:50	0:15	LINE FAULT
296	9-Jan-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	17:01	17:05	0:04	HAND TRIPPED
297	9-Jan-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	10:09	10:20	0:11	TRANSFORMER FAULT
298	9-Jan-19	TUMKUR	66	TR-2	THIMMASANDRA_66	12:30	13:31	1:00	LINE CLEAR AVAILED
299	10-Jan-19	BAGALKOT	66	HARIHAR-BANUVALLY	BANUVALLY_66	16:59	17:21	0:22	LINE FAULT
300	10-Jan-19	BAGALKOT	110	110/11KV,HV-1	ACHANUR_110	7:21	7:28	0:07	LOAD CURTAILMENT
301	10-Jan-19	BAGALKOT	110	110/11KV,HV-1	ATHARGA_110	7:22	7:35	0:13	LOAD CURTAILMENT
302	10-Jan-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	19:12	23:59	4:47	LINE CLEAR AVAILED
303	10-Jan-19	BAGALKOT	110	110/11KV,HV-4	GAJENDRAGAD_110	7:21	7:42	0:21	LOAD CURTAILMENT
304	10-Jan-19	BAGALKOT	110	GOPANAKOPPA-MRITYUNJAYANAGAR 1&2	GOPANAKOPPA_110	9:55	15:21	5:26	LINE CLEAR AVAILED
305	10-Jan-19	BAGALKOT	110	110/33KV,HV-1	HANAGAL_110,33KV PALA & BOMMANAHALLI	7:22	8:32	1:10	LOAD CURTAILMENT
306	10-Jan-19	BAGALKOT	110	110/33KV,HV-3	HIDIKAL_110,33KV KOLIGUDDA & SULTANPUR	7:22	7:40	0:18	LOAD CURTAILMENT
307	10-Jan-19	BAGALKOT	110	110/11KV,HV-1	LAXMESHAWAR_110	7:21	7:35	0:14	LOAD CURTAILMENT
308	10-Jan-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	10:49	23:59	13:10	LINE CLEAR AVAILED
309	10-Jan-19	BAGALKOT	220	ALAMATTI 1-BAGALAKOT	BAGALKOT_220	15:40	18:58	3:18	LINE CLEAR AVAILED
310	10-Jan-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI 1	BAGALKOT_220	0:00	17:29	17:29	HAND TRIPPED
311	10-Jan-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	10:34	21:41	11:07	LINE CLEAR AVAILED
312	10-Jan-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	0:00	17:23	17:23	HAND TRIPPED
313	10-Jan-19	BAGALKOT	110	TADASINKOPPA-TARIHAL	TARIHAL_110	12:03	12:08	0:05	HAND TRIPPED
314	10-Jan-19	BAGALKOT	110	TADASINKOPPA-TARIHAL	TARIHAL_110	14:26	14:31	0:05	HAND TRIPPED
315	10-Jan-19	BAGALKOT	110	SIRSI-KUMTA1&2	KUMTA_110	11:59	12:21	0:22	LINE CLEAR AVAILED
316	10-Jan-19	BAGALKOT	110	SAVANUR-SHIGGOAN	SHIGGOAN_110	6:35	6:57	0:22	LINE FAULT
317	10-Jan-19	BAGALKOT	110	110/33KV,HV2	SAVALAGI_110,KALBALGI_33	7:22	7:41	0:19	LOAD CURTAILMENT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
318	10-Jan-19	BAGALKOT	110	110/33KV,HV2	SANKESHWAR_110, HEBBAL_33, KANAGAL_33	7:21	7:37	0:16	LOAD CURTAILMENT
319	10-Jan-19	BAGALKOT	110	110/11KV, HV2	RON_110	17:01	18:37	1:36	LINE CLEAR AVAILED
320	10-Jan-19	BAGALKOT	110	110/11KV,HV2	NANADI_110	16:43	17:51	1:08	LINE CLEAR AVAILED
321	10-Jan-19	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	7:48	7:54	0:06	LINE FAULT
322	10-Jan-19	BAGALKOT	220	ATRIA1-BAGEWADI	BAGEWADI_220	8:32	18:34	10:02	LINE CLEAR AVAILED
323	10-Jan-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	18:53	21:06	2:13	LINE CLEAR AVAILED
324	10-Jan-19	BANGALORE	66	HV2	BAIRAKURU	5:12	5:30	0:17	TRANSFORMER FAULT
325	10-Jan-19	BANGALORE	66	HV1	HAROBEL	14:58	15:05	0:06	LINE CLEAR AVAILED
326	10-Jan-19	BANGALORE	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, NANGALI	5:12	5:24	0:11	LINE FAULT
327	10-Jan-19	BANGALORE	66	HV1	HULLENHALLI	10:35	11:04	0:29	LINE CLEAR AVAILED
328	10-Jan-19	BANGALORE	66	SURYANAGAR - YERANDANAHALLI 220	SURYANAGAR	16:30	16:38	0:07	LINE CLEAR AVAILED
329	10-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLDEVANAHALLI	6:22	6:37	0:15	LINE FAULT
330	10-Jan-19	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLDEVANAHALLI	12:37	13:02	0:24	LINE CLEAR AVAILED
331	10-Jan-19	BANGALORE	66	HV1	MAGADI 220	17:01	17:30	0:28	LINE CLEAR AVAILED
332	10-Jan-19	BANGALORE	66	HV2	AMARJYOTHI	15:45	17:08	1:22	LINE CLEAR AVAILED
333	10-Jan-19	BANGALORE	66	CHANDRAPPA CIRCLE - KUMBALAGODU	CHANDRAPPA CIRCLE	14:22	14:31	0:09	LINE CLEAR AVAILED
334	10-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENHALLI, HAROBEL	7:44	8:03	0:18	LINE FAULT
335	10-Jan-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENHALLI, HAROBEL	8:35	8:43	0:07	LINE FAULT
336	10-Jan-19	BANGALORE	66	HV1	RAJANAKUNTE	12:29	12:33	0:03	LINE CLEAR AVAILED
337	10-Jan-19	BANGALORE	66	HV2	RAJANAKUNTE	12:29	12:32	0:03	LINE CLEAR AVAILED
338	10-Jan-19	BANGALORE	66	HV2	RAJANAKUNTE	12:33	12:48	0:15	TRANSFORMER FAULT
339	10-Jan-19	BANGALORE	66	HV2	REMCO	11:47	11:55	0:07	LINE CLEAR AVAILED
340	10-Jan-19	BANGALORE	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALI, SRIGANDAKAVAL	8:29	8:46	0:16	LINE FAULT
341	10-Jan-19	BANGALORE	66	HV2	TELECOM LAYOUT	14:05	16:40	2:34	LINE CLEAR AVAILED
342	10-Jan-19	BANGALORE	66	HV2	TK HALLI 220	18:33	18:39	0:05	TRANSFORMER FAULT
343	10-Jan-19	BANGALORE	66	HV1	LR BANDE	9:43	10:23	0:39	LINE CLEAR AVAILED
344	10-Jan-19	BANGALORE	66	HV2	VIDYANAGARA	2:16	2:44	0:27	TRANSFORMER FAULT
345	10-Jan-19	BANGALORE	220	TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	13:18	13:28	0:10	MAIN SUPPLY FAILURE
346	10-Jan-19	BANGALORE	220	TK HALLI 220 - KOLLEGALA 1 & 2	TK HALLI 220	13:18	13:28	0:10	MAIN SUPPLY FAILURE
347	10-Jan-19	BANGALORE	66	TK HALLI 220 - MANDYA 1 & 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA, K HONALGERE	13:18	13:28	0:10	MAIN SUPPLY FAILURE
348	10-Jan-19	BANGALORE	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, DODDALAHALLI	13:18	13:28	0:10	MAIN SUPPLY FAILURE
349	10-Jan-19	BANGALORE	66	TK HALLI 220 - IGGALUR	IGGALUR, AKKURMOLE	13:18	13:28	0:10	MAIN SUPPLY FAILURE

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
350	10-Jan-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	13:18	13:28	0:10	MAIN SUPPLY FAILURE
351	10-Jan-19	BANGALORE	66	TK HALLI 220 - BWSSB 1 (EHT)	BWSSB (EHT)	13:18	13:28	0:10	MAIN SUPPLY FAILURE
352	10-Jan-19	BANGALORE	66	TK HALLI 220 - BWSSB 2 (EHT)	BWSSB (EHT)	13:18	13:28	0:10	MAIN SUPPLY FAILURE
353	10-Jan-19	BANGALORE	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB (EHT)	13:18	13:28	0:10	MAIN SUPPLY FAILURE
354	10-Jan-19	GULBARGA	220	HV2	SHAHPUR_220	15:23	18:04	2:41	LINE CLEAR AVAILED
355	10-Jan-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGAL_110	0:00	0:20	0:20	LINE FAULT
356	10-Jan-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGAL_110	1:30	1:36	0:06	LINE FAULT
357	10-Jan-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGAL_110	3:33	7:36	4:03	LINE FAULT
358	10-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	7:20	7:40	0:20	LOAD CURTAILMENT
359	10-Jan-19	GULBARGA	110	HV3	LINGASUGUR_220	7:20	7:35	0:15	LOAD CURTAILMENT
360	10-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	13:55	14:05	0:10	LOAD CURTAILMENT
361	10-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	14:45	14:50	0:05	LOAD CURTAILMENT
362	10-Jan-19	GULBARGA	110	HUMNABAD220-CHITAGUPPA	CHITAGUPPA_110	10:13	10:34	0:21	LINE FAULT
363	10-Jan-19	GULBARGA	110	HV1	KURKUNTA_110	7:21	8:40	1:19	TRANSFORMER FAULT
364	10-Jan-19	GULBARGA	110	HUMNABAD220-SASTAPUR	MANTHAL_110 , SASTHAPUR_110,RAJESHWAR_110	21:00	21:10	0:10	LINE FAULT
365	10-Jan-19	GULBARGA	110	HV1	YELBURGA_110	17:05	17:43	0:38	LINE CLEAR AVAILED
366	10-Jan-19	GULBARGA	110	RAJESHWAR-WARDHA_SOLAR_IPP	RAJESHWAR_110	18:14	21:05	2:51	LINE CLEAR AVAILED
367	10-Jan-19	GULBARGA	110	KEMBHAVI-HUNASGI	HUNASGI_110	3:35	4:15	0:40	LINE FAULT
368	10-Jan-19	GULBARGA	110	KEMBHAVI-HUNASGI	HUNASGI_110	18:35	18:40	0:05	LINE FAULT
369	10-Jan-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110	0:10	0:15	0:05	LINE FAULT
370	10-Jan-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110	2:03	2:13	0:10	LINE FAULT
371	10-Jan-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110	3:35	4:08	0:33	LINE FAULT
372	10-Jan-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110	6:02	6:19	0:17	LINE FAULT
373	10-Jan-19	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110	19:34	20:14	0:40	LINE FAULT
374	10-Jan-19	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	4:08	11:52	7:44	LINE FAULT
375	10-Jan-19	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	19:56	23:59	4:03	LINE FAULT
376	10-Jan-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	14:05	15:03	0:58	LINE CLEAR AVAILED
377	10-Jan-19	GULBARGA	66	HV1	HAMPASAGAR_66	4:16	4:18	0:02	TRANSFORMER FAULT
378	10-Jan-19	GULBARGA	66	HANASI-KUDILIGI	HANASI_66	10:35	15:37	5:02	LINE CLEAR AVAILED
379	10-Jan-19	GULBARGA	66	HV1	ITTAGI_220	10:15	10:25	0:10	TRANSFORMER FAULT
380	10-Jan-19	GULBARGA	66	LV1	ITTAGI_220	13:15	13:23	0:08	LINE CLEAR AVAILED
381	10-Jan-19	GULBARGA	66	LV2	ITTAGI_220	13:15	13:23	0:08	TRANSFORMER FAULT
382	10-Jan-19	GULBARGA	66	ITTAGI220-TAMBRAHALLI	TAMBRAHALLI_66	14:25	14:32	0:07	LINE CLEAR AVAILED
383	10-Jan-19	HASSAN	400	UPCL-HASSAN1	UPCL_GEN	0:00	6:51	6:51	LINE CLEAR AVAILED
384	10-Jan-19	HASSAN	220	GERSOPA-TALGUPA1	GERSOPPA_GEN	11:14	15:20	4:06	NFBC ISSUED
385	10-Jan-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	0:00	17:40	17:40	NFBC ISSUED
386	10-Jan-19	HASSAN	220	MRSSHM-STRP1	MRSSMG_220	11:14	15:20	4:06	LINE CLEAR AVAILED
387	10-Jan-19	HASSAN	110	HV1	GURUVAYANKERE_110	7:56	8:06	0:10	TRANSFORMER FAULT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
388	10-Jan-19	HASSAN	110	HV2	HALADY_110	7:10	7:20	0:10	TRANSFORMER FAULT
389	10-Jan-19	HASSAN	110	HV4	KAVOOR_220	12:25	17:56	5:31	LINE CLEAR AVAILED
390	10-Jan-19	HASSAN	110	HV5	KAVOOR_220	9:37	12:21	2:44	LINE CLEAR AVAILED
391	10-Jan-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	21:00	21:06	0:06	LINE FAULT
392	10-Jan-19	HASSAN	110	NERALA-TEREKERE	NERALEKERE_110	11:44	13:46	2:02	LINE FAULT
393	10-Jan-19	HASSAN	110	HV1	NITTUR_110	0:00	0:11	0:11	TRANSFORMER FAULT
394	10-Jan-19	HASSAN	110	PUTTUR-KARAYA	PUTTUR_110	10:04	14:01	3:57	LINE CLEAR AVAILED
395	10-Jan-19	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLY_66	18:10	19:56	1:46	LINE CLEAR AVAILED
396	10-Jan-19	HASSAN	66	HV1	DODDAKADNUR_66	15:40	15:49	0:09	LOAD CURTAILMENT
397	10-Jan-19	HASSAN	66	HNPR2-MYSOR1	HNPUA_220	6:29	6:36	0:07	LINE FAULT
398	10-Jan-19	HASSAN	66	HNPR2-MYSOR2	HNPUA_220	9:24	9:27	0:03	HAND TRIPPED
399	10-Jan-19	HASSAN	66	HNPR2-MYSOR2	HNPUA_220	13:35	13:37	0:02	HAND TRIPPED
400	10-Jan-19	HASSAN	66	HV2	KIADBHASSAN_66	16:18	16:27	0:09	TRANSFORMER FAULT
401	10-Jan-19	HASSAN	66	MHHOSALLI-BIOMASS	MOSALEHOSALLI_66	9:43	16:33	6:50	NFBC ISSUED
402	10-Jan-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	7:22	7:36	0:14	TRANSFORMER FAULT
403	10-Jan-19	HASSAN	66	SALAGAME-HIREMANGLUR	SALAGAME_66	17:38	19:52	2:14	NFBC ISSUED
404	10-Jan-19	HASSAN	66	SALAGAME-HIREMANGLUR	SALAGAME_66	13:40	13:50	0:10	LOAD CURTAILMENT
405	10-Jan-19	HASSAN	66	HV2	SALAGAME_66	7:23	7:29	0:06	MAIN SUPPLY FAILURE
406	10-Jan-19	HASSAN	66	HV1	SATHENALLI_66	7:23	7:27	0:04	MAIN SUPPLY FAILURE
407	10-Jan-19	HASSAN	66	HV2	TAVARECHETNALLY_66	10:40	11:10	0:30	TRANSFORMER FAULT
408	10-Jan-19	MYSORE	66	HV2	BILIKERE_66	15:20	15:36	0:16	HAND TRIPPED
409	10-Jan-19	MYSORE	66	HV1	BILIKERE_66	15:37	15:38	0:01	HAND TRIPPED
410	10-Jan-19	MYSORE	66	HV1	PERIYAPATNA_66	15:30	16:00	0:30	LINE CLEAR AVAILED
411	10-Jan-19	MYSORE	66	HV2	PONNAMPET_66	7:22	7:35	0:12	LOAD CURTAILMENT
412	10-Jan-19	MYSORE	66	HV2	PONNAMPET_66	17:34	17:43	0:08	TRANSFORMER FAULT
413	10-Jan-19	MYSORE	66	HV2	SALIGRAMA_66	9:08	9:15	0:06	TRANSFORMER FAULT
414	10-Jan-19	MYSORE	220	HV1	KADAKOLA_220	2:02	2:24	0:21	TRANSFORMER FAULT
415	10-Jan-19	MYSORE	220	HV2	KADAKOLA_220	2:02	2:24	0:21	TRANSFORMER FAULT
416	10-Jan-19	MYSORE	66	HV1	KADAKOLA_220	11:30	12:29	0:59	LINE CLEAR AVAILED
417	10-Jan-19	MYSORE	66	HV1	HOOTAGALLY_220	16:20	16:41	0:21	HAND TRIPPED
418	10-Jan-19	MYSORE	66	HV2	HOOTAGALLY_220	16:46	17:58	1:11	HAND TRIPPED
419	10-Jan-19	MYSORE	66	HV3	KIKKERI_66	13:00	13:48	0:48	LINE CLEAR AVAILED
420	10-Jan-19	MYSORE	66	HV1	K_HONNALGERE_66	13:17	13:31	0:14	HAND TRIPPED
421	10-Jan-19	MYSORE	66	HV2	K_HONNALGERE_66	13:17	13:32	0:14	HAND TRIPPED
422	10-Jan-19	MYSORE	66	HV1	PANDAVAPURA_66	7:23	8:13	0:50	LOAD CURTAILMENT
423	10-Jan-19	MYSORE	66	HV1	KUNTHUR_66	4:55	5:15	0:20	TRANSFORMER FAULT
424	10-Jan-19	MYSORE	220	HV1	MADHUVANAHALLI_220	13:22	13:34	0:11	HAND TRIPPED
425	10-Jan-19	MYSORE	220	HV2	MADHUVANAHALLI_220	13:22	13:34	0:11	HAND TRIPPED

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
426	10-Jan-19	MYSORE	220	CR NAGARA-MADHUVANAHALLI 1	CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALI_66 KUNTHUR_66 CRNAGAR_220	13:16	13:34	0:17	LINE FAULT
427	10-Jan-19	MYSORE	220	VAJAMANGALA-TK HALLI	VAJAMANGALA_220 DEVANOORMYS_66 FTS_66 MEGALAPURA_66 BANNUR_66 KIRUGAVALU_66 BGPURA_66 THALAKADU_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 BANNIMANTAP_66 THAYURU_66 THUMLA_66 THALAKADU_66 RAJEEVNAGARA_66 DKMAIDANA_66	13:15	13:28	0:12	HAND TRIPPED
428	10-Jan-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	13:14	14:22	1:07	HAND TRIPPED
429	10-Jan-19	MYSORE	66	DK MAIDANA-KADAKOLA	DKMAIDANA_66	13:16	13:21	0:04	LINE FAULT
430	10-Jan-19	MYSORE	220	HOOTAGALLI-VAJAMANGALA	VAJAMANGALA_220 DEVANOORMYS_66 FTS_66 MEGALAPURA_66 BANNUR_66 KIRUGAVALU_66 BGPURA_66 THALAKADU_66 AYRALLI_66 MARADIHUNDI_66 JYOTHINAGARA_66 BANNIMANTAP_66 THAYURU_66 THUMLA_66 THALAKADU_66 RAJEEVNAGARA_66 DKMAIDANA_66	13:15	13:29	0:13	LINE FAULT
431	10-Jan-19	TUMKUR	220	TR-2(HV SIDE)	DAVANGERE_SRS_220	11:57	13:42	1:45	LINE CLEAR AVAILED
432	10-Jan-19	TUMKUR	110	TR-1	GUBBI_110	22:07	22:12	0:05	TRANSFORMER FAULT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
433	10-Jan-19	TUMKUR	110	TR-1	KALLUR_110	13:54	16:18	2:23	LINE CLEAR AVAILED
434	10-Jan-19	TUMKUR	110	TR-1	MAYASANDRA_110	13:34	14:41	1:06	LINE CLEAR AVAILED
435	10-Jan-19	TUMKUR	110	TR-2	SAMPIGE_110	20:59	21:08	0:09	TRANSFORMER FAULT
436	10-Jan-19	TUMKUR	66	ANCHEPALYA 220KV- KUNIGAL	KUNIGAL_66	10:08	16:33	6:25	LINE CLEAR AVAILED
437	10-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:32	22:37	12:05	LINE CLEAR AVAILED
438	10-Jan-19	TUMKUR	66	TR-2	BELLAVI_66	12:30	12:52	0:22	LINE CLEAR AVAILED
439	10-Jan-19	TUMKUR	66	TR-2	DAVANAGERE_66	12:31	12:33	0:02	LINE CLEAR AVAILED
440	10-Jan-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	11:56	12:21	0:25	HAND TRIPPED
441	10-Jan-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	13:25	13:51	0:26	HAND TRIPPED
442	10-Jan-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:55	12:35	0:39	HAND TRIPPED
443	10-Jan-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:41	11:55	0:13	HAND TRIPPED
444	10-Jan-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:24	14:01	0:37	HAND TRIPPED
445	10-Jan-19	TUMKUR	66	TR-1(HV SIDE )	DAVANGERE_SRS_220	11:41	11:54	0:12	HAND TRIPPED
446	10-Jan-19	TUMKUR	66	TR-1(HV SIDE )	DAVANGERE_SRS_220	13:24	14:01	0:37	HAND TRIPPED
447	10-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:37	17:42	9:05	HAND TRIPPED
448	10-Jan-19	TUMKUR	66	TR-2	GUTTUR_66	6:57	7:19	0:22	TRANSFORMER FAULT
449	10-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	6:51	6:57	0:06	MAIN SUPPLY FAILURE
450	10-Jan-19	TUMKUR	66	TR- & TR-2	HULIYURDURGA_66	10:12	15:23	5:11	LINE CLEAR AVAILED
451	10-Jan-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:04	10:11	0:07	LINE FAULT
452	10-Jan-19	TUMKUR	66	TR-1	KUNIGAL_66	9:48	17:33	7:44	LINE CLEAR AVAILED
453	10-Jan-19	TUMKUR	66	TR-2	KUNIGAL_66	9:48	16:36	6:47	LINE CLEAR AVAILED
454	10-Jan-19	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66	6:07	6:11	0:03	HAND TRIPPED
455	10-Jan-19	TUMKUR	66	TR-1	SAVALANGA_66	21:34	21:47	0:12	TRANSFORMER FAULT
456	10-Jan-19	TUMKUR	66	KEMPANAHALLI - AGALAKOTE	AGALKOTE_66	15:01	16:38	1:37	LINE CLEAR AVAILED
457	10-Jan-19	TUMKUR	66	TR-1	CHITRADURGA_66	2:35	2:58	0:22	TRANSFORMER FAULT
458	11-Jan-19	BAGALKOT	110	ATHANI 220 -HALIYAL	ATHANI_220	1:29	1:46	0:17	LINE FAULT
459	11-Jan-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	9:28	16:05	6:37	LINE CLEAR AVAILED
460	11-Jan-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	0:00	16:03	16:03	LINE CLEAR AVAILED

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
461	11-Jan-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	11:38	23:59	12:21	LINE FAULT
462	11-Jan-19	BAGALKOT	220	ALAMATTI 1-BAGALKOT	BAGALKOT_220	21:55	23:59	2:04	HAND TRIPPED
463	11-Jan-19	BAGALKOT	110	BAGALKOT-KATARAKI	NEERBUDIHAI_110	10:14	18:36	8:22	HAND TRIPPED
464	11-Jan-19	BAGALKOT	110	BAGALKOT-LOKAPUR 1	LOKAPUR_110	10:15	19:22	9:07	HAND TRIPPED
465	11-Jan-19	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	10:15	19:07	8:52	HAND TRIPPED
466	11-Jan-19	BAGALKOT	110	BAGALKOT-GULEDGUDD	GULEDGUDD_110	10:15	18:34	8:19	HAND TRIPPED
467	11-Jan-19	BAGALKOT	110	110/11KV,HV-3	BAGALKOT_220	10:17	18:50	8:33	HAND TRIPPED
468	11-Jan-19	BAGALKOT	110	BAGALKOT -NAVANAGAR 2	NAVANAGAR(B)_110	10:21	18:33	8:12	HAND TRIPPED
469	11-Jan-19	BAGALKOT	110	BAGALKOT220 -BAGALKOT 2	BAGALKOT_110	10:26	19:04	8:38	HAND TRIPPED
470	11-Jan-19	BAGALKOT	110	220/110KV,LV-2	BAGALKOT_220	10:27	18:36	8:09	HAND TRIPPED
471	11-Jan-19	BAGALKOT	110	BAGALKOT-NAVANAGAR 1	NAVANAGAR(B)_110	15:40	23:59	8:19	HAND TRIPPED
472	11-Jan-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110	16:22	16:25	0:03	TRANSFORMER FAULT
473	11-Jan-19	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRAHATTI_110	10:20	17:43	7:23	LINE CLEAR AVAILED
474	11-Jan-19	BAGALKOT	110	BPCL1&2-SHIRAHATTI	SHIRAHATTI_110	10:28	17:45	7:17	LINE CLEAR AVAILED
475	11-Jan-19	BAGALKOT	110	SHIRAHATTI-LAXMESHWAR	LAXMESHWAR_110	10:36	17:34	6:58	LINE CLEAR AVAILED
476	11-Jan-19	BAGALKOT	110	RON- HIREHAL	HIREHAL_110	7:56	8:09	0:13	LINE CLEAR AVAILED
477	11-Jan-19	BAGALKOT	110	RON- HIREHAL	HIREHAL_110	19:04	19:08	0:04	LINE CLEAR AVAILED
478	11-Jan-19	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	13:19	13:50	0:31	TRANSFORMER FAULT
479	11-Jan-19	BAGALKOT	110	CHIKKODI220-RAIBAG	RAIBAG_110	12:52	13:26	0:34	LINE CLEAR AVAILED
480	11-Jan-19	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	12:52	13:26	0:34	LINE CLEAR AVAILED
481	11-Jan-19	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	12:52	13:29	0:37	LINE CLEAR AVAILED
482	11-Jan-19	BAGALKOT	220	220/110KV, HV2&LV2	NARENDRA_220	9:33	23:59	14:26	LINE CLEAR AVAILED
483	11-Jan-19	BAGALKOT	110	110/11KV, HV2	MUNVALLI_110	19:54	20:01	0:07	TRANSFORMER FAULT
484	11-Jan-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	8:16	13:40	5:24	NFBC ISSUED
485	11-Jan-19	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI2	MAHALINGAPUR_220	0:00	13:29	13:29	LINE CLEAR AVAILED
486	11-Jan-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	15:17	15:47	0:30	LINE FAULT
487	11-Jan-19	BAGALKOT	110	110/11KV, HV2	KULIGOD_110	23:35	23:44	0:09	TRANSFORMER FAULT
488	11-Jan-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	10:25	23:59	13:34	LINE CLEAR AVAILED
489	11-Jan-19	BAGALKOT	110	110/11KV, HV4	KERUR_110	10:29	13:48	3:19	LINE CLEAR AVAILED
490	11-Jan-19	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	10:39	13:43	3:04	LINE CLEAR AVAILED
491	11-Jan-19	BAGALKOT	110	110/11KV, HV3	JAMKHANDI_110	16:15	16:17	0:02	LINE CLEAR AVAILED
492	11-Jan-19	BAGALKOT	110	MAHALINGAPUR-BANHATTI	BANHATTI_110	0:00	14:12	14:12	LINE CLEAR AVAILED
493	11-Jan-19	BAGALKOT	110	110/11KV,HV1	SIRSI_220	20:20	23:59	3:39	HAND TRIPPED
494	11-Jan-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	17:39	17:41	0:02	LINE FAULT
495	11-Jan-19	BANGALORE	66	CHIKKABALLAPURA I/A - DB PURA 1	TUBUGERE	4:43	5:15	0:32	LINE FAULT
496	11-Jan-19	BANGALORE	66	HV1	CHIKKABALLAPURA I/A	10:34	11:54	1:20	LINE CLEAR AVAILED
497	11-Jan-19	BANGALORE	66	HV1	D PALYA	10:38	15:30	4:52	LINE CLEAR AVAILED
498	11-Jan-19	BANGALORE	66	HV2	D PALYA	10:40	15:30	4:50	LINE CLEAR AVAILED



Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
499	11-Jan-19	BANGALORE	66	HV1	SUGUTUR	18:05	18:31	0:26	TRANSFORMER FAULT
500	11-Jan-19	BANGALORE	66	HV1	VOLVO	10:02	11:19	1:17	LINE CLEAR AVAILED
501	11-Jan-19	BANGALORE	66	HV2	VIJAYANAGAR	8:49	9:20	0:31	MAIN SUPPLY FAILURE
502	11-Jan-19	BANGALORE	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	12:28	13:58	1:30	LINE CLEAR AVAILED
503	11-Jan-19	BANGALORE	220	HV2	NRS 220	8:48	11:29	2:40	TRANSFORMER FAULT
504	11-Jan-19	BANGALORE	66	HV2	NRS 220	22:03	22:11	0:07	LOAD CHANGEOVER
505	11-Jan-19	BANGALORE	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	8:48	9:20	0:31	LINE FAULT
506	11-Jan-19	BANGALORE	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	8:48	10:07	1:18	LINE FAULT
507	11-Jan-19	BANGALORE	66	HV2	ABBIGERE	10:45	11:45	0:59	TRANSFORMER FAULT
508	11-Jan-19	BANGALORE	66	TELECOM LAYOUT - NRS 1	TELECOM LAYOUT	15:10	15:16	0:06	LOAD CHANGEOVER
509	11-Jan-19	BANGALORE	66	HV2	TELECOM LAYOUT	13:16	13:32	0:16	LINE CLEAR AVAILED
510	11-Jan-19	BANGALORE	66	HV2	TELECOM LAYOUT	13:58	14:48	0:49	LINE CLEAR AVAILED
511	11-Jan-19	BANGALORE	66	TK HALLI 220 - IGGALURU	IGGALURU, AKKURMOLE, K HONALGERE	7:46	7:52	0:06	LINE FAULT
512	11-Jan-19	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGRAGOAN_110,DIGGI_110	13:21	13:29	0:08	LINE FAULT
513	11-Jan-19	GULBARGA	110	KUSTAGI-KANAKAGIRI	KANAKAGIRI_110,GANDAL_110	6:40	7:36	0:56	LINE FAULT
514	11-Jan-19	GULBARGA	110	HV3	KOLHAR_110	13:10	13:45	0:35	LINE CLEAR AVAILED
515	11-Jan-19	GULBARGA	110	KOLHAR-NSSK_IPP	KOLHAR_110	13:20	13:22	0:02	LINE FAULT
516	11-Jan-19	GULBARGA	110	HV4	YELBURGA_110	9:04	9:17	0:13	TRANSFORMER FAULT
517	11-Jan-19	GULBARGA	110	HV3	HANUMASAGAR_110	17:25	20:00	2:35	TRANSFORMER FAULT
518	11-Jan-19	GULBARGA	110	HV3	HANUMASAGAR_110	20:05	20:08	0:03	LINE CLEAR AVAILED
519	11-Jan-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGAL_110	15:45	15:56	0:11	LINE FAULT
520	11-Jan-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	16:56	20:24	3:28	NFBC ISSUED
521	11-Jan-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:10	16:43	6:33	NFBC ISSUED
522	11-Jan-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:09	16:43	6:34	NFBC ISSUED
523	11-Jan-19	HASSAN	220	SHARAVATHY-SHIRALKOPPA	SHRAVTHY_GEN	12:52	16:21	3:29	LINE FAULT
524	11-Jan-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	12:50	16:21	3:31	LINE FAULT
525	11-Jan-19	HASSAN	220	VARAHI-KEMAR3	VARAHI_GEN	12:35	23:59	11:24	NFBC ISSUED
526	11-Jan-19	HASSAN	110	BARANGI-ANVATTI	BARANGI_110	13:43	14:29	0:46	NFBC ISSUED
527	11-Jan-19	HASSAN	110	HV2	HALADY_110	11:35	12:05	0:30	LINE CLEAR AVAILED
528	11-Jan-19	HASSAN	110	SAGARA-IDLE	SAGARA_110	13:30	13:35	0:05	HAND TRIPPED
529	11-Jan-19	HASSAN	110	SAGARA-IDLE	SAGARA_110	17:05	17:20	0:15	HAND TRIPPED
530	11-Jan-19	HASSAN	110	HV4	SHIRALKOPPA_220	12:55	13:25	0:30	TRANSFORMER FAULT
531	11-Jan-19	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	2:42	2:52	0:10	LINE FAULT
532	11-Jan-19	HASSAN	110	SHRLKP-SORABA	SHIRALKOPPA_220	12:50	17:09	4:19	LINE FAULT
533	11-Jan-19	HASSAN	110	SORABA-SHR220	SAGARA_110	13:37	17:13	3:36	LINE CLEAR AVAILED
534	11-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	15:05	16:30	1:25	LINE CLEAR AVAILED
535	11-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	13:33	13:40	0:07	HAND TRIPPED
536	11-Jan-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	15:55	16:21	0:26	LINE CLEAR AVAILED

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
537	11-Jan-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	15:00	16:20	1:20	HAND TRIPPED
538	11-Jan-19	HASSAN	66	HV2	KIADB HASSAN_66	9:52	10:02	0:10	TRANSFORMER FAULT
539	11-Jan-19	HASSAN	66	HV2	KIADB HASSAN_66	12:01	12:11	0:10	TRANSFORMER FAULT
540	11-Jan-19	HASSAN	66	HV2	KIADB HASSAN_66	15:50	15:56	0:06	TRANSFORMER FAULT
541	11-Jan-19	MYSORE	66	HV1	BOOKANAKERE_66	13:24	14:27	1:02	LINE CLEAR AVAILED
542	11-Jan-19	MYSORE	66	HV2	HANAGODU_66	12:41	14:05	1:23	LINE CLEAR AVAILED
543	11-Jan-19	MYSORE	66	HV2	JYOTHINAGARA_66	13:12	13:28	0:16	HAND TRIPPED
544	11-Jan-19	MYSORE	66	KADAKOLA-DK MAIDANA	DKMAIDANA_66	23:43	23:49	0:05	LINE FAULT
545	11-Jan-19	MYSORE	66	HV3	KIKKERI_66	12:46	13:28	0:42	LINE CLEAR AVAILED
546	11-Jan-19	MYSORE	66	HV3	KRPET_66	10:27	12:48	2:21	LINE CLEAR AVAILED
547	11-Jan-19	MYSORE	66	HV1	KRPET_220	16:29	16:32	0:02	TRANSFORMER FAULT
548	11-Jan-19	MYSORE	66	HV2	SANTHESARAGUR_66	15:20	16:53	1:33	LINE CLEAR AVAILED
549	11-Jan-19	MYSORE	66	KIIRUGAVALU-SFC	KIRUGAVALU_66	10:16	19:00	8:44	LINE CLEAR AVAILED
550	11-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:16	18:16	8:00	LINE CLEAR AVAILED
551	11-Jan-19	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 1	CHITRADURGA_66	12:05	13:24	1:19	HAND TRIPPED
552	11-Jan-19	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 2	CHITRADURGA_66	12:05	13:25	1:19	HAND TRIPPED
553	11-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:25	17:43	9:17	HAND TRIPPED
554	11-Jan-19	TUMKUR	66	TR-1	HARAPPANAHALLI_66	13:21	18:18	4:57	TRANSFORMER FAULT
555	11-Jan-19	TUMKUR	66	TR-2	HINDASGHATTA_66	12:02	13:02	0:59	LINE CLEAR AVAILED
556	11-Jan-19	TUMKUR	66	TR-3	HOLALKERE_66	16:37	17:11	0:34	LINE CLEAR AVAILED
557	11-Jan-19	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	17:28	18:09	0:41	LINE FAULT
558	11-Jan-19	TUMKUR	66	TR-1	MATHOD_66	15:49	15:51	0:02	HAND TRIPPED
559	11-Jan-19	TUMKUR	66	TR-1	MATHOD_66	16:38	16:45	0:07	HAND TRIPPED
560	11-Jan-19	TUMKUR	66	TR-1	MATHOD_66	17:09	17:33	0:24	HAND TRIPPED
561	11-Jan-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	7:58	8:19	0:20	TRANSFORMER FAULT
562	11-Jan-19	TUMKUR	66	TR-1	SAVALANGA_66	17:48	17:53	0:05	LINE CLEAR AVAILED
563	12-Jan-19	BAGALKOT	110	ATHANI 220 -AIGALI	AIGALI_110	6:40	6:49	0:09	LINE FAULT
564	12-Jan-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110	15:25	15:33	0:08	TRANSFORMER FAULT
565	12-Jan-19	BAGALKOT	220	220/110KV, HV2&LV2	NARENDRA_220	0:00	15:24	15:24	LINE CLEAR AVAILED
566	12-Jan-19	BAGALKOT	220	220/110KV, HV1&LV1	NARENDRA_220	15:33	23:59	8:26	LINE CLEAR AVAILED
567	12-Jan-19	BAGALKOT	110	110/11KV, HV1	NANADI_110	15:06	15:52	0:46	LINE CLEAR AVAILED
568	12-Jan-19	BAGALKOT	110	MKHUBLI220-KHANAPUR	KHANAPUR_110	10:09	17:28	7:19	LINE CLEAR AVAILED
569	12-Jan-19	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	17:49	18:27	0:38	LINE CLEAR AVAILED
570	12-Jan-19	BAGALKOT	110	110/11KV, HV2	BELUR_110	17:02	17:20	0:18	HAND TRIPPED
571	12-Jan-19	BAGALKOT	110	110/11KV,HV1	SIRSI_220	0:00	0:05	0:05	HAND TRIPPED
572	12-Jan-19	BANGALORE	66	BEGUR 220 - BIAL 1 (EHT)	BIAL (EHT)	11:58	12:14	0:16	LINE CLEAR AVAILED
573	12-Jan-19	BANGALORE	66	BEGUR 220 - BIAL 2 (EHT)	BIAL (EHT)	11:58	12:14	0:16	LINE CLEAR AVAILED

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
574	12-Jan-19	BANGALORE	66	BEGUR 220 - BOODIGERE	BOODIGERE	11:59	12:16	0:17	LINE CLEAR AVAILED
575	12-Jan-19	BANGALORE	220	BEGUR 220 - HOODY 220	BEGUR 220	11:58	12:00	0:02	LOAD CHANGEOVER
576	12-Jan-19	BANGALORE	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220	11:58	12:23	0:25	LINE CLEAR AVAILED
577	12-Jan-19	BANGALORE	220	HV1	BEGUR 220	11:58	12:01	0:03	LINE CLEAR AVAILED
578	12-Jan-19	BANGALORE	220	HV2	BEGUR 220	11:58	12:14	0:16	LINE CLEAR AVAILED
579	12-Jan-19	BANGALORE	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A	12:07	12:16	0:09	LINE FAULT
580	12-Jan-19	BANGALORE	66	CHIKKABALLAPURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	9:10	9:55	0:45	LINE FAULT
581	12-Jan-19	BANGALORE	66	CHIKKABALLAPURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	12:11	12:17	0:06	LINE CLEAR AVAILED
582	12-Jan-19	BANGALORE	220	HOSKOTE 220 - BEGUR 220	HOSKOTE 220	11:58	12:25	0:27	LINE CLEAR AVAILED
583	12-Jan-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	VIDYANAGARA, HENNUR CROSS, GRIND WELL (EHT)	11:58	12:36	0:38	LINE CLEAR AVAILED
584	12-Jan-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	11:58	12:33	0:35	LINE CLEAR AVAILED
585	12-Jan-19	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:58	12:32	0:34	LINE CLEAR AVAILED
586	12-Jan-19	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	11:58	12:40	0:42	LINE CLEAR AVAILED
587	12-Jan-19	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	11:58	12:35	0:37	LINE CLEAR AVAILED
588	12-Jan-19	BANGALORE	220	HV1	HOSKOTE 220	11:58	12:27	0:29	LINE CLEAR AVAILED
589	12-Jan-19	BANGALORE	220	HV2	HOSKOTE 220	11:58	12:28	0:30	LINE CLEAR AVAILED
590	12-Jan-19	BANGALORE	66	HV1	SUGATUR	14:19	14:30	0:11	LOAD CHANGEOVER
591	12-Jan-19	BANGALORE	220	HV2	HOODY 220	9:32	9:39	0:07	LOAD CHANGEOVER
592	12-Jan-19	BANGALORE	220	HV3	HOODY 220	9:40	9:48	0:08	LOAD CHANGEOVER
593	12-Jan-19	BANGALORE	66	HOODY 220 - BMRCL (EHT)	BMRCL (EHT)	13:24	13:26	0:01	LOAD CHANGEOVER
594	12-Jan-19	BANGALORE	66	VICTORIA - A STATION 220	VICTORIA	12:34	12:41	0:07	LOAD CHANGEOVER
595	12-Jan-19	BANGALORE	66	VICTORIA HOSPITAL - NATIONAL COLLEGE	VICTORIA	15:10	15:13	0:03	LOAD CHANGEOVER
596	12-Jan-19	BANGALORE	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	15:07	15:14	0:07	LOAD CHANGEOVER
597	12-Jan-19	BANGALORE	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE, RBI	15:07	15:14	0:07	LOAD CHANGEOVER
598	12-Jan-19	GULBARGA	220	HV1,HV2	LINGASUGUR_220	2:05	2:15	0:10	TRANSFORMER FAULT
599	12-Jan-19	GULBARGA	110	HV2	HANUMASAGAR_110	17:00	17:45	0:45	LINE CLEAR AVAILED
600	12-Jan-19	GULBARGA	110	HV3	HATTI_110	2:10	3:10	1:00	TRANSFORMER FAULT
601	12-Jan-19	GULBARGA	110	HV1	HATTI_110	2:40	2:50	0:10	TRANSFORMER FAULT
602	12-Jan-19	GULBARGA	110	HV2	HATTI_110	3:15	3:50	0:35	TRANSFORMER FAULT
603	12-Jan-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGAL_110	5:23	6:00	0:37	LINE FAULT
604	12-Jan-19	GULBARGA	110	HV1	RAICHUR_220	6:09	6:12	0:03	TRANSFORMER FAULT
605	12-Jan-19	GULBARGA	110	GURUGUNTA-LJVL_IPP	GURUGUNTA_110	2:05	2:45	0:40	LINE FAULT
606	12-Jan-19	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	6:35	6:45	0:10	LINE FAULT
607	12-Jan-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	4:07	4:13	0:06	LINE FAULT
608	12-Jan-19	HASSAN	220	KADUR-DABUSET	KADUR_220	9:55	17:40	7:45	LOAD CURTAILMENT
609	12-Jan-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	13:35	18:17	4:42	LINE FAULT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
610	12-Jan-19	HASSAN	220	SHRAVATHY-SHIMOGA4	SHRAVTHY_GEN	13:35	18:17	4:42	LINE FAULT
611	12-Jan-19	HASSAN	110	HV2	KEMAR_220	20:13	20:25	0:12	LINE CLEAR AVAILED
612	12-Jan-19	HASSAN	110	SAGARA-IDLE	SAGARA_110	4:43	4:58	0:15	HAND TRIPPED
613	12-Jan-19	HASSAN	110	SAGARA-IDLE	SAGARA_110	12:09	12:15	0:06	HAND TRIPPED
614	12-Jan-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	15:04	15:07	0:03	HAND TRIPPED
615	12-Jan-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	4:24	12:04	7:40	LINE FAULT
616	12-Jan-19	HASSAN	110	SORABA-SHR220	SORABA_110	5:03	12:18	7:15	LINE CLEAR AVAILED
617	12-Jan-19	HASSAN	66	HV2	BELUR_66	7:50	8:10	0:20	TRANSFORMER FAULT
618	12-Jan-19	HASSAN	66	HV2	HASSN_66	21:43	22:30	0:47	TRANSFORMER FAULT
619	12-Jan-19	HASSAN	66	HV2	KIADB HASSAN_66	16:25	16:35	0:10	TRANSFORMER FAULT
620	12-Jan-19	MYSORE	66	FTS-RAJEEV NAGARA	RAJEEVNAGARA_66 DEVANOORMYS_66	11:18	13:10	1:51	LINE CLEAR AVAILED
621	12-Jan-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADICHUNCHANAGIRI_66 ADDIHALLI_66 BGNAGARA_66 BASARALU_66 HARADANAHALLI(JAK) SHIVALLY _66 VADERALLI_66	17:47	17:55	0:07	LINE FAULT
622	12-Jan-19	TUMKUR	110	HONNAVALLI 110-ADANSOLAR_IPP_110	ADANSOLAR_IPP_110	18:06	18:48	0:42	LINE CLEAR AVAILED
623	12-Jan-19	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:38	18:08	6:29	LINE CLEAR AVAILED
624	12-Jan-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	17:50	18:03	0:13	LINE FAULT
625	12-Jan-19	TUMKUR	66	TR-1& TR-2	CHANNAGIRI_66	9:42	9:51	0:08	MAIN SUPPLY FAILURE
626	12-Jan-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	10:03	10:14	0:11	HAND TRIPPED
627	12-Jan-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	4:17	4:30	0:12	LINE FAULT
628	12-Jan-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:53	17:38	9:45	HAND TRIPPED
629	12-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	4:49	4:55	0:06	LINE FAULT
630	12-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	7:53	9:35	1:42	LINE FAULT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
631	12-Jan-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:40	9:47	0:06	HAND TRIPPED
632	12-Jan-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	14:29	14:41	0:11	LINE FAULT
633	12-Jan-19	TUMKUR	66	KORATAGERE-HOLAVANHALLI	KORATAGERE_66	20:13	20:40	0:26	MAIN SUPPLY FAILURE
634	12-Jan-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:32	5:41	0:09	LINE FAULT
635	12-Jan-19	TUMKUR	66	TR-1	KUNIGAL_66	11:13	13:48	2:35	LINE CLEAR AVAILED
636	12-Jan-19	TUMKUR	66	TR-1	LINGADAHALLY_66	7:58	8:00	0:02	TRANSFORMER FAULT
637	12-Jan-19	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	20:12	20:21	0:08	LINE FAULT
638	12-Jan-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	14:27	14:36	0:08	TRANSFORMER FAULT
639	13-Jan-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	7:55	9:54	1:59	HAND TRIPPED
640	13-Jan-19	BAGALKOT	110	ENERCON2-SOUDATTI	SOUDATTI_110	18:52	20:11	1:19	LINE FAULT
641	13-Jan-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	7:00	23:59	16:59	LINE FAULT
642	13-Jan-19	BAGALKOT	220	220/110KV, HV1&LV1	NARENDRA_220	0:00	18:32	18:32	LINE CLEAR AVAILED
643	13-Jan-19	BAGALKOT	110	MKHUBLI220-BIDI1	BIDI_110	10:00	17:01	7:01	LINE CLEAR AVAILED
644	13-Jan-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	0:00	8:05	8:05	LINE CLEAR AVAILED
645	13-Jan-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	7:01	13:12	6:11	LINE FAULT
646	13-Jan-19	BANGALORE	66	HV1	NELAMANAGALA 66	6:41	6:46	0:05	LOAD CHANGEOVER
647	13-Jan-19	BANGALORE	66	HV1	NELAMANAGALA 66	9:08	9:12	0:04	LOAD CHANGEOVER
648	13-Jan-19	BANGALORE	220	HV3	HOODY 220	19:24	19:30	0:06	LOAD CHANGEOVER
649	13-Jan-19	BANGALORE	220	HV2	HOODY 220	19:11	19:20	0:09	LOAD CHANGEOVER
650	13-Jan-19	BANGALORE	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT)	8:21	9:06	0:45	LINE FAULT
651	13-Jan-19	BANGALORE	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	8:28	8:34	0:06	LOAD CHANGEOVER
652	13-Jan-19	BANGALORE	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	11:26	11:30	0:04	LOAD CHANGEOVER
653	13-Jan-19	BANGALORE	66	HV2	C STATION	12:23	13:16	0:53	LINE CLEAR AVAILED
654	13-Jan-19	BANGALORE	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	5:50	8:10	2:20	LINE FAULT
655	13-Jan-19	BANGALORE	66	HV1	KENGERI SATELLITE TOWN	5:15	8:12	2:57	TRANSFORMER FAULT
656	13-Jan-19	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	5:15	9:08	3:53	TRANSFORMER FAULT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
657	13-Jan-19	BANGALORE	66	RAJANAKUNTE - YELAHANKA 220	RAJANAKUNTE	18:38	19:04	0:25	LINE FAULT
658	13-Jan-19	BANGALORE	66	HV2	RAJANAKUNTE	19:11	19:30	0:19	TRANSFORMER FAULT
659	13-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	18:01	22:38	4:36	LINE FAULT
660	13-Jan-19	BANGALORE	66	RR NAGAR - SUBRAMANYA PURA 220	R R NAGAR	18:01	18:25	0:24	LOAD CHANGEOVER
661	13-Jan-19	BANGALORE	66	RR NAGAR - VRISHABHAVATHI 220	R R NAGAR	22:50	22:54	0:04	LOAD CHANGEOVER
662	13-Jan-19	BANGALORE	66	T K HALLI 220 - MANDYA 2	KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:47	16:05	0:17	LINE FAULT
663	13-Jan-19	BANGALORE	66	HV2	APPAREAL PARK	11:01	11:56	0:55	LINE CLEAR AVAILED
664	13-Jan-19	GULBARGA	220	SEDAM-TANDUR	SEDAM_220	22:30	23:20	0:50	LINE FAULT
665	13-Jan-19	GULBARGA	110	HV2	HANUMASAGAR_110	17:00	17:30	0:30	LINE CLEAR AVAILED
666	13-Jan-19	GULBARGA	110	RAJESHWAR-WARADHA SLR	RAJESHWAR_110	10:21	11:41	1:20	LINE CLEAR AVAILED
667	13-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	9:35	9:56	0:21	TRANSFORMER FAULT
668	13-Jan-19	GULBARGA	66	HV1	HAMPASAGAR_66	9:32	9:42	0:10	TRANSFORMER FAULT
669	13-Jan-19	HASSAN	110	ARSK2-BANAVARA	ARSIKERE_110	16:48	17:09	0:21	LINE FAULT
670	13-Jan-19	HASSAN	110	HV2	BAIKAMPADI_110	7:00	9:32	2:32	LINE CLEAR AVAILED
671	13-Jan-19	HASSAN	110	HV1	BANAVARA_110	10:30	15:49	5:19	LINE CLEAR AVAILED
672	13-Jan-19	HASSAN	110	HV2	GANDASI_110	17:55	18:05	0:10	TRANSFORMER FAULT
673	13-Jan-19	HASSAN	110	HV2	GANDASI_110	18:27	18:39	0:12	TRANSFORMER FAULT
674	13-Jan-19	HASSAN	66	HV2	HASSN_66	11:13	14:08	2:55	LINE CLEAR AVAILED
675	13-Jan-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	20:30	21:05	0:35	HAND TRIPPED
676	13-Jan-19	HASSAN	66	HV2	MATTNAVILE_66	7:23	18:29	11:06	TRANSFORMER FAULT
677	13-Jan-19	HASSAN	66	SIGEBAGE-KDLGRE	SIGEBAGE_66	19:55	20:30	0:35	HAND TRIPPED
678	13-Jan-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66, KIADBMANDYA_66 & MADDUR_66 K HONNALAGERE	15:46	16:05	0:18	LINE FAULT
679	13-Jan-19	MYSORE	66	PERIYAPATNA-HANAGODU	HANAGODU_66, PONNAMPET_66, VIRAJPET_66	3:40	3:48	0:07	LINE FAULT
680	13-Jan-19	TUMKUR	110	TR-1	KBCROSS_220	18:38	19:25	0:46	HAND TRIPPED
681	13-Jan-19	TUMKUR	110	TR-1	KEREKODI_110	10:36	13:05	2:29	LINE CLEAR AVAILED
682	13-Jan-19	TUMKUR	66	TR-2	CHANNAGIRI_66	10:00	10:05	0:04	TRANSFORMER FAULT
683	13-Jan-19	TUMKUR	66	TR-2	CHANNAGIRI_66	22:07	22:09	0:01	MAIN SUPPLY FAILURE
684	13-Jan-19	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	18:15	18:25	0:09	TRANSFORMER FAULT
685	13-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	15:00	15:05	0:04	MAIN SUPPLY FAILURE
686	13-Jan-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	10:11	10:22	0:10	LINE FAULT

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
687	13-Jan-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	17:15	21:37	4:21	LINE FAULT
688	13-Jan-19	TUMKUR	66	TR-1	KORA_66	11:58	12:02	0:04	TRANSFORMER FAULT
689	13-Jan-19	TUMKUR	66	TR-1	LINGDHALLI_66	17:15	21:05	3:50	LINE CLEAR AVAILED
690	13-Jan-19	TUMKUR	66	TR-1	MALLASANDRA_66	2:05	2:13	0:07	TRANSFORMER FAULT
691	13-Jan-19	TUMKUR	66	TR-1	MAVINAKATTE_66	9:31	9:34	0:02	TRANSFORMER FAULT
692	13-Jan-19	TUMKUR	66	SAVALANGA 66kv-HNLI220_NYMT	SAVALANGA_66	10:44	17:47	7:03	LINE CLEAR AVAILED
693	13-Jan-19	TUMKUR	66	TR-1	SAVALANGA_66	10:44	17:48	7:03	LINE CLEAR AVAILED
694	14-Jan-19	BAGALKOT	110	BAGALKOT220-NAVANAGAR1	NAVANAGAR_110	0:00	12:49	12:49	HAND TRIPPED
695	14-Jan-19	BAGALKOT	110	110/11KV, HV1	JAMBAGI_110	15:51	15:58	0:07	TRANSFORMER FAULT
696	14-Jan-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	0:00	10:33	10:33	LINE CLEAR AVAILED
697	14-Jan-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	13:44	14:04	0:20	LINE CLEAR AVAILED
698	14-Jan-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	5:48	6:00	0:11	LINE FAULT
699	14-Jan-19	BANGALORE	66	HV1	LAKKUR	6:53	7:01	0:07	TRANSFORMER FAULT
700	14-Jan-19	BANGALORE	66	HV1	DEVANAHALLI	15:44	15:55	0:10	TRANSFORMER FAULT
701	14-Jan-19	BANGALORE	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	18:56	19:04	0:08	LINE CLEAR AVAILED
702	14-Jan-19	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	12:04	17:54	5:50	LINE CLEAR AVAILED
703	14-Jan-19	BANGALORE	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	13:14	14:50	1:36	LINE CLEAR AVAILED
704	14-Jan-19	BANGALORE	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	13:14	13:42	0:28	MAIN SUPPLY FAILURE
705	14-Jan-19	BANGALORE	66	KENGERI SATELLITE TOWN - KUMBALGODU	SIR MV LAYOUT, KENGERI SATELLITE TOWN	18:50	19:00	0:10	LOAD CHANGEOVER
706	14-Jan-19	BANGALORE	66	HV2	NRS 220	12:09	12:14	0:05	LOAD CHANGEOVER
707	14-Jan-19	BANGALORE	66	HV2	NRS 220	13:18	13:23	0:05	LOAD CHANGEOVER
708	14-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	9:15	9:40	0:25	LINE FAULT
709	14-Jan-19	BANGALORE	66	AREHALLI - BANASHANKARI	AREHALLI	14:23	14:25	0:02	LOAD CHANGEOVER
710	14-Jan-19	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	23:20	23:25	0:05	LOAD CHANGEOVER
711	14-Jan-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	7:40	7:58	0:18	LINE FAULT
712	14-Jan-19	BANGALORE	66	HV1	KANAKAPURA 66	11:28	11:35	0:06	LINE CLEAR AVAILED
713	14-Jan-19	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	6:45	7:07	0:22	LINE FAULT
714	14-Jan-19	GULBARGA	110	HV2	BETAGERA_110	8:15	8:43	0:28	LINE CLEAR AVAILED

Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
715	14-Jan-19	GULBARGA	110	HV1	GULUNI_110	11:40	12:41	1:01	LINE CLEAR AVAILED
716	14-Jan-19	GULBARGA	110	HV3	GULUNI_110	12:05	12:15	0:10	LINE CLEAR AVAILED
717	14-Jan-19	GULBARGA	110	HV2	HANUMASAGAR_110	10:15	11:20	1:05	LINE CLEAR AVAILED
718	14-Jan-19	GULBARGA	110	HV1	HANUMASAGAR_110	16:15	16:30	0:15	TRANSFORMER FAULT
719	14-Jan-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110,B TPS WATER WORK	4:10	4:17	0:07	LINE FAULT
720	14-Jan-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110,B TPS WATER WORK	12:35	13:05	0:30	LINE CLEAR AVAILED
721	14-Jan-19	GULBARGA	110	SINDHANOOR-MUNIRABAD1	GANGAVATHI_110,KARTAGI_110,SR ERAMANAGAR_110,VENKATAGIRI_1 10	12:54	13:05	0:11	LINE CLEAR AVAILED
722	14-Jan-19	GULBARGA	110	HV1,HV2	LINGASUGUR_220	13:37	13:45	0:08	TRANSFORMER FAULT
723	14-Jan-19	GULBARGA	110	HV2	DEODURGA_110	12:34	18:50	6:16	LINE CLEAR AVAILED
724	14-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:19	19:17	11:58	LINE CLEAR AVAILED
725	14-Jan-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	19:49	20:18	0:29	NFBC ISSUED
726	14-Jan-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	19:21	20:02	0:41	LINE FAULT
727	14-Jan-19	HASSAN	66	BELUR-MUDIGERE	BELUR_66	18:17	18:31	0:14	LINE CLEAR AVAILED
728	14-Jan-19	HASSAN	66	GENDEGA-HASSAN	GENDEHALLI_66	18:19	18:32	0:13	LINE CLEAR AVAILED
729	14-Jan-19	HASSAN	66	HV1	HARIHARAPURA_66	14:54	15:35	0:41	LINE CLEAR AVAILED
730	14-Jan-19	HASSAN	66	HARIHARA-KADUVINKOTE	HARIHARAPURA_66	14:54	15:35	0:41	LINE CLEAR AVAILED
731	14-Jan-19	HASSAN	66	HV2	HASSAN_66	11:34	11:55	0:21	LINE CLEAR AVAILED
732	14-Jan-19	HASSAN	66	MRSSHM-DVG2	MRS MG_220	14:53	15:55	1:02	LINE FAULT
733	14-Jan-19	HASSAN	66	HV2	SBELAGOLA_66	15:35	18:07	2:32	LINE CLEAR AVAILED
734	14-Jan-19	HASSAN	66	HV2	SALAGAME_66	17:33	17:34	0:01	LOAD CURTAILMENT
735	14-Jan-19	HASSAN	66	SIGEBAGE-KDLGRE	SIGEBAGE_66	15:54	16:02	0:08	MAIN SUPPLY FAILURE
736	14-Jan-19	MYSORE	66	HV1	DODDINADUVADI_66	14:20	14:22	0:01	TRANSFORMER FAULT
737	14-Jan-19	MYSORE	66	HV2	DODDINADUVADI_66	12:30	13:50	1:20	LINE CLEAR AVAILED
738	14-Jan-19	MYSORE	66	HV1	MEGALAPURA_66	16:11	16:16	0:04	HAND TRIPPED
739	14-Jan-19	MYSORE	66	MYSORE SOUTH-KADAKOLA	MYSORESOUTH_66	13:39	13:47	0:08	HAND TRIPPED
740	14-Jan-19	MYSORE	66	HV1	PANDAVAPURA_66	11:02	12:06	1:04	LINE CLEAR AVAILED
741	14-Jan-19	MYSORE	66	HV2	SATHEGALA_66	11:23	12:42	1:18	LINE CLEAR AVAILED
742	14-Jan-19	MYSORE	66	TUBINAKERE-MANDYA 2	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 MANDYA_66 MALAVALLI_66 & HADLI_66	11:40	11:48	0:08	HAND TRIPPED



Sl.No	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
743	14-Jan-19	MYSORE	66	TUBINAKERE-MANDYA 4	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 MANDYA_66 MALAVALLI_66 & HADLI_66	11:40	11:49	0:09	HAND TRIPPED
744	14-Jan-19	MYSORE	66	HV1	VIRAJPETE	23:18	23:40	0:22	TRANSFORMER FAULT
745	14-Jan-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	4:02	4:29	0:27	LINE FAULT
746	14-Jan-19	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETTYKERE_110	4:02	4:22	0:20	LINE FAULT
747	14-Jan-19	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	4:02	4:15	0:12	LINE FAULT
748	14-Jan-19	TUMKUR	110	TR-1(HV SIDE)	KBCROSS_220	13:02	14:02	1:00	HAND TRIPPED
749	14-Jan-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	15:38	17:20	1:42	LINE CLEAR AVAILED
750	14-Jan-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:41	8:43	0:01	TRANSFORMER FAULT
751	14-Jan-19	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	18:23	18:30	0:07	LINE FAULT
752	14-Jan-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	18:19	18:22	0:02	LINE CLEAR AVAILED
753	14-Jan-19	TUMKUR	66	TR-1	KORA_66	11:06	11:08	0:02	TRANSFORMER FAULT
754	14-Jan-19	TUMKUR	66	TR-1	MADHUGIRI_66	13:02	13:09	0:07	TRANSFORMER FAULT
755	14-Jan-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	13:41	13:56	0:14	MAIN SUPPLY FAILURE
756	14-Jan-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	16:15	17:20	1:04	MAIN SUPPLY FAILURE
757	14-Jan-19	TUMKUR	66	TR-2	TAVAREKERE(C)_66	16:52	17:20	0:28	MAIN SUPPLY FAILURE