

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 12.11.2019 TO 18.11.2019**

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	12-Nov-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	11:50	20:48	8:58	LINE CLEAR AVAILED
2	12-Nov-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	20:53	23:59	3:06	LINE CLEAR AVAILED
3	12-Nov-19	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	11:49	12:18	0:29	LINE CLEAR AVAILED
4	12-Nov-19	BAGALKOT	110	ITANAL-HIDIKAL	HIDIKAL_110	17:46	18:13	0:27	HAND TRIPPED
5	12-Nov-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	12:29	23:59	11:30	LINE CLEAR AVAILED
6	12-Nov-19	BAGALKOT	110	ITANAL-HIDIKAL	HIDIKAL_110	12:07	16:23	4:16	LINE CLEAR AVAILED
7	12-Nov-19	BAGALKOT	220	GHATAPRABHA-KUDACHI	GHATAPRABHA_220	10:47	17:08	6:21	LINE CLEAR AVAILED
8	12-Nov-19	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	14:40	16:30	1:50	LINE CLEAR AVAILED
9	12-Nov-19	BAGALKOT	110	KARWAR220-BINAGA	BINAGA(EHT)_110	0:00	1:15	1:15	LINE CLEAR AVAILED
10	12-Nov-19	BAGALKOT	110	110/33KV,HV4	ZALAKI_110,HALASANGI_33,NEVARG I_33,DHULKHED_33	10:02	10:09	0:07	TRANSFORMER FAULT
11	12-Nov-19	BAGALKOT	110	110/33KV,HV3	ZALAKI_110,HORTI_33	17:56	18:03	0:07	LINE CLEAR AVAILED
12	12-Nov-19	BAGALKOT	110	110/11KV,HV1	YELPHARATTI_110	9:23	13:04	3:41	LINE CLEAR AVAILED
13	12-Nov-19	BAGALKOT	110	110/11KV,HV2	YELPHARATTI_110	12:55	16:47	3:52	LINE CLEAR AVAILED
14	12-Nov-19	BAGALKOT	220	220/110KV,HV1	SIRSI_220	10:19	12:43	2:24	LINE CLEAR AVAILED
15	12-Nov-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	9:52	9:59	0:07	HAND TRIPPED
16	12-Nov-19	BENGALURU	66	HV2	BANASWADI	12:57	14:33	1:36	LINE CLEAR AVAILED
17	12-Nov-19	BENGALURU	66	ITI - HOODY 220	ITI	23:30	23:59	0:29	MAIN SUPPLY FAILURE
18	12-Nov-19	BENGALURU	66	HV2	TK HALLI 220	9:15	10:07	0:52	LINE CLEAR AVAILED
19	12-Nov-19	BENGALURU	66	HV1	KYALANNUR	1:20	1:30	0:10	TRANSFORMER FAULT
20	12-Nov-19	GULBARGA	110	ALIPUR-PDHALLI	PDHALLI_110	4:53	5:40	0:47	MAIN SUPPLY FAILURE
21	12-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	15:51	15:51	LINE FAULT
22	12-Nov-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:52	11:34	0:42	LINE CLEAR AVAILED
23	12-Nov-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:51	11:35	0:44	NFBC ISSUED
24	12-Nov-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:58	12:11	0:13	LINE CLEAR AVAILED
25	12-Nov-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	17:36	17:52	0:16	LINE CLEAR AVAILED
26	12-Nov-19	HASSAN	110	HV1	ANAVATTI_110	11:54	13:24	1:30	LINE CLEAR AVAILED
27	12-Nov-19	HASSAN	110	HV1	ANAVATTI_110	17:37	17:51	0:14	LINE CLEAR AVAILED
28	12-Nov-19	HASSAN	110	HV2	ANAVATTI_110	11:54	13:24	1:30	LINE CLEAR AVAILED
29	12-Nov-19	HASSAN	110	HV2	ANAVATTI_110	17:37	17:51	0:14	LINE CLEAR AVAILED
30	12-Nov-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	11:58	13:02	1:04	LINE CLEAR AVAILED
31	12-Nov-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	17:37	18:08	0:31	LINE CLEAR AVAILED
32	12-Nov-19	HASSAN	110	HV1	BAIKAMPADI_110	11:29	13:33	2:04	LINE CLEAR AVAILED
33	12-Nov-19	HASSAN	110	HV2	BRAHMAVARA_110	13:36	15:59	2:23	LINE CLEAR AVAILED
34	12-Nov-19	HASSAN	110	HV2	KEMAR_220	11:36	14:27	2:51	LINE CLEAR AVAILED
35	12-Nov-19	HASSAN	110	LV2	KEMAR_220	11:36	14:27	2:51	LINE CLEAR AVAILED
36	12-Nov-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	15:29	16:06	0:37	LINE CLEAR AVAILED
37	12-Nov-19	HASSAN	110	HV1	PUTTUR_110	10:19	17:17	6:58	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
38	12-Nov-19	HASSAN	110	HV2	PUTTUR_110	10:19	17:17	6:58	LINE CLEAR AVAILED
39	12-Nov-19	HASSAN	66	CHANNARA-UDAYAPURA	CRPATNA_220	12:37	12:47	0:10	LINE CLEAR AVAILED
40	12-Nov-19	HASSAN	66	CHANNARA-UDAYAPURA	CRPATNA_220	13:30	13:42	0:12	LINE CLEAR AVAILED
41	12-Nov-19	HASSAN	66	HV1	DUDDA_66	11:00	14:55	3:55	LINE CLEAR AVAILED
42	12-Nov-19	HASSAN	66	HV1	HAGARE_66	12:47	13:12	0:25	LINE CLEAR AVAILED
43	12-Nov-19	HASSAN	66	HV1	HOLALUR_66	10:26	13:41	3:15	LINE CLEAR AVAILED
44	12-Nov-19	HASSAN	66	HV2	HOLALUR_66	10:27	13:41	3:14	LINE CLEAR AVAILED
45	12-Nov-19	HASSAN	66	HV2	HOLEHONNUR_66	12:20	13:35	1:15	MAIN SUPPLY FAILURE
46	12-Nov-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	6:50	6:58	0:08	LINE FAULT
47	12-Nov-19	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	16:15	16:22	0:07	LINE CLEAR AVAILED
48	12-Nov-19	MYSORE	66	CHUNCHUNKATTE-KR NAGARA	BHERYA_66, BILIKERE_66, DMG_HALLI_66, GVGUDI_66, KRNAGARA_66.	12:55	13:12	0:17	LINE FAULT
49	12-Nov-19	MYSORE	66	CR NAGARA-YELANDUR	YELANDUR_66	18:03	18:08	0:05	LINE FAULT
50	12-Nov-19	MYSORE	66	HV1	HEBBAL_66	9:40	15:38	5:57	LINE CLEAR AVAILED
51	12-Nov-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	5:51	5:55	0:03	LINE FAULT
52	12-Nov-19	MYSORE	66	HV2	KRPET_66	12:14	12:31	0:17	LINE CLEAR AVAILED
53	12-Nov-19	MYSORE	66	HV3	KRPET_66	12:33	12:47	0:13	LINE CLEAR AVAILED
54	12-Nov-19	MYSORE	66	KUSHALANAGAR 220-MYSORE 1	MIRLE_66	12:56	13:06	0:10	LINE FAULT
55	12-Nov-19	TUMKUR	400	GUTTUR 400KV- KAIGA2	GUTUR_400	8:06	9:47	1:40	LINE CLEAR AVAILED
56	12-Nov-19	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	12:49	18:08	5:18	LINE FAULT
57	12-Nov-19	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	12:50	12:51	0:01	LINE FAULT
58	12-Nov-19	TUMKUR	220	NEELAGUNDA- GUTTUR	NEELAGUNDA_220	15:05	18:03	2:58	LINE CLEAR AVAILED
59	12-Nov-19	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	14:36	17:15	2:38	LINE CLEAR AVAILED
60	12-Nov-19	TUMKUR	220	TR-2(HV SIDE)	NEELAGUNDA_220	12:50	13:45	0:54	TRANSFORMER FAULT
61	12-Nov-19	TUMKUR	110	TR-1	BANDIHALLI_110	15:21	15:38	0:17	LINE CLEAR AVAILED
62	12-Nov-19	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	14:36	17:16	2:39	LINE CLEAR AVAILED
63	12-Nov-19	TUMKUR	66	BENNEHALLI-KOTTUR	BENNEHALLI_66	3:46	3:56	0:10	LINE FAULT
64	12-Nov-19	TUMKUR	66	TR-2	BENKIKERE_66	14:08	14:14	0:05	LINE CLEAR AVAILED
65	12-Nov-19	TUMKUR	66	CHAWDANKUPPE-ESENGY_SLR	ESENGY_SLR	13:18	14:21	1:03	LINE CLEAR AVAILED
66	12-Nov-19	TUMKUR	66	NEELAGUNDA 220kv-HARAPPANAHALLI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	13:01	13:46	0:44	HAND TRIPPED
67	12-Nov-19	TUMKUR	66	NEELAGUNDA 220kv-HULUVAGALU	HALUVAGALU_66	13:01	13:46	0:45	HAND TRIPPED
68	12-Nov-19	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAPPANAH ALLI_66,HALUVAGALU_66,TELAGI_6 6	13:01	13:46	0:44	HAND TRIPPED
69	12-Nov-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	18:18	18:23	0:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
70	12-Nov-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	18:18	18:23	0:04	LINE FAULT
71	12-Nov-19	TUMKUR	66	TR-2	NEELAGUNDA_220	12:50	13:50	0:59	MAIN SUPPLY FAILURE
72	13-Nov-19	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	21:29	23:59	2:30	LINE CLEAR AVAILED
73	13-Nov-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	0:00	13:04	13:04	LINE CLEAR AVAILED
74	13-Nov-19	BAGALKOT	110	110/33KV, HV1	KUMATA_110, HONNAVAR_33, ANKOLA_33	12:08	13:08	1:00	LINE CLEAR AVAILED
75	13-Nov-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	0:00	11:35	11:35	LINE CLEAR AVAILED
76	13-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	11:37	23:59	12:22	LINE CLEAR AVAILED
77	13-Nov-19	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	13:35	15:17	1:42	LINE CLEAR AVAILED
78	13-Nov-19	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	13:36	15:17	1:41	LINE CLEAR AVAILED
79	13-Nov-19	BAGALKOT	220	HARTI2-BIDNAL	BIDNAL_220	13:48	23:59	10:11	LINE CLEAR AVAILED
80	13-Nov-19	BENGALURU	66	HV1	RR NAGAR	11:40	11:55	0:15	TRANSFORMER FAULT
81	13-Nov-19	BENGALURU	66	HV2	RR NAGAR	12:40	14:00	1:20	TRANSFORMER FAULT
82	13-Nov-19	BENGALURU	66	HV1	HEBBAL 66	6:55	12:30	5:35	TRANSFORMER FAULT
83	13-Nov-19	BENGALURU	66	HV2	BANASWADI	4:15	4:27	0:12	LINE CLEAR AVAILED
84	13-Nov-19	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	9:05	17:52	8:47:00	NFBC ISSUED
85	13-Nov-19	HASSAN	110	HV1	KADUR_220	10:56	11:56	1:00	LINE CLEAR AVAILED
86	13-Nov-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	10:58	12:58	2:00:00	LINE CLEAR AVAILED
87	13-Nov-19	HASSAN	110	HV1	KARAYA_110	13:30	14:18	0:48	LINE CLEAR AVAILED
88	13-Nov-19	HASSAN	110	HV2	KARAYA_110	11:56	14:18	2:22:00	LINE CLEAR AVAILED
89	13-Nov-19	HASSAN	110	KARAYA-PUTTUR	KARAYA_110	13:30	14:18	0:48	LINE CLEAR AVAILED
90	13-Nov-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	9:40	18:13	8:33:00	NFBC ISSUED
91	13-Nov-19	HASSAN	110	HV1	KONAJE_110	10:01	17:11	7:10:00	LINE CLEAR AVAILED
92	13-Nov-19	HASSAN	110	HV2	KONAJE_110	10:01	17:36	7:35:00	LINE CLEAR AVAILED
93	13-Nov-19	HASSAN	110	HV3	KONAJE_110	10:01	17:10	7:09:00	LINE CLEAR AVAILED
94	13-Nov-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	10:41	15:57	5:16:00	LINE CLEAR AVAILED
95	13-Nov-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	10:41	15:57	5:16:00	NFBC ISSUED
96	13-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:22	23:59	2:37	LINE CLEAR AVAILED
97	13-Nov-19	MYSORE	66	HV1	DATTAGALLY_66	12:39	12:45	0:06	TRANSFORMER FAULT
98	13-Nov-19	MYSORE	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66, KOPPA_66	11:30	11:39	0:09	LINE FAULT
99	13-Nov-19	MYSORE	66	HV1	HANAGODU_66	12:54	15:31	2:37	LINE CLEAR AVAILED
100	13-Nov-19	MYSORE	66	HV2	HANAGODU_66	12:54	14:28	1:33	LINE CLEAR AVAILED
101	13-Nov-19	MYSORE	66	HUNSUR-HOOTAGALLY	HOSURGATE_66	10:40	12:55	2:14	NFBC ISSUED
102	13-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	6:45	6:51	0:05	LINE FAULT
103	13-Nov-19	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	11:04	15:25	4:21	LINE CLEAR AVAILED
104	13-Nov-19	MYSORE	66	HV1	KIKKERI_66	11:48	13:03	1:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
105	13-Nov-19	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	6:17	6:25	0:07	LINE FAULT
106	13-Nov-19	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	10:56	11:00	0:04	LINE FAULT
107	13-Nov-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	12:03	13:53	1:50	LINE CLEAR AVAILED
108	13-Nov-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	13:56	14:37	0:41	LINE CLEAR AVAILED
109	13-Nov-19	MYSORE	66	HV1	RAMAPURA_MYS_66	14:10	15:59	1:49	LINE CLEAR AVAILED
110	13-Nov-19	MYSORE	66	HV2	RAMAPURA_MYS_66	14:10	14:30	0:20	LINE CLEAR AVAILED
111	13-Nov-19	MYSORE	66	HV1	SATHEGALA_66	11:50	13:30	1:40	LINE CLEAR AVAILED
112	13-Nov-19	MYSORE	66	HV2	SATHEGALA_66	10:15	12:50	2:35	LINE CLEAR AVAILED
113	13-Nov-19	MYSORE	66	HV1	SANTHEBACHALLI_66	15:03	18:43	3:39	LINE CLEAR AVAILED
114	13-Nov-19	MYSORE	66	HV2	SANTHEBACHALLI_66	15:03	18:43	3:39	LINE CLEAR AVAILED
115	13-Nov-19	TUMKUR	110	TR-1	KADABA_110	12:02	14:30	2:27	LINE CLEAR AVAILED
116	13-Nov-19	TUMKUR	110	TR-1	KGTEMPLE_110	16:08	19:10	3:02	LINE CLEAR AVAILED
117	13-Nov-19	TUMKUR	110	K G TEMPLE-KALLUR	KGTEMPLE_110	16:06	16:42	0:36	LINE CLEAR AVAILED
118	13-Nov-19	TUMKUR	110	K G TEMPLE-NITTUR220	KGTEMPLE_110	16:07	19:10	3:02	LINE CLEAR AVAILED
119	13-Nov-19	TUMKUR	110	K G TEMPLE-UNGRDLI	KGTEMPLE_110	16:11	19:11	3:00	LINE CLEAR AVAILED
120	13-Nov-19	TUMKUR	110	TR-1	NITTUR_220	14:52	17:44	2:51	TRANSFORMER FAULT
121	13-Nov-19	TUMKUR	110	TR-1	NITTUR_220	17:56	19:56	1:59	TRANSFORMER FAULT
122	13-Nov-19	TUMKUR	110	TR-1	SAMPIGE_110	13:34	13:40	0:06	HAND TRIPPED
123	13-Nov-19	TUMKUR	110	TR-1	SAMPIGE_110	14:00	14:06	0:06	HAND TRIPPED
124	13-Nov-19	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	12:18	12:49	0:31	MAIN SUPPLY FAILURE
125	13-Nov-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	20:23	20:46	0:23	LINE FAULT
126	13-Nov-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	18:11	18:44	0:33	LINE FAULT
127	13-Nov-19	TUMKUR	66	TR-2	HONNALLI_220	14:28	15:36	1:08	LINE CLEAR AVAILED
128	13-Nov-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	17:53	17:59	0:06	LINE FAULT
129	13-Nov-19	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	16:19	17:27	1:07	LINE CLEAR AVAILED
130	13-Nov-19	TUMKUR	66	TR-1	KORA_66	11:59	12:13	0:14	LINE CLEAR AVAILED
131	13-Nov-19	TUMKUR	66	MELKOTE-ANTHRASANAHALLI	MELKOTE_66	12:04	12:32	0:27	LINE CLEAR AVAILED
132	13-Nov-19	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	12:04	12:37	0:33	LINE CLEAR AVAILED
133	14-Nov-19	BAGALKOT	110	110/33KV,HV3	ANKALI_110,NADIKUROLI_33	13:50	14:21	0:31	LINE CLEAR AVAILED
134	14-Nov-19	BAGALKOT	110	220/110KV,LV1	ATHANI_220	11:04	12:43	1:39	LINE CLEAR AVAILED
135	14-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	0:00	17:18	17:18	LINE CLEAR AVAILED
136	14-Nov-19	BAGALKOT	220	HARTI2-BIDNAL	BIDNAL_220	0:00	14:27	14:27	LINE CLEAR AVAILED
137	14-Nov-19	BAGALKOT	110	ENERCON-BELLATTI	BELLATTI_110	15:11	16:01	0:50	LINE CLEAR AVAILED
138	14-Nov-19	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	10:24	16:27	6:03	LINE CLEAR AVAILED
139	14-Nov-19	BAGALKOT	110	110/33KV,HV4	MACHE_110	11:32	12:21	0:49	LINE CLEAR AVAILED
140	14-Nov-19	BAGALKOT	110	110/33KV,HV3	MACHE_110	12:22	12:52	0:30	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
141	14-Nov-19	BAGALKOT	110	110/33KV,HV3	UGAR KHUD_110,SEDABAL_33,MANGASULI_33	9:55	17:07	7:12	LINE CLEAR AVAILED
142	14-Nov-19	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	4:48	23:59	19:11	LINE FAULT
143	14-Nov-19	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR	VAJRAMATTI_220	10:17	14:28	4:11	LINE CLEAR AVAILED
144	14-Nov-19	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	10:00	13:38	3:38	LINE CLEAR AVAILED
145	14-Nov-19	BAGALKOT	220	BAGEWADI-BIJAPUR1	BAGEWADI_220	17:47	18:11	0:24	LINE FAULT
146	14-Nov-19	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	9:30	17:08	7:38	LINE CLEAR AVAILED
147	14-Nov-19	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	13:19	15:35	2:16	LINE CLEAR AVAILED
148	14-Nov-19	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS	VICATASAGAR CEMENTS_IPP	2:18	2:23	0:05	LINE FAULT
149	14-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	3:43	11:02	7:19	LINE CLEAR AVAILED
150	14-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:51	23:59	0:08	HAND TRIPPED
151	14-Nov-19	HASSAN	220	TALAGU-ST3	TALAGUPPA_400	12:56	15:26	2:30	LINE FAULT
152	14-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:11	6:11	LINE CLEAR AVAILED
153	14-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:43	23:59	1:16	LINE CLEAR AVAILED
154	14-Nov-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	10:42	13:28	2:46	LINE CLEAR AVAILED
155	14-Nov-19	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	13:34	16:19	2:45	LINE FAULT
156	14-Nov-19	HASSAN	110	HV1	KAVOOR_220	9:28	23:59	14:31	LINE CLEAR AVAILED
157	14-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	22:42	23:59	1:17	LINE CLEAR AVAILED
158	14-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	12:53	13:18	0:25	LINE FAULT
159	14-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	22:40	23:59	1:19	LINE CLEAR AVAILED
160	14-Nov-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	10:41	13:28	2:47	NFBC ISSUED
161	14-Nov-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:20	17:17	1:57	LINE CLEAR AVAILED
162	14-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	12:52	13:18	0:26	HAND TRIPPED
163	14-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	22:41	23:59	1:18	LINE CLEAR AVAILED
164	14-Nov-19	HASSAN	220	SHRAVITY-ST3	sharavathy_gen	12:57	16:26	3:29	LINE CLEAR AVAILED
165	14-Nov-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:21	17:17	1:56	NFBC ISSUED
166	14-Nov-19	HASSAN	110	HV1	PUTTUR_110	10:18	16:32	6:14	LINE CLEAR AVAILED
167	14-Nov-19	HASSAN	110	HV2	PUTTUR_110	10:18	16:31	6:13	LINE CLEAR AVAILED
168	14-Nov-19	HASSAN	110	HV1	HALADY_110	12:41	15:05	2:24	LINE CLEAR AVAILED
169	14-Nov-19	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:06	17:26	5:20	LINE CLEAR AVAILED
170	14-Nov-19	HASSAN	66	HV1	DUDDA_66	11:26	13:38	2:12	LINE CLEAR AVAILED
171	14-Nov-19	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	15:12	16:26	1:14	LINE CLEAR AVAILED
172	14-Nov-19	MYSORE	66	GUNDLUPETE-CR NAGARA	TERAKANAMBE_66	11:08	15:20	4:11	NFBC ISSUED
173	14-Nov-19	MYSORE	66	HV1	KIKKERI_66	10:36	12:58	2:21	LINE CLEAR AVAILED
174	14-Nov-19	MYSORE	66	HV2	KIKKERI_66	10:57	12:45	1:48	LINE CLEAR AVAILED
175	14-Nov-19	MYSORE	66	HV3	KIKKERI_66	12:27	14:44	2:17	LINE CLEAR AVAILED
176	14-Nov-19	MYSORE	66	HV2	KRPET_66	13:28	13:54	0:26	LINE CLEAR AVAILED
177	14-Nov-19	MYSORE	66	HV3	KRPET_66	17:41	18:04	0:22	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
178	14-Nov-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	9:29	9:40	0:11	LINE FAULT
179	14-Nov-19	MYSORE	220	HV1	TUBINAKERE_220	14:46	17:21	2:34	LINE CLEAR AVAILED
180	14-Nov-19	MYSORE	66	HV1	TNARASIPURA_66	10:05	16:46	6:41	LINE CLEAR AVAILED
181	14-Nov-19	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	12:29	12:57	0:28	LINE CLEAR AVAILED
182	14-Nov-19	TUMKUR	110	TR-1	GUBBI_110	12:04	14:56	2:51	LINE CLEAR AVAILED
183	14-Nov-19	TUMKUR	110	TR-2	GUBBI_110	12:04	14:56	2:51	LINE CLEAR AVAILED
184	14-Nov-19	TUMKUR	110	TR-1	KADABA_110	12:42	12:57	0:15	LINE CLEAR AVAILED
185	14-Nov-19	TUMKUR	110	TR-2	SAMPIGE_110	14:12	14:21	0:08	LINE CLEAR AVAILED
186	14-Nov-19	TUMKUR	66	BANUVALLI- HONNALLI	NANDIGUDI_66,MALEBENNUR_66	14:32	14:38	0:06	MAIN SUPPLY FAILURE
187	14-Nov-19	TUMKUR	66	TR-1& TR-2	HONNALLI_220	14:19	14:35	0:16	LINE CLEAR AVAILED
188	14-Nov-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:18	14:35	0:16	LINE CLEAR AVAILED
189	14-Nov-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:15	14:39	0:24	LINE CLEAR AVAILED
190	14-Nov-19	TUMKUR	66	TR-2(LV SIDE)	HONNALLI_220	13:52	16:30	2:37	LINE CLEAR AVAILED
191	14-Nov-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	14:19	14:35	0:16	LINE CLEAR AVAILED
192	14-Nov-19	TUMKUR	66	NITRAHALLI 66 -CLEAN SOLAR	CLEANMAXSOLAR_IPP_66	15:56	17:01	1:04	LINE FAULT
193	14-Nov-19	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	17:46	18:43	0:56	LINE FAULT
194	14-Nov-19	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:36	18:09	0:33	LINE FAULT
195	14-Nov-19	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	18:43	18:49	0:06	LINE FAULT
196	15-Nov-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	10:45	11:21	0:36	LINE FAULT
197	15-Nov-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	10:01	23:59	13:58	LINE CLEAR AVAILED
198	15-Nov-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	10:09	15:11	5:02	LINE CLEAR AVAILED
199	15-Nov-19	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	6:28	6:51	0:23	LINE FAULT
200	15-Nov-19	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINGAD_33,MYTR A SOLAR_33,KARADI_33	8:02	8:09	0:07	TRANSFORMER FAULT
201	15-Nov-19	BAGALKOT	110	110/11KV,HV1	KAGAWADA_110	10:22	13:20	2:58	LINE CLEAR AVAILED
202	15-Nov-19	BAGALKOT	110	110/11KV,HV2	KAGAWADA_110	13:10	17:05	3:55	LINE CLEAR AVAILED
203	15-Nov-19	BAGALKOT	110	220/110KV,LV1	MK HUBLI_220	2:58	6:38	3:40	LINE CLEAR AVAILED
204	15-Nov-19	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	2:57	7:44	4:47	LINE CLEAR AVAILED
205	15-Nov-19	BAGALKOT	220	220/110KV,HV2	NARENDRA_220	12:44	14:56	2:12	LINE CLEAR AVAILED
206	15-Nov-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	10:48	13:01	2:13	LINE CLEAR AVAILED
207	15-Nov-19	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	12:15	13:05	0:50	LINE CLEAR AVAILED
208	15-Nov-19	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	12:20	13:10	0:50	LINE CLEAR AVAILED
209	15-Nov-19	GULBARGA	220	SEDAM-CLEAN MAX SOLAR	SEDAM_220	12:25	13:15	0:50	LINE CLEAR AVAILED
210	15-Nov-19	GULBARGA	220	HV1	SEDAM_220	12:10	23:59	11:49	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
211	15-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	9:34	9:34	LINE CLEAR AVAILED
212	15-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:18	23:59	0:41	HAND TRIPPED
213	15-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:32	7:32	LINE CLEAR AVAILED
214	15-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:47	23:59	1:12	LINE CLEAR AVAILED
215	15-Nov-19	HASSAN	220	HV3	KAVOOR_220	17:37	23:59	6:22	TRANSFORMER FAULT
216	15-Nov-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	17:37	18:02	0:25	LINE FAULT
217	15-Nov-19	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	17:53	18:08	0:15	LINE FAULT
218	15-Nov-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	17:53	18:09	0:16	LINE FAULT
219	15-Nov-19	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	13:33	23:59	10:26	LINE FAULT
220	15-Nov-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	17:37	18:09	0:32	LINE FAULT
221	15-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	0:00	7:28	7:28	LINE CLEAR AVAILED
222	15-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	17:38	18:03	0:25	LINE FAULT
223	15-Nov-19	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	22:53	23:59	1:06	LINE CLEAR AVAILED
224	15-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	0:00	7:29	7:29	LINE CLEAR AVAILED
225	15-Nov-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	22:55	23:59	1:04	LINE CLEAR AVAILED
226	15-Nov-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:40	17:09	0:29	LINE FAULT
227	15-Nov-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:40	17:07	0:27	LINE FAULT
228	15-Nov-19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	16:11	17:05	0:54	LINE FAULT
229	15-Nov-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	16:11	17:06	0:55	LINE FAULT
230	15-Nov-19	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	8:55	13:42	4:47	LINE CLEAR AVAILED
231	15-Nov-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	12:55	14:07	1:12	LINE FAULT
232	15-Nov-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	17:37	18:09	0:32	LINE FAULT
233	15-Nov-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	17:37	18:08	0:31	LINE FAULT
234	15-Nov-19	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	22:54	23:59	1:05	LINE CLEAR AVAILED
235	15-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	0:00	7:30	7:30	LINE CLEAR AVAILED
236	15-Nov-19	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	22:55	23:59	1:04	LINE CLEAR AVAILED
237	15-Nov-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	10:48	13:01	2:13	LINE CLEAR AVAILED
238	15-Nov-19	HASSAN	220	VARAHI-SHMG3	varahi_gen	12:54	14:07	1:13	LINE FAULT
239	15-Nov-19	HASSAN	110	HV1	BAIKAMPADI_110	17:35	18:10	0:35	MAIN SUPPLY FAILURE
240	15-Nov-19	HASSAN	110	HV2	BAIKAMPADI_110	17:35	18:10	0:35	MAIN SUPPLY FAILURE
241	15-Nov-19	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	12:55	13:03	0:08	LINE FAULT
242	15-Nov-19	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:36	18:58	0:22	LINE FAULT
243	15-Nov-19	HASSAN	110	HV2	KONAJE_110	16:37	17:49	1:12	LINE CLEAR AVAILED
244	15-Nov-19	HASSAN	110	KONAJEMANJESWARG	KONAJE_110	9:54	16:36	6:42	LINE CLEAR AVAILED
245	15-Nov-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	16:12	17:09	0:57	MAIN SUPPLY FAILURE
246	15-Nov-19	HASSAN	110	MAQNIPAL-KEMAR1	MANIPAL_110	16:11	17:05	0:54	LINE FAULT
247	15-Nov-19	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	16:11	17:05	0:54	LINE FAULT
248	15-Nov-19	HASSAN	110	SALATHUR-BNTWAL	SALATHUR_110	9:56	16:26	6:30	NFBC ISSUED
249	15-Nov-19	HASSAN	66	HASSN22-MALLALI	HASSAN_220	1:07	1:24	0:17	LINE FAULT
250	15-Nov-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	14:51	14:55	0:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
251	15-Nov-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:39	17:23	6:44	LINE CLEAR AVAILED
252	15-Nov-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66	13:36	13:42	0:06	LINE FAULT
253	15-Nov-19	MYSORE	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	7:38	7:45	0:06	LINE FAULT
254	15-Nov-19	MYSORE	66	KOPPA-BESAGARAHALLI	BESAGARAHALLI_66	7:20	7:38	0:18	LINE FAULT
255	15-Nov-19	MYSORE	66	HV1	SUNTIKOPPA_66	10:57	11:06	0:08	HAND TRIPPED
256	15-Nov-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	7:57	8:14	0:16	LINE FAULT
257	15-Nov-19	TUMKUR	220	TR-2(HV SIDE)	CHITRADURGA_220	0:17	1:02	0:45	TRANSFORMER FAULT
258	15-Nov-19	TUMKUR	110	TR-2	SAMPIGE_110	9:41	11:01	1:19	LINE CLEAR AVAILED
259	15-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	7:31	7:42	0:11	LINE FAULT
260	15-Nov-19	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	2:55	3:15	0:20	HAND TRIPPED
261	15-Nov-19	TUMKUR	66	TR-2(LV SIDE)	CHITRADURGA_220	0:17	1:03	0:46	TRANSFORMER FAULT
262	15-Nov-19	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	2:54	3:11	0:17	LINE FAULT
263	16-Nov-19	BAGALKOT	220	ALAMATTI2-BAGALKOT	BAGALKOT_220	9:33	9:51	0:18	HAND TRIPPED
264	16-Nov-19	BAGALKOT	220	ALAMATTI2-BAGALKOT	BAGALKOT_220	15:15	18:05	2:50	LINE CLEAR AVAILED
265	16-Nov-19	BAGALKOT	110	GADAG220-DAMBAL	DAMBAL_110	10:04	12:02	1:58	LINE CLEAR AVAILED
266	16-Nov-19	BAGALKOT	220	ALAMATTI2-BAGEWADI	BAGEWADI_220	12:45	13:20	0:35	HAND TRIPPED
267	16-Nov-19	BAGALKOT	110	110/11KV, HV1	ITANAL_110	14:25	14:30	0:05	HAND TRIPPED
268	16-Nov-19	BAGALKOT	110	110/11KV, HV2	ITANAL_110	9:05	9:10	0:05	HAND TRIPPED
269	16-Nov-19	BAGALKOT	220	220/110KV, HV1&LV1	NARENDRA_220	11:27	14:41	3:14	LINE CLEAR AVAILED
270	16-Nov-19	HASSAN	400	TALAGU	NELAMANGALA#2	0:00	10:04	10:04	LINE CLEAR AVAILED
271	16-Nov-19	HASSAN	400	TALAGU	NELAMANGALA#2	16:21	23:59	7:38	LINE CLEAR AVAILED
272	16-Nov-19	HASSAN	400	UPCL	HASSAN1	0:00	7:50	7:50	LINE CLEAR AVAILED
273	16-Nov-19	HASSAN	400	UPCL	HASSAN1	21:41	23:59	2:18	LINE CLEAR AVAILED
274	16-Nov-19	HASSAN	220	ARSK2	NITTUR	12:21	12:45	0:24	LINE CLEAR AVAILED
275	16-Nov-19	HASSAN	220	ARSK2	HV2	12:21	12:45	0:24	LINE CLEAR AVAILED
276	16-Nov-19	HASSAN	220	KAVOOR	HV3	0:00	17:01	17:01	LINE CLEAR AVAILED
277	16-Nov-19	HASSAN	220	KEMAR	Kavoor2	0:00	7:15	7:15	MAIN SUPPLY FAILURE
278	16-Nov-19	HASSAN	220	KEMAR	PUTUR2	0:00	7:17	7:17	MAIN SUPPLY FAILURE
279	16-Nov-19	HASSAN	220	MRSSHM	VARAHI2	11:15	14:16	3:01	LINE FAULT
280	16-Nov-19	HASSAN	220	MSEZ	HV1	15:29	16:49	1:20	LINE CLEAR AVAILED
281	16-Nov-19	HASSAN	220	MSEZ	KEMAR2	0:00	7:15	7:15	LINE CLEAR AVAILED
282	16-Nov-19	HASSAN	220	PUTTUR	KEMAR2	0:00	7:17	7:17	LINE CLEAR AVAILED
283	16-Nov-19	HASSAN	220	VARAHI	KEMAR1	19:30	23:59	4:29	LINE FAULT
284	16-Nov-19	HASSAN	220	VARAHI	KEMAR3	15:08	15:18	0:10	LINE FAULT
285	16-Nov-19	HASSAN	220	VARAHI	SHIMOGA2	11:15	14:35	3:20	LINE FAULT



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
286	16-Nov-19	HASSAN	110	ARSK2	ARSKR	12:21	13:18	0:57	LINE CLEAR AVAILED
287	16-Nov-19	HASSAN	110	ARSK2	BANAVARA	11:39	11:42	0:03	HAND TRIPPED
288	16-Nov-19	HASSAN	110	ARSK2	BANAVARA	12:21	13:15	0:54	LINE CLEAR AVAILED
289	16-Nov-19	HASSAN	110	KEMAR	Guruvykere2	11:46	13:41	1:55	LINE CLEAR AVAILED
290	16-Nov-19	HASSAN	110	KEMAR	LV1	15:46	16:18	0:32	LINE FAULT
291	16-Nov-19	HASSAN	110	KEMAR	Manipal2	15:46	16:21	0:35	LINE FAULT
292	16-Nov-19	HASSAN	110	KEMAR	NANDHIKUR1	15:46	16:23	0:37	LINE FAULT
293	16-Nov-19	HASSAN	110	KEMAR	NANDHIKUR2	15:46	16:23	0:37	LINE FAULT
294	16-Nov-19	HASSAN	110	MSEZ	LV1	15:27	16:50	1:23	LINE CLEAR AVAILED
295	16-Nov-19	HASSAN	110	PUTTUR	SULIA	16:09	16:55	0:46	LINE FAULT
296	16-Nov-19	HASSAN	110	BANTWA	HV3	9:52	16:17	6:25	LINE CLEAR AVAILED
297	16-Nov-19	HASSAN	110	GURUVA	KEMAR2	11:46	13:41	1:55	NFBC ISSUED
298	16-Nov-19	HASSAN	110	HIRIYA	MADHUVANA	16:13	16:18	0:05	MAIN SUPPLY FAILURE
299	16-Nov-19	HASSAN	110	KADUR	NERELEKERE	11:00	12:32	1:32	LINE CLEAR AVAILED
300	16-Nov-19	HASSAN	110	NERALA	HV2	11:00	13:01	2:01	MAIN SUPPLY FAILURE
301	16-Nov-19	HASSAN	66	MRSSHM	HOLUR	9:29	9:33	0:04	HAND TRIPPED
302	16-Nov-19	HASSAN	66	ALDUR	BALEHONNUR	8:25	8:59	0:34	LINE CLEAR AVAILED
303	16-Nov-19	HASSAN	66	CHIKMA	HV2	12:08	14:00	1:52	LINE CLEAR AVAILED
304	16-Nov-19	HASSAN	66	HASSN220	MALLALI	1:58	2:04	0:06	LINE FAULT
305	16-Nov-19	HASSAN	66	MAGGE	HV2	10:23	14:19	3:56	LINE CLEAR AVAILED
306	16-Nov-19	HASSAN	66	MOSALEH	HV1	12:40	12:59	0:19	LINE FAULT
307	16-Nov-19	HASSAN	66	SAKALE	HV1			0:00	LINE FAULT
308	16-Nov-19	HASSAN	66	SAKALE	HV1	7:10	7:20	0:10	LINE FAULT
309	16-Nov-19	HASSAN	66	SAKALE	IPCL1	14:55	17:06	2:11	LINE CLEAR AVAILED
310	16-Nov-19	HASSAN	66	SAKALE	IPCL2	14:55	16:35	1:40	LINE CLEAR AVAILED
311	16-Nov-19	MYSORE	66	HV3	KUSHALANAGARA_66	15:32	16:01	0:29	LINE CLEAR AVAILED
312	16-Nov-19	MYSORE	66	HV1	MALAVALLI_66	15:15	15:58	0:42	LINE CLEAR AVAILED
313	16-Nov-19	MYSORE	66	HV1	PGPALYA_66	11:46	13:18	1:31	LINE CLEAR AVAILED
314	16-Nov-19	MYSORE	66	HV1	RKNAGARA_66	10:00	15:54	5:53	LINE CLEAR AVAILED
315	16-Nov-19	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	12:14	12:18	0:04	LINE CLEAR AVAILED
316	16-Nov-19	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	9:07	13:39	4:31	LINE CLEAR AVAILED
317	16-Nov-19	TUMKUR	110	TR-1	TURUVEKERE_110	13:13	13:30	0:17	LINE CLEAR AVAILED
318	16-Nov-19	TUMKUR	110	TR-1&TR-2	SAMPIGE_110	10:00	12:11	2:11	LINE CLEAR AVAILED
319	16-Nov-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:53	10:56	0:02	HAND TRIPPED
320	16-Nov-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	10:56	11:06	0:09	HAND TRIPPED
321	16-Nov-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	13:07	13:11	0:04	HAND TRIPPED
322	16-Nov-19	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	10:32	10:36	0:03	HAND TRIPPED
323	16-Nov-19	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	13:17	13:21	0:03	HAND TRIPPED
324	16-Nov-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:44	10:53	0:09	HAND TRIPPED
325	16-Nov-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:17	13:07	0:49	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
326	16-Nov-19	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:57	14:13	0:15	LINE FAULT
327	16-Nov-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66	12:34	12:49	0:15	LINE FAULT
328	16-Nov-19	TUMKUR	66	TR-2	NITRAHALLI_66	11:23	13:09	1:45	LINE CLEAR AVAILED
329	16-Nov-19	TUMKUR	66	TR-1	PAVAGADA_66	11:24	12:02	0:38	LINE CLEAR AVAILED
330	17-Nov-19	HASSAN	400	TALAGU	NELAMANGALA#2	16:21	23:59	7:38	LINE CLEAR AVAILED
331	17-Nov-19	HASSAN	400	UPCL	HASSAN1	0:00	7:49	7:49	LINE CLEAR AVAILED
332	17-Nov-19	HASSAN	400	UPCL	HASSAN1	0:00	16:35	16:35	LINE CLEAR AVAILED
333	17-Nov-19	HASSAN	220	KAVOOR	HV3	13:08	16:04	2:56	LINE FAULT
334	17-Nov-19	HASSAN	220	KAVOOR	HV1	13:08	13:39	0:31	LINE FAULT
335	17-Nov-19	HASSAN	220	KAVOOR	HV2	13:08	13:39	0:31	LINE FAULT
336	17-Nov-19	HASSAN	220	KAVOOR	KEMAR3	13:24	13:41	0:17	MAIN SUPPLY FAILURE
337	17-Nov-19	HASSAN	220	KAVOOR	KEMR1	13:24	13:37	0:13	MAIN SUPPLY FAILURE
338	17-Nov-19	HASSAN	220	KAVOOR	KEMR2	13:24	13:38	0:14	MAIN SUPPLY FAILURE
339	17-Nov-19	HASSAN	220	KEMAR	Kavoor2	13:08	13:24	0:16	HAND TRIPPED
340	17-Nov-19	HASSAN	220	KEMAR	Varahi1	8:54	19:31	10:37	LINE FAULT
341	17-Nov-19	HASSAN	220	MRSSHM	VARAHI3	9:30	10:06	0:36	HAND TRIPPED
342	17-Nov-19	HASSAN	220	MSEZ	KAVOOR1	13:22	13:37	0:15	HAND TRIPPED
343	17-Nov-19	HASSAN	220	MSEZ	KAVOOR2	13:22	13:37	0:15	HAND TRIPPED
344	17-Nov-19	HASSAN	220	VARAHI	KEMAR1	0:00	8:54	8:54	LINE FAULT
345	17-Nov-19	HASSAN	220	VARAHI	SHMG3	9:29	10:07	0:38	NFBC ISSUED
346	17-Nov-19	HASSAN	110	KAVOOR	LV1	13:08	13:39	0:31	LINE FAULT
347	17-Nov-19	HASSAN	110	KAVOOR	LV2	13:08	13:39	0:31	LINE FAULT
348	17-Nov-19	HASSAN	110	KAVOOR	BAIKAMP	13:08	13:44	0:36	LINE FAULT
349	17-Nov-19	HASSAN	110	MRSSHM	GAJNUR	9:30	10:08	0:38	HAND TRIPPED
350	17-Nov-19	HASSAN	110	BAIKAM	HV1	13:06	13:52	0:46	MAIN SUPPLY FAILURE
351	17-Nov-19	HASSAN	110	BAIKAM	HV2	13:06	13:50	0:44	MAIN SUPPLY FAILURE
352	17-Nov-19	HASSAN	110	GAJNUR	IPP IC LINE	9:25	10:18	0:53	MAIN SUPPLY FAILURE
353	17-Nov-19	HASSAN	110	MOODAB	SOHAM1	13:10	13:45	0:35	MAIN SUPPLY FAILURE
354	17-Nov-19	HASSAN	110	MOODAB	SOHAM2	13:10	13:45	0:35	MAIN SUPPLY FAILURE
355	17-Nov-19	HASSAN	110	SHIKAR	HV2	11:06	12:34	1:28	LINE CLEAR AVAILED
356	17-Nov-19	HASSAN	66	BELUR66	MUDIGERE	18:10	18:25	0:15	HAND TRIPPED
357	17-Nov-19	HASSAN	66	BHADRA	LINGADAHALLI	10:36	10:43	0:07	LINE FAULT
358	17-Nov-19	HASSAN	66	MAGGE	HV1	6:23	6:55	0:32	LINE FAULT
359	17-Nov-19	MYSORE	66	HV1	ADICHUNCHANAGIRI_66	10:11	11:07	0:56	LINE CLEAR AVAILED
360	17-Nov-19	MYSORE	66	HAMPAPURA-MANDYA	CHIKKA_MANDYA_66	13:39	14:55	1:15	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
361	17-Nov-19	MYSORE	66	KADAKOLA-NANJANAGUDU 1	NANJANGUDU_66 SINDHUVALLI_66	8:38	18:54	10:15	LINE CLEAR AVAILED
362	17-Nov-19	MYSORE	66	KADAKOLA-NANJANAGUDU 2	THANDYA_66	7:48	19:00	11:11	LINE CLEAR AVAILED
363	17-Nov-19	MYSORE	66	MANDYA -CHIKKMANDYA	CHIKKA_MANDYA_66 BESAGARAHALLI_66 HAMPAPURA_66 KOPPA_66	12:59	14:47	1:48	LINE FAULT
364	17-Nov-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66	17:58	18:11	0:13	LINE FAULT
365	18-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:34	7:34	LINE CLEAR AVAILED
366	18-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:43	23:59	0:16	HAND TRIPPED
367	18-Nov-19	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	14:24	15:28	1:04	NFBC ISSUED
368	18-Nov-19	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	12:58	13:41	0:43	NFBC ISSUED
369	18-Nov-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	12:40	12:46	0:06	LINE FAULT
370	18-Nov-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:40	13:22	2:42	LINE CLEAR AVAILED
371	18-Nov-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	11:43	13:41	1:58	LINE FAULT
372	18-Nov-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	14:22	15:28	1:06	LINE FAULT
373	18-Nov-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	12:40	12:46	0:06	LINE FAULT
374	18-Nov-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:41	13:23	2:42	LINE CLEAR AVAILED
375	18-Nov-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:17	11:48	0:31	LINE FAULT
376	18-Nov-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	11:17	12:13	0:56	LINE FAULT
377	18-Nov-19	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	15:19	15:57	0:38	LINE CLEAR AVAILED
378	18-Nov-19	HASSAN	66	HV1	HARIHARAPURA_66	9:43	10:06	0:23	MAIN SUPPLY FAILURE
379	18-Nov-19	HASSAN	66	HV1	HARIHARAPURA_66	16:48	16:50	0:02	MAIN SUPPLY FAILURE
380	18-Nov-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	9:42	10:04	0:22	HAND TRIPPED
381	18-Nov-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	16:48	16:49	0:01	HAND TRIPPED
382	18-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	9:41	10:04	0:23	HAND TRIPPED
383	18-Nov-19	MYSORE	66	HV1	ADICHUNCHANAGIRI_66	11:16	11:56	0:39	LINE CLEAR AVAILED
384	18-Nov-19	MYSORE	66	HV1	BANANGADI_66	14:32	15:17	0:44	LINE CLEAR AVAILED
385	18-Nov-19	MYSORE	66	HV2	BANANGADI_66	13:15	14:30	1:15	LINE CLEAR AVAILED
386	18-Nov-19	MYSORE	66	HV2	BILIKERE_66	12:28	12:50	0:21	LINE CLEAR AVAILED
387	18-Nov-19	MYSORE	66	HV1	BOOKANAKERE_66	12:17	13:31	1:14	LINE CLEAR AVAILED
388	18-Nov-19	MYSORE	66	CR NAGARA-GUNDLUPET 2	TERAKANAMBE_66	15:34	17:24	1:49	LINE CLEAR AVAILED
389	18-Nov-19	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	11:47	15:16	3:29	LINE CLEAR AVAILED
390	18-Nov-19	MYSORE	66	HOOTAGALLY-HEBBAL	HEBBAL_66 METAGALLY_66	11:43	14:15	2:32	LINE FAULT
391	18-Nov-19	MYSORE	220	HV1	KADAKOLA_220	10:29	15:19	4:50	LINE CLEAR AVAILED
392	18-Nov-19	MYSORE	66	HV1	K_HONNALGERE_66	11:24	11:36	0:12	MAIN SUPPLY FAILURE
393	18-Nov-19	MYSORE	66	HV2	K_HONNALGERE_66	11:24	11:36	0:12	MAIN SUPPLY FAILURE
394	18-Nov-19	MYSORE	66	HV1	KIADBMANDYA_66	11:24	11:40	0:15	MAIN SUPPLY FAILURE
395	18-Nov-19	MYSORE	66	HV2	KIADBMANDYA_66	11:24	11:40	0:15	MAIN SUPPLY FAILURE
396	18-Nov-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66, SOMANAHALLI_66	11:26	11:40	0:14	MAIN SUPPLY FAILURE
397	18-Nov-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	11:26	11:40	0:14	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
398	18-Nov-19	MYSORE	66	METAGALLY-HEBBAL	HEBBAL_66	12:23	12:36	0:12	HAND TRIPPED
399	18-Nov-19	MYSORE	66	HV1	SUNTIKOPPA_66	13:00	13:45	0:44	LINE CLEAR AVAILED
400	18-Nov-19	TUMKUR	220	TR-2(HV SIDE )	ANTHRASANAHALLI_220	11:00	11:12	0:11	LINE CLEAR AVAILED
401	18-Nov-19	TUMKUR	220	TR-2(HV SIDE )	ANTHRASANAHALLI_220	16:38	16:43	0:04	LINE CLEAR AVAILED
402	18-Nov-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	13:27	17:15	3:47	LINE FAULT
403	18-Nov-19	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	18:16	18:47	0:31	LINE CLEAR AVAILED
404	18-Nov-19	TUMKUR	110	TR-1	KBCROSS_220	11:38	13:20	1:42	LINE CLEAR AVAILED
405	18-Nov-19	TUMKUR	110	TR-1	MAYASANDRA_110	13:32	13:50	0:17	LINE CLEAR AVAILED
406	18-Nov-19	TUMKUR	110	TR-2(HV SIDE )	ANTHRASANAHALLI_220	11:00	11:12	0:11	LINE CLEAR AVAILED
407	18-Nov-19	TUMKUR	110	TR-2(HV SIDE )	ANTHRASANAHALLI_220	16:38	16:44	0:05	LINE CLEAR AVAILED
408	18-Nov-19	TUMKUR	66	TR-3	AVAREGERE_66	17:31	17:43	0:12	LINE CLEAR AVAILED
409	18-Nov-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TM2_66	11:24	16:55	5:30	LINE CLEAR AVAILED
410	18-Nov-19	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	11:24	16:55	5:30	LINE CLEAR AVAILED
411	18-Nov-19	TUMKUR	66	TR-2	HALUVAGALU_66	14:21	14:31	0:10	TRANSFORMER FAULT
412	18-Nov-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	20:10	20:19	0:09	LINE FAULT
413	18-Nov-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	11:55	12:07	0:11	LINE FAULT
414	18-Nov-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	13:37	13:46	0:09	LINE FAULT
415	18-Nov-19	TUMKUR	66	TR-1	PANDARAHALLI_66	22:51	23:38	0:47	TRANSFORMER FAULT
416	18-Nov-19	TUMKUR	66	TR-2	RAMPURA_66	14:36	15:49	1:12	LINE CLEAR AVAILED
417	18-Nov-19	TUMKUR	66	TR-2	TELAGI_66	16:12	16:53	0:41	LINE CLEAR AVAILED