

**400/220/110/66 kV TRANSMISSION OUTAGES FROM : 02.08.22 TO 08.08.2022**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	2-Aug-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED AEQUS_220	21:09 (30.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
2	2-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED SIRSI_220	8:47	14:36	5:49	TRANSFORMER FAULT
3	2-Aug-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	7:28 (29.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
4	2-Aug-22	BAGALKOT	110	110/11KV,HV1	KULAGERI CROSS_110	14:05	15:55	1:50	LINE CLEAR AVOIDED
5	2-Aug-22	BAGALKOT	110	110/11KV,HV2	KAMBAGI_110	15:30	15:39	0:09	TRANSFORMER FAULT
6	2-Aug-22	BAGALKOT	110	110/11KV,HV2	KAMBAGI_110	16:03	16:13	0:10	TRANSFORMER FAULT
7	2-Aug-22	BAGALKOT	110	110/11KV,HV2	KAMBAGI_110	18:32	18:51	0:19	TRANSFORMER FAULT
8	2-Aug-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
9	2-Aug-22	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	14:18(2.8.22)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
10	2-Aug-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
11	2-Aug-22	BAGALKOT	110	ANNIGERI-GADAG	ANNIGERI_110	17:38	18:18	0:40	HAND TRIPPED
12	2-Aug-22	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	7:47	8:08	0:21	LINE FAULT
13	2-Aug-22	BAGALKOT	110	CHAND KAVATE-ALMEL	ALMEL_110	4:01	4:05	0:04	LINE FAULT
14	2-Aug-22	BAGALKOT	110	DAVALESHWAR-SAIDAPUR	SAIDAPUR_110	18:59	19:13	0:14	LINE FAULT
15	2-Aug-22	BAGALKOT	110	HUDLI-ANKALI	ANKALI_110	6:14	6:44	0:30	LINE FAULT
16	2-Aug-22	BAGALKOT	110	HUNGUND-ILKAL2	HUNGUND_110	12:39	15:37	2:58	LINE CLEAR AVOIDED
17	2-Aug-22	BAGALKOT	110	KUDACHI220-AINAPUR	AINAPUR_110	10:40	12:15	1:35	LINE CLEAR AVOIDED
18	2-Aug-22	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MALGHAN(S)_110	5:42	6:04	0:22	LINE FAULT
19	2-Aug-22	BAGALKOT	110	MUGALKHOD220-HIDKAL	HIDKAL_110	13:14	13:21	0:06	LINE FAULT
20	2-Aug-22	BAGALKOT	110	RANEENNUR220-AREMALLAPUR (HONNATTI)	HONNATTI_110	6:58	7:10	0:12	LINE FAULT
21	2-Aug-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	8:39	8:48	0:09	LINE FAULT
22	2-Aug-22	BAGALKOT	110	TODALABAGI-JAMAKHANDI	TODALABAGI_110	7:47	7:54	0:07	LINE FAULT
23	2-Aug-22	BAGALKOT	110	TODALBAGI-SAVALAGI	STATION NOT AFFECTED TODALBAGI_110	18:00 (20.07.2022)			LINE OPEN,LINE FAULT
24	2-Aug-22	BAGALKOT	110	UTTUR - F1 JAMB CB( MUDHOL)	STATION NOT AFFECTED UTTUR_110	9:51 (24.07.2022)			LINE OPEN,LINE CLEAR AVOIDED
25	2-Aug-22	BAGALKOT	110	VAJRAMATTI 220-KATARAKI	KATARKI_110	6:31	6:41	0:09	LINE FAULT
26	2-Aug-22	BAGALKOT	110	VAJRAMATTI220- JK CEMENT	JK CEMENT_110 STATION NOT AFFECTED VAJRAMATTI_220	17:09	18:14	1:04	LINE CLEAR AVOIDED
27	2-Aug-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
28	2-Aug-22	BAGALKOT	220	220/110KV, HV-3 & LV3	STATION NOT AFFECTED ATHANI_220	10:26 (25.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
29	2-Aug-22	BAGALKOT	220	220/110KV,HV2& LV2	STATION NOT AFFECTED VIJAYPUR_220	7:27	7:53	0:26	TRANSFORMER FAULT
30	2-Aug-22	BAGALKOT	220	BAGALAKOT-VAJRAMATTI-1	STATION NOT AFFECTED BAGALKOT_220	17:48 (02.08.2022)			LINE OPEN,LINE CLEAR AVAILED
31	2-Aug-22	BAGALKOT	220	BAGALKOT - ALAMATTI-1 (LINE2)	STATION NOT AFFECTED BAGALKOT_220	4:51	16:23	6:37	LINE FAULT
32	2-Aug-22	BAGALKOT	220	BAGALKOT - ALAMATTI-2 (LINE1)	STATION NOT AFFECTED BAGALKOT_220	9:51	16:26	6:36	LINE CLEAR AVAILED
33	2-Aug-22	BAGALKOT	220	BELAGAVI-AEQUS-2	STATION NOT AFFECTED BELAGAVI_220	9:30 (02.08.2022)			LINE OPEN,LINE CLEAR AVAILED
34	2-Aug-22	BAGALKOT	220	BELAGAVI--NARENDRA-1	STATION NOT AFFECTED BELAGAVI_220	11:27 (01.08.2022)			LINE OPEN,LINE CLEAR AVAILED
35	2-Aug-22	BAGALKOT	220	MUGALKHOD-CHIKKODI-2	STATION NOT AFFECTED MUGALKHOD_220	14:27	15:15	0:53	LINE FAULT
36	2-Aug-22	BAGALKOT	220	MUGALKHOD-GHATAPRABHA-2	STATION NOT AFFECTED MUGALKHOD_220	15:20	15:31	0:11	LINE FAULT
37	2-Aug-22	BAGALKOT	220	NARENDRA220-KNBRG1 (BELAGAVI 1 )	NARENDRA_220	11:27 (01.08.2022)			LINE OPEN,LINE CLEAR AVAILED
38	2-Aug-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
39	2-Aug-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
40	2-Aug-22	BENGALURU	66	CESSNA -EXORA	EXORA, ORACLE(EHT)	15:30	15:40	0:10	LINE CLEAR AVAILED
41	2-Aug-22	BENGALURU	66	CHELUR - SOMANATHPURA	CHELUR	0:00	0:25	0:25	LINE FAULT
42	2-Aug-22	BENGALURU	66	CHELUR - SOMANATHPURA	CHELUR	23:55:00(01/08/2022)	00:25(02/08/2022 )	0:30HRS	LINE CHARGED
43	2-Aug-22	BENGALURU	66	CHIKKENAHALLI - KANAKAPURA 220	CHIKKENAHALLI, CHANNAPATNA, VANDARGUPPE	10:25	16:34	6:09	LINE CLEAR AVAILED
44	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	0:29	1:29	1:00	LINE CLEAR AVAILED
45	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	1:30	1:33	0:03	LINE CLEAR AVAILED
46	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	15:10	16:43	1:33	LINE CLEAR AVAILED
47	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	19:38	20:03	0:25	LOAD CURTAILMENT
48	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	19:38	20:03	0:25	LOAD CURTAILMENT
49	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	0:25	0:32	0:07	LINE CLEAR AVAILED
50	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	19:38	20:03	0:25	LOAD CURTAILMENT
51	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	19:38	20:03	0:25	LOAD CURTAILMENT
52	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	19:06	19:26	0:20	LOAD CURTAILMENT
53	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	19:38	19:53	0:15	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
54	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	19:06	19:18	0:12	LOAD CURTAILMENT
55	2-Aug-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALIC CROSS, YENIGADALE	19:38	20:03	0:25	LOAD CURTAILMENT
56	2-Aug-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	0:00	0:42	0:42	LINE FAULT
57	2-Aug-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	22:32(01/08/2022)	00:42(02/08/2022 )	2:20HRS	LINE CHARGED
58	2-Aug-22	BENGALURU	66	DEVARABISANAHALLI - HSR LAYOUT 220	DEVARABISANAHALLI	10:44	15:30	4:46	LINE CLEAR AVAILED
59	2-Aug-22	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	PALLICHERLU	19:41	20:15	0:34	LOAD CURTAILMENT
60	2-Aug-22	BENGALURU	66	GOKULA - SAHAKARI NAGAR 220	GOKULA, BEL (EHT), HMT (EHT), RMV, TATA INSTITUTE (EHT)	20:10	20:35	0:25	MAIN SUPPLY FAILURE
61	2-Aug-22	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	1:27	1:55	0:28	LINE FAULT
62	2-Aug-22	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	19:15	20:10	0:55	LOAD CURTAILMENT
63	2-Aug-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	NO STATION AFFECTED	0:00	3:53	3:53	LINE FAULT
64	2-Aug-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	NO STATION AFFECTED	22:05(01/08/2022)	3:53(02/08/2022)	5:08HRS	LINE CHARGED
65	2-Aug-22	BENGALURU	66	HV1	ANEKAL	14:26	14:27	0:01	LINE CLEAR AVAILED
66	2-Aug-22	BENGALURU	66	HV1	ANEKAL	17:51	17:55	0:04	LOAD CHANGE OVER
67	2-Aug-22	BENGALURU	66	HV1	CESSNA	12:35	12:45	0:10	LINE CLEAR AVAILED
68	2-Aug-22	BENGALURU	66	HV1	CESSNA	15:35	15:42	0:07	LOAD CHANGE OVER
69	2-Aug-22	BENGALURU	66	HV1	ELITA PROMENENDE	15:32	15:51	0:19	LINE CLEAR AVAILED
70	2-Aug-22	BENGALURU	66	HV1	HAROBELE KANAKAPURA	11:45	11:50	0:05	LINE CLEAR AVAILED
71	2-Aug-22	BENGALURU	66	HV1	KOLAR 220	0:48	1:45	0:57	LINE CLEAR AVAILED
72	2-Aug-22	BENGALURU	66	HV1	KOLAR 220	23:49:00(01/08/2022)	1:42(02/08/2022)	1:52HRS	TRANSFORMER CHARGED
73	2-Aug-22	BENGALURU	66	HV1	SM MANGALA	10:11	10:37	0:26	TRANSFORMER FAULT
74	2-Aug-22	BENGALURU	66	HV1	SOMANAHALLI 220	0:00	0:15	0:15	TRANSFORMER FAULT
75	2-Aug-22	BENGALURU	66	HV1	SOMANAHALLI 220	23:53(01/08/2022)	00:15(02/08/2022 )	0:22 hrs	TRANSFORMER CHARGED
76	2-Aug-22	BENGALURU	66	HV1	VIDHURASHWATHA	9:30	9:45	0:15	TRANSFORMER FAULT
77	2-Aug-22	BENGALURU	66	HV1	VIDHURASHWATHA	16:30	16:50	0:20	TRANSFORMER FAULT
78	2-Aug-22	BENGALURU	66	HV1	VIJAYANAGARA	6:24	6:34	0:10	LOAD CHANGE OVER
79	2-Aug-22	BENGALURU	66	HV2	BRINDAVANA 220	2:39	3:53	1:14	TRANSFORMER FAULT
80	2-Aug-22	BENGALURU	66	HV2	KOLAR 220	16:25	16:45	0:20	LINE CLEAR AVAILED
81	2-Aug-22	BENGALURU	66	HV2	SAMANDURU	18:40	18:55	0:15	LINE CLEAR AVAILED
82	2-Aug-22	BENGALURU	66	HV2	VIDHURASHWATHA	8:27	9:50	1:23	LINE CLEAR AVAILED
83	2-Aug-22	BENGALURU	66	HV2	VIJAYANAGARA	6:24	6:34	0:10	LOAD CHANGE OVER
84	2-Aug-22	BENGALURU	66	HV3	NRS 220	2:00	2:30	0:30	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
85	2-Aug-22	BENGALURU	66	HV3	YARANDANAHALLI 220	10:06	10:19	0:13	TRANSFORMER FAULT
86	2-Aug-22	BENGALURU	66	IRAGAMPALLI - BURUDUGUNTE	BURUDUGUNTE	16:38	16:55	0:17	LOAD CHANGE OVER
87	2-Aug-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	9:50	10:14	0:24	LINE FAULT
88	2-Aug-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	19:38	20:06	0:28	LOAD CURTAILMENT
89	2-Aug-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	19:45	20:07	0:22	LOAD CURTAILMENT
90	2-Aug-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	19:45	20:07	0:22	LOAD CURTAILMENT
91	2-Aug-22	BENGALURU	66	KOLAR 220 - PGCIL AUX	PGCIL AUX, SUGUTUR	19:38	20:05	0:27	LOAD CURTAILMENT
92	2-Aug-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	19:53	20:05	0:12	LOAD CURTAILMENT
93	2-Aug-22	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	19:38	20:05	0:27	LOAD CURTAILMENT
94	2-Aug-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	13:20	14:47	1:27	LINE CLEAR AVAILED
95	2-Aug-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	19:38	20:08	0:30	LOAD CURTAILMENT
96	2-Aug-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI, KC VALLEY (EHT)	19:38	20:05	0:27	LOAD CURTAILMENT
97	2-Aug-22	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	7:53	7:56	0:03	LOAD CHANGE OVER
98	2-Aug-22	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	15:13	15:18	0:05	LINE FAULT
99	2-Aug-22	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	15:13	15:18	0:05	LINE FAULT
100	2-Aug-22	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	6:08	6:10	0:02	LOAD CHANGE OVER
101	2-Aug-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	8:40	8:43	0:03	MAIN SUPPLY FAILURE
102	2-Aug-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	8:40	8:43	0:03	MAIN SUPPLY FAILURE
103	2-Aug-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	19:40	19:47	0:07	LOAD CURTAILMENT
104	2-Aug-22	BENGALURU	66	MARALAWADI - GODUR	GODUR	19:18	19:33	0:15	LINE FAULT
105	2-Aug-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	4:48	5:10	0:22	MAIN SUPPLY FAILURE
106	2-Aug-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	4:48	5:10	0:22	MAIN SUPPLY FAILURE
107	2-Aug-22	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	4:48	5:10	0:22	MAIN SUPPLY FAILURE
108	2-Aug-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	4:48	5:10	0:22	MAIN SUPPLY FAILURE
109	2-Aug-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI, BURUDAGUNTE	4:48	5:10	0:22	MAIN SUPPLY FAILURE
110	2-Aug-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	4:48	5:10	0:22	MAIN SUPPLY FAILURE
111	2-Aug-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	0:00	0:08	0:08	LINE FAULT
112	2-Aug-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	23:54:00(01/08/2022)	00:08(02/08/2022 )	00:14HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
113	2-Aug-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	4:48	5:10	0:22	MAIN SUPPLY FAILURE
114	2-Aug-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	21:51	22:15	0:24	LINE FAULT
115	2-Aug-22	BENGALURU	66	SAHAKARI NAGAR 220 - GOKULA	GOKULA, BEL (EHT), HMT (EHT), RMV, TATA INSTITUTE (EHT)	20:10	20:35	0:25	MAIN SUPPLY FAILURE
116	2-Aug-22	BENGALURU	66	SHOBHA CITY - HBR LAYOUT 220	SHOBHA CITY	3:33	3:40	0:07	LOAD CHANGE OVER
117	2-Aug-22	BENGALURU	66	SHOBHA CITY - MANYATHA TECH PARK 220	SHOBHA CITY	1:02	1:10	0:08	LOAD CHANGE OVER
118	2-Aug-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	19:46	20:33	0:47	LOAD CURTAILMENT
119	2-Aug-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	19:46	20:33	0:47	LOAD CURTAILMENT
120	2-Aug-22	BENGALURU	66	T GOLLAHALLI 220 - KYASAMBALLI	KYASAMBALLI, DODDAKARI	19:46	20:33	0:47	LOAD CURTAILMENT
121	2-Aug-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	19:46	20:33	0:47	LOAD CURTAILMENT
122	2-Aug-22	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1 220	MITTEMARI 220	4:48	5:10	0:22	LINE FAULT
123	2-Aug-22	BENGALURU	220	HV1	MAGADI 220	8:40	8:42	0:02	LOAD CHANGE OVER
124	2-Aug-22	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 220	MITTEMARI 220	4:48	5:10	0:22	MAIN SUPPLY FAILURE
125	2-Aug-22	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 2 220	NO STATION AFFECTED	20:13	23:26	3:13	LINE FAULT
126	2-Aug-22	BENGALURU	220	SAHAKARI NAGAR 220 - SRS PEENYA 220	SAHAKARI NAGAR 220	20:10	20:50	0:40	LINE FAULT
127	2-Aug-22	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 2 220	NO STATION AFFECTED	20:13	23:22	3:09	LINE FAULT
128	2-Aug-22	GULBARGA	66	HV2	HANSI_66	9:20	9:30	0:10	LINE CLEAR AVAILED
129	2-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_1	HIREHADAGALI_66,GIRYAPUR_66 ,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	7:13	7:42	0:29	LINE FAULT
130	2-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_1	HIREHADAGALI_66,GIRYAPUR_66 ,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	7:13	7:42	0:29	LINE FAULT
131	2-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66 ,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	7:13	9:22	2:09	LINE FAULT
132	2-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66 ,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	19:05	19:15	0:10	LINE FAULT
133	2-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66 ,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	7:13	9:22	2:09	LINE FAULT
134	2-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	SOVENHALLI_66	10:22	12:44	2:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
135	2-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	SOVENHALLI_66	10:22(2.8.22)			LINE OPEN,LINE FAULT
136	2-Aug-22	GULBARGA	66	KUDLIGI-ACME SLOAR_IPP	KUDLIGI_220	11:10	11:30	0:20	LINE CLEAR AVAILED
137	2-Aug-22	GULBARGA	66	MAGALA-HIREHADAGALI	MAGALA_66	6:20	6:30	0:10	MAIN SUPPLY FAILURE
138	2-Aug-22	GULBARGA	66	MAGALA-HIREHADAGALI	MAGALA_66	8:15	8:40	0:25	MAIN SUPPLY FAILURE
139	2-Aug-22	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	11:19	12:00	0:41	LOAD CURTAILMENT
140	2-Aug-22	GULBARGA	110	GHATARGA-SHAHBAD	GHATARGA_110	5:42	6:22	0:40	LINE FAULT
141	2-Aug-22	GULBARGA	110	GURMITKAL-KONKAL	GURMITKAL_110	22:50	23:05	0:15	LINE FAULT
142	2-Aug-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	06:55 (26/07/2022)			LINE OPEN,LINE FAULT
143	2-Aug-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	06:55 (26/07/2022)			LINE OPEN,LINE FAULT
144	2-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	5:44	5:52	0:08	LINE FAULT
145	2-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	20:17	20:23	0:06	LINE FAULT
146	2-Aug-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
147	2-Aug-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
148	2-Aug-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
149	2-Aug-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
150	2-Aug-22	GULBARGA	110	HV1	ALIPUR_220	1:13	1:23	0:10	TRANSFORMER FAULT
151	2-Aug-22	GULBARGA	110	HV1	ALIPUR_220	6:29	6:49	0:20	TRANSFORMER FAULT
152	2-Aug-22	GULBARGA	110	HV1	ALIPUR_220	8:03	8:17	0:14	TRANSFORMER FAULT
153	2-Aug-22	GULBARGA	110	HV2	HATTI_110	7:43	7:46	0:03	TRANSFORMER FAULT
154	2-Aug-22	GULBARGA	110	HV2	HATTI_110	11:43	11:49	0:06	TRANSFORMER FAULT
155	2-Aug-22	GULBARGA	110	HV2	SREERAMANAGAR_110	9:00(02.08.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
156	2-Aug-22	GULBARGA	110	HV2	TEKKALKOTE_110	16:00	16:15	0:15	TRANSFORMER FAULT
157	2-Aug-22	GULBARGA	110	HV3	VALKAMDINNI_110	6:47	6:56	0:09	TRANSFORMER FAULT
158	2-Aug-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	0:43	0:51	0:08	LINE FAULT
159	2-Aug-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	6:07	6:18	0:11	LINE FAULT
160	2-Aug-22	GULBARGA	110	KEMBHAVI-AVADASLR	KEMBHAVI_110	5:30	6:40	1:10	LINE FAULT
161	2-Aug-22	GULBARGA	110	KEMBHAVI-AVADASLR	KEMBHAVI_110	12:10	12:55	0:45	LINE FAULT
162	2-Aug-22	GULBARGA	110	KEMBHAVI-AVADASLR	KEMBHAVI_110	12:55	14:15	1:20	LINE FAULT
163	2-Aug-22	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	2:05	2:15	0:10	LINE FAULT
164	2-Aug-22	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,HUNSAGI_110,ASKI_110,UGARSUGAR_IPP	5:15	5:25	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
165	2-Aug-22	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,HUNSAGI_110,A SKI_110,UGARSUGAR_IPP	12:10	12:20	0:10	LINE FAULT
166	2-Aug-22	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,HUNSAGI_110,A SKI_110,UGARSUGAR_IPP	12:55	13:00	0:05	LINE FAULT
167	2-Aug-22	GULBARGA	110	KUSATGI-BEVOOR	BEVOOR_110,MANGALORE_110, CHILAKAMUKI_110	19:19	20:30	1:11	LINE CLEAR AVAILED
168	2-Aug-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONN AGAR_110,HANUMANAL_110	19:19	20:33	1:14	LINE CLEAR AVAILED
169	2-Aug-22	GULBARGA	110	KUSTAGI-VAJRABANDI	VAJRABANDI_110,YELBURGA_11 0,KUKNOOR_110	19:19	23:55	4:36	LINE CLEAR AVAILED
170	2-Aug-22	GULBARGA	110	LV1	LINGASUGUR_220	21:01	21:08	0:07	TRANSFORMER FAULT
171	2-Aug-22	GULBARGA	110	LV1	SHAHAPUR_220	5:15	5:24	0:09	TRANSFORMER FAULT
172	2-Aug-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GANDHINAGAR_110	20:02	20:12	0:10	LINE FAULT
173	2-Aug-22	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	4:57	5:10	0:13	LINE FAULT
174	2-Aug-22	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110	20:15	20:26	0:11	MAIN SUPPLY FAILURE
175	2-Aug-22	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	23:47	23:55	0:08	LINE FAULT
176	2-Aug-22	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	5:30	5:40	0:10	LINE FAULT
177	2-Aug-22	GULBARGA	110	NALWAR-SHAHAPUR,SHAHABAD	NALWAR_110	5:10	5:30	0:20	MAIN SUPPLY FAILURE
178	2-Aug-22	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	23:55(01.08.2022)	0:05(2.08.2022)	00:10HRS	MAIN SUPPLY FAILURE
179	2-Aug-22	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	2:30	3:00	0:30	MAIN SUPPLY FAILURE
180	2-Aug-22	GULBARGA	110	RAICHUR-SINDHNOOR2	KURDICROSS_110,MADLAPUR_1 10,MANVI_110	4:20	4:28	0:08	LINE FAULT
181	2-Aug-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	6:05	6:10	0:05	LINE FAULT
182	2-Aug-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	21:05	21:10	0:05	LINE FAULT
183	2-Aug-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	23:10	23:15	0:05	LINE FAULT
184	2-Aug-22	GULBARGA	110	SHAHABAD-FARTHABAD	FARTHABAD_110,GULBARGA SOUTH_110	7:10	7:43	0:33	LINE CLEAR AVAILED
185	2-Aug-22	GULBARGA	110	SHAHABAD-FARTHABAD	FARTHABAD_110,GULBARGA SOUTH_110	12:56	13:34	0:38	LINE CLEAR AVAILED
186	2-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
187	2-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
188	2-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
189	2-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
190	2-Aug-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	23:59(01.08.202022)	00:08(02.08.2022)	00:09HRS	LINE CHARGED
191	2-Aug-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	23:59(01.08.202022)	00:08(02.08.2022)	00:09HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
192	2-Aug-22	GULBARGA	110	SHAHAPUR-KEMBHAVI,KHANAPUR,SHORAPUR,SHAHAPUR 1&2,RAICHUR 1&2	KEMBHAVI_110,KHANAPUR_110,SHORAPUR_110,SHAHAPUR 1&2_110,SAIDAPUR_110,JEWARGI_110,WADGERA_110	5:15	5:32	0:17	LINE CLEAR AVAILED
193	2-Aug-22	GULBARGA	110	SHAHAPUR-RAICHUR_1	DEODURGA_110	5:15	6:01	0:46	LINE FAULT
194	2-Aug-22	GULBARGA	110	SHAHAPUR-RAICHUR_2	DEODURGA_110	5:15	6:12	0:57	LINE FAULT
195	2-Aug-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110	4:14	4:20	0:06	LINE FAULT
196	2-Aug-22	GULBARGA	110	SINDHNOOR-VALABELLARI	VALABELLARI_110,JAWALGERA_110,ADVIAMRESHWAR_110	23:59(02.08.2022)			LINE OPEN,LINE FAULT
197	2-Aug-22	GULBARGA	220	HV1&LV1	LINGASUGUR_220	21:01	21:21	0:20	TRANSFORMER FAULT
198	2-Aug-22	GULBARGA	220	HV2	KUDLIGI_220	6:20	12:10	5:50	TRANSFORMER FAULT
199	2-Aug-22	GULBARGA	220	HV2	RAICHUR_220	13:52	13:55	0:03	LINE CLEAR AVAILED
200	2-Aug-22	GULBARGA	220	SEDAM_SHAHAPUR	SEDAM_220	05:48(10/06/2022)			LINE OPEN,LINE CLEAR AVAILED
201	2-Aug-22	GULBARGA	400	RTPS-BTPS	RTPS_400	5:08	9:47	4:39	LINE FAULT
202	2-Aug-22	GULBARGA	400	RTPS-MEHEBUB NAGAR	MEHEBUB NAGAR_400	14:36	16:29	1:53	LINE FAULT
203	2-Aug-22	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	15:13	15:32	0:19	MAIN SUPPLY FAILURE
204	2-Aug-22	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	15:13	15:32	0:19	MAIN SUPPLY FAILURE
205	2-Aug-22	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	15:13	15:33	0:20	MAIN SUPPLY FAILURE
206	2-Aug-22	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	15:13	15:33	0:20	MAIN SUPPLY FAILURE
207	2-Aug-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	15:13	15:32	0:19	MAIN SUPPLY FAILURE
208	2-Aug-22	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	10:39	10:47	0:08	HAND TRIPPED
209	2-Aug-22	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	15:15	15:45	0:30	MAIN SUPPLY FAILURE
210	2-Aug-22	HASSAN	66	HNPURA-SALIGRAMA	HNPURA_66	10:39	10:47	0:08	HAND TRIPPED
211	2-Aug-22	HASSAN	66	HNPURA-SALIGRAMA	HNPURA_66	15:15	15:45	0:30	MAIN SUPPLY FAILURE
212	2-Aug-22	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	10:39	10:47	0:08	HAND TRIPPED
213	2-Aug-22	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	15:15	15:45	0:30	MAIN SUPPLY FAILURE
214	2-Aug-22	HASSAN	66	HV1	DODDAHALLI_66	15:18	15:35	0:17	MAIN SUPPLY FAILURE
215	2-Aug-22	HASSAN	66	HV1	HNPURA_66	10:39	10:47	0:08	HAND TRIPPED
216	2-Aug-22	HASSAN	66	HV1	HNPURA_66	15:15	15:45	0:30	MAIN SUPPLY FAILURE
217	2-Aug-22	HASSAN	66	HV1	KUDLIGERE_66	12:47	13:30	0:43	LINE CLEAR AVAILED
218	2-Aug-22	HASSAN	66	HV1	UDAYAPURA_66	10:44	10:50	0:06	HAND TRIPPED
219	2-Aug-22	HASSAN	66	HV2	HNPURA_66	11:20	17:35	6:15	LINE CLEAR AVAILED
220	2-Aug-22	HASSAN	66	HV2	HNPURA_66	10:39	10:47	0:08	HAND TRIPPED
221	2-Aug-22	HASSAN	66	HV2	HNPURA_66	15:15	15:45	0:30	MAIN SUPPLY FAILURE
222	2-Aug-22	HASSAN	66	HV2	UDAYAPURA_66	10:44	10:50	0:06	HAND TRIPPED
223	2-Aug-22	HASSAN	66	HV2	MANJUNATHPURA_66	11:42	13:36	1:54	LINE CLEAR AVAILED
224	2-Aug-22	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	8:05	8:15	0:10	LINE FAULT
225	2-Aug-22	HASSAN	110	HV1	HEGGUNJE_220	16:36	17:53	1:17	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
226	2-Aug-22	HASSAN	110	HV1	KALLUSADARAHALLI	11:08	13:32	2:24	LINE CLEAR AVAIED
227	2-Aug-22	HASSAN	110	HV1	SINGATGERER_110	1:33(31.07.2022)	17:06(02.08.2022)	63:33HRS	TRANSFORMER CHARGED
228	2-Aug-22	HASSAN	110	HV2	MSEZ_220	10:30	13:33	3:03	LINE CLEAR AVAIED
229	2-Aug-22	HASSAN	110	KALLUSA-KADUR	KALLUSADARAHALLI	11:08	13:34	2:26	LINE CLEAR AVAIED
230	2-Aug-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	11:08	13:12	2:04	LINE CLEAR AVAIED
231	2-Aug-22	HASSAN	110	MRSSHM-MPM	MRSMG_220	9:07	11:51	2:44	LINE CLEAR AVAIED
232	2-Aug-22	HASSAN	110	SHIRAL-KITTADAHALLI	SHIRALKOPPA_220	18:56	19:18	0:22	LINE FAULT
233	2-Aug-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	10:10	18:02	7:52	LINE CLEAR AVAIED
234	2-Aug-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
235	2-Aug-22	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	13:40	16:48	3:08	LINE CLEAR AVAIED
236	2-Aug-22	HASSAN	220	TALAGU-ST3	TALAGUPPA_400	11:15	16:46	5:31	LINE FAULT
237	2-Aug-22	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:27(02.08.2022)			LINE OPEN,LINE CLEAR AVAIED
238	2-Aug-22	MYSORE	66	CHIKKMANDYA-MANDYA	CHIKKMANDYA_66 HAMPAPURA_66	22:38	6:16	8:15	LINE CLEAR AVAIED
239	2-Aug-22	MYSORE	66	DR PETE-KUNTHUR	SANTHEMARALLI_66 MUGUR_66 JANNUR_66 THAYUR_66	9:36	9:42	0:06	LINE FAULT
240	2-Aug-22	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	10:24	17:16	6:51	LINE CLEAR AVAIED
241	2-Aug-22	MYSORE	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAIED
242	2-Aug-22	MYSORE	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN,LINE CLEAR AVAIED
243	2-Aug-22	MYSORE	66	HOOTAGALLY -BEML	HEBBAL-INDUSTRIAL_66	20:30(02.08.22)	2:12:00 (3.08.2022)	5:38 hrs	LINE CHARGED
244	2-Aug-22	MYSORE	66	HV1	COWDALI_66	7:39	7:47	0:07	TRANSFORMER FAULT
245	2-Aug-22	MYSORE	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAIED
246	2-Aug-22	MYSORE	66	HV1	KHB STATION_66	1:19	12:55	11:35	TRANSFORMER FAULT
247	2-Aug-22	MYSORE	66	HV1	LOKKANAHALLI_66	15:20	15:30	0:10	LINE CLEAR AVAIED
248	2-Aug-22	MYSORE	66	HV1	MANDGERE_66	15:15	15:38	0:23	HAND TRIPPED
249	2-Aug-22	MYSORE	66	HV1	SFCSIVA_66	8:38	8:47	0:09	TRANSFORMER FAULT
250	2-Aug-22	MYSORE	66	HV1	SHANIVARSANTHE_66	16:18	17:09	0:50	LINE CLEAR AVAIED
251	2-Aug-22	MYSORE	66	HV2	SHIVALLI_66	15:08	15:21	0:12	LINE CLEAR AVAIED
252	2-Aug-22	MYSORE	66	HV3	KRPETE_66	9:59	10:08	0:09	LINE CLEAR AVAIED
253	2-Aug-22	MYSORE	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	5:53	6:01	0:07	LINE FAULT
254	2-Aug-22	MYSORE	66	KRPETE220-MAHADESHWARAPURA	MAHADESHWARAPURA_66 GMALLIGERE_66 JAKKANAHALLY_66	23:07	23:14	0:07	LINE FAULT
255	2-Aug-22	MYSORE	66	P PURA-ATRIA 1	NO STATIONS EFFECTED	20:45(02.08.22)	10:20:00 (3.08.2022)	13:34 hrs	LINE CHARGED
256	2-Aug-22	MYSORE	66	PERIAPATNA-HUNSUR	KAMPLAPURA_66	2:30	2:38	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
257	2-Aug-22	MYSORE	66	SFCSIVA-SOLAR 10MW	NO STATIONS EFFECTED	12:35	12:55	0:20	LINE FAULT
258	2-Aug-22	MYSORE	66	SFCSIVA-SOLAR 5MW	NO STATIONS EFFECTED	12:35	12:50	0:15	LINE FAULT
259	2-Aug-22	MYSORE	66	VAJMANGALA-KADKOLA1	MARADIHUNDI_66 AYRALLI_66	5:57	6:05	0:08	LINE FAULT
260	2-Aug-22	MYSORE	66	VAJMANGALA-KADKOLA1	MARADIHUNDI_66 AYRALLI_66	19:36	19:54	0:18	HAND TRIPPED
261	2-Aug-22	MYSORE	66	VAJMANGALA-KADKOLA2	MYSORE SOUTH_66 JAIPURA_66 HAMPAPURA_66	19:42	19:54	0:12	HAND TRIPPED
262	2-Aug-22	MYSORE	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
263	2-Aug-22	MYSORE	220	HV1	TUBINKERE_220	9:27	16:32	7:04	LINE CLEAR AVAILED
264	2-Aug-22	MYSORE	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
265	2-Aug-22	MYSORE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	17:21	22:09	4:48	LINE FAULT
266	2-Aug-22	MYSORE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	19:35(02.08.22)	9:13:00 (3.08.2022)	13:38 hrs	LINE CHARGED
267	2-Aug-22	MYSORE	220	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	15:13	15:18	0:05	HAND TRIPPED
268	2-Aug-22	MYSORE	220	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	11:04	14:31	3:27	LINE FAULT
269	2-Aug-22	MYSORE	220	VAJMANGALA-TKHALLI	NO STATIONS EFFECTED	12:46	14:40	1:54	LINE FAULT
270	2-Aug-22	MYSORE	220	VAJMANGALA-TKHALLI	NO STATIONS EFFECTED	15:02	17:04	2:02	LINE CLEAR AVAILED
271	2-Aug-22	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	19:39	20:06	0:26	LOAD CURTAILMENT
272	2-Aug-22	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	20:13	20:21	0:07	LINE FAULT
273	2-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR 2	AMRUTHUR_66, HULLENAHALLI_66,KUDUR_66	19:40	20:08	0:28	LOAD CURTAILMENT
274	2-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	19:40	20:06	0:26	LOAD CURTAILMENT
275	2-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	19:40	20:08	0:28	LOAD CURTAILMENT
276	2-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	19:39	19:46	0:06	LOAD CURTAILMENT
277	2-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	19:40	20:08	0:27	LOAD CURTAILMENT
278	2-Aug-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	20:14	20:26	0:11	LOAD CURTAILMENT
279	2-Aug-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	7:46	18:38	10:52	LINE CLEAR AVAILED
280	2-Aug-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	20:09	20:20	0:10	LOAD CURTAILMENT
281	2-Aug-22	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALI_66	11:20	16:26	5:06	LINE CLEAR AVAILED
282	2-Aug-22	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALI_66	19:22	20:12	0:49	LOAD CURTAILMENT
283	2-Aug-22	TUMKUR	66	BADDIHALI- MELEKOTE	BADDIHALI_66	16:06	16:31	0:24	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
284	2-Aug-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	10:08	12:50	2:41	LINE CLEAR AVAILED
285	2-Aug-22	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	19:47	20:16	0:29	LOAD CURTAILMENT
286	2-Aug-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	19:47	20:16	0:29	LOAD CURTAILMENT
287	2-Aug-22	TUMKUR	66	HAGALWADI66-ANCHEPALYA220	HAGALWADI_66	11:10	18:04	6:54	LINE CLEAR AVAILED
288	2-Aug-22	TUMKUR	66	HIREHALLI - BADDIHALLI	BADDIHALLI_66	11:06	11:09	0:03	HAND TRIPPED
289	2-Aug-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	2:00	2:52	0:51	HAND TRIPPED
290	2-Aug-22	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	2:01	2:57	0:55	HAND TRIPPED
291	2-Aug-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	8:44	8:54	0:10	LINE FAULT
292	2-Aug-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	15:53	16:34	0:41	LINE FAULT
293	2-Aug-22	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	2:00	2:52	0:51	HAND TRIPPED
294	2-Aug-22	TUMKUR	66	MELKOTE-ANTHRASANAHALLI	MELKOTE_66	13:36	16:32	2:55	LINE CLEAR AVAILED
295	2-Aug-22	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	1:36	2:15	0:39	LINE FAULT
296	2-Aug-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	6:55	7:10	0:15	TRANSFORMER FAULT
297	2-Aug-22	TUMKUR	66	TR-1	HAGALWADI_66	11:10	18:05	6:55	LINE CLEAR AVAILED
298	2-Aug-22	TUMKUR	66	TR-1	HONNALI_66	19:05	19:18	0:12	TRANSFORMER FAULT
299	2-Aug-22	TUMKUR	66	TR-1	HONNALI_66	19:20	19:41	0:20	TRANSFORMER FAULT
300	2-Aug-22	TUMKUR	66	TR-1	HONNALI_66	19:54	20:22	0:27	TRANSFORMER FAULT
301	2-Aug-22	TUMKUR	66	TR-1	KORATAGERE_66	1:50	2:10	0:20	TRANSFORMER FAULT
302	2-Aug-22	TUMKUR	66	TR-1	KUNDUR_66	9:56	10:21	0:24	TRANSFORMER FAULT
303	2-Aug-22	TUMKUR	66	TR-1	KUNIGAL_66	10:29	11:32	1:03	LINE CLEAR AVAILED
304	2-Aug-22	TUMKUR	66	TR-1	YEDIYUR_66	10:10	18:41	8:31	LINE CLEAR AVAILED
305	2-Aug-22	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	1:59	13:04	11:05	TRANSFORMER FAULT
306	2-Aug-22	TUMKUR	66	TR-2	HONNUDIKE_66	14:09	14:14	0:05	TRANSFORMER FAULT
307	2-Aug-22	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	14:57	15:07	0:09	HAND TRIPPED
308	2-Aug-22	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_110,	11:41	12:47	1:05	LINE FAULT
309	2-Aug-22	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	14:20(27.07.2022)	16:15(2.8.22)	146:50 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
310	2-Aug-22	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	20:53	20:59	0:05	HAND TRIPPED
311	2-Aug-22	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	7:20	11:20	4:00	LINE FAULT
312	2-Aug-22	TUMKUR	220	PAVAGADA220-GREENCO_ SOLAR_IPP_220	GREENCO_ SOLAR_IPP_220	3:17	7:40	4:23	LINE FAULT
313	2-Aug-22	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	1:30	9:44	8:13	LINE FAULT
314	2-Aug-22	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	1:59	13:02	11:03	TRANSFORMER FAULT
315	2-Aug-22	TUMKUR	220	TR-2HV SIDE)	KBCROSS_220	10:55	11:22	0:26	HAND TRIPPED
316	3-Aug-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED BILAGI_110	15:00	15:20	0:20	LINE CLEAR AVAILED
317	3-Aug-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIRSI_220	8:47	14:36	5:49	TRANSFORMER FAULT
318	3-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED AEQU_220	21:09 (30.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
319	3-Aug-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	7:28 (29.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
320	3-Aug-22	BAGALKOT	110	110/11KV,HV1	HANAGALL_110	16:47	18:53	2:06	TRANSFORMER FAULT
321	3-Aug-22	BAGALKOT	110	110/11KV,HV1	LAKAMANAHALLI_110	10:44	19:41	8:57	LINE CLEAR AVAILED
322	3-Aug-22	BAGALKOT	110	110/11KV,HV1	MALGHAN(S)_110	15:06	16:40	1:34	LINE CLEAR AVAILED
323	3-Aug-22	BAGALKOT	110	110/11KV,HV2	ANKOLA_110	8:47	13:18	4:31	TRANSFORMER FAULT
324	3-Aug-22	BAGALKOT	110	110/11KV,HV2	BISANAL_110	16:55	17:01	0:06	TRANSFORMER FAULT
325	3-Aug-22	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	10:03	19:41	9:38	LINE CLEAR AVAILED
326	3-Aug-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
327	3-Aug-22	BAGALKOT	110	110/11KV,HV2	THORVI_110	11:27	11:33	0:06	TRANSFORMER FAULT
328	3-Aug-22	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	14:18 (2.8.22)			TRANSFORMER OPEN,LINE CLEAR AVAILED
329	3-Aug-22	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	8:21	9:40	1:19	LINE CLEAR AVAILED
330	3-Aug-22	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	17:41	18:11	0:30	LINE CLEAR AVAILED
331	3-Aug-22	BAGALKOT	110	110/11KV,HV4	LAKAMANAHALLI_110	10:03	19:41	9:38	LINE CLEAR AVAILED
332	3-Aug-22	BAGALKOT	110	110/33KV, HV-3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
333	3-Aug-22	BAGALKOT	110	110/33KV,HV4	ZALKI_110	7:34	7:37	0:03	TRANSFORMER FAULT
334	3-Aug-22	BAGALKOT	110	220/110/KV, LV2	STATION NOT AFFECTED MUGALKHOD_220	11:00	11:03	0:03	TRANSFORMER FAULT
335	3-Aug-22	BAGALKOT	110	220/110/KV, LV2	STATION NOT AFFECTED MUGALKHOD_220	13:18	13:56	0:38	TRANSFORMER FAULT
336	3-Aug-22	BAGALKOT	110	220/110KV, LV3	STATION NOT AFFECTED BAGALKOT_220	2:30	18:03	15:33	TRANSFORMER FAULT
337	3-Aug-22	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	20:14	21:24	1:10	LINE CLEAR AVAILED
338	3-Aug-22	BAGALKOT	110	ALMEL-JAMAKHANDI &KPR SUGARS	ALMEL_110	5:24	5:30	0:06	LINE FAULT
339	3-Aug-22	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	11:12	11:53	0:41	LINE CLEAR AVAILED
340	3-Aug-22	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	8:27	19:11	10:44	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
341	3-Aug-22	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	21:43	22:52	1:09	LINE FAULT
342	3-Aug-22	BAGALKOT	110	HAVERI220- HANAGAL ( TILUVALI )	STATION NOT AFFECTED HAVERI_220	11:12	18:00	6:48	NFBC ISSUED
343	3-Aug-22	BAGALKOT	110	KARWAR220- ARGA (KUMTA)	KARWAR_220	14:06	16:14	2:08	LINE CLEAR AVAILED
344	3-Aug-22	BAGALKOT	110	KARWAR220- SOLARIS (BINAGA)	BINAGA SOLARIS_110 STATION NOT AFFECTED KARWAR_220	14:03	16:09	2:06	LINE CLEAR AVAILED
345	3-Aug-22	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MALGHAN(S)_110	10:17	10:36	0:19	LINE FAULT
346	3-Aug-22	BAGALKOT	110	MUGALKHOD220- LN11 (NAGANUR)	NAGANUR_110	18:01	18:17	0:16	LINE FAULT
347	3-Aug-22	BAGALKOT	110	MUGALKHOD220-PG HUNSHAL	STATION NOT AFFECTED MUGALKHOD_220	11:05	14:10	3:05	NFBC ISSUED
348	3-Aug-22	BAGALKOT	110	MUNDARAGI-VIJAY SUGARS	MUNDARAGI_110	7:12	7:55	0:43	LINE FAULT
349	3-Aug-22	BAGALKOT	110	RANEBENNU220-BYADAGI	STATION NOT AFFECTED RANEBENNUR_220	11:20	13:35	2:15	LINE CLEAR AVAILED
350	3-Aug-22	BAGALKOT	110	SAMBAPUR ROAD-DAMBAL	SAMBAPUR ROAD_110	7:12	11:13	4:01	LINE FAULT
351	3-Aug-22	BAGALKOT	110	SAVANUR-ASF	SAVANUR_110	2:49	3:03	0:14	LINE FAULT
352	3-Aug-22	BAGALKOT	110	TODALBAGI-SAVALAGI	STATION NOT AFFECTED TODALBAGI_110	18:00 (20.07.2022)	10:29 (03.08.2022)	328:29 hrs	LINE CHARGED
353	3-Aug-22	BAGALKOT	110	UTTUR - F1 JAMB CB( MUDHOL)	STATION NOT AFFECTED UTTUR_110	9:51 (24.07.2022)			LINE OPEN,LINE CLEAR AVAILED
354	3-Aug-22	BAGALKOT	110	VAJRAMATTI220-MANTUR-1	MANTUR_110	6:51	6:59	0:08	LINE FAULT
355	3-Aug-22	BAGALKOT	110	VAJRAMATTI220-MANTUR-2	MANTUR_110	6:50	7:00	0:10	LINE FAULT
356	3-Aug-22	BAGALKOT	220	220/110/KV, HV2 & LV2	STATION NOT AFFECTED MUGALKHOD_220	11:35	12:45	1:10	TRANSFORMER FAULT
357	3-Aug-22	BAGALKOT	220	220/110KV, HV-1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
358	3-Aug-22	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED BAGALKOT_220	2:30	18:01	15:31	TRANSFORMER FAULT
359	3-Aug-22	BAGALKOT	220	220/110KV, HV-3 & LV-3	STATION NOT AFFECTED ATHANI_220	10:26 (25.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
360	3-Aug-22	BAGALKOT	220	AMBEAWADI -NARENDRA-1	STATION NOT AFFECTED AMBEWADI_220	9:01	13:56	4:55	LINE FAULT
361	3-Aug-22	BAGALKOT	220	AMBEAWADI -PONDA-2	STATION NOT AFFECTED AMBEWADI_220	18:36 (03.08.2022)			LINE OPEN,LINE CLEAR AVAILED
362	3-Aug-22	BAGALKOT	220	BAGALAKOT-VAJRAMATTI-1	STATION NOT AFFECTED BAGALKOT_220	17:48 (02.08.2022)			LINE OPEN,LINE CLEAR AVAILED
363	3-Aug-22	BAGALKOT	220	BELAGAVI-AEQUS-2	STATION NOT AFFECTED BELAGAVI_220	9:30 (02.08.2022)	10:27 (03.28.2022)	24:57 hrs	LINE CHARGED
364	3-Aug-22	BAGALKOT	220	BELAGAVI-KNBRGI2 (NARENDRA-2)	STATION NOT AFFECTED BELAGAVI_220	10:07	12:42	2:35	LINE FAULT
365	3-Aug-22	BAGALKOT	220	BELAGAVI-KNBRGI2 (NARENDRA-2)	STATION NOT AFFECTED BELAGAVI_220	12:42	19:40	6:58	LINE FAULT
366	3-Aug-22	BAGALKOT	220	BELAGAVI-NARENDRA-1	STATION NOT AFFECTED BELAGAVI_220	11:27 (01.08.2022)	19:40 (03.08.2022)	56:13 hrs	LINE CHARGED
367	3-Aug-22	BAGALKOT	220	NARENDRA220-KNBRG1 (BELAGAVI 1 )	NARENDRA_220	11:27 (01.08.2022)	19:40 (03.08.2022)	56:13 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
368	3-Aug-22	BAGALKOT	220	NARENDRA-AMBEAWADI-1	STATION NOT AFFECTED NARENDRA_220	9:00	14:04	5:04	LINE FAULT
369	3-Aug-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
370	3-Aug-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
371	3-Aug-22	BAGALKOT	220	SIRSI-SHARAWATI-1	STATION NOT AFFECTED SIRSI_220	11:39	12:52	1:13	LINE CLEAR AVAILED
372	3-Aug-22	BENGALURU	66	BANASHANKARI - SUBRAMANYAPURA 220	BANASHANKARI	16:38	16:42	0:04	LOAD CHANGE OVER
373	3-Aug-22	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	11:07	11:10	0:03	LOAD CHANGE OVER
374	3-Aug-22	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	18:29	19:04	0:35	MAIN SUPPLY FAILURE
375	3-Aug-22	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	18:29	19:04	0:35	MAIN SUPPLY FAILURE
376	3-Aug-22	BENGALURU	66	BIDADI 220 - TPIPL (EHT)	TPIPL (EHT)	18:29	19:04	0:35	MAIN SUPPLY FAILURE
377	3-Aug-22	BENGALURU	66	CHAKAVELU - CHELUR	CHAKAVELU	5:00	5:15	0:15	LINE FAULT
378	3-Aug-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	NO STATION AFFECTED	18:59	19:21	0:22	LINE FAULT
379	3-Aug-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLI CROSS, YENIGADALE	8:20	8:27	0:07	LINE FAULT
380	3-Aug-22	BENGALURU	66	GANJIGUNTE - PALLICHERLU	PALLICHERLU	18:59	19:26	0:27	LINE FAULT
381	3-Aug-22	BENGALURU	66	GOKULA - SRS PEENYA 1 & 2 220	GOKULA, BEL (EHT), HMT (EHT), RMV, TATA INSTITUTE (EHT)	5:32	5:37	0:05	LOAD CHANGE OVER
382	3-Aug-22	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	19:05	19:10	0:05	LOAD CHANGE OVER
383	3-Aug-22	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	17:55	18:00	0:05	LOAD CHANGE OVER
384	3-Aug-22	BENGALURU	66	HV1	BIDADI 220	18:29	19:04	0:35	MAIN SUPPLY FAILURE
385	3-Aug-22	BENGALURU	66	HV1	BUDIKOTE	12:10	12:55	0:45	LINE CLEAR AVAILED
386	3-Aug-22	BENGALURU	66	HV1	DODDALAHALLI	17:34	17:48	0:14	TRANSFORMER FAULT
387	3-Aug-22	BENGALURU	66	HV1	KOLAR 220	1:12	2:36	1:24	MAIN SUPPLY FAILURE
388	3-Aug-22	BENGALURU	66	HV1	KOLAR 220	6:21	6:31	0:10	LOAD CHANGE OVER
389	3-Aug-22	BENGALURU	66	HV1	REMCO	10:26	10:33	0:07	LOAD CHANGE OVER
390	3-Aug-22	BENGALURU	66	HV1	SAMANDURU	17:56	18:05	0:09	TRANSFORMER FAULT
391	3-Aug-22	BENGALURU	66	HV1	SANKALGERE(BYRPATNA)	14:04	14:09	0:05	LINE CLEAR AVAILED
392	3-Aug-22	BENGALURU	66	HV1	SM MANGALA	1:48	1:59	0:11	TRANSFORMER FAULT
393	3-Aug-22	BENGALURU	66	HV1	VIJAYANAGARA	6:22	6:38	0:16	LOAD CHANGE OVER
394	3-Aug-22	BENGALURU	66	HV1	VIJAYANAGARA	9:15	9:23	0:08	LOAD CHANGE OVER
395	3-Aug-22	BENGALURU	66	HV1	VIJAYANAGARA	10:29	10:35	0:06	MAIN SUPPLY FAILURE
396	3-Aug-22	BENGALURU	66	HV2	BIDADI 220	18:29	19:04	0:35	MAIN SUPPLY FAILURE
397	3-Aug-22	BENGALURU	66	HV2	KOLAR 220	1:12	2:36	1:24	MAIN SUPPLY FAILURE
398	3-Aug-22	BENGALURU	66	HV2	KOLAR 220	6:21	6:31	0:10	LOAD CHANGE OVER
399	3-Aug-22	BENGALURU	66	HV2	REMCO	10:26	10:33	0:07	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
400	3-Aug-22	BENGALURU	66	HV2	VIJAYANAGARA	6:22	6:38	0:16	LOAD CHANGE OVER
401	3-Aug-22	BENGALURU	66	HV2	VIJAYANAGARA	9:15	9:23	0:08	LOAD CHANGE OVER
402	3-Aug-22	BENGALURU	66	HV3	BIDADI 220	18:25	18:40	0:15	LINE CLEAR AVAILED
403	3-Aug-22	BENGALURU	66	HV3	CHIKKABALLAPURA IND AREA	14:04	14:15	0:11	LINE CLEAR AVAILED
404	3-Aug-22	BENGALURU	66	HV3	ELECTRONIC CITY	12:15	14:04	1:49	TRANSFORMER FAULT
405	3-Aug-22	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	6:56	7:10	0:14	LINE FAULT
406	3-Aug-22	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	NO STATION AFFECTED	6:56	10:55	3:59	LINE FAULT
407	3-Aug-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA	1:12	3:10	1:58	MAIN SUPPLY FAILURE
408	3-Aug-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA	6:21	6:35	0:14	LOAD CHANGE OVER
409	3-Aug-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI, KC VALLEY (EHT)	1:12	2:36	1:24	MAIN SUPPLY FAILURE
410	3-Aug-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI, KC VALLEY (EHT)	6:21	6:31	0:10	LOAD CHANGE OVER
411	3-Aug-22	BENGALURU	66	KYALNUR - VEMGAL	KYALNUR	1:12	2:55	1:43	MAIN SUPPLY FAILURE
412	3-Aug-22	BENGALURU	66	KYALNUR - VEMGAL	KYALNUR	6:14	6:40	0:26	MAIN SUPPLY FAILURE
413	3-Aug-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	7:44	7:52	0:08	LOAD CHANGE OVER
414	3-Aug-22	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	7:40	8:14	0:34	LINE FAULT
415	3-Aug-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	5:19	6:01	0:42	LINE CLEAR AVAILED
416	3-Aug-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	10:30	11:05	0:35	LOAD CHANGE OVER
417	3-Aug-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	16:41	16:44	0:03	LOAD CHANGE OVER
418	3-Aug-22	BENGALURU	66	SIDLAGHATTA - CHINTAMANI 220	SIDLAGHATTA, MELUR	8:09	8:18	0:09	LINE FAULT
419	3-Aug-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	NO STATION AFFECTED	10:46	12:10	1:24	LINE FAULT
420	3-Aug-22	BENGALURU	66	VEMGAL - KOLAR 220	VEMGAL	1:12	2:55	1:43	MAIN SUPPLY FAILURE
421	3-Aug-22	BENGALURU	66	VEMGAL - TALAGAWARA	VEMGAL	6:15	6:35	0:20	LOAD CHANGE OVER
422	3-Aug-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	08:38:00(23/07/2022)			LINE OPEN,LINE FAULT
423	3-Aug-22	BENGALURU	220	HV2	BIDADI 220	18:29	18:57	0:28	LINE CLEAR AVAILED
424	3-Aug-22	BENGALURU	220	HV2	KOLAR 220	1:12	2:36	1:24	TRANSFORMER FAULT
425	3-Aug-22	GULBARGA	66	HV2	KUDLIGI_66	8:40	9:00	0:20	TRANSFORMER FAULT
426	3-Aug-22	GULBARGA	66	ITTAGI-HUVINAHADGALI	HUVINAHADGALI_66,HOLAGUNDI_66	21:05	21:15	0:10	LINE FAULT
427	3-Aug-22	GULBARGA	66	NEELAGUNDA-HP HALLI1	HP HALLI_66	6:10	6:18	0:08	LINE FAULT
428	3-Aug-22	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	15:30	15:40	0:10	LINE FAULT
429	3-Aug-22	GULBARGA	110	GHATARGA-SHAHBAD	GHATARGA_110	7:53	7:59	0:06	LINE FAULT
430	3-Aug-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	06:55 (26/07/2022)			LINE OPEN,LINE FAULT
431	3-Aug-22	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	18:41(03.08.2022)			LINE OPEN,LINE FAULT
432	3-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	6:03	6:08	0:05	LINE FAULT
433	3-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	6:13	6:20	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
434	3-Aug-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	05:20(3.088.2022)			LINE OPEN,LINE FAULT
435	3-Aug-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	0:12	4:27	4:15	LINE FAULT
436	3-Aug-22	GULBARGA	110	HUMNABAD-DUBALAGUNDI	DUBALAGUNDI_110	17:20	17:38	0:18	LINE FAULT
437	3-Aug-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN,LINE CLEAR AVAIED
438	3-Aug-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN,LINE CLEAR AVAIED
439	3-Aug-22	GULBARGA	110	HV1	MYLAR_110	12:05	13:10	1:05	LINE CLEAR AVAIED
440	3-Aug-22	GULBARGA	110	HV2	SREERAMANAGAR_110	9:00(02.08.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
441	3-Aug-22	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	14:57	16:13	1:16	LINE FAULT
442	3-Aug-22	GULBARGA	110	KEMBHAVI-ASKI	ASKI_110	13:20	13:40	0:20	LINE FAULT
443	3-Aug-22	GULBARGA	110	KUDLIGI-KOTTUR	KOTTUR_220	13:04	13:20	0:16	LINE FAULT
444	3-Aug-22	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110,CHOWDAPUR,AFZ ALPUR_110,KARAJAGI_110	4:20	4:33	0:13	LINE FAULT
445	3-Aug-22	GULBARGA	110	MALAT-SIRWAR	SIRWAR_110	11:57	12:15	0:18	LINE FAULT
446	3-Aug-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GANDHINAGAR_110	0:14	0:24	0:10	LINE FAULT
447	3-Aug-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GANDHINAGAR_110	11:57	12:15	0:18	LINE FAULT
448	3-Aug-22	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KE REHALLI_110,MALLAPUR_110	9:23	9:24	0:01	LINE CLEAR AVAIED
449	3-Aug-22	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	1:18	1:34	0:16	MAIN SUPPLY FAILURE
450	3-Aug-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	6:03	6:15	0:12	LINE FAULT
451	3-Aug-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:14	19:18	0:04	LINE FAULT
452	3-Aug-22	GULBARGA	110	RAICHUR-SINDHNOOR2	KURDICROSS_110,MADLAPUR_1 10,MANVI_110	2:24	2:30	0:06	LINE FAULT
453	3-Aug-22	GULBARGA	110	RAICHUR-SINDHNOOR2	KURDICROSS_110,MADLAPUR_1 10,MANVI_110	7:38	7:45	0:07	LINE FAULT
454	3-Aug-22	GULBARGA	110	RAICHUR-SINDHNOOR2	KURDICROSS_110,MADLAPUR_1 10,MANVI_110	14:32	16:25	1:53	LINE CLEAR AVAIED
455	3-Aug-22	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	6:15	6:31	0:16	LINE FAULT
456	3-Aug-22	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	5:28	6:30	1:02	LINE FAULT
457	3-Aug-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	5:25	5:40	0:15	LINE FAULT
458	3-Aug-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	5:50	5:55	0:05	LINE FAULT
459	3-Aug-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	6:05	6:31	0:26	LINE FAULT
460	3-Aug-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	7:50	7:55	0:05	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
461	3-Aug-22	GULBARGA	110	SHAHABAD-GULBARGAUNIVERSITY2	GULBARGAUNIVERSITY_110	4:30	4:35	0:05	LINE FAULT
462	3-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
463	3-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
464	3-Aug-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SANNATHI_IPP	12:03	12:57	0:54	NFBC ISSUED
465	3-Aug-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	15:32	18:55	3:23	LINE CLEAR AVAILED
466	3-Aug-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YARADONA_110,BENNUR_110,BTPAS WATER WORKS,KAMPLI_110	13:00	13:10	0:10	LINE FAULT
467	3-Aug-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	0:55	1:10	0:15	LINE FAULT
468	3-Aug-22	GULBARGA	110	SINDHNOOR-VALABELLARI	VALABELLARI_110,JAWALGERA_110,ADVAMRESHWAR_110	23:59(02.08.2022)	00:09(03.08.2022)	00:10HSR	LINE CHARGED
469	3-Aug-22	GULBARGA	110	SINDHNOOR-VALABELLARI	VALABELLARI_110,JAWALGERA_110,ADVAMRESHWAR_110	1:23	1:36	0:13	LINE FAULT
470	3-Aug-22	GULBARGA	110	WAJRABANDI-KUSHTAGI	WAJRABANDI_110,YELBURGA_110,KUKUNOOR_110	9:55	10:16	0:21	MAIN SUPPLY FAILURE
471	3-Aug-22	GULBARGA	110	YELBURGA-KUKUNOOR	KUKUNOOR_110	19:18	19:56	0:38	LINE CLEAR AVAILED
472	3-Aug-22	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMANABAD_220	4:36	7:16	2:40	LINE CLEAR AVAILED
473	3-Aug-22	GULBARGA	220	HV1 & LV1	SHAHAPUR_220	15:29	18:36	3:07	LINE CLEAR AVAILED
474	3-Aug-22	GULBARGA	220	ITTAGI-EMBASSY SOLAR_IPP	ITTAGI_220	13:02	15:50	2:48	LINE FAULT
475	3-Aug-22	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_110	14:23	20:13	5:50	LINE FAULT
476	3-Aug-22	GULBARGA	220	LINGSUGUR-RTPS2	RTPS_220	20:04	20:45	0:41	LINE FAULT
477	3-Aug-22	GULBARGA	220	SEDAM-HUMNABAD1	HUMANABAD_220	6:08	8:07	1:59	LINE FAULT
478	3-Aug-22	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLI_66	10:53	12:29	1:36	NFBC ISSUED
479	3-Aug-22	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	10:59	12:31	1:32	NFBC ISSUED
480	3-Aug-22	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATTANA_220	10:40	18:36	7:56	LINE CLEAR AVAILED
481	3-Aug-22	HASSAN	66	CRPATNA-SBELAGOLA2	CHANNARAYAPATTANA_220	7:30	7:40	0:10	LINE FAULT
482	3-Aug-22	HASSAN	66	HV1	BALLUPETE_66	15:10	16:16	1:06	LINE CLEAR AVAILED
483	3-Aug-22	HASSAN	66	HV1	BYACHANAHALLI_66	10:59	12:31	1:32	LINE CLEAR AVAILED
484	3-Aug-22	HASSAN	66	HV2	HALEBEEDU_66	14:44	15:12	0:28	LINE CLEAR AVAILED
485	3-Aug-22	HASSAN	66	HV2	HOLENARASIPURA_66	16:04	17:50	1:46	LINE CLEAR AVAILED
486	3-Aug-22	HASSAN	66	MATTNAV-CRPATNA	MATTANAVILE_66	12:04	19:13	7:09	NFBC ISSUED
487	3-Aug-22	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	10:55	12:05	1:10	LINE CLEAR AVAILED
488	3-Aug-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	10:42	13:00	2:18	NFBC ISSUED
489	3-Aug-22	HASSAN	110	HV1	HALADY_110	10:38	11:43	1:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
490	3-Aug-22	HASSAN	110	HV1	HIRENALLUR_110	13:15	19:50	6:35	LINE CLEAR AVAIED
491	3-Aug-22	HASSAN	110	HV1	KAVOOR_220	21:36(03.08.2022)			TRANSFORMER OPEN,LINE CLEAR AVAIED
492	3-Aug-22	HASSAN	110	HV1	KEMAR_220	14:52	15:06	0:14	TRANSFORMER FAULT
493	3-Aug-22	HASSAN	110	HV2	HALADY_110	12:13	13:02	0:49	LINE CLEAR AVAIED
494	3-Aug-22	HASSAN	110	HV2	KARAYA_110	15:03	15:15	0:12	HAND TRIPPED
495	3-Aug-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:42	13:00	2:18	LINE CLEAR AVAIED
496	3-Aug-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
497	3-Aug-22	HASSAN	220	GERSOPA-TALGUPA1	gen_gersoppa	11:12	18:32	7:20	LINE CLEAR AVAIED
498	3-Aug-22	HASSAN	220	GERSOPA-TALGUPA2	gen_gersoppa	12:34	16:25	3:51	LINE CLEAR AVAIED
499	3-Aug-22	HASSAN	220	KEMAR-BJP1	KEMAR_220	9:44	12:07	2:23	NFBC ISSUED
500	3-Aug-22	HASSAN	220	KEMAR-VARAH12	KEMAR_220	17:43(03.08.2022)			LINE OPEN,LINE FAULT
501	3-Aug-22	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	11:09	11:26	0:17	NFBC ISSUED
502	3-Aug-22	HASSAN	220	MRSSHM-STRP2	MRSMSG_220	11:12	18:32	7:20	LINE CLEAR AVAIED
503	3-Aug-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:21	13:24	4:03	LINE CLEAR AVAIED
504	3-Aug-22	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	9:44	12:07	2:23	LINE CLEAR AVAIED
505	3-Aug-22	HASSAN	220	SHRZVTY-SHIMOGA1	gen_sharavathy	11:09	11:26	0:17	LINE CLEAR AVAIED
506	3-Aug-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	12:33	16:24	3:51	LINE CLEAR AVAIED
507	3-Aug-22	HASSAN	220	VARAH1-KEMAR2	gen_varahi	17:43(03.08.2022)			LINE OPEN,LINE FAULT
508	3-Aug-22	HASSAN	220	VARAH1-SHIMOGA2	gen_varahi	9:21	13:24	4:03	LINE CLEAR AVAIED
509	3-Aug-22	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:27(02.08.2022)	6:39(03.08.2022)	7:11 hrs	LINE CHARGED
510	3-Aug-22	MYSURU	66	ADDIHALLY-B G NAGARA	BGNAGARA_66	0:40	0:50	0:10	LINE FAULT
511	3-Aug-22	MYSURU	66	BEGUR-NANJANGUD	NO STATIONS EFFECTED	20:15	20:20	0:05	LINE FAULT
512	3-Aug-22	MYSURU	66	BETTADAPURA-CHUNCHANAKATTE	KITTUR_66 RAVANDUR_66	10:03	13:16	3:12	LINE CLEAR AVAIED
513	3-Aug-22	MYSURU	66	BG NAGARA-HIRISAVE	KADBALLI_66	0:40	0:52	0:12	LINE FAULT
514	3-Aug-22	MYSURU	66	BG NAGARA-HIRISAVE	KADBALLI_66	11:36	11:45	0:08	HAND TRIPPED
515	3-Aug-22	MYSURU	66	BG NAGARA-HIRISAVE	KADBALLI_66	19:00	19:05	0:05	HAND TRIPPED
516	3-Aug-22	MYSURU	66	BG NAGARA-NAGMANGALA	KADBALLI_66 BGNAGARA_66	0:18	0:30	0:11	LINE FAULT
517	3-Aug-22	MYSURU	66	BG NAGARA-YEDIYUR	ADICHUNCHANAGIRI_66 VADERALLI_66	0:18	1:03	0:44	LINE FAULT
518	3-Aug-22	MYSURU	66	CHIKKMANDYA-MANDYA	CHIKKMANDYA_66 HAMPAPURA_66	22:38:00 (2.08.2022)	6:16:00 (3.08.2022)	7:38HRS	LINE CHARGED
519	3-Aug-22	MYSURU	66	HD KOTE-TARAKA	NO STATIONS EFFECTED	5:43	5:56	0:12	LINE FAULT
520	3-Aug-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
521	3-Aug-22	MYSURU	66	HEBBANI-MEGALAPURA	CHIDRAVALI_66THUMBLA_66M EGALAPURA_66BGPURA_66CHA NDALLI_66GARGESHWARI_66PA RINAMIPURA_66THALAKADU_66 THUMBLA_66VYASRAJPURA_66T NARASIPURA_66	0:16	6:16	6:00	LINE FAULT
522	3-Aug-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
523	3-Aug-22	MYSURU	66	HV1	BEGUR_66	11:15	12:25	1:10	LINE CLEAR AVAILED
524	3-Aug-22	MYSURU	66	HV1	COWDALLI_66	18:06	19:15	1:08	TRANSFORMER FAULT
525	3-Aug-22	MYSURU	66	HV1	DEVANOORNGUDU_66	4:02	4:10	0:08	TRANSFORMER FAULT
526	3-Aug-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
527	3-Aug-22	MYSURU	66	HV2	COWDALLI_66	18:25	19:15	0:50	LINE CLEAR AVAILED
528	3-Aug-22	MYSURU	66	HV2	HAMPAPURA_66	20:27:42 (3.8.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
529	3-Aug-22	MYSURU	66	KADAKOLA-SARGUR 1	NO STATIONS EFFECTED	0:23	0:28	0:05	LINE FAULT
530	3-Aug-22	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	BILIKERE_66 BHERYA_66KRNAGARA_66GVGU DI_66DMG_HALLI_66 MIRLE_66CHUNCHUNKATTE_66K HB_66	10:27	13:31	3:04	LINE CLEAR AVAILED
531	3-Aug-22	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-1	PERIYAPATNA_66HANAGODU_6 6KAMPLAPURA_66PONNAMPET _66VIRAJPET_66	17:30	17:36	0:06	LINE FAULT
532	3-Aug-22	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-2	BYLUKUPPE_66	17:24	17:36	0:11	LINE FAULT
533	3-Aug-22	MYSURU	66	KUSHALNAGARA 220- RAMANATHAPURA1	KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66	6:13	6:19	0:05	LINE FAULT
534	3-Aug-22	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	PGPALYA_66 LOKKANAHALLI_66	6:07	6:12	0:04	LINE FAULT
535	3-Aug-22	MYSURU	66	NAGAMANGALA 220-KASALGERE	NO STATIONS EFFECTED	14:14	14:19	0:05	HAND TRIPPED
536	3-Aug-22	MYSURU	66	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	14:14	14:19	0:05	HAND TRIPPED
537	3-Aug-22	MYSURU	66	NANJANGUDU-KADAKOLA	NANJANGUDU_66	13:23	14:37	1:14	LINE CLEAR AVAILED
538	3-Aug-22	MYSURU	66	NANJANGUDU-SINDHUVALLI	NO STATIONS EFFECTED	13:23	14:37	1:14	LINE CLEAR AVAILED
539	3-Aug-22	MYSURU	66	PONNAMPETE-HANGODU	PONNAMPETE_66	11:01	15:55	4:54	LINE CLEAR AVAILED
540	3-Aug-22	MYSURU	66	PONNAMPETE-VIRAJPETE	VIRAJPETE_66	11:01	15:56	4:54	LINE CLEAR AVAILED
541	3-Aug-22	MYSURU	66	VAJMANGALA-MEGALAPURA	TNARASIPURA_66MEGALAPURA _66THUMBLA_66VYASRAJPURA_ 66GARGESHWARI_66CHIDRAVAL LI_66	6:00	6:11	0:11	LINE FAULT
542	3-Aug-22	MYSURU	66	YEREHALLI -HD KOTE	ANTHARSANTHE_66HDKOTE_66	5:40	5:50	0:10	LINE FAULT
543	3-Aug-22	MYSURU	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
544	3-Aug-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
545	3-Aug-22	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	13:15	17:07	3:52	LINE FAULT
546	3-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	10:11	10:23	0:12	LINE FAULT
547	3-Aug-22	TUMKUR	66	ANTHRASANAHALI 220KV- KORA	KORA_66, THOVINAKERE_66	20:25	20:45	0:19	LINE FAULT
548	3-Aug-22	TUMKUR	66	BHARAMASAGARA-CHITRADURGA	BHARAMASAGARA_66	9:15	18:33	9:18	MAIN SUPPLY FAILURE
549	3-Aug-22	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:07	16:29	6:21	LINE CLEAR AVAILED
550	3-Aug-22	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66 ,KADAJJI_66	6:05	6:19	0:13	LINE FAULT
551	3-Aug-22	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	9:25	9:30	0:05	MAIN SUPPLY FAILURE
552	3-Aug-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:06	11:09	0:02	LINE FAULT
553	3-Aug-22	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	4:05	4:16	0:11	LINE FAULT
554	3-Aug-22	TUMKUR	66	HONNALLI-HONNALLI	HONNALLI_66, KATTIGE_66	16:37	16:46	0:09	LINE FAULT
555	3-Aug-22	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI	MEDIGESHI_66	11:51	12:41	0:49	LINE CLEAR AVAILED
556	3-Aug-22	TUMKUR	66	MADHUGIRI 220kV- PULLAMAGATTA	PULLAMGATTA_66	17:03	17:09	0:06	LINE FAULT
557	3-Aug-22	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	7:56	8:39	0:43	LINE FAULT
558	3-Aug-22	TUMKUR	66	THALLAK 220kV - BGKERE 1	BGKERE_66	9:44	9:56	0:12	LINE FAULT
559	3-Aug-22	TUMKUR	66	THALLAK 220kV - BGKERE 2	BGKERE_66	9:44	9:57	0:13	LINE FAULT
560	3-Aug-22	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1 & 2	WELSPUNSOLAR1&2_IPP_66	13:42	13:50	0:08	LINE FAULT
561	3-Aug-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	5:36	5:39	0:02	TRANSFORMER FAULT
562	3-Aug-22	TUMKUR	66	TR-1	LINGADAHALLI_66	12:08	12:53	0:44	LINE CLEAR AVAILED
563	3-Aug-22	TUMKUR	66	TR-1	MADHUGIRI_220	14:31	14:39	0:07	TRANSFORMER FAULT
564	3-Aug-22	TUMKUR	66	TR-1	RANGANATHAPURA_66	13:19	14:05	0:46	TRANSFORMER FAULT
565	3-Aug-22	TUMKUR	66	TR-1	TYAVANAGI_66	4:18	7:53	3:35	TRANSFORMER FAULT
566	3-Aug-22	TUMKUR	66	TR-2	GULIGENAHALLI_66	11:49	15:55	4:05	LINE CLEAR AVAILED
567	3-Aug-22	TUMKUR	66	TR-2	HOSAKERE_66(M)	11:04	11:40	0:35	LINE CLEAR AVAILED
568	3-Aug-22	TUMKUR	66	TR-2	KOLALA_66	4:39	4:49	0:10	TRANSFORMER FAULT
569	3-Aug-22	TUMKUR	66	TR-2	SANEKERE_66	13:39	13:50	0:11	LINE CLEAR AVAILED
570	3-Aug-22	TUMKUR	66	TR-3	HOLALKERE_66	12:30	14:24	1:54	LINE CLEAR AVAILED
571	3-Aug-22	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	0:02	0:15	0:12	LINE FAULT
572	3-Aug-22	TUMKUR	110	TR-2(HV2)	MAYASANDRA_110	15:56	17:29	1:32	LINE CLEAR AVAILED
573	3-Aug-22	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 2	PAVAGADA_220	2:28	9:08	6:39	LINE FAULT
574	3-Aug-22	TUMKUR	220	TR-3	KBCROSS_220	15:07	21:05	5:57	LINE CLEAR AVAILED
575	4-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED AEQUS_220	21:09 (30.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
576	4-Aug-22	BAGALKOT	110	110/11KV, HV-2	STATION NOT AFFECTED TILUVALLI_110	13:25	14:00	0:35	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
577	4-Aug-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	7:28 (29.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
578	4-Aug-22	BAGALKOT	110	110/11KV, HV-3	STATION NOT AFFECTED SVANUR_110	13:00	14:05	1:05	LINE CLEAR AVAILED
579	4-Aug-22	BAGALKOT	110	110/11KV, HV-3	STATION NOT AFFECTED TILUVALLI_110	13:25	13:49	0:24	TRANSFORMER FAULT
580	4-Aug-22	BAGALKOT	110	110/11KV,HV1	DADDI_110	10:13	11:45	1:32	LINE CLEAR AVAILED
581	4-Aug-22	BAGALKOT	110	110/11KV,HV2	KAMBAGI_110	17:39	17:49	0:10	TRANSFORMER FAULT
582	4-Aug-22	BAGALKOT	110	110/11KV,HV2	LAKAMANAHALLI_110	17:25	20:25	3:00	LINE CLEAR AVAILED
583	4-Aug-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAKAMANAHALLI_110	11:30	14:30	3:00	LINE CLEAR AVAILED
584	4-Aug-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED SHIRAGUPPI_110	12:30	12:50	0:20	LINE CLEAR AVAILED
585	4-Aug-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
586	4-Aug-22	BAGALKOT	110	110/11KV,HV2	THORVI_110	17:07	17:12	0:05	TRANSFORMER FAULT
587	4-Aug-22	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	14:18 (2.8.22)	18:45 (4.8.2022)	52:27 hrs	TRANSFORMER CHARGED
588	4-Aug-22	BAGALKOT	110	110/33KV, HV-3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
589	4-Aug-22	BAGALKOT	110	110/33KV,HV4	ZALAKI_110 & DHULKHED,NEVARAGI&HALSAN GI_33	12:08	12:11	0:03	TRANSFORMER FAULT
590	4-Aug-22	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MUGALKHOD_220	2:53	13:14	10:21	TRANSFORMER FAULT
591	4-Aug-22	BAGALKOT	110	AIGALI-SAVALAGI	AIGALI_110	13:23	14:19	0:56	HAND TRIPPED
592	4-Aug-22	BAGALKOT	110	ALMEL-KPR &JAMAKHANDI SUGARS	ALMEL_110	20:23	20:42	0:19	HAND TRIPPED
593	4-Aug-22	BAGALKOT	110	ALMEL-KPR &JAMAKHANDI SUGARS	ALMEL_110	23:27	23:29	0:02	LINE FAULT
594	4-Aug-22	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	16:20	17:27	1:07	LINE CLEAR AVAILED
595	4-Aug-22	BAGALKOT	110	BAGEWADI-MUKARTIHAL	MUKARTIHAL_110	11:57	17:41	5:44	LINE CLEAR AVAILED
596	4-Aug-22	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	16:20	17:36	1:16	LINE CLEAR AVAILED
597	4-Aug-22	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	12:43	13:45	1:02	LINE CLEAR AVAILED
598	4-Aug-22	BAGALKOT	110	CHANDKAVATE-ALMEL	ALMEL_110	6:28	6:31	0:03	LINE FAULT
599	4-Aug-22	BAGALKOT	110	CHANDKAVATE-ALMEL	ALMEL_110	23:12	23:22	0:10	LINE FAULT
600	4-Aug-22	BAGALKOT	110	DAVALESHWAR-SAIDAPUR	SAIDAPUR_110	0:16	0:24	0:08	LINE FAULT
601	4-Aug-22	BAGALKOT	110	HAVERI220- SAVANUR	SAVANUR_110	6:31	6:52	0:21	LINE FAULT
602	4-Aug-22	BAGALKOT	110	MAHALINGAPUR220-HIDAKAL	HIDAKAL_110	11:01	11:12	0:11	HAND TRIPPED
603	4-Aug-22	BAGALKOT	110	MAHALINGAPUR220-RABAKAVI	RABAKAVI_110	11:01	11:12	0:11	HAND TRIPPED
604	4-Aug-22	BAGALKOT	110	MAMADAPUR-BABALESHWAR	BABALESHWAR_110	5:38	6:11	0:33	LINE FAULT
605	4-Aug-22	BAGALKOT	110	NARENDRA- UAS DHARAWAD	UAS DHARWAD_110	11:11	13:20	2:09	LINE CLEAR AVAILED
606	4-Aug-22	BAGALKOT	110	NARENDRA220- MRITHJAYNGR2 (UAS DHARWAD)	STATION NOT AFFECTED NARENDRA_220	11:11	13:20	2:09	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
607	4-Aug-22	BAGALKOT	110	SAVANUR-AFT (ASIAN FEBTECH SOLAR )	ASIAN FEB SOLAR_110 STATION NOT AFFECTED SVANUR_110	6:30	7:05	0:35	LINE FAULT
608	4-Aug-22	BAGALKOT	110	SAVANUR-SHIGGAON	SHIGGAON_110	6:28	6:55	0:27	HAND TRIPPED
609	4-Aug-22	BAGALKOT	110	TODALABAGI-SAVALAGI	SAVALAGI-110	11:10	14:09	2:59	LINE CLEAR AVAILED
610	4-Aug-22	BAGALKOT	110	UTTUR - F1 JAMB CB( MUDHOL)	STATION NOT AFFECTED UTTUR_110	9:51 (24.07.2022)			LINE OPEN,LINE CLEAR AVAILED
611	4-Aug-22	BAGALKOT	220	220/110KV, HV-1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
612	4-Aug-22	BAGALKOT	220	220/110KV, HV2 , LV2	STATION NOT AFFECTED VIJAYPUR_220	17:44	22:35	4:51	TRANSFORMER FAULT
613	4-Aug-22	BAGALKOT	220	220/110KV, HV2 , LV2	STATION NOT AFFECTED VIJAYPUR_220	23:29 (04.08.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
614	4-Aug-22	BAGALKOT	220	220/110KV, HV3 & LV3	STATION NOT AFFECTED MAHALINGAPUR_220	11:01	11:12	0:11	HAND TRIPPED
615	4-Aug-22	BAGALKOT	220	220/110KV, HV-3 & LV-3	STATION NOT AFFECTED ATHANI_220	10:26 (25.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
616	4-Aug-22	BAGALKOT	220	220/110KV, HV4 & LV4	STATION NOT AFFECTED GADAG_220	12:35	13:34	0:59	LINE CLEAR AVAILED
617	4-Aug-22	BAGALKOT	220	AMBEAWADI -PONDA-2	STATION NOT AFFECTED AMBEWADI_220	18:36 (03.08.2022)	16:25 (04.08.2022)	21:49 hrs	LINE CHARGED
618	4-Aug-22	BAGALKOT	220	AMBEWADI-NAGJHARI-2	STATION NOT AFFECTED AMBEWADI_220	16:08	16:33	0:25	LINE FAULT
619	4-Aug-22	BAGALKOT	220	AMBEWADI-NARENDRA-1	STATION NOT AFFECTED AMBEWADI_220	17:23 (04.08.2022)			LINE OPEN,LINE CLEAR AVAILED
620	4-Aug-22	BAGALKOT	220	BAGALAKOT-VAJRAMATTI-1	STATION NOT AFFECTED BAGALKOT_220	17:48 (02.08.2022)			LINE OPEN,LINE CLEAR AVAILED
621	4-Aug-22	BAGALKOT	220	BELAGAVI-KNRB-1 (NARENDRA-2)	STATION NOT AFFECTED BELAGAVI_220	4:58	5:44	0:46	LINE FAULT
622	4-Aug-22	BAGALKOT	220	BELAGAVI-KNRB-1 (NARENDRA-2)	STATION NOT AFFECTED BELAGAVI_220	9:13	17:53	8:40	NFBC ISSUED
623	4-Aug-22	BAGALKOT	220	HAVERI220-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:12	18:00	6:48	NFBC ISSUED
624	4-Aug-22	BAGALKOT	220	HUBLI-NAGZARI-3	STATION NOT AFFECTED HUBLI_220	10:28	15:52	5:24	NFBC ISSUED
625	4-Aug-22	BAGALKOT	220	NARENDRA-AMBEWADI-1	STATION NOT AFFECTED NARENDRA_220	17:17 (04.08.2022)			LINE OPEN,LINE CLEAR AVAILED
626	4-Aug-22	BAGALKOT	220	NARENDRA-BELAGAVI-2	STATION NOT AFFECTED NARENDRA_220	20:35 (03.08.2022)	17:53 (04.08.2022)	21:18HRS	LINE CHARGED
627	4-Aug-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
628	4-Aug-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
629	4-Aug-22	BAGALKOT	220	SIRSI-SHARAWATI 1	SIRSI_220	14:29	15:58	1:29	LINE CLEAR AVAILED
630	4-Aug-22	BAGALKOT	220	SIRSI-SHARAWATI 1	STATION NOT AFFECTED SIRSI_220	11:39	12:51	1:12	LINE CLEAR AVAILED
631	4-Aug-22	BAGALKOT	220	SIRSI-SHARAWATI 2	SIRSI_220	12:07	13:30	1:23	LINE CLEAR AVAILED
632	4-Aug-22	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	10:02	10:07	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
633	4-Aug-22	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	8:14	8:30	0:16	MAIN SUPPLY FAILURE
634	4-Aug-22	BENGALURU	66	HV1	ANDERSONPET	14:01	14:14	0:13	LINE CLEAR AVAILED
635	4-Aug-22	BENGALURU	66	HV2	BOODIGERE	11:30	11:35	0:05	LINE CLEAR AVAILED
636	4-Aug-22	BENGALURU	66	HV2	GANJIGUNTE	6:59	7:06	0:07	TRANSFORMER FAULT
637	4-Aug-22	BENGALURU	66	HV2	IRGAMPALLI	17:30	17:50	0:20	TRANSFORMER FAULT
638	4-Aug-22	BENGALURU	66	HV4	NRS 220	20:50	20:57	0:07	TRANSFORMER FAULT
639	4-Aug-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	5:17	5:29	0:12	LINE FAULT
640	4-Aug-22	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	13:40	14:15	0:35	LINE CLEAR AVAILED
641	4-Aug-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADAHOSAHALLI	18:55	19:00	0:05	LINE FAULT
642	4-Aug-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	11:23	11:29	0:06	LINE FAULT
643	4-Aug-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	7:24	7:29	0:05	LOAD CHANGE OVER
644	4-Aug-22	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	13:29	13:34	0:05	LOAD CHANGE OVER
645	4-Aug-22	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	22:10	22:14	0:04	LOAD CHANGE OVER
646	4-Aug-22	BENGALURU	66	SRS PEENYA 220 - DG2	BIEC	8:14	9:59	1:45	LINE FAULT
647	4-Aug-22	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	16:46	17:58	1:12	LINE FAULT
648	4-Aug-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	08:38:00(23/07/2022)			LINE OPEN,LINE FAULT
649	4-Aug-22	BENGALURU	220	HV2	KUMBALAGODU	3:09	7:47	4:38	TRANSFORMER FAULT
650	4-Aug-22	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66,HARVI_66	6:10	6:15	0:05	MAIN SUPPLY FAILURE
651	4-Aug-22	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66, HOSAHALLI_66	12:35	13:20	0:45	LINE CLEAR AVAILED
652	4-Aug-22	GULBARGA	66	KUDLIGI-HANASI	KUDLIGI_66	5:20	5:30	0:10	LINE FAULT
653	4-Aug-22	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI_66,YARAGUNTA_66	11:10	12:30	1:20	LINE CLEAR AVAILED
654	4-Aug-22	GULBARGA	110	ALIPUR-BELLARY SOUTH	BELLARY SOUTH_110,HALKUNDI_110	9:30	17:48	8:18	LINE CLEAR AVAILED
655	4-Aug-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS	9:30	17:50	8:20	LINE CLEAR AVAILED
656	4-Aug-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110 ,KURUGOD_110,SHATAVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP, KAMLAPUR_IPP,MATR_110,RBNS FACTORY,SIRIGERA CROSS_110	9:30	17:50	8:20	LINE CLEAR AVAILED
657	4-Aug-22	GULBARGA	110	CHIDRI-HALBARGA	CHIDRI_110	15:25	16:40	1:15	MAIN SUPPLY FAILURE
658	4-Aug-22	GULBARGA	110	GHATARGA-SHAHBAD	GHATARGA_110	18:40	18:45	0:05	LINE FAULT
659	4-Aug-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	06:55 (26/07/2022)	17:04(4.08.2022)	226:09HRS	LINE CHARGED
660	4-Aug-22	GULBARGA	110	HALBARGA-CHIDRI 2	CHIDRI_110	15:23	16:05	0:42	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
661	4-Aug-22	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	18:41(03.08.2022)	16:40(4.08.2022)	21:59HRS	LINE CHARGED
662	4-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	6:05	6:11	0:06	LINE FAULT
663	4-Aug-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
664	4-Aug-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
665	4-Aug-22	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	21:01	21:15	0:14	MAIN SUPPLY FAILURE
666	4-Aug-22	GULBARGA	110	HUNASAGI-KEMBHAVI	HUNASAGI_110	22:00	22:15	0:15	MAIN SUPPLY FAILURE
667	4-Aug-22	GULBARGA	110	HV1	BENNUR_110	9:00	9:10	0:10	TRANSFORMER FAULT
668	4-Aug-22	GULBARGA	110	HV2	SREERAMANAGAR_110	9:00(02.08.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
669	4-Aug-22	GULBARGA	110	HV3	KEMBHAVI_110	10:05	10:20	0:15	TRANSFORMER FAULT
670	4-Aug-22	GULBARGA	110	HV3	KEMBHAVI_110	10:35	11:15	0:40	TRANSFORMER FAULT
671	4-Aug-22	GULBARGA	110	HV3	KEMBHAVI_110	12:30	13:35	1:05	TRANSFORMER FAULT
672	4-Aug-22	GULBARGA	110	HV3	KEMBHAVI_110	14:05	14:40	0:35	TRANSFORMER FAULT
673	4-Aug-22	GULBARGA	110	HV3	VALKAMDINNI_110	12:51	12:57	0:06	TRANSFORMER FAULT
674	4-Aug-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	21:22	21:29	0:07	LINE FAULT
675	4-Aug-22	GULBARGA	110	KEMBHAVI-ASKI	ASKI_110	11:25	11:50	0:25	LINE FAULT
676	4-Aug-22	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	21:00	21:15	0:15	LINE FAULT
677	4-Aug-22	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	22:00	22:15	0:15	LINE FAULT
678	4-Aug-22	GULBARGA	110	KEMBHAVI-UGAR SUGAR_IPP	KEMBHAVI_110	5:45	5:55	0:10	LINE FAULT
679	4-Aug-22	GULBARGA	110	KEMBHAVI-UGAR SUGAR_IPP	KEMBHAVI_110	23:15	23:35	0:20	LINE FAULT
680	4-Aug-22	GULBARGA	110	MALLAT-KKAVITHAL	KAVITHAL_110	20:13	20:24	0:11	LINE FAULT
681	4-Aug-22	GULBARGA	110	MALLAT-KKAVITHAL	KAVITHAL_110	20:40	20:50	0:10	LINE FAULT
682	4-Aug-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	22:15	22:25	0:10	LINE FAULT
683	4-Aug-22	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	20:22	20:32	0:10	LINE FAULT
684	4-Aug-22	GULBARGA	110	MUDGAL-BAYYAPURA	BAYYAPURA_110	17:45	18:33	0:48	LOAD CURTAILMENT
685	4-Aug-22	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	18:43	18:55	0:12	LINE FAULT
686	4-Aug-22	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	9:30	18:10	8:40	MAIN SUPPLY FAILURE
687	4-Aug-22	GULBARGA	110	PDHALLI-BELLARY NORTH	PD_HALLI_110	10:03	16:10	6:07	LINE CLEAR AVAILED
688	4-Aug-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	5:40	5:45	0:05	LINE FAULT
689	4-Aug-22	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	6:55	7:10	0:15	LINE FAULT
690	4-Aug-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	18:48	18:51	0:03	LINE FAULT
691	4-Aug-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	18:40	20:28	1:48	LINE FAULT
692	4-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
693	4-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
694	4-Aug-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_220	23:50	23:57	0:07	LINE FAULT
695	4-Aug-22	GULBARGA	110	SHAHAPUR-WARAD SOLAR_IPP	SHAHAPUR_220	8:25	8:32	0:07	LINE FAULT
696	4-Aug-22	GULBARGA	110	SHAHAPUR-YADGIR	SAIDAPUR_110,YADGIR_110	13:05	15:30	2:25	LINE CLEAR AVAILED
697	4-Aug-22	GULBARGA	110	SHAKTINAGAR-RAICHURBIO	SHAKTINAGAR_110	19:30	19:38	0:08	LINE FAULT
698	4-Aug-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YARADONA_110 ,BENNUR_110,BTPAS WATER WORKS,KAMPLI_110	18:45	18:55	0:10	LINE FAULT
699	4-Aug-22	GULBARGA	110	SINDHNOOR-VALABELLARI	VALABELLARI_110,JAWALGERA_ 110,ADVIAMRESHWAR_110	5:55	6:10	0:15	LINE FAULT
700	4-Aug-22	GULBARGA	220	ALLIPUR-BTPS	ALIPUR_220	9:35	18:00	8:25	LINE CLEAR AVAILED
701	4-Aug-22	GULBARGA	220	ALLIPUR-RAGALAPADU	ALIPUR_220	9:30	17:45	8:15	LINE CLEAR AVAILED
702	4-Aug-22	GULBARGA	220	HV1	ALIPUR_220	10:00	17:30	7:30	LINE CLEAR AVAILED
703	4-Aug-22	GULBARGA	220	HV1	ITTAGI_220	10:45(04.08.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
704	4-Aug-22	GULBARGA	220	HV2	ALIPUR_220	10:27	18:25	7:58	LINE CLEAR AVAILED
705	4-Aug-22	GULBARGA	220	ITTAGI-BMM ISPAT	BMM ISPAT_220	13:05	16:52	3:47	LINE CLEAR AVAILED
706	4-Aug-22	GULBARGA	220	LINGASUGUR- SHAHAPUR	SHAHAPUR_220	19:44	19:53	0:09	LINE FAULT
707	4-Aug-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	19:48	19:51	0:03	LINE FAULT
708	4-Aug-22	HASSAN	66	AREHALI-SAKLESPUR	AREHALI_66	11:24	13:36	2:12	NFBC ISSUED
709	4-Aug-22	HASSAN	66	BHADRA-LINGADAHALLI	gen_bhadra	8:01	8:15	0:14	LINE FAULT
710	4-Aug-22	HASSAN	66	HV1	SINGAPURA_66	12:27	13:05	0:38	LINE CLEAR AVAILED
711	4-Aug-22	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	10:41	15:15	4:34	LINE CLEAR AVAILED
712	4-Aug-22	HASSAN	66	SAKALE-HANBAL	SAKALESHPURA_66	11:24	13:31	2:07	LINE CLEAR AVAILED
713	4-Aug-22	HASSAN	66	UDYAP-BAGUR	UDAYAPURA_66	11:12	11:52	0:40	LINE CLEAR AVAILED
714	4-Aug-22	HASSAN	66	UDYAP-SATHENAHALLI	UDAYAPURA_66	11:12	11:52	0:40	LINE CLEAR AVAILED
715	4-Aug-22	HASSAN	110	GAJNUR-OUTGOING LINE	GAJNUR_110	10:32	16:08	5:36	LINE CLEAR AVAILED
716	4-Aug-22	HASSAN	110	HV1	HOSANGADI_110	12:31	13:37	1:06	TRANSFORMER FAULT
717	4-Aug-22	HASSAN	110	HV1	KAVOOR_220	21:36(03.08.2022)	14:31(04.08.2022)	17:05HRS	TRANSFORMER CHARGED
718	4-Aug-22	HASSAN	110	HV1	SHIKARIPURA_110	17:16	18:08	0:52	LINE CLEAR AVAILED
719	4-Aug-22	HASSAN	110	HV2	ANANDAPURA_110	21:49	22:09	0:20	TRANSFORMER FAULT
720	4-Aug-22	HASSAN	110	KADUR-AJAMPURA	KADUR_220	18:50	19:24	0:34	LINE FAULT
721	4-Aug-22	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	11:08	14:47	3:39	LINE CLEAR AVAILED
722	4-Aug-22	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	10:23	12:19	1:56	LINE CLEAR AVAILED
723	4-Aug-22	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	17:35	17:50	0:15	LINE FAULT
724	4-Aug-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	11:06	11:26	0:20	LINE CLEAR AVAILED
725	4-Aug-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:46	13:54	0:08	MAIN SUPPLY FAILURE
726	4-Aug-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:46	13:54	0:08	MAIN SUPPLY FAILURE
727	4-Aug-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:46	13:54	0:08	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
728	4-Aug-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:46	13:54	0:08	MAIN SUPPLY FAILURE
729	4-Aug-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	13:46	13:55	0:09	MAIN SUPPLY FAILURE
730	4-Aug-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
731	4-Aug-22	HASSAN	220	CRPATNA-MATTANAVILE	CRPATNA-:220	9:19	9:40	0:21	LINE CLEAR AVAILED
732	4-Aug-22	HASSAN	220	KADUR-DABUSET	KADUR_220	16:47	20:39	3:52	LINE FAULT
733	4-Aug-22	HASSAN	220	KEMAR-Varahi2	KEMAR_220	17:43(03.08.2022)	10:30(04.08.2022)	16:47HRS	LINE CHARGED
734	4-Aug-22	HASSAN	220	MRSSHM-SHARAVATHY1	SHIRALKOPPA_220	10:46	16:18	5:32	LINE CLEAR AVAILED
735	4-Aug-22	HASSAN	220	MRSSHM-VARAH13	SHIRALKOPPA_220	11:08	15:50	4:42	LINE CLEAR AVAILED
736	4-Aug-22	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	10:46	16:18	5:32	LINE CLEAR AVAILED
737	4-Aug-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	13:46	19:46	6:00	LINE FAULT
738	4-Aug-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	13:46	19:46	6:00	LINE FAULT
739	4-Aug-22	HASSAN	220	VARAHI-KEMAR2	gen_varahi	17:43(03.08.2022)	10:30(04.08.2022)	16:47HRS	LINE CHARGED
740	4-Aug-22	HASSAN	220	VARAHI-SHMG3	gen_varahi	11:08	15:50	4:42	LINE CLEAR AVAILED
741	4-Aug-22	HASSAN	400	UPCL-HASSAN2	gen_upcl	0:04	6:32	6:28	LINE CLEAR AVAILED
742	4-Aug-22	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	10:28	16:50	6:22	NFBC ISSUED
743	4-Aug-22	MYSURU	66	CR NAGARA-HONGANUR	HONGANUR_66YELANDUR_66	11:39	11:47	0:07	LINE FAULT
744	4-Aug-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
745	4-Aug-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
746	4-Aug-22	MYSURU	66	HOOTAGALLI-KAGGERE HAMPAPURA	KAGGERE HAMPAPURA_66	18:50	19:06	0:16	LINE FAULT
747	4-Aug-22	MYSURU	66	HV1	DATTAGALLY_66	11:58	16:43	4:44	LINE CLEAR AVAILED
748	4-Aug-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
749	4-Aug-22	MYSURU	66	HV1	HAMPAPURA_66	9:25	9:30	0:05	HAND TRIPPED
750	4-Aug-22	MYSURU	66	HV1	MALAVALLI_66	13:11	16:17	3:05	LINE CLEAR AVAILED
751	4-Aug-22	MYSURU	66	HV2	BGNAGARA_66	12:49	13:58	1:09	LINE CLEAR AVAILED
752	4-Aug-22	MYSURU	66	HV2	DKMAIDANA_66	9:45	15:33	5:48	LINE CLEAR AVAILED
753	4-Aug-22	MYSURU	66	HV2	HAMPAPURA_66	20:27:42 (3.8.2022)	10:57:00 (4.8.2022)	14:29HRS	TRANSFORMER CHARGED
754	4-Aug-22	MYSURU	66	KR NAGARA-BILIKERE	NO STATIONS EFFECTED	13:10:58 (4.8.2022)			LINE OPEN,LINE CLEAR AVAILED
755	4-Aug-22	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66	10:35	16:26	5:51	LINE CLEAR AVAILED
756	4-Aug-22	MYSURU	66	MADHUVANAHALI-KUNTHUR	NO STATIONS EFFECTED	6:17	6:22	0:04	LINE FAULT
757	4-Aug-22	MYSURU	66	MADHUVANAHALI-LOKKANAHALI	LOKKANAHALI_66PG PALYA_66	18:24	18:30	0:05	LINE FAULT
758	4-Aug-22	MYSURU	66	NANJANGUDU-SINDUVALLI	NO STATIONS EFFECTED	22:27	22:37	0:09	LINE FAULT
759	4-Aug-22	MYSURU	66	SR PATNA-HV1	SRIRANGAPATNA_66	10:09	10:15	0:05	LINE FAULT
760	4-Aug-22	MYSURU	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	13:46	14:05	0:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
761	4-Aug-22	MYSURU	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
762	4-Aug-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
763	4-Aug-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	7:01	17:51	10:49	LINE CLEAR AVAILED
764	4-Aug-22	TUMKUR	66	ANTHRASANAHALI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	17:08	17:28	0:20	LINE FAULT
765	4-Aug-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	14:35	14:54	0:18	LINE FAULT
766	4-Aug-22	TUMKUR	66	DASUDI-66INCOMER HIRIYUR	DASUDI_66	16:30	16:32	0:01	LINE CLEAR AVAILED
767	4-Aug-22	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	14:20	14:32	0:12	LINE FAULT
768	4-Aug-22	TUMKUR	66	HIRIYURkv 220kv- SUZLON 1	SUZLON1_IPP_66	7:20	7:50	0:30	LINE FAULT
769	4-Aug-22	TUMKUR	66	HIRIYURkv 220kv- SUZLON 2	SUZLON1_IPP_66	9:48	9:51	0:02	LINE FAULT
770	4-Aug-22	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	10:55	12:20	1:25	LINE CLEAR AVAILED
771	4-Aug-22	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	4:15	7:25	3:10	LINE CLEAR AVAILED
772	4-Aug-22	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	10:53	11:10	0:16	LINE FAULT
773	4-Aug-22	TUMKUR	66	KORATAGERE-HOLAVANHALLI	KORATAGERE_66	17:46	18:13	0:27	HAND TRIPPED
774	4-Aug-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:17	17:32	1:14	LINE CLEAR AVAILED
775	4-Aug-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR_IPP_66	CLEAR SOLAR_IPP_66	12:57	13:07	0:10	HAND TRIPPED
776	4-Aug-22	TUMKUR	66	SIRA- MADHUGIRI 1	SIRA_66,BUKKAPATNA_66, KALLAMBELLA_66	14:04	14:18	0:13	LINE FAULT
777	4-Aug-22	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:54	11:07	0:12	LINE FAULT
778	4-Aug-22	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUN SOLAR2	15:06	15:15	0:09	LINE FAULT
779	4-Aug-22	TUMKUR	66	TR-1	CHANNAGIRI_66	10:19	11:16	0:56	LINE CLEAR AVAILED
780	4-Aug-22	TUMKUR	66	TR-1	DASUDI_66	15:06	16:32	1:25	LINE CLEAR AVAILED
781	4-Aug-22	TUMKUR	66	TR-1	VENKATAPURA_66	9:34	14:08	4:33	TRANSFORMER FAULT
782	4-Aug-22	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	1:27	10:48	9:21	LINE CLEAR AVAILED
783	4-Aug-22	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	18:20	19:27	1:07	LINE CLEAR AVAILED
784	5-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED AEQUS_220	21:09 (30.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
785	5-Aug-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	7:28 (29.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
786	5-Aug-22	BAGALKOT	110	110/11KV,HV1	HUDALI_110	10:02	16:35	6:33	LINE CLEAR AVAILED
787	5-Aug-22	BAGALKOT	110	110/11KV,HV1	MUDDEBIHAL_110	16:33	16:40	0:07	TRANSFORMER FAULT
788	5-Aug-22	BAGALKOT	110	110/11KV,HV1&2	ALABAL_110	14:31	16:19	1:48	LINE CLEAR AVAILED
789	5-Aug-22	BAGALKOT	110	110/11KV,HV2	DEVAR GENNUR_110	19:04	20:00	0:56	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
790	5-Aug-22	BAGALKOT	110	110/11KV,HV2	KAMBAGI_110	9:15	9:32	0:17	TRANSFORMER FAULT
791	5-Aug-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(S)_110	11:02	11:19	0:17	TRANSFORMER FAULT
792	5-Aug-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
793	5-Aug-22	BAGALKOT	110	110/11KV,HV2	THORVI_110	13:34	19:14	5:40	TRANSFORMER FAULT
794	5-Aug-22	BAGALKOT	110	110/11KV,HV3	SADALAGA_110	10:19	18:14	7:55	LINE CLEAR AVAILED
795	5-Aug-22	BAGALKOT	110	110/11KV,HV4	SADALAGA_110	10:18	17:50	7:32	LINE CLEAR AVAILED
796	5-Aug-22	BAGALKOT	110	110/33KV, HV3	SINDAGI_110 &KALAKERI&GOLAGER_33	11:24	17:40	6:16	TRANSFORMER FAULT
797	5-Aug-22	BAGALKOT	110	110/33KV, HV-3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
798	5-Aug-22	BAGALKOT	110	110/33KV,HV1,2	SADALAGA_110&KGANALLI,BOR GOAN,BHOJ&NANADAI	10:18	18:16	7:58	LINE CLEAR AVAILED
799	5-Aug-22	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 &RUSUMPR,BGM W/S&GODACHI MALKI_33	12:45	12:50	0:05	TRANSFORMER FAULT
800	5-Aug-22	BAGALKOT	110	220/110KV,LV2	MAHALINGAPUR_220	12:25	12:37	0:12	TRANSFORMER FAULT
801	5-Aug-22	BAGALKOT	110	AIGALI-ATHANI	AIGALI_110	14:14	17:50	3:36	LINE CLEAR AVAILED
802	5-Aug-22	BAGALKOT	110	AIGALI-SAVALGI	AIGALI_110	17:50	18:32	0:42	LINE CLEAR AVAILED
803	5-Aug-22	BAGALKOT	110	ALBAL-SPRS	ALBAL_110	11:34	11:59	0:25	HAND TRIPPED
804	5-Aug-22	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	11:59	12:04	0:05	LINE FAULT
805	5-Aug-22	BAGALKOT	110	ALMEL-KPR&JAMAKHANDI SUGARS	ALMEL_110	2:28	11:27	8:59	LINE CLEAR AVAILED
806	5-Aug-22	BAGALKOT	110	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI220	13:51	17:45	3:54	LINE CLEAR AVAILED
807	5-Aug-22	BAGALKOT	110	BELAGAVI220-ANKALAGI ( HUDALI )	HUDALI_110	10:10	16:33	6:23	LINE CLEAR AVAILED
808	5-Aug-22	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	20:05	20:30	0:25	HAND TRIPPED
809	5-Aug-22	BAGALKOT	110	BELLATTI-ENERCON	BELLATTI_110	20:05	20:27	0:22	HAND TRIPPED
810	5-Aug-22	BAGALKOT	110	BGM -HUDALI	HUDALI_110	10:03	16:34	6:31	LINE CLEAR AVAILED
811	5-Aug-22	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	10:25	15:46	5:21	NFBC ISSUED
812	5-Aug-22	BAGALKOT	110	GHATAPRABHA-ISALMPUR	ISLAMPUR_110	16:43	16:51	0:08	HAND TRIPPED
813	5-Aug-22	BAGALKOT	110	HUDALI(BELGAUM2)-ANKALAGI	ANKALAGI_110	9:55	16:42	6:47	NFBC ISSUED
814	5-Aug-22	BAGALKOT	110	HUDALI-BSPL	HUDALI_110	10:03	16:52	6:49	LINE CLEAR AVAILED
815	5-Aug-22	BAGALKOT	110	LAXMESHWAR-BELLATI	BELLATTI_110	20:03	20:18	0:15	LINE FAULT
816	5-Aug-22	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	20:04	20:18	0:14	LINE FAULT
817	5-Aug-22	BAGALKOT	110	MANTUR- MAREGUDDI	MAREGUDDI_110	5:45	5:50	0:05	LINE FAULT
818	5-Aug-22	BAGALKOT	110	RANEBENNUR220-AREMALLAPUR	AREMALLAPUR_110	19:28	19:35	0:07	HAND TRIPPED
819	5-Aug-22	BAGALKOT	110	RANEBENNUR220-BYADAGI	BYADAGI_110	19:28	19:35	0:07	HAND TRIPPED
820	5-Aug-22	BAGALKOT	110	RANEBENNUR220-HIREKERUR	HIREKERUR_110	19:26	19:35	0:09	HAND TRIPPED
821	5-Aug-22	BAGALKOT	110	RANEBENNUR220-RATTIHALLI	RATTIHALLI_110	19:26	19:35	0:09	HAND TRIPPED
822	5-Aug-22	BAGALKOT	110	SADALAGA-VPPL	SADALAGA_110	10:18	16:24	6:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
823	5-Aug-22	BAGALKOT	110	UTTUR - F1 JAMB CB( MUDHOL)	STATION NOT AFFECTED UTTUR_110	9:51 (24.07.2022)			LINE OPEN,LINE CLEAR AVAILED
824	5-Aug-22	BAGALKOT	110	YELLAMMANAWADI- F2 ( SAVALAGI )	STATION NOT AFFECTED YELLAMMANAWADI_110	9:00	14:12	5:12	LINE CLEAR AVOIDED
825	5-Aug-22	BAGALKOT	110	YELLAMMANAWADI- F3 (ALBAL )	ALBAL_110	14:38	16:12	1:34	LINE CLEAR AVOIDED
826	5-Aug-22	BAGALKOT	110	ZALKI-CHADACHAN-2	CHADACHAN_110 INCHAGERI_110	3:05	3:15	0:10	LINE FAULT
827	5-Aug-22	BAGALKOT	220	220/110KV, HV & LV	STATION NOT AFFECTED INDI_220	16:25	20:20	3:55	LINE CLEAR AVOIDED
828	5-Aug-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AEQUS_220	17:10	17:13	0:03	HAND TRIPPED
829	5-Aug-22	BAGALKOT	220	220/110KV, HV-1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
830	5-Aug-22	BAGALKOT	220	220/110KV, HV1 & LV1	STATION NOT AFFECTED KARWAR_220	13:08	14:01	0:53	LINE CLEAR AVOIDED
831	5-Aug-22	BAGALKOT	220	220/110KV, HV1 & LV1	STATION NOT AFFECTED VIJAYPUR_220	17:53	17:56	0:03	HAND TRIPPED
832	5-Aug-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED AEQUS_220	17:10	17:15	0:05	HAND TRIPPED
833	5-Aug-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED AEQUS_220	17:52	18:06	0:14	HAND TRIPPED
834	5-Aug-22	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED VIJAYPUR_220	0:49	2:02	1:13	TRANSFORMER FAULT
835	5-Aug-22	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED VIJAYPUR_220	10:08	10:31	0:23	HAND TRIPPED
836	5-Aug-22	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED VIJAYPUR_220	10:59	15:45	4:46	LINE CLEAR AVOIDED
837	5-Aug-22	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED VIJAYPUR_220	17:13	17:27	0:14	HAND TRIPPED
838	5-Aug-22	BAGALKOT	220	220/110KV, HV2 , LV2	STATION NOT AFFECTED VIJAYPUR_220	23:29 (04.08.2022)	00:03 (05.08.2022)	0:04 hrs	TRANSFORMER CHARGED
839	5-Aug-22	BAGALKOT	220	220/110KV, HV-3 & LV3	STATION NOT AFFECTED CHIKKODI_220	14:11	16:18	2:07	LINE CLEAR AVOIDED
840	5-Aug-22	BAGALKOT	220	220/110KV, HV-3 & LV-3	STATION NOT AFFECTED ATHANI_220	10:26 (25.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
841	5-Aug-22	BAGALKOT	220	AMBEWADI-NARENDRA-1	STATION NOT AFFECTED AMBEWADI_220	17:23 (04.08.2022)	17:57 (05.08.2022)	24:34HRS	LINE CHARGED
842	5-Aug-22	BAGALKOT	220	BAGALAKOT-VAJRAMATTI-1	STATION NOT AFFECTED BAGALKOT_220	17:48 (02.08.2022)			LINE OPEN,LINE CLEAR AVAILED
843	5-Aug-22	BAGALKOT	220	BAGEWADI-ATRIA1	BAGEWADI_220	5:35	6:10	0:35	LINE FAULT
844	5-Aug-22	BAGALKOT	220	BELAGAVI-AEQUS-2	STATION NOT AFFECTED BELAGAVI_220	11:39 (05.08.2022)			LINE OPEN,LINE CLEAR AVAILED
845	5-Aug-22	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	12:57	18:03	5:06	LINE FAULT
846	5-Aug-22	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	15:21	20:34	5:13	LINE FAULT
847	5-Aug-22	BAGALKOT	220	CHIKKODI-AEQUS-2	STATION NOT AFFECTED CHIKKODI_220	11:00	12:58	1:58	LINE CLEAR AVOIDED
848	5-Aug-22	BAGALKOT	220	HAVERI-GUTTUR-2	STATION NOT AFFECTED HAVERI_220i	16:13	17:03	0:50	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
849	5-Aug-22	BAGALKOT	220	HUBLI-NAGAZARI-1	STATION NOT AFFECTED HUBLI_220	15:34	16:11	0:37	LINE FAULT
850	5-Aug-22	BAGALKOT	220	NARENDRA-AMBEWADI-1	STATION NOT AFFECTED NARENDRA_220	17:17 (04.08.2022)	17:57 (05.08.2022)	24:40 hrs	LINE CHARGED
851	5-Aug-22	BAGALKOT	220	NARENDRA-HAVERI1 ( BIDNAL )	STATION NOT AFFECTED NARENDRA_220	15:20	20:34	5:14	LINE FAULT
852	5-Aug-22	BAGALKOT	220	RANEENNUR-SHIRALKOPPA ( BALLIGAVI )	STATION NOT AFFECTED RANEENNUR_220	19:26 (05.08.2022)			LINE OPEN,LINE CLEAR AVAILED
853	5-Aug-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
854	5-Aug-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)			LINE OPEN,LINE CLEAR AVAILED
855	5-Aug-22	BAGALKOT	220	VIJAYAPUR-GMNAVAR-1	STATION NOT AFFECTED VIJAYPUR_220	17:38	17:44	0:06	HAND TRIPPED
856	5-Aug-22	BAGALKOT	220	VIJAYAPUR-GMNAVAR-2	STATION NOT AFFECTED VIJAYPUR_220	17:57	18:00	0:03	HAND TRIPPED
857	5-Aug-22	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, JAKKASANDRA	6:31	6:54	0:23	MAIN SUPPLY FAILURE
858	5-Aug-22	BENGALURU	66	AREHALLI - SUBRAMANYAPURA	AREHALLI	6:31	6:49	0:18	MAIN SUPPLY FAILURE
859	5-Aug-22	BENGALURU	66	AREHALLI - SUBRAMANYAPURA	AREHALLI	7:08	7:10	0:02	MAIN SUPPLY FAILURE
860	5-Aug-22	BENGALURU	66	AVANI - KC VALLEY(EHT)	KC VALLEY(EHT)	13:20	15:00	1:40	LINE CLEAR AVAILED
861	5-Aug-22	BENGALURU	66	BRIGADE MEADOWS - SHOBHA FOREST	SHOBHA FOREST	8:34	8:48	0:14	LINE FAULT
862	5-Aug-22	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	6:31	7:08	0:37	MAIN SUPPLY FAILURE
863	5-Aug-22	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	8:01	8:07	0:06	LOAD CHANGE OVER
864	5-Aug-22	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	6:31	6:48	0:17	MAIN SUPPLY FAILURE
865	5-Aug-22	BENGALURU	66	HULLENHALLI - ANCHEPALYA 220	HULLENHALLI, KUDUR, SIRIGIRIPURA	19:36	20:41	1:05	MAIN SUPPLY FAILURE
866	5-Aug-22	BENGALURU	66	HULLENHALLI - KUDUR	KUDUR, SIRIGIRIPURA	10:10	10:22	0:12	LINE FAULT
867	5-Aug-22	BENGALURU	66	HV1	BAGEPALLI	13:40	14:10	0:30	LINE CLEAR AVAILED
868	5-Aug-22	BENGALURU	66	HV1	CHINTAMANI	20:19	21:06	0:47	LINE CLEAR AVAILED
869	5-Aug-22	BENGALURU	66	HV1	DODDALAHALLI	14:59	15:11	0:12	TRANSFORMER FAULT
870	5-Aug-22	BENGALURU	66	HV1	GANJIGUNTE	8:48	8:54	0:06	TRANSFORMER FAULT
871	5-Aug-22	BENGALURU	66	HV1	GUDEMARANAHALLI	16:20	16:28	0:08	TRANSFORMER FAULT
872	5-Aug-22	BENGALURU	66	HV1	JIGANI 220	14:51	15:00	0:09	TRANSFORMER FAULT
873	5-Aug-22	BENGALURU	66	HV1	KHODAYS 220	6:31	7:04	0:33	MAIN SUPPLY FAILURE
874	5-Aug-22	BENGALURU	66	HV1	KHODAYS 220	7:19	7:21	0:02	LINE CLEAR AVAILED
875	5-Aug-22	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	12:48	12:52	0:04	TRANSFORMER FAULT
876	5-Aug-22	BENGALURU	66	HV1	REMC0	8:19	8:26	0:07	LOAD CHANGE OVER
877	5-Aug-22	BENGALURU	66	HV1	REMC0	12:50	12:55	0:05	LOAD CHANGE OVER
878	5-Aug-22	BENGALURU	66	HV1	SOMENAHALLI	4:55	5:10	0:15	TRANSFORMER FAULT
879	5-Aug-22	BENGALURU	66	HV1	TYAMAGONDALU	7:10	7:20	0:10	TRANSFORMER FAULT
880	5-Aug-22	BENGALURU	66	HV2	BG ROAD	16:34	16:38	0:04	TRANSFORMER FAULT
881	5-Aug-22	BENGALURU	66	HV2	KHODAYS 220	6:31	7:04	0:33	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
882	5-Aug-22	BENGALURU	66	HV2	KHODAYS 220	7:19	7:21	0:02	LINE CLEAR AVAILED
883	5-Aug-22	BENGALURU	66	HV2	SARJAPURA 220	2:58	3:37	0:39	TRANSFORMER FAULT
884	5-Aug-22	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	6:31	7:04	0:33	MAIN SUPPLY FAILURE
885	5-Aug-22	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	7:19	7:21	0:02	LINE CLEAR AVAILED
886	5-Aug-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	4:18	4:26	0:08	LINE FAULT
887	5-Aug-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	13:02	13:38	0:36	LINE CLEAR AVAILED
888	5-Aug-22	BENGALURU	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	6:31	7:12	0:41	MAIN SUPPLY FAILURE
889	5-Aug-22	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	15:00	15:05	0:05	LINE FAULT
890	5-Aug-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	8:51	8:57	0:06	LINE FAULT
891	5-Aug-22	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA, SARAKKI	6:31	7:16	0:45	MAIN SUPPLY FAILURE
892	5-Aug-22	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA, SARAKKI	15:03	15:43	0:40	MAIN SUPPLY FAILURE
893	5-Aug-22	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE	6:31	7:16	0:45	MAIN SUPPLY FAILURE
894	5-Aug-22	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	15:03	15:43	0:40	MAIN SUPPLY FAILURE
895	5-Aug-22	BENGALURU	66	PADMANABHANAGARA - NIMHANS 220	PADMANABHANAGARA	6:31	7:01	0:30	MAIN SUPPLY FAILURE
896	5-Aug-22	BENGALURU	66	PADMANABHANAGARA - NIMHANS 220	PADMANABHANAGARA	15:03	15:15	0:12	MAIN SUPPLY FAILURE
897	5-Aug-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	7:25	7:33	0:08	LOAD CHANGE OVER
898	5-Aug-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	6:31	6:52	0:21	MAIN SUPPLY FAILURE
899	5-Aug-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	13:02	13:05	0:03	LOAD CHANGE OVER
900	5-Aug-22	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	15:48	16:00	0:12	LOAD CHANGE OVER
901	5-Aug-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	6:31	6:46	0:15	MAIN SUPPLY FAILURE
902	5-Aug-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	7:06	7:09	0:03	LOAD CURTAILMENT
903	5-Aug-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	6:31	6:46	0:15	MAIN SUPPLY FAILURE
904	5-Aug-22	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	6:31	6:46	0:15	MAIN SUPPLY FAILURE
905	5-Aug-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, KC VALIEY(EHT),MULBAGAL	13:23	13:55	0:32	LINE FAULT
906	5-Aug-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	13:44	13:56	0:12	LOAD CHANGE OVER
907	5-Aug-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU,AVANI, MULBAGALU	17:28	17:37	0:09	LOAD CHANGE OVER
908	5-Aug-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	08:38:00(23/07/2022)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
909	5-Aug-22	BENGALURU	220	HSR LAYOUT 220 - MYLSANDRA 400	KORAMANGALA 220 , NIMHANS 220	6:31	7:10	0:39	MAIN SUPPLY FAILURE
910	5-Aug-22	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220	6:31	7:04	0:33	LINE FAULT
911	5-Aug-22	BENGALURU	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220 , NIMHANS 220	6:31	7:06	0:35	MAIN SUPPLY FAILURE
912	5-Aug-22	BENGALURU	220	NIMHANS 220 - KORAMANGALA 220	NIMHANS 220	6:31	7:16	0:45	MAIN SUPPLY FAILURE
913	5-Aug-22	BENGALURU	220	NIMHANS 220 - KORAMANGALA 220	NIMHANS 220	15:03	15:43	0:40	MAIN SUPPLY FAILURE
914	5-Aug-22	BENGALURU	220	SOMANAHALLI 220 - KHODAYS 220	KHODAYS 220, SUBRAMANYAPURA 220	6:31	7:04	0:33	LINE FAULT
915	5-Aug-22	BENGALURU	220	SUBRAMANYAPURA 220 - KHODAYS 220	SUBRAMANYAPURA 220	6:31	6:46	0:15	MAIN SUPPLY FAILURE
916	5-Aug-22	BENGALURU	400	ICT 1	MYLSANDRA 400	6:31	9:30	2:59	TRANSFORMER FAULT
917	5-Aug-22	BENGALURU	400	ICT 3	MYLSANDRA 400	6:31	8:02	1:31	TRANSFORMER FAULT
918	5-Aug-22	GULBARGA	66	BENNEHALLI-RISHAB BUILWELL SLR	BENNEHALLI_66	15:20	15:30	0:10	LOAD CURTAILMENT
919	5-Aug-22	GULBARGA	66	HV1	KUDLIGI_220	9:10	9:15	0:05	TRANSFORMER FAULT
920	5-Aug-22	GULBARGA	66	HV2	TELIGI_66	15:50	15:55	0:05	TRANSFORMER FAULT
921	5-Aug-22	GULBARGA	66	NEELAGUNDA-HALAVAGALU	HALAVAGALU_66	6:10	6:20	0:10	LINE FAULT
922	5-Aug-22	GULBARGA	66	NEELAGUNDA-HALAVAGALU	HALAVAGALU_66	7:05	7:37	0:32	LINE FAULT
923	5-Aug-22	GULBARGA	66	NEELAGUNDA-TELIGI	TELIGI_66,KURBHALLI_66,YEREGUNTA_66	3:14	3:23		LINE OPEN,LINE FAULT
924	5-Aug-22	GULBARGA	110	GANGAVATI-KANAKAGIRI	NAVALI_110,CLEAN SOLAR_IPP	13:17	13:40	0:23	LINE FAULT
925	5-Aug-22	GULBARGA	110	GHATARGA-SHAHBAD	GHATARGA_110	1:35	1:40	0:05	LINE FAULT
926	5-Aug-22	GULBARGA	110	GHATARGA-SHAHBAD	GHATARGA_110	5:00	5:10	0:10	LINE FAULT
927	5-Aug-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	05:20(3.08.2022)			LINE OPEN,LINE FAULT
928	5-Aug-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
929	5-Aug-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
930	5-Aug-22	GULBARGA	110	HV1	YELBURGA_110	13:06	15:30	2:24	LINE CLEAR AVAILED
931	5-Aug-22	GULBARGA	110	HV1	YERADONA_110	7:05	8:25	1:20	TRANSFORMER FAULT
932	5-Aug-22	GULBARGA	110	HV2	HUNASAGI_110	16:40	18:50	2:10	LINE CLEAR AVAILED
933	5-Aug-22	GULBARGA	110	HV2	SREERAMANAGAR_110	9:00(02.08.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
934	5-Aug-22	GULBARGA	110	HV3	MUNIRABAD_220	10:07	17:23	7:16	LINE CLEAR AVAILED
935	5-Aug-22	GULBARGA	110	HV5	MUNIRABAD_220	10:30(5.08.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
936	5-Aug-22	GULBARGA	110	JAWALAGERA-WALABELLARI	JAWALAGERA_110	21:35	21:45	0:10	LINE FAULT
937	5-Aug-22	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	5:48	5:56	0:08	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
938	5-Aug-22	GULBARGA	110	KUSHTAGI-VAJJARBANDI	VAJJARBANDI_110, YALBURGA_110, BEVOOR_110, MANGALURU_110, CHILAKAMUKHI_110, KUKUNOOR_110	14:04	15:48	1:44	LINE FAULT
939	5-Aug-22	GULBARGA	110	RAICHUR-SINDHNOOR2	KURDICROSS_110,MADLAPUR_1 10,MANVI_110	18:04	19:56	1:52	LINE FAULT
940	5-Aug-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	4:22	8:45	4:23	LINE FAULT
941	5-Aug-22	GULBARGA	110	SHAHABAD-FARTHABAD	FARTHABAD_110,GULBARGA SOUTH_110	11:58	13:40	1:42	LINE CLEAR AVAILED
942	5-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
943	5-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
944	5-Aug-22	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110,NALWAR_110	1:40	1:47	0:07	LINE FAULT
945	5-Aug-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	11:16	11:57	0:41	LINE CLEAR AVAILED
946	5-Aug-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:15	12:06	0:51	LINE CLEAR AVAILED
947	5-Aug-22	GULBARGA	110	SHAKTINAGAR-RAICHURBIO	SHAKTINAGAR_110	0:02	0:09	0:07	LINE FAULT
948	5-Aug-22	GULBARGA	110	YELBURGA-PRPJS LR	YELBURGA_110	14:01	15:15	1:14	LINE FAULT
949	5-Aug-22	GULBARGA	220	HV1	ITTAGI_220	10:45(04.08.2022)	20:38(05.08.2022)	33:53HRS	TRANSFORMER CHARGED
950	5-Aug-22	GULBARGA	220	HV1	KUSHTAGI_220	14:04	15:11	1:07	TRANSFORMER FAULT
951	5-Aug-22	GULBARGA	220	HV2	KUSHTAGI_220	14:04	15:51	1:47	TRANSFORMER FAULT
952	5-Aug-22	GULBARGA	220	HV2	KUSHTAGI_220	19:28	21:44	2:16	LINE CLEAR AVAILED
953	5-Aug-22	GULBARGA	220	KAPNOOR-HUMNABAD	HUMNABAD_220	12:28	15:30	3:02	LINE CLEAR AVAILED
954	5-Aug-22	GULBARGA	220	KUSHTAGI-LINGASUGUR	LINGASUGUR_220	13:58	14:01	0:03	LINE CLEAR AVAILED
955	5-Aug-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	21:05	21:19	0:14	LINE FAULT
956	5-Aug-22	GULBARGA	220	RAICHUR-JURALA1	RAICHUR_220	0:05	1:27	1:22	LINE FAULT
957	5-Aug-22	GULBARGA	220	RAICHUR-JURALA2	RAICHUR_220	6:10	7:02	0:52	LINE FAULT
958	5-Aug-22	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	14:06	16:18	2:12	LINE CLEAR AVAILED
959	5-Aug-22	HASSAN	66	HNPR2-HNPR1	HOLENARSIPURA_220	6:47	7:01	0:14	LINE FAULT
960	5-Aug-22	HASSAN	66	HV1	ALDUR_66	1:20	1:35	0:15	TRANSFORMER FAULT
961	5-Aug-22	HASSAN	66	HV1	BALEHONNUR_66	19:58	20:16	0:18	HAND TRIPPED
962	5-Aug-22	HASSAN	66	HV1	HNPURA_66	6:56	7:08	0:12	MAIN SUPPLY FAILURE
963	5-Aug-22	HASSAN	66	HV2	HNPURA_66	6:56	7:08	0:12	MAIN SUPPLY FAILURE
964	5-Aug-22	HASSAN	66	NGRTHI-L2 CB	NAGARTHI_66	5:04	5:17	0:13	LINE FAULT
965	5-Aug-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_66	13:12	13:16	0:04	LINE FAULT
966	5-Aug-22	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_66	13:44	15:23	1:39	NFBC ISSUED
967	5-Aug-22	HASSAN	110	HV1	BHADRAVATHI_110	10:25	12:00	1:35	LINE CLEAR AVAILED
968	5-Aug-22	HASSAN	110	HV1	HALADY_110	16:23	17:50	1:27	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
969	5-Aug-22	HASSAN	110	HV2	HALADY_110	4:16	4:30	0:14	TRANSFORMER FAULT
970	5-Aug-22	HASSAN	110	KADUR-NERELEKERE	KADUR_220	9:59	12:10	2:11	LINE CLEAR AVAILED
971	5-Aug-22	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	15:07	15:17	0:10	HAND TRIPPED
972	5-Aug-22	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	12:36	12:43	0:07	LINE FAULT
973	5-Aug-22	HASSAN	110	SHIVAPU-BIRUR	SHIVAPURA_110	10:00	12:20	2:20	MAIN SUPPLY FAILURE
974	5-Aug-22	HASSAN	110	SIVAPU-NERLEKERE	SHIVAPURA_110	10:00	12:12	2:12	MAIN SUPPLY FAILURE
975	5-Aug-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
976	5-Aug-22	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:06	12:47	2:41	NFBC ISSUED
977	5-Aug-22	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	13:12	15:22	2:10	LINE FAULT
978	5-Aug-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	19:27	19:32	0:05	LINE FAULT
979	5-Aug-22	HASSAN	220	VARAHI-KEMAR1	gen_varahi	10:06	12:47	2:41	LINE CLEAR AVAILED
980	5-Aug-22	HASSAN	220	VARAHI-SHMG3	gen_varahi	13:12	15:22	2:10	LINE FAULT
981	5-Aug-22	MYSURU	66	BG NAGARA-HIRISAVE	KADBALLI_66	14:06	14:21	0:15	LINE FAULT
982	5-Aug-22	MYSURU	66	COWDALLI-MARTHALLI	RAMAPURA_MYS_66MARTAHALLI_66	8:15	8:25	0:10	LINE FAULT
983	5-Aug-22	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
984	5-Aug-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
985	5-Aug-22	MYSURU	66	HV1	DEVANOORNGUDU_66	15:13	15:41	0:28	TRANSFORMER FAULT
986	5-Aug-22	MYSURU	66	HV1	GUDDENAHALLI_66	12:31	15:34	3:02	LINE CLEAR AVAILED
987	5-Aug-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
988	5-Aug-22	MYSURU	66	HV1	JAKKANAHALLY_66	12:11	13:19	1:07	LINE CLEAR AVAILED
989	5-Aug-22	MYSURU	66	HV1	MANDGERE_66	5:05	5:15	0:10	MAIN SUPPLY FAILURE
990	5-Aug-22	MYSURU	66	HV1	SATHEGALA_66	14:49	14:50	0:01	HAND TRIPPED
991	5-Aug-22	MYSURU	66	HV2	SATHEGALA_66	13:03	16:18	3:14	LINE CLEAR AVAILED
992	5-Aug-22	MYSURU	66	KADAKOLA -SARGUR2	DOORA_66HULLAHALLI_66HURA_66	6:01	6:06	0:05	LINE FAULT
993	5-Aug-22	MYSURU	66	KADAKOLA -VAJMANGALA 2	NO STATIONS EFFECTED	2:55	3:16	0:21	LINE FAULT
994	5-Aug-22	MYSURU	66	KADAKOLA -VAJMANGALA 2	NO STATIONS EFFECTED	14:17	14:24	0:07	LINE FAULT
995	5-Aug-22	MYSURU	66	KADAKOLA -VAJMANGALA 2	NO STATIONS EFFECTED	16:15	16:26	0:11	LINE FAULT
996	5-Aug-22	MYSURU	66	KR NAGARA-BILIKERE	NO STATIONS EFFECTED	13:10:58 (4.8.2022)			LINE OPEN,LINE CLEAR AVAILED
997	5-Aug-22	MYSURU	66	KR NAGARA-KUSHALNAGARA 1	NO STATIONS EFFECTED	14:25	19:47	5:21	LINE CLEAR AVAILED
998	5-Aug-22	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	2:52	2:58	0:06	LINE FAULT
999	5-Aug-22	MYSURU	220	CR NAGARA-BEGUR 1	NO STATIONS EFFECTED	12:50	13:35	0:45	LINE CLEAR AVAILED
1000	5-Aug-22	MYSURU	220	CR NAGARA-MADHUVANAHALLI 1	NO STATIONS EFFECTED	12:50	13:40	0:49	LINE CLEAR AVAILED
1001	5-Aug-22	MYSURU	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1002	5-Aug-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1003	5-Aug-22	MYSURU	220	KADAKOLA -ADAKANAHALLI- BEGUR 2	NO STATIONS EFFECTED	19:07:02 (5.8.2022)			LINE OPEN,LINE CLEAR AVAILED
1004	5-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVANI_66	19:42	20:41	0:58	HAND TRIPPED
1005	5-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA 1	ANCHEPALYA_66,BHAKTHARAHA LLI_66	19:42	20:23	0:40	HAND TRIPPED
1006	5-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA 2	ANCHEPALYA_66,BHAKTHARAHA LLI_66	19:42	20:40	0:57	HAND TRIPPED
1007	5-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66,NIDSALE_6 6,DUNDANAHALLI_66	19:42	20:40	0:57	HAND TRIPPED
1008	5-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66,MATTIKERE_66	19:42	20:41	0:59	HAND TRIPPED
1009	5-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	T G HALLI_66,HOSAPALYA_66,SOLUR_66, MAGADI_66,V G DODDI_66	19:42	20:40	0:57	HAND TRIPPED
1010	5-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	ANCHEPALYA_220	19:42	20:41	0:58	HAND TRIPPED
1011	5-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR_66	YEDIYUR_66,THIPPUR_66,JIDDEG ERE_66	19:42	20:40	0:57	HAND TRIPPED
1012	5-Aug-22	TUMKUR	66	ANTHRASANAHALI 220kV- KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_ 66, BELADARA_66	11:19	13:30	2:10	LINE CLEAR AVAILED
1013	5-Aug-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGA LUR_66	13:37	14:32	0:55	LINE FAULT
1014	5-Aug-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	0:13	0:24	0:11	LINE FAULT
1015	5-Aug-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	14:06	14:16	0:10	LINE FAULT
1016	5-Aug-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	16:26	22:21	5:55	LINE FAULT
1017	5-Aug-22	TUMKUR	66	HIREHALLI - BADDIHALLI	BADDIHALLI_66	6:08	6:38	0:29	LINE FAULT
1018	5-Aug-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR_IPP_66	CLEAR SOLAR_IPP_66	14:42	14:49	0:07	MAIN SUPPLY FAILURE
1019	5-Aug-22	TUMKUR	66	PD KOTE66-AZURE POWER_IPP_66	AZURE POWER_IPP_66	14:42	14:49	0:07	MAIN SUPPLY FAILURE
1020	5-Aug-22	TUMKUR	66	PD KOTE66-SOLITAIRE_IPP_66	SOLITAIRE_IPP_66	14:42	15:09	0:27	MAIN SUPPLY FAILURE
1021	5-Aug-22	TUMKUR	66	TR-1	BADAVANAHALLI_66	12:03	13:15	1:11	LINE CLEAR AVAILED
1022	5-Aug-22	TUMKUR	66	TR-1	BADDIHALLI_66	12:35	12:56	0:21	LINE CLEAR AVAILED
1023	5-Aug-22	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	19:36	20:22	0:46	TRANSFORMER FAULT
1024	5-Aug-22	TUMKUR	66	TR-2	BADDIHALLI_66	12:35	12:56	0:21	LINE CLEAR AVAILED
1025	5-Aug-22	TUMKUR	66	TR-2	CHANNAGIRI_66	2:20	2:22	0:02	TRANSFORMER FAULT
1026	5-Aug-22	TUMKUR	66	TR-2	CHANNAGIRI_66	20:21	20:27	0:05	TRANSFORMER FAULT
1027	5-Aug-22	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	19:36	20:39	1:03	TRANSFORMER FAULT
1028	5-Aug-22	TUMKUR	110	TR-1	AMMASANDRA_110	23:10(04.08.2022)	16:56(05.08.2022)	17:16HRS	TRANSFORMER CHARGED
1029	5-Aug-22	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	19:36	20:21	0:44	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1030	5-Aug-22	TUMKUR	220	TR-1(HV SIDE)	HIRIYUR_220	16:00	18:05	2:05	LINE CLEAR AVAILED
1031	5-Aug-22	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	13:17	13:58	0:41	TRANSFORMER FAULT
1032	5-Aug-22	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	15:50	18:05	2:15	TRANSFORMER FAULT
1033	6-Aug-22	BAGALKOT	110	110/11KV, HV1(10MVA)	UCHGOAN_110	15:41	16:36	0:55	LINE CLEAR AVAILED
1034	6-Aug-22	BAGALKOT	110	110/11KV, HV-1(20MVA)	STATION NOT AFFECTED AEQUS_220	21:09 (30.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1035	6-Aug-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	7:28 (29.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1036	6-Aug-22	BAGALKOT	110	110/11KV,HV1	ALABAL_110	19:37	20:07	0:30	NFBC ISSUED
1037	6-Aug-22	BAGALKOT	110	110/11KV,HV1	HIRESMASALI_110	10:43	11:48	1:05	LINE CLEAR AVAILED
1038	6-Aug-22	BAGALKOT	110	110/11KV,HV1	PG HUNASYAL_110	13:34	17:15	3:41	LINE CLEAR AVAILED
1039	6-Aug-22	BAGALKOT	110	110/11KV,HV1	PG HUNASYAL_110	17:15	18:25	1:10	LINE CLEAR AVAILED
1040	6-Aug-22	BAGALKOT	110	110/11KV,HV2	ALABAL_110	19:37	20:44	1:07	NFBC ISSUED
1041	6-Aug-22	BAGALKOT	110	110/11KV,HV2	HIRESHAL_110	12:31	13:41	1:10	LINE CLEAR AVAILED
1042	6-Aug-22	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	16:00	16:06	0:06	TRANSFORMER FAULT
1043	6-Aug-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1044	6-Aug-22	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	14:53	19:51	4:58	LINE CLEAR AVAILED
1045	6-Aug-22	BAGALKOT	110	110/33KV, HV-3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1046	6-Aug-22	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	12:36	15:06	2:30	LINE CLEAR AVAILED
1047	6-Aug-22	BAGALKOT	110	ALABAL-RFE	ALABAL_110	13:17	20:29	7:12	NFBC ISSUED
1048	6-Aug-22	BAGALKOT	110	ALABAL-SPRS	ALABAL_110	13:17	20:27	7:10	NFBC ISSUED
1049	6-Aug-22	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	16:43	16:45	0:02	HAND TRIPPED
1050	6-Aug-22	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	16:43	17:24	0:41	HAND TRIPPED
1051	6-Aug-22	BAGALKOT	110	BAGALAKOT220-F4NAVANAGAR-2	STATION NOT AFFECTED BAGALKOT_220	12:35	15:13	2:40	LINE CLEAR AVAILED
1052	6-Aug-22	BAGALKOT	110	BAGALKOT220-F10KALADAGI	KALADAGI_110	12:35	12:52	0:17	HAND TRIPPED
1053	6-Aug-22	BAGALKOT	110	BAGALKOT220-F10KALADAGI	KALADAGI_110	14:41	15:07	0:26	HAND TRIPPED
1054	6-Aug-22	BAGALKOT	110	BAGALKOT220-F5GULEDGUDDA	GULEDGUDDA_110	12:35	12:54	0:19	HAND TRIPPED
1055	6-Aug-22	BAGALKOT	110	BAGALKOT220-F5GULEDGUDDA	GULEDGUDDA_110	14:41	15:06	0:25	HAND TRIPPED
1056	6-Aug-22	BAGALKOT	110	BAGALKOT220-F9KATARKI (NEERABUDIHAL)	NEERABUDIHAL_110	13:10	13:43	0:33	HAND TRIPPED
1057	6-Aug-22	BAGALKOT	110	BAGALKOT220-F9KATARKI (NEERABUDIHAL)	NEERABUDIHAL_110	14:34	15:09	0:35	HAND TRIPPED
1058	6-Aug-22	BAGALKOT	110	CHAND KAVATE-ALMEL	CHANDKAVATE_110	10:01	16:38	6:37	NFBC ISSUED
1059	6-Aug-22	BAGALKOT	110	DAMBAL-MUNDRAGI	MUNDARAGI_110	9:57	10:20	0:23	LINE FAULT
1060	6-Aug-22	BAGALKOT	110	GHATAPRABHA220- PGHUNSHYAL	PGHUNSHYAL_110	10:09	13:21	3:12	LINE CLEAR AVAILED
1061	6-Aug-22	BAGALKOT	110	HUNGUND-KDALSANAGAM	KUDALASANGAM_110	14:58	16:38	1:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1062	6-Aug-22	BAGALKOT	110	INDI220-ZLAKI-1&2	ZALAKI_110 CHADACHAN_110 INCHAGERI_110	10:00	19:37	9:37	LINE CLEAR AVAILED
1063	6-Aug-22	BAGALKOT	110	MUGALKHOD220-PGHUNSHAL	PGHUNSHAL_110	10:15	13:22	3:07	NFBC ISSUED
1064	6-Aug-22	BAGALKOT	110	RON-GAMESH	RON_110	11:08	11:45	0:37	HAND TRIPPED
1065	6-Aug-22	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	11:47	16:04	4:17	LINE CLEAR AVAILED
1066	6-Aug-22	BAGALKOT	110	SAVALAGI-AIGALI	SAVALAGI_110	18:20 (05.08.2022)	8:20 (06.08.2022)	14:00HRS	LINE CHARGED
1067	6-Aug-22	BAGALKOT	110	SAVALAGI-AIGALI	SAVALAGI_110	16:44 (06.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1068	6-Aug-22	BAGALKOT	110	SOUDATTI-MUNAVALLY( SOUDATTI 1)	SOUDATTI_110	9:05	9:15	0:10	LINE CLEAR AVAILED
1069	6-Aug-22	BAGALKOT	110	SOUDATTI-MUNAVALLY( SOUDATTI 2)	SOUDATTI_110	9:05	9:15	0:10	LINE CLEAR AVAILED
1070	6-Aug-22	BAGALKOT	110	UAS-F1CBreaker(NARENDRA)	STATION NOT AFFECTED UAS DHARWAD_110	16:54	17:20	0:26	LINE FAULT
1071	6-Aug-22	BAGALKOT	110	UDIKERI-SOUDATTI(NOKAR SOLAR )	NOKAR SOALR_110 STATION NOT AFFECTED UDIKERI_110	1:18	2:04	0:46	LINE FAULT
1072	6-Aug-22	BAGALKOT	110	UTTUR - F1 JAMB CB( MUDHOL)	STATION NOT AFFECTED UTTUR_110	9:51 (24.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1073	6-Aug-22	BAGALKOT	110	VAJJRAMATTI220-BILAGI	BILAGI_110 SHIRGUPPI_110 GIRISAGAR_110 TOLAMATTI_110 BISNAL_110	5:08	5:13	0:05	LINE FAULT
1074	6-Aug-22	BAGALKOT	110	VAJRA220-BILAGI	BILAGI_110, SHIRAGUPPI_110, BISNAL_110,GIRISAGAR_110, TOLAMATTI_110	5:08	5:13	0:05	LINE FAULT
1075	6-Aug-22	BAGALKOT	110	YALLAMANAWADI-AIGALI	AIGALI_110	8:02	19:55	11:53	NFBC ISSUED
1076	6-Aug-22	BAGALKOT	110	YLWD-F2 Cbreaker(SAVALAGI)	STATION NOT AFFECTED YELLAMANAWADI_110	19:58 (06.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1077	6-Aug-22	BAGALKOT	110	YLWD-F3 Cbreaker(ALBAL)	ALBAL_110 STATION NOT AFFECTED YELLAMANAWADI_110	13:01	20:06	7:05	NFBC ISSUED
1078	6-Aug-22	BAGALKOT	220	220/110KV, HV-1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1079	6-Aug-22	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED INDI_220	9:45	17:10	7:25	LINE CLEAR AVAILED
1080	6-Aug-22	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED INDI_220	17:50	17:53	0:03	HAND TRIPPED
1081	6-Aug-22	BAGALKOT	220	220/110KV, HV-3 & LV-3	STATION NOT AFFECTED ATHANI_220	10:26 (25.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1082	6-Aug-22	BAGALKOT	220	AMBEWADI-PONDA-2	STATION NOT AFFECTED AMBEWADI_220	0:34	7:58	7:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1083	6-Aug-22	BAGALKOT	220	BAGALAKOT-VAJRAMATTI-1	STATION NOT AFFECTED BAGALKOT_220	17:48 (02.08.2022)	17:43 (06.08.2022)	95:55HRS	LINE CHARGED
1084	6-Aug-22	BAGALKOT	220	BELAGAVI-AEQUS-2	STATION NOT AFFECTED BELAGAVI_220	11:39 (05.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1085	6-Aug-22	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	3:58 (06.08.2022)			LINE OPEN,LINE FAULT
1086	6-Aug-22	BAGALKOT	220	HUBLI-BIDNAL-1	STATION NOT AFFECTED HUBLI_220	3:58 (06.08.2022)			LINE OPEN,LINE FAULT
1087	6-Aug-22	BAGALKOT	220	HUBLI-NAGAZARI-1	STATION NOT AFFECTED HUBLI_220	2:06	6:51	4:45	LINE CLEAR AVOIDED
1088	6-Aug-22	BAGALKOT	220	RANEENNUR-SHIRALKOPPA ( BALLIGAVI )	STATION NOT AFFECTED RANEENNUR_220	19:26 (05.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1089	6-Aug-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)	6:33 (06.08.2022)	514:47HRS	LINE CHARGED
1090	6-Aug-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	19:46 (15.07.2022)	6:33 (06.08.2022)	514:47HRS	LINE CHARGED
1091	6-Aug-22	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	8:30	8:35	0:05	LOAD CHANGE OVER
1092	6-Aug-22	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	18:02	18:06	0:04	LOAD CHANGE OVER
1093	6-Aug-22	BENGALURU	66	BAGMANE WTP - HOODY 220	BAGWAME WTP	14:29	16:50	2:21	LINE CLEAR AVOIDED
1094	6-Aug-22	BENGALURU	66	BMTC - EAST DIVISION COMPOUND 220	BMTC	8:40	8:43	0:03	LOAD CHANGE OVER
1095	6-Aug-22	BENGALURU	66	DIBBURAHALLI - CHINTAMANI 220	DIBBURAHALLI	18:30	18:35	0:05	LOAD CHANGE OVER
1096	6-Aug-22	BENGALURU	66	DIVYASHREE TECH PARK - EPIP 220	DIVYASHREE TECH PARK	11:15	12:42	1:27	LINE CLEAR AVOIDED
1097	6-Aug-22	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	10:45	16:05	5:20	LINE CLEAR AVOIDED
1098	6-Aug-22	BENGALURU	66	GUNDLU KOTTUR - GOWRIBIDANUR 220	GUNDLU KOTTUR	15:26	15:49	0:23	LINE CLEAR AVOIDED
1099	6-Aug-22	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	12:07	14:40	2:33	LINE CLEAR AVOIDED
1100	6-Aug-22	BENGALURU	66	HEJJALA - BIDADI 1 220	NO STATION AFFECTED	09:10:00(06/08/2022)			LINE OPEN,LINE FAULT
1101	6-Aug-22	BENGALURU	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK	11:04	14:20	3:16	LINE CLEAR AVOIDED
1102	6-Aug-22	BENGALURU	66	HOODY 220 - HAL 2	BAGMANE WORLD TECH PARK	11:04	14:21	3:17	LINE CLEAR AVOIDED
1103	6-Aug-22	BENGALURU	66	HV1	BAGEPALLI	14:43	14:50	0:06	LINE CLEAR AVOIDED
1104	6-Aug-22	BENGALURU	66	HV1	CHINTAMANI 66	12:39	12:44	0:04	LINE CLEAR AVOIDED
1105	6-Aug-22	BENGALURU	66	HV1	GOLF LINK	10:20	12:45	2:25	LINE CLEAR AVOIDED
1106	6-Aug-22	BENGALURU	66	HV1	IRGAMPALLI	9:25	10:40	1:15	LINE CLEAR AVOIDED
1107	6-Aug-22	BENGALURU	66	HV1	MITTEMARI 220	8:48	10:29	1:41	TRANSFORMER FAULT
1108	6-Aug-22	BENGALURU	66	HV1	MITTEMARI 220	17:23	17:46	0:22	LINE CLEAR AVOIDED
1109	6-Aug-22	BENGALURU	66	HV2	DOMMASANDRA	17:25	17:38	0:13	TRANSFORMER FAULT
1110	6-Aug-22	BENGALURU	66	HV2	EAST DIVISION COMPOUND 220	10:22	10:28	0:06	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1111	6-Aug-22	BENGALURU	66	HV2	EAST DIVISION COMPOUND 220	17:24	17:28	0:04	LINE CLEAR AVAILED
1112	6-Aug-22	BENGALURU	66	HV2	GOLF LINK	12:00	14:20	2:20	LINE CLEAR AVAILED
1113	6-Aug-22	BENGALURU	66	HV2	IISc	17:06	17:10	0:04	LINE CLEAR AVAILED
1114	6-Aug-22	BENGALURU	66	HV2	IISc	17:53	18:02	0:09	LOAD CHANGE OVER
1115	6-Aug-22	BENGALURU	66	HV2	IRGAMPALLI	8:37	10:47	2:10	LINE CLEAR AVAILED
1116	6-Aug-22	BENGALURU	66	HV2	RMV	12:27	12:28	0:01	LINE CLEAR AVAILED
1117	6-Aug-22	BENGALURU	66	HV2	SIDDLAGHATTA	10:13	10:16	0:02	LINE CLEAR AVAILED
1118	6-Aug-22	BENGALURU	66	HV3	BIDADI 220	9:10	9:25	0:15	MAIN SUPPLY FAILURE
1119	6-Aug-22	BENGALURU	66	HV3	EAST DIVISION COMPOUND 220	10:22	10:28	0:06	LINE CLEAR AVAILED
1120	6-Aug-22	BENGALURU	66	HV3	EAST DIVISION COMPOUND 220	17:24	17:28	0:04	LINE CLEAR AVAILED
1121	6-Aug-22	BENGALURU	66	HV4	NRS 220	9:46	10:15	0:29	TRANSFORMER FAULT
1122	6-Aug-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	8:36	10:05	1:28	LINE FAULT
1123	6-Aug-22	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	10:16	10:30	0:14	LINE FAULT
1124	6-Aug-22	BENGALURU	66	MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66	MANYATHA TECH PARK 66	10:26	16:11	5:45	LINE CLEAR AVAILED
1125	6-Aug-22	BENGALURU	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	10:15	14:56	4:41	LINE CLEAR AVAILED
1126	6-Aug-22	BENGALURU	66	VEMGAL - KYALANUR	TALAGUNDA, VEMGAL, KYALNUR	10:50	10:55	0:05	LOAD CHANGE OVER
1127	6-Aug-22	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	VIDHURASHWATHA	17:15	17:25	0:10	LINE FAULT
1128	6-Aug-22	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	17:15	17:30	0:15	LINE FAULT
1129	6-Aug-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	9:15	9:29	0:14	LINE CLEAR AVAILED
1130	6-Aug-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	9:13	9:30	0:17	LINE CLEAR AVAILED
1131	6-Aug-22	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	11:29	17:15	5:46	LINE CLEAR AVAILED
1132	6-Aug-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	08:38:00(23/07/2022)			LINE OPEN,LINE FAULT
1133	6-Aug-22	BENGALURU	220	HV1	YARANDANAHALLI 220	9:18	9:27	0:09	LINE CLEAR AVAILED
1134	6-Aug-22	GULBARGA	66	HIREHADAGALI-SUZLONE_IPP	HIREHADAGALI_66	19:05(06.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1135	6-Aug-22	GULBARGA	66	HIREHADAGALLI-GIRIYAPURA	GIRIYAPURA_66,SOVENAHALLI_6 6,MAGALA_66	18:45	18:55	0:10	LINE FAULT
1136	6-Aug-22	GULBARGA	66	HV2	HALVAGALU_66	9:35	9:40	0:05	TRANSFORMER FAULT
1137	6-Aug-22	GULBARGA	66	HV2	TELAGI_66	8:10	8:15	0:05	TRANSFORMER FAULT
1138	6-Aug-22	GULBARGA	66	HV2	TELAGI_66	12:55	13:00	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1139	6-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66, MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	18:45(06.08.2022)			LINE OPEN,LINE FAULT
1140	6-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66, MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	4:25	4:30	0:05	LINE FAULT
1141	6-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	19:25(06.08.2022)			LINE OPEN,LINE FAULT
1142	6-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	19:25(06.08.2022)			LINE OPEN,LINE FAULT
1143	6-Aug-22	GULBARGA	66	KUDALAGI-KOTTUR	KOTTUR_220	18:40	18:50	0:10	LINE FAULT
1144	6-Aug-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK _IPP,BHALKI SUGAR_IPP	15:14	18:23	3:09	LINE CLEAR AVAILED
1145	6-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_ 110,DIGGI_110	15:14	18:29	3:15	LINE CLEAR AVAILED
1146	6-Aug-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	05:20(3.08.2022)			LINE OPEN,LINE FAULT
1147	6-Aug-22	GULBARGA	110	HUMNABAD-DUBALAGUNDI	DUBALAGUNDI_110	11:35	12:05	0:30	LINE FAULT
1148	6-Aug-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1149	6-Aug-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1150	6-Aug-22	GULBARGA	110	HV2	SREERAMANAGAR_110	9:00(02.08.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1151	6-Aug-22	GULBARGA	110	HV2	SREERAMANAGAR_110	9:00(02.08.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1152	6-Aug-22	GULBARGA	110	HV5	MUNIRABAD_220	17:04	17:57	0:53	LINE CLEAR AVAILED
1153	6-Aug-22	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	5:30	5:40	0:10	LINE FAULT
1154	6-Aug-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110, MANVI_110, ADVIAMRESHWAR_110	2:06	2:22	0:16	LINE FAULT
1155	6-Aug-22	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	12:10	12:25	0:15	MAIN SUPPLY FAILURE
1156	6-Aug-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGAL_110	4:53	5:08	0:15	LINE FAULT
1157	6-Aug-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGAL_110	19:48	20:20	0:32	LINE FAULT
1158	6-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1159	6-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1160	6-Aug-22	GULBARGA	110	SHAHAPUR-RAICHUR1&2	DEODURGA_110	15:02	16:50	1:48	LINE CLEAR AVAILED
1161	6-Aug-22	GULBARGA	110	SINDHNOOR-SINDHNOOR2	SINDHNOOR_110,VALKAMDINNI _110,BYAGWAT_110	10:15	18:20	8:05	LINE CLEAR AVAILED
1162	6-Aug-22	GULBARGA	110	SULEKAL-TAVARGERE	TAVARGERE_110	10:32	10:55	0:23	LINE CLEAR AVAILED
1163	6-Aug-22	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	02:06(06.08.2022)			LOAD CURTAILMENT
1164	6-Aug-22	HASSAN	66	CHIKABO-SIDPR	CHIKABOMMENAHALLI_66	15:24	15:45	0:21	LINE FAULT
1165	6-Aug-22	HASSAN	66	HNPR2-HNPR1	HOLEANARASIPURA_220	11:52	11:57	0:05	HAND TRIPPED
1166	6-Aug-22	HASSAN	66	HNPR2-RNPR1	HOLEANARASIPURA_220	6:44	6:52	0:08	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1167	6-Aug-22	HASSAN	66	HV1	BELUR_66	9:57	12:03	2:06	LINE CLEAR AVAILED
1168	6-Aug-22	HASSAN	66	HV1	HNPURA_66	11:50	12:00	0:10	MAIN SUPPLY FAILURE
1169	6-Aug-22	HASSAN	66	HV1	KUDLIGERE_66	15:30	16:40	1:10	MAIN SUPPLY FAILURE
1170	6-Aug-22	HASSAN	66	HV2	BELUR_66	9:57	12:32	2:35	LINE CLEAR AVAILED
1171	6-Aug-22	HASSAN	66	HV2	HNPURA_66	11:50	12:00	0:10	MAIN SUPPLY FAILURE
1172	6-Aug-22	HASSAN	66	HV2	SHANTHIGRAMA_66	10:28	12:08	1:40	LINE CLEAR AVAILED
1173	6-Aug-22	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	15:28	16:34	1:06	LINE FAULT
1174	6-Aug-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	15:30	16:40	1:10	MAIN SUPPLY FAILURE
1175	6-Aug-22	HASSAN	110	HV1	TOGARSI_110	15:58	17:10	1:12	LINE CLEAR AVAILED
1176	6-Aug-22	HASSAN	110	HV2	SORABA_110	10:09	13:50	3:41	LINE CLEAR AVAILED
1177	6-Aug-22	HASSAN	110	HV2	SORABA_110	20:25	23:05	2:40	LINE CLEAR AVAILED
1178	6-Aug-22	HASSAN	110	HV4	MANIPAL_110	9:52	11:03	1:11	LINE CLEAR AVAILED
1179	6-Aug-22	HASSAN	110	LV2	SHIRALKOPPA_220	12:46	16:35	3:49	TRANSFORMER FAULT
1180	6-Aug-22	HASSAN	110	LV3	KEMAR_220	10:26	12:40	2:14	LINE CLEAR AVAILED
1181	6-Aug-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:50	13:30	1:40	LINE CLEAR AVAILED
1182	6-Aug-22	HASSAN	110	SHRLKP-SHRLKP	SHIRALKOPPA_220	9:20	9:42	0:22	LINE CLEAR AVAILED
1183	6-Aug-22	HASSAN	220	ARSK2-HSN	ARASIKERE_220	11:30	17:12	5:42	NFBC ISSUED
1184	6-Aug-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
1185	6-Aug-22	HASSAN	220	HV2	SHIRALKOPPA_220	12:46	16:35	3:49	TRANSFORMER FAULT
1186	6-Aug-22	HASSAN	220	HV3	KEMAR_220	10:27	12:40	2:13	LINE CLEAR AVAILED
1187	6-Aug-22	HASSAN	220	KADUR-DABUSET	KADUR_220	11:35	17:16	5:41	NFBC ISSUED
1188	6-Aug-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	9:30	17:32	8:02	LINE CLEAR AVAILED
1189	6-Aug-22	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	9:32	15:30	5:58	LINE CLEAR AVAILED
1190	6-Aug-22	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	12:26	12:37	0:11	LINE FAULT
1191	6-Aug-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
1192	6-Aug-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	9:05	13:27	4:22	LINE CLEAR AVAILED
1193	6-Aug-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
1194	6-Aug-22	MYSURU	66	HOOTAGALLI-BARC-1	NO STATIONS EFFECTED	10:03	14:00	3:57	LINE CLEAR AVAILED
1195	6-Aug-22	MYSURU	66	HOOTAGALLI-BARC-2	NO STATIONS EFFECTED	10:03	14:00	3:57	LINE CLEAR AVAILED
1196	6-Aug-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1197	6-Aug-22	MYSURU	66	HV1	JAIPUR_66	10:10	11:06	0:56	LINE CLEAR AVAILED
1198	6-Aug-22	MYSURU	66	HV1	NANJANGUDU_66	10:01	10:13	0:11	HAND TRIPPED
1199	6-Aug-22	MYSURU	66	HV2	MEGALAPURA_66	21:44	22:05	0:20	TRANSFORMER FAULT
1200	6-Aug-22	MYSURU	66	HV2	MEGALAPURA_66	22:05	23:21	1:15	LINE CLEAR AVAILED
1201	6-Aug-22	MYSURU	66	KHB STATION-HOOTAGALLI	NO STATIONS EFFECTED	15:27	15:31	0:03	HAND TRIPPED
1202	6-Aug-22	MYSURU	66	KR NAGARA-BILIKERE	NO STATIONS EFFECTED	13:10:58 (4.8.2022)	15:20:00 (6.8.2022)	50:09HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1203	6-Aug-22	MYSURU	66	KUSHALNAGARA-MERCERA-1	MADIKERI_66	10:00	18:36	8:36	LINE CLEAR AVAILED
1204	6-Aug-22	MYSURU	66	KUSHALNAGARA-SUNTIKOPPA	SUNTIKOPPA_66	10:00	18:36	8:36	LINE CLEAR AVAILED
1205	6-Aug-22	MYSURU	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1206	6-Aug-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1207	6-Aug-22	MYSURU	220	KADAKOLA -ADAKANAHALLI- BEGUR 2	NO STATIONS EFFECTED	19:07:02 (5.8.2022)	18:47:00 (6.8.2022)	23:39HRS	LINE CHARGED
1208	6-Aug-22	MYSURU	220	KUSHALNAGARA-BASTIPURA 1	NO STATIONS EFFECTED	17:30	18:54	1:24	LINE FAULT
1209	6-Aug-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	8:01	18:52	10:51	LINE CLEAR AVAILED
1210	6-Aug-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGA LUR_66	2:07	2:20	0:12	LINE FAULT
1211	6-Aug-22	TUMKUR	66	HIRIYUR 220KV- SIRA220	HIRIYUR_220	11:19	11:25	0:05	HAND TRIPPED
1212	6-Aug-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	0:56	0:59	0:02	LINE FAULT
1213	6-Aug-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	10:15	10:20	0:05	LINE FAULT
1214	6-Aug-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	11:06	11:25	0:19	LINE FAULT
1215	6-Aug-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	12:05	12:20	0:15	LINE FAULT
1216	6-Aug-22	TUMKUR	66	PAVAGADA66-VENKATAPURA66	PAVAGADA_66	14:59	15:33	0:33	HAND TRIPPED
1217	6-Aug-22	TUMKUR	66	PAVAGADA66-VENKATAPURA66	PAVAGADA_66	22:10	22:21	0:11	LINE FAULT
1218	6-Aug-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	12:04	12:22	0:17	HAND TRIPPED
1219	6-Aug-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	13:14	13:29	0:14	HAND TRIPPED
1220	6-Aug-22	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	5:57	6:03	0:05	MAIN SUPPLY FAILURE
1221	6-Aug-22	TUMKUR	66	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	13:02	13:43	0:41	HAND TRIPPED
1222	6-Aug-22	TUMKUR	66	TR-1	BUKKAPATNA_66	14:30	15:35	1:05	LINE CLEAR AVAILED
1223	6-Aug-22	TUMKUR	66	TR-1	KATTIGE_66	16:15	17:06	0:51	LINE CLEAR AVAILED
1224	6-Aug-22	TUMKUR	66	TR-1	LOKIKERE_66	7:16	7:29	0:12	TRANSFORMER FAULT
1225	6-Aug-22	TUMKUR	66	TR-1	MADADAKERE_66	7:04	7:10	0:06	TRANSFORMER FAULT
1226	6-Aug-22	TUMKUR	66	TR-1	RAMPURA_66	20:50	21:01	0:11	TRANSFORMER FAULT
1227	6-Aug-22	TUMKUR	66	TR-2	CHANNAGIRI_66	16:43	16:49	0:06	TRANSFORMER FAULT
1228	6-Aug-22	TUMKUR	66	TR-2	MADADAKERE_66	13:06	13:12	0:06	TRANSFORMER FAULT
1229	6-Aug-22	TUMKUR	110	TR-2	HULIYAR_110	19:21	20:07	0:45	TRANSFORMER FAULT
1230	6-Aug-22	TUMKUR	220	ANTHRASANAHALLI 220kv- SHIMOGA	ANTHRASANAHALLI_220	9:30	17:55	8:25	LINE CLEAR AVAILED
1231	6-Aug-22	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	9:33	15:38	6:04	LINE CLEAR AVAILED
1232	6-Aug-22	TUMKUR	220	NITTUR 220kv- HASSAN(ARASIKERE)	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	11:31	17:13	5:42	LINE CLEAR AVAILED
1233	7-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED AEQUS_220	21:09 (30.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1234	7-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED KATARAKI_110	12:40	14:10	1:30	LINE CLEAR AVAILED
1235	7-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED KUDACHI_220	10:18	10:22	0:04	TRANSFORMER FAULT
1236	7-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED KUDACHI_220	12:59	13:03	0:04	TRANSFORMER FAULT
1237	7-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED MACHE_110	4:50	5:10	0:20	TRANSFORMER FAULT
1238	7-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED MACHE_110	5:43	7:03	1:20	TRANSFORMER FAULT
1239	7-Aug-22	BAGALKOT	110	110/11KV, HV-1	STATION NOT AFFECTED SHIRAGUPPI_110	14:55	15:25	0:30	TRANSFORMER FAULT
1240	7-Aug-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	7:28 (29.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1241	7-Aug-22	BAGALKOT	110	110/11KV,HV1	TIKOTA_110	12:24	12:31	0:07	TRANSFORMER FAULT
1242	7-Aug-22	BAGALKOT	110	110/11KV,HV1	TIKOTA_110	18:16	18:56	0:40	TRANSFORMER FAULT
1243	7-Aug-22	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	6:33	6:43	0:10	TRANSFORMER FAULT
1244	7-Aug-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1245	7-Aug-22	BAGALKOT	110	110/33KV, HV-3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1246	7-Aug-22	BAGALKOT	110	ALABAL-RFE	ALABAL_110	10:26	13:44	3:18	NFBC ISSUED
1247	7-Aug-22	BAGALKOT	110	ALABAL-SPRS	ALABAL_110	10:26	14:03	3:37	NFBC ISSUED
1248	7-Aug-22	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	13:22	17:24	4:02	LINE FAULT
1249	7-Aug-22	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	17:24	19:01	1:37	LINE CLEAR AVAILED
1250	7-Aug-22	BAGALKOT	110	DAMBAL-EILS	DAMBAL_110	12:25	12:55	0:30	LINE FAULT
1251	7-Aug-22	BAGALKOT	110	SAVALAGI-AIGALI	SAVALAGI_110	16:44 (06.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1252	7-Aug-22	BAGALKOT	110	UTTUR - F1 JAMB CB( MUDHOL)	STATION NOT AFFECTED UTTUR_110	9:51 (24.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1253	7-Aug-22	BAGALKOT	110	YALLAMANAWADI-AIGALI	AIGALI_110	10:26	13:39	3:13	NFBC ISSUED
1254	7-Aug-22	BAGALKOT	110	YALLAMANAWADI-AIGALI	AIGALI_110	14:34	14:43	0:09	LINE FAULT
1255	7-Aug-22	BAGALKOT	110	YLWD-F2 Cbreaker(SAVALAGI)	STATION NOT AFFECTED YELLAMANAWADI_110,	19:58 (06.08.2022)	14:29 (07.08.2022)	18:31HRS	LINE CHARGED
1256	7-Aug-22	BAGALKOT	110	YLWD-F2 Cbreaker(SAVALAGI)	STATION NOT AFFECTED YELLAMANAWADI_110,SAVALAG I_110	14:34 (07.08.2022)			LINE OPEN,LINE FAULT
1257	7-Aug-22	BAGALKOT	220	BIJAPUR-INDI- 2	STATION NOT AFFECTED INDI_220	16:30	18:20	1:50	LINE CLEAR AVAILED
1258	7-Aug-22	BAGALKOT	220	220/110KV, HV-1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1259	7-Aug-22	BAGALKOT	220	220/110KV, HV-2 & LV2	STATION NOT AFFECTED BIJAPUR_220	17:57	18:34	0:37	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1260	7-Aug-22	BAGALKOT	220	220/110KV, HV-3 & LV-3	STATION NOT AFFECTED ATHANI_220	10:26 (25.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVOIDED
1261	7-Aug-22	BAGALKOT	220	BAGEWADI-ATRIYA1&2	BAGEWADI_220	10:23	11:40	1:17	LINE CLEAR AVOIDED
1262	7-Aug-22	BAGALKOT	220	BELAGAVI-AEQUS-2	STATION NOT AFFECTED BELAGAVI_220	11:39 (05.08.2022)			LINE OPEN,LINE CLEAR AVOIDED
1263	7-Aug-22	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	16:50	19:16	2:26	NFBC ISSUED
1264	7-Aug-22	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	3:58 (6.8.2022)	14:50 (7.8.2022)	34:52HRS	LINE CHARGED
1265	7-Aug-22	BAGALKOT	220	BIJAPUR-INDI-2	STATION NOT AFFECTED BIJAPUR_220	13:40	18:20	4:40	LINE CLEAR AVOIDED
1266	7-Aug-22	BAGALKOT	220	HUBLI-BIDNAL-1	STATION NOT AFFECTED HUBLI_220	3:58 (06.08.2022)	15:13 (07.08.2022)	35:15HRS	LINE CHARGED
1267	7-Aug-22	BAGALKOT	220	RANEBENNUR-SHIRALKOPPA ( BALLIGAVI )	STATION NOT AFFECTED RANEBENNUR_220	19:26 (05.08.2022)			LINE OPEN,LINE CLEAR AVOIDED
1268	7-Aug-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	6:40 (07.08.2022)			LINE OPEN,LINE CLEAR AVOIDED
1269	7-Aug-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	6:39 (07.08.2022)			LINE OPEN,LINE CLEAR AVOIDED
1270	7-Aug-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	15:57	16:43	0:46	LINE CLEAR AVOIDED
1271	7-Aug-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	15:57	16:43	0:46	LINE CLEAR AVOIDED
1272	7-Aug-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	16:52	17:02	0:10	LINE FAULT
1273	7-Aug-22	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	15:57	16:43	0:46	LINE CLEAR AVOIDED
1274	7-Aug-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	15:57	16:43	0:46	LINE CLEAR AVOIDED
1275	7-Aug-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	15:57	16:43	0:46	LINE CLEAR AVOIDED
1276	7-Aug-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	15:57	16:43	0:46	LINE CLEAR AVOIDED
1277	7-Aug-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, GUNDAMGERE	15:57	16:43	0:46	LINE CLEAR AVOIDED
1278	7-Aug-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:57	16:43	0:46	LINE CLEAR AVOIDED
1279	7-Aug-22	BENGALURU	66	GURUVINAPURA - BV HALLI	BV HALLI	4:57	5:13	0:16	LINE FAULT
1280	7-Aug-22	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	11:30	11:35	0:05	LOAD CHANGE OVER
1281	7-Aug-22	BENGALURU	66	HEJJALA - BIDADI 1 220	NO STATION AFFECTED	09:10:00(06/08/2022)			LINE OPEN,LINE FAULT
1282	7-Aug-22	BENGALURU	66	HV1	SOMANAHALLI 220	7:56	8:17	0:21	TRANSFORMER FAULT
1283	7-Aug-22	BENGALURU	66	HV1	YARANDANAHALLI 220	15:40	16:12	0:32	LINE CLEAR AVOIDED
1284	7-Aug-22	BENGALURU	66	HV2	DOMMASANDRA	21:25	21:30	0:05	TRANSFORMER FAULT
1285	7-Aug-22	BENGALURU	66	HV2	YARANDANAHALLI 220	15:45	16:03	0:18	LINE CLEAR AVOIDED
1286	7-Aug-22	BENGALURU	66	HV3	YARANDANAHALLI 220	15:40	16:12	0:32	LINE CLEAR AVOIDED
1287	7-Aug-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	10:20	17:30	7:10	LINE CLEAR AVOIDED
1288	7-Aug-22	BENGALURU	66	KODIGEHALI - MAGADI 220	KODIGEHALI	10:24	16:12	5:48	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1289	7-Aug-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	10:55	12:30	1:35	LINE CLEAR AVAILED
1290	7-Aug-22	BENGALURU	66	MAGADI 220 - TG HALLI	VG DODDI, TAVAREKERE	10:55	12:30	1:35	LINE CLEAR AVAILED
1291	7-Aug-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	13:12	15:04	1:52	LINE CLEAR AVAILED
1292	7-Aug-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	13:12	15:04	1:52	LINE CLEAR AVAILED
1293	7-Aug-22	BENGALURU	66	RANGANDODDI - KANAKPURA 220	RANGANDODDI	10:28	17:30	7:02	LINE CLEAR AVAILED
1294	7-Aug-22	BENGALURU	66	SATNUR - KANAKPURA 220	SATANUR, HONNIGANAHALLI, HALGUR	11:10	11:30	0:20	LINE FAULT
1295	7-Aug-22	BENGALURU	66	T G HALLI - TAVAREKERE	TAVAREKERE	13:25	16:10	2:45	LINE CLEAR AVAILED
1296	7-Aug-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	15:38	16:06	0:28	LINE CLEAR AVAILED
1297	7-Aug-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	15:38	16:06	0:28	LINE CLEAR AVAILED
1298	7-Aug-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	15:43	16:10	0:27	LINE CLEAR AVAILED
1299	7-Aug-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	15:43	16:10	0:27	LINE CLEAR AVAILED
1300	7-Aug-22	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	15:38	16:11	0:33	LINE CLEAR AVAILED
1301	7-Aug-22	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	9:06	17:00	7:54	LINE CLEAR AVAILED
1302	7-Aug-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	08:38:00(23/07/2022)			LINE OPEN,LINE FAULT
1303	7-Aug-22	BENGALURU	220	HV1	YARANDANAHALLI 220	15:52	16:08	0:16	LINE CLEAR AVAILED
1304	7-Aug-22	BENGALURU	220	HV3	YARANDANAHALLI 220	15:46	16:02	0:16	LINE CLEAR AVAILED
1305	7-Aug-22	GULBARGA	66	BENNEHALLI-ITTAGGI	BENNEHALLI_66,KOTTUR_66	9:35	9:55	0:20	LINE FAULT
1306	7-Aug-22	GULBARGA	66	BENNEHALLI-ITTAGGI	BENNEHALLI_66,KOTTUR_66	13:30	13:45	0:15	LINE FAULT
1307	7-Aug-22	GULBARGA	66	GANDHINAGAR-TURVIHAL	TURVIHAL_110	4:31	4:33	0:02	LINE FAULT
1308	7-Aug-22	GULBARGA	66	HOSAHALLI-SML_WIND	HOSAHALLI_66	9:20	9:40	0:20	LINE FAULT
1309	7-Aug-22	GULBARGA	66	HV	ITTAGI_220KV	15:43			TRANSFORMER OPEN,LINE CLEAR AVAILED
1310	7-Aug-22	GULBARGA	66	HV2	BENNEHALLI_66	16:30	16:45	0:15	TRANSFORMER FAULT
1311	7-Aug-22	GULBARGA	66	HV2	SEDAM_220KV	10:05			LOAD CURTAILMENT
1312	7-Aug-22	GULBARGA	66	HV2	SEDAM_220KV	9:35	17:20	7:45	LOAD CURTAILMENT
1313	7-Aug-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66 & BENNEHALLI_66	9:35	9:53	0:18	LINE FAULT
1314	7-Aug-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66 & BENNEHALLI_66	13:35	13:45	0:10	LINE FAULT
1315	7-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	19:25(06.08.2022)	02:50(07.08.2022)	7:25HRS	LINE CHARGED
1316	7-Aug-22	GULBARGA	66	ITTAGI-RENEW SOLAR1&2_IPP	ITTAGI_220KV	19:08	21:58	2:50	LINE CLEAR AVAILED
1317	7-Aug-22	GULBARGA	66	SEDAM-HUMNABAD2	HUMNABAD_220KV	10:04			LOAD CURTAILMENT
1318	7-Aug-22	GULBARGA	66	SEDAM-HUMNABAD2	HUMNABAD_220KV	9:30	17:25	7:55	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1319	7-Aug-22	GULBARGA	66	SEDAM-SHAHAPUR	NO STATION LOAD IS EFFECTED.	12:35	19:52	7:17	NFBC ISSUED
1320	7-Aug-22	GULBARGA	66	SEDAM-TANDUR	TANDUR_220KV	1:17	9:19	8:02	LOAD CURTAILMENT
1321	7-Aug-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	2:55	3:00	0:05	MAIN SUPPLY FAILURE
1322	7-Aug-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	5:15	5:20	0:05	MAIN SUPPLY FAILURE
1323	7-Aug-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	5:45	5:50	0:05	MAIN SUPPLY FAILURE
1324	7-Aug-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	11:50	12:10	0:20	MAIN SUPPLY FAILURE
1325	7-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	2:56	3:01	0:05	LINE FAULT
1326	7-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	5:16	5:21	0:05	LINE FAULT
1327	7-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	5:45	5:50	0:05	LINE FAULT
1328	7-Aug-22	GULBARGA	110	HIREHADAGALI-SUZLONE_IPP	HIREHADAGALI_66	19:05(06.08.2022)	3:05(7.08.2022)	08:00HRS	LINE CHARGED
1329	7-Aug-22	GULBARGA	110	HOSAHALLI-CLEAN MAX_IPP	HOSAHALLI_110	9:20	9:40	0:20	LINE FAULT
1330	7-Aug-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	05:20(3.08.2022)			LINE OPEN,LINE FAULT
1331	7-Aug-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1332	7-Aug-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1333	7-Aug-22	GULBARGA	110	HV2	DEODURGA_110	18:10	18:20	0:10	TRANSFORMER FAULT
1334	7-Aug-22	GULBARGA	110	HV2	DEODURGA_110	18:30	18:40	0:10	TRANSFORMER FAULT
1335	7-Aug-22	GULBARGA	110	HV2	DEODURGA_110	19:00	19:10	0:10	TRANSFORMER FAULT
1336	7-Aug-22	GULBARGA	110	HV2	SREERAMANAGAR_110	9:00(02.08.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1337	7-Aug-22	GULBARGA	110	HV3	HATTI_110	13:52	14:10	0:18	TRANSFORMER FAULT
1338	7-Aug-22	GULBARGA	110	ITTAGI-HIREHADAGALI_2	HIREHADAGALI_66,GIRYAPUR_66, MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	18:45(06.08.2022)	2:50(07.08.2022)	08:05HRS	LINE CHARGED
1339	7-Aug-22	GULBARGA	110	JEEWARGI-SHAHAPUR1	JEEWARGI_110	23:30	23:43	0:13	LINE FAULT
1340	7-Aug-22	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	23:38	23:44	0:06	LINE FAULT
1341	7-Aug-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110, MANVI_110, ADVIAMRESHWAR_110	0:28	0:35	0:07	LINE FAULT
1342	7-Aug-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110, MANVI_110, ADVIAMRESHWAR_110	2:12	2:22	0:10	LINE FAULT
1343	7-Aug-22	GULBARGA	110	NALWAR-SHAHABAD2	JEEWARGI_110	23:30	23:45	0:15	LINE FAULT
1344	7-Aug-22	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	15:00	15:35	0:35	MAIN SUPPLY FAILURE
1345	7-Aug-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGAL_110	20:33	20:40	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1346	7-Aug-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGAL_110	20:50	21:03	0:13	LINE FAULT
1347	7-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1348	7-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1349	7-Aug-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	23:32	23:37	0:05	LINE FAULT
1350	7-Aug-22	GULBARGA	110	SINDHNOOR-SIRIGUPPA	DHADESUGUR_110,SIRIGUPPA_110,TEKKALKOTE_110,NSLSUGAR_110,SIRIGERICROSS_110	4:01	4:15	0:14	LINE FAULT
1351	7-Aug-22	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	02:06(06.08.2022)			LOAD CURTAILMENT
1352	7-Aug-22	HASSAN	66	HV4	BALEHONNUR_66	17:01	17:26	0:25	LINE CLEAR AVAILED
1353	7-Aug-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	14:35	14:53	0:18	LINE FAULT
1354	7-Aug-22	HASSAN	110	HV2	BAIKAMPADY_110	10:30	12:09	1:39	LINE CLEAR AVAILED
1355	7-Aug-22	HASSAN	110	HV2	BANAVARA_110	11:40	11:50	0:10	MAIN SUPPLY FAILURE
1356	7-Aug-22	HASSAN	220	ARSK2-HSN	ARASIKERE_220	9:17	17:11	7:54	NFBC ISSUED
1357	7-Aug-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
1358	7-Aug-22	HASSAN	220	KADUR-DABUSET	KADUR_220	8:58	17:01	8:03	NFBC ISSUED
1359	7-Aug-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	9:03	14:33	5:30	LINE CLEAR AVAILED
1360	7-Aug-22	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	9:01	17:37	8:36	LINE CLEAR AVAILED
1361	7-Aug-22	MYSURU	66	HALAGUR-HONNAGAHALLI	HALAGUR_66	11:10	11:40	0:30	HAND TRIPPED
1362	7-Aug-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAILED
1363	7-Aug-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN,LINE CLEAR AVAILED
1364	7-Aug-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1365	7-Aug-22	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	17:57	18:26	0:28	LINE FAULT
1366	7-Aug-22	MYSURU	66	KADAKOLA-SARGUR 2	NO STATIONS EFFECTED	17:57	18:12	0:15	LINE FAULT
1367	7-Aug-22	MYSURU	66	THANDYA-KADAKOLA	NO STATIONS EFFECTED	17:57	18:26	0:29	LINE FAULT
1368	7-Aug-22	MYSURU	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1369	7-Aug-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1370	7-Aug-22	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	10:56	14:27	3:31	LINE CLEAR AVAILED
1371	7-Aug-22	TUMKUR	66	HIRIYUR 220KV- SIRA220	HIRIYUR_220	16:20	16:45	0:25	LINE FAULT
1372	7-Aug-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:12	15:21	0:09	LINE FAULT
1373	7-Aug-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	11:29	11:36	0:07	HAND TRIPPED
1374	7-Aug-22	TUMKUR	66	TR-1	KATTIGE_66	10:32	18:06	7:34	LINE CLEAR AVAILED
1375	7-Aug-22	TUMKUR	66	TR-2	CHANNAGIRI_66	3:52	4:08	0:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1376	7-Aug-22	TUMKUR	66	TR-2	KUKKAWADA_66	15:05	16:12	1:07	TRANSFORMER FAULT
1377	7-Aug-22	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_110,	15:44	17:43	1:58	LINE CLEAR AVAILED
1378	7-Aug-22	TUMKUR	110	SAMPIGE- NITTUR220	SAMPIGE_110	14:06	14:58	0:52	MAIN SUPPLY FAILURE
1379	7-Aug-22	TUMKUR	110	TR-1	KBCROSS_220	15:44	17:43	1:58	LINE CLEAR AVAILED
1380	7-Aug-22	TUMKUR	110	TR-1	MAYASANDRA_110	10:10	17:00	6:50	LINE CLEAR AVAILED
1381	7-Aug-22	TUMKUR	220	ANTHRASANAHALLI 220kV- KB CROSS 220	KB CROSS_220	10:12	17:30	7:18	LINE CLEAR AVAILED
1382	7-Aug-22	TUMKUR	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	9:03	14:38	5:35	NFBC ISSUED
1383	7-Aug-22	TUMKUR	220	BENKIKERE220-HOSADURGA220KV	BENKIKERE_220	13:57	18:02	4:05	LINE CLEAR AVAILED
1384	7-Aug-22	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	9:02	17:43	8:40	LINE CLEAR AVAILED
1385	7-Aug-22	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	14:14	17:11	2:57	LINE CLEAR AVAILED
1386	8-Aug-22	BAGALKOT	110	110/11KV, HV-1(20MVA)	STATION NOT AFFECTED AEQUS_220	21:09 (30.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1387	8-Aug-22	BAGALKOT	110	110/11KV, HV-2	STATION NOT AFFECTED MANTUR_110	10:15	10:20	0:05	TRANSFORMER FAULT
1388	8-Aug-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED BILAGI_110	7:28 (29.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1389	8-Aug-22	BAGALKOT	110	110/11KV,HV1	DEVAR GENNUR_110	12:36	13:08	0:32	TRANSFORMER FAULT
1390	8-Aug-22	BAGALKOT	110	110/11KV,HV1	DEVAR GENNUR_110	18:18	18:34	0:16	TRANSFORMER FAULT
1391	8-Aug-22	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	11:16	12:35	1:19	LINE CLEAR AVAILED
1392	8-Aug-22	BAGALKOT	110	110/11KV,HV1	VAJRAMATTI_110	12:58	13:17	0:19	TRANSFORMER FAULT
1393	8-Aug-22	BAGALKOT	110	110/11KV,HV1 (10MVA)	SIDDAPUR_110	17:08	17:38	0:30	LINE CLEAR AVAILED
1394	8-Aug-22	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	13:26	19:10	5:44	LINE CLEAR AVAILED
1395	8-Aug-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED TODALBAGI_110	19:13 (17.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1396	8-Aug-22	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	11:05	12:25	1:20	TRANSFORMER FAULT
1397	8-Aug-22	BAGALKOT	110	110/33KV, HV-3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1398	8-Aug-22	BAGALKOT	110	110/33KV, HV4(HV2)	ZALKI_110, HALSANGI_33,DHULKHED_33,NE VARGI_33	13:32	13:36	0:04	TRANSFORMER FAULT
1399	8-Aug-22	BAGALKOT	110	110/33KV,HV1	CHIKKODI_110 , KABBUR_33	8:15	8:21	0:06	TRANSFORMER FAULT
1400	8-Aug-22	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110 &KARJOL ,NTPC&KOLHAR_33	12:35	12:46	0:11	TRANSFORMER FAULT
1401	8-Aug-22	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 &RUSUMPUR & BGM W/S_33	22:26	22:39	0:13	TRANSFORMER FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1402	8-Aug-22	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 &RUSUMPUR & BGM W/S_33	22:45	22:49	0:04	TRANSFORMER FAULT
1403	8-Aug-22	BAGALKOT	110	AHERI220-LN5 (SINDAGI)	STATION NOT AFFECTED SINDAGI_110	7:08	13:38	6:30	LINE CLEAR AVAILED
1404	8-Aug-22	BAGALKOT	110	AHERI220-LN7 (MALAGHAN(S))	STATION NOT AFFECTED MALAGHAN(S)_110	7:12	13:17	6:05	LINE CLEAR AVAILED
1405	8-Aug-22	BAGALKOT	110	ANMOD-GOA-2	ANMOD_110	13:10 (08.08.2022)			MAIN SUPPLY FAILURE
1406	8-Aug-22	BAGALKOT	110	BHUTANAL-BJCTY(THORVI)	THORVI_110	13:43	17:32	3:49	LOAD CURTAILMENT
1407	8-Aug-22	BAGALKOT	110	BIJAPUR220-KIADB1,2&BIJAPUR	KIADB BIJAPUR_110	7:12	7:30	0:18	HAND TRIPPED
1408	8-Aug-22	BAGALKOT	110	DAMBAL-MUNDARAGI(GADAGL5)	MUNDARAGI_110	9:00	9:25	0:25	LINE FAULT
1409	8-Aug-22	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	1:50	19:15	17:25	LINE CLEAR AVAILED
1410	8-Aug-22	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERADAL_110	1:15	1:27	0:12	LINE FAULT
1411	8-Aug-22	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERADAL_110	1:31	2:05	0:34	HAND TRIPPED
1412	8-Aug-22	BAGALKOT	110	MALGHAN(S)-MORATAGI	STATION NOT AFFECTED MALAGHAN(S)_110	7:12	13:20	6:08	LINE CLEAR AVAILED
1413	8-Aug-22	BAGALKOT	110	MAMADAPUR -SHIRABUR	SHIRABUR_110	15:52	18:32	2:40	LINE CLEAR AVAILED
1414	8-Aug-22	BAGALKOT	110	SATTI-RABAKAVI	RABAKAVI_110	1:59	2:08	0:09	HAND TRIPPED
1415	8-Aug-22	BAGALKOT	110	SAVALAGI-AIGALI	STATION NOT AFFECTED SAVALAGI_110	16:44 (06.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1416	8-Aug-22	BAGALKOT	110	TAKLI-KNSCBreaker	TAKKALAKI_110, KN SOLAR_IPP	7:05	8:00	0:55	HAND TRIPPED
1417	8-Aug-22	BAGALKOT	110	TAKLI-KNSCBreaker	TAKKALAKI_110, KN SOLAR_IPP	17:34	17:36	0:02	HAND TRIPPED
1418	8-Aug-22	BAGALKOT	110	TAKLI-TIK Cbreaker	TAKKALAKI_110	17:34	17:35	0:01	HAND TRIPPED
1419	8-Aug-22	BAGALKOT	110	TAKLI-TRVCBbreaker	TAKKALAKI_110	17:32	17:34	0:02	HAND TRIPPED
1420	8-Aug-22	BAGALKOT	110	TAKLI-WRDCBbreaker	TAKKALAKI_110, WRDSOLAR_IPP	17:33	17:36	0:03	HAND TRIPPED
1421	8-Aug-22	BAGALKOT	110	UTTUR - F1 JAMB CB( MUDHOL)	STATION NOT AFFECTED UTTUR_110	9:51 (24.07.2022)			LINE OPEN,LINE CLEAR AVAILED
1422	8-Aug-22	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	12:58	13:17	0:19	LINE FAULT
1423	8-Aug-22	BAGALKOT	110	YLWD-F2 Cbreaker(SAVALAGI)	STATION NOT AFFECTED YELLAMANAWADI_110	14:34 (07.08.2022)	20:05 (08.08.2022)	29:31HRS	LINE CHARGED
1424	8-Aug-22	BAGALKOT	220	220/110KV, HV-1	STATION NOT AFFECTED AMBEWADI_220	20:00 (09.07.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1425	8-Aug-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED AHERI_220	13:08	14:52	1:44	LINE CLEAR AVAILED
1426	8-Aug-22	BAGALKOT	220	220/110KV, HV2 (HV3) & LV2 (LV3)	STATION NOT AFFECTED CHIKKODI_220	8:42	13:38	4:56	TRANSFORMER FAULT
1427	8-Aug-22	BAGALKOT	220	220/110KV, HV-3 & LV-3	STATION NOT AFFECTED ATHANI_220	10:26 (25.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1428	8-Aug-22	BAGALKOT	220	AHERI-VIJAYPUR-1	AHERI_220	8:55	12:46	3:51	LINE CLEAR AVAILED
1429	8-Aug-22	BAGALKOT	220	AHERI-VIJAYPUR-2	AHERI_220	8:56	12:46	3:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1430	8-Aug-22	BAGALKOT	220	BELAGAVI-AEQUS-2	STATION NOT AFFECTED BELAGAVI_220	11:39 (05.08.2022)	19:06 (08.08.2022)	79:27HRS	LINE CHARGED
1431	8-Aug-22	BAGALKOT	220	GADAG-HARTHI-2	STATION NOT AFFECTED GADAG_220	16:52:00 (06.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1432	8-Aug-22	BAGALKOT	220	HUBLI-NARENDRA-2	STATIONN OT AFFECTED HUBLI_220	21:51 (08.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1433	8-Aug-22	BAGALKOT	220	INDI-VIJAYPUR-1&2	INDI_220	7:10	13:00	5:50	LINE FAULT
1434	8-Aug-22	BAGALKOT	220	NARENDRA-HUBLI-2	STATION NOT AFFECTED NARENDRA_220	21:46 (08.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1435	8-Aug-22	BAGALKOT	220	RANEENNUR-SHIRALKOPPA ( BALLIGAVI )	STATION NOT AFFECTED RANEENNUR_220	19:26 (05.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1436	8-Aug-22	BAGALKOT	220	SIRSI-HUBLI-1	STATION NOT AFFECTED SIRSI_220	6:40 (07.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1437	8-Aug-22	BAGALKOT	220	SIRSI-HUBLI-2	STATION NOT AFFECTED SIRSI_220	6:39 (07.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1438	8-Aug-22	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI, JAKKASANDRA	8:26	8:33	0:07	LOAD CHANGE OVER
1439	8-Aug-22	BENGALURU	66	AVANI - KOLAR 220	AVANI	14:55	15:20	0:25	LINE CLEAR AVOIDED
1440	8-Aug-22	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	NO STATION AFFECTED	6:50	7:15	0:25	LINE FAULT
1441	8-Aug-22	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	14:35	14:50	0:15	LOAD CHANGE OVER
1442	8-Aug-22	BENGALURU	66	BRIGADE GATEWAY - NRS 220	BRIGADE GATEWAY	10:25	17:09	6:44	LINE CLEAR AVOIDED
1443	8-Aug-22	BENGALURU	66	C STATION 1 & 2 - A STATION 220	C STATION 1 & 2	7:03	7:08	0:05	LOAD CHANGE OVER
1444	8-Aug-22	BENGALURU	66	C STATION 1 & 2 - A STATION 220	C STATION 1 & 2	22:31	22:33	0:02	LOAD CHANGE OVER
1445	8-Aug-22	BENGALURU	66	C STATION 1 & 2 - HEBBALA 220	C STATION 1 & 2	18:13	18:18	0:05	LOAD CHANGE OVER
1446	8-Aug-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:23	11:34	0:11	LINE FAULT
1447	8-Aug-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	13:50	14:20	0:30	LINE CLEAR AVOIDED
1448	8-Aug-22	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	11:10	18:05	6:55	LINE FAULT
1449	8-Aug-22	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	11:10	11:15	0:05	LOAD CHANGE OVER
1450	8-Aug-22	BENGALURU	66	HEJJALA - BIDADI 1 220	NO STATION AFFECTED	09:10:00(06/08/2022)	15:40(08/08/2022 )	54:30HRS	LINE CHARGED
1451	8-Aug-22	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	14:23	14:35	0:12	LINE FAULT
1452	8-Aug-22	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	17:25	17:30	0:05	LOAD CHANGE OVER
1453	8-Aug-22	BENGALURU	66	HV1	BOODIGERE	12:05	13:35	1:30	LINE CLEAR AVOIDED
1454	8-Aug-22	BENGALURU	66	HV1	PALLICHERLU	10:43	10:54	0:10	TRANSFORMER FAULT
1455	8-Aug-22	BENGALURU	66	HV1	REMC0	9:33	9:36	0:03	LOAD CHANGE OVER
1456	8-Aug-22	BENGALURU	66	HV1	T GOLLAHALLI 220	13:30	14:10	0:40	LINE CLEAR AVOIDED
1457	8-Aug-22	BENGALURU	66	HV1	VIJAYANAGARA	9:40	9:47	0:07	LOAD CHANGE OVER
1458	8-Aug-22	BENGALURU	66	HV1	VIJAYANAGARA	23:16	23:23	0:07	LOAD CHANGE OVER
1459	8-Aug-22	BENGALURU	66	HV2	BAGEPALLI	13:49	13:55	0:05	LINE CLEAR AVOIDED
1460	8-Aug-22	BENGALURU	66	HV2	BIDADI 220	7:28	14:24	6:56	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1461	8-Aug-22	BENGALURU	66	HV2	CHAKAVELU	19:22	19:32	0:10	LINE CLEAR AVAILED
1462	8-Aug-22	BENGALURU	66	HV2	GOWRIBIDANUR 220	12:52	13:03	0:11	TRANSFORMER FAULT
1463	8-Aug-22	BENGALURU	66	HV2	NRS 220	16:32	17:05	0:33	LINE CLEAR AVAILED
1464	8-Aug-22	BENGALURU	66	HV2	REMC0	23:08	23:11	0:03	LOAD CHANGE OVER
1465	8-Aug-22	BENGALURU	66	HV2	SIDDLAGHATTA	13:55	14:00	0:04	LINE CLEAR AVAILED
1466	8-Aug-22	BENGALURU	66	HV2	SM MANGALA	14:32	15:04	0:32	LINE CLEAR AVAILED
1467	8-Aug-22	BENGALURU	66	HV2	VIJAYANAGARA	9:40	9:47	0:07	LOAD CHANGE OVER
1468	8-Aug-22	BENGALURU	66	HV2	VIJAYANAGARA	23:16	23:26	0:10	LOAD CHANGE OVER
1469	8-Aug-22	BENGALURU	66	HV4	NRS 220	10:20	13:30	3:10	LINE CLEAR AVAILED
1470	8-Aug-22	BENGALURU	66	HV5	NRS 220	10:40	17:20	6:40	LINE CLEAR AVAILED
1471	8-Aug-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	16:14	18:10	1:56	LINE CLEAR AVAILED
1472	8-Aug-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	18:11	18:17	0:06	LINE CLEAR AVAILED
1473	8-Aug-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	17:15	17:24	0:09	LINE FAULT
1474	8-Aug-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	7:16	7:21	0:05	LOAD CHANGE OVER
1475	8-Aug-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	15:05	15:20	0:15	LOAD CHANGE OVER
1476	8-Aug-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	15:40	15:47	0:07	LOAD CHANGE OVER
1477	8-Aug-22	BENGALURU	66	TELECOM LAYOUT - NRS 220	TELECOM LAYOUT	10:20	17:03	6:43	LINE CLEAR AVAILED
1478	8-Aug-22	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	6:30	6:46	0:16	LINE FAULT
1479	8-Aug-22	BENGALURU	220	EAST DIVISION COMPOUND 220 - A STATION 220	NO STATION AFFECTED	08:38:00(23/07/2022)			LINE OPEN,LINE FAULT
1480	8-Aug-22	GULBARGA	66	HOSAHALLI-SML WIND	HOSAHALLI_66	12:20	12:35	0:15	LINE CLEAR AVAILED
1481	8-Aug-22	GULBARGA	66	HV1	ITTAGI_220KV	15:43(07.08.2022)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1482	8-Aug-22	GULBARGA	66	HV2	SEDAM_220KV	10:05(07.08.2022)			LOAD CURTAILMENT
1483	8-Aug-22	GULBARGA	66	ITTAGI-HIREHADAGALI_1	HIREHADAGALI_66	12:32	12:39	0:07	HAND TRIPPED
1484	8-Aug-22	GULBARGA	66	SEDAM-HUMNABAD2	HUMNABAD_220KV	10:04(07.08.2022)			LINE OPEN,LINE CLEAR AVAILED
1485	8-Aug-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	5:42	5:47	0:05	MAIN SUPPLY FAILURE
1486	8-Aug-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	20:57	21:02	0:05	MAIN SUPPLY FAILURE
1487	8-Aug-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	5:43	5:48	0:05	LINE FAULT
1488	8-Aug-22	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	05:20(3.08.2022)			LINE OPEN,LINE FAULT
1489	8-Aug-22	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	5:50	6:07	0:17	LINE FAULT
1490	8-Aug-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1491	8-Aug-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:54(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1492	8-Aug-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1493	8-Aug-22	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	9:34(20/07/2022)			LINE OPEN,LINE CLEAR AVAILED
1494	8-Aug-22	GULBARGA	110	HV2	SREERAMANAGAR_110	9:00(02.08.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1495	8-Aug-22	GULBARGA	110	HV2	YAPALDINNI_110	8:39	9:38	0:59	LINE CLEAR AVAILED
1496	8-Aug-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPURA_1 10,NSL SUGARS FACTORY	4:17	4:24	0:07	LINE FAULT
1497	8-Aug-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPURA_1 10,NSL SUGARS FACTORY	5:51	6:01	0:10	LINE FAULT
1498	8-Aug-22	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	13:05	17:15	4:10	LINE CLEAR AVAILED
1499	8-Aug-22	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	0:45	0:53	0:08	LINE FAULT
1500	8-Aug-22	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	5:15	5:50	0:35	LINE FAULT
1501	8-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1502	8-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1503	8-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1504	8-Aug-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN,LINE CLEAR AVAILED
1505	8-Aug-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	5:20	5:24	0:04	LINE FAULT
1506	8-Aug-22	GULBARGA	110	SHAHAPUR-RAICHUR1&2	DEODURGA_110	11:14	14:09	2:55	LINE CLEAR AVAILED
1507	8-Aug-22	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	18:49(08/08/2022)			LINE OPEN,LINE FAULT
1508	8-Aug-22	GULBARGA	220	HUMNABAD-HALBARGA2	HALBARGA_220	20:48	20:52	0:04	LINE FAULT
1509	8-Aug-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	13:05	18:30	5:25	LINE CLEAR AVAILED
1510	8-Aug-22	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	1:51	2:01	0:10	LINE FAULT
1511	8-Aug-22	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	13:16	18:30	5:14	LINE CLEAR AVAILED
1512	8-Aug-22	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	02:06(06.08.2022)			LOAD CURTAILMENT
1513	8-Aug-22	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	3:45	3:55	0:10	HAND TRIPPED
1514	8-Aug-22	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	2:50	3:46	0:56	LINE FAULT
1515	8-Aug-22	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	14:52	15:13	0:21	LINE FAULT
1516	8-Aug-22	HASSAN	66	HV1	AREHALLI_66	20:36	20:47	0:11	TRANSFORMER FAULT
1517	8-Aug-22	HASSAN	66	HV1	BELUR_66	19:52	20:06	0:14	TRANSFORMER FAULT
1518	8-Aug-22	HASSAN	66	HV1	YESLUR_66	2:40	20:22	17:42	MAIN SUPPLY FAILURE
1519	8-Aug-22	HASSAN	66	HV2	S.BELAGOLA_66	13:55	14:05	0:10	TRANSFORMER FAULT
1520	8-Aug-22	HASSAN	66	HV2	SAKLESH PURA_66	15:10	15:21	0:11	TRANSFORMER FAULT
1521	8-Aug-22	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATANA_66	2:37	3:19	0:42	LINE FAULT
1522	8-Aug-22	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATANA_66	3:35	4:00	0:25	LINE FAULT
1523	8-Aug-22	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATANAHALLI_66	12:14	12:34	0:20	LINE FAULT
1524	8-Aug-22	HASSAN	66	YESLUR-SNVRST	YESLUR_66	2:40	20:22	17:42	MAIN SUPPLY FAILURE
1525	8-Aug-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	2:48	3:12	0:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1526	8-Aug-22	HASSAN	110	HV2	ANAVATTI_110	10:05	10:28	0:23	TRANSFORMER FAULT
1527	8-Aug-22	HASSAN	110	HV2	HALADY_110	12:03	12:11	0:08	TRANSFORMER FAULT
1528	8-Aug-22	HASSAN	110	HV2	KARAYA_110	11:36	18:27	6:51	LINE CLEAR AVAIED
1529	8-Aug-22	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	13:34(15.07.2022)			LINE OPEN,LINE FAULT
1530	8-Aug-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	11:22	12:50	1:28	LINE CLEAR AVAIED
1531	8-Aug-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:23	12:51	1:28	LINE CLEAR AVAIED
1532	8-Aug-22	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:10	6:22	6:12	LINE CLEAR AVAIED
1533	8-Aug-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN,LINE CLEAR AVAIED
1534	8-Aug-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN,LINE CLEAR AVAIED
1535	8-Aug-22	MYSURU	66	HV1	GUNDLUPETE_66	17:02:00 (12.07.2022)			TRANSFORMER OPEN,LINE CLEAR AVAIED
1536	8-Aug-22	MYSURU	66	HV1	KOLKARANADODDI_66	8:45	15:45	7:00	LINE CLEAR AVAIED
1537	8-Aug-22	MYSURU	66	HV1	PGPALYA_66	15:35	16:30	0:54	LINE CLEAR AVAIED
1538	8-Aug-22	MYSURU	66	HV1	THALAKADU_66	14:49	14:54	0:04	HAND TRIPPED
1539	8-Aug-22	MYSURU	66	HV1	THALAKADU_66	16:42	16:47	0:04	HAND TRIPPED
1540	8-Aug-22	MYSURU	66	HV2	KMDODDI_66	9:21	19:39	10:18	LINE CLEAR AVAIED
1541	8-Aug-22	MYSURU	66	HV2	KOLKARANADODDI_66	8:45	15:45	7:00	LINE CLEAR AVAIED
1542	8-Aug-22	MYSURU	66	HV2	MEGALAPURA_66	14:05	17:07	3:02	LINE CLEAR AVAIED
1543	8-Aug-22	MYSURU	66	HV2	NAGAMANGALA_66	11:34	11:41	0:06	TRANSFORMER FAULT
1544	8-Aug-22	MYSURU	66	HV2	THALAKADU_66	14:49	14:54	0:04	HAND TRIPPED
1545	8-Aug-22	MYSURU	66	HV2	THALAKADU_66	16:42	16:47	0:04	HAND TRIPPED
1546	8-Aug-22	MYSURU	66	KADAKOLA-SARAGUR 1	JAIPUR_66 HAMPAPURA(K)_66	9:40	9:45	0:05	LINE FAULT
1547	8-Aug-22	MYSURU	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	7:42	15:40	7:58	NFBC ISSUED
1548	8-Aug-22	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66	8:11	16:06	7:54	LINE CLEAR AVAIED
1549	8-Aug-22	MYSURU	66	MANDYA-KK HALLI	NO STATIONS EFFECTED	7:51	15:58	8:06	LINE CLEAR AVAIED
1550	8-Aug-22	MYSURU	66	MANDYA-M1	NO STATIONS EFFECTED	8:16	15:45	7:29	LINE CLEAR AVAIED
1551	8-Aug-22	MYSURU	66	SHANIVARASANTHE-YESSLUR	SANIVARASANTHE_66	2:50	3:35	0:44	LINE FAULT
1552	8-Aug-22	MYSURU	66	SHANIVARASANTHE-YESSLUR	SANIVARASANTHE_66	3:35	19:18	15:42	LINE FAULT
1553	8-Aug-22	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	13:30	14:35	1:05	LINE CLEAR AVAIED
1554	8-Aug-22	MYSURU	220	HV1	KADAKOLA_220	1:41:14 (21/07/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1555	8-Aug-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1556	8-Aug-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	8:01	17:27	9:26	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1557	8-Aug-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA	KOLALA_66, URDIGERE_66	6:11	16:40	10:29	LINE FAULT
1558	8-Aug-22	TUMKUR	66	BENKIKERE_66	BENKIKERE220	17:20	17:24	0:04	LINE FAULT
1559	8-Aug-22	TUMKUR	66	BENKIKERE_66	BENKIKERE220	17:25	17:30	0:05	LINE FAULT
1560	8-Aug-22	TUMKUR	66	DAVANGERE SRS- CTA -1	DAVANGERE_SRS_220	12:25	12:35	0:10	LINE FAULT
1561	8-Aug-22	TUMKUR	66	DAVANGERE SRS- CTA -1		19:08	19:23	0:15	LINE FAULT
1562	8-Aug-22	TUMKUR	66	DAVANGERE SRS- CTA -1	DAVANGERE_SRS_220	21:43	21:53	0:10	LINE FAULT
1563	8-Aug-22	TUMKUR	66	DAVANGERE SRS- CTA -1	DAVANGERE_SRS_220	2:15	3:07	0:52	LINE FAULT
1564	8-Aug-22	TUMKUR	66	DAVANGERE SRS- CTA -1	DAVANGERE_SRS_220	3:33	3:57	0:24	LINE FAULT
1565	8-Aug-22	TUMKUR	66	DAVANGERE SRS- CTA -1	DAVANGERE_SRS_220	4:06	4:11	0:05	LINE FAULT
1566	8-Aug-22	TUMKUR	66	DAVANGERE SRS- CTA -1		14:09	14:24	0:15	LINE FAULT
1567	8-Aug-22	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	16:25	16:56	0:30	LINE CLEAR AVAILED
1568	8-Aug-22	TUMKUR	66	MALADIHALLI_66	BENKIKERE220	17:20	17:24	0:04	LINE FAULT
1569	8-Aug-22	TUMKUR	66	TR-1	HANAGAL_66	11:35	12:25	0:50	LINE CLEAR AVAILED
1570	8-Aug-22	TUMKUR	66	TR-2	CHANNAGIRI_66	11:47	11:50	0:03	TRANSFORMER FAULT
1571	8-Aug-22	TUMKUR	66	TR-2	HANAGAL_66	13:20	13:30	0:10	LINE CLEAR AVAILED
1572	8-Aug-22	TUMKUR	66	TR-2	HOLALKERE_66	13:17	13:27	0:10	TRANSFORMER FAULT
1573	8-Aug-22	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	6:15	6:35	0:19	LINE FAULT
1574	8-Aug-22	TUMKUR	110	TR-1	KGTEMPLE_110	12:39	12:59	0:19	LINE CLEAR AVAILED
1575	8-Aug-22	TUMKUR	110	TR-2	KGTEMPLE_110	12:30	13:00	0:30	LINE CLEAR AVAILED
1576	8-Aug-22	TUMKUR	220	ANCHEPALYA 220kv- NElMANGALA-1	ANCHEPALYA_220	12:16	15:45	3:29	NFBC ISSUED
1577	8-Aug-22	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:00	16:55	4:55	NFBC ISSUED
1578	8-Aug-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	7:12	15:42	8:30	LINE FAULT
1579	8-Aug-22	TUMKUR	220	DAVANGERE SRS- HONNALI	DAVANGERE_SRS_220	15:38	15:53	0:15	LINE FAULT
1580	8-Aug-22	TUMKUR	220	TR1	HONNALI_220	15:38	15:53	0:15	HAND TRIPPED
1581	8-Aug-22	TUMKUR	220	TR2	HONNALI_220	15:38	15:53	0:15	HAND TRIPPED