

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 14.05.2019 to 20.05.2019**

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                           | Station_Name                            | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|--------------------------------|---|---------|-----------|----------|---------------------|
| 1      | 14-May-19 | BAGALKOT  | 110     | 110/11KV, HV2                  | BANAHATTI_110                           | 10:15   | 13:39     | 3:24     | LINE CLEAR AVAILED  |
| 2      | 14-May-19 | BAGALKOT  | 220     | ATRIA1-BAGEWADI                | BAGEWADI_220                            | 14:10   | 15:08     | 0:58     | LINE FAULT          |
| 3      | 14-May-19 | BAGALKOT  | 220     | FORTUNEFIVE1&2-BAGEWADI        | BAGEWADI_220                            | 14:10   | 15:09     | 0:59     | LINE CLEAR AVAILED  |
| 4      | 14-May-19 | BAGALKOT  | 220     | RBRK-BAGEWADI                  | BAGEWADI_220                            | 14:10   | 15:24     | 1:14     | LINE CLEAR AVAILED  |
| 5      | 14-May-19 | BAGALKOT  | 220     | ALAMATTI2-BAGEWADI             | BAGEWADI_220                            | 15:53   | 16:11     | 0:18     | HAND TRIPPED        |
| 6      | 14-May-19 | BAGALKOT  | 110     | BAGEWADI-MAMDAPUR1&2           | MAMDAPUR_110                            | 14:10   | 15:07     | 0:57     | LINE CLEAR AVAILED  |
| 7      | 14-May-19 | BAGALKOT  | 110     | BAGEWADI-MUDDEBIHAL            | MUDDEBIHAL_110                          | 14:10   | 15:07     | 0:57     | LINE CLEAR AVAILED  |
| 8      | 14-May-19 | BAGALKOT  | 110     | BAGEWADI-NIDAGUNDI             | NIDAGUNDI_110                           | 14:10   | 15:06     | 0:56     | LINE CLEAR AVAILED  |
| 9      | 14-May-19 | BAGALKOT  | 110     | CHIKKODI220-SADALAGA           | SADALAGA_110                            | 18:15   | 18:22     | 0:07     | LINE CLEAR AVAILED  |
| 10     | 14-May-19 | BAGALKOT  | 110     | AMBEWADI-KIRUVATTI             | KIRUVATTI_110                           | 23:03   | 23:59     | 0:56     | LINE CLEAR AVAILED  |
| 11     | 14-May-19 | BAGALKOT  | 110     | GAMESHA-KULIGOD                | KULIGOD_110                             | 9:11    | 13:21     | 4:10     | LINE CLEAR AVAILED  |
| 12     | 14-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                   | MKHUBLI_220                             | 15:54   | 16:39     | 0:45     | LINE CLEAR AVAILED  |
| 13     | 14-May-19 | BAGALKOT  | 110     | TARIHAL -TADASINAKOPPA(IDLE)   | TARIHAL_110                             | 10:43   | 13:35     | 2:52     | LINE CLEAR AVAILED  |
| 14     | 14-May-19 | BAGALKOT  | 110     | SIRSI 220-KAVALWADA (IDLE2)    | KAVALWADA_110(NO STATION INTERRUPTED)   | 22:25   | 23:59     | 1:34     | LINE CLEAR AVAILED  |
| 15     | 14-May-19 | BAGALKOT  | 220     | SHARAVATHY 2-SIRSI             | SIRSI_220                               | 2:54    | 3:23      | 0:29     | LINE FAULT          |
| 16     | 14-May-19 | BAGALKOT  | 220     | SIRSI 220-HUBLI 2              | SIRSI_220                               | 8:52    | 12:02     | 3:10     | LINE CLEAR AVAILED  |
| 17     | 14-May-19 | BAGALKOT  | 110     | SIRSI-KUMATA 2                 | SIRSI_110                               | 12:30   | 12:32     | 0:02     | HAND TRIPPED        |
| 18     | 14-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                   | MUNDUGANUR_110                          | 9:59    | 12:50     | 2:51     | LINE CLEAR AVAILED  |
| 19     | 14-May-19 | BAGALKOT  | 110     | 110/11KV,HV2                   | MUKARTIHAL_110                          | 15:11   | 16:18     | 1:07     | LINE CLEAR AVAILED  |
| 20     | 14-May-19 | BAGALKOT  | 110     | MUDDEBIHAL-BALAJI SUGARS       | MUDDEBIHAL_110,BALAJI SUGAR_IPP         | 14:09   | 15:11     | 1:02     | MAIN SUPPLY FAILURE |
| 21     | 14-May-19 | BENGALURU | 66      | CHINTAMANI 220 - TALAGAWARA    | TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA | 13:28   | 14:21     | 0:53     | LINE CLEAR AVAILED  |
| 22     | 14-May-19 | BENGALURU | 66      | HV3                            | DEVANAHALLI                             | 6:05    | 6:10      | 0:05     | TRANSFORMER FAULT   |
| 23     | 14-May-19 | BENGALURU | 220     | HV1                            | DABUSPET 220                            | 16:38   | 17:00     | 0:22     | LINE CLEAR AVAILED  |
| 24     | 14-May-19 | BENGALURU | 66      | DABUSPET 220 - HIREHALLI       | HIREHALLI, HONNUDIKE                    | 16:38   | 17:00     | 0:22     | MAIN SUPPLY FAILURE |
| 25     | 14-May-19 | BENGALURU | 66      | DABUSPET 220 - JINDAL (EHT)    | JINDAL (EHT)                            | 16:38   | 17:00     | 0:22     | MAIN SUPPLY FAILURE |
| 26     | 14-May-19 | BENGALURU | 66      | HV1                            | DABUSPET 220                            | 16:38   | 17:00     | 0:22     | MAIN SUPPLY FAILURE |
| 27     | 14-May-19 | BENGALURU | 66      | HV2                            | DABUSPET 220                            | 16:38   | 17:00     | 0:22     | MAIN SUPPLY FAILURE |
| 28     | 14-May-19 | BENGALURU | 66      | HV2                            | MAASTHI                                 | 11:17   | 11:23     | 0:05     | TRANSFORMER FAULT   |
| 29     | 14-May-19 | BENGALURU | 66      | HV2                            | VIJAYANAGARA                            | 18:42   | 18:50     | 0:08     | LOAD CHANGEOVER     |
| 30     | 14-May-19 | BENGALURU | 66      | REMCO - VRISHBHAVATHI 220      | REMCO                                   | 18:38   | 18:52     | 0:13     | LINE FAULT          |
| 31     | 14-May-19 | BENGALURU | 66      | REMCO - NRS                    | VIJAYANAGARA                            | 19:16   | 19:47     | 0:30     | LINE FAULT          |
| 32     | 14-May-19 | BENGALURU | 66      | PLATINUM CITY - SRS PEENYA 220 | PLATINUM CITY                           | 9:15    | 9:27      | 0:12     | LOAD CHANGEOVER     |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                        | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|-----------------------------|--|---------|-----------|----------|---------------------|
| 33     | 14-May-19 | BENGALURU | 66      | KHODAYS 220 - ANJANAPURA    | ANJANAPURA   | 10:43   | 10:46     | 0:03     | LOAD CHANGEOVER     |
| 34     | 14-May-19 | BENGALURU | 66      | KHODAYS 220 - BTM 4TH PHASE | BTM 4TH PHASE  | 10:42   | 10:47     | 0:04     | LOAD CHANGEOVER     |
| 35     | 14-May-19 | BENGALURU | 66      | KHODAYS 220 - SOUTH CITY    | SOUTH CITY   | 10:42   | 10:46     | 0:03     | LOAD CHANGEOVER     |
| 36     | 14-May-19 | BENGALURU | 66      | KANAKAPURA 220 - TK HALLI 1 | HUKUNDA, KODIHALLI,<br>HUNSENAHALLI, HAROBELE  | 11:43   | 11:57     | 0:13     | LINE FAULT          |
| 37     | 14-May-19 | BENGALURU | 66      | KANAKAPURA 220 - TK HALLI 1 | HUKUNDA, KODIHALLI,<br>HUNSENAHALLI, HAROBELE  | 12:12   | 15:54     | 3:41     | LINE FAULT          |
| 38     | 14-May-19 | BENGALURU | 66      | KANAKAPURA 220 - TK HALLI 1 | HUKUNDA, KODIHALLI,<br>HUNSENAHALLI, HAROBELE  | 12:12   | 15:54     | 3:41     | LINE FAULT          |
| 39     | 14-May-19 | BENGALURU | 66      | BTM 4TH PHASE - SOUTH CITY  | BTM 4TH PHASE  | 12:07   | 12:12     | 0:05     | LOAD CHANGEOVER     |
| 40     | 14-May-19 | BENGALURU | 66      | HV1                         | TK HALLI 220   | 1:48    | 2:06      | 0:18     | TRANSFORMER FAULT   |
| 41     | 14-May-19 | BENGALURU | 66      | HV2                         | TK HALLI 220   | 2:10    | 2:15      | 0:05     | TRANSFORMER FAULT   |
| 42     | 14-May-19 | BENGALURU | 66      | HV2                         | MELEHALLI  | 18:51   | 20:52     | 2:01     | LINE CLEAR AVAILED  |
| 43     | 14-May-19 | BENGALURU | 66      | HV1                         | KHODAYS 220  | 10:44   | 10:46     | 0:02     | LOAD CHANGEOVER     |
| 44     | 14-May-19 | BENGALURU | 66      | HV2                         | KHODAYS 220  | 10:44   | 10:46     | 0:02     | LOAD CHANGEOVER     |
| 45     | 14-May-19 | BENGALURU | 66      | HV2                         | BANASWADI  | 5:39    | 7:36      | 1:56     | LINE CLEAR AVAILED  |
| 46     | 14-May-19 | BENGALURU | 66      | HV3                         | BANASWADI  | 11:24   | 11:29     | 0:04     | LINE CLEAR AVAILED  |
| 47     | 14-May-19 | BENGALURU | 66      | HV1                         | ANJANAPURA   | 16:20   | 16:24     | 0:04     | TRANSFORMER FAULT   |
| 48     | 14-May-19 | GULBARGA  | 220     | SHAHPUR-LINGASUGUR          | LINGASUGUR_220   | 15:25   | 15:27     | 0:02     | LINE FAULT          |
| 49     | 14-May-19 | GULBARGA  | 220     | KUSTAGI-LINGASUGUR          | KUSTAGI_220  | 14:09   | 16:11     | 2:02     | LINE FAULT          |
| 50     | 14-May-19 | GULBARGA  | 220     | KUSTAGI-LINGASUGUR          | KUSTAGI_220  | 16:19   | 18:04     | 1:45     | LINE FAULT          |
| 51     | 14-May-19 | GULBARGA  | 110     | HV1                         | HATTI_110  | 0:10    | 0:31      | 0:21     | TRANSFORMER FAULT   |
| 52     | 14-May-19 | GULBARGA  | 110     | KAPNOOR-HUMNABAD1           | MAHAGOAN_110,MARAGUTTI_110   | 14:02   | 14:19     | 0:17     | LINE FAULT          |
| 53     | 14-May-19 | GULBARGA  | 110     | YELBURGA-KUSHTAGI           | YELBURGA_110   | 16:27   | 17:01     | 0:34     | MAIN SUPPLY FAILURE |
| 54     | 14-May-19 | GULBARGA  | 110     | HV3                         | HATTI_110  | 20:44   | 21:26     | 0:42     | LINE CLEAR AVAILED  |
| 55     | 14-May-19 | GULBARGA  | 110     | KOLHAR-SHAHI_SLR IPP        | KOLHAR_110   | 16:50   | 19:00     | 2:10     | LINE FAULT          |
| 56     | 14-May-19 | GULBARGA  | 110     | LV2                         | SHAHPUR_220  | 11:06   | 19:26     | 8:20     | LINE CLEAR AVAILED  |
| 57     | 14-May-19 | GULBARGA  | 110     | HV2                         | SHAHPUR_220  | 9:19    | 21:35     | 12:16    | LINE CLEAR AVAILED  |
| 58     | 14-May-19 | GULBARGA  | 110     | SHAHPUR-KHANAPUR            | KHANAPUR_GLB_110,<br>SAIDAPUR_GLB_110,<br>WADAGERA_110,SANNATI_IPP,<br>COREGREEN_IPP, NALWAR_110 | 16:57   | 19:29     | 2:32     | LINE CLEAR AVAILED  |
| 59     | 14-May-19 | GULBARGA  | 66      | LV1                         | ITTAGI_66  | 6:25    | 6:45      | 0:20     | TRANSFORMER FAULT   |
| 60     | 14-May-19 | GULBARGA  | 66      | ITTAGI-RNWSLR               | RNWSLR_IPP   | 6:25    | 6:50      | 0:25     | LINE FAULT          |
| 61     | 14-May-19 | HASSAN    | 400     | HASSAN440-UPCL2             | HASSAN_400   | 8:28    | 23:59     | 15:31    | LINE CLEAR AVAILED  |
| 62     | 14-May-19 | HASSAN    | 400     | UPCL-HASSAN2                | upcl_gen   | 8:28    | 23:59     | 15:31    | LINE CLEAR AVAILED  |
| 63     | 14-May-19 | HASSAN    | 110     | HV1                         | BANTWAL_110  | 10:46   | 12:14     | 1:28     | LINE CLEAR AVAILED  |

| Sl.No. | DATE      | Tr_ZONE | Voltage | Line                                    | Station_Name                               | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|---------|---------|---|--|---------|-----------|----------|--------------------|
| 64     | 14-May-19 | HASSAN  | 110     | GURUPUR-KAVOOR                          | GURUPUR                                    | 10:10   | 15:20     | 5:10     | NFBC ISSUED        |
| 65     | 14-May-19 | HASSAN  | 110     | HV1                                     | GURUVAYANAKERE_110                         | 6:26    | 6:34      | 0:08     | TRANSFORMER FAULT  |
| 66     | 14-May-19 | HASSAN  | 110     | HV2                                     | HALADY_110                                 | 10:03   | 10:37     | 0:34     | LINE CLEAR AVAILED |
| 67     | 14-May-19 | HASSAN  | 110     | HV1                                     | KADUR_220                                  | 11:50   | 12:55     | 1:05     | LINE CLEAR AVAILED |
| 68     | 14-May-19 | HASSAN  | 110     | KAVOOR-Kulashkhara1                     | KAVOOR_220                                 | 10:11   | 15:20     | 5:09     | LINE CLEAR AVAILED |
| 69     | 14-May-19 | HASSAN  | 110     | KEMAR-Manipal2                          | KEMAR_220                                  | 10:38   | 11:49     | 1:11     | LINE CLEAR AVAILED |
| 70     | 14-May-19 | HASSAN  | 110     | MANIPAL-BRAMVR                          | MANIPAL_110                                | 9:59    | 14:24     | 4:25     | LINE CLEAR AVAILED |
| 71     | 14-May-19 | HASSAN  | 66      | HV1                                     | KANDLI_66                                  | 10:44   | 12:20     | 1:36     | LINE CLEAR AVAILED |
| 72     | 14-May-19 | HASSAN  | 66      | HV1                                     | MOSALEHOSAHALLI_66                         | 4:10    | 6:20      | 2:10     | TRANSFORMER FAULT  |
| 73     | 14-May-19 | HASSAN  | 66      | SAKALE-IPCL1                            | SAKLESH PURA_66                            | 9:02    | 19:21     | 10:19    | LINE CLEAR AVAILED |
| 74     | 14-May-19 | HASSAN  | 66      | SAKALE-IPCL2                            | SAKLESH PURA_66                            | 9:02    | 19:21     | 10:19    | LINE CLEAR AVAILED |
| 75     | 14-May-19 | HASSAN  | 66      | HV1                                     | SINGAPURA_66                               | 8:29    | 18:40     | 10:11    | LINE CLEAR AVAILED |
| 76     | 14-May-19 | HASSAN  | 66      | HV2                                     | SINGAPURA_66                               | 14:40   | 18:38     | 3:58     | LINE CLEAR AVAILED |
| 77     | 14-May-19 | MYSORE  | 66      | HV2                                     | ADDIHALI_66                                | 9:58    | 12:20     | 2:22     | LINE CLEAR AVAILED |
| 78     | 14-May-19 | MYSORE  | 66      | BILIKERE-GV GUDI                        | GVGUDI_66                                  | 11:14   | 23:59     | 12:44    | LINE CLEAR AVAILED |
| 79     | 14-May-19 | MYSORE  | 66      | HV1                                     | HAMPAPURA(K)_66                            | 11:30   | 13:18     | 1:48     | LINE CLEAR AVAILED |
| 80     | 14-May-19 | MYSORE  | 66      | HOOTAGALLI-DATAGALLI                    | DATTAGALLY_66 RKNAGARA_66                  | 18:32   | 18:35     | 0:03     | HAND TRIPPED       |
| 81     | 14-May-19 | MYSORE  | 66      | HV1                                     | HOOTAGALLY_220                             | 11:06   | 11:09     | 0:03     | TRANSFORMER FAULT  |
| 82     | 14-May-19 | MYSORE  | 66      | HV2                                     | HOOTAGALLY_220                             | 11:11   | 12:46     | 1:35     | LINE CLEAR AVAILED |
| 83     | 14-May-19 | MYSORE  | 66      | HV1                                     | MADDUR_66                                  | 14:53   | 16:17     | 1:23     | LINE CLEAR AVAILED |
| 84     | 14-May-19 | MYSORE  | 66      | HV2                                     | MADDUR_66                                  | 12:36   | 14:22     | 1:46     | LINE CLEAR AVAILED |
| 85     | 14-May-19 | MYSORE  | 66      | MEGHALAPURA-SFC                         | THUMLA_66 CHIDRAVALLI                      | 10:40   | 18:20     | 7:40     | LINE CLEAR AVAILED |
| 86     | 14-May-19 | MYSORE  | 66      | HV1                                     | MEGALAPURA_66                              | 10:00   | 18:00     | 8:00     | LINE CLEAR AVAILED |
| 87     | 14-May-19 | MYSORE  | 66      | HV2                                     | MEGALAPURA_66                              | 10:00   | 19:25     | 9:25     | LINE CLEAR AVAILED |
| 88     | 14-May-19 | MYSORE  | 66      | HV1                                     | MEGALAPURA_66                              | 19:12   | 19:30     | 0:17     | LINE CLEAR AVAILED |
| 89     | 14-May-19 | MYSORE  | 66      | HV1                                     | SALIGRAMA_66                               | 11:50   | 12:20     | 0:30     | LINE CLEAR AVAILED |
| 90     | 14-May-19 | MYSORE  | 66      | HV1                                     | SALIGRAMA_66                               | 12:50   | 13:00     | 0:10     | TRANSFORMER FAULT  |
| 91     | 14-May-19 | MYSORE  | 66      | HV2                                     | SALIGRAMA_66                               | 12:29   | 13:03     | 0:34     | LINE CLEAR AVAILED |
| 92     | 14-May-19 | MYSORE  | 66      | HV1                                     | SANTHESARAGUR_66                           | 6:40    | 11:23     | 4:42     | TRANSFORMER FAULT  |
| 93     | 14-May-19 | MYSORE  | 66      | VAJAMANGALA-KADAKOLA 1                  | AYRALLI_66 MARADIHUNDI_66                  | 16:22   | 16:26     | 0:03     | HAND TRIPPED       |
| 94     | 14-May-19 | MYSORE  | 66      | VAJAMANGALA-MEGHALAPURA                 | MEGALAPURA_66                              | 14:15   | 17:49     | 3:34     | NFBC ISSUED        |
| 95     | 14-May-19 | TUMKUR  | 220     | THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66 | SEL DIAMOND SOLAR_IPP_66                   | 17:25   | 18:46     | 1:21     | LINE CLEAR AVAILED |
| 96     | 14-May-19 | TUMKUR  | 110     | TR-1                                    | KADABA_110                                 | 11:01   | 13:35     | 2:34     | TRANSFORMER FAULT  |
| 97     | 14-May-19 | TUMKUR  | 110     | KB CROSS 220kV- MAYASANDRA              | MAYASANDRA_110, TANDAGA_110, KADEHALLI_110 | 17:23   | 18:09     | 0:46     | LINE FAULT         |
| 98     | 14-May-19 | TUMKUR  | 66      | ANCHEPALYA 220kV- KUNIGAL               | KUNIGAL_66                                 | 12:07   | 14:51     | 2:43     | LINE CLEAR AVAILED |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                 | Station_Name                                 | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|--------------------------------------|--|---------|-----------|----------|---------------------|
| 99     | 14-May-19 | TUMKUR    | 66      | TR-1                                 | BAGUR_TMK_66                                 | 8:01    | 9:33      | 1:31     | LINE CLEAR AVAILED  |
| 100    | 14-May-19 | TUMKUR    | 66      | TR-1                                 | BAGUR_TMK_66                                 | 18:35   | 18:57     | 0:22     | LINE CLEAR AVAILED  |
| 101    | 14-May-19 | TUMKUR    | 66      | TR-1                                 | BELADARA_66                                  | 11:56   | 12:20     | 0:23     | LINE CLEAR AVAILED  |
| 102    | 14-May-19 | TUMKUR    | 66      | BHAKTHARA HALLI -ANCHEPALYA          | BHAKTHARAHALLI_66                            | 11:57   | 16:35     | 4:38     | LINE FAULT          |
| 103    | 14-May-19 | TUMKUR    | 66      | DODDASARANGI-ANCHEPALYA              | DODDASARANGI_66                              | 10:46   | 13:05     | 2:19     | LINE CLEAR AVAILED  |
| 104    | 14-May-19 | TUMKUR    | 66      | DODDASARANGI- ANTHRASANAHALLI        | DODDASARANGI_66                              | 13:05   | 13:08     | 0:02     | LINE CLEAR AVAILED  |
| 105    | 14-May-19 | TUMKUR    | 66      | TR-1 & TR-2                          | HIREGUNTANUR_66                              | 15:03   | 16:07     | 1:03     | LINE CLEAR AVAILED  |
| 106    | 14-May-19 | TUMKUR    | 66      | TR-1 & TR-2                          | HIREGUNTANUR_66                              | 17:58   | 18:09     | 0:11     | LINE CLEAR AVAILED  |
| 107    | 14-May-19 | TUMKUR    | 66      | HONNALLI 220KV- BANUVALLI            | BANUVALLI_66, NANDIGUDI_66,<br>KARGIL_EHT_66 | 4:47    | 4:59      | 0:11     | LINE FAULT          |
| 108    | 14-May-19 | TUMKUR    | 66      | TR-1                                 | HULIYURDURGA_66                              | 13:05   | 13:19     | 0:13     | TRANSFORMER FAULT   |
| 109    | 14-May-19 | TUMKUR    | 66      | TR-1                                 | HULIYURDURGA_66                              | 14:06   | 14:17     | 0:11     | TRANSFORMER FAULT   |
| 110    | 14-May-19 | TUMKUR    | 66      | KALAMARANAHALLI- PR PURA             | KALAMARANAHALLI_66                           | 11:19   | 17:48     | 6:28     | LINE CLEAR AVAILED  |
| 111    | 14-May-19 | TUMKUR    | 66      | TR-2                                 | SANIKERE_66                                  | 9:30    | 9:38      | 0:08     | TRANSFORMER FAULT   |
| 112    | 15-May-19 | BAGALKOT  | 110     | ATHANI220-AIGALI                     | AIGALI_110                                   | 4:44    | 5:07      | 0:23     | LINE FAULT          |
| 113    | 15-May-19 | BAGALKOT  | 220     | HUBL220I-SIRSI 2                     | HUBLI_220                                    | 8:01    | 15:40     | 7:39     | NFBC ISSUED         |
| 114    | 15-May-19 | BAGALKOT  | 110     | MKHUBLI220-BAILHONGAL                | BAILHONGAL_110                               | 13:40   | 14:23     | 0:43     | LINE CLEAR AVAILED  |
| 115    | 15-May-19 | BAGALKOT  | 110     | 110/11KV,HV2                         | BEDI_110                                     | 12:22   | 23:59     | 11:37    | TRANSFORMER FAULT   |
| 116    | 15-May-19 | BAGALKOT  | 220     | BELGAUM-CHIKKODI1                    | BELGAUM_220                                  | 9:30    | 11:34     | 2:04     | LINE CLEAR AVAILED  |
| 117    | 15-May-19 | BAGALKOT  | 220     | BELGAUM-CHIKKODI2                    | BELGAUM_220                                  | 11:30   | 13:51     | 2:21     | LINE CLEAR AVAILED  |
| 118    | 15-May-19 | BAGALKOT  | 220     | BELGAUM-NARENDRA1                    | BELGAUM_220                                  | 11:34   | 13:58     | 2:24     | LINE CLEAR AVAILED  |
| 119    | 15-May-19 | BAGALKOT  | 220     | DHONI-LINGAPUR 1                     | DHONI_400                                    | 0:00    | 12:23     | 12:23    | LINE CLEAR AVAILED  |
| 120    | 15-May-19 | BAGALKOT  | 110     | MKHUBLI110-KITTUR                    | KITTUR_110                                   | 8:59    | 17:06     | 8:07     | LINE CLEAR AVAILED  |
| 121    | 15-May-19 | BAGALKOT  | 110     | 110/33KV,HV1                         | KUMATA_110, HONNAVAR_33,<br>ANKOLA_33        | 12:05   | 12:22     | 0:17     | HAND TRIPPED        |
| 122    | 15-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                         | MUNDAGANUR_110                               | 12:07   | 12:22     | 0:15     | LINE CLEAR AVAILED  |
| 123    | 15-May-19 | BAGALKOT  | 220     | NARENDRA-BELGAUM 1<br>(KANABARAGI 1) | NARENDRA_220                                 | 12:08   | 13:58     | 1:50     | NFBC ISSUED         |
| 124    | 15-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                         | NIDAGUNDI_110                                | 13:45   | 16:10     | 2:25     | LINE CLEAR AVAILED  |
| 125    | 15-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                         | NIDAGUNDI_110                                | 18:07   | 18:10     | 0:03     | LINE CLEAR AVAILED  |
| 126    | 15-May-19 | BENGALURU | 66      | HV2                                  | BAGEPALLI                                    | 10:04   | 10:06     | 0:01     | LINE CLEAR AVAILED  |
| 127    | 15-May-19 | BENGALURU | 66      | HV2                                  | BAGEPALLI                                    | 12:00   | 12:10     | 0:10     | LINE CLEAR AVAILED  |
| 128    | 15-May-19 | BENGALURU | 220     | BEGUR 220 - DB PURA 220              | BEGUR 220                                    | 17:52   | 18:02     | 0:10     | LINE FAULT          |
| 129    | 15-May-19 | BENGALURU | 220     | BEGUR 220 - HOSKOTE 220              | HOSKOTE 220                                  | 17:52   | 18:03     | 0:11     | MAIN SUPPLY FAILURE |
| 130    | 15-May-19 | BENGALURU | 66      | BEGUR 220 - ITC (EHT)                | ITC (EHT)                                    | 17:52   | 18:04     | 0:12     | MAIN SUPPLY FAILURE |
| 131    | 15-May-19 | BENGALURU | 66      | BEGUR 220 - BIAL 1 (EHT)             | BIAL (EHT)                                   | 17:52   | 18:02     | 0:10     | MAIN SUPPLY FAILURE |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                             | Station_Name  | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|----------------------------------|---|---------|-----------|----------|---------------------|
| 132    | 15-May-19 | BENGALURU | 66      | BEGUR 220 - BIAL 2 (EHT)         | BIAL (EHT)  | 17:52   | 18:02     | 0:10     | MAIN SUPPLY FAILURE |
| 133    | 15-May-19 | BENGALURU | 66      | BEGUR 220 - BOODIGERE            | BOODIGERE   | 17:52   | 18:04     | 0:12     | MAIN SUPPLY FAILURE |
| 134    | 15-May-19 | BENGALURU | 66      | HV1                              | BEGUR 220   | 17:52   | 18:02     | 0:10     | MAIN SUPPLY FAILURE |
| 135    | 15-May-19 | BENGALURU | 66      | HV2                              | BEGUR 220   | 17:52   | 18:02     | 0:10     | MAIN SUPPLY FAILURE |
| 136    | 15-May-19 | BENGALURU | 220     | CHINTAMANI 220 - PGCIL 1         | CHINTAMANI 220  | 15:48   | 16:10     | 0:22     | LOAD CHANGEOVER     |
| 137    | 15-May-19 | BENGALURU | 220     | CHINTAMANI 220 - PGCIL 2         | CHINTAMANI 220  | 9:38    | 10:39     | 1:01     | LINE CLEAR AVAILED  |
| 138    | 15-May-19 | BENGALURU | 220     | CHINTAMANI 220 - PGCIL 2         | CHINTAMANI 220  | 15:48   | 16:10     | 0:22     | LOAD CHANGEOVER     |
| 139    | 15-May-19 | BENGALURU | 220     | HV3                              | CHINTAMANI 220  | 9:38    | 10:39     | 1:01     | LINE CLEAR AVAILED  |
| 140    | 15-May-19 | BENGALURU | 220     | HV3                              | CHINTAMANI 220  | 15:48   | 16:10     | 0:22     | LOAD CHANGEOVER     |
| 141    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220- GANJIGUNTE 1 & 2 | GANJIGUNTE , PALLICHERLU,<br>DIBBURAHALLI, SADALI,<br>JULUPALYA,SOMENAHALLI | 9:38    | 10:40     | 1:02     | MAIN SUPPLY FAILURE |
| 142    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220- LAKSHMIPURA      | LAKSHMIPURA , ADDAGAL,<br>SOMAYAJANAHALLI                                   | 9:38    | 10:40     | 1:02     | MAIN SUPPLY FAILURE |
| 143    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 -NANDIGANAHALLI   | NANDIGANAHALLI  | 9:38    | 10:40     | 1:02     | MAIN SUPPLY FAILURE |
| 144    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220- GANJIGUNTE 1 & 2 | GANJIGUNTE , PALLICHERLU,<br>DIBBURAHALLI, SADALI,<br>JULUPALYA,SOMENAHALLI | 15:47   | 16:10     | 0:22     | MAIN SUPPLY FAILURE |
| 145    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220- LAKSHMIPURA      | LAKSHMIPURA , ADDAGAL,<br>SOMAYAJANAHALLI                                   | 15:47   | 16:10     | 0:22     | MAIN SUPPLY FAILURE |
| 146    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 -NANDIGANAHALLI   | NANDIGANAHALLI  | 15:47   | 16:10     | 0:22     | MAIN SUPPLY FAILURE |
| 147    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 - CHINTAMANI 66   | CHINTAMANI 66, SM MANGALA   | 15:47   | 16:10     | 0:22     | MAIN SUPPLY FAILURE |
| 148    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 - IRAGAMPALLI     | IRAGAMPALLI, M GOLLAHALLI   | 15:47   | 16:10     | 0:22     | MAIN SUPPLY FAILURE |
| 149    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 - SRINIVASAPURA   | SRINIVASAPURA, KODIHALLI  | 15:47   | 16:10     | 0:22     | MAIN SUPPLY FAILURE |
| 150    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 - TALAGAWARA      | TALAGAWARA, Y HUNSENAHALLI,<br>CHEEMANGALA                                  | 15:47   | 16:10     | 0:22     | MAIN SUPPLY FAILURE |
| 151    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 - YENIGADALE      | YENIGADALE, CHELUR, CHAKAVELU   | 15:47   | 16:10     | 0:22     | MAIN SUPPLY FAILURE |
| 152    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 - SIDLAGHATTA     | SIDLAGHATTA, MELUR  | 15:47   | 16:10     | 0:22     | MAIN SUPPLY FAILURE |
| 153    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 - SIDLAGHATTA     | SIDLAGHATTA, MELUR  | 17:18   | 17:23     | 0:04     | LINE FAULT          |
| 154    | 15-May-19 | BENGALURU | 66      | CHINTAMANI 220 - TALAGAWARA      | TALAGAWARA, Y HUNSENAHALLI,<br>CHEEMANGALA                                  | 5:58    | 6:08      | 0:09     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                 | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|--------------------------------------|--|---------|-----------|----------|---------------------|
| 155    | 15-May-19 | BENGALURU | 66      | DB PURA 220 - CHIKKABALLAPURA I/ A 2 | CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI | 16:09   | 16:49     | 0:39     | LINE CLEAR AVAILED  |
| 156    | 15-May-19 | BENGALURU | 66      | DB PURA 220 - TUBUGERE               | TUBUGERE   | 16:09   | 16:49     | 0:39     | LINE CLEAR AVAILED  |
| 157    | 15-May-19 | BENGALURU | 66      | DB PURA 220 - DEVANAHALLI 1          | KUNDANA  | 12:06   | 12:18     | 0:11     | LINE FAULT          |
| 158    | 15-May-19 | BENGALURU | 66      | DB PURA 220 - DG 1                   | AIR (EHT)  | 11:41   | 11:55     | 0:13     | LOAD CHANGEOVER     |
| 159    | 15-May-19 | BENGALURU | 66      | DB PURA 220 - VIJAYAPURA             | VIJAYAPURA, JANGAMAKOTE  | 16:09   | 16:50     | 0:40     | LINE CLEAR AVAILED  |
| 160    | 15-May-19 | BENGALURU | 66      | DB PURA 220 - VIJAYAPURA             | VIJAYAPURA, JANGAMAKOTE  | 18:09   | 18:21     | 0:11     | LINE FAULT          |
| 161    | 15-May-19 | BENGALURU | 66      | DEVANAHALLI - DB PURA 1              | DEVANAHALLI  | 12:06   | 12:17     | 0:11     | LINE FAULT          |
| 162    | 15-May-19 | BENGALURU | 66      | HV3                                  | DEVANAHALLI  | 15:30   | 15:35     | 0:05     | TRANSFORMER FAULT   |
| 163    | 15-May-19 | BENGALURU | 66      | HOSKOTE 220 - HOSKOTE 1              | GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS                     | 17:49   | 19:47     | 1:57     | LINE FAULT          |
| 164    | 15-May-19 | BENGALURU | 66      | HOSKOTE 220 - HOSKOTE 2              | HBR LAYOUT, BELL CERAMICS (EHT)                                | 14:17   | 15:06     | 0:48     | LINE FAULT          |
| 165    | 15-May-19 | BENGALURU | 66      | HOSKOTE 220 - HOSKOTE 2              | HBR LAYOUT, BELL CERAMICS (EHT)                                | 17:52   | 18:23     | 0:31     | MAIN SUPPLY FAILURE |
| 166    | 15-May-19 | BENGALURU | 66      | HV1                                  | HOSKOTE 220  | 17:52   | 18:22     | 0:30     | MAIN SUPPLY FAILURE |
| 167    | 15-May-19 | BENGALURU | 66      | HOSKOTE 220 - PILAGUMPA              | PILAGUMPA  | 17:52   | 18:24     | 0:32     | MAIN SUPPLY FAILURE |
| 168    | 15-May-19 | BENGALURU | 66      | HOSKOTE 220 - VOLVO                  | VOLVO, NANDAGUDI   | 17:52   | 18:24     | 0:32     | MAIN SUPPLY FAILURE |
| 169    | 15-May-19 | BENGALURU | 66      | HOSKOTE 220 - VOLVO                  | VOLVO, NANDAGUDI   | 18:43   | 19:16     | 0:33     | LINE FAULT          |
| 170    | 15-May-19 | BENGALURU | 66      | HOSKOTE 220 - HOSKOTE 2              | BELL CERAMICS (EHT)  | 18:26   | 19:47     | 1:20     | LINE FAULT          |
| 171    | 15-May-19 | BENGALURU | 66      | HBR LAYOUT - HOSKOTE 220             | HBR LAYOUT   | 18:26   | 19:02     | 0:35     | MAIN SUPPLY FAILURE |
| 172    | 15-May-19 | BENGALURU | 66      | HBR LAYOUT - LR BANDE                | HBR LAYOUT   | 19:55   | 20:05     | 0:10     | LOAD CHANGEOVER     |
| 173    | 15-May-19 | BENGALURU | 66      | HOSKOTE 220 - SULIBELE               | SULIBELE   | 17:52   | 18:24     | 0:32     | MAIN SUPPLY FAILURE |
| 174    | 15-May-19 | BENGALURU | 66      | KOLAR 220 - SRINIVASPURA             | DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR                      | 11:05   | 11:17     | 0:12     | LINE FAULT          |
| 175    | 15-May-19 | BENGALURU | 66      | KEMBODI - NANGLI                     | MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI                      | 13:11   | 13:18     | 0:07     | LINE FAULT          |
| 176    | 15-May-19 | BENGALURU | 66      | KEMBODI - NANGLI                     | MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI                      | 18:21   | 18:45     | 0:23     | LINE FAULT          |
| 177    | 15-May-19 | BENGALURU | 66      | MALUR 220 - MAASTHI                  | LAKKUR, DEVANAGONDHI, MAASTHI                                  | 14:55   | 15:12     | 0:16     | LINE FAULT          |
| 178    | 15-May-19 | BENGALURU | 66      | MALUR 220 - KGF 2                    | ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI                | 14:22   | 14:43     | 0:20     | LINE FAULT          |
| 179    | 15-May-19 | BENGALURU | 66      | MALUR 220 - KGF 2                    | ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI                | 15:40   | 16:12     | 0:32     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                  | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|---------------------------------------|--|---------|-----------|----------|---------------------|
| 180    | 15-May-19 | BENGALURU | 66      | MALUR 220 - KGF 1                     | KGF, TEKAL, BUDIKOTE, KAMASAMUDRA                        | 15:40   | 16:11     | 0:30     | LINE FAULT          |
| 181    | 15-May-19 | BENGALURU | 66      | CHIKKENAHALLI - CHANNAPATNA           | CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR | 8:27    | 8:33      | 0:05     | LINE FAULT          |
| 182    | 15-May-19 | BENGALURU | 66      | PLATINUM CITY - DG 4                  | PLATINUM CITY  | 6:00    | 6:10      | 0:10     | LOAD CHANGEVER      |
| 183    | 15-May-19 | BENGALURU | 66      | HV2                                   | ISRO LAYOUT  | 5:59    | 7:01      | 1:01     | TRANSFORMER FAULT   |
| 184    | 15-May-19 | BENGALURU | 66      | HV2                                   | KADUGODI   | 21:10   | 21:36     | 0:25     | TRANSFORMER FAULT   |
| 185    | 15-May-19 | BENGALURU | 66      | HV2                                   | BANASWADI  | 13:40   | 14:43     | 1:03     | LINE CLEAR AVAILED  |
| 186    | 15-May-19 | BENGALURU | 66      | HV3                                   | ELECTRONIC CIT   | 11:48   | 15:24     | 3:35     | LINE CLEAR AVAILED  |
| 187    | 15-May-19 | BENGALURU | 66      | HV1                                   | TELECOM LAYOUT   | 8:00    | 8:51      | 0:50     | TRANSFORMER FAULT   |
| 188    | 15-May-19 | BENGALURU | 66      | HV1                                   | POTTERY ROAD   | 14:36   | 14:55     | 0:18     | TRANSFORMER FAULT   |
| 189    | 15-May-19 | BENGALURU | 66      | HV2                                   | TAVAREKERE   | 16:16   | 16:22     | 0:05     | TRANSFORMER FAULT   |
| 190    | 15-May-19 | BENGALURU | 66      | HEBBAL 220 - IISC                     | IISC   | 14:06   | 14:35     | 0:28     | LINE CLEAR AVAILED  |
| 191    | 15-May-19 | BENGALURU | 66      | SOMANAHALLI 220 - KUMBALAGODU         | KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE  | 20:36   | 23:59     | 3:22     | LINE FAULT          |
| 192    | 15-May-19 | BENGALURU | 66      | HEBBAL 220 - BANASWADI                | BANASWADI  | 14:07   | 14:23     | 0:15     | LINE CLEAR AVAILED  |
| 193    | 15-May-19 | BENGALURU | 66      | HEBBAL 220 - LR BANDE                 | LR BANDE   | 14:07   | 14:23     | 0:16     | LINE CLEAR AVAILED  |
| 194    | 15-May-19 | BENGALURU | 66      | SOMANAHALLI 220 - KUMBALAGODU         | KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE  | 15:34   | 16:22     | 0:48     | LINE FAULT          |
| 195    | 15-May-19 | BENGALURU | 66      | SOMANAHALLI 220 - KUMBALAGODU         | KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE  | 19:52   | 20:36     | 0:44     | LINE FAULT          |
| 196    | 15-May-19 | BENGALURU | 66      | NRS 220 - MYSORE ROAD 1               | VIJAYANAGARA   | 14:05   | 14:09     | 0:03     | LOAD CHANGEVER      |
| 197    | 15-May-19 | BENGALURU | 66      | NRS 220 - MYSORE ROAD 1               | VIJAYANAGARA   | 14:05   | 14:09     | 0:03     | LOAD CHANGEVER      |
| 198    | 15-May-19 | BENGALURU | 66      | HV2                                   | YERANDANAHALLI 220                                       | 11:25   | 16:20     | 4:55     | MAIN SUPPLY FAILURE |
| 199    | 15-May-19 | BENGALURU | 66      | HV2                                   | YERANDANAHALLI 220                                       | 18:20   | 18:25     | 0:05     | LOAD CHANGEVER      |
| 200    | 15-May-19 | GULBARGA  | 220     | LINGAPUR-KUSHTAGI                     | LINGAPUR_220   | 9:58    | 22:59     | 13:01    | NFBC ISSUED         |
| 201    | 15-May-19 | GULBARGA  | 220     | SINDHANOOR-SUZLON1_IPP                | SIDHANOOR_220  | 19:40   | 19:53     | 0:13     | LINE FAULT          |
| 202    | 15-May-19 | GULBARGA  | 220     | KUSTAGI-SUZLONWIND_IPP,ASTRO WIND-IPP | KUSTAGI_220  | 22:12   | 22:50     | 0:38     | LOAD CHANGEVER      |
| 203    | 15-May-19 | GULBARGA  | 220     | SHAHPUR-SEDAM                         | SEDAM_220  | 20:35   | 23:59     | 3:24     | LINE CLEAR AVAILED  |
| 204    | 15-May-19 | GULBARGA  | 110     | KUSHTAGI-KANAKAGIRI                   | KANAKAGIRI_110, GANADAL_110                              | 9:04    | 15:17     | 6:13     | LINE CLEAR AVAILED  |
| 205    | 15-May-19 | GULBARGA  | 110     | HV2                                   | SHAHPUR_220  | 14:20   | 16:27     | 2:07     | TRANSFORMER FAULT   |

| Sl.No. | DATE      | Tr_ZONE  | Voltage | Line                   | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|----------|---------|------------------------|--|---------|-----------|----------|---------------------|
| 206    | 15-May-19 | GULBARGA | 110     | SHAHPUR-KHANAPUR       | KHANAPUR_GLB_110,<br>SAIDAPUR_GLB_110,<br>WADAGERA_110,SANNATI_IPP,<br>COREGREEN_IPP, NALWAR_110 | 17:40   | 18:06     | 0:26     | LINE CLEAR AVAILED  |
| 207    | 15-May-19 | GULBARGA | 110     | HV2                    | SHAHPUR_220  | 23:05   | 23:59     | 0:54     | TRANSFORMER FAULT   |
| 208    | 15-May-19 | HASSAN   | 66      | HV1                    | SINGAPURA_66   | 8:29    | 18:40     | 10:11    | LINE CLEAR AVAILED  |
| 209    | 15-May-19 | HASSAN   | 220     | HV2                    | HASSAN_220   | 10:06   | 12:41     | 2:35     | LINE CLEAR AVAILED  |
| 210    | 15-May-19 | HASSAN   | 110     | HV3                    | BAIKAMPADI_110   | 15:02   | 15:11     | 0:09     | TRANSFORMER FAULT   |
| 211    | 15-May-19 | HASSAN   | 110     | HOSNGD-VTRG1           | HOSANGADI_110  | 11:19   | 11:43     | 0:24     | MAIN SUPPLY FAILURE |
| 212    | 15-May-19 | HASSAN   | 110     | KADUR-YGTI             | KADUR_220  | 10:31   | 12:16     | 1:45     | LINE CLEAR AVAILED  |
| 213    | 15-May-19 | HASSAN   | 110     | NERALA-TEREKERE        | NERALAKERE_110   | 17:45   | 18:10     | 0:25     | LINE FAULT          |
| 214    | 15-May-19 | HASSAN   | 110     | SHIVAPUR-BIRUR         | SHIVPURA_110   | 17:44   | 18:04     | 0:20     | LINE FAULT          |
| 215    | 15-May-19 | HASSAN   | 110     | SHRLKP-SHIRALKOPPA     | SHIRALKOPPA_220  | 14:16   | 18:14     | 3:58     | LINE CLEAR AVAILED  |
| 216    | 15-May-19 | HASSAN   | 110     | HV4                    | SHIRALKOPPA_110  | 14:10   | 18:15     | 4:05     | LINE CLEAR AVAILED  |
| 217    | 15-May-19 | HASSAN   | 66      | BASAVAGT-DUDDA         | BASAVAGHATTA_66  | 10:10   | 15:45     | 5:35     | MAIN SUPPLY FAILURE |
| 218    | 15-May-19 | HASSAN   | 66      | HV1                    | BASAVAGHATTA_66  | 10:10   | 15:45     | 5:35     | MAIN SUPPLY FAILURE |
| 219    | 15-May-19 | HASSAN   | 66      | HV2                    | BASAVAGHATTA_66  | 10:10   | 15:45     | 5:35     | MAIN SUPPLY FAILURE |
| 220    | 15-May-19 | HASSAN   | 66      | DODDAHA-HOOTGALLI      | DODDAHALLY_66  | 22:36   | 22:48     | 0:12     | LINE FAULT          |
| 221    | 15-May-19 | HASSAN   | 66      | HAGARE-HASSAN          | HAGARE_66  | 10:15   | 10:27     | 0:12     | HAND TRIPPED        |
| 222    | 15-May-19 | HASSAN   | 66      | HASSN220-BELUR         | HASSAN_220   | 10:06   | 10:32     | 0:26     | LINE CLEAR AVAILED  |
| 223    | 15-May-19 | HASSAN   | 66      | HASSN220-CHIKAMAGLUR2  | HASSAN_220   | 10:06   | 10:41     | 0:35     | LINE CLEAR AVAILED  |
| 224    | 15-May-19 | HASSAN   | 66      | HASSN220-MALLALI       | HASSAN_220   | 10:06   | 10:42     | 0:36     | LINE CLEAR AVAILED  |
| 225    | 15-May-19 | HASSAN   | 66      | HASSN220-UDDURKOPLU    | HASSAN_220   | 10:06   | 10:59     | 0:53     | LINE CLEAR AVAILED  |
| 226    | 15-May-19 | HASSAN   | 66      | KANDLI-SAKLESHPUR      | KANDLI_66  | 11:05   | 16:00     | 4:55     | LINE CLEAR AVAILED  |
| 227    | 15-May-19 | HASSAN   | 66      | SAKALE-IPCL1           | SAKLESHPURA_66   | 7:37    | 19:30     | 11:53    | LINE CLEAR AVAILED  |
| 228    | 15-May-19 | HASSAN   | 66      | IPCL2                  | SAKLESHPURA_66   | 7:37    | 19:30     | 11:53    | LINE CLEAR AVAILED  |
| 229    | 15-May-19 | MYSORE   | 66      | HV1                    | BESAGARAHALLI_66   | 15:55   | 17:15     | 1:20     | LINE CLEAR AVAILED  |
| 230    | 15-May-19 | MYSORE   | 66      | HV2                    | BESAGARAHALLI_66   | 13:15   | 23:59     | 10:44    | LINE CLEAR AVAILED  |
| 231    | 15-May-19 | MYSORE   | 66      | HV1                    | COWDALLI_66  | 9:11    | 11:00     | 1:48     | LINE CLEAR AVAILED  |
| 232    | 15-May-19 | MYSORE   | 66      | CR NAGARA-GUNDLUPETE 2 | TERAKANAMBE_66   | 18:09   | 18:14     | 0:05     | LINE FAULT          |
| 233    | 15-May-19 | MYSORE   | 66      | CR NAGARA-HONNALLI     | ATTIGULIPURA_66<br>HONNALLY_MYS_66   | 10:30   | 17:31     | 7:01     | LINE CLEAR AVAILED  |
| 234    | 15-May-19 | MYSORE   | 66      | HV2                    | HAMPAPURA_66   | 17:07   | 17:39     | 0:32     | TRANSFORMER FAULT   |
| 235    | 15-May-19 | MYSORE   | 66      | HV1                    | K_HONNALGERE_66  | 7:31    | 7:40      | 0:09     | HAND TRIPPED        |
| 236    | 15-May-19 | MYSORE   | 66      | HV2                    | K_HONNALGERE_66  | 7:31    | 7:40      | 0:09     | HAND TRIPPED        |
| 237    | 15-May-19 | MYSORE   | 66      | HV1                    | K_HONNALGERE_66  | 17:51   | 18:06     | 0:14     | HAND TRIPPED        |
| 238    | 15-May-19 | MYSORE   | 66      | HV1                    | K_HONNALGERE_66  | 18:08   | 18:31     | 0:22     | HAND TRIPPED        |



| Sl.No. | DATE      | Tr_ZONE  | Voltage | Line                                   | Station_Name  | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|----------|---------|--|---|---------|-----------|----------|--------------------|
| 239    | 15-May-19 | MYSORE   | 66      | KIADB MANDYA-TK HALLI                  | KIADBMANDYA_66 MADDUR_66<br>SOMANAHALLI_66 TUMBEKERE_66             | 17:42   | 18:05     | 0:23     | LINE FAULT         |
| 240    | 15-May-19 | MYSORE   | 66      | KIADB MANDYA-TK HALLI                  | KIADBMANDYA_66 MADDUR_66<br>SOMANAHALLI_66 TUMBEKERE_66             | 18:05   | 18:12     | 0:07     | LINE FAULT         |
| 241    | 15-May-19 | MYSORE   | 66      | KUSHALANAGARA 220-MYSORE-1             | BHERYA, BILIKERE, DMG_HALLI_66<br>GVGUDI_66 KRNAGARA_66<br>MIRLE_66 | 13:12   | 13:25     | 0:12     | LINE FAULT         |
| 242    | 15-May-19 | MYSORE   | 66      | KUSHALANAGARA 220-MYSORE-1             | BHERYA, BILIKERE, DMG_HALLI_66<br>GVGUDI_66 KRNAGARA_66<br>MIRLE_66 | 14:56   | 15:10     | 0:14     | LINE FAULT         |
| 243    | 15-May-19 | MYSORE   | 66      | MADHUVANAHALLI-PG PALYA                | PGPALYA_66  | 17:35   | 17:59     | 0:23     | LINE FAULT         |
| 244    | 15-May-19 | MYSORE   | 66      | HV2                                    | MEGALAPURA_66   | 11:30   | 11:35     | 0:05     | TRANSFORMER FAULT  |
| 245    | 15-May-19 | MYSORE   | 66      | HV1                                    | SANTHESARAGUR_66  | 12:30   | 14:23     | 1:53     | LINE CLEAR AVAILED |
| 246    | 15-May-19 | MYSORE   | 66      | HV1                                    | SANTHESARAGUR_66  | 19:07   | 19:09     | 0:02     | TRANSFORMER FAULT  |
| 247    | 15-May-19 | MYSORE   | 66      | HV1                                    | SOMANAHALLI_66  | 19:45   | 22:10     | 2:25     | TRANSFORMER FAULT  |
| 248    | 15-May-19 | MYSORE   | 66      | TUBINAKERE-PANDAVAPURA                 | DODDABYADARAHALLI_66<br>PANDAVAPURA_66                              | 21:59   | 22:16     | 0:17     | LINE FAULT         |
| 249    | 15-May-19 | TUMKUR   | 66      | DAVANGERE SRS- GUTTUR66                | GUTTUR_66   | 10:25   | 10:39     | 0:14     | LINE FAULT         |
| 250    | 15-May-19 | TUMKUR   | 66      | DAVANGERE SRS- KUKKAWADA               | KUKKAWADA_66, TYAVANAGI_66,<br>BASAVAPATNA_66,<br>SANTEBENNUR_66    | 7:31    | 7:44      | 0:12     | LINE FAULT         |
| 251    | 15-May-19 | TUMKUR   | 66      | DAVANGERE SRS- KUKKAWADA               | KUKKAWADA_66, TYAVANAGI_66,<br>BASAVAPATNA_66,<br>SANTEBENNUR_66    | 10:25   | 10:40     | 0:15     | LINE FAULT         |
| 252    | 15-May-19 | TUMKUR   | 66      | DYAVARANAHALLI- CELESTIALSOLAR         | CELESTIALSOLAR_IPP_66   | 22:28   | 22:35     | 0:06     | LINE FAULT         |
| 253    | 15-May-19 | TUMKUR   | 66      | KUKKAWADA-<br>LINGADAHALLI(CHANNAGIRI) | TYAVANAGI_66,<br>BASAVAPATNA_66,<br>SANTEBENNUR_66                  | 7:25    | 7:30      | 0:04     | LINE FAULT         |
| 254    | 15-May-19 | TUMKUR   | 66      | MADHUGIRI 220kV- SIRA                  | SIRA_66, KALLAMBELLA_66,<br>BUKKAPATNA_66                           | 22:08   | 22:10     | 0:01     | LINE FAULT         |
| 255    | 15-May-19 | TUMKUR   | 220     | TR-2                                   | PATTANAYAKANAHALLI_66   | 12:10   | 12:21     | 0:11     | LINE CLEAR AVAILED |
| 256    | 16-May-19 | BAGALKOT | 220     | BELGAUM-CHIKKODI 2                     | BELGAUM_220   | 5:13    | 6:04      | 0:51     | LINE FAULT         |
| 257    | 16-May-19 | BAGALKOT | 220     | 220/110KV,HV2&LV2                      | BELGAUM_220   | 5:13    | 5:58      | 0:45     | TRANSFORMER FAULT  |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                 | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|--------------------------------------|--|---------|-----------|----------|---------------------|
| 258    | 16-May-19 | BAGALKOT  | 110     | BELGAUM-KANABARGI LAYOUT             | KANABARGI LAYOUT _110  | 5:15    | 5:58      | 0:43     | HAND TRIPPED        |
| 259    | 16-May-19 | BAGALKOT  | 110     | BELGAUM-ANKALAGI                     | ANKALAGI _110  | 5:24    | 5:58      | 0:34     | HAND TRIPPED        |
| 260    | 16-May-19 | BAGALKOT  | 220     | DHONI-LINGAPUR 1                     | DHONI _400   | 10:48   | 16:17     | 5:29     | LINE CLEAR AVAILED  |
| 261    | 16-May-19 | BAGALKOT  | 110     | CHIKKODI-ANKALI                      | ANKALI _110  | 13:10   | 15:49     | 2:39     | LINE CLEAR AVAILED  |
| 262    | 16-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                         | GULEDGUDDA _110  | 0:00    | 14:40     | 14:40    | LINE CLEAR AVAILED  |
| 263    | 16-May-19 | BAGALKOT  | 110     | 110/11KV, HV1                        | NIDAGUNDI _110   | 0:02    | 0:10      | 0:08     | TRANSFORMER FAULT   |
| 264    | 16-May-19 | BAGALKOT  | 110     | 110/11KV, HV1                        | NIDAGUNDI _110   | 15:05   | 15:10     | 0:05     | HAND TRIPPED        |
| 265    | 16-May-19 | BAGALKOT  | 110     | 110/11KV, HV2                        | MUNVALLI _110  | 0:33    | 0:41      | 0:08     | TRANSFORMER FAULT   |
| 266    | 16-May-19 | BAGALKOT  | 110     | 110/11KV, HV2                        | MALGHAN(B) _110  | 12:35   | 13:43     | 1:08     | LINE CLEAR AVAILED  |
| 267    | 16-May-19 | BAGALKOT  | 220     | SIRSI-HUBLI1                         | SIRSI _220   | 8:21    | 11:08     | 2:47     | LINE CLEAR AVAILED  |
| 268    | 16-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - ADUGODI 1 & 2       | ADUGODI, BOSCH (EHT)   | 11:03   | 11:20     | 0:16     | MAIN SUPPLY FAILURE |
| 269    | 16-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - KORAMANGALA         | KORAMANGALA, K & C VALLEY, NAL (EHT)                               | 11:03   | 11:20     | 0:16     | MAIN SUPPLY FAILURE |
| 270    | 16-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - DEVARBISANAHALLI    | DEVARBISANAHALLI   | 11:03   | 11:25     | 0:21     | MAIN SUPPLY FAILURE |
| 271    | 16-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - SHOBHA APARTMENT    | SHOBHA APARTMENT   | 11:03   | 11:20     | 0:16     | MAIN SUPPLY FAILURE |
| 272    | 16-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - ST. JOHNS           | ST. JOHNS  | 11:03   | 11:20     | 0:16     | MAIN SUPPLY FAILURE |
| 273    | 16-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - ADUGODI 1 & 2       | ADUGODI, BOSCH (EHT)   | 13:17   | 13:43     | 0:26     | MAIN SUPPLY FAILURE |
| 274    | 16-May-19 | BENGALURU | 66      | KUMBALAGODU - KENGERI SATELLITE TOWN | KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE            | 5:10    | 5:15      | 0:05     | LOAD CHANGEOVER     |
| 275    | 16-May-19 | BENGALURU | 66      | RMV - HEBBAL 220                     | RMV, TATA INSTITUTE (EHT)  | 13:12   | 13:17     | 0:05     | LOAD CHANGEOVER     |
| 276    | 16-May-19 | BENGALURU | 66      | HV1                                  | BOODIGERE  | 7:06    | 7:12      | 0:05     | TRANSFORMER FAULT   |
| 277    | 16-May-19 | BENGALURU | 66      | HV2                                  | TAVAREKERE   | 15:45   | 15:52     | 0:06     | TRANSFORMER FAULT   |
| 278    | 16-May-19 | BENGALURU | 66      | HV2                                  | TELECOM LAYOUT   | 9:09    | 9:18      | 0:08     | TRANSFORMER FAULT   |
| 279    | 16-May-19 | BENGALURU | 66      | HV3                                  | YERANDANAHALLI 2200  | 11:18   | 13:45     | 2:26     | TRANSFORMER FAULT   |
| 280    | 16-May-19 | BENGALURU | 66      | HV3                                  | YERANDANAHALLI 2200  | 17:47   | 18:02     | 0:15     | TRANSFORMER FAULT   |
| 281    | 16-May-19 | BENGALURU | 220     | HV2                                  | HSR LAYOUT 220   | 13:16   | 13:43     | 0:26     | TRANSFORMER FAULT   |
| 282    | 16-May-19 | BENGALURU | 66      | GOKULA - BEL (EH)                    | BEL (EHT)  | 11:17   | 11:38     | 0:21     | MAIN SUPPLY FAILURE |
| 283    | 16-May-19 | BENGALURU | 66      | GOKULA - MATHIKERE                   | MATHIKERE  | 11:17   | 11:54     | 0:36     | MAIN SUPPLY FAILURE |
| 284    | 16-May-19 | BENGALURU | 66      | GOKULA - RMV                         | RMV, TATA INSTITUTE (EHT)  | 11:17   | 11:51     | 0:33     | LINE FAULT          |
| 285    | 16-May-19 | BENGALURU | 66      | SRS PEENYA 220 - GOKULA 1            | GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT) | 11:17   | 11:33     | 0:15     | LINE FAULT          |
| 286    | 16-May-19 | BENGALURU | 66      | SRS PEENYA 220 - GOKULA 2            | GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT) | 11:17   | 11:33     | 0:15     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line  | Station_Name  | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|-----------|---------|---|---|---------|-----------|----------|--------------------|
| 287    | 16-May-19 | BENGALURU | 66      | SRS PEENYA 220 - NELAKADRINAHALLI           | NELAKADRINAHALLI  | 12:54   | 13:44     | 0:49     | LINE CLEAR AVAILED |
| 288    | 16-May-19 | BENGALURU | 66      | SOLDEVANAHALLI - SRS PEENYA 220             | SOLDEVANAHALLI  | 19:22   | 19:36     | 0:14     | LOAD CHANGEOVER    |
| 289    | 16-May-19 | BENGALURU | 220     | SOMANAHALLI 220 - HSR LAYOUT 220            | HSR LAYOUT 220  | 11:03   | 11:20     | 0:16     | LINE FAULT         |
| 290    | 16-May-19 | BENGALURU | 66      | CHINTAMANI 220 - GANJIGUNTE 1 & 2           | GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI | 13:21   | 13:32     | 0:11     | LOAD CHANGEOVER    |
| 291    | 16-May-19 | BENGALURU | 66      | CHINTAMANI 220 - IRGAMPALLI                 | IRAGAMPALLI, M GOLLAHALLI   | 13:21   | 13:32     | 0:11     | LOAD CHANGEOVER    |
| 292    | 16-May-19 | BENGALURU | 66      | CHINTAMANI 220 - LAKSHMIPURA                | LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI                                 | 13:21   | 13:32     | 0:11     | LOAD CHANGEOVER    |
| 293    | 16-May-19 | BENGALURU | 66      | CHINTAMANI 220 - NANDIGANAHALLI             | NANDIGANAHALLI  | 13:21   | 13:32     | 0:11     | LOAD CHANGEOVER    |
| 294    | 16-May-19 | BENGALURU | 66      | CHINTAMANI 220 - SIDLAGHATTA                | SIDLAGHATTA, MELUR  | 13:21   | 13:32     | 0:11     | LOAD CHANGEOVER    |
| 295    | 16-May-19 | BENGALURU | 66      | CHINTAMANI 220 - SRINIVASPURA               | SRINIVASPURA, KODIHALLI   | 13:21   | 13:32     | 0:11     | LOAD CHANGEOVER    |
| 296    | 16-May-19 | BENGALURU | 66      | CHINTAMANI 220 - TALAGAWARA                 | TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI                               | 13:21   | 13:32     | 0:11     | LOAD CHANGEOVER    |
| 297    | 16-May-19 | BENGALURU | 66      | CHINTAMANI 220 - YENIGADALE                 | YENIGADALE, CHELUR, CHAKAVELU   | 13:21   | 13:32     | 0:11     | LOAD CHANGEOVER    |
| 298    | 16-May-19 | BENGALURU | 66      | GOWRIBIDANUR 220 - BAGEPALLI 1              | VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA                | 16:29   | 16:43     | 0:13     | LINE FAULT         |
| 299    | 16-May-19 | BENGALURU | 66      | HV1   | GOWRIBIDANUR 220  | 10:12   | 10:27     | 0:15     | TRANSFORMER FAULT  |
| 300    | 16-May-19 | BENGALURU | 66      | HV1   | GOWRIBIDANUR 220  | 19:28   | 19:35     | 0:07     | TRANSFORMER FAULT  |
| 301    | 16-May-19 | BENGALURU | 66      | HULLENAHALLI - KUDUR                        | KUDUR   | 11:08   | 13:51     | 2:42     | LINE CLEAR AVAILED |
| 302    | 16-May-19 | BENGALURU | 66      | HULLENAHALLI - KUDUR                        | KUDUR   | 16:16   | 16:41     | 0:25     | LINE CLEAR AVAILED |
| 303    | 16-May-19 | BENGALURU | 66      | SARJAPURA 220 - CHANDAPURA                  | CHANDAPURA  | 5:22    | 6:05      | 0:42     | LINE FAULT         |
| 304    | 16-May-19 | BENGALURU | 66      | SARJAPURA 220 - CHANDAPURA                  | CHANDAPURA  | 6:05    | 6:25      | 0:20     | LINE FAULT         |
| 305    | 16-May-19 | BENGALURU | 66      | CHANDAPURA - YARANDANAHALLI 220             | CHANDAPURA  | 12:50   | 12:58     | 0:08     | LOAD CHANGEOVER    |
| 306    | 16-May-19 | BENGALURU | 66      | YELAHANKA 220 - LINE 6                      | SOLADEVANAHALLI   | 17:45   | 18:02     | 0:16     | LINE FAULT         |
| 307    | 16-May-19 | BENGALURU | 66      | SOLADEVANAHALLI - SRS PEENYA 220            | SOLADEVANAHALLI   | 19:22   | 19:36     | 0:14     | LOAD CHANGEOVER    |
| 308    | 16-May-19 | BENGALURU | 66      | CHIKKABALLAPURA URBAN - CHIKKABALLAPURA I/A | CHIKKABALLAPURA URBAN   | 10:14   | 11:06     | 0:51     | LINE CLEAR AVAILED |

| Sl.No. | DATE      | Tr_ZONE  | Voltage | Line                     | Station_Name                 | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|----------|---------|--------------------------|------------------------------|---------|-----------|----------|--------------------|
| 309    | 16-May-19 | GULBARGA | 220     | HV2                      | RAICHUR_220                  | 9:38    | 10:31     | 0:53     | LINE CLEAR AVAILED |
| 310    | 16-May-19 | GULBARGA | 220     | LINGAPUR-SINDHANOOR      | LINGAPUR_220                 | 14:58   | 15:30     | 0:32     | LINE FAULT         |
| 311    | 16-May-19 | GULBARGA | 220     | SHAHPUR-SEDAM            | SEDAM_220                    | 0:00    | 10:25     | 10:25    | LINE CLEAR AVAILED |
| 312    | 16-May-19 | GULBARGA | 110     | HV2                      | SHAHPUR_220                  | 0:00    | 14:15     | 14:15    | TRANSFORMER FAULT  |
| 313    | 16-May-19 | GULBARGA | 110     | RAICHUR-SINDHANOOR1      | SIRWAR_110,VALKAMDINNI_110   | 8:48    | 11:12     | 2:24     | LINE CLEAR AVAILED |
| 314    | 16-May-19 | GULBARGA | 110     | RAICHUR-SINDHANOOR2      | KURDICROSS_110               | 7:14    | 11:12     | 3:58     | LINE FAULT         |
| 315    | 16-May-19 | GULBARGA | 110     | RAICHUR-MALIYABAD        | MALIYABAD_110, VADAVATTI_110 | 8:48    | 11:12     | 2:24     | LINE CLEAR AVAILED |
| 316    | 16-May-19 | GULBARGA | 110     | RAICHUR-MATMARI          | MATMARI_110                  | 8:48    | 11:12     | 2:24     | LINE CLEAR AVAILED |
| 317    | 16-May-19 | GULBARGA | 110     | KAPNOOR-GULBARGANORTH1,2 | GULBARGA NORTH_110           | 18:02   | 18:10     | 0:08     | LINE FAULT         |
| 318    | 16-May-19 | GULBARGA | 66      | HV1                      | HAMPASAGAR_66                | 10:27   | 10:32     | 0:05     | TRANSFORMER FAULT  |
| 319    | 16-May-19 | GULBARGA | 66      | ITTAGI-RENWSLR1,2        | ITTAGI_220                   | 18:11   | 19:45     | 1:34     | LINE CLEAR AVAILED |
| 320    | 16-May-19 | HASSAN   | 220     | SHRAVITY-SHIRALKOPPA     | sharavathy_gen               | 12:50   | 14:05     | 1:15     | LINE CLEAR AVAILED |
| 321    | 16-May-19 | HASSAN   | 220     | SHRLKP-SGS               | SHIRALKOPPA_220              | 12:53   | 14:02     | 1:09     | LINE CLEAR AVAILED |
| 322    | 16-May-19 | HASSAN   | 110     | SHRLKP-SHIRALKOPPA       | SHIRALKOPPA_220              | 14:08   | 18:49     | 4:41     | LINE CLEAR AVAILED |
| 323    | 16-May-19 | HASSAN   | 110     | HV1                      | BIRUR_110                    | 9:30    | 17:26     | 7:56     | LINE CLEAR AVAILED |
| 324    | 16-May-19 | HASSAN   | 110     | HV1                      | GURUVAYANAKERE_110           | 10:02   | 16:32     | 6:30     | LINE CLEAR AVAILED |
| 325    | 16-May-19 | HASSAN   | 110     | HV2                      | GURUVAYANAKERE_110           | 10:02   | 23:59     | 13:57    | LINE CLEAR AVAILED |
| 326    | 16-May-19 | HASSAN   | 110     | HV3                      | GURUVAYANAKERE_110           | 10:02   | 23:59     | 13:57    | LINE CLEAR AVAILED |
| 327    | 16-May-19 | HASSAN   | 110     | GURUVA-KEMAR1            | GURUVAYANAKERE_110           | 10:03   | 16:30     | 6:27     | LINE CLEAR AVAILED |
| 328    | 16-May-19 | HASSAN   | 110     | GURUVA-KEMAR2            | GURUVAYANAKERE_110           | 10:03   | 16:30     | 6:27     | LINE CLEAR AVAILED |
| 329    | 16-May-19 | HASSAN   | 110     | KAVOOR-BAIKAMPADY        | KAVOOR_220                   | 4:39    | 4:55      | 0:16     | LINE FAULT         |
| 330    | 16-May-19 | HASSAN   | 110     | KEMAR-Guruvykere1        | KEMAR_220                    | 10:05   | 16:29     | 6:24     | NFBC ISSUED        |
| 331    | 16-May-19 | HASSAN   | 110     | KEMAR-Guruvykere2        | KEMAR_220                    | 10:05   | 16:30     | 6:25     | NFBC ISSUED        |
| 332    | 16-May-19 | HASSAN   | 66      | BHADRA-LINGADAHALLI      | bhadra_gen                   | 16:14   | 16:25     | 0:11     | LINE FAULT         |
| 333    | 16-May-19 | HASSAN   | 66      | HV1                      | DIDIGA_66                    | 16:13   | 17:06     | 0:53     | LINE CLEAR AVAILED |
| 334    | 16-May-19 | HASSAN   | 66      | HV1                      | HARIHARAPURA_66              | 19:25   | 19:49     | 0:24     | TRANSFORMER FAULT  |
| 335    | 16-May-19 | HASSAN   | 66      | HASSN220-ARAKALGUD       | HASSAN_220                   | 19:58   | 21:10     | 1:12     | LINE FAULT         |
| 336    | 16-May-19 | HASSAN   | 66      | HNPR2-CRPTN              | HOLENARASIPURA_220           | 19:30   | 19:49     | 0:19     | LINE FAULT         |
| 337    | 16-May-19 | HASSAN   | 66      | HNPR2-MYSOR1             | HOLENARASIPURA_220           | 19:15   | 19:48     | 0:33     | LINE FAULT         |
| 338    | 16-May-19 | HASSAN   | 66      | SAKALE-IPCL1             | SAKLESHPUA_66                | 7:24    | 19:01     | 11:37    | LINE CLEAR AVAILED |
| 339    | 16-May-19 | HASSAN   | 66      | SAKALE-IPCL2             | SAKLESHPUA_66                | 7:24    | 19:01     | 11:37    | LINE CLEAR AVAILED |
| 340    | 16-May-19 | MYSORE   | 66      | G UKKADA-METAGALLY       | SRIRANGAPATNA_66             | 18:54   | 19:00     | 0:06     | LINE FAULT         |
| 341    | 16-May-19 | MYSORE   | 66      | HUNSUR-HOOTAGALLI        | HOSURGATE_66                 | 20:06   | 20:32     | 0:26     | LINE FAULT         |

| Sl.No. | DATE      | Tr_ZONE | Voltage | Line                       | Station_Name  | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|---------|---------|----------------------------|---|---------|-----------|----------|--------------------|
| 342    | 16-May-19 | MYSORE  | 66      | JAKKANAHALLI-NAGAMANGALA   | BOGADHI MANDYA_66 G<br>MALLIGERE_66<br>GUDDENAHALLI_66<br>NAGAMANGALA_66  | 18:09   | 18:31     | 0:21     | LINE FAULT         |
| 343    | 16-May-19 | MYSORE  | 66      | HV1                        | K_HONNALGERE_66   | 13:00   | 13:27     | 0:26     | LINE CLEAR AVAILED |
| 344    | 16-May-19 | MYSORE  | 66      | K HONNALAGERE-MADDUR       | K_HONNALGERE_66   | 10:31   | 13:51     | 3:20     | LINE CLEAR AVAILED |
| 345    | 16-May-19 | MYSORE  | 66      | K HONNALAGERE-IGLOOR       | K_HONNALGERE_66   | 10:31   | 11:49     | 1:18     | LINE CLEAR AVAILED |
| 346    | 16-May-19 | MYSORE  | 66      | KADAKOLA-SARAGUR 1         | ANTHARSANTHE_66<br>HAMPAPURA(K)_66 HDKOTE_66<br>JAIPUR_66   | 20:23   | 20:32     | 0:08     | LINE FAULT         |
| 347    | 16-May-19 | MYSORE  | 66      | KIADB MANDYA-MADDUR        | MADDUR_66 SOMANAHALLI_66  | 13:42   | 17:18     | 3:36     | LINE CLEAR AVAILED |
| 348    | 16-May-19 | MYSORE  | 66      | HV1                        | KIKKERI_66  | 15:21   | 16:23     | 1:02     | LINE CLEAR AVAILED |
| 349    | 16-May-19 | MYSORE  | 66      | HV2                        | KIRUGAVALU_66   | 15:08   | 15:13     | 0:05     | TRANSFORMER FAULT  |
| 350    | 16-May-19 | MYSORE  | 66      | KR PETE-AKKIHEBBAL 1       | AKKIHEBBAL_66   | 18:58   | 19:22     | 0:24     | LINE FAULT         |
| 351    | 16-May-19 | MYSORE  | 66      | KR PETE-AKKIHEBBAL 2       | AKKIHEBBAL_66   | 18:58   | 19:22     | 0:24     | LINE FAULT         |
| 352    | 16-May-19 | MYSORE  | 66      | KR PETE 220-MADESHWARAPURA | BOGADHI MANDYA_66 G<br>MALLIGERE_66<br>GUDDENAHALLI_66<br>NAGAMANGALA_66<br>JAKKANAHALLY_66<br>MADESWARAPURA_66 | 18:20   | 18:27     | 0:07     | LINE FAULT         |
| 353    | 16-May-19 | MYSORE  | 66      | HV1                        | KRPET_220   | 20:40   | 21:00     | 0:20     | TRANSFORMER FAULT  |
| 354    | 16-May-19 | MYSORE  | 66      | MADHUVANAHALLI-YELANDUR    | MAMBALLI_66 YELANDUR_66   | 11:28   | 11:37     | 0:09     | LINE FAULT         |
| 355    | 16-May-19 | MYSORE  | 66      | HV1                        | SANTHESARAGUR_66  | 5:58    | 6:09      | 0:11     | TRANSFORMER FAULT  |
| 356    | 16-May-19 | MYSORE  | 66      | HV1                        | SANTHESARAGUR_66  | 10:24   | 10:30     | 0:06     | TRANSFORMER FAULT  |
| 357    | 16-May-19 | MYSORE  | 66      | HV1                        | SANTHESARAGUR_66  | 13:45   | 16:07     | 2:22     | TRANSFORMER FAULT  |
| 358    | 16-May-19 | MYSORE  | 66      | HV1                        | SANTHESARAGUR_66  | 16:10   | 18:12     | 2:02     | LINE CLEAR AVAILED |
| 359    | 16-May-19 | MYSORE  | 66      | HV1                        | SANTHESARAGUR_66  | 11:40   | 12:20     | 0:39     | HAND TRIPPED       |
| 360    | 16-May-19 | MYSORE  | 66      | HV1                        | TARIPURA_66   | 14:37   | 16:32     | 1:55     | LINE CLEAR AVAILED |
| 361    | 16-May-19 | MYSORE  | 66      | TUBINAKERE-ARAKERE         | ARAKERE_66 GAMANAHALLY_66<br>TARIPURA_66  | 5:34    | 5:52      | 0:18     | LINE FAULT         |

| Sl.No. | DATE      | Tr_ZONE | Voltage | Line                        | Station_Name  | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|---------|---------|-----------------------------|---|---------|-----------|----------|--------------------|
| 362    | 16-May-19 | MYSORE  | 66      | TUBINAKERE-G UKKADA         | ADDIHALLI_66<br>ADICHUNCHANAGIRI_66<br>BASARALU_66 BGNAGARA_66<br>DODDABYADARAHALLI_66<br>GARUDANAUKADDA_66<br>HARADANAHALLI(JAK)_66<br>KESLAGERE_66 PANDAVAPURA_66<br>SHIVALLY_66 SRIRANGAPATNA_66<br>VADERALLI_66 | 5:43    | 5:51      | 0:07     | HAND TRIPPED       |
| 363    | 16-May-19 | MYSORE  | 66      | TUBINAKERE-PANDAVAPURA      | ADDIHALLI_66<br>ADICHUNCHANAGIRI_66<br>BASARALU_66 BGNAGARA_66<br>DODDABYADARAHALLI_66<br>GARUDANAUKADDA_66<br>HARADANAHALLI(JAK)_66<br>KESLAGERE_66 PANDAVAPURA_66<br>SHIVALLY_66 SRIRANGAPATNA_66<br>VADERALLI_66 | 5:43    | 5:48      | 0:05     | HAND TRIPPED       |
| 364    | 16-May-19 | MYSORE  | 66      | TUBINAKERE-NAGAMANGALA 2    | ADDIHALLI_66<br>ADICHUNCHANAGIRI_66<br>BASARALU_66 BGNAGARA_66<br>DODDABYADARAHALLI_66<br>GARUDANAUKADDA_66<br>HARADANAHALLI(JAK)_66<br>KESLAGERE_66 PANDAVAPURA_66<br>SHIVALLY_66 SRIRANGAPATNA_66<br>VADERALLI_66 | 5:43    | 5:48      | 0:04     | HAND TRIPPED       |
| 365    | 16-May-19 | TUMKUR  | 220     | KB CROSS 220kV- NELAMANGALA | KBCROSS_220   | 17:51   | 20:30     | 2:39     | LINE FAULT         |
| 366    | 16-May-19 | TUMKUR  | 220     | TR-3                        | KBCROSS_220   | 17:51   | 18:20     | 0:29     | TRANSFORMER FAULT  |
| 367    | 16-May-19 | TUMKUR  | 220     | TR-3                        | KBCROSS_220   | 4:22    | 4:40      | 0:18     | TRANSFORMER FAULT  |
| 368    | 16-May-19 | TUMKUR  | 66      | TR-2                        | BELLAVI_66  | 13:39   | 14:53     | 1:13     | LINE CLEAR AVAILED |
| 369    | 16-May-19 | TUMKUR  | 66      | TR-1                        | BELLAVI_66  | 11:40   | 13:36     | 1:56     | LINE CLEAR AVAILED |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                   | Station_Name   | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|-----------|---------|--|--|---------|-----------|----------|--------------------|
| 370    | 16-May-19 | TUMKUR    | 66      | CHITRADURGA 220kV- TURUVANUR           | MADANAYAKANAHALLI_66,<br>TURUVANUR_66, BIDARKERE_66,<br>JAGALUR_66, SOKKE_66                       | 12:07   | 13:06     | 0:58     | LINE CLEAR AVAILED |
| 371    | 16-May-19 | TUMKUR    | 66      | TR-2                                   | DAVANGERE_66   | 0:09    | 0:14      | 0:04     | TRANSFORMER FAULT  |
| 372    | 16-May-19 | TUMKUR    | 66      | HIREHALLI - BADDIHALLI                 | BADDIHALLI_66  | 18:11   | 19:09     | 0:58     | LINE FAULT         |
| 373    | 16-May-19 | TUMKUR    | 66      | HONNALLI 220kV-<br>CHANNAGIRI(NALLUR ) | CHANNAGIRI_66,<br>DEVARAHALLI_66, BENKIKERE_66,<br>TAVAREKERE(C)_66,<br>GOPPENAHALLI_66, NALLUR_66 | 13:05   | 13:15     | 0:09     | LINE FAULT         |
| 374    | 16-May-19 | TUMKUR    | 66      | HONNALLI 220kV-<br>CHANNAGIRI(NALLUR ) | CHANNAGIRI_66,<br>DEVARAHALLI_66, BENKIKERE_66,<br>TAVAREKERE(C)_66,<br>GOPPENAHALLI_66, NALLUR_66 | 23:37   | 23:48     | 0:10     | LINE FAULT         |
| 375    | 16-May-19 | TUMKUR    | 66      | KORA- BRAHMASANDRA                     | BRAHMASANDRA_66  | 9:11    | 14:24     | 5:12     | LINE CLEAR AVAILED |
| 376    | 17-May-19 | BAGALKOT  | 220     | AMBEWADI-PONDA 2                       | AMBEWADI_220   | 12:42   | 16:13     | 3:31     | LINE FAULT         |
| 377    | 17-May-19 | BAGALKOT  | 110     | 110/11KV,HV 2                          | AMBEWADI_220   | 9:40    | 17:37     | 7:57     | LINE CLEAR AVAILED |
| 378    | 17-May-19 | BAGALKOT  | 110     | 110/11KV,HV 4                          | GHATAPRABHA_110  | 4:30    | 4:32      | 0:02     | TRANSFORMER FAULT  |
| 379    | 17-May-19 | BAGALKOT  | 110     | 110/11KV,HV-1                          | GULEDGUDDA_110   | 10:05   | 12:15     | 2:10     | TRANSFORMER FAULT  |
| 380    | 17-May-19 | BAGALKOT  | 110     | 110/11KV,HV-1                          | GULEDGUDDA_110   | 12:54   | 13:31     | 0:37     | LINE CLEAR AVAILED |
| 381    | 17-May-19 | BAGALKOT  | 110     | SOUDATTI220-MUNVALLY                   | MUNVALLY_110   | 1:01    | 1:54      | 0:53     | LINE FAULT         |
| 382    | 17-May-19 | BAGALKOT  | 110     | MAHALINGPUR220-RANNABELAGALI           | RANNABELAGALI_110  | 12:11   | 21:20     | 9:09     | LINE CLEAR AVAILED |
| 383    | 17-May-19 | BAGALKOT  | 220     | SIRSI-HUBLI1                           | SIRSI_220  | 14:12   | 17:49     | 3:37     | LINE CLEAR AVAILED |
| 384    | 17-May-19 | BAGALKOT  | 220     | SIRSI-HUBLI2                           | SIRSI_220  | 14:22   | 17:59     | 3:37     | LINE CLEAR AVAILED |
| 385    | 17-May-19 | BAGALKOT  | 110     | CHIKKODI1-RAIBAG                       | RAIBAG_110   | 10:48   | 12:34     | 1:46     | LINE CLEAR AVAILED |
| 386    | 17-May-19 | BAGALKOT  | 110     | 110/11KV, HV2                          | MUNVALLY_110   | 0:32    | 0:36      | 0:04     | TRANSFORMER FAULT  |
| 387    | 17-May-19 | BAGALKOT  | 110     | BALAJI SUGARS-MUDDEBIHAL               | MUDDEBIHAL_110   | 3:45    | 4:16      | 0:31     | LINE FAULT         |
| 388    | 17-May-19 | BAGALKOT  | 110     | AMBEWADI-KIRUVATTI                     | KIRUVATTI_110  | 0:00    | 12:57     | 12:57    | LINE CLEAR AVAILED |
| 389    | 17-May-19 | BAGALKOT  | 220     | CHIKKODI-BELGAUM2                      | CHIKKODI_220   | 12:37   | 14:16     | 1:39     | LINE CLEAR AVAILED |
| 390    | 17-May-19 | BENGALURU | 66      | SOMANAHALLI 220 - JIGANI 1             | SOUTH CITY   | 13:26   | 13:37     | 0:11     | LINE FAULT         |
| 391    | 17-May-19 | BENGALURU | 66      | HV2                                    | TAVAREKERE   | 20:00   | 20:07     | 0:07     | TRANSFORMER FAULT  |
| 392    | 17-May-19 | BENGALURU | 66      | HV1                                    | TAVAREKERE   | 20:00   | 20:11     | 0:11     | TRANSFORMER FAULT  |
| 393    | 17-May-19 | BENGALURU | 66      | HV1                                    | TAVAREKERE   | 6:48    | 6:54      | 0:06     | TRANSFORMER FAULT  |
| 394    | 17-May-19 | BENGALURU | 66      | HV2                                    | TAVAREKERE   | 14:18   | 14:21     | 0:03     | TRANSFORMER FAULT  |
| 395    | 17-May-19 | BENGALURU | 66      | PLATINUM CITY - DG 3                   | PLATINUM CITY  | 22:35   | 22:40     | 0:05     | LOAD CHANGE OVER   |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                    | Station_Name                                  | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|---|---|---------|-----------|----------|---------------------|
| 396    | 17-May-19 | BENGALURU | 66      | PLATINUM CITY - SRS PEENYA 220          | PLATINUM CITY                                 | 20:15   | 20:50     | 0:35     | LOAD CHANGEOVER     |
| 397    | 17-May-19 | BENGALURU | 66      | HV23                                    | YERANDANAHALLI 2200                           | 15:08   | 15:17     | 0:09     | TRANSFORMER FAULT   |
| 398    | 17-May-19 | BENGALURU | 66      | HV2                                     | TELECOM LAYOUT                                | 19:30   | 19:34     | 0:04     | TRANSFORMER FAULT   |
| 399    | 17-May-19 | BENGALURU | 66      | HV2                                     | NRS 220                                       | 22:08   | 22:29     | 0:20     | LOAD CHANGEOVER     |
| 400    | 17-May-19 | BENGALURU | 66      | HV2                                     | NRS 220                                       | 20:14   | 20:39     | 0:25     | MAIN SUPPLY FAILURE |
| 401    | 17-May-19 | BENGALURU | 66      | HOODY 220 - HEBBAL 220                  | HEBBAL 220                                    | 15:36   | 16:44     | 1:07     | LINE FAULT          |
| 402    | 17-May-19 | BENGALURU | 66      | RMV - GOKULA                            | RMV   | 22:34   | 22:38     | 0:04     | LOAD CHANGEOVER     |
| 403    | 17-May-19 | BENGALURU | 66      | RMV - TATA INSTITUTE (ETH)              | TATA INSTITUTE (EHT)                          | 22:34   | 22:45     | 0:11     | LOAD CHANGEOVER     |
| 404    | 17-May-19 | BENGALURU | 220     | SRS PEENYA 220 - NELAMANGALA 3          | SRS PEENYA 220                                | 20:10   | 20:55     | 0:45     | LINE FAULT          |
| 405    | 17-May-19 | BENGALURU | 220     | SRS PEENYA 220 - NELAMANGALA 2          | SRS PEENYA 220                                | 20:10   | 20:32     | 0:22     | LINE FAULT          |
| 406    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 - GOKULA                 | GOKULA, MATHIKERE, BEL (EHT),<br>HMT (EHT)    | 20:10   | 20:40     | 0:30     | MAIN SUPPLY FAILURE |
| 407    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 - PLATINUM CITY          | PLATINUM CITY                                 | 20:10   | 20:32     | 0:22     | MAIN SUPPLY FAILURE |
| 408    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 - DG2                    | ALUR, NELAMANGALA 66                          | 20:10   | 20:32     | 0:22     | MAIN SUPPLY FAILURE |
| 409    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 - WEL CAST               | WEL CAST                                      | 20:10   | 21:23     | 1:13     | MAIN SUPPLY FAILURE |
| 410    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 - MEI LAYOUT             | MEI LAYOUT, WIDIA, WIDIA (EHT)                | 20:10   | 20:32     | 0:22     | MAIN SUPPLY FAILURE |
| 411    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 - NRS 1                  | NANDINI LAYOUT                                | 20:10   | 20:47     | 0:37     | MAIN SUPPLY FAILURE |
| 412    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 - NRS 2                  | MAHALAKSHMI LAYOUT                            | 20:10   | 20:39     | 0:29     | MAIN SUPPLY FAILURE |
| 413    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 - BYADRAHALLI            | BYADRAHALLI, TAVAREKERE,<br>KODIHALLI         | 20:10   | 20:32     | 0:22     | MAIN SUPPLY FAILURE |
| 414    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 - BRINDAVANA             | BRINDAVANA                                    | 20:10   | 20:32     | 0:22     | MAIN SUPPLY FAILURE |
| 415    | 17-May-19 | BENGALURU | 66      | SRS PEENYA 220 -<br>NELAKADRINAHALLI    | NELAKADRINAHALLI                              | 20:10   | 21:28     | 1:18     | MAIN SUPPLY FAILURE |
| 416    | 17-May-19 | BENGALURU | 66      | MAHALAKSHMI LAYOUT - NRS 220            | MAHALAKSHMI LAYOUT                            | 22:09   | 22:12     | 0:02     | LOAD CHANGEOVER     |
| 417    | 17-May-19 | BENGALURU | 66      | MATHIKERE - GOKULA                      | MATHIKERE                                     | 22:30   | 22:36     | 0:06     | LOAD CHANGEOVER     |
| 418    | 17-May-19 | BENGALURU | 66      | RMV - GOKULA                            | RMV, TATA INSTITUTE (EHT)                     | 20:10   | 20:52     | 0:42     | MAIN SUPPLY FAILURE |
| 419    | 17-May-19 | BENGALURU | 66      | NANDINI LAYOUT - SRS PEENYA 220         | NANDINI LAYOUT                                | 22:05   | 22:10     | 0:05     | LOAD CHANGEOVER     |
| 420    | 17-May-19 | BENGALURU | 66      | BEGUR 220 - BOODIGERE                   | BOODIGERE                                     | 18:35   | 19:25     | 0:50     | LINE FAULT          |
| 421    | 17-May-19 | BENGALURU | 66      | DB PURA 220 - TUBUGERE                  | TUBUGERE                                      | 7:59    | 8:04      | 0:04     | LINE FAULT          |
| 422    | 17-May-19 | BENGALURU | 66      | DB PURA 220 - CHIKKABALLAPURA I/<br>A 2 | CHIKKABALLAPURA I/A,<br>CHIKKABALLAPURA URBAN | 7:59    | 8:04      | 0:04     | LINE FAULT          |
| 423    | 17-May-19 | BENGALURU | 66      | CHIKKABALLAPURA I/A - DB PURA 1         | CHIKKABALLAPURA I/A                           | 7:59    | 8:20      | 0:20     | LINE FAULT          |



| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                     | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|--|--|---------|-----------|----------|---------------------|
| 424    | 17-May-19 | BENGALURU | 66      | CHIKKABALLAPURA I/A - NALLIMARADANAHALLI | NALLIMARADANAHALLI   | 7:59    | 8:36      | 0:36     | MAIN SUPPLY FAILURE |
| 425    | 17-May-19 | BENGALURU | 66      | CHINTAMANI 220 - IRAGAMPALLI             | IRAGAMPALLI, M GOLLAHALLI  | 15:12   | 15:25     | 0:12     | LINE FAULT          |
| 426    | 17-May-19 | BENGALURU | 66      | CHINTAMANI 220 - LAKSHMIPURA             | LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI                                    | 14:22   | 14:29     | 0:07     | LINE FAULT          |
| 427    | 17-May-19 | BENGALURU | 66      | CHINTAMANI 220 - YENNIGADALE             | YENNIGADALE, CHELUR, CHAKAVELU   | 17:13   | 17:20     | 0:06     | LINE FAULT          |
| 428    | 17-May-19 | BENGALURU | 66      | HV1                                      | DEVANAHALLI  | 18:50   | 19:00     | 0:10     | TRANSFORMER FAULT   |
| 429    | 17-May-19 | BENGALURU | 66      | DB PURA 220 - VIJAYAPURA                 | VIJAYAPURA, JANGAMAKOTE  | 18:40   | 18:54     | 0:13     | LINE FAULT          |
| 430    | 17-May-19 | BENGALURU | 220     | DB PURA 220 - NELAMANGALA 1              | DB PURA 220  | 14:13   | 14:40     | 0:27     | LINE FAULT          |
| 431    | 17-May-19 | BENGALURU | 220     | DB PURA 220 - NELAMANGALA 1              | DB PURA 220  | 14:13   | 14:40     | 0:27     | LINE FAULT          |
| 432    | 17-May-19 | BENGALURU | 66      | DB PURA 220 - CHIKKABALLAPURA I/ A 1 & 2 | TUBUGERE, CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI | 14:13   | 14:43     | 0:30     | MAIN SUPPLY FAILURE |
| 433    | 17-May-19 | BENGALURU | 66      | DB PURA 220 - DEVANAHALLI 1 & 2          | KUNDANA, DEVANAHALLI   | 14:13   | 14:48     | 0:35     | MAIN SUPPLY FAILURE |
| 434    | 17-May-19 | BENGALURU | 66      | DB PURA 220 - DG 2                       | DODDABELAVANGALA   | 14:13   | 14:48     | 0:35     | MAIN SUPPLY FAILURE |
| 435    | 17-May-19 | BENGALURU | 66      | DB PURA 220 - D CROSS                    | D CROSS  | 14:13   | 14:48     | 0:35     | MAIN SUPPLY FAILURE |
| 436    | 17-May-19 | BENGALURU | 66      | DB PURA 220 - VIJAYAPURA                 | VIJAYAPURA, JANGAMAKOTE  | 14:13   | 14:42     | 0:29     | MAIN SUPPLY FAILURE |
| 437    | 17-May-19 | BENGALURU | 66      | GOWRIBIDANUR 220 - BAGEPALLI 1           | VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA                    | 17:38   | 17:49     | 0:11     | LINE FAULT          |
| 438    | 17-May-19 | BENGALURU | 66      | HV2                                      | GUDIBANDE  | 4:42    | 17:00     | 12:17    | LINE CLEAR AVAILED  |
| 439    | 17-May-19 | BENGALURU | 66      | HV2                                      | JIGANI 66  | 13:01   | 13:07     | 0:05     | LINE CLEAR AVAILED  |
| 440    | 17-May-19 | BENGALURU | 66      | HV2                                      | JIGANI 66  | 15:01   | 15:06     | 0:05     | LINE CLEAR AVAILED  |
| 441    | 17-May-19 | BENGALURU | 220     | HV1                                      | MAGADI 220   | 14:12   | 15:38     | 1:25     | TRANSFORMER FAULT   |
| 442    | 17-May-19 | BENGALURU | 66      | HV1                                      | MAGADI 220   | 14:12   | 15:38     | 1:25     | MAIN SUPPLY FAILURE |
| 443    | 17-May-19 | BENGALURU | 66      | HV2                                      | THIMAMPALLI  | 9:38    | 10:05     | 0:26     | LINE CLEAR AVAILED  |
| 444    | 17-May-19 | BENGALURU | 220     | MALUR 220 - SARJAPURA 220                | SARJAPURA 220, VIKAS TECH PARK 220                                       | 15:32   | 15:47     | 0:15     | LINE FAULT          |
| 445    | 17-May-19 | BENGALURU | 66      | SARJAPURA 220 - ATTIBELE                 | ATTIBELE   | 15:32   | 15:52     | 0:19     | MAIN SUPPLY FAILURE |
| 446    | 17-May-19 | BENGALURU | 66      | SARJAPURA 220 - CHANDAPURA               | CHANDAPURA   | 15:32   | 15:48     | 0:15     | MAIN SUPPLY FAILURE |
| 447    | 17-May-19 | BENGALURU | 66      | SARJAPURA 220 - DOMMASANDRA              | DOMMASANDRA  | 15:32   | 15:55     | 0:22     | MAIN SUPPLY FAILURE |
| 448    | 17-May-19 | BENGALURU | 66      | HV1                                      | SARJAPURA 220  | 15:32   | 15:47     | 0:15     | MAIN SUPPLY FAILURE |
| 449    | 17-May-19 | BENGALURU | 66      | HV2                                      | SARJAPURA 220  | 15:32   | 15:50     | 0:17     | MAIN SUPPLY FAILURE |
| 450    | 17-May-19 | BENGALURU | 220     | NELAMANGALA 400 - DB PURA 1              | DB PURA 220  | 14:12   | 15:56     | 1:43     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                            | Station_Name                | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|---------------------------------|-----------------------------|---------|-----------|----------|---------------------|
| 451    | 17-May-19 | BENGALURU | 220     | NELAMANGALA 400 - DB PURA 2     | DB PURA 220                 | 14:12   | 15:56     | 1:44     | LINE FAULT          |
| 452    | 17-May-19 | BENGALURU | 220     | NELAMANGALA 400 - YELAHANKA 220 | YELAHANKA 220               | 20:13   | 23:59     | 3:45     | LINE FAULT          |
| 453    | 17-May-19 | BENGALURU | 220     | NELAMANGALA 400 - SRS PEENYA 2  | SRS PEENYA 220              | 14:12   | 17:28     | 3:16     | LINE FAULT          |
| 454    | 17-May-19 | BENGALURU | 220     | NELAMANGALA 400 - SRS PEENYA 2  | SRS PEENYA 220              | 22:44   | 23:59     | 1:14     | LINE CLEAR AVAILED  |
| 455    | 17-May-19 | BENGALURU | 66      | NELAMANGALA 66 - DABUSPET 220   | NELAMANGALA 66              | 22:25   | 22:29     | 0:04     | LOAD CHANGEOVER     |
| 456    | 17-May-19 | BENGALURU | 66      | NELAMANGALA 66 - DABUSPET 220   | NELAMANGALA 66              | 13:22   | 13:32     | 0:10     | LOAD CHANGEOVER     |
| 457    | 17-May-19 | GULBARGA  | 110     | HV1                             | KAMPLI_GLB_110              | 8:10    | 8:25      | 0:15     | LINE CLEAR AVAILED  |
| 458    | 17-May-19 | GULBARGA  | 110     | HV1                             | KAMPLI_GLB_110              | 9:00    | 9:10      | 0:10     | TRANSFORMER FAULT   |
| 459    | 17-May-19 | GULBARGA  | 110     | HV1                             | KAMPLI_GLB_110              | 11:30   | 11:40     | 0:10     | TRANSFORMER FAULT   |
| 460    | 17-May-19 | GULBARGA  | 110     | SHAHPUR-KEMBHAVI1               | KEMBHAVI_110, UGARSUGAR_IPP | 13:18   | 13:27     | 0:09     | LINE FAULT          |
| 461    | 17-May-19 | GULBARGA  | 110     | SHAHPUR-KEMBHAVI2               | KBJNL_IPP                   | 13:01   | 17:00     | 3:59     | LINE FAULT          |
| 462    | 17-May-19 | GULBARGA  | 66      | KOTTUR-UJJANI                   | UJJANI_66                   | 10:45   | 13:40     | 2:55     | LINE CLEAR AVAILED  |
| 463    | 17-May-19 | HASSAN    | 220     | GERSOPA-TALGUPA1                | gerusoppa_gen               | 11:16   | 11:40     | 0:24     | LINE CLEAR AVAILED  |
| 464    | 17-May-19 | HASSAN    | 220     | GERSOPA-TALGUPA2                | gerusoppa_gen               | 11:17   | 11:36     | 0:19     | LINE CLEAR AVAILED  |
| 465    | 17-May-19 | HASSAN    | 220     | MRSSHM-SHARAVATHY1(STRP1)       | MRSMSG_220                  | 11:17   | 11:36     | 0:19     | LINE CLEAR AVAILED  |
| 466    | 17-May-19 | HASSAN    | 220     | MRSSHM-VARAH12                  | MRSMSG_220                  | 11:19   | 11:47     | 0:28     | LINE FAULT          |
| 467    | 17-May-19 | HASSAN    | 220     | TALAGU-STRP2                    | TALAGUPPA_400               | 11:17   | 11:35     | 0:18     | HAND TRIPPED        |
| 468    | 17-May-19 | HASSAN    | 220     | VARAHI-SHIMOGA2                 | varahi_gen                  | 11:19   | 11:49     | 0:30     | LINE FAULT          |
| 469    | 17-May-19 | HASSAN    | 110     | HV1                             | ALKOLA_110                  | 12:25   | 13:30     | 1:05     | LINE CLEAR AVAILED  |
| 470    | 17-May-19 | HASSAN    | 110     | HV2                             | ALKOLA_110                  | 11:46   | 12:22     | 0:36     | LINE CLEAR AVAILED  |
| 471    | 17-May-19 | HASSAN    | 110     | HV1                             | SHIVPURA_110                | 12:10   | 13:13     | 1:03     | LINE CLEAR AVAILED  |
| 472    | 17-May-19 | HASSAN    | 66      | MRSSHM-HOLUR                    | MRSMSG_220                  | 11:14   | 11:49     | 0:35     | LINE FAULT          |
| 473    | 17-May-19 | HASSAN    | 66      | HV1                             | CHANNARAYAPATNA_66          | 12:02   | 13:32     | 1:30     | LINE CLEAR AVAILED  |
| 474    | 17-May-19 | HASSAN    | 66      | HV2                             | CHANNARAYAPATNA_66          | 12:02   | 13:32     | 1:30     | LINE CLEAR AVAILED  |
| 475    | 17-May-19 | HASSAN    | 66      | DODDAKA-HNPURA                  | DODDAKADANUR_66             | 8:25    | 10:34     | 2:09     | MAIN SUPPLY FAILURE |
| 476    | 17-May-19 | HASSAN    | 66      | HV1                             | DODDAKADANUR_66             | 8:25    | 10:34     | 2:09     | MAIN SUPPLY FAILURE |
| 477    | 17-May-19 | HASSAN    | 66      | DODDAKA-HNPURA                  | DODDAKADANUR_66             | 14:55   | 16:55     | 2:00     | MAIN SUPPLY FAILURE |
| 478    | 17-May-19 | HASSAN    | 66      | HV1                             | DODDAKADANUR_66             | 14:55   | 16:55     | 2:00     | MAIN SUPPLY FAILURE |
| 479    | 17-May-19 | HASSAN    | 66      | HNPR2-MYSOR2                    | HOLENARASIPURA_220          | 8:25    | 10:31     | 2:06     | LINE CLEAR AVAILED  |
| 480    | 17-May-19 | HASSAN    | 66      | HNPR2-MYSOR2                    | HOLENARASIPURA_220          | 14:55   | 16:40     | 1:45     | LINE CLEAR AVAILED  |
| 481    | 17-May-19 | HASSAN    | 66      | SAKALE-IPCL1                    | SAKLESH PURA_66             | 7:31    | 18:30     | 10:59    | LINE CLEAR AVAILED  |
| 482    | 17-May-19 | HASSAN    | 66      | SAKALE-IPCL2                    | SAKLESH PURA_66             | 7:31    | 18:30     | 10:59    | LINE CLEAR AVAILED  |

| Sl.No. | DATE      | Tr_ZONE | Voltage | Line                          | Station_Name   | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|---------|---------|-------------------------------|--|---------|-----------|----------|--------------------|
| 483    | 17-May-19 | MYSORE  | 66      | CR NAGARA-HONNALLY            | ATTIGULIPURA_66<br>HONNALLY_MYS_66   | 15:47   | 15:55     | 0:07     | LINE FAULT         |
| 484    | 17-May-19 | MYSORE  | 66      | HV1                           | HANNUR_66  | 11:38   | 11:59     | 0:20     | LINE CLEAR AVAILED |
| 485    | 17-May-19 | MYSORE  | 66      | KADAKOLA-SARAGURU 2           | ANTHARSANTHE_66 B<br>MATKERE_66 DOORA_66<br>HAMPAPURA(K)_66 HDKOTE_66<br>HULLAHALLI_66 HURA_66<br>JAIPUR_66 SANTHESARAGUR_66 | 17:29   | 18:45     | 1:16     | LINE CLEAR AVAILED |
| 486    | 17-May-19 | MYSORE  | 66      | KADAKOLA-SARAGURU 1           | ANTHARSANTHE_66 B<br>MATKERE_66 DOORA_66<br>HAMPAPURA(K)_66 HDKOTE_66<br>HULLAHALLI_66 HURA_66<br>JAIPUR_66 SANTHESARAGUR_66 | 17:29   | 18:45     | 1:16     | LINE CLEAR AVAILED |
| 487    | 17-May-19 | MYSORE  | 220     | HV1                           | KADAKOLA_220   | 18:26   | 20:05     | 1:38     | LINE CLEAR AVAILED |
| 488    | 17-May-19 | MYSORE  | 66      | HV1                           | KIKKERI_66   | 16:15   | 16:17     | 0:02     | HAND TRIPPED       |
| 489    | 17-May-19 | MYSORE  | 66      | KIRUGAVLU-SFC                 | KIRUGAVALU_66  | 8:35    | 17:20     | 8:45     | LINE CLEAR AVAILED |
| 490    | 17-May-19 | MYSORE  | 66      | KUSHALANAGARA 220-MYSORE-1    | BHERYA_66 BILIKERE_66<br>DMG_HALLI_66 GVGUDI_66<br>KRNAGARA_66 MIRLE_66  | 17:42   | 17:47     | 0:05     | LINE FAULT         |
| 491    | 17-May-19 | MYSORE  | 66      | KUSHALANAGARA 220-BETTADAPURA | BETTADHAPURA_66<br>CHUNCHUNKATTE_66 KITTUR_66<br>RAVANDUR_66   | 4:52    | 5:02      | 0:10     | LINE FAULT         |
| 492    | 17-May-19 | MYSORE  | 66      | MADHUVANAHALLI -KOLLEGALA     | BGPURA_66 CHANDALLI_66<br>KOLLEGALA_66<br>PARINAMIPURA_66<br>SATHEGALA_66 THALAKADU_66                                       | 16:50   | 17:00     | 0:10     | LINE FAULT         |
| 493    | 17-May-19 | MYSORE  | 66      | HV2                           | SANTHEMARAHALLI_66   | 16:12   | 16:33     | 0:20     | HAND TRIPPED       |
| 494    | 17-May-19 | MYSORE  | 66      | HV1                           | SFCSHIVA_66  | 9:26    | 20:30     | 11:03    | LINE CLEAR AVAILED |
| 495    | 17-May-19 | MYSORE  | 66      | HV3                           | SFCSHIVA_66  | 9:29    | 19:45     | 10:15    | LINE CLEAR AVAILED |
| 496    | 17-May-19 | MYSORE  | 66      | HV2                           | SFCSHIVA_66  | 9:26    | 20:30     | 11:03    | LINE CLEAR AVAILED |
| 497    | 17-May-19 | MYSORE  | 66      | HV4                           | SFCSHIVA_66  | 9:27    | 20:30     | 11:02    | LINE CLEAR AVAILED |
| 498    | 17-May-19 | MYSORE  | 66      | SFC SIVA-VAJAMANGALA          | VADKEPURA_66   | 9:25    | 20:35     | 11:10    | LINE CLEAR AVAILED |
| 499    | 17-May-19 | MYSORE  | 66      | HV1                           | THALAKADU_66   | 5:55    | 6:08      | 0:13     | HAND TRIPPED       |
| 500    | 17-May-19 | MYSORE  | 66      | HV2                           | THALAKADU_66   | 5:55    | 6:08      | 0:13     | HAND TRIPPED       |
| 501    | 17-May-19 | TUMKUR  | 110     | TR-1                          | NITTUR_220   | 12:17   | 19:30     | 7:13     | LINE CLEAR AVAILED |
| 502    | 17-May-19 | TUMKUR  | 66      | HIREHALLI - BADDIHALLI        | BADDIHALLI_66  | 11:57   | 13:23     | 1:25     | LINE CLEAR AVAILED |

| Sl.No. | DATE      | Tr_ZONE  | Voltage | Line                                   | Station_Name  | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|----------|---------|--|---|---------|-----------|----------|---------------------|
| 503    | 17-May-19 | TUMKUR   | 66      | HONNALLI 220KV-<br>CHANNAGIRI(NALLUR ) | CHANNAGIRI_66,<br>DEVARAHALLI_66, BENKIKERE_66,<br>TAVAREKERE(C)_66,<br>GOPPENAHALLI_66 | 11:46   | 11:52     | 0:05     | LINE FAULT          |
| 504    | 17-May-19 | TUMKUR   | 66      | MATHOD- PANCHANAHALLI                  | PANCHANAHALLI_66, GARAGA_66   | 12:09   | 12:10     | 0:01     | MAIN SUPPLY FAILURE |
| 505    | 18-May-19 | BAGALKOT | 220     | XELDOM-AMBEWADI                        | AMBEWADI_220  | 12:12   | 12:56     | 0:44     | LINE FAULT          |
| 506    | 18-May-19 | BAGALKOT | 220     | NAGJHARI 1-AMBEWADI                    | AMBEWADI_220  | 14:11   | 14:43     | 0:32     | LINE FAULT          |
| 507    | 18-May-19 | BAGALKOT | 110     | BELGAUM220-ANKALAGI                    | ANKALAGI_110  | 9:15    | 18:49     | 9:34     | LINE CLEAR AVAILED  |
| 508    | 18-May-19 | BAGALKOT | 110     | 110/11KV,HV2                           | BEDI_110  | 14:16   | 17:45     | 3:29     | LINE CLEAR AVAILED  |
| 509    | 18-May-19 | BAGALKOT | 220     | BELGAUM-CHIKKODI 1                     | BELGAUM_220   | 9:06    | 11:59     | 2:53     | LINE CLEAR AVAILED  |
| 510    | 18-May-19 | BAGALKOT | 220     | BELGAUM-CHIKKODI 2                     | BELGAUM_220   | 9:06    | 12:12     | 3:06     | LINE CLEAR AVAILED  |
| 511    | 18-May-19 | BAGALKOT | 220     | BELGAUM-NARENDRA 2                     | BELGAUM_220   | 9:13    | 16:18     | 7:05     | LINE CLEAR AVAILED  |
| 512    | 18-May-19 | BAGALKOT | 220     | BELGAUM-NARENDRA 1                     | BELGAUM_220   | 16:41   | 18:22     | 1:41     | LINE CLEAR AVAILED  |
| 513    | 18-May-19 | BAGALKOT | 110     | BIDNAL220-GADAG ROAD                   | GADAG ROAD_110  | 10:00   | 11:47     | 1:47     | LINE CLEAR AVAILED  |
| 514    | 18-May-19 | BAGALKOT | 110     | GHATAPRABHA220-GHTAPRABHA              | GHATAPRABHA_110   | 11:08   | 11:57     | 0:49     | LINE FAULT          |
| 515    | 18-May-19 | BAGALKOT | 110     | AMBEWADI220-HALIYAL                    | HALIYAL_110   | 0:00    | 11:33     | 11:33    | LINE CLEAR AVAILED  |
| 516    | 18-May-19 | BAGALKOT | 110     | AMBEWADI220-HALIYAL                    | HALIYAL_110   | 12:41   | 23:59     | 11:18    | LINE CLEAR AVAILED  |
| 517    | 18-May-19 | BAGALKOT | 110     | KUSTAGI-GAJENDRAGAD                    | GAJENDRAGAD_110   | 0:00    | 10:22     | 10:22    | LINE CLEAR AVAILED  |
| 518    | 18-May-19 | BAGALKOT | 110     | KUSTAGI-GAJENDRAGAD                    | GAJENDRAGAD_110   | 17:18   | 23:59     | 6:41     | LINE CLEAR AVAILED  |
| 519    | 18-May-19 | BAGALKOT | 110     | GADAG ROAD-GOPANAKOPPA                 | GOPANAKOPPA_110   | 9:56    | 12:01     | 2:05     | LINE CLEAR AVAILED  |
| 520    | 18-May-19 | BAGALKOT | 110     | 110/11KV,HV1                           | GULEDAGUDDA_110   | 8:10    | 10:08     | 1:58     | LINE CLEAR AVAILED  |
| 521    | 18-May-19 | BAGALKOT | 110     | 110/11KV,HV1                           | GULEDAGUDDA_110   | 11:54   | 13:41     | 1:47     | LINE CLEAR AVAILED  |
| 522    | 18-May-19 | BAGALKOT | 110     | 110/33KV,HV2                           | GULEDAGUDDA_110,KAMATAGI_3<br>3,SHIRUR_33   | 14:56   | 15:14     | 0:18     | LINE CLEAR AVAILED  |
| 523    | 18-May-19 | BAGALKOT | 220     | GUTTUR 1-HAVERI                        | HAVERI_220  | 18:01   | 20:23     | 2:22     | LINE FAULT          |
| 524    | 18-May-19 | BAGALKOT | 110     | 110/33KV,HV1                           | YARAGATTI_110,SIVAPUR_33KV,C<br>HINCHANUR_33KV,BOSCH<br>SOLAR_33KV                      | 15:05   | 15:07     | 0:02     | LINE CLEAR AVAILED  |
| 525    | 18-May-19 | BAGALKOT | 110     | SIRSI220-UMMACHAGI                     | UMMACHAGI_110   | 13:15   | 13:25     | 0:10     | LINE CLEAR AVAILED  |
| 526    | 18-May-19 | BAGALKOT | 220     | HUBLI-SIRSI2                           | HUBLI_220   | 12:49   | 14:57     | 2:08     | LINE FAULT          |
| 527    | 18-May-19 | BAGALKOT | 220     | HUBLI-SIRSI1                           | HUBLI_220   | 15:53   | 23:16     | 7:23     | LINE FAULT          |
| 528    | 18-May-19 | BAGALKOT | 110     | 110/11KV,HV1                           | SHIRGOAN_110  | 8:15    | 8:57      | 0:42     | LINE CLEAR AVAILED  |
| 529    | 18-May-19 | BAGALKOT | 110     | SIRSI220-KAVALWADA                     | KAVALWADA_110   | 13:35   | 14:30     | 0:55     | LINE CLEAR AVAILED  |
| 530    | 18-May-19 | BAGALKOT | 220     | NARENDRA-KANABARGI1                    | NARENDRA_220  | 16:42   | 18:13     | 1:31     | NFBC ISSUED         |
| 531    | 18-May-19 | BAGALKOT | 110     | 110/11KV,HV2                           | MUKARTHAL_110   | 12:03   | 12:25     | 0:22     | LINE CLEAR AVAILED  |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                | Station_Name                                    | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|-----------|---------|-------------------------------------|---|---------|-----------|----------|--------------------|
| 532    | 18-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                        | LAXMESHWAR_110                                  | 10:35   | 18:20     | 7:45     | LINE CLEAR AVAILED |
| 533    | 18-May-19 | BAGALKOT  | 110     | 110/33KV,HV3                        | LAXMESHWAR_110,MMCL_33KV&SSM_33KV               | 10:35   | 18:29     | 7:54     | LINE CLEAR AVAILED |
| 534    | 18-May-19 | BAGALKOT  | 110     | 110/33KV,HV4                        | LAKMANHALLI_110,ALNAVAR_33                      | 0:29    | 1:05      | 0:36     | TRANSFORMER FAULT  |
| 535    | 18-May-19 | BAGALKOT  | 110     | AMBEWADI-KIRUVATTI                  | KIRUVATTI_110                                   | 12:51   | 13:13     | 0:22     | LINE FAULT         |
| 536    | 18-May-19 | BAGALKOT  | 110     | AMBEWADI-KIRUVATTI                  | KIRUVATTI_110                                   | 15:15   | 22:39     | 7:24     | LINE CLEAR AVAILED |
| 537    | 18-May-19 | BAGALKOT  | 110     | SIRSI-KIRUVATTI                     | KIRUVATTI_110                                   | 13:13   | 13:21     | 0:08     | HAND TRIPPED       |
| 538    | 18-May-19 | BENGALURU | 66      | MATHIKERE - HEBBAL 220              | MATHIKERE                                       | 0:33    | 0:38      | 0:05     | LOAD CHANGEOVER    |
| 539    | 18-May-19 | BENGALURU | 66      | NANDINI LAYOUT - NRS 220            | NANDINI LAYOUT                                  | 0:35    | 0:40      | 0:05     | LOAD CHANGEOVER    |
| 540    | 18-May-19 | BENGALURU | 66      | NANDINI LAYOUT - SRS PEENYA 220     | NANDINI LAYOUT                                  | 13:29   | 13:36     | 0:07     | LOAD CHANGEOVER    |
| 541    | 18-May-19 | BENGALURU | 66      | NANDINI LAYOUT - NRS 220            | NANDINI LAYOUT                                  | 14:17   | 14:23     | 0:06     | LOAD CHANGEOVER    |
| 542    | 18-May-19 | BENGALURU | 66      | RMV - GOKULA                        | RMV, TATA INSTITUTE (EHT)                       | 23:06   | 23:10     | 0:04     | LOAD CHANGEOVER    |
| 543    | 18-May-19 | BENGALURU | 66      | RMV - HEBBAL 220                    | RMV, TATA INSTITUTE (EHT)                       | 0:33    | 0:38      | 0:05     | LOAD CHANGEOVER    |
| 544    | 18-May-19 | BENGALURU | 66      | PLATINUM CITY - SRS PEENYA 220      | PLATINUM CITY                                   | 0:35    | 0:40      | 0:05     | LOAD CHANGEOVER    |
| 545    | 18-May-19 | BENGALURU | 66      | PLATINUM CITY - DG 4                | PLATINUM CITY                                   | 13:30   | 13:40     | 0:10     | LOAD CHANGEOVER    |
| 546    | 18-May-19 | BENGALURU | 66      | PLATINUM CITY - SRS PEENYA 220      | PLATINUM CITY                                   | 14:20   | 14:25     | 0:05     | LOAD CHANGEOVER    |
| 547    | 18-May-19 | BENGALURU | 66      | HV2                                 | NRS 220   | 22:47   | 22:53     | 0:06     | LOAD CHANGEOVER    |
| 548    | 18-May-19 | BENGALURU | 66      | HOODY MUSS II                       | HOODY 220                                       | 17:33   | 18:10     | 0:36     | LINE FAULT         |
| 549    | 18-May-19 | BENGALURU | 66      | HV2                                 | HEJJALA   | 12:56   | 13:10     | 0:13     | LINE CLEAR AVAILED |
| 550    | 18-May-19 | BENGALURU | 66      | MATHIKERE - HEBBAL 220              | MATHIKERE                                       | 0:33    | 0:38      | 0:05     | LOAD CHANGEOVER    |
| 551    | 18-May-19 | BENGALURU | 66      | MATHIKERE - GOKULA                  | MATHIKERE                                       | 23:06   | 23:11     | 0:05     | LOAD CHANGEOVER    |
| 552    | 18-May-19 | BENGALURU | 66      | MAHALAKSHMI LAYOUT - NRS 220        | MAHALAKSHMI LAYOUT                              | 0:37    | 0:41      | 0:04     | LOAD CHANGEOVER    |
| 553    | 18-May-19 | BENGALURU | 66      | MAHALAKSHMI LAYOUT - SRS PEENYA 220 | MAHALAKSHMI LAYOUT                              | 22:47   | 22:54     | 0:06     | LOAD CHANGEOVER    |
| 554    | 18-May-19 | BENGALURU | 66      | EPIP 220 - KADUGODI                 | KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA | 15:36   | 16:23     | 0:47     | LINE CLEAR AVAILED |
| 555    | 18-May-19 | BENGALURU | 66      | BANASHANKARI - VRISHBHAVATHI 220    | BANASHANKARI                                    | 4:01    | 4:05      | 0:03     | LOAD CHANGEOVER    |
| 556    | 18-May-19 | BENGALURU | 66      | BANASHANKARI - AREHALLI             | BANASHANKARI                                    | 2:53    | 2:57      | 0:04     | LOAD CHANGEOVER    |
| 557    | 18-May-19 | BENGALURU | 66      | CHINTAMANI 220 - SIDLAGHATTA        | SIDLAGHATTA, MELUR                              | 16:08   | 16:15     | 0:07     | LINE FAULT         |
| 558    | 18-May-19 | BENGALURU | 66      | HV2                                 | KIADB DB PURA 220                               | 9:30    | 14:10     | 4:40     | TRANSFORMER FAULT  |
| 559    | 18-May-19 | BENGALURU | 66      | DB PURA 220 - DG 2                  | DODDABELAVANGALA                                | 9:36    | 9:37      | 0:01     | LINE CLEAR AVAILED |
| 560    | 18-May-19 | BENGALURU | 220     | HV2                                 | SARJAPURA 220                                   | 16:22   | 21:50     | 5:28     | LINE CLEAR AVAILED |
| 561    | 18-May-19 | BENGALURU | 66      | HV1                                 | SARJAPURA 220                                   | 16:22   | 16:46     | 0:24     | LOAD CHANGEOVER    |
| 562    | 18-May-19 | BENGALURU | 66      | SARJAPURA 220 - ATTIBELE            | ATTIBELE  | 16:22   | 16:59     | 0:37     | LOAD CHANGEOVER    |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                            | Station_Name    | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|---------------------------------|-----------------|---------|-----------|----------|---------------------|
| 563    | 18-May-19 | BENGALURU | 66      | HV1                             | SARJAPURA 220   | 22:48   | 22:50     | 0:02     | LOAD CHANGEOVER     |
| 564    | 18-May-19 | BENGALURU | 66      | SARJAPURA 220 - ATTIBELE        | ATTIBELE        | 22:21   | 22:25     | 0:04     | LOAD CHANGEOVER     |
| 565    | 18-May-19 | BENGALURU | 66      | HV2                             | SOMAYAJANAHALLI | 9:15    | 9:27      | 0:12     | TRANSFORMER FAULT   |
| 566    | 18-May-19 | BENGALURU | 66      | SURYANAGAR - ANEKAL             | SURYANAGAR      | 18:08   | 18:19     | 0:11     | LOAD CHANGEOVER     |
| 567    | 18-May-19 | BENGALURU | 66      | SURYANAGAR - YARANDANAHALLI 220 | SURYANAGAR      | 15:01   | 15:09     | 0:08     | LOAD CHANGEOVER     |
| 568    | 18-May-19 | BENGALURU | 66      | YELAHANKA 220 - LINE 7          | KANASWADI       | 10:56   | 12:59     | 2:03     | LINE CLEAR AVAILED  |
| 569    | 18-May-19 | BENGALURU | 66      | WELCAST - ABBIGERE              | WELCAST         | 0:54    | 0:58      | 0:04     | LOAD CHANGEOVER     |
| 570    | 18-May-19 | BENGALURU | 66      | WELCAST - SRS PEENYA 220        | WELCAST         | 13:30   | 13:35     | 0:05     | LOAD CHANGEOVER     |
| 571    | 18-May-19 | BENGALURU | 66      | WELCAST - ABBIGERE              | WELCAST         | 14:18   | 14:25     | 0:07     | LOAD CHANGEOVER     |
| 572    | 18-May-19 | BENGALURU | 66      | WELCAST - SRS PEENYA 220        | WELCAST         | 22:47   | 22:50     | 0:03     | LOAD CHANGEOVER     |
| 573    | 18-May-19 | BENGALURU | 66      | HV2                             | TYAMAGONDLU     | 11:16   | 11:36     | 0:19     | LINE CLEAR AVAILED  |
| 574    | 18-May-19 | BENGALURU | 66      | HV1                             | WELCAST         | 11:25   | 11:40     | 0:15     | LINE CLEAR AVAILED  |
| 575    | 18-May-19 | BENGALURU | 66      | HV1                             | WELCAST         | 12:20   | 12:25     | 0:05     | LINE CLEAR AVAILED  |
| 576    | 18-May-19 | BENGALURU | 66      | HV2                             | WELCAST         | 14:30   | 14:31     | 0:01     | LINE CLEAR AVAILED  |
| 577    | 18-May-19 | BENGALURU | 66      | HV2                             | WELCAST         | 15:10   | 15:14     | 0:04     | LINE CLEAR AVAILED  |
| 578    | 18-May-19 | BENGALURU | 66      | NELAMANGALA 66 - DABUSPET 220   | NELAMANGALA 66  | 7:31    | 7:34      | 0:02     | LOAD CHANGEOVER     |
| 579    | 18-May-19 | BENGALURU | 66      | NELAMANGALA 66 - DABUSPET 220   | NELAMANGALA 66  | 9:14    | 9:17      | 0:03     | LOAD CHANGEOVER     |
| 580    | 18-May-19 | BENGALURU | 66      | NELAMANGALA 66 - DABUSPET 220   | NELAMANGALA 66  | 13:29   | 13:33     | 0:03     | LOAD CHANGEOVER     |
| 581    | 18-May-19 | BENGALURU | 66      | NELAMANGALA 66 - DABUSPET 220   | NELAMANGALA 66  | 22:51   | 22:54     | 0:02     | LOAD CHANGEOVER     |
| 582    | 18-May-19 | GULBARGA  | 220     | HV2                             | HALBURGA_220    | 1:08    | 1:14      | 0:06     | TRANSFORMER FAULT   |
| 583    | 18-May-19 | GULBARGA  | 220     | HV2                             | KAPNOOR_220     | 1:07    | 23:59     | 22:52    | TRANSFORMER FAULT   |
| 584    | 18-May-19 | GULBARGA  | 220     | LINGAPUR-KUSHTAGI               | LINGAPUR_220    | 9:51    | 15:26     | 5:35     | LINE FAULT          |
| 585    | 18-May-19 | GULBARGA  | 220     | HV1                             | ITTAGI_220      | 13:45   | 14:00     | 0:15     | TRANSFORMER FAULT   |
| 586    | 18-May-19 | GULBARGA  | 220     | HV2                             | HALBURGA_220    | 21:55   | 22:08     | 0:13     | TRANSFORMER FAULT   |
| 587    | 18-May-19 | GULBARGA  | 220     | KUSTAGI-ODPWIND                 | KUSTAGI_220     | 9:50    | 15:19     | 5:29     | LINE CLEAR AVAILED  |
| 588    | 18-May-19 | GULBARGA  | 220     | KUSTAGI-SUZWIND1                | KUSTAGI_220     | 16:10   | 17:20     | 1:10     | LINE FAULT          |
| 589    | 18-May-19 | GULBARGA  | 110     | LV2                             | HALBURGA_220    | 1:08    | 1:14      | 0:06     | TRANSFORMER FAULT   |
| 590    | 18-May-19 | GULBARGA  | 110     | SHAHAPUR-KEMBHAVI2              | KBJNL_IPP       | 10:15   | 11:10     | 0:55     | LINE CLEAR AVAILED  |
| 591    | 18-May-19 | GULBARGA  | 110     | HV1                             | SHAHAPUR_220    | 11:55   | 12:15     | 0:20     | TRANSFORMER FAULT   |
| 592    | 18-May-19 | GULBARGA  | 110     | YELBURGA-KUSHTAGI               | YELBURGA_110    | 10:14   | 16:15     | 6:01     | MAIN SUPPLY FAILURE |
| 593    | 18-May-19 | GULBARGA  | 110     | LV2                             | ITTAGI_220      | 13:45   | 14:00     | 0:15     | TRANSFORMER FAULT   |
| 594    | 18-May-19 | GULBARGA  | 110     | HV2                             | CHITGUPPA_110   | 15:06   | 15:26     | 0:20     | TRANSFORMER FAULT   |
| 595    | 18-May-19 | GULBARGA  | 110     | LV2                             | HALBURGA_220    | 21:55   | 22:08     | 0:13     | TRANSFORMER FAULT   |

| Sl.No. | DATE      | Tr_ZONE  | Voltage | Line                 | Station_Name       | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|----------|---------|----------------------|--------------------|---------|-----------|----------|---------------------|
| 596    | 18-May-19 | GULBARGA | 110     | HALBURGA-CHIDRI-2    | HALBURGA_220       | 21:55   | 22:25     | 0:30     | LINE FAULT          |
| 597    | 18-May-19 | GULBARGA | 110     | HANUMASAGAR-KUSTAGI  | KUSTAGI_220        | 9:55    | 17:15     | 7:20     | MAIN SUPPLY FAILURE |
| 598    | 18-May-19 | GULBARGA | 110     | HV3                  | KUSTAGI_220        | 9:50    | 15:29     | 5:39     | LINE CLEAR AVOIDED  |
| 599    | 18-May-19 | GULBARGA | 110     | HV2                  | KUSTAGI_220        | 9:50    | 15:50     | 6:00     | LINE CLEAR AVOIDED  |
| 600    | 18-May-19 | GULBARGA | 110     | KUSTAGI-KANAKAGIRI   | KUSTAGI_220        | 16:07   | 16:20     | 0:13     | LINE FAULT          |
| 601    | 18-May-19 | GULBARGA | 110     | MASKI-SINDHANOR      | MASKI_110          | 22:35   | 22:49     | 0:14     | MAIN SUPPLY FAILURE |
| 602    | 18-May-19 | GULBARGA | 110     | KEMBHAVI-SHAHAPUR    | KEMBHAVI_110       | 10:40   | 10:45     | 0:05     | LINE FAULT          |
| 603    | 18-May-19 | GULBARGA | 66      | ITTAGI-TAMBRAHALLI   | TAMBRAHALLI_66     | 12:15   | 12:25     | 0:10     | MAIN SUPPLY FAILURE |
| 604    | 18-May-19 | GULBARGA | 66      | HV1 HV2              | TAMBRAHALLI_66     | 12:15   | 12:30     | 0:15     | LINE CLEAR AVOIDED  |
| 605    | 18-May-19 | GULBARGA | 66      | ITTAGI-TAMBRAHALLI   | TAMBRAHALLI_66     | 13:45   | 14:05     | 0:20     | MAIN SUPPLY FAILURE |
| 606    | 18-May-19 | HASSAN   | 220     | ARSK2-HSN            | ARASIKERE_220      | 16:10   | 19:07     | 2:57     | LINE CLEAR AVOIDED  |
| 607    | 18-May-19 | HASSAN   | 220     | MRSSHM-ANTRSNH       | MRSMSG_220         | 10:10   | 14:53     | 4:43     | LINE CLEAR AVOIDED  |
| 608    | 18-May-19 | HASSAN   | 220     | MRSSHM-SHARAVATHY1   | MRSMSG_220         | 8:02    | 23:59     | 15:57    | NFBC ISSUED         |
| 609    | 18-May-19 | HASSAN   | 220     | MRSSHM-SHARAVATHY3   | MRSMSG_220         | 13:05   | 13:33     | 0:28     | LINE FAULT          |
| 610    | 18-May-19 | HASSAN   | 220     | SHRAVTY-SHIMOGA1     | sharavathy_gen     | 8:01    | 14:59     | 6:58     | LINE CLEAR AVOIDED  |
| 611    | 18-May-19 | HASSAN   | 220     | SHRAVTY-SHIMOGA2     | sharavathy_gen     | 13:04   | 13:40     | 0:36     | LINE FAULT          |
| 612    | 18-May-19 | HASSAN   | 220     | SHRAVTY-SIRISI 1     | sharavathy_gen     | 12:55   | 14:59     | 2:04     | LINE FAULT          |
| 613    | 18-May-19 | HASSAN   | 220     | SHRAVTY-SIRISI 2     | sharavathy_gen     | 12:55   | 14:59     | 2:04     | LINE CLEAR AVOIDED  |
| 614    | 18-May-19 | HASSAN   | 220     | HV1                  | SHIRALKOPPA_220    | 14:01   | 14:06     | 0:05     | HAND TRIPPED        |
| 615    | 18-May-19 | HASSAN   | 66      | HNPR2-HASS2          | HOLENARASIPURA_220 | 20:54   | 21:54     | 1:00     | LINE FAULT          |
| 616    | 18-May-19 | HASSAN   | 66      | SHRAVTY-MRSSHM-HOLUR | MRSMSG_220         | 13:06   | 13:25     | 0:19     | LINE FAULT          |
| 617    | 18-May-19 | HASSAN   | 66      | HASSN22-MALLALI      | HASSAN_220         | 20:38   | 20:51     | 0:13     | LINE FAULT          |
| 618    | 18-May-19 | HASSAN   | 66      | ARAKAL-MALLIPATNA    | ARAKALGUD_66       | 14:00   | 14:50     | 0:50     | LINE CLEAR AVOIDED  |
| 619    | 18-May-19 | HASSAN   | 66      | HV1                  | CHIKMAGALUR_66     | 21:03   | 21:13     | 0:10     | TRANSFORMER FAULT   |
| 620    | 18-May-19 | HASSAN   | 66      | GORUR-ARAKALGUD      | GORUR_66           | 11:08   | 13:53     | 2:45     | LINE CLEAR AVOIDED  |
| 621    | 18-May-19 | HASSAN   | 66      | HV1                  | HARIHARAPURA_66    | 11:34   | 12:08     | 0:34     | LINE CLEAR AVOIDED  |
| 622    | 18-May-19 | HASSAN   | 66      | SAKALE-IPCL1         | SAKLESHUPURA_66    | 7:25    | 18:50     | 11:25    | LINE CLEAR AVOIDED  |
| 623    | 18-May-19 | HASSAN   | 66      | SAKALE-IPCL2         | SAKLESHUPURA_66    | 7:25    | 18:50     | 11:25    | LINE CLEAR AVOIDED  |
| 624    | 18-May-19 | HASSAN   | 66      | HV1                  | SALAGAME_66        | 12:10   | 13:55     | 1:45     | LINE CLEAR AVOIDED  |
| 625    | 18-May-19 | HASSAN   | 66      | HV2                  | SALAGAME_66        | 11:30   | 13:10     | 1:40     | LINE CLEAR AVOIDED  |
| 626    | 18-May-19 | HASSAN   | 66      | CHANNAR-MALLALI      | CHANNARAYAPATNA_66 | 20:21   | 20:46     | 0:25     | LINE FAULT          |
| 627    | 18-May-19 | HASSAN   | 110     | HV2                  | PUTTUR_110         | 9:55    | 11:57     | 2:02     | LINE CLEAR AVOIDED  |
| 628    | 18-May-19 | HASSAN   | 110     | BANTWA-SALATTUR      | BANTWAL_110        | 9:59    | 13:56     | 3:57     | LINE CLEAR AVOIDED  |
| 629    | 18-May-19 | HASSAN   | 110     | JOG-NK1              | mghejog_gen        | 12:58   | 13:24     | 0:26     | LINE FAULT          |
| 630    | 18-May-19 | HASSAN   | 110     | JOG-NK2              | mghejog_gen        | 12:58   | 13:24     | 0:26     | LINE FAULT          |
| 631    | 18-May-19 | HASSAN   | 110     | KAVOOR-BAIKAMPADY    | KAVOOR_220         | 1:30    | 1:40      | 0:10     | LINE FAULT          |
| 632    | 18-May-19 | HASSAN   | 110     | KAVOOR-MCFLine       | KAVOOR_220         | 1:37    | 4:11      | 2:34     | LINE CLEAR AVOIDED  |
| 633    | 18-May-19 | HASSAN   | 110     | KAVOOR-MCFLine       | KAVOOR_220         | 4:29    | 5:55      | 1:26     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE  | Voltage | Line                                  | Station_Name  | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|----------|---------|---------------------------------------|---|---------|-----------|----------|--------------------|
| 634    | 18-May-19 | HASSAN   | 110     | MOODAB-GURUPURA                       | MOODABIDRE_110  | 10:29   | 12:02     | 1:33     | LINE CLEAR AVAILED |
| 635    | 18-May-19 | HASSAN   | 110     | LV1                                   | SHIRALKOPPA_220   | 14:00   | 14:08     | 0:08     | HAND TRIPPED       |
| 636    | 18-May-19 | MYSORE   | 66      | HV1                                   | BILIKERE_66   | 14:15   | 16:00     | 1:44     | LINE CLEAR AVAILED |
| 637    | 18-May-19 | MYSORE   | 66      | HV2                                   | BILIKERE_66   | 11:24   | 23:59     | 12:34    | LINE CLEAR AVAILED |
| 638    | 18-May-19 | MYSORE   | 66      | HV1                                   | HONNALLY_MYS_66   | 11:23   | 11:48     | 0:24     | HAND TRIPPED       |
| 639    | 18-May-19 | MYSORE   | 66      | KUNTHUR-DR PETE                       | MUGUR_66 THAYURU_66<br>TNARASIPURA_66<br>SANTHEMARAHALLI_66   | 16:41   | 16:49     | 0:08     | LINE FAULT         |
| 640    | 18-May-19 | MYSORE   | 66      | KUSHALANAGARA 220-<br>BETTADAPURA     | BETTADHAPURA_66<br>CHUNCHUNKATTE_66 KITTUR_66<br>RAVANDUR_66  | 5:57    | 6:08      | 0:11     | LINE FAULT         |
| 641    | 18-May-19 | MYSORE   | 66      | HV5                                   | SFCSHIVA_66   | 13:42   | 19:10     | 5:27     | LINE CLEAR AVAILED |
| 642    | 18-May-19 | MYSORE   | 66      | TUBINAKERE-NAGAMANGALA 2              | ADDIHALLI_66<br>HARADANAHALLI(JAK)_66<br>BGNAGARA_66<br>ADICHUNCHANAGIRI_66<br>VADERALLI_66 BASARALU_66<br>SHIVALLY_66 KESLAGERE_66 | 15:52   | 15:58     | 0:05     | LINE FAULT         |
| 643    | 18-May-19 | TUMKUR   | 220     | ANTHRASANAHALLI 220kv-<br>NELAMANGALA | ANTHRASANAHALLI_220   | 14:14   | 14:30     | 0:15     | LINE FAULT         |
| 644    | 18-May-19 | TUMKUR   | 220     | GUTUR_400-NEELAGUNDA                  | NEELAGUNDA_220  | 13:44   | 16:41     | 2:57     | LINE FAULT         |
| 645    | 18-May-19 | TUMKUR   | 220     | NEELAGUNDA- GUTTUR                    | NEELAGUNDA_220  | 13:44   | 16:48     | 3:03     | LINE FAULT         |
| 646    | 18-May-19 | TUMKUR   | 220     | NITTUR 220kv- (HASAN) ARASIKERE       | NITTUR_220  | 16:10   | 19:07     | 2:56     | LINE FAULT         |
| 647    | 18-May-19 | TUMKUR   | 110     | DODDAGUNI- SAMPIGE                    | SAMPIGE_110   | 12:17   | 12:21     | 0:04     | HAND TRIPPED       |
| 648    | 18-May-19 | TUMKUR   | 110     | TR-1                                  | GUBBI_110   | 6:15    | 6:30      | 0:15     | TRANSFORMER FAULT  |
| 649    | 18-May-19 | TUMKUR   | 66      | ANTHRASANAHALLI 220KV- CHELUR         | CHELURU_66, HOSAKERE_66,<br>ANKASANDRA_66   | 14:14   | 14:30     | 0:15     | LINE FAULT         |
| 650    | 18-May-19 | TUMKUR   | 66      | TR-1                                  | BHAKTHARAHALLI_66   | 11:19   | 12:02     | 0:43     | LINE CLEAR AVAILED |
| 651    | 18-May-19 | TUMKUR   | 66      | TR-2                                  | CHITRADURGA_220   | 17:19   | 17:22     | 0:03     | HAND TRIPPED       |
| 652    | 18-May-19 | TUMKUR   | 66      | TR-2                                  | HALURAMESHWARA_66   | 15:02   | 15:41     | 0:38     | LINE CLEAR AVAILED |
| 653    | 18-May-19 | TUMKUR   | 66      | TR-2                                  | PATTANAYAKANAHALLI_66   | 8:40    | 9:21      | 0:41     | LINE CLEAR AVAILED |
| 654    | 18-May-19 | TUMKUR   | 66      | TR-2                                  | THIMMASANDRA_66   | 13:24   | 14:08     | 0:44     | LINE CLEAR AVAILED |
| 655    | 18-May-19 | TUMKUR   | 66      | TURUVANUR66-CHITRADURGA               | TURUVANUR_66  | 18:08   | 18:21     | 0:12     | LINE FAULT         |
| 656    | 19-May-19 | BAGALKOT | 220     | BAGEWADI-ATRIA 1                      | BAGEWADI_220  | 13:58   | 14:37     | 0:39     | LINE FAULT         |
| 657    | 19-May-19 | BAGALKOT | 110     | BAGEWADI220-NIDAGUNDI                 | NIDAGUNDI_110   | 13:25   | 14:01     | 0:36     | HAND TRIPPED       |
| 658    | 19-May-19 | BAGALKOT | 220     | BELGAUM-NARENDRA 1                    | BELGAUM_220   | 8:34    | 18:55     | 10:21    | LINE CLEAR AVAILED |
| 659    | 19-May-19 | BAGALKOT | 110     | GHATAPRABHA-HIDIKAL DAM               | HIDIKAL DAM_110   | 13:24   | 19:45     | 6:21     | NFBC ISSUED        |



| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                | Station_Name                          | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|-------------------------------------|---------------------------------------|---------|-----------|----------|---------------------|
| 660    | 19-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                        | ITANAL_110                            | 19:20   | 19:25     | 0:05     | TRANSFORMER FAULT   |
| 661    | 19-May-19 | BAGALKOT  | 110     | 110/11KV,HV2                        | KALAGHATGI_110                        | 1:30    | 5:22      | 3:52     | LINE CLEAR AVAILED  |
| 662    | 19-May-19 | BAGALKOT  | 110     | KALAGHATGI-HUBLI KAVALAWAD-         | KALAGHATGI_110                        | 3:34    | 4:00      | 0:26     | HAND TRIPPED        |
| 663    | 19-May-19 | BAGALKOT  | 110     | BELGAUM-VADAGOAN                    | VADAGON_110                           | 9:26    | 23:59     | 14:33    | LINE CLEAR AVAILED  |
| 664    | 19-May-19 | BAGALKOT  | 110     | RANNABELAGALI-UTTUR                 | UTTUR_110                             | 13:36   | 18:20     | 4:44     | LINE CLEAR AVAILED  |
| 665    | 19-May-19 | BAGALKOT  | 110     | 110/11KV,HV2                        | SHIROL_110                            | 6:31    | 7:56      | 1:25     | TRANSFORMER FAULT   |
| 666    | 19-May-19 | BAGALKOT  | 110     | MAHALINGAPUR-RANNABELAGALI          | RANNABELAGALI                         | 1:16    | 13:32     | 12:16    | MAIN SUPPLY FAILURE |
| 667    | 19-May-19 | BAGALKOT  | 110     | 110/11KV,HV2                        | NIPPANI_110                           | 11:15   | 17:36     | 6:21     | LINE CLEAR AVAILED  |
| 668    | 19-May-19 | BAGALKOT  | 110     | 110/33KV,HV3                        | NIPPANI_110,BENADI_33KV,KADAL KT_33KV | 15:00   | 17:50     | 2:50     | LINE CLEAR AVAILED  |
| 669    | 19-May-19 | BAGALKOT  | 220     | SHARAVATHI1-SIRSI220                | SIRSI_220                             | 2:25    | 13:40     | 11:15    | LINE FAULT          |
| 670    | 19-May-19 | BAGALKOT  | 220     | NARENDRA-KANABARGI1                 | NARENDRA_220                          | 8:34    | 18:55     | 10:21    | NFBC ISSUED         |
| 671    | 19-May-19 | BAGALKOT  | 110     | MACHE-ASHOK IRON PLANT              | MACHE_110                             | 16:08   | 18:47     | 2:39     | LINE CLEAR AVAILED  |
| 672    | 19-May-19 | BAGALKOT  | 110     | BELLATTI-LAXMESHVAR                 | LAXMESHVAR_110                        | 11:11   | 18:00     | 6:49     | LINE CLEAR AVAILED  |
| 673    | 19-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                        | MORATAGI_110                          | 13:22   | 13:26     | 0:04     | TRANSFORMER FAULT   |
| 674    | 19-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                        | MORATAGI_110                          | 13:32   | 13:34     | 0:02     | TRANSFORMER FAULT   |
| 675    | 19-May-19 | BAGALKOT  | 110     | 110/11KV,HV1                        | MORATAGI_110                          | 15:26   | 15:29     | 0:03     | TRANSFORMER FAULT   |
| 676    | 19-May-19 | BAGALKOT  | 110     | AMBEWADI-KIRUVATTI                  | KIRUVATTI_110                         | 9:13    | 23:59     | 14:46    | LINE CLEAR AVAILED  |
| 677    | 19-May-19 | BENGALURU | 66      | HV1                                 | HEJJALA                               | 14:05   | 16:15     | 2:10     | LINE CLEAR AVAILED  |
| 678    | 19-May-19 | BENGALURU | 66      | RMV - HEBBAL 220                    | RMV, TATA INSTITUTE (EHT)             | 12:58   | 13:02     | 0:04     | LOAD CHANGEOR       |
| 679    | 19-May-19 | BENGALURU | 66      | MATHIKERE - HEBBAL 220              | MATHIKERE                             | 16:00   | 16:05     | 0:05     | LOAD CHANGEOR       |
| 680    | 19-May-19 | BENGALURU | 66      | HV2                                 | SRS PEENYA 220                        | 6:07    | 6:11      | 0:03     | LOAD CHANGEOR       |
| 681    | 19-May-19 | BENGALURU | 66      | HV2                                 | SRS PEENYA 220                        | 16:07   | 16:10     | 0:02     | LOAD CHANGEOR       |
| 682    | 19-May-19 | BENGALURU | 66      | HV2                                 | NRS 220                               | 16:13   | 16:15     | 0:01     | LOAD CHANGEOR       |
| 683    | 19-May-19 | BENGALURU | 66      | HV1                                 | BRINDAVANA                            | 8:05    | 8:43      | 0:38     | LINE CLEAR AVAILED  |
| 684    | 19-May-19 | BENGALURU | 66      | MAHALAKSHMI LAYOUT - SRS PEENYA 220 | MAHALAKSHMI LAYOUT                    | 16:07   | 16:14     | 0:07     | LOAD CHANGEOR       |
| 685    | 19-May-19 | BENGALURU | 66      | BANASHANKARI - VRISHBHAVATHI 220    | BANASHANKARI                          | 10:16   | 10:20     | 0:03     | LOAD CHANGEOR       |
| 686    | 19-May-19 | BENGALURU | 66      | BANASHANKARI - AREHALLI             | BANASHANKARI                          | 14:16   | 14:19     | 0:03     | LOAD CHANGEOR       |
| 687    | 19-May-19 | BENGALURU | 66      | ABBIGERE - SRS PEENYA 220           | ABBIGERE                              | 12:55   | 12:58     | 0:02     | LOAD CHANGEOR       |
| 688    | 19-May-19 | BENGALURU | 66      | ABBIGERE - DG 3                     | ABBIGERE                              | 15:26   | 15:29     | 0:02     | LOAD CHANGEOR       |
| 689    | 19-May-19 | BENGALURU | 66      | PLATINUM CITY - DG 4                | PLATINUM CITY                         | 13:05   | 13:10     | 0:05     | LOAD CHANGEOR       |
| 690    | 19-May-19 | BENGALURU | 66      | NANDINI LAYOUT - NRS 220            | NANDINI LAYOUT                        | 15:55   | 16:01     | 0:06     | LOAD CHANGEOR       |
| 691    | 19-May-19 | BENGALURU | 400     | HV3                                 | NELAMANGALA 400                       | 16:11   | 17:04     | 0:53     | TRANSFORMER FAULT   |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                                     | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|--|--|---------|-----------|----------|---------------------|
| 692    | 19-May-19 | BENGALURU | 220     | NELAMANGALA 400 - ANCHEPALYA 1           | ANCHEPALYA 220   | 16:33   | 17:38     | 1:04     | LINE FAULT          |
| 693    | 19-May-19 | BENGALURU | 220     | NELAMANGALA 400 - MAGADI 220             | MAGADI 220   | 16:11   | 17:34     | 1:22     | LINE FAULT          |
| 694    | 19-May-19 | BENGALURU | 220     | NELAMANGALA 400 - DB PURA 1              | DB PURA 220  | 16:11   | 23:59     | 7:47     | LINE FAULT          |
| 695    | 19-May-19 | BENGALURU | 220     | NELAMANGALA 400 - DB PURA 2              | DB PURA 220  | 16:11   | 16:37     | 0:25     | LINE FAULT          |
| 696    | 19-May-19 | BENGALURU | 220     | NELAMANGALA 400 - DABUSPET 220           | DABUSPET 220   | 17:04   | 17:09     | 0:05     | LINE CLEAR AVAILED  |
| 697    | 19-May-19 | BENGALURU | 220     | MALUR 220 - SARJAPURA 220                | VIKAS TECH PARK 220  | 11:12   | 11:30     | 0:18     | LINE CLEAR AVAILED  |
| 698    | 19-May-19 | BENGALURU | 66      | VIKAS TECH PARK 220 - GTP                | VIKAS TECH PARK 220  | 17:15   | 17:18     | 0:03     | LOAD CHANGEOVER     |
| 699    | 19-May-19 | BENGALURU | 220     | SARJAPURA 220 - MALUR 220                | SARJAPURA 220  | 11:12   | 11:26     | 0:14     | LOAD CHANGEOVER     |
| 700    | 19-May-19 | BENGALURU | 66      | HV2                                      | SARJAPURA 220  | 11:12   | 11:29     | 0:17     | LOAD CHANGEOVER     |
| 701    | 19-May-19 | BENGALURU | 66      | SARJAPURA 220 - DOMMASANDRA              | DOMMASANDRA  | 11:12   | 11:30     | 0:18     | LOAD CHANGEOVER     |
| 702    | 19-May-19 | BENGALURU | 66      | HV2                                      | SARJAPURA 220  | 17:10   | 17:14     | 0:04     | LOAD CHANGEOVER     |
| 703    | 19-May-19 | BENGALURU | 66      | SARJAPURA 220 - DOMMASANDRA              | DOMMASANDRA  | 17:10   | 17:23     | 0:13     | LOAD CHANGEOVER     |
| 704    | 19-May-19 | BENGALURU | 66      | HV1                                      | SARJAPURA 220  | 17:10   | 17:13     | 0:03     | LOAD CHANGEOVER     |
| 705    | 19-May-19 | BENGALURU | 66      | WELCAST - ABBIGERE                       | WELCAST  | 12:58   | 13:02     | 0:04     | LOAD CHANGEOVER     |
| 706    | 19-May-19 | BENGALURU | 66      | ATTUR YELAHANKA - DG 3                   | ATTUR YELAHANKA  | 13:10   | 15:24     | 2:14     | LINE CLEAR AVAILED  |
| 707    | 19-May-19 | BENGALURU | 66      | SAHAKARINAGAR - ATTUR YELAHANKA          | SAHAKARINAGAR  | 13:10   | 15:22     | 2:12     | LINE CLEAR AVAILED  |
| 708    | 19-May-19 | BENGALURU | 66      | YELAHANKA 220 - LINE 3                   | ESCORTS (EHT)  | 13:29   | 15:12     | 1:43     | LINE CLEAR AVAILED  |
| 709    | 19-May-19 | BENGALURU | 66      | YELAHANKA 220 - LINE 4                   | RAILWAYS (EHT)   | 13:29   | 15:13     | 1:43     | LINE CLEAR AVAILED  |
| 710    | 19-May-19 | BENGALURU | 66      | HV2                                      | MAASTHI  | 12:07   | 12:11     | 0:03     | TRANSFORMER FAULT   |
| 711    | 19-May-19 | BENGALURU | 220     | DB PURA 220 - NELAMANGALA 1              | DB PURA 220  | 16:11   | 23:59     | 7:47     | LINE FAULT          |
| 712    | 19-May-19 | BENGALURU | 220     | DB PURA 220 - NELAMANGALA 2              | DB PURA 220  | 16:11   | 16:37     | 0:25     | LINE FAULT          |
| 713    | 19-May-19 | BENGALURU | 220     | HV1                                      | DB PURA 220  | 16:11   | 16:39     | 0:27     | MAIN SUPPLY FAILURE |
| 714    | 19-May-19 | BENGALURU | 220     | HV2                                      | DB PURA 220  | 16:11   | 16:39     | 0:27     | MAIN SUPPLY FAILURE |
| 715    | 19-May-19 | BENGALURU | 66      | DB PURA 220 - CHIKKABALLAPURA I/ A 1 & 2 | TUBUGERE, CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI | 16:11   | 16:41     | 0:29     | MAIN SUPPLY FAILURE |
| 716    | 19-May-19 | BENGALURU | 66      | DB PURA 220 - D CROSS                    | D CROSS  | 16:11   | 16:41     | 0:29     | MAIN SUPPLY FAILURE |
| 717    | 19-May-19 | BENGALURU | 66      | DB PURA 220 - DEVANAHALLI 1 & 2          | KUNDANA, DEVANAHALLI   | 16:11   | 16:41     | 0:29     | MAIN SUPPLY FAILURE |
| 718    | 19-May-19 | BENGALURU | 66      | DB PURA 220 - DG 1                       | AIR (EHT)  | 16:11   | 16:41     | 0:29     | MAIN SUPPLY FAILURE |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                            | Station_Name                 | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|---------------------------------|------------------------------|---------|-----------|----------|---------------------|
| 719    | 19-May-19 | BENGALURU | 66      | DB PURA 220 - DG 2              | DODDABELAVANGALA, GUNDAMGERE | 16:11   | 16:41     | 0:29     | MAIN SUPPLY FAILURE |
| 720    | 19-May-19 | BENGALURU | 66      | DABUSPET 220 - NELAMANGALA 66   | NELAMANGALA 66               | 2:10    | 2:39      | 0:29     | LINE FAULT          |
| 721    | 19-May-19 | BENGALURU | 66      | DABUSPET 220 - NELAMANGALA 66   | NELAMANGALA 66               | 12:05   | 12:29     | 0:24     | LINE CLEAR AVAILED  |
| 722    | 19-May-19 | BENGALURU | 66      | DABUSPET 220 - TYAMAGONDLU      | TYAMAGONDLU, T BEGUR         | 12:24   | 12:32     | 0:07     | LINE CLEAR AVAILED  |
| 723    | 19-May-19 | BENGALURU | 66      | CHINTAMANI 220 - IRGAMPALLI     | IRAGAMPALLI, M GOLLAHALLI    | 18:25   | 18:56     | 0:30     | LINE CLEAR AVAILED  |
| 724    | 19-May-19 | BENGALURU | 66      | CHANDAPURA - SARJAPURA 220      | CHANDAPURA                   | 11:12   | 11:23     | 0:11     | LOAD CHANGEOR       |
| 725    | 19-May-19 | BENGALURU | 66      | CHANDAPURA - YARANDANAHALLI 220 | CHANDAPURA                   | 17:17   | 17:22     | 0:05     | LOAD CHANGEOR       |
| 726    | 19-May-19 | BENGALURU | 66      | ATTIBELE - SARAJAPURA 220       | ATTIBELE                     | 11:12   | 11:25     | 0:13     | LOAD CHANGEOR       |
| 727    | 19-May-19 | BENGALURU | 66      | ATTIBELE - ANEKAL               | ATTIBELE                     | 17:30   | 17:35     | 0:05     | LOAD CHANGEOR       |
| 728    | 19-May-19 | BENGALURU | 66      | NELAMANGALA 66 - SRS PEENYA 220 | NELAMANAGALA 66              | 13:16   | 17:15     | 3:59     | LOAD CHANGEOR       |
| 729    | 19-May-19 | BENGALURU | 66      | NELAMANGALA 66 - DABUSPET 220   | NELAMANGALA 66               | 16:42   | 16:43     | 0:01     | LOAD CHANGEOR       |
| 730    | 19-May-19 | BENGALURU | 66      | NELAMANGALA 66 - DABUSPET 220   | NELAMANGALA 66               | 16:45   | 17:03     | 0:18     | LOAD CHANGEOR       |
| 731    | 19-May-19 | BENGALURU | 66      | NELAMANGALA 66 - DABUSPET 220   | NELAMANGALA 66               | 19:11   | 19:14     | 0:03     | LOAD CHANGEOR       |
| 732    | 19-May-19 | GULBARGA  | 220     | SEDAM-CLNMAX_IPP                | SEDAM_220                    | 22:38   | 23:59     | 1:21     | LINE CLEAR AVAILED  |
| 733    | 19-May-19 | GULBARGA  | 110     | HV2                             | BHALKI_110                   | 15:25   | 16:10     | 0:45     | LINE CLEAR AVAILED  |
| 734    | 19-May-19 | GULBARGA  | 110     | HV1                             | HANUMASAGAR_110              | 22:42   | 22:45     | 0:03     | TRANSFORMER FAULT   |
| 735    | 19-May-19 | GULBARGA  | 110     | HV2                             | HATTI_110                    | 9:38    | 9:43      | 0:05     | TRANSFORMER FAULT   |
| 736    | 19-May-19 | GULBARGA  | 110     | HV2                             | HATTI_110                    | 14:50   | 14:55     | 0:05     | TRANSFORMER FAULT   |
| 737    | 19-May-19 | GULBARGA  | 110     | HV2                             | HATTI_110                    | 17:10   | 17:15     | 0:05     | TRANSFORMER FAULT   |
| 738    | 19-May-19 | GULBARGA  | 110     | SHAHAPUR-KEMBHAVI               | KEMBAHVI_110                 | 20:35   | 20:45     | 0:10     | LINE FAULT          |
| 739    | 19-May-19 | GULBARGA  | 110     | MASKI-SINDHANOOR                | SINDHANOOR_110               | 7:40    | 7:50      | 0:10     | LINE CLEAR AVAILED  |
| 740    | 19-May-19 | GULBARGA  | 110     | MASKI-SINDHANOOR                | SINDHANOOR_110               | 17:15   | 17:20     | 0:05     | LINE FAULT          |
| 741    | 19-May-19 | GULBARGA  | 110     | MASKI-HATTI                     | HATTI_110                    | 17:15   | 18:54     | 1:39     | LINE FAULT          |
| 742    | 19-May-19 | HASSAN    | 220     | KADUR-DABUSET                   | KADUR_220                    | 16:54   | 18:12     | 1:18     | MAIN SUPPLY FAILURE |
| 743    | 19-May-19 | HASSAN    | 220     | KADUR-SHIMOGA                   | KADUR_220                    | 16:54   | 17:07     | 0:13     | MAIN SUPPLY FAILURE |
| 744    | 19-May-19 | HASSAN    | 220     | MRSSHM-KADUR                    | MRSMSG_220                   | 16:54   | 17:11     | 0:17     | LINE FAULT          |
| 745    | 19-May-19 | HASSAN    | 220     | SHRAVITY-SIRISI 1               | sharavathy_gen               | 2:24    | 13:49     | 11:25    | LINE FAULT          |
| 746    | 19-May-19 | HASSAN    | 220     | SHRAVITY-SIRISI 1               | sharavathy_gen               | 16:40   | 17:13     | 0:33     | LINE CLEAR AVAILED  |
| 747    | 19-May-19 | HASSAN    | 220     | SHRAVITY-TALAGUPPA 2            | sharavathy_gen               | 2:52    | 23:59     | 21:07    | LINE FAULT          |
| 748    | 19-May-19 | HASSAN    | 220     | SHRAVITY-TALAGUPPA1             | sharavathy_gen               | 2:52    | 23:59     | 21:07    | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE | Voltage | Line                       | Station_Name                                | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|---------|---------|----------------------------|---|---------|-----------|----------|---------------------|
| 749    | 19-May-19 | HASSAN  | 220     | TALAGU-SGS1                | TALAGUPPA_400                               | 2:52    | 18:26     | 15:34    | LINE FAULT          |
| 750    | 19-May-19 | HASSAN  | 220     | TALAGU-SGS2                | TALAGUPPA_400                               | 2:53    | 23:59     | 21:06    | LINE FAULT          |
| 751    | 19-May-19 | HASSAN  | 220     | HV1                        | KEMAR_220                                   | 22:27   | 22:54     | 0:27     | TRANSFORMER FAULT   |
| 752    | 19-May-19 | HASSAN  | 220     | HV1                        | KEMAR_220                                   | 23:12   | 23:30     | 0:18     | TRANSFORMER FAULT   |
| 753    | 19-May-19 | HASSAN  | 110     | KADUR-AJAMPURA             | KADUR_220                                   | 17:03   | 17:21     | 0:18     | HAND TRIPPED        |
| 754    | 19-May-19 | HASSAN  | 110     | HV1                        | KADUR_220                                   | 17:00   | 17:10     | 0:10     | HAND TRIPPED        |
| 755    | 19-May-19 | HASSAN  | 110     | HV2                        | KADUR_220                                   | 17:00   | 17:10     | 0:10     | HAND TRIPPED        |
| 756    | 19-May-19 | HASSAN  | 110     | KADUR-NERELEKERE           | KADUR_220                                   | 17:03   | 17:12     | 0:09     | HAND TRIPPED        |
| 757    | 19-May-19 | HASSAN  | 110     | KADUR-NGNHL                | KADUR_220                                   | 17:03   | 17:21     | 0:18     | HAND TRIPPED        |
| 758    | 19-May-19 | HASSAN  | 110     | KADUR-TNGL                 | KADUR_220                                   | 17:00   | 17:12     | 0:12     | HAND TRIPPED        |
| 759    | 19-May-19 | HASSAN  | 110     | KADUR-YGTI                 | KADUR_220                                   | 17:03   | 17:14     | 0:11     | HAND TRIPPED        |
| 760    | 19-May-19 | HASSAN  | 110     | KEMAR-Guruvykere1          | KEMAR_220                                   | 22:27   | 23:59     | 1:32     | LINE FAULT          |
| 761    | 19-May-19 | HASSAN  | 110     | KEMAR-Guruvykere2          | KEMAR_220                                   | 22:27   | 23:22     | 0:55     | LINE FAULT          |
| 762    | 19-May-19 | HASSAN  | 110     | LV1                        | KEMAR_220                                   | 22:27   | 22:54     | 0:27     | TRANSFORMER FAULT   |
| 763    | 19-May-19 | HASSAN  | 110     | LV1                        | KEMAR_220                                   | 23:12   | 23:31     | 0:19     | TRANSFORMER FAULT   |
| 764    | 19-May-19 | HASSAN  | 110     | HV1                        | BAIKAMPADY_110                              | 10:02   | 12:47     | 2:45     | MAIN SUPPLY FAILURE |
| 765    | 19-May-19 | HASSAN  | 110     | HV2                        | BAIKAMPADY_110                              | 12:37   | 12:48     | 0:11     | MAIN SUPPLY FAILURE |
| 766    | 19-May-19 | HASSAN  | 110     | HV3                        | BAIKAMPADY_110                              | 10:01   | 12:49     | 2:48     | MAIN SUPPLY FAILURE |
| 767    | 19-May-19 | HASSAN  | 110     | HV4                        | BAIKAMPADY_110                              | 10:01   | 12:51     | 2:50     | MAIN SUPPLY FAILURE |
| 768    | 19-May-19 | HASSAN  | 110     | GURUVA-KEMAR1              | GURUVAYANAKERE_110                          | 22:30   | 23:59     | 1:29     | MAIN SUPPLY FAILURE |
| 769    | 19-May-19 | HASSAN  | 110     | GURUVA-KEMAR2              | GURUVAYANAKERE_110                          | 22:30   | 23:22     | 0:52     | MAIN SUPPLY FAILURE |
| 770    | 19-May-19 | HASSAN  | 110     | KAVOOR-MCFLine             | KAVOOR_220                                  | 10:01   | 12:44     | 2:43     | LINE CLEAR AVAILED  |
| 771    | 19-May-19 | HASSAN  | 66      | ARAKAL-MALLIPATNA          | ARAKALGUD_66                                | 15:31   | 15:56     | 0:25     | LINE FAULT          |
| 772    | 19-May-19 | HASSAN  | 66      | BHADRA-LINGADAHALLI        | bhadra_gen                                  | 9:52    | 9:59      | 0:07     | LINE FAULT          |
| 773    | 19-May-19 | HASSAN  | 66      | BHADRA-LINGADAHALLI        | bhadra_gen                                  | 16:52   | 16:57     | 0:05     | LINE FAULT          |
| 774    | 19-May-19 | HASSAN  | 66      | CHIKMA-L1-ALDUR            | CHIKMAGALUR_66                              | 23:57   | 23:59     | 0:02     | LINE FAULT          |
| 775    | 19-May-19 | MYSORE  | 66      | HV2                        | BOOKANAKERE_66                              | 9:12    | 9:24      | 0:11     | TRANSFORMER FAULT   |
| 776    | 19-May-19 | MYSORE  | 66      | HV2                        | BOOKANAKERE_66                              | 10:18   | 10:25     | 0:07     | TRANSFORMER FAULT   |
| 777    | 19-May-19 | MYSORE  | 66      | HV2                        | KIRUGAVALU_66                               | 3:10    | 3:19      | 0:08     | TRANSFORMER FAULT   |
| 778    | 19-May-19 | MYSORE  | 66      | HV2                        | SANTHEMARAHALLI_66                          | 10:22   | 19:16     | 8:53     | LINE CLEAR AVAILED  |
| 779    | 19-May-19 | MYSORE  | 66      | HV1                        | SANTHEMARAHALLI_66                          | 10:20   | 19:10     | 8:50     | LINE CLEAR AVAILED  |
| 780    | 19-May-19 | MYSORE  | 66      | HV5                        | SFCSHIVA_66                                 | 14:13   | 23:59     | 9:45     | LINE CLEAR AVAILED  |
| 781    | 19-May-19 | MYSORE  | 66      | VAJAMANGALA-KADAKOLA 1     | AYRALLI_66 MARADIHUNDI_66                   | 5:37    | 5:48      | 0:11     | LINE FAULT          |
| 782    | 19-May-19 | TUMKUR  | 220     | DAVANGERE SRS- HONNALI     | HONNALLI_220                                | 9:38    | 10:29     | 0:51     | LINE FAULT          |
| 783    | 19-May-19 | TUMKUR  | 220     | NITTUR 220kV- NELAMANGALA  | NITTUR_220                                  | 16:11   | 17:17     | 1:05     | LINE FAULT          |
| 784    | 19-May-19 | TUMKUR  | 220     | THALLAK 220-HIRIYUR        | HIRIYUR_220                                 | 18:19   | 18:58     | 0:39     | LINE FAULT          |
| 785    | 19-May-19 | TUMKUR  | 66      | CHITRADURGA 220kV- HIRIYUR | IMANGALA_66,<br>ENERCON1_IPP_66, HIRIYUR_66 | 18:41   | 19:32     | 0:50     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE  | Voltage | Line                                   | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|----------|---------|--|--|---------|-----------|----------|---------------------|
| 786    | 19-May-19 | TUMKUR   | 66      | CHITRADURGA 220kV- HIRIYUR             | IMANGALA_66,<br>ENERCON1_IPP_66, HIRIYUR_66          | 20:51   | 22:13     | 1:21     | LINE CLEAR AVAILED  |
| 787    | 19-May-19 | TUMKUR   | 66      | CHITRADURGA 220kV-<br>PANDARAHALLI 2   | HIREGUNTANUR_66, SIRIGERE_66,<br>BRAHMASAGARA_IPP_66 | 10:54   | 11:00     | 0:05     | LINE FAULT          |
| 788    | 19-May-19 | TUMKUR   | 66      | TR-2                                   | HALURAMESHWARA_66                                    | 10:03   | 16:44     | 6:40     | LINE CLEAR AVAILED  |
| 789    | 19-May-19 | TUMKUR   | 66      | HULIYURDURGA- ANCHEPALYA               | HULIYURDURGA_66                                      | 6:13    | 6:42      | 0:29     | LINE FAULT          |
| 790    | 19-May-19 | TUMKUR   | 66      | HULIYURDURGA- DUNDANAHALLI             | DUNDANAHALLI_66                                      | 6:13    | 7:03      | 0:50     | LINE FAULT          |
| 791    | 19-May-19 | TUMKUR   | 66      | KUKKAWADA-<br>LINGADAHALLI(CHANNAGIRI) | TYAVANAGI_66,<br>BASAVAPATNA_66,<br>SANTEBENNUR_66   | 9:37    | 9:43      | 0:06     | LINE FAULT          |
| 792    | 19-May-19 | TUMKUR   | 66      | TR-1                                   | SAVALANGA_66   | 9:38    | 10:38     | 0:59     | MAIN SUPPLY FAILURE |
| 793    | 20-May-19 | BAGALKOT | 110     | 110/33KV,HV2                           | ANKALAGI_110,KHANAGAVI_33,NE<br>SARGI_33             | 3:32    | 3:48      | 0:16     | TRANSFORMER FAULT   |
| 794    | 20-May-19 | BAGALKOT | 220     | ATHANI-MAHALINGAPUR                    | ATHANI_220   | 20:48   | 23:59     | 3:11     | LINE FAULT          |
| 795    | 20-May-19 | BAGALKOT | 220     | ALMATTI 2-BAGALKOT                     | BAGALKOT_220   | 12:04   | 14:15     | 2:11     | LINE CLEAR AVAILED  |
| 796    | 20-May-19 | BAGALKOT | 110     | 110/33KV,HV3                           | BAGALKOT_220,KATAGERI_33                             | 10:02   | 12:05     | 2:03     | LINE CLEAR AVAILED  |
| 797    | 20-May-19 | BAGALKOT | 110     | MAHALINGAPUR220-BANAHATTI              | BANAHATTI_110  | 22:25   | 23:59     | 1:34     | LINE CLEAR AVAILED  |
| 798    | 20-May-19 | BAGALKOT | 110     | 110/11KV,HV2                           | BHUTHNAL_110   | 16:41   | 19:14     | 2:33     | LINE CLEAR AVAILED  |
| 799    | 20-May-19 | BAGALKOT | 110     | MAHALINGAPUR220-<br>DHAVALESHWARA      | DHAVALESHWARA_110                                    | 21:46   | 23:59     | 2:13     | LINE CLEAR AVAILED  |
| 800    | 20-May-19 | BAGALKOT | 110     | RON1&2-GAJENDRAGAD                     | GAJENDRAGAD_110                                      | 21:17   | 21:40     | 0:23     | MAIN SUPPLY FAILURE |
| 801    | 20-May-19 | BAGALKOT | 110     | KUSTAGI-GAJENDRAGAD                    | GAJENDRAGAD_110                                      | 0:00    | 21:37     | 21:37    | LINE CLEAR AVAILED  |
| 802    | 20-May-19 | BAGALKOT | 110     | RON1&2-GAJENDRAGAD                     | GAJENDRAGAD_110                                      | 22:00   | 22:57     | 0:57     | LINE FAULT          |
| 803    | 20-May-19 | BAGALKOT | 110     | KUSTAGI-GAJENDRAGAD                    | GAJENDRAGAD_110                                      | 22:00   | 23:03     | 1:03     | LINE FAULT          |
| 804    | 20-May-19 | BAGALKOT | 110     | RON1&2-GAJENDRAGAD                     | GAJENDRAGAD_110                                      | 22:59   | 23:11     | 0:12     | LINE FAULT          |
| 805    | 20-May-19 | BAGALKOT | 110     | 110/11KV,HV4                           | GHATAPRABHA_110                                      | 5:23    | 5:27      | 0:04     | TRANSFORMER FAULT   |
| 806    | 20-May-19 | BAGALKOT | 110     | GADAG ROAD-GOPANAKOPPA                 | GOPANAKOPPA_110                                      | 22:05   | 23:59     | 1:54     | LINE FAULT          |
| 807    | 20-May-19 | BAGALKOT | 110     | MRUTHYUNJAY NAGAR-<br>GOPPANKOPPA      | GOPPANKOPPA_110                                      | 22:16   | 22:24     | 0:08     | LINE CLEAR AVAILED  |
| 808    | 20-May-19 | BAGALKOT | 110     | MAHALINGAPUR-HIDIKAL                   | HIDIKAL_110  | 23:43   | 23:59     | 0:16     | HAND TRIPPED        |
| 809    | 20-May-19 | BAGALKOT | 220     | HUBLI-NARENDRA2                        | HUBLI_220  | 22:34   | 23:59     | 1:25     | LINE FAULT          |
| 810    | 20-May-19 | BAGALKOT | 110     | MAHALINGPUR (NAVALAGI)-<br>JAMAKHANDI  | JAMAKHANDI_110                                       | 19:37   | 22:21     | 2:44     | MAIN SUPPLY FAILURE |
| 811    | 20-May-19 | BAGALKOT | 110     | AMBEWADI-KIRUVATTI                     | KIRUVATTI_110  | 0:00    | 12:52     | 12:52    | LINE CLEAR AVAILED  |
| 812    | 20-May-19 | BAGALKOT | 110     | AMBEWADI-KIRUVATTI                     | KIRUVATTI_110  | 16:07   | 23:59     | 7:52     | LINE CLEAR AVAILED  |
| 813    | 20-May-19 | BAGALKOT | 220     | KUDACHI -MAHALINGPUR                   | KUDACHI_220  | 20:48   | 23:59     | 3:11     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE  | Voltage | Line                        | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|----------|---------|-----------------------------|--|---------|-----------|----------|---------------------|
| 814    | 20-May-19 | BAGALKOT | 110     | 110/33KV,HV3                | MACHE_110,ASHOK IRON PLANT_33KV,KHANAPUR_33KV  | 12:36   | 14:08     | 1:32     | LINE CLEAR AVAILED  |
| 815    | 20-May-19 | BAGALKOT | 220     | MAHALINGAPUR-NARENDRA1      | MAHALINGAPUR_220   | 21:01   | 23:59     | 2:58     | LINE CLEAR AVAILED  |
| 816    | 20-May-19 | BAGALKOT | 220     | MAHALINGAPUR-VAJRAMATTI 1&2 | MAHALINGAPUR_220   | 21:01   | 23:59     | 2:58     | LINE CLEAR AVAILED  |
| 817    | 20-May-19 | BAGALKOT | 220     | MAHALINGAPUR-SOUDATTI       | MAHALINGAPUR_220   | 21:02   | 23:59     | 2:57     | LINE CLEAR AVAILED  |
| 818    | 20-May-19 | BAGALKOT | 220     | 220/110KV,HV2,LV2,LV3       | MAHALINGAPUR_220,TERADAL_110,RABAKAVI_110,BANAHATTI_110,RANNABELAGALI_110,DHAVALESHWAR_110,GSML1&2 | 21:02   | 23:59     | 2:57     | LINE CLEAR AVAILED  |
| 819    | 20-May-19 | BAGALKOT | 110     | BAGEWADI220-MUDEBIHAL       | MUDEBIHAL_110  | 15:31   | 15:56     | 0:25     | LINE CLEAR AVAILED  |
| 820    | 20-May-19 | BAGALKOT | 110     | 110/33KV,HV3                | MUNAVALLI_110  | 11:10   | 12:49     | 1:39     | LINE CLEAR AVAILED  |
| 821    | 20-May-19 | BAGALKOT | 110     | 110/11KV,HV2                | MUNAVALLI_110  | 19:32   | 19:41     | 0:09     | TRANSFORMER FAULT   |
| 822    | 20-May-19 | BAGALKOT | 110     | 110/11KV,HV1                | MUNDAGANUR_110   | 8:43    | 11:23     | 2:40     | LINE CLEAR AVAILED  |
| 823    | 20-May-19 | BAGALKOT | 110     | BETAGERI-NARAGAL            | NARAGAL_110  | 21:31   | 23:59     | 2:28     | MAIN SUPPLY FAILURE |
| 824    | 20-May-19 | BAGALKOT | 110     | 110/11KV,HV1                | NAREGAL_110  | 20:39   | 21:51     | 1:12     | TRANSFORMER FAULT   |
| 825    | 20-May-19 | BAGALKOT | 110     | BETAGERI-NAREGAL            | NAREGAL_110  | 21:52   | 23:59     | 2:07     | LINE FAULT          |
| 826    | 20-May-19 | BAGALKOT | 110     | SOUDATTI-RAMDURGA1          | RAMDURGA_110   | 13:30   | 13:49     | 0:19     | LINE FAULT          |
| 827    | 20-May-19 | BAGALKOT | 110     | MAHALINGAPUR-RANNABELAGALI  | RANNABELAGALI_110  | 20:50   | 22:40     | 1:50     | MAIN SUPPLY FAILURE |
| 828    | 20-May-19 | BAGALKOT | 110     | 110/11KV,HV2                | RON_110  | 20:39   | 21:45     | 1:06     | TRANSFORMER FAULT   |
| 829    | 20-May-19 | BAGALKOT | 110     | 110/11KV,HV2                | RON_110  | 22:00   | 23:17     | 1:17     | TRANSFORMER FAULT   |
| 830    | 20-May-19 | BAGALKOT | 110     | SALAHALLI-SHIVASAGAR SUGARS | SALAHALLI_110  | 10:10   | 14:01     | 3:51     | LINE CLEAR AVAILED  |
| 831    | 20-May-19 | BAGALKOT | 110     | 110/11KV,HV2                | SANKESHWAR_110   | 11:10   | 11:18     | 0:08     | LINE CLEAR AVAILED  |
| 832    | 20-May-19 | BAGALKOT | 110     | 110/33KV,HV3                | SANKESHWAR_110,HEBBAL_33KV,KANAGAL_33KV  | 11:32   | 11:44     | 0:12     | LINE CLEAR AVAILED  |
| 833    | 20-May-19 | BAGALKOT | 110     | SIRSI-KUMTA2                | SIRSI_110  | 6:01    | 15:07     | 9:06     | LINE FAULT          |
| 834    | 20-May-19 | BAGALKOT | 110     | SIRSI-KUMTA1                | SIRSI_110  | 6:01    | 14:57     | 8:56     | LINE FAULT          |
| 835    | 20-May-19 | BAGALKOT | 110     | 110/11KV,HV1                | SIRSI_110  | 14:57   | 18:05     | 3:08     | LINE CLEAR AVAILED  |
| 836    | 20-May-19 | BAGALKOT | 220     | SIRSI-HUBLI1                | SIRSI_220  | 13:01   | 15:18     | 2:17     | LINE CLEAR AVAILED  |
| 837    | 20-May-19 | BAGALKOT | 220     | SIRSI-HUBLI2                | SIRSI_220  | 13:02   | 15:25     | 2:23     | LINE CLEAR AVAILED  |
| 838    | 20-May-19 | BAGALKOT | 220     | 220/110KV,HV1               | SIRSI_220  | 13:02   | 16:05     | 3:03     | LINE CLEAR AVAILED  |
| 839    | 20-May-19 | BAGALKOT | 220     | SHARAVATHY 2-SIRSI          | SIRSI_220  | 3:26    | 17:13     | 13:47    | LINE FAULT          |
| 840    | 20-May-19 | BAGALKOT | 220     | SHARAVATHY 1-SIRSI          | SIRSI_220  | 11:45   | 17:12     | 5:27     | LINE CLEAR AVAILED  |
| 841    | 20-May-19 | BAGALKOT | 220     | SOUDATTI-MAHALINGAPUR       | SOUNDATTI_220  | 20:48   | 23:59     | 3:11     | LINE FAULT          |
| 842    | 20-May-19 | BAGALKOT | 110     | BELGAUM-VADAGON             | VADAGON_110  | 0:00    | 7:08      | 7:08     | LINE CLEAR AVAILED  |
| 843    | 20-May-19 | BAGALKOT | 220     | VAJRAMATTI-MAHALINGAPUR1    | VAJRAMATTI_220   | 20:47   | 23:50     | 3:03     | LINE FAULT          |
| 844    | 20-May-19 | BAGALKOT | 220     | VAJRAMATTI-MAHALINGAPUR2    | VAJRAMATTI_220   | 20:47   | 23:59     | 3:12     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                              | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|-----------------------------------|--|---------|-----------|----------|---------------------|
| 845    | 20-May-19 | BENGALURU | 66      | SOMANAHALLI 220 - JIGANI 2        | BG ROAD, JIGANI LINK ROAD, JIGANI 66                     | 15:09   | 15:18     | 0:09     | LINE FAULT          |
| 846    | 20-May-19 | BENGALURU | 220     | HV1                               | HSR LAYOUT 220   | 12:41   | 23:59     | 11:18    | TRANSFORMER FAULT   |
| 847    | 20-May-19 | BENGALURU | 220     | LV1                               | HSR LAYOUT 220   | 12:41   | 23:59     | 11:18    | TRANSFORMER FAULT   |
| 848    | 20-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - KORAMANGALA      | KORAMANGALA, K & C VALLEY, NAL (EHT)                     | 12:45   | 13:10     | 0:24     | MAIN SUPPLY FAILURE |
| 849    | 20-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - DEVARBISANAHALLI | DEVARBISANAHALLI   | 12:45   | 13:10     | 0:24     | MAIN SUPPLY FAILURE |
| 850    | 20-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - SHOBHA APARTMENT | SHOBHA APARTMENT   | 12:45   | 13:07     | 0:22     | MAIN SUPPLY FAILURE |
| 851    | 20-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - ST. JOHNS        | ST. JOHNS  | 12:45   | 13:10     | 0:24     | MAIN SUPPLY FAILURE |
| 852    | 20-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - KORAMANGALA      | KORAMANGALA, K & C VALLEY, NAL (EHT)                     | 21:38   | 22:15     | 0:36     | MAIN SUPPLY FAILURE |
| 853    | 20-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - DEVARBISANAHALLI | DEVARBISANAHALLI   | 21:38   | 22:10     | 0:31     | MAIN SUPPLY FAILURE |
| 854    | 20-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - SHOBHA APARTMENT | SHOBHA APARTMENT   | 21:38   | 22:22     | 0:43     | MAIN SUPPLY FAILURE |
| 855    | 20-May-19 | BENGALURU | 66      | HSR LAYOUT 220 - ST. JOHNS        | ST. JOHNS  | 21:38   | 22:10     | 0:31     | MAIN SUPPLY FAILURE |
| 856    | 20-May-19 | BENGALURU | 66      | HV1                               | MEI LAYOUT   | 17:44   | 18:17     | 0:32     | TRANSFORMER FAULT   |
| 857    | 20-May-19 | BENGALURU | 66      | HV2                               | GOKULA   | 9:47    | 10:37     | 0:50     | LINE CLEAR AVAILED  |
| 858    | 20-May-19 | BENGALURU | 66      | HV1                               | GOKULA   | 12:11   | 12:40     | 0:29     | LINE CLEAR AVAILED  |
| 859    | 20-May-19 | BENGALURU | 220     | SOMANAHALLI 220 - HSR LAYOUT 220  | HSR LAYOUT 220   | 12:45   | 12:55     | 0:10     | LINE FAULT          |
| 860    | 20-May-19 | BENGALURU | 220     | SOMANAHALLI 220 - HSR LAYOUT 220  | HSR LAYOUT 220   | 21:38   | 22:04     | 0:25     | LINE FAULT          |
| 861    | 20-May-19 | BENGALURU | 66      | HV2                               | HONNIGANAHALLI   | 10:39   | 10:55     | 0:15     | TRANSFORMER FAULT   |
| 862    | 20-May-19 | BENGALURU | 66      | HV2                               | HONNIGANAHALLI   | 18:18   | 18:31     | 0:12     | TRANSFORMER FAULT   |
| 863    | 20-May-19 | BENGALURU | 66      | HV1                               | HONNIGANAHALLI   | 18:18   | 18:35     | 0:16     | TRANSFORMER FAULT   |
| 864    | 20-May-19 | BENGALURU | 66      | HV2                               | ANEKAL   | 13:06   | 13:40     | 0:34     | TRANSFORMER FAULT   |
| 865    | 20-May-19 | BENGALURU | 66      | HV2                               | ANEKAL   | 15:45   | 15:55     | 0:10     | LINE CLEAR AVAILED  |
| 866    | 20-May-19 | BENGALURU | 66      | HV1                               | ATTIBELE   | 11:52   | 14:30     | 2:38     | LINE CLEAR AVAILED  |
| 867    | 20-May-19 | BENGALURU | 66      | HV1                               | BANGARPET  | 13:38   | 14:01     | 0:22     | TRANSFORMER FAULT   |
| 868    | 20-May-19 | BENGALURU | 66      | HV2                               | CHAKAVELU  | 13:38   | 14:08     | 0:30     | TRANSFORMER FAULT   |
| 869    | 20-May-19 | BENGALURU | 66      | CHIKKENAHALLI - CHANNAPATNA       | CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR | 5:32    | 5:34      | 0:02     | LINE FAULT          |
| 870    | 20-May-19 | BENGALURU | 66      | CHINTAMANI 220 - LAKSHMIPURA      | LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI                    | 7:50    | 7:53      | 0:02     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE   | Voltage | Line                          | Station_Name  | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|-----------|---------|-------------------------------|---|---------|-----------|----------|---------------------|
| 871    | 20-May-19 | BENGALURU | 66      | DB PURA 220 - VIJAYAPURA      | VIJAYAPURA, JANGAMAKOTE                                       | 15:41   | 15:45     | 0:04     | LINE FAULT          |
| 872    | 20-May-19 | BENGALURU | 66      | HV2                           | MAASTHI   | 10:05   | 10:18     | 0:13     | TRANSFORMER FAULT   |
| 873    | 20-May-19 | BENGALURU | 66      | HV1                           | VIJAYAPURA  | 15:31   | 15:56     | 0:25     | TRANSFORMER FAULT   |
| 874    | 20-May-19 | BENGALURU | 66      | DABUSPET 220 - NELAMANGALA 66 | NELAMANGALA 66  | 3:17    | 3:31      | 0:14     | LINE FAULT          |
| 875    | 20-May-19 | GULBARGA  | 400     | BTPS-RTPS                     | BTPS_400  | 4:20    | 5:16      | 0:56     | LINE FAULT          |
| 876    | 20-May-19 | GULBARGA  | 400     | GUTTUR-JSWVL                  | JSWVL_IPP   | 11:35   | 23:59     | 12:24    | LINE FAULT          |
| 877    | 20-May-19 | GULBARGA  | 220     | HV2                           | HALBURGA_220  | 5:40    | 5:49      | 0:09     | TRANSFORMER FAULT   |
| 878    | 20-May-19 | GULBARGA  | 220     | SEDAM-CLNMAX_IPP              | SEDAM_220   | 0:00    | 2:03      | 2:03     | LINE CLEAR AVAILED  |
| 879    | 20-May-19 | GULBARGA  | 220     | SEDAM-SHREE_CMT               | SHREE CEMENT_IPP  | 12:12   | 16:38     | 4:26     | LINE CLEAR AVAILED  |
| 880    | 20-May-19 | GULBARGA  | 220     | HV1                           | KAPNOOR_220   | 15:55   | 16:37     | 0:42     | LINE CLEAR AVAILED  |
| 881    | 20-May-19 | GULBARGA  | 220     | RTPS-LINGASUGUR2              | LINGASUGUR_220  | 21:41   | 23:59     | 2:18     | LINE FAULT          |
| 882    | 20-May-19 | GULBARGA  | 220     | RTPS-LINGASUGUR3              | LINGASUGUR_220  | 21:55   | 22:59     | 1:04     | LINE FAULT          |
| 883    | 20-May-19 | GULBARGA  | 110     | HALBARGA-SANTHAPUR            | DONGRAGO_A_110,SANTHAPUR_110,KAMALANAGAR_110                  | 5:40    | 5:52      | 0:12     | LINE FAULT          |
| 884    | 20-May-19 | GULBARGA  | 110     | KOLHAR-NSSK                   | JANAWADA_110,NSSK SUGAR FACTORY_IPP                           | 5:40    | 5:53      | 0:13     | LINE FAULT          |
| 885    | 20-May-19 | GULBARGA  | 110     | JANAWADA-SANTHAPUR            | JANAWADA_110  | 19:01   | 20:24     | 1:23     | LINE CLEAR AVAILED  |
| 886    | 20-May-19 | GULBARGA  | 110     | LV2                           | HALBURGA_110  | 12:57   | 20:16     | 7:19     | TRANSFORMER FAULT   |
| 887    | 20-May-19 | GULBARGA  | 110     | KAPNOOR-HUMNABAD1             | GULBARGA NORTH_110,GULBARGA SOUTH_110,GULBARGA UNIVERSITY_110 | 15:23   | 17:20     | 1:57     | LINE FAULT          |
| 888    | 20-May-19 | GULBARGA  | 110     | GABBUR-DEODURGA               | GABBUR_110  | 21:45   | 22:00     | 0:15     | LINE FAULT          |
| 889    | 20-May-19 | GULBARGA  | 110     | HV2                           | KAMPLI_110  | 18:01   | 18:24     | 0:23     | HAND TRIPPED        |
| 890    | 20-May-19 | GULBARGA  | 66      | HV2                           | CHORNOOR_66   | 13:18   | 13:22     | 0:04     | TRANSFORMER FAULT   |
| 891    | 20-May-19 | GULBARGA  | 66      | HV1                           | HAMPASAGAR_66   | 11:11   | 11:15     | 0:04     | LINE CLEAR AVAILED  |
| 892    | 20-May-19 | GULBARGA  | 66      | HV1                           | HAMPASAGAR_66   | 11:23   | 11:33     | 0:10     | LINE CLEAR AVAILED  |
| 893    | 20-May-19 | GULBARGA  | 66      | HANASI-KADALIGI               | HANASI_66   | 11:58   | 12:28     | 0:30     | LINE CLEAR AVAILED  |
| 894    | 20-May-19 | GULBARGA  | 400     | GUTTUR-JSWVL                  | JSWVL_IPP   | 0:00    | 15:50     | 15:50    | LINE FAULT          |
| 895    | 20-May-19 | HASSAN    | 220     | MRSSHM-SHARAVATHY2            | MRSMSG_220  | 0:00    | 16:52     | 16:52    | NFBC ISSUED         |
| 896    | 20-May-19 | HASSAN    | 220     | SHRAVITY-SIRISI 1             | sharavathy_gen  | 11:45   | 17:11     | 5:26     | LINE CLEAR AVAILED  |
| 897    | 20-May-19 | HASSAN    | 220     | SHRAVITY-SIRISI 2             | sharavathy_gen  | 3:20    | 17:12     | 13:52    | LINE FAULT          |
| 898    | 20-May-19 | HASSAN    | 220     | SHRAVITY-TALAGUPPA1           | sharavathy_gen  | 13:00   | 15:45     | 2:45     | NFBC ISSUED         |
| 899    | 20-May-19 | HASSAN    | 220     | TALAGU-SGS1                   | TALAGUPPA_400   | 13:00   | 15:45     | 2:45     | LINE CLEAR AVAILED  |
| 900    | 20-May-19 | HASSAN    | 110     | GURUVA-KEMAR1                 | GURUVAYANAKERE_110  | 0:00    | 13:00     | 13:00    | MAIN SUPPLY FAILURE |
| 901    | 20-May-19 | HASSAN    | 110     | HV1                           | HOSANGADI_110   | 10:07   | 12:21     | 2:14     | LINE CLEAR AVAILED  |
| 902    | 20-May-19 | HASSAN    | 110     | KAVOOR-MCFLine                | KAVOOR_220  | 1:39    | 2:24      | 0:45     | LINE FAULT          |



| Sl.No. | DATE      | Tr_ZONE | Voltage | Line                 | Station_Name   | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|---------|---------|----------------------|--|---------|-----------|----------|---------------------|
| 903    | 20-May-19 | HASSAN  | 110     | KAVOOR-MCFLine       | KAVOOR_220   | 3:39    | 4:04      | 0:25     | LINE FAULT          |
| 904    | 20-May-19 | HASSAN  | 110     | KEMAR-Guruvykere1    | KEMAR_220  | 0:00    | 13:00     | 13:00    | LINE FAULT          |
| 905    | 20-May-19 | HASSAN  | 110     | HV2                  | MOODABIDRE_110   | 1:40    | 2:17      | 0:37     | MAIN SUPPLY FAILURE |
| 906    | 20-May-19 | HASSAN  | 110     | MOODAB-SOHAM1        | MOODABIDRE_110   | 1:46    | 2:17      | 0:31     | MAIN SUPPLY FAILURE |
| 907    | 20-May-19 | HASSAN  | 110     | MOODAB-SOHAM2        | MOODABIDRE_110   | 1:40    | 2:17      | 0:37     | MAIN SUPPLY FAILURE |
| 908    | 20-May-19 | HASSAN  | 66      | BELUR66-MUDIGERE     | BELUR_66   | 10:28   | 11:11     | 0:43     | LINE FAULT          |
| 909    | 20-May-19 | HASSAN  | 66      | BHADRA-LINGADAHALLI  | bhadra_gen   | 12:29   | 12:36     | 0:07     | LINE FAULT          |
| 910    | 20-May-19 | HASSAN  | 66      | BYARAPU-BAGUR        | K_BYRAPURA_66  | 15:30   | 19:00     | 3:30     | MAIN SUPPLY FAILURE |
| 911    | 20-May-19 | HASSAN  | 66      | CHIKMA-L1-ALDUR      | CHIKMAGALUR_66   | 0:00    | 0:30      | 0:30     | LINE FAULT          |
| 912    | 20-May-19 | HASSAN  | 66      | GENDEHA-HASSAN       | GENDEHALLI_66  | 10:01   | 11:12     | 1:11     | LINE FAULT          |
| 913    | 20-May-19 | HASSAN  | 66      | GENDEHA-MUDIGERE     | GENDEHALLI_66  | 5:19    | 5:43      | 0:24     | LINE FAULT          |
| 914    | 20-May-19 | HASSAN  | 66      | GENDEHA-MUDIGERE     | GENDEHALLI_66  | 10:47   | 11:24     | 0:37     | HAND TRIPPED        |
| 915    | 20-May-19 | HASSAN  | 66      | HNPR2-HASS2          | HOLENARASIPURA_220   | 12:24   | 12:50     | 0:26     | LINE FAULT          |
| 916    | 20-May-19 | HASSAN  | 66      | HNPURA-RAMNATHPURA   | HNPURA_66  | 11:41   | 11:45     | 0:04     | LINE FAULT          |
| 917    | 20-May-19 | HASSAN  | 66      | HNPURA-SOMANAHALLI   | HNPURA_66  | 12:13   | 15:00     | 2:47     | LINE CLEAR AVAILED  |
| 918    | 20-May-19 | HASSAN  | 66      | KUDLIGE-ANVRPP       | KUDLIGERE_66   | 5:56    | 6:07      | 0:11     | HAND TRIPPED        |
| 919    | 20-May-19 | HASSAN  | 66      | KUDLIGE-ANVRPP       | KUDLIGERE_66   | 6:15    | 6:29      | 0:14     | HAND TRIPPED        |
| 920    | 20-May-19 | HASSAN  | 66      | KUDLIGE-ANVRPP       | KUDLIGERE_66   | 15:16   | 15:23     | 0:07     | LINE FAULT          |
| 921    | 20-May-19 | HASSAN  | 66      | HV2                  | SATHENAHALLY_66  | 11:15   | 12:30     | 1:15     | LINE CLEAR AVAILED  |
| 922    | 20-May-19 | HASSAN  | 66      | HV1                  | SATHENAHALLY_66  | 12:35   | 15:30     | 2:55     | LINE CLEAR AVAILED  |
| 923    | 20-May-19 | MYSORE  | 66      | HV1                  | BANNUR_66  | 11:24   | 13:48     | 2:23     | LINE CLEAR AVAILED  |
| 924    | 20-May-19 | MYSORE  | 66      | HV2                  | BANNUR_66  | 12:20   | 23:59     | 11:39    | LINE CLEAR AVAILED  |
| 925    | 20-May-19 | MYSORE  | 66      | HV1                  | DUNDANAHALLI_66  | 13:35   | 15:35     | 2:00     | LINE CLEAR AVAILED  |
| 926    | 20-May-19 | MYSORE  | 66      | HV2                  | DUNDANAHALLI_66  | 11:30   | 14:00     | 2:30     | LINE CLEAR AVAILED  |
| 927    | 20-May-19 | MYSORE  | 66      | HAMPAPURA-BASARALU   | BESAGARAHALLI_66 KOPPA_66                                      | 5:42    | 5:52      | 0:09     | LINE FAULT          |
| 928    | 20-May-19 | MYSORE  | 66      | HV1                  | HANGLA_66  | 10:20   | 16:45     | 6:25     | LINE CLEAR AVAILED  |
| 929    | 20-May-19 | MYSORE  | 66      | HV2                  | HANGLA_66  | 10:20   | 16:45     | 6:25     | LINE CLEAR AVAILED  |
| 930    | 20-May-19 | MYSORE  | 66      | HOOTAGALLI-DATAGALLI | DATTAGALLY_66  | 9:35    | 9:37      | 0:02     | HAND TRIPPED        |
| 931    | 20-May-19 | MYSORE  | 220     | HV1                  | HOOTAGALLY_220   | 9:54    | 14:15     | 4:21     | LINE CLEAR AVAILED  |
| 932    | 20-May-19 | MYSORE  | 66      | HV1                  | JAKKANAHALLY_66  | 14:15   | 14:57     | 0:41     | LINE CLEAR AVAILED  |
| 933    | 20-May-19 | MYSORE  | 66      | HV1                  | KIADBMANDYA_66   | 13:12   | 13:14     | 0:01     | HAND TRIPPED        |
| 934    | 20-May-19 | MYSORE  | 66      | HV2                  | KIADBMANDYA_66   | 13:12   | 13:14     | 0:01     | HAND TRIPPED        |
| 935    | 20-May-19 | MYSORE  | 66      | KIADB MANDYA-MADDUR  | MADDUR_66 SOMANAHALLI_66                                       | 13:12   | 13:14     | 0:02     | HAND TRIPPED        |
| 936    | 20-May-19 | MYSORE  | 66      | KM DODDI-MANDYA      | KOLKARANADODDI_66,<br>KIADBMANDYA_66 MADDUR_66<br>TUMBEKERE_66 | 11:47   | 13:06     | 1:18     | NFBC ISSUED         |
| 937    | 20-May-19 | MYSORE  | 66      | V2                   | KRPET_66   | 11:59   | 14:35     | 2:36     | LINE CLEAR AVAILED  |
| 938    | 20-May-19 | MYSORE  | 66      | KOPPA-BESAGARAHALLI  | BESAGARAHALLI_66   | 5:50    | 6:20      | 0:30     | LINE FAULT          |

| Sl.No. | DATE      | Tr_ZONE | Voltage | Line                                   | Station_Name  | Open_At | Closed_At | Duration | REASON             |
|--------|-----------|---------|---------|--|---|---------|-----------|----------|--------------------|
| 939    | 20-May-19 | MYSORE  | 66      | HV1                                    | SANTHESARAGUR_66  | 18:49   | 19:01     | 0:11     | TRANSFORMER FAULT  |
| 940    | 20-May-19 | TUMKUR  | 220     | TR-3                                   | HIRIYUR_220   | 3:02    | 3:44      | 0:41     | TRANSFORMER FAULT  |
| 941    | 20-May-19 | TUMKUR  | 110     | TR-2                                   | TIPTUR_110  | 4:31    | 4:38      | 0:07     | TRANSFORMER FAULT  |
| 942    | 20-May-19 | TUMKUR  | 66      | ANTHRASANAHALLI 220KV- TUMKUR          | TUMKUR_66   | 10:36   | 12:42     | 2:05     | LINE FAULT         |
| 943    | 20-May-19 | TUMKUR  | 66      | BALENAHALLI-CHALKERE                   | BALENAHALLI_66  | 1:45    | 7:52      | 6:06     | LINE FAULT         |
| 944    | 20-May-19 | TUMKUR  | 66      | TR-1                                   | BRAHMASANDRA_66   | 12:12   | 12:23     | 0:11     | LINE CLEAR AVAILED |
| 945    | 20-May-19 | TUMKUR  | 66      | DYAVARANAHALLI- CELESTIALSOLAR         | CELESTIALSOLAR_IPP_66   | 0:24    | 0:30      | 0:06     | LINE FAULT         |
| 946    | 20-May-19 | TUMKUR  | 66      | DYAVARANAHALLI-MYLANAHALLI             | DYAVARANAHALLI_66   | 3:56    | 6:29      | 2:32     | LINE CLEAR AVAILED |
| 947    | 20-May-19 | TUMKUR  | 66      | TR-1                                   | HALURAMESHWARA_66   | 10:49   | 15:01     | 4:11     | LINE CLEAR AVAILED |
| 948    | 20-May-19 | TUMKUR  | 66      | TR-2                                   | HALURAMESHWARA_66   | 15:25   | 17:17     | 1:51     | LINE CLEAR AVAILED |
| 949    | 20-May-19 | TUMKUR  | 66      | HANAGAL- AVADASOLAR_IPP_66             | AVADASOLAR_IPP_66   | 2:40    | 2:50      | 0:10     | HAND TRIPPED       |
| 950    | 20-May-19 | TUMKUR  | 66      | HANAGAL- B G KERE                      | HANAGAL_66,<br>NAGASAMUDRA_66,<br>RAMPURA_66  | 2:48    | 3:50      | 1:02     | LINE FAULT         |
| 951    | 20-May-19 | TUMKUR  | 66      | HANAGAL-GUDEKOTE                       | HANAGAL_66  | 0:42    | 2:48      | 2:05     | LINE FAULT         |
| 952    | 20-May-19 | TUMKUR  | 66      | HIRIYUR 220KV- ENERCON-1               | ENERCON1_IPP_66   | 3:07    | 3:51      | 0:44     | HAND TRIPPED       |
| 953    | 20-May-19 | TUMKUR  | 66      | HIRIYUR 220kv- BEVINAHALLI             | DASUDI_66,<br>JAVAGONDANAHALLI_66,<br>BEVINAHALLI_66                                    | 3:28    | 3:48      | 0:19     | HAND TRIPPED       |
| 954    | 20-May-19 | TUMKUR  | 66      | HIRIYUR 220KV- RKP 1                   | RKP1_IPP_66   | 3:06    | 3:48      | 0:42     | HAND TRIPPED       |
| 955    | 20-May-19 | TUMKUR  | 66      | HIRIYUR 220KV- RKP2                    | RKP2_IPP_66   | 3:06    | 3:48      | 0:42     | HAND TRIPPED       |
| 956    | 20-May-19 | TUMKUR  | 66      | HIRIYUR 220KV- RANGANATHPURA           | RANGANATHAPURA_66   | 3:05    | 3:51      | 0:45     | HAND TRIPPED       |
| 957    | 20-May-19 | TUMKUR  | 66      | HONNALLI 220kv-<br>CHANNAGIRI(NALLUR ) | CHANNAGIRI_66,<br>DEVARAHALLI_66, BENKIKERE_66,<br>TAVAREKERE(C)_66,<br>GOPPENAHALLI_66 | 12:57   | 15:14     | 2:16     | LINE CLEAR AVAILED |
| 958    | 20-May-19 | TUMKUR  | 66      | HONNALLI 220KV- SASUVEHALLI            | SASUVEHALLI_66  | 5:30    | 6:08      | 0:37     | LINE FAULT         |
| 959    | 20-May-19 | TUMKUR  | 66      | HONNALLI 220KV- SASUVEHALLI            | SASUVEHALLI_66  | 12:57   | 15:14     | 2:16     | LINE CLEAR AVAILED |
| 960    | 20-May-19 | TUMKUR  | 66      | HULIYURDURGA- DUNDANAHALLI             | DUNDANAHALLI_66   | 11:44   | 12:33     | 0:49     | LINE CLEAR AVAILED |
| 961    | 20-May-19 | TUMKUR  | 66      | TR-1                                   | KORATAGERE_66   | 15:01   | 15:25     | 0:23     | LINE CLEAR AVAILED |
| 962    | 20-May-19 | TUMKUR  | 66      | KUKKAWADA- LINGADAHALLI                | TYAVANAGI_66,<br>BASAVAPATNA_66,<br>SANTEBENNUR_66                                      | 13:57   | 14:17     | 0:20     | LINE FAULT         |

| Sl.No. | DATE      | Tr_ZONE | Voltage | Line                                | Station_Name  | Open_At | Closed_At | Duration | REASON              |
|--------|-----------|---------|---------|-------------------------------------|---|---------|-----------|----------|---------------------|
| 963    | 20-May-19 | TUMKUR  | 66      | MATHOD-RAMCO CEMENT _EHT_66         | RAMCO CEMENT _EHT_66  | 4:26    | 11:55     | 7:28     | LINE FAULT          |
| 964    | 20-May-19 | TUMKUR  | 66      | MYLANAHALLI-THALLAK                 | MYLANAHALLI_66  | 1:42    | 6:48      | 5:05     | MAIN SUPPLY FAILURE |
| 965    | 20-May-19 | TUMKUR  | 66      | TR-1                                | MYLANAHALLI_66  | 1:42    | 6:48      | 5:05     | MAIN SUPPLY FAILURE |
| 966    | 20-May-19 | TUMKUR  | 66      | TR-1                                | SAVALANGA_66  | 5:09    | 6:10      | 1:00     | MAIN SUPPLY FAILURE |
| 967    | 20-May-19 | TUMKUR  | 66      | THALLAK 220kV -BGKERE 1             | BGKERE_66, HANAGAL_66,<br>NAGASAMUDRA_66,<br>RAMPURA_66       | 1:09    | 2:31      | 1:21     | LINE FAULT          |
| 968    | 20-May-19 | TUMKUR  | 66      | THALLAK 220kV- CHALLAKERE-2         | CHALLAKERE_66, SANIKERE_66                                    | 0:24    | 0:38      | 0:14     | LINE FAULT          |
| 969    | 20-May-19 | TUMKUR  | 66      | THALLAK 220kV- CHALLAKERE-2         | CHALLAKERE_66, SANIKERE_66                                    | 1:10    | 1:19      | 0:09     | LINE FAULT          |
| 970    | 20-May-19 | TUMKUR  | 66      | THALLAK 220kV- CHALLAKERE-2         | CHALLAKERE_66, SANIKERE_66                                    | 1:28    | 1:40      | 0:11     | LINE FAULT          |
| 971    | 20-May-19 | TUMKUR  | 66      | THALLAK 220kV- CHALLAKERE-2         | CHALLAKERE_66, SANIKERE_66                                    | 1:41    | 2:41      | 1:00     | LINE FAULT          |
| 972    | 20-May-19 | TUMKUR  | 66      | THALLAK 220kV- GOWRASAMUDRA         | GOWRASAMUDRA_66   | 1:28    | 2:40      | 1:11     | LINE FAULT          |
| 973    | 20-May-19 | TUMKUR  | 66      | TR-1(LV SIDE)                       | THALLAKK_220  | 0:24    | 0:37      | 0:13     | TRANSFORMER FAULT   |
| 974    | 20-May-19 | TUMKUR  | 66      | TR-1(LV SIDE)                       | THALLAKK_220  | 1:45    | 2:28      | 0:42     | TRANSFORMER FAULT   |
| 975    | 20-May-19 | TUMKUR  | 66      | TR-2 (LV SIDE)                      | THALLAKK_220  | 1:09    | 1:18      | 0:08     | TRANSFORMER FAULT   |
| 976    | 20-May-19 | TUMKUR  | 66      | TURUVANUR66-JAGALUR                 | JAGALUR_66,BIDARKERE_66,SOKK<br>E_66                          | 2:47    | 2:51      | 0:04     | LINE CLEAR AVAILED  |
| 977    | 20-May-19 | TUMKUR  | 66      | CHITRADURGA 66kV- CHITRADURGA<br>3  | CHITRADURGA_66  | 2:45    | 10:08     | 7:23     | LINE FAULT          |
| 978    | 20-May-19 | TUMKUR  | 66      | CHITRADURGA 66kV- PANDARAHALLI<br>2 | HIREGUNTANUR_66, SIRIGERE_66,<br>BRAHMASAGARA_IPP_66          | 2:45    | 3:16      | 0:30     | LINE CLEAR AVAILED  |
| 979    | 20-May-19 | TUMKUR  | 66      | CHITRADURGA 66kV- MEGMICON 1        | MEGMICON 1_IPP_66   | 2:37    | 9:12      | 6:35     | LINE FAULT          |
| 980    | 20-May-19 | TUMKUR  | 66      | CHITRADURGA 66kV- MEGMICON 2        | MEGMICON 1_IPP_66   | 2:37    | 5:22      | 2:45     | LINE FAULT          |
| 981    | 20-May-19 | TUMKUR  | 66      | TR-1 & TR-2                         | CHANNAGIRI_66   | 3:42    | 7:34      | 3:52     | LINE CLEAR AVAILED  |
| 982    | 20-May-19 | TUMKUR  | 66      | CHIKKABANAGERE- GLOBAL<br>TECKPARK  | GLOBAL TECKPARK_IPP_66  | 8:48    | 9:29      | 0:41     | HAND TRIPPED        |
| 983    | 20-May-19 | TUMKUR  | 66      | LINGADHALLI-CHANNAGIRI              | CHANNAGIRI_66,DEVARAHALLI_66<br>,BENKIKERE_66,GOPPENAHALLI_66 | 13:51   | 18:31     | 4:40     | MAIN SUPPLY FAILURE |
| 984    | 20-May-19 | TUMKUR  | 66      | TR-1                                | LINGADAHALLY_66   | 7:37    | 8:41      | 1:04     | TRANSFORMER FAULT   |
| 985    | 20-May-19 | TUMKUR  | 66      | LINGADAHALLI- SHIMOGA               | LINGDHALLI_66   | 7:02    | 15:33     | 8:31     | LINE FAULT          |
| 986    | 20-May-19 | TUMKUR  | 66      | LINGADAHALLI- SHIMOGA               | LINGDHALLI_66   | 18:31   | 22:23     | 3:52     | LINE FAULT          |