

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM : 05.01.2021 TO 11.01.2021

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	5-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
2	5-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
3	5-Jan-2021	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	11:21 (04.01.2021)	12:07 (05.01.2021)	24:46hrs	TRANSFOERMER CHARGED
4	5-Jan-2021	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	16:18	16:52	0:34	HAND TRIPPED
5	5-Jan-2021	BAGALKOT	110	110/11KV,HV1	PH COMPOUND_110	0:28	18:28	18:00	TRANSFORMER FAULT
6	5-Jan-2021	BAGALKOT	110	110/11KV,HV1	TODALBAG_110	08:25	08:43	0:18	TRANSFORMER FAULT
7	5-Jan-2021	BAGALKOT	110	110/11KV,HV2	KANABARGI LAYOUT_110	11:46	16:54	5:08	LINE CLEAR AVAILED
8	5-Jan-2021	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	1:30	1:40	0:10	TRANSFORMER FAULT
9	5-Jan-2021	BAGALKOT	110	110/33KV, HV1 (ACTUAL HV2)	YARAGATTI_110,CHUNCHANUR_33 KV,BOSCH_IPP,SHIVAPURA_33KV	17:26	18:06	0:40	LINE CLEAR AVAILED
10	5-Jan-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	HALIYAL_110	11:56	13:05	1:09	LINE CLEAR AVAILED
11	5-Jan-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	KAVALWADA_110	9:53	09:57	0:04	LINE FAULT
12	5-Jan-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	KAVALWADA_110	12:52	13:04	0:12	LINE FAULT
13	5-Jan-2021	BAGALKOT	110	BIDNAL220-ANNIGERI	STATION NOT AFFECTED BIDNAL 220	10:16	15:30	5:14	LINE CLEAR AVAILED
14	5-Jan-2021	BAGALKOT	110	BIDNAL220-GADAG ROAD	STATION NOT AFFECTED BIDNAL 220	10:16	15:24	5:08	LINE CLEAR AVAILED
15	5-Jan-2021	BAGALKOT	110	BIDNAL220-NAVALGUND	STATION NOT AFFECTED BIDNAL 220	10:16	15:26	5:10	LINE CLEAR AVAILED
16	5-Jan-2021	BAGALKOT	110	BIDNAL220-P H COMPOUND	STATION NOT AFFECTED BIDNAL 220	10:30	14:37	4:07	LINE CLEAR AVAILED
17	5-Jan-2021	BAGALKOT	110	BIDNAL-NAVAGUND	STATION NOT AFFECTED NAVAGUND 110	10:51	15:29	4:38	LOAD CHANGE OVER
18	5-Jan-2021	BAGALKOT	110	BORUKA(BPCL)-ITNAL	STATION NOT AFFECTED ITNAL 110	4:33	4:39	0:06	LINE FAULT
19	5-Jan-2021	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	04:13	04:33	0:20	LINE FAULT
20	5-Jan-2021	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	05:56	06:10	0:14	LINE FAULT
21	5-Jan-2021	BAGALKOT	110	GADAG220-DAMBAL	STATION NOT AFFECTED DAMBAL 110	10:29	13:22	2:53	LINE CLEAR AVAILED
22	5-Jan-2021	BAGALKOT	110	GADAG220-LAXMESHVAR	STATION NOT AFFECTED GADAG 220	10:33	13:30	2:57	LINE CLEAR AVAILED
23	5-Jan-2021	BAGALKOT	110	GADAG220-SHIRAHATTI	STATION NOT AFFECTED GADAG 220	13:34	17:21	3:47	LINE CLEAR AVAILED
24	5-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
25	5-Jan-2021	BAGALKOT	110	GHATAPRABHA220-SHIRGAON	SHIRGAON_110	15:53	17:28	1:35	LINE CLEAR AVAILED
26	5-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA 110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
27	5-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
28	5-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
29	5-Jan-2021	BAGALKOT	110	HIDIKAL-ITNAL(RAIBAG)	STATION NOT AFFECTED ITNAL_110	14:03	20:06	6:03	LINE CLEAR AVOIDED
30	5-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
31	5-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
32	5-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
33	5-Jan-2021	BAGALKOT	110	KUMATA- SIRSI1	STATION NOT AFFECTED KUMATA_110	16:59 (04.01.2021)	17:56 (05.01.2021)	24:57hrs	LINE CHARGED
34	5-Jan-2021	BAGALKOT	110	LAXMESHWAR-GADAG1	STATION NOT AFFECTED LAXMESHWAR_110	10:33	13:30	2:57	LINE CLEAR AVOIDED
35	5-Jan-2021	BAGALKOT	110	NAVAGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVAGUND_110	15:29 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
36	5-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	8:38 (23.12.2020)	10:29 (05.01.2021)	1:51hrs	LINE CHARGED
37	5-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
38	5-Jan-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN :LINE FAULT
39	5-Jan-2021	BAGALKOT	110	SIRSI(AMBEWADI)- KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	18:50 (04.01.2021)	13:18 (05.01.2021)	18:28hrs	LINE CHARGED
40	5-Jan-2021	BAGALKOT	110	SIRSI-JOG1	STATION NOT AFFECTED SIRSI_110	13:08	13:10	0:02	LOAD CURTAILMENT
41	5-Jan-2021	BAGALKOT	110	SIRSI-KUMATA 1	SIRSI_110	16:45 (04.01.2021)	17:30 (05.01.2021)	24:45hrs	LINE CHARGED
42	5-Jan-2021	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	15:46	17:19	1:33	LINE CLEAR AVOIDED
43	5-Jan-2021	BAGALKOT	220	220/110KV,HV1,LV1	BAGEWADI_220	16:35 (05.01.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
44	5-Jan-2021	BAGALKOT	220	220/110KV,HV1,LV1	BIDNAL_220	10:30	14:27	3:57	LINE CLEAR AVOIDED
45	5-Jan-2021	BAGALKOT	220	220/110KV,HV1,LV1(HV2,LV2)	STATION NOT AFFECTED GADAG_220	15:11	17:22	2:11	LINE CLEAR AVOIDED
46	5-Jan-2021	BAGALKOT	220	220/110KV,HV3,LV3	GADAG_220	17:23	18:42	1:19	LINE CLEAR AVOIDED
47	5-Jan-2021	BAGALKOT	220	AMBEWADI-NARENDRA1	STATION NOT AFFECTED AMBEWADI_220	05:44	17:37	11:53	LINE FAULT
48	5-Jan-2021	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	13:08	17:33	4:25	LINE CLEAR AVOIDED
49	5-Jan-2021	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	22:45 (04.01.2021)	2:31 (05.01.2021)	3:46hrs	LINE CHARGED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
50	5-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
51	5-Jan-2021	BAGALKOT	220	HAVERI-BIDNAL (NARENDRA 1)	STATION NOT AFFECTED HAVERI_220	22:46 (04.01.2021)	2:32 (05.01.2021)	3:46hrs	LINE CHARGED
52	5-Jan-2021	BAGALKOT	220	MAHALINGAPUR-NARENDRA2	STATION NOT AFFECTED MAHALINGAPUR_220	12:27	14:30	2:03	LINE CLEAR AVAILED
53	5-Jan-2021	BAGALKOT	220	MK HUBI -NARENDRA 2	STATION NOT AFFECTED MK HUBLI_220	8:44 (05.01.2021)			LINE OPEN :LINE FAULT
54	5-Jan-2021	BAGALKOT	220	NARENDRA -AMBEWADI 1	STATION NOT AFFECTED NARENDRA_220	5:56	17:33	11:37	LINE FAULT
55	5-Jan-2021	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	12:17	13:33	1:16	LINE CLEAR AVAILED
56	5-Jan-2021	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	21:10 (04.01.2021)	14:36 (05.01.2021)	17:26hrs	LINE CHARGED
57	5-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)	18:00 (05.01.2021)	923:45hrs	LINE CHARGED
58	5-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)	3:51 (05.01.2021)	909:36hrs	LINE CHARGED
59	5-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	4:31 (05.01.2021)			LOAD CURTAILMENT
60	5-Jan-2021	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
61	5-Jan-2021	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
62	5-Jan-2021	BENGALURU	66	HV2	APPAREL PARK	16:00	16:30	00:30	LINE CLEAR AVAILED
63	5-Jan-2021	BENGALURU	66	HV2	ATTUR YELAHANKA	03:44	04:19	00:35	TRANSFORMER FAULT
64	5-Jan-2021	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
65	5-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	10:01	10:11	00:10	LINE FAULT
66	5-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPUR_110,MANVI_110	19:22	19:35	00:13	LINE FAULT
67	5-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADALAPUR_110,MANVI_110	20:06	20:13	00:07	LINE FAULT
68	5-Jan-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110	05:36	05:46	00:10	LINE FAULT
69	5-Jan-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110	20:42	21:02	00:20	LINE FAULT
70	5-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	04:05	04:09	00:04	LINE FAULT
71	5-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	05:26	05:37	00:11	LINE FAULT
72	5-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	20:50	21:03	00:13	LINE FAULT
73	5-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:12	22:24	00:12	LINE FAULT
74	5-Jan-2021	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	08:10	08:20	00:10	LINE FAULT
75	5-Jan-2021	GULBARGA	220	KUSHTAGI-LINGAPUR	LINGAPUR_220	09:55	22:30	12:35	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
76	5-Jan-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_2220	10:59(05.01.2021)			LINE OPEN :LINE FAULT
77	5-Jan-2021	HASSAN	66	HV1	GORUR	14:48	15:58	01:10	LINE CLEAR AVAILED
78	5-Jan-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
79	5-Jan-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
80	5-Jan-2021	HASSAN	110	BANTWA-KAVOOR	BANTWA	10:09	14:25	04:16	LINE CLEAR AVAILED
81	5-Jan-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	09:09	17:21	08:12	LINE CLEAR AVAILED
82	5-Jan-2021	HASSAN	110	HV1	GURUVA	16:55	17:03	00:08	TRANSFORMER FAULT
83	5-Jan-2021	HASSAN	110	HV2	SHIKAR	00:15	00:42	00:27	TRANSFORMER FAULT
84	5-Jan-2021	HASSAN	110	JOG-JLT4	mghejog_gen	11:11 (28.12.2020)			LINE OPEN:LINE CLEAR AVAILED
85	5-Jan-2021	HASSAN	110	KEMAR-KAVOOR	KEMAR_220	10:31	16:50	06:19	NFBC ISSUED
86	5-Jan-2021	HASSAN	110	LV3	KEMAR_220	10:02	13:48	03:46	LINE CLEAR AVAILED
87	5-Jan-2021	HASSAN	110	MADHUV-HIRIYADKA	MADHUV	09:14	16:32	07:18	NFBC ISSUED
88	5-Jan-2021	HASSAN	110	SAGARA-LST4	SAGARA	09:38	16:32	06:54	NFBC ISSUED
89	5-Jan-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:42	11:58	00:16	MAIN SUPPLY FAILURE
90	5-Jan-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:42	11:45	00:03	MAIN SUPPLY FAILURE
91	5-Jan-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:42	11:58	00:16	MAIN SUPPLY FAILURE
92	5-Jan-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:42	11:45	00:03	MAIN SUPPLY FAILURE
93	5-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
94	5-Jan-2021	HASSAN	220	HV3	KEMAR_220	10:02	13:48	03:46	LINE CLEAR AVAILED
95	5-Jan-2021	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:31	16:50	06:19	LINE CLEAR AVAILED
96	5-Jan-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:42	13:56	01:14	LINE CLEAR AVAILED
97	5-Jan-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	11:42	16:53	05:11	LINE FAULT
98	5-Jan-2021	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	11:42	13:56	02:14	LINE FAULT
99	5-Jan-2021	HASSAN	220	SHRAVITY-TALAGUPPA1	sharavathy_gen	11:42	13:52	02:10	LINE FAULT
100	5-Jan-2021	HASSAN	220	SHRAVITY-TALAGUPPA3	sharavathy_gen	11:42	13:53	02:11	LINE FAULT
101	5-Jan-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:42	17:24	05:42	MAIN SUPPLY FAILURE
102	5-Jan-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	12:40	13:42	01:02	LINE CLEAR AVAILED
103	5-Jan-2021	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	17:10	17:54	00:44	HAND TRIPPED
104	5-Jan-2021	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	21:33 (3.01.2021)	7:13 (5.01.2021)	31:12 hrs	LINE CHARGED
105	5-Jan-2021	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	11:34	15:32	03:58	NFBC ISSUED
106	5-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:10 (4.01.2021)	7:20 (05.01.2021)	8:09 hrs	LINE CHARGED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
107	5-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN:LINE CLEAR AVAILED
108	5-Jan-2021	MYSORE	66	ADDIHALLI-NAGMANGLA	ADDIHALLI_66	10:06	16:16	6:09	LINE CLEAR AVAILED
109	5-Jan-2021	MYSORE	66	BANNUR-MALIYUR	BANNUR_66	17:51	17:53	0:02	HAND TRIPPED
110	5-Jan-2021	MYSORE	66	BANNUR-VAJMANGALA	BANNUR_66	17:50	17:53	0:02	HAND TRIPPED
111	5-Jan-2021	MYSORE	66	HANAGODU-HUNSUR	NO STATION EFFECTED	9:35	18:36	9:01	NFBC ISSUED
112	5-Jan-2021	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66 KALAMANDIRA_66	14:07	15:19	1:12	LINE FAULT
113	5-Jan-2021	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66	10:35	17:20	6:45	NFBC ISSUED
114	5-Jan-2021	MYSORE	66	HUNSUR-ELAWALA	HUNSUR_66 GAVADAGERE_66	10:09	18:16	8:06	LINE CLEAR AVAILED
115	5-Jan-2021	MYSORE	66	HUNSUR-HOOTAGALLI	HUNSUR_66 HOSURGATE_66	10:09	18:22	8:13	LINE CLEAR AVAILED
116	5-Jan-2021	MYSORE	66	HV1	BANNUR_66	4:47	5:19	0:32	LINE CLEAR AVAILED
117	5-Jan-2021	MYSORE	66	HV1	BANNUR_66	11:24	11:51	0:26	LINE CLEAR AVAILED
118	5-Jan-2021	MYSORE	66	HV1	BANNUR_66	15:30	17:53	2:23	LINE CLEAR AVAILED
119	5-Jan-2021	MYSORE	66	HV1	MALAVALLI_66	7:57	19:02	11:04	LINE CLEAR AVAILED
120	5-Jan-2021	MYSORE	66	HV1	SANIVARASANTHE_66	10:52	16:00	5:07	LINE CLEAR AVAILED
121	5-Jan-2021	MYSORE	66	HV2	MADHUVANAHALLI_220	12:28	13:08	0:40	LINE CLEAR AVAILED
122	5-Jan-2021	MYSORE	66	HV2	MALAVALLI_66	7:57	19:02	11:04	LINE CLEAR AVAILED
123	5-Jan-2021	MYSORE	66	HV3	KRPET_66	12:14 (04.01.20201)			TRANSFORMER OPEN:LINE CLEAR AVAILED
124	5-Jan-2021	MYSORE	66	JYOTHINAGARA-DK MAIDANA	DKMAIDANA_66	7:26	7:46	0:19	LINE FAULT
125	5-Jan-2021	MYSORE	66	MADHUVANAHALLI-HANNUR 2	NO STATION EFFECTED	17:22	17:27	0:04	LINE FAULT
126	5-Jan-2021	MYSORE	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	18:19	18:29	0:10	LINE FAULT
127	5-Jan-2021	MYSORE	66	MADHUVANAHALLI-MAMBALLY	MAMBALLI_66	13:28	13:34	0:06	LINE FAULT
128	5-Jan-2021	MYSORE	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYASRAJPURA_66 CHIDRAVALLI_66 BGPURA_66	15:14	15:25	0:11	LINE FAULT
129	5-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	15:02	18:01	2:58	LINE CLEAR AVAILED
130	5-Jan-2021	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	8:22	9:27	1:04	LINE FAULT
131	5-Jan-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	3:14	3:39	0:25	HAND TRIPPED
132	5-Jan-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	18:12	18:38	0:26	HAND TRIPPED
133	5-Jan-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	20:24	20:32	0:08	HAND TRIPPED
134	5-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	3:20	3:40	0:20	HAND TRIPPED
135	5-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	18:12	18:39	0:26	HAND TRIPPED
136	5-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	20:23	21:34	1:11	LINE CLEAR AVAILED
137	5-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	19:06	20:23	1:16	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
138	5-Jan-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	7:07	7:15	0:07	LINE FAULT
139	5-Jan-2021	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	8:09	9:19	1:09	LINE CLEAR AVAILED
140	5-Jan-2021	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR1	WELSPUN SOLAR 1_IPP_66	12:41	14:52	2:11	LINE FAULT
141	5-Jan-2021	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR2	WELSPUN SOLAR_IPP_66	7:15	10:56	3:41	LINE FAULT
142	5-Jan-2021	TUMKUR	66	TR-1	SOKKE_66	18:40	18:46	0:05	HAND TRIPPED
143	5-Jan-2021	TUMKUR	66	TR-2	BENNEHALLI_66	10:32	10:38	0:05	TRANSFORMER FAULT
144	5-Jan-2021	TUMKUR	66	TR-2	HIREGUNTANUR_66	16:12	17:07	0:55	LINE CLEAR AVAILED
145	5-Jan-2021	TUMKUR	66	TR-2	HOLALKERE_66	7:42	8:30	0:48	LINE CLEAR AVAILED
146	5-Jan-2021	TUMKUR	66	TR-3	HARIYABBE_66	10:41	15:18	4:36	LINE CLEAR AVAILED
147	5-Jan-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	16:46	17:04	0:17	TRANSFORMER FAULT
148	5-Jan-2021	TUMKUR	110	TR-1	MAYASANDRA_110	13:07	13:45	0:38	LINE CLEAR AVAILED
149	5-Jan-2021	TUMKUR	110	TR-1	SAMPIGE_110	9:40	12:53	3:12	LINE CLEAR AVAILED
150	5-Jan-2021	TUMKUR	110	TR-2	MAYASANDRA_110	13:49	14:11	0:22	LINE CLEAR AVAILED
151	5-Jan-2021	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	16:42	17:26	0:43	LINE CLEAR AVAILED
152	5-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
153	5-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
154	5-Jan-2021	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	21:45(04.01.202 0)			LINE OPEN:LINE CLEAR AVAILED
155	6-Jan-2021	BAGALKOT	66	66/11KV,HV4	HARIHAR HOSPET_66	07:12	10:47	3:35	LOAD CURTAILMENT
156	6-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
157	6-Jan-2021	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	07:12	07:40	0:28	LOAD CURTAILMENT
158	6-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
159	6-Jan-2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	8:25	09:24	0:59	LOAD CURTAILMENT
160	6-Jan-2021	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	8:04	8:20	0:16	TRANSFORMER FAULT
161	6-Jan-2021	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	10:01	19:04	9:03	LINE CLEAR AVAILED
162	6-Jan-2021	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	10:01	17:35	7:34	LINE CLEAR AVAILED
163	6-Jan-2021	BAGALKOT	110	110/11KV,HV2	GOPANAKOPPA_110	10:01	17:29	7:28	LINE CLEAR AVAILED
164	6-Jan-2021	BAGALKOT	110	110/11KV,HV4	GAJEDRAGAD_110	07:15	07:28	0:13	LOAD CURTAILMENT
165	6-Jan-2021	BAGALKOT	110	110/33KV, HV2	NO STATION AFFECTED HUBLI_220	15:47	21:44	5:57	LINE CLEAR AVAILED
166	6-Jan-2021	BAGALKOT	110	110/33KV, HV2	SAVALAGI_110,HIREPADASALAGI_LI S,TUNGAL LIS,KALABILAGI_33	14:00	15:33	1:33	LINE CLEAR AVAILED
167	6-Jan-2021	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	7:15	7:27	0:12	LOAD CURTAILMENT
168	6-Jan-2021	BAGALKOT	110	110/33KV,HV2 (HV1)	SAVALAGI_110	7:15	7:30	0:15	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
169	6-Jan-2021	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	20:56	21:04	0:08	LINE FAULT
170	6-Jan-2021	BAGALKOT	110	BAGALKOT220-KALADAGI	KALADAGI_110	12:10	12:59	0:49	LINE FAULT
171	6-Jan-2021	BAGALKOT	110	BIJAPUR-ENERCON	BIJAPUR_220 (STATION NOT AFFECTED)	08:40	8:47	0:07	LINE FAULT
172	6-Jan-2021	BAGALKOT	110	BYADAGI-SUZLON	BYADAGI_110 (STATION NOT AFFECTED)	10:14	17:52	7:38	LINE CLEAR AVAILED
173	6-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
174	6-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
175	6-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
176	6-Jan-2021	BAGALKOT	110	HALIYAL-GMR SUGARS	HALIYAL_110 (STATION NOT AFFECTED)	09:31	20:02	10:31	LINE CLEAR AVAILED
177	6-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
178	6-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
179	6-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
180	6-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
181	6-Jan-2021	BAGALKOT	110	NAVAGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND_110	15:29 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
182	6-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
183	6-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN :LINE FAULT
184	6-Jan-2021	BAGALKOT	110	RANEBENNUR-BYADAGI	BYADAGI_110	10:10	17:36	7:26	LINE CLEAR AVAILED
185	6-Jan-2021	BAGALKOT	220	220/110KV,HV1,LV1	BAGEWADI_220	16:35 (05.01.2021)	16:42 (06.01.2021)	24:07hrs	TRANSFOERMER CHARGED
186	6-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	(STATION NOT AFFECTED) BELGAUM_220	20:36 (06.01.2021)			LOAD CURTAILMENT
187	6-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA1	(STATION NOT AFFECTED) BELGAUM_220	20:34 (06.01.2021)			LOAD CURTAILMENT
188	6-Jan-2021	BAGALKOT	220	DHONI-GADAG1	(STATION NOT AFFECTED) DHONI_400	22:11 (06.01.2021)			LINE OPEN :LINE FAULT
189	6-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
190	6-Jan-2021	BAGALKOT	220	GADAG-DHONI1	(STATION NOT AFFECTED) GADAG_220	22:12 (06.01.2021)			LINE OPEN :LINE FAULT
191	6-Jan-2021	BAGALKOT	220	MK HUBI -NARENDRA 2	STATION NOT AFFECTED MK HUBLI_220	8:44 (05.01.2021)			LINE OPEN :LINE FAULT
192	6-Jan-2021	BAGALKOT	220	NAGJHARI1- HUBLI	NO STATION AFFECTED HUBLI_220	12:13	21:44	9:31	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
193	6-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	4:31 (05.01.2021)	3:24 (06.01.2021)	22:53hrs	LOAD CURTAILMENT
194	6-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	4:47 (06.01.2021)			LOAD CURTAILMENT
195	6-Jan-2021	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVALIED
196	6-Jan-2021	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
197	6-Jan-2021	BENGALURU	66	BRIGADE MEADOWS - SHOBHA CITY	BRIGADE MEADOWS	16:33	16:38	00:05	LOAD CHANGE OVER
198	6-Jan-2021	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	13:33	13:47	00:14	LOAD CHANGE OVER
199	6-Jan-2021	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	12:25	12:45	00:20	LINE CLEAR AVALIED
200	6-Jan-2021	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	13:55	13:59	00:04	LINE CLEAR AVALIED
201	6-Jan-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:59	12:01	00:01	LINE CLEAR AVALIED
202	6-Jan-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	09:58	10:03	00:05	LOAD CHANGE OVER
203	6-Jan-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	19:41	19:57	00:16	LINE CLEAR AVALIED
204	6-Jan-2021	BENGALURU	66	HV1	BRIGADE MEADOWS	10:48	10:52	00:04	LINE CLEAR AVALIED
205	6-Jan-2021	BENGALURU	66	HV1	VIJAYANAGARA	16:15	16:25	00:10	MAIN SUPPLY FAILURE
206	6-Jan-2021	BENGALURU	66	HV1	VIJAYANAGARA	18:20	18:25	00:05	LOAD CHANGE OVER
207	6-Jan-2021	BENGALURU	66	HV1	RMV	16:20	16:24	00:04	LINE CLEAR AVALIED
208	6-Jan-2021	BENGALURU	66	HV1	SHAMARAJU TECH PARK	09:11	09:33	00:22	TRANSFORMER FAULT
209	6-Jan-2021	BENGALURU	66	HV1	HSR LAYOUT	11:49	12:36	00:47	LINE CLEAR AVALIED
210	6-Jan-2021	BENGALURU	66	HV1	SURYANAGAR	22:08	22:43	00:35	TRANSFORMER FAULT
211	6-Jan-2021	BENGALURU	66	HV1	SURYANAGAR	09:27	14:20	04:53	TRANSFORMER FAULT
212	6-Jan-2021	BENGALURU	66	HV2	BRIGADE MEADOWS	13:50	13:51	00:01	LINE CLEAR AVALIED
213	6-Jan-2021	BENGALURU	66	HV2	KUMBALAGODU	12:50	15:06	02:16	LINE CLEAR AVALIED
214	6-Jan-2021	BENGALURU	66	HV2	RMV	17:20	17:25	00:05	TRANSFORMER FAULT
215	6-Jan-2021	BENGALURU	66	HV2	MAASTHI	14:25	14:30	00:05	LINE CLEAR AVALIED
216	6-Jan-2021	BENGALURU	66	HV3	ELECTRONIC CITY	13:48	15:18	01:30	LINE CLEAR AVALIED
217	6-Jan-2021	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	10:18	10:30	00:12	LINE FAULT
218	6-Jan-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODUR	11:17	12:51	01:34	LINE CLEAR AVALIED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
219	6-Jan-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODUR	17:03	18:34	01:31	LINE CLEAR AVAILED
220	6-Jan-2021	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	04:55	05:30	00:35	LINE FAULT
221	6-Jan-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	12:01	12:40	00:38	LINE CLEAR AVAILED
222	6-Jan-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	07:30	07:52	00:22	LOAD CURTAILMENT
223	6-Jan-2021	BENGALURU	66	KOTHIPURA 220kV - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	06:28	07:53	01:25	LINE FAULT
224	6-Jan-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	14:10	14:15	00:05	LOAD CHANGE OVER
225	6-Jan-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	11:50	11:55	00:05	LOAD CHANGE OVER
226	6-Jan-2021	BENGALURU	66	MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66	MANYATHA TECH PARK 66	13:28	14:08	00:40	LINE FAULT
227	6-Jan-2021	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY	NO STATION AFFECTED	15:34	16:25	00:51	LINE FAULT
228	6-Jan-2021	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY	NO STATION AFFECTED	16:25	23:13	06:48	LINE FAULT
229	6-Jan-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	11:48	11:52	00:04	LOAD CHANGE OVER
230	6-Jan-2021	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	17:08	17:12	00:04	LOAD CHANGE OVER
231	6-Jan-2021	BENGALURU	66	REMCO - NRS	NO STATION AFFECTED	16:15	16:25	00:10	LINE FAULT
232	6-Jan-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	11:57	16:00	04:03	LINE CLEAR AVAILED
233	6-Jan-2021	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	13:53	14:09	00:16	MAIN SUPPLY FAILURE
234	6-Jan-2021	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	17:50	17:54	00:04	LOAD CHANGE OVER
235	6-Jan-2021	BENGALURU	66	SHOBHA CITY - HENNUR CROSS	SHOBHA CITY	20:22	20:29	00:07	LOAD CHANGE OVER
236	6-Jan-2021	BENGALURU	66	SHOBHA CITY - MANYATHA TECH PARK 220	SHOBHA CITY	15:33	15:52	00:19	MAIN SUPPLY FAILURE
237	6-Jan-2021	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	09:26	09:30	00:04	LOAD CHANGE OVER
238	6-Jan-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	13:49	17:38	03:49	LINE FAULT
239	6-Jan-2021	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
240	6-Jan-2021	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	17:22	21:03	03:41	LINE FAULT
241	6-Jan-2021	BENGALURU	220	DABUSPET 220 - NELAMANGALA 400	DABUSPET 22	19:28	21:43	02:15	LINE CLEAR AVAILED
242	6-Jan-2021	BENGALURU	220	NELMANGALA 400 - NITTUR	NO STATION AFFECTED	15:46	22:12	06:26	LINE FAULT
243	6-Jan-2021	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	12:53	13:19	00:26	LINE FAULT
244	6-Jan-2021	GULBARGA	110	HV1	KUDITINI_110	07:10	07:15	00:05	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
245	6-Jan-2021	GULBARGA	110	HV1	KUDITINI_110	11:40	20:10	08:30	TRANSFORMER FAULT
246	6-Jan-2021	GULBARGA	110	HV1 & HV2	RAJESHWAR_110	07:10	07:20	00:10	LOAD CURTAILMENT
247	6-Jan-2021	GULBARGA	110	HV2	SINDHANOOR_110	20:20	20:57	00:37	TRANSFORMER FAULT
248	6-Jan-2021	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110,TORANGALLU_110	16:00	17:17	01:17	LINE FAULT
249	6-Jan-2021	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMSAGAR_110,HANUMNAL_110,HIREGONNAGAR_110	23:51(6.1.2021)			LINE OPEN :LINE FAULT
250	6-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	05:15	05:25	00:10	LINE FAULT
251	6-Jan-2021	GULBARGA	110	SINDHANOOR-MUDDAPURA	MUDDAPURA_110	20:45	21:00	00:15	LINE FAULT
252	6-Jan-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR110	SINDHANOOR_110,VALKAMDINNI_110	07:50	08:00	00:10	MAIN SUPPLY FAILURE
253	6-Jan-2021	GULBARGA	110	SINDHANOOR-SINDHNOOR	SINDHNOOR_110	07:45	07:55	00:10	LINE CLEAR AVAILED
254	6-Jan-2021	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERA DONA_110,SRNAGAR_110,MALLAPURA_110	14:13	14:23	00:10	LINE FAULT
255	6-Jan-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGUR_110,TEKKALKOTE_110,NSLSUGAR_IPP	12:35	12:45	00:10	LINE FAULT
256	6-Jan-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGUR_110,TEKKALKOTE_110,NSLSUGAR_IPP	14:12	14:22	00:10	LINE FAULT
257	6-Jan-2021	GULBARGA	220	HV1	KUSHTAGI_220	23:51	23:59	00:08	TRANSFORMER FAULT
258	6-Jan-2021	GULBARGA	220	HV1	KUSHTAGI_220	18:54	20:00	01:06	TRANSFORMER FAULT
259	6-Jan-2021	GULBARGA	220	LINGAPUR-ARRESS STEELS	ARRESS STEELS_IPP,HRGSTEELS_IPP	08:38	14:43	06:05	LINE CLEAR AVAILED
260	6-Jan-2021	GULBARGA	220	LINGASUGUR-KUSHTAGI	KUSHTAGI_220	18:54(06.01.2021)			LINE OPEN :LINE FAULT
261	6-Jan-2021	GULBARGA	220	RTPS-LINGSUGUR2	LINGSUGUR_220	09:30	17:31	08:01	NFBC ISSUED
262	6-Jan-2021	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	10:14	13:17	03:03	LINE CLEAR AVAILED
263	6-Jan-2021	GULBARGA	400	JSWL-GUTTUR	JSWL_400	10:14	13:17	03:03	LINE CLEAR AVAILED
264	6-Jan-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	10:59(05.01.2021)	11:29(6.1.2021)	24:30hrs	LINE CHARGED
265	6-Jan-2021	HASSAN	66	HIREMAN-CKM220	HIREMANGALORE_66	09:01	11:28	02:27	MAIN SUPPLY FAILURE
266	6-Jan-2021	HASSAN	66	HV1	HANGRAHALLY_66	07:15	07:36	00:21	TRANSFORMER FAULT
267	6-Jan-2021	HASSAN	66	HV1	HIRISAVE_66	12:53	13:55	01:02	MAIN SUPPLY FAILURE
268	6-Jan-2021	HASSAN	66	HV1	SAKLESHUPURA_66	10:01	17:01	07:00	LINE CLEAR AVAILED
269	6-Jan-2021	HASSAN	66	HV1	S.BELAGOLA_66	07:10	09:24	02:14	TRANSFORMER FAULT
270	6-Jan-2021	HASSAN	66	HV1	MALLAPURA_66	10:14	16:07	05:53	LINE CLEAR AVAILED
271	6-Jan-2021	HASSAN	66	HV2	HIRISAVE_66	12:53	13:55	01:02	MAIN SUPPLY FAILURE
272	6-Jan-2021	HASSAN	66	HV2	SALGAME_66	12:13	13:46	01:33	LINE CLEAR AVAILED
273	6-Jan-2021	HASSAN	66	HV2	MALLAPURA_66	10:14	16:08	05:54	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
274	6-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
275	6-Jan-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
276	6-Jan-2021	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	10:14	16:07	05:53	LINE CLEAR AVAILED
277	6-Jan-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	12:16	12:22	00:06	LINE FAULT
278	6-Jan-2021	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:36	12:37	02:01	LINE CLEAR AVAILED
279	6-Jan-2021	HASSAN	110	HV1	GURUVAYANAKERE_110	10:20	11:48	01:28	LINE CLEAR AVAILED
280	6-Jan-2021	HASSAN	110	HV1	JAVAGAL_110	07:13	07:25	00:12	TRANSFORMER FAULT
281	6-Jan-2021	HASSAN	110	HV2	ESSUR_110	09:38	09:44	00:06	HAND TRIPPED
282	6-Jan-2021	HASSAN	110	HV2	GANDASI_110	07:13	07:30	00:17	TRANSFORMER FAULT
283	6-Jan-2021	HASSAN	110	HV2	GERUMARA_110	07:14	08:08	00:54	TRANSFORMER FAULT
284	6-Jan-2021	HASSAN	110	HV3	GURUVAYANAKERE_110	10:20	11:48	01:28	LINE CLEAR AVAILED
285	6-Jan-2021	HASSAN	110	JOG-JLT4	JOG_110	11:11 (28.12.2020)	11:21 (6.01.2021)	216:10hrs	LINE CHARGED
286	6-Jan-2021	HASSAN	110	JOG-JLT4	JOG_110	11:45	16:37	04:52	NFBC ISSUED
287	6-Jan-2021	HASSAN	110	KADUR-NGNHL	KADUR_220	07:45	09:06	01:21	LINE CLEAR AVAILED
288	6-Jan-2021	HASSAN	110	KADUR-YGTI	KADUR_220	07:45	09:06	01:21	LINE CLEAR AVAILED
289	6-Jan-2021	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	09:33	16:47	07:14	LINE CLEAR AVAILED
290	6-Jan-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	21:42	22:20	00:38	LINE FAULT
291	6-Jan-2021	HASSAN	110	LV1	ARASIKERE_220	11:43	15:20	03:37	LINE CLEAR AVAILED
292	6-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
293	6-Jan-2021	HASSAN	220	ARSK2-HSN	ARASIKERE_220	18:12 (6.01.2021)			LINE OPEN:LINE CLEAR AVAILED
294	6-Jan-2021	HASSAN	220	HV1	ARASIKERE_220	11:43	15:20	03:37	LINE CLEAR AVAILED
295	6-Jan-2021	HASSAN	220	KADUR-DABUSET	KADUR_220	17:21	20:59	03:38	LINE FAULT
296	6-Jan-2021	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	20:37	20:52	00:15	LINE FAULT
297	6-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:35 (6.01.2021)			LINE OPEN:LINE CLEAR AVAILED
298	6-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN:LINE CLEAR AVAILED
299	6-Jan-2021	MYSORE	66	B MATAKERE-BEGUR	B MATKERE_66	10:30	18:00	7:30	LINE CLEAR AVAILED
300	6-Jan-2021	MYSORE	66	B MATAKERE-SARGUR	B MATKERE_66	10:30	17:30	7:00	LINE CLEAR AVAILED
301	6-Jan-2021	MYSORE	66	BEGUR 220-SARGUR	SANTHESARAGUR_66	10:28	17:41	7:13	NFBC ISSUED
302	6-Jan-2021	MYSORE	66	BETTADAPURA-KUSHALNAGARA	BETTADHAPURA_66	10:04	17:01	6:56	LINE CLEAR AVAILED
303	6-Jan-2021	MYSORE	66	BG PURA-CHANDALLY	NO STATIONS EFFECTED	11:35	15:17	3:42	NFBC ISSUED
304	6-Jan-2021	MYSORE	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	12:57	13:21	0:23	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
305	6-Jan-2021	MYSORE	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66 HONNALLY MYS 66	12:57	13:14	0:16	LINE FAULT
306	6-Jan-2021	MYSORE	66	HV 1	BGPURA_66	7:15	7:30	0:15	LOAD CURTAILMENT
307	6-Jan-2021	MYSORE	66	HV1	BILIKERE_66	7:13	7:50	0:37	LOAD CURTAILMENT
308	6-Jan-2021	MYSORE	66	HV1	DMG_HALLI_66	17:06	17:25	0:18	TRANSFORMER FAULT
309	6-Jan-2021	MYSORE	66	HV1	DMG_HALLI_66	22:03	22:12	0:08	TRANSFORMER FAULT
310	6-Jan-2021	MYSORE	66	HV1	SATHEGALA_66	7:15	7:45	0:30	LOAD CURTAILMENT
311	6-Jan-2021	MYSORE	66	HV1	RAMAPURA_MYS_66	7:15	7:48	0:33	LOAD CURTAILMENT
312	6-Jan-2021	MYSORE	66	HV2	KIRUGAVALU_66	7:15	7:44	0:29	LOAD CURTAILMENT
313	6-Jan-2021	MYSORE	66	HV2	KMDODDI_66	7:10	7:32	0:22	LOAD CURTAILMENT
314	6-Jan-2021	MYSORE	66	HV2	AKKIHEBBAL_66	10:46	15:16	4:30	LINE CLEAR AVAILED
315	6-Jan-2021	MYSORE	66	HV3	KRPET_66	12:14 (04.01.20201)	17:26	29:12HRS	TRANSFOERMER CHARGED
316	6-Jan-2021	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR 66	18:42	18:47	0:05	LINE FAULT
317	6-Jan-2021	MYSORE	66	KADAKOLA-SARGUR 2	NO STATIONS EFFECTED	18:42	18:47	0:05	LINE FAULT
318	6-Jan-2021	MYSORE	66	KIRUGAVALU-MALIYUR	KIRUGAVALU_66 VADKEPURA_66	18:10	18:20	0:09	LINE FAULT
319	6-Jan-2021	MYSORE	66	KR PETE 220-BOOKANKERE	SHEELUNERE_66, GANJIGERE_66, BOOKANAKERE_66, BANANGADI 66 CHINAKURALI 66	11:35	11:40	0:05	LINE FAULT
320	6-Jan-2021	MYSORE	66	KUSHALNAGARA-PERIYAPATNA 1	NO STATIONS EFFECTED	22:30	22:38	0:08	LINE FAULT
321	6-Jan-2021	MYSORE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	18:13	18:21	0:07	LINE FAULT
322	6-Jan-2021	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	12:47	12:53	0:06	LINE FAULT
323	6-Jan-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALLI_66	7:43	8:31	0:48	HAND TRIPPED
324	6-Jan-2021	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,	8:45	9:46	1:00	LINE CLEAR AVAILED
325	6-Jan-2021	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	13:11	14:00	0:49	HAND TRIPPED
326	6-Jan-2021	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI 66	7:11	7:22	0:10	HAND TRIPPED
327	6-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	9:06	9:30	0:24	LOAD CURTAILMENT
328	6-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	15:03	18:14	3:11	LINE CLEAR AVAILED
329	6-Jan-2021	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	9:06	15:04	5:58	LINE CLEAR AVAILED
330	6-Jan-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	6:42	6:56	0:14	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
331	6-Jan-2021	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	MADHUGIRI_66	11:26	15:13	3:47	LINE CLEAR AVAILED
332	6-Jan-2021	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66	11:26	15:13	3:46	LINE CLEAR AVAILED
333	6-Jan-2021	TUMKUR	66	NEELAGUNDA 220kV- HULUVAGALU	HALUVAGALU_66	12:02	21:37	9:35	LINE CLEAR AVAILED
334	6-Jan-2021	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:28	10:51	0:22	TRANSFORMER FAULT
335	6-Jan-2021	TUMKUR	66	TR-1	LINGADAHALLI_TM2_66	9:38	11:02	1:23	LINE CLEAR AVAILED
336	6-Jan-2021	TUMKUR	66	TR-1	PAVAGADA_220	16:18	17:02	0:43	LINE CLEAR AVAILED
337	6-Jan-2021	TUMKUR	66	TR-2	BENKIKERE_66	15:59	16:17	0:18	TRANSFORMER FAULT
338	6-Jan-2021	TUMKUR	66	TR-2	MADHUGIRI_66	15:12	15:19	0:06	LINE CLEAR AVAILED
339	6-Jan-2021	TUMKUR	66	TR-3	HARIYABBE_66	9:18	15:46	6:27	LINE CLEAR AVAILED
340	6-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
341	6-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
342	6-Jan-2021	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	22:32:00(06.01.2 021)			LINE OPEN :LINE FAULT
343	6-Jan-2021	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	15:46	22:32	6:45	LINE FAULT
344	6-Jan-2021	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	18:00	19:36	1:36	LINE CLEAR AVAILED
345	6-Jan-2021	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	21:45(04.01.202 0)			LINE OPEN:LINE CLEAR AVAILED
346	07-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
347	07-Jan-21	BAGALKOT	110	110/11KV, HV1	HIDAKAL DAM_110	15:14	15:16	0:02	LINE CLEAR AVAILED
348	07-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
349	07-Jan-21	BAGALKOT	110	110/11KV,HV1	SIRSI_110	3:59	4:11	0:12	TRANSFORMER FAULT
350	07-Jan-21	BAGALKOT	110	110/11KV,HV1	SATTI_110	11:59	12:10	0:11	HAND TRIPPED
351	07-Jan-21	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	15:14	16:22	1:08	LINE CLEAR AVAILED
352	07-Jan-21	BAGALKOT	110	110/11KV,HV2	TARIHAL_110	6:40	12:20	5:40	TRANSFORMER FAULT
353	07-Jan-21	BAGALKOT	110	ANKOLA_KUMTA (L2)	STATION NOT AFFECTED KUMTA_110	2:10	11:54	9:44	LINE FAULT
354	07-Jan-21	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
355	07-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
356	07-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
357	07-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
358	07-Jan-21	BAGALKOT	110	HUBLI-TARIHAL1	STATION NOT AFFECTED HUBLI_220	10:20	14:10	3:50	LINE CLEAR AVAILED
359	07-Jan-21	BAGALKOT	110	HUBLI-TARIHAL2	STATION NOT AFFECTED HUBLI_220	7:50	14:10	6:20	LINE FAULT
360	07-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
361	07-Jan-21	BAGALKOT	110	HUNGUND-KUDALASANGAM	STATION NOT AFFECTED KUDALASANGAM_110	17:10	17:30	0:20	HAND TRIPPED
362	07-Jan-21	BAGALKOT	110	JOG2-SIRSI	STATION NOT AFFECTED SIRSI_110	16:38	16:41	0:03	HAND TRIPPED
363	07-Jan-21	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
364	07-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
365	07-Jan-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	15:21	16:05	0:44	LOAD CHANGE OVER
366	07-Jan-21	BAGALKOT	110	NAVAGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND_110	15:29 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
367	07-Jan-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
368	07-Jan-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN :LINE FAULT
369	07-Jan-21	BAGALKOT	110	STATION NOT AFFECTED AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED HALIYAL_110	05:56	09:56	4:00	LINE CLEAR AVAILED
370	07-Jan-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	6:27	17:02	10:35	LINE CLEAR AVAILED
371	07-Jan-21	BAGALKOT	110	UGAR SUGARS-UGAR KHUD	UGAR KHUD_110	23:14 (07.01.2021)			LINE OPEN :LINE FAULT
372	07-Jan-21	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED KARWAR_220	15:12	18:10	2:58	LINE CLEAR AVAILED
373	07-Jan-21	BAGALKOT	220	220/110KV,HV2	HUBLI_220	12:19	12:25	0:06	HAND TRIPPED
374	07-Jan-21	BAGALKOT	220	BAGALKOT-GADAG2	STATION NOT AFFECTED BAGALKOT_220	3:48	8:55	5:07	LINE CLEAR AVAILED
375	07-Jan-21	BAGALKOT	220	BELGAUM-CHIKKODI1	(STATION NOT AFFECTED) BELGAUM_220	20:36 (06.01.2021)	7:06 (07.01.2021)	10:30 HRS	LINE CHARGED
376	07-Jan-21	BAGALKOT	220	BELGAUM-NARENDRA1	(STATION NOT AFFECTED) BELGAUM_220	20:34 (06.01.2021)	7:05 (07.01.2021)	10:31 HRS	LINE CHARGED
377	07-Jan-21	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	12:21	15:47	3:26	LINE CLEAR AVAILED
378	07-Jan-21	BAGALKOT	220	DHONI-GADAG1	(STATION NOT AFFECTED) DHONI_400	22:11 (06.01.2021)			LINE OPEN :LINE FAULT
379	07-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
380	07-Jan-21	BAGALKOT	220	GADAG-DHONI1	(STATION NOT AFFECTED) GADAG_220	22:12 (06.01.2021)			LINE OPEN :LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
381	07-Jan-21	BAGALKOT	220	HUBLI-NAGJHARI3	STATION NOT AFFECTED HUBLI_220	12:19	15:57	3:38	LINE CLEAR AVAILED
382	07-Jan-21	BAGALKOT	220	MK HUBI -NARENDRA 2	STATION NOT AFFECTED MK HUBLI_220	8:44 (05.01.2021)	12:11 (07.01.2021)	27:27 HRS	LINE CHARGED
383	07-Jan-21	BAGALKOT	220	MK HUBLI-NARENDRA1	STATION NOT AFFECTED MK HUBLI_220	8:39	11:10	2:31	LINE CLEAR AVAILED
384	07-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	4:47 (06.01.2021)	6:15 (07.01.2021)	25:28 HRS	LINE CHARGED
385	07-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	7:15 (07.01.2021)			LOAD CURTAILMENT
386	07-Jan-21	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
387	07-Jan-21	BENGALURU	66	BEGUR 220 - VIDYANAGARA	VIDYANAGARA,HENNUR CROSS	17:57	18:11	00:14	LINE FAULT
388	07-Jan-21	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
389	07-Jan-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	16:18	16:34	00:16	LOAD CHANGE OVER
390	07-Jan-21	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	SHOBHA CITY	19:28	19:32	00:04	LOAD CHANGE OVER
391	07-Jan-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	17:57	18:06	00:09	MAIN SUPPLY FAILURE
392	07-Jan-21	BENGALURU	66	HV1	KORAMANGALA 220	11:35	11:45	00:10	LINE CLEAR AVAILED
393	07-Jan-21	BENGALURU	66	HV1	KOLAR 220	20:35	20:51	00:16	TRANSFORMER FAULT
394	07-Jan-21	BENGALURU	66	HV1	MAASTHI	16:12	17:29	01:17	LINE CLEAR AVAILED
395	07-Jan-21	BENGALURU	66	HV1	SURYANAGARA	01:53	03:39	01:46	TRANSFORMER FAULT
396	07-Jan-21	BENGALURU	66	HV1	VIJAYAPURA	09:42	09:45	00:03	LINE CLEAR AVAILED
397	07-Jan-21	BENGALURU	66	HV2	ST.JOHNS WOOD	09:44	09:53	00:09	TRANSFORMER FAULT
398	07-Jan-21	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	07:11	07:16	00:05	LOAD CHANGE OVER
399	07-Jan-21	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	00:08	00:30	00:22	MAIN SUPPLY FAILURE
400	07-Jan-21	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA, WIDIA(EHT)	06:13	07:40	01:27	LINE FAULT
401	07-Jan-21	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT	06:13	06:45	00:32	LINE FAULT
402	07-Jan-21	BENGALURU	66	SRS PEENYA 220 - NRS 2	NO STATION AFFECTED	00:08	04:22	04:14	LINE FAULT
403	07-Jan-21	BENGALURU	66	SRS PEENYA 220 - NRS 2	NO STATION AFFECTED	04:22	07:00	02:38	LINE FAULT
404	07-Jan-21	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
405	07-Jan-21	GULBARGA	110	HV1	KURUKUNTA_110	13:00	14:30	01:30	LINE CLEAR AVAILED
406	07-Jan-21	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMSAGAR_110,HANUMNAL_110,HIREGONNAGAR_110	23:51(6.1.2021)			LINE OPEN :LINE FAULT
407	07-Jan-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	11:08	11:52	00:44	LINE CLEAR AVAILED
408	07-Jan-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	05:28	05:33	00:05	LINE FAULT
409	07-Jan-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	11:08	11:52	00:44	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
410	07-Jan-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:35	19:47	00:12	LINE FAULT
411	07-Jan-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERA DONA_110,SRNAGAR_110,MALLAP URA_110	05:50	06:20	00:30	LINE CLEAR AVAILED
412	07-Jan-21	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	09:55	17:20	07:25	LINE CLEAR AVAILED
413	07-Jan-21	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	11:11	18:22	07:11	LINE CLEAR AVAILED
414	07-Jan-21	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	14:43	20:01	05:18	NFBC ISSUED
415	07-Jan-21	GULBARGA	220	HUMNABAD-HALBARGA2	HALBARGA_220	03:11	07:28	04:17	LINE CLEAR AVAILED
416	07-Jan-21	GULBARGA	220	HV1	SINDHANOOR_220	04:50	05:45	00:55	TRANSFORMER FAULT
417	07-Jan-21	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	03:00	07:15	04:15	LINE CLEAR AVAILED
418	07-Jan-21	GULBARGA	220	LINGAPUR-ARRESS STEELS	ARRESS STEELS_IPP,HRGSTEELS_IPP	03:00	04:29	01:29	LINE FAULT
419	07-Jan-21	GULBARGA	220	LINGAPUR-BMM ISPAT	BMM ISPAT_IPP	03:00	04:17	01:17	LINE FAULT
420	07-Jan-21	GULBARGA	220	LINGAPUR-BTPS	BTPS_220	03:00	04:19	01:19	LINE FAULT
421	07-Jan-21	GULBARGA	220	LINGAPUR-GUDDAHALLI1,2	GUDDAHALLI_400	03:00	04:08	01:08	LINE FAULT
422	07-Jan-21	GULBARGA	220	LINGAPUR-HALVARTHI	HALVARTHI_220,X-INDIA_IPP	03:00	04:33	01:33	LINE FAULT
423	07-Jan-21	GULBARGA	220	LINGAPUR-JINDAL1,2	JINDAL_220	03:00	04:22	01:22	LINE FAULT
424	07-Jan-21	GULBARGA	220	LINGAPUR-KUSHTAGI	KUSHTAGI_220	03:00	15:04	12:04	LINE FAULT
425	07-Jan-21	GULBARGA	220	LINGAPUR-MUNIRABAD1,2	MUNIRABAD_220	03:00	04:14	01:14	LINE FAULT
426	07-Jan-21	GULBARGA	220	LINGAPUR-SINDHANOOR	SINDHANOOR_220	03:00	04:35	01:35	LINE FAULT
427	07-Jan-21	GULBARGA	220	LINGASUGUR-KUSHTAGI	KUSHTAGI_220	18:54(06.01.2021)	12:35(7.1.2021)	14:41 HRS	LINE CHARGED
428	07-Jan-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	09:29	14:35	05:06	LINE FAULT
429	07-Jan-21	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	1:47(7.1.2021)			LINE OPEN :LINE FAULT
430	07-Jan-21	HASSAN	66	HASSN22-BELUR	HASSAN_220	10:44	12:41	01:57	LINE CLEAR AVAILED
431	07-Jan-21	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	10:44	12:48	02:04	LINE CLEAR AVAILED
432	07-Jan-21	HASSAN	66	HV1	KUDLIGERE_66	13:18	14:51	01:33	LINE CLEAR AVAILED
433	07-Jan-21	HASSAN	66	HV1	RAMPURA_66	11:43	11:47	00:04	TRANSFORMER FAULT
434	07-Jan-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
435	07-Jan-21	HASSAN	66	LV2	HASSAN_220	10:45	12:34	01:49	LINE CLEAR AVAILED
436	07-Jan-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
437	07-Jan-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	20:08(7.1.2021)			LINE OPEN:LINE CLEAR AVAILED
438	07-Jan-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	19:59	22:17	02:18	LINE FAULT
439	07-Jan-21	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	20:16	22:25	02:09	LINE CLEAR AVAILED
440	07-Jan-21	HASSAN	110	HV1	ESSUR_110	11:58	12:03	00:05	LINE CLEAR AVAILED
441	07-Jan-21	HASSAN	110	HV2	PUTTUR_110	15:46	17:03	01:17	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
442	07-Jan-21	HASSAN	110	HV2	ESSUR_110	09:48	10:00	00:12	LINE CLEAR AVAILED
443	07-Jan-21	HASSAN	110	HV2	NERALAKERE_110	00:07	00:31	00:24	TRANSFORMER FAULT
444	07-Jan-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	20:08(7.1.2021)			LINE OPEN :LINE FAULT
445	07-Jan-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	19:59	22:17	02:18	LINE FAULT
446	07-Jan-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	16:19	20:05	03:46	LINE CLEAR AVAILED
447	07-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
448	07-Jan-21	HASSAN	220	AESK2-HSN	ARASIKERE_220	18:12 (6.01.2021)	13:49(7.1.2021)	19:96 HRS	LINE CHARGED
449	07-Jan-21	HASSAN	220	KADUR-DABUSET	KADUR_220	11:18	13:33	02:15	NFBC ISSUED
450	07-Jan-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:52 (7.01.2021)			LINE OPEN:LINE CLEAR AVAILED
451	07-Jan-21	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:40 (7.01.2021)			LINE OPEN:LINE CLEAR AVAILED
452	07-Jan-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	11:43	13:43	02:00	LINE FAULT
453	07-Jan-21	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	10:37	14:28	03:51	NFBC ISSUED
454	07-Jan-21	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	11:43	13:43	02:00	LINE FAULT
455	07-Jan-21	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	09:44	12:51	03:07	LINE CLEAR AVAILED
456	07-Jan-21	HASSAN	220	TLAGU-SGS2	TALAGUPPA_400	09:44	12:51	03:07	LINE CLEAR AVAILED
457	07-Jan-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:35 (6.01.2021)			LINE OPEN:LINE CLEAR AVAILED
458	07-Jan-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN:LINE CLEAR AVAILED
459	07-Jan-21	MYSORE	66	BANNUR-MALIYURU	MALIYURU_66	7:56	8:06	0:09	LINE FAULT
460	07-Jan-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	15:14	15:22	0:07	LINE FAULT
461	07-Jan-21	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	6:18	6:24	0:06	LINE FAULT
462	07-Jan-21	MYSORE	66	HANAGODU-PONNAMPETE	PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66	10:11	17:45	7:34	NFBC ISSUED
463	07-Jan-21	MYSORE	66	HDKOTE-TARAKA	NO STATIONS EFFECTED	3:12	4:57	1:44	LINE FAULT
464	07-Jan-21	MYSORE	66	HDKOTE-TARAKA	NO STATIONS EFFECTED	11:09	17:27	6:18	NFBC ISSUED
465	07-Jan-21	MYSORE	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	9:07	11:41	2:33	LINE CLEAR AVAILED
466	07-Jan-21	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	11:52	13:31	1:39	LINE CLEAR AVAILED
467	07-Jan-21	MYSORE	66	HV1	BETTADHAPURA_66	12:49	13:52	1:03	LINE CLEAR AVAILED
468	07-Jan-21	MYSORE	66	HV1	BGNAGARA_66	11:14	13:32	2:17	LINE CLEAR AVAILED
469	07-Jan-21	MYSORE	66	HV1	DEVANOORMYS_66	16:01	16:14	0:13	TRANSFORMER FAULT
470	07-Jan-21	MYSORE	66	HV1	KIKKERI_66	11:01	16:20	5:18	LINE CLEAR AVAILED
471	07-Jan-21	MYSORE	66	HV2	BETTADHAPURA_66	14:10	15:21	1:11	LINE CLEAR AVAILED
472	07-Jan-21	MYSORE	66	HV2	KADAKOLA_220	12:12	13:50	1:37	LINE CLEAR AVAILED
473	07-Jan-21	MYSORE	66	HV2	KIKKERI_66	16:20	18:08	1:48	LINE CLEAR AVAILED
474	07-Jan-21	MYSORE	66	HV2	PANDAVAPURA_66	10:56	11:21	0:24	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
475	07-Jan-21	MYSORE	66	HV2	SANTHEMARAHALLI_66	11:44	13:03	1:19	LINE CLEAR AVAILED
476	07-Jan-21	MYSORE	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	0:10	0:28	0:18	LINE FAULT
477	07-Jan-21	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	3:06	3:11	0:05	LINE FAULT
478	07-Jan-21	MYSORE	66	KM DODDI-MANDYA	KIADBMANDYA_66, KMDODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	15:09	15:16	0:07	MAIN SUPPLY FAILURE
479	07-Jan-21	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66, PERIYAPATNA_66	10:25	17:35	7:09	NFBC ISSUED
480	07-Jan-21	MYSORE	66	KUSHALNAGARA 220- PERIYAPATNA-1	BYLUKUPPE_66, PERIYAPATNA_66	10:25	17:35	7:09	NFBC ISSUED
481	07-Jan-21	MYSORE	66	MEGHALAPURA-HEBBANI	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	6:43	6:54	0:11	LINE FAULT
482	07-Jan-21	MYSORE	66	SATHEGALA-BPCL	NO STATIONS EFFECTED	13:36	14:54	1:17	LINE CLEAR AVAILED
483	07-Jan-21	MYSORE	66	SATHEGALA-HEBBANI	SATHEGALA_66	13:36	14:54	1:18	LINE CLEAR AVAILED
484	07-Jan-21	MYSORE	66	SATHEGALA-KOLLEGALA	NO STATIONS EFFECTED	12:55	14:50	1:55	LINE CLEAR AVAILED
485	07-Jan-21	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66 MALIYURU_66	7:43	7:52	0:09	LINE FAULT
486	07-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:08	10:24	0:15	LINE FAULT
487	07-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	11:58	12:29	0:31	HAND TRIPPED
488	07-Jan-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	15:01	15:41	0:40	LINE FAULT
489	07-Jan-21	TUMKUR	66	BENKIKERE-NALLUR	BENKIKERE_66	12:43	14:28	1:44	LINE CLEAR AVAILED
490	07-Jan-21	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	04:42	04:51	0:08	LINE FAULT
491	07-Jan-21	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR IPP 66	BPCLSOLAR_IPP_66	18:24	19:03	0:39	LINE FAULT
492	07-Jan-21	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	11:59	12:28	0:29	MAIN SUPPLY FAILURE
493	07-Jan-21	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	15:44	15:48	0:04	MAIN SUPPLY FAILURE
494	07-Jan-21	TUMKUR	66	NEELAGUNDA 220KV- PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHANGI DURGA_66, PALLAGATTE_66, SOKKE_66	15:12	15:52	0:39	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
495	07-Jan-21	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	18:23	18:26	0:02	LINE FAULT
496	07-Jan-21	TUMKUR	66	TR-1	BENKIKERE_66	12:44	14:31	1:46	LINE CLEAR AVAILED
497	07-Jan-21	TUMKUR	66	TR-1	KORA_66	17:19	17:24	0:04	TRANSFORMER FAULT
498	07-Jan-21	TUMKUR	66	TR-1	MYLANAHALLI_66	13:29	15:42	2:13	LINE CLEAR AVAILED
499	07-Jan-21	TUMKUR	66	TR-1	PAVAGADA_220	10:50	10:54	0:03	TRANSFORMER FAULT
500	07-Jan-21	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	10:09	10:15	0:06	HAND TRIPPED
501	07-Jan-21	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	12:29	12:57	0:27	HAND TRIPPED
502	07-Jan-21	TUMKUR	66	TR-2	BENKIKERE_66	12:44	14:22	1:37	LINE CLEAR AVAILED
503	07-Jan-21	TUMKUR	66	TR-2	MATHOD_66	07:49	07:55	0:05	TRANSFORMER FAULT
504	07-Jan-21	TUMKUR	66	TR-2	NYAMATHI_66	16:39	17:35	0:56	LINE CLEAR AVAILED
505	07-Jan-21	TUMKUR	66	TR-2	THIMMASANDRA_66	07:16	07:47	0:31	TRANSFORMER FAULT
506	07-Jan-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	13:08	13:35	0:27	LINE CLEAR AVAILED
507	07-Jan-21	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA 1	ANCHEPALYA_220	15:01	17:11	2:10	LINE CLEAR AVAILED
508	07-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
509	07-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
510	07-Jan-21	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	09:03	09:19	0:15	HAND TRIPPED
511	07-Jan-21	TUMKUR	220	NITTUR 220kv- HASSAN(ARASIKERE)	NITTUR_220	22:32:00(06.01.2 021)	18:21:58 (07.01.2021)	19:49	LINE CLEAR AVAILED
512	07-Jan-21	TUMKUR	220	TR-1	NEELAGUNDA_220	15:57	15:58	0:01	TRANSFORMER FAULT
513	07-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	9:45:16 PM(04.01.2020)			LINE OPEN:LINE CLEAR AVAILED
514	8-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
515	8-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
516	8-Jan-2021	BAGALKOT	110	110/11KV,HV1	KANABARAGI LAYOUT_110	10:21	11:16	0:55	LINE CLEAR AVAILED
517	8-Jan-2021	BAGALKOT	110	110/11KV,HV2	KANABARAGI LAYOUT_110	11:19	13:14	1:55	LINE CLEAR AVAILED
518	8-Jan-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	13:03	14:26	1:23	LINE CLEAR AVAILED
519	8-Jan-2021	BAGALKOT	110	110/33KV,HV3	STATION NOT AFFETED LAXMESHVAR_110	19:08 (08.01.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
520	8-Jan-2021	BAGALKOT	110	110/33KV,HV4	LAKKAMANAHALLI_110, ALNAVAR_33	15:47	15:56	0:09	TRANSFORMER FAULT
521	8-Jan-2021	BAGALKOT	110	AMBEWADI-SUPA 1	STATION NOT AFFETED AMBEWADI_220	10:08	15:33	5:25	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
522	8-Jan-2021	BAGALKOT	110	AMBEWADI-SUPA2	STATION NOT AFFETED AMBEWADI_220	10:08	15:34	5:26	NFBC ISSUED
523	8-Jan-2021	BAGALKOT	110	BANAHATTI-NAVALGI(110KV JAMAKHANDI)	NAVALAGI_110	18:41	19:07	0:26	LINE FAULT
524	8-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
525	8-Jan-2021	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110,NAREGAL_110,RON_ 110,GAJENDRAGAD_110	20:58 (08.01.2021)			LINE OPEN :LINE FAULT
526	8-Jan-2021	BAGALKOT	110	GADAG-BETAGERI	STATION NOT AFFETED GADAG_220	20:58 (08.01.2021)			LINE OPEN :LINE FAULT
527	8-Jan-2021	BAGALKOT	110	GAJENDRAGAD -RON 1& RON 2	GAJENDRGAD_110,RON_110	21:06	21:21	0:15	HAND TRIPPED
528	8-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
529	8-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
530	8-Jan-2021	BAGALKOT	110	HVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
531	8-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
532	8-Jan-2021	BAGALKOT	110	KALAGATAGI-ASPL SOLAR	KALAGATAGI_110	18:39	21:40	3:01	LINE CLEAR AVOIDED
533	8-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
534	8-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
535	8-Jan-2021	BAGALKOT	110	NAVAGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND_110	15:29 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
536	8-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
537	8-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN :LINE FAULT
538	8-Jan-2021	BAGALKOT	110	RON- GAMESHA WIND	RON_110	21:30	21:45	0:15	HAND TRIPPED
539	8-Jan-2021	BAGALKOT	110	SIRSI- JOG1 (SIDDAPUR)	SIDDAPUR_110	17:12	21:36	4:24	LINE FAULT
540	8-Jan-2021	BAGALKOT	110	SIRSI- JOG2	STATION NOT AFFECTED SIRSI_110	17:12 (08.01.2021)			LINE OPEN :LINE FAULT
541	8-Jan-2021	BAGALKOT	110	UGAR SUGARS-UGAR KHUD	UGAR KHUD_110	23:14 (07.01.2021)	3:42 (08.01.2021)	4:28hrs	LINE CHARGED
542	8-Jan-2021	BAGALKOT	220	AMBEWADI-NARENDRA 2	STATION NOT AFFETED AMBEWADI_220	10:40	15:59	5:19	NFBC ISSUED
543	8-Jan-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFETED AMBEWADI_220	14:24 (08.01.2021)			LINE OPEN :LINE FAULT
544	8-Jan-2021	BAGALKOT	220	AMBEWADI-XELDOM (PONDA1)	STATION NOT AFFETED AMBEWADI_220	14:24 (08.01.2021)			LINE OPEN :LINE FAULT
545	8-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	STATION NOT AFFETED BELGAUM_220	20:28 (08.01.2021)			LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
546	8-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA 2(KANBARAGI2)	STATION NOT AFFETED BELGAUM_220	22:27 (08.01.2021)			LOAD CURTAILMENT
547	8-Jan-2021	BAGALKOT	220	CHIKKODI -TALANDAGE (KOLAPUR 1)	CHIKKODI_220	17:52 (08.01.2021)			LINE OPEN :LINE FAULT
548	8-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM 2	STATION NOT AFFETED CHIKKODI_220	20:30 (08.01.2020)			LOAD CURTAILMENT
549	8-Jan-2021	BAGALKOT	220	DHONI 400-GADAG 2	STATION NOT AFFETED DHONI_400	11:01	14:51	3:50	NFBC ISSUED
550	8-Jan-2021	BAGALKOT	220	DHONI-GADAG1	(STATION NOT AFFECTED) DHONI_400	22:11 (06.01.2021)	14:50 (08.01.2021)	40:37hrs	LINE CHARGED
551	8-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
552	8-Jan-2021	BAGALKOT	220	GADAG- DHONI 2 (LINGAPUR 2)	STATION NOT AFFETED GADAG_220	10:54	15:51	4:57	NFBC ISSUED
553	8-Jan-2021	BAGALKOT	220	GADAG-DHONI1	(STATION NOT AFFECTED) GADAG_220	22:12 (06.01.2021)	15:50 (08.01.2021)	41:38hrs	LINE CHARGED
554	8-Jan-2021	BAGALKOT	220	GHATAPRABHA-KUDACHI (CHIKKODI 2)	STATION NOT AFFETED GHATAPRABHA_220	19:52	21:06	1:14	LINE FAULT
555	8-Jan-2021	BAGALKOT	220	HUBLI- NAGJHARI3	STATION NOT AFFECTED HUBLI_220	7:25	18:27	11:02	LINE CLEAR AVAILED
556	8-Jan-2021	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	11:06	19:21	8:15	LINE FAULT
557	8-Jan-2021	BAGALKOT	220	MK HUBLI-NARENDRA 2	STATION NOT AFFETED MK HUBLI_220	9:52	18:42	8:50	NFBC ISSUED
558	8-Jan-2021	BAGALKOT	220	NAGJHARI 2-BIDNAL	STATION NOT AFFETED BIDNAL_220	07:16	19:31	12:15	LINE CLEAR AVAILED
559	8-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	7:15 (07.01.2021)			LOAD CURTAILMENT
560	8-Jan-2021	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
561	8-Jan-2021	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5- 2020)			LINE OPEN :LINE FAULT
562	8-Jan-2021	BENGALURU	66	BYADRAHALLI - T G HALLI	KODIGEHALI	13:05	13:15	00:10	LINE CLEAR AVAILED
563	8-Jan-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALI, CHEEMANGALA	11:35	11:53	00:18	LINE CLEAR AVAILED
564	8-Jan-2021	BENGALURU	66	HV2	GOKULA	21:45	21:54	00:09	LINE CLEAR AVAILED
565	8-Jan-2021	BENGALURU	66	IISC - HEBBAL 220	IISC	17:45	17:49	00:04	LOAD CHANGE OVER
566	8-Jan-2021	BENGALURU	66	IISC - NRS 220	IISC	21:08	21:15	00:07	LOAD CHANGE OVER
567	8-Jan-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	12:04	16:00	03:55	LINE CLEAR AVAILED
568	8-Jan-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALI, BAIRAKURU, NANGALI	12:04	15:45	03:41	LINE CLEAR AVAILED
569	8-Jan-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:04	15:45	03:41	LINE CLEAR AVAILED
570	8-Jan-2021	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	19:11	19:17	00:06	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
571	8-Jan-2021	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	17:11	17:24	00:13	MAIN SUPPLY FAILURE
572	8-Jan-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:00	17:49	07:49	LINE CLEAR AVAILED
573	8-Jan-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:00	17:49	07:49	LINE CLEAR AVAILED
574	8-Jan-2021	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	07:21	07:39	00:17	LINE FAULT
575	8-Jan-2021	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
576	8-Jan-2021	BENGALURU	220	HV2	HEBBALA 220	17:11	19:06	01:55	TRANSFORMER FAULT
577	8-Jan-2021	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	11:10	11:21	00:11	LINE FAULT
578	8-Jan-2021	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	12:08	17:44	05:36	LOAD CHANGE OVER
579	8-Jan-2021	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	12:02	12:17	00:15	LOAD CHANGE OVER
580	8-Jan-2021	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	17:18	17:44	00:26	LOAD CHANGE OVER
581	8-Jan-2021	GULBARGA	110	HV1	HANUMANAL_110	15:00	15:15	00:15	LINE CLEAR AVAILED
582	8-Jan-2021	GULBARGA	110	HV2	SINDHNOOR_110	11:15	12:55	01:40	LINE CLEAR AVAILED
583	8-Jan-2021	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMSAGAR_110,HANUMNAL_110,HIREGONNAGAR_110	23:51(6.1.2021)	14:38(08.01.2021)	38:47HRS	LINE CHARGED
584	8-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	11:57	16:46	04:49	LINE CLEAR AVAILED
585	8-Jan-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:55	16:45	04:50	LINE CLEAR AVAILED
586	8-Jan-2021	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	14:00	17:04	03:04	LINE CLEAR AVAILED
587	8-Jan-2021	GULBARGA	220	HALBARGA-HUMNABAD	HALBARGA_220	16:45	22:20	05:35	NFBC ISSUED
588	8-Jan-2021	GULBARGA	220	JINDAL-LINGAPUR2	LINGAPUR_220	12:17	13:51	01:34	LINE FAULT
589	8-Jan-2021	GULBARGA	220	SINDHNOOR-NIRLOOTI_IPP	SINDHANOOR_220	10:10	17:20	07:10	LINE CLEAR AVAILED
590	8-Jan-2021	GULBARGA	220	SINDHNOOR-SUZLON_IPP	SINDHANOOR_220	10:15	10:30	00:15	LINE FAULT
591	8-Jan-2021	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	1:47(7.1.2021)			LINE OPEN :LINE FAULT
592	8-Jan-2021	HASSAN	66	HV1	CRPATNA_220	10:55	11:46	00:51	LINE CLEAR AVAILED
593	8-Jan-2021	HASSAN	66	HV1	MALLIPATNA_66	12:32	13:04	00:32	LINE CLEAR AVAILED
594	8-Jan-2021	HASSAN	66	HV2	UDAYAPURA_66	08:50	08:57	00:07	TRANSFORMER FAULT
595	8-Jan-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:07 (8.01.2021)			LINE OPEN:LINE CLEAR AVAILED
596	8-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
597	8-Jan-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
598	8-Jan-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	08:25	08:36	00:11	LINE FAULT
599	8-Jan-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	20:58	21:09	00:11	LINE FAULT
600	8-Jan-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	20:08(7.1.2021)	12:23(8.1.2021)	16:74 hrs	LINE CHARGED
601	8-Jan-2021	HASSAN	110	HV1	BARANGI_110	11:02	15:02	04:00	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
602	8-Jan-2021	HASSAN	110	HV2	BARANGI_110	14:19	15:04	00:45	LINE CLEAR AVAILED
603	8-Jan-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	20:08(7.1.2021)	12:21 (8.01.2021)	16:72 hrs	LINE CHARGED
604	8-Jan-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:48	18:09	00:21	HAND TRIPPED
605	8-Jan-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:01	18:03	08:02	LINE CLEAR AVAILED
606	8-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
607	8-Jan-2021	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	08:20	12:18	03:58	LINE CLEAR AVAILED
608	8-Jan-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	09:34	15:20	05:46	NFBC ISSUED
609	8-Jan-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:52 (7.01.2021)			LINE OPEN:LINE CLEAR AVAILED
610	8-Jan-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:40 (7.01.2021)			LINE OPEN:LINE CLEAR AVAILED
611	8-Jan-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	09:34	15:20	05:46	LINE CLEAR AVAILED
612	8-Jan-2021	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	06:48	16:00	09:12	LINE FAULT
613	8-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:35 (6.01.2021)	7:18(8.01.2021)	8:42 hrs	LINE CHARGED
614	8-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:27 (8.01.2021)			LINE OPEN:LINE CLEAR AVAILED
615	8-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:33	15:41	02:08	LINE FAULT
616	8-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN:LINE CLEAR AVAILED
617	8-Jan-2021	MYSORE	66	HV1	DEVANOORMYS_66	10:44	10:53	0:09	TRANSFORMER FAULT
618	8-Jan-2021	MYSORE	66	HV1	VAJAMANGALA_220	10:25	13:45	3:19	LINE CLEAR AVAILED
619	8-Jan-2021	MYSORE	66	HV2	VAJAMANGALA_220	13:30	14:48	1:18	LINE CLEAR AVAILED
620	8-Jan-2021	MYSORE	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	13:46	13:49	0:03	LINE FAULT
621	8-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:55	15:08	0:12	LINE FAULT
622	8-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	19:29	19:32	0:03	HAND TRIPPED
623	8-Jan-2021	TUMKUR	66	BALENAHALLI-FEFCWIND_IPP_66	FEFCWIND_IPP_66	23:12	23:23	0:11	LINE FAULT
624	8-Jan-2021	TUMKUR	66	BEVINAHALLI- JAVAGONDANAHALLI	BEVINAHALLI_66	11:37	11:51	0:13	LINE FAULT
625	8-Jan-2021	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	17:07	17:12	0:05	LINE FAULT
626	8-Jan-2021	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66,CHIT RAHALI_66	17:08	17:15	0:06	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
627	8-Jan-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:33	19:23	0:50	LINE FAULT
628	8-Jan-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	10:18	15:41	5:22	LINE CLEAR AVAILED
629	8-Jan-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	10:19	15:37	5:18	LINE CLEAR AVAILED
630	8-Jan-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:14	18:34	0:19	LINE FAULT
631	8-Jan-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	18:14	18:25	0:11	LINE FAULT
632	8-Jan-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	15:25	15:30	0:05	TRANSFORMER FAULT
633	8-Jan-2021	TUMKUR	66	TR-1	TAVAREKERE(C)_66	11:54	15:03	3:09	LINE CLEAR AVAILED
634	8-Jan-2021	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	14:54	19:21	4:26	LINE CLEAR AVAILED
635	8-Jan-2021	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	17:10	17:11	0:00	TRANSFORMER FAULT
636	8-Jan-2021	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	18:33	18:57	0:24	TRANSFORMER FAULT
637	8-Jan-2021	TUMKUR	66	TR-2	CHITRADURGA_220	17:06	17:14	0:07	LINE CLEAR AVAILED
638	8-Jan-2021	TUMKUR	66	TR-2	HARIYABBE_66	9:47	18:34	8:47	LINE CLEAR AVAILED
639	8-Jan-2021	TUMKUR	66	TR-2	TUMKUR_66	4:44	5:50	1:06	TRANSFORMER FAULT
640	8-Jan-2021	TUMKUR	66	TR-2	TUMKUR_66	5:54	5:58	0:04	TRANSFORMER FAULT
641	8-Jan-2021	TUMKUR	66	TR-3	HARIYABBE_66	10:40	15:43	5:02	LINE CLEAR AVAILED
642	8-Jan-2021	TUMKUR	110	TR-1	KALLUR_110	10:27	17:56	7:29	LINE CLEAR AVAILED
643	8-Jan-2021	TUMKUR	110	TR-3	GUBBI_110	11:44	13:52	2:08	LINE CLEAR AVAILED
644	8-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
645	8-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
646	8-Jan-2021	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	17:06	17:10	0:03	TRANSFORMER FAULT
647	8-Jan-2021	TUMKUR	220	TR-1(HV SIDE)	DAVANGERE_SRS_220	18:33	18:57	0:24	TRANSFORMER FAULT
648	8-Jan-2021	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	21:45(04.01.2020)			LINE OPEN:LINE CLEAR AVAILED
649	9-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
650	9-Jan-2021	BAGALKOT	110	110/11KV, HV2	SHIROL_110	02:00	02:13	0:13	TRANSFORMER FAULT
651	9-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
652	9-Jan-2021	BAGALKOT	110	110/11KV,HV1	BETAGERI_110	19:05	19:13	0:08	TRANSFORMER FAULT
653	9-Jan-2021	BAGALKOT	110	110/11KV,HV1 &HV2	NAVANGAR(B)_110	6:05	18:07	12:02	LINE CLEAR AVAILED
654	9-Jan-2021	BAGALKOT	110	110/11KV,HV2	AKSHAYA COLONY_110	10:15	11:29	1:14	TRANSFORMER FAULT
655	9-Jan-2021	BAGALKOT	110	110/33KV,HV2	UTTUR_110,YADWAD_33, ONTIGODI_33	6:33 (09.01.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
656	9-Jan-2021	BAGALKOT	110	110/33KV,HV3	STATION NOT AFFETED LAXMESHVAR_110	19:08 (08.01.2021)	2:56 (09.01.2021)	7:48hrs	TRANSFOERMER CHARGED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
657	9-Jan-2021	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 & BELGAUM W/S 1,2&3 STAGE	11:43	12:02	0:19	TRANSFORMER FAULT
658	9-Jan-2021	BAGALKOT	110	110/33KV,HV3	NIPPANI_110,BENNDI_33,JATRA_33,MAGNUM_33	1:50	3:16	1:26	TRANSFORMER FAULT
659	9-Jan-2021	BAGALKOT	110	220/110KV,LV 2	STATION NOT AFFECTED MK HUBLI_220	20:08			TRANSFORMER OPEN:LINE CLEAR AVOIDED
660	9-Jan-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	(STATION NOT AFFECTED) AMBEWADI_220	21:53 (09.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
661	9-Jan-2021	BAGALKOT	110	ATHANI220-KSSKN	STATION NOT AFFECTED ATHANI_220	11:41	11:51	0:10	LINE FAULT
662	9-Jan-2021	BAGALKOT	110	BAGALKOT-NAVANAGAR(B)1&2	NAVANAGAR(B)_110	6:01	17:58	11:57	LINE CLEAR AVOIDED
663	9-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
664	9-Jan-2021	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110,NAREGAL_110,RON_110,GAJENDRAGAD_110	20:58 (08.01.2021)	11:44 (9.01.2021)	14:46hrs	LINE CHARGED
665	9-Jan-2021	BAGALKOT	110	GADAG-BETAGERI	STATION NOT AFFECTED GADAG_220	20:58 (08.01.2021)	11:37 (9.01.2021)	14:39hrs	LINE CHARGED
666	9-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
667	9-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
668	9-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVOIDED
669	9-Jan-2021	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	7:37	11:10	3:33	LINE FAULT
670	9-Jan-2021	BAGALKOT	110	HAVERI-AFS(SAVANUR)	STATION NOT AFFECTED SAVANUR_110	7:38	11:02	3:24	LINE FAULT
671	9-Jan-2021	BAGALKOT	110	HAVERI-SAVANUR	SVANUR_110	0:06	0:36	0:30	LINE FAULT
672	9-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVOIDED
673	9-Jan-2021	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110	7:18	7:40	0:22	LINE FAULT
674	9-Jan-2021	BAGALKOT	110	KALGHATGI-ASPL (KAWALAWAD)	STATION NOT AFFECTED KALAGHATGI_110	19:12	21:48	2:36	LINE CLEAR AVOIDED
675	9-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT-NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
676	9-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
677	9-Jan-2021	BAGALKOT	110	NAREGAL-BETAGERI	BETAGERI_110	9:51	12:03	2:12	LINE CLEAR AVOIDED
678	9-Jan-2021	BAGALKOT	110	NAREGAL-RON	RON_110	9:51	9:55	0:04	HAND TRIPPED
679	9-Jan-2021	BAGALKOT	110	NAVAGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND_110	15:29 (05.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
680	9-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
681	9-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN :LINE FAULT
682	9-Jan-2021	BAGALKOT	110	SIRSI- JOG2	STATION NOT AFFECTED SIRSI 110	17:12 (08.01.2021)	11:05 (09.01.2021)	17:53hrs	LINE CHARGED
683	9-Jan-2021	BAGALKOT	110	SIRSI-KUMATA 1	STATION NOT AFFECTED SIRSI 110	15:40 (09.01.2021)			LINE OPEN :LINE FAULT
684	9-Jan-2021	BAGALKOT	110	SIRSI-KUMATA 2	SIRSI_110	09:00	13:18	4:18	LINE CLEAR AVAILED
685	9-Jan-2021	BAGALKOT	110	SOUDATTI220-YARAGATTI	YARAGATTI_110	7:06	8:39	1:33	LINE FAULT
686	9-Jan-2021	BAGALKOT	110	YARAGATTI-KATAKOL	KATAKOL_110	09:44	09:48	0:04	LINE FAULT
687	9-Jan-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFETED AMBEWADI 220	14:24 (08.01.2021)	17:24 (09.01.2021)	27:00hrs	LINE CHARGED
688	9-Jan-2021	BAGALKOT	220	AMBEWADI-XELDOM (PONDA1)	STATION NOT AFFETED AMBEWADI 220	14:24 (08.01.2021)			LINE OPEN :LINE FAULT
689	9-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	STATION NOT AFFETED BELGAUM 220	20:28 (08.01.2021)	8:09 (09.01.2021)	11:41hrs	LINE CHARGED
690	9-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM 220	21:54 (09.01.2021)			LINE OPEN:LINE CLEAR AVAILED
691	9-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA 2(KANBARAGI2)	STATION NOT AFFETED BELGAUM 220	22:27 (08.01.2021)	8:08 (09.01.2021)	9:41hrs	LINE CHARGED
692	9-Jan-2021	BAGALKOT	220	BELGAUM- NARENDRA2(KANABARGI2)	STATION NOT AFFECTED BELGAUM 220	22:01 (09.01.2021)			LINE OPEN:LINE CLEAR AVAILED
693	9-Jan-2021	BAGALKOT	220	CHIKKODI -TALANDAGE (KOLAPUR 1)	CHIKKODI_220	17:52 (08.01.2021)	12:48 (09.01.2021)	12:56hrs	LINE CHARGED
694	9-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM 2	STATION NOT AFFETED CHIKKODI 220	20:30 (08.01.2020)	8:09 (09.01.2021)	11:39hrs	LINE CHARGED
695	9-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI 220	21:54 (09.01.2021)			LINE OPEN:LINE CLEAR AVAILED
696	9-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
697	9-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	7:15 (07.01.2021)			LOAD CURTAILMENT
698	9-Jan-2021	BENGALURU	66	BANASAWADI - HEBBALA 220	BANASAWADI	12:37	12:56	00:19	MAIN SUPPLY FAILURE
699	9-Jan-2021	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
700	9-Jan-2021	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
701	9-Jan-2021	BENGALURU	66	CB PURA I/A - DB PURA 1	NO STATION AFFECTED	12:37	12:55	00:17	LINE FAULT
702	9-Jan-2021	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	12:07	12:14	00:06	LINE FAULT
703	9-Jan-2021	BENGALURU	66	HV1	HAL 220	11:44	12:02	00:18	LINE CLEAR AVAILED
704	9-Jan-2021	BENGALURU	66	HV1	KORAMANGALA 220	06:31	06:40	00:09	LOAD CHANGE OVER
705	9-Jan-2021	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	00:02	00:10	00:08	TRANSFORMER FAULT
706	9-Jan-2021	BENGALURU	66	HV1	KOLAR 220	10:20	18:38	08:18	LINE CLEAR AVAILED
707	9-Jan-2021	BENGALURU	66	HV1	KUNDANA	08:35	09:55	01:20	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
708	9-Jan-2021	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	18:12	18:18	00:06	TRANSFORMER FAULT
709	9-Jan-2021	BENGALURU	66	HV2	BANASAWADI	11:56	12:05	00:09	MAIN SUPPLY FAILURE
710	9-Jan-2021	BENGALURU	66	HV2	KORAMANGALA 220	06:31	06:40	00:09	LOAD CHANGE OVER
711	9-Jan-2021	BENGALURU	66	HV2	MEI LAYOUT	15:17	15:23	00:06	TRANSFORMER FAULT
712	9-Jan-2021	BENGALURU	66	HV2	KOLAR 220	10:20	18:38	08:18	LINE CLEAR AVAILED
713	9-Jan-2021	BENGALURU	66	ITI 220 - BANASAWADI	NO STATION AFFECTED	11:44	12:54	01:10	LINE FAULT
714	9-Jan-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODUR	12:34	13:41	01:07	LINE CLEAR AVAILED
715	9-Jan-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODUR	17:04	17:56	00:52	LINE CLEAR AVAILED
716	9-Jan-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:26	10:30	00:04	LOAD CHANGE OVER
717	9-Jan-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	10:26	10:30	00:04	LOAD CHANGE OVER
718	9-Jan-2021	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	14:05	14:10	00:05	LOAD CHANGE OVER
719	9-Jan-2021	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	12:38	12:46	00:08	MAIN SUPPLY FAILURE
720	9-Jan-2021	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	06:22	06:28	00:06	LOAD CHANGE OVER
721	9-Jan-2021	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
722	9-Jan-2021	BENGALURU	220	HV2	HEBBALA 220	12:37	14:03	01:26	TRANSFORMER FAULT
723	9-Jan-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:57(09.01.2021)			LINE OPEN :LINE FAULT
724	9-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	03:35	03:45	00:10	LINE FAULT
725	9-Jan-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURU DICROSS 110	07:00	07:10	00:10	LINE FAULT
726	9-Jan-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	DHADESUGUR_110,SIRIGUPPA_110, TEKKALKOTE_110,NSLSUGAR_IPP	06:40	06:55	00:15	LINE FAULT
727	9-Jan-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	DHADESUGUR_110,SIRIGUPPA_110, TEKKALKOTE_110,NSLSUGAR_IPP	20:06	20:42	00:36	LINE FAULT
728	9-Jan-2021	GULBARGA	220	LINGAPUR-JVSL2	JVSL_220	10:49	16:52	06:03	NFBC ISSUED
729	9-Jan-2021	GULBARGA	220	RTPS-LINGSUGUR1	LINGSUGUR_220	03:20	12:08	08:48	LINE FAULT
730	9-Jan-2021	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	1:47(7.1.2021)			LINE OPEN :LINE FAULT
731	9-Jan-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:07 (8.01.2021)			LINE OPEN:LINE CLEAR AVAILED
732	9-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
733	9-Jan-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
734	9-Jan-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	17:04	17:09	00:05	LINE FAULT
735	9-Jan-2021	HASSAN	110	SAGARA-LST4	SAGARA_110	10:28	11:00	00:32	NFBC ISSUED
736	9-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
737	9-Jan-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	09:31	12:04	02:33	NFBC ISSUED
738	9-Jan-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:52 (7.01.2021)			LINE OPEN:LINE CLEAR AVAILED
739	9-Jan-2021	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:40 (7.01.2021)			LINE OPEN:LINE CLEAR AVAILED
740	9-Jan-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	09:31	12:14	02:43	LINE CLEAR AVAILED
741	9-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:27 (8.01.2021)	6:46 (9.01.2021)	9:78 hrs	LINE CHARGED
742	9-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:01 (9.01.2021)			LINE OPEN:LINE CLEAR AVAILED
743	9-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN:LINE CLEAR AVAILED
744	9-Jan-2021	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	18:15	18:33	0:18	LINE FAULT
745	9-Jan-2021	MYSORE	66	HV1	BASARALU_66	9:27	15:30	6:02	LINE CLEAR AVAILED
746	9-Jan-2021	MYSORE	66	HV1	DEVANOORMYS_66	11:48	11:56	0:08	TRANSFORMER FAULT
747	9-Jan-2021	MYSORE	66	HV1	DEVANOORMYS_66	15:54	16:07	0:12	TRANSFORMER FAULT
748	9-Jan-2021	MYSORE	66	HV2	BASARALU_66	9:27	17:14	7:46	LINE CLEAR AVAILED
749	9-Jan-2021	MYSORE	66	KOLLEGALA-PARINAMIPURA	NO STATION EFFECTED	13:07	16:14	3:07	LINE CLEAR AVAILED
750	9-Jan-2021	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	16:15	16:20	0:05	LINE FAULT
751	9-Jan-2021	TUMKUR	66	BALENAHALLI-FEFCWIND_IPP_66	FEFCWIND_IPP_66	1:11	7:43	6:31	LINE FAULT
752	9-Jan-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	7:08	7:21	0:13	MAIN SUPPLY FAILURE
753	9-Jan-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:53	11:05	0:12	LINE FAULT
754	9-Jan-2021	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	10:32	10:38	0:05	LINE FAULT
755	9-Jan-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:05	9:21	0:15	LINE FAULT
756	9-Jan-2021	TUMKUR	66	TR-1	BENKIKERE_66	4:36	10:28	5:52	TRANSFORMER FAULT
757	9-Jan-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	8:48	9:34	0:46	LINE CLEAR AVAILED
758	9-Jan-2021	TUMKUR	66	TR-2	HARIYABBE_66	7:11	7:29	0:17	MAIN SUPPLY FAILURE
759	9-Jan-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	8:48	9:34	0:45	LINE CLEAR AVAILED
760	9-Jan-2021	TUMKUR	66	TR-3	HARIYABBE_66	7:11	7:29	0:18	MAIN SUPPLY FAILURE
761	9-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
762	9-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
763	9-Jan-2021	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	21:45(04.01.202 0)			LINE OPEN:LINE CLEAR AVAILED
764	10-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
765	10-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
766	10-Jan-2021	BAGALKOT	110	110/33KV,HV2	UTTUR_110,YADWAD_33,ONTIGOD I_33	6:33 (09.01.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
767	10-Jan-2021	BAGALKOT	110	110/33KV,HV3	NIPPANI_110,BENNDI_33,JATRAT_3 3,MAGNUM_33	17:29	18:29	1:00	TRANSFORMER FAULT
768	10-Jan-2021	BAGALKOT	110	220/110KV,LV 2	MK HUBLI_220	20:08 (10.01.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
769	10-Jan-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	(STATION NOT AFFECTED) AMBEWADI_220	21:53 (09.01.2021)			LINE OPEN:LINE CLEAR AVAILED
770	10-Jan-2021	BAGALKOT	110	BAGALKOT-NAVANAGAR(B)1&2	NAVANAGAR(B)_110	6:01	13:25	7:24	LINE CLEAR AVAILED
771	10-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
772	10-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
773	10-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
774	10-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
775	10-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
776	10-Jan-2021	BAGALKOT	110	KALGHATGI-ASPL (KAWALAWAD)	STATION NOT AFFECTED) KALAGHATGI_110	19:14	20:31	1:17	LINE CLEAR AVAILED
777	10-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
778	10-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
779	10-Jan-2021	BAGALKOT	110	NAVAGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND_110	15:29 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
780	10-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
781	10-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN :LINE FAULT
782	10-Jan-2021	BAGALKOT	110	SIRSI-KUMATA 1	SIRSI_110	15:40 (09.01.2021)	16:45 (10.01.2021)	23:55hrs	LINE CHARGED
783	10-Jan-2021	BAGALKOT	110	SIRSI-KUMATA 2	SIRSI_110	12:10	16:50	4:40	LINE CLEAR AVAILED
784	10-Jan-2021	BAGALKOT	110	SOUDATTI220-YARAGATTI	YARAGATTI_110	8:40	9:28	0:48	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
785	10-Jan-2021	BAGALKOT	220	AMBEWADI-XELDOM (PONDA1)	STATION NOT AFFETED AMBEWADI_220	14:24 (08.01.2021)	16:58 (10.01.2021)	50:34hrs	LINE CHARGED
786	10-Jan-2021	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	13:03	13:16	0:13	LINE FAULT
787	10-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	19:15 (10.01.2021)			LINE OPEN:LINE CLEAR AVAILED
788	10-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	21:54 (09.01.2021)	7:53 (10.01.2021)	9:59hrs	LINE CHARGED
789	10-Jan-2021	BAGALKOT	220	BELGAUM- NARENDRA1&2(KANABARGI1&2)	BELGAUM_220	9:22	19:09	9:47	LINE CLEAR AVAILED
790	10-Jan-2021	BAGALKOT	220	BELGAUM- NARENDRA2(KANABARGI2)	BELGAUM_220	22:01 (09.01.2021)	7:54 (10.01.2021)	9:53hrs	LINE CHARGED
791	10-Jan-2021	BAGALKOT	220	BELGAUM- NARENDRA2(KANABARGI2)	BELGAUM_220	19:17 (10.01.2021)			LINE OPEN:LINE CLEAR AVAILED
792	10-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	19:16 (10.01.2021)			LINE OPEN:LINE CLEAR AVAILED
793	10-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	21:54 (09.01.2021)	7:53 (10.01.2021)	9:59hrs	LINE CHARGED
794	10-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
795	10-Jan-2021	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	22:04 (10.01.2021)			LINE OPEN:LINE CLEAR AVAILED
796	10-Jan-2021	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	09:17	16:18	7:01	LINE CLEAR AVAILED
797	10-Jan-2021	BAGALKOT	220	NAGJHARI 2-BIDNAL	BIDNAL_220	07:04	19:26	12:22	LINE CLEAR AVAILED
798	10-Jan-2021	BAGALKOT	220	NARENDRA-KANABARAGI 1& 2	STATION NOT AFFECTED NARENDRA_220	9:21	19:09	9:48	LINE CLEAR AVAILED
799	10-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	7:15 (07.01.2021)			LOAD CURTAILMENT
800	10-Jan-2021	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
801	10-Jan-2021	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5- 2020)			LINE OPEN :LINE FAULT
802	10-Jan-2021	BENGALURU	66	HOODY 220 - POTTERY ROAD	NO STATION AFFECTED	03:31	04:36	01:05	LINE FAULT
803	10-Jan-2021	BENGALURU	66	HV2	BRIGADE MEADOWS	16:14	16:21	00:07	TRANSFORMER FAULT
804	10-Jan-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	07:11	07:14	00:03	LOAD CHANGE OVER
805	10-Jan-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	07:10	07:14	00:03	LOAD CHANGE OVER
806	10-Jan-2021	BENGALURU	66	KOTHIPURA 220kV - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	09:36	17:12	07:36	LINE CLEAR AVAILED
807	10-Jan-2021	BENGALURU	66	MAASTHI - MALUR 220	MAASTHI, DEVANGONDHI, LAKKUR	11:00	12:09	01:09	MAIN SUPPLY FAILURE
808	10-Jan-2021	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	09:00	20:15	11:15	LINE CLEAR AVAILED
809	10-Jan-2021	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
810	10-Jan-2021	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	NO STATION AFFECTED	02:19	03:46	03:46	LINE FAULT
811	10-Jan-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALU_110,KUDITINI_110,KU RUGOD_110,SHATHVAHANA_IPP,A GARWAL_IPP,SUZLON_IPP,KAMALA PUR_110,MATRI_110,RBNS_FACTO RY	06:12	06:23	00:11	LINE FAULT
812	10-Jan-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IP P,BHALKISUGAR_IPP	16:42	16:55	00:13	LINE FAULT
813	10-Jan-2021	GULBARGA	110	HALBARGA-SANTHPUR	SANTHPUR_110,DONGARGAON_11 0	06:50	06:54	00:04	LINE FAULT
814	10-Jan-2021	GULBARGA	110	JANAWADA-SANTHPUR	SANTHPUR_110,DONGARGAON_11 0	06:50	07:05	00:15	LINE FAULT
815	10-Jan-2021	GULBARGA	110	LV1	RAICHUR_220	12:58	13:05	00:07	TRANSFORMER FAULT
816	10-Jan-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	02:12	02:20	00:08	LINE FAULT
817	10-Jan-2021	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	04:42	04:52	00:10	LINE FAULT
818	10-Jan-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	02:07	02:14	00:07	LINE FAULT
819	10-Jan-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	13:25	18:35	05:10	LINE FAULT
820	10-Jan-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:57(09.01.202 1)	17:09(10.01.20 21)	21:12HRS	LINE CHARGED
821	10-Jan-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	DHADESUGUR_110,SIRIGUPPA_110, TEKALKOTE_110,NSLSUGAR_IPP	22:55	23:07	00:12	LINE FAULT
822	10-Jan-2021	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	1:47(7.1.2021)			LINE OPEN :LINE FAULT
823	10-Jan-2021	HASSAN	66	HV1	HNPURA_66	21:17	21:31	00:14	TRANSFORMER FAULT
824	10-Jan-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	9:07(8.1.2021)	18:03(10.1.202 1)	56:55 hrs	LINE CHARGED
825	10-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
826	10-Jan-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
827	10-Jan-2021	HASSAN	110	HV1	BARANGI_110	11:24	12:48	01:24	LINE CLEAR AVAILED
828	10-Jan-2021	HASSAN	110	HV2	PUTTUR_110	12:06	16:54	04:48	LINE CLEAR AVAILED
829	10-Jan-2021	HASSAN	110	HV2	BAIKAMPADI_110	10:05	16:07	06:02	LINE CLEAR AVAILED
830	10-Jan-2021	HASSAN	110	KADUR-NGNHL	KADUR_220	07:08	08:40	01:32	LINE FAULT
831	10-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
832	10-Jan-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	14:52 (7.01.2021)			LINE OPEN:LINE CLEAR AVAILED
833	10-Jan-2021	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	15:40 (7.01.2021)			LINE OPEN:LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
834	10-Jan-2021	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	14:45	17:39	02:54	LINE FAULT
835	10-Jan-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	14:44	17:39	02:55	LINE FAULT
836	10-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:01 (9.01.2021)			LINE OPEN:LINE CLEAR AVAILED
837	10-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN:LINE CLEAR AVAILED
838	10-Jan-2021	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	6:12	6:23	0:10	LINE FAULT
839	10-Jan-2021	MYSORE	66	HV1	JAKKANAHALLY_66	10:06	12:12	2:05	LINE CLEAR AVAILED
840	10-Jan-2021	MYSORE	66	HV1	JAKKANAHALLY_66	16:16	16:21	0:05	HAND TRIPPED
841	10-Jan-2021	MYSORE	66	HV1	KOLLEGALA_66	11:55	13:25	1:30	LINE CLEAR AVAILED
842	10-Jan-2021	MYSORE	66	HV1	MADESWARAPURA_66	12:59	14:38	1:39	LINE CLEAR AVAILED
843	10-Jan-2021	MYSORE	66	HV2	JAKKANAHALLY_66	7:55	9:05	1:10	LINE CLEAR AVAILED
844	10-Jan-2021	MYSORE	66	HV2	KOLLEGALA_66	15:52	16:23	0:31	LINE CLEAR AVAILED
845	10-Jan-2021	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	18:24	18:31	0:07	LINE FAULT
846	11-Jan-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
847	11-Jan-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
848	11-Jan-21	BAGALKOT	110	110/11KV,HV1	P H COMPOUND_110	15:32	16:20	0:48	LINE CLEAR AVAILED
849	11-Jan-21	BAGALKOT	110	110/11KV,HV2	KUD DHARWAD_110	2:49	02:56	0:07	TRANSFORMER FAULT
850	11-Jan-21	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	4:13	7:32	3:19	LINE CLEAR AVAILED
851	11-Jan-21	BAGALKOT	110	110/33KV,HV2	UTTUR_110, YADWAD_33,ONTIGODI_33	6:33 (09.01.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
852	11-Jan-21	BAGALKOT	110	220/110KV,LV 2	MK HUBLI_220	20:08 (10.01.2020)	7:15(11.01.2021)	10:57	LINE CLEAR AVAILED
853	11-Jan-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	(STATION NOT AFFECTED) AMBEWADI_220	21:53(09.01.2021)	8:43 (11.01.2021)	34:36 hrs	LINE CHARGED
854	11-Jan-21	BAGALKOT	110	BELGAUM220-VADAGOAN	VADAGOAN_110	15:54	15:55	0:01	HAND TRIPPED
855	11-Jan-21	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
856	11-Jan-21	BAGALKOT	110	GHATAPRABHA-GOKAK	GOKAK_110	14:13	14:32	0:19	LINE FAULT
857	11-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
858	11-Jan-21	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
859	11-Jan-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
860	11-Jan-21	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN:LINE CLEAR AVAILED
861	11-Jan-21	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
862	11-Jan-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN :LINE FAULT
863	11-Jan-21	BAGALKOT	110	MK HUBLI-HIRE BAGEWADI_110	HIREBAGEWADI_110	14:33	17:38	3:05	LINE FAULT
864	11-Jan-21	BAGALKOT	110	MRUTHYUNJAYANAGAR-NARENDRA1	STATION NOT AFFECTED MRUTHYUNJAYANAGAR_110	14:05	15:25	1:20	LINE CLEAR AVAILED
865	11-Jan-21	BAGALKOT	110	NARENDRA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED NARENDRA_220	12:50	14:35	1:45	LINE CLEAR AVAILED
866	11-Jan-21	BAGALKOT	110	NAVAGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND_110	15:29 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
867	11-Jan-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
868	11-Jan-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN :LINE FAULT
869	11-Jan-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	19:15 (10.01.2021)	8:32 (11.01.2021)	14:17	LINE CLEAR AVAILED
870	11-Jan-21	BAGALKOT	220	BELGAUM-NARENDRA1(KANABARGI1)	BELGAUM_220	19:17 (10.01.2021)	8:03 (11.01.2021)	12:50	LINE CLEAR AVAILED
871	11-Jan-21	BAGALKOT	220	BIDNAL-NAGJARI2	STATION NOT AFFECTED BIDNAL_220	8:15	18:32	10:17	LINE CLEAR AVAILED
872	11-Jan-21	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	19:16 (10.01.2021)	8:33 (11.01.2021)	14:17	LINE CLEAR AVAILED
873	11-Jan-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
874	11-Jan-21	BAGALKOT	220	HUBLI-NAGJHARI3	STATION NOT AFFECTED HUBLI_220	08:35	18:19	9:44	LINE CLEAR AVAILED
875	11-Jan-21	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	22:04 (10.01.2021)	6:37 (11.01.2021)	8:31	LINE CLEAR AVAILED
876	11-Jan-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	7:15 (07.01.2021)			LOAD CURTAILMENT
877	11-Jan-21	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
878	11-Jan-21	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN :LINE FAULT
879	11-Jan-21	BENGALURU	66	HBR LAYOUT - HEBBALA 220	HBR LAYOUT	08:30	08:35	00:05	LOAD CHANGE OVER
880	11-Jan-21	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	07:46	07:54	00:08	MAIN SUPPLY FAILURE
881	11-Jan-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	07:46	08:28	00:42	LINE FAULT
882	11-Jan-21	BENGALURU	66	HV1	BTM 4TH PHASE	09:05	09:14	00:09	TRANSFORMER FAULT
883	11-Jan-21	BENGALURU	66	HV1	CHATRA	12:15	12:30	00:15	LINE CLEAR AVAILED
884	11-Jan-21	BENGALURU	66	HV1	BAGHMANE WORLD TECH PARK	12:17	12:25	00:08	LINE CLEAR AVAILED
885	11-Jan-21	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN:LINE CLEAR AVAILED
886	11-Jan-21	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	07:27	07:33	00:06	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
887	11-Jan-21	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	08:42	09:20	00:38	LINE FAULT
888	11-Jan-21	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	10:16	14:30	04:14	LINE CLEAR AVAILED
889	11-Jan-21	GULBARGA	110	HV1	RAJESHWAR_110	09:45	09:50	00:05	TRANSFORMER FAULT
890	11-Jan-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	03:59	04:06	00:07	LINE FAULT
891	11-Jan-21	GULBARGA	110	SINDHNOOR-MUNIRABAD1	KARATAGI_110,SRNAGAR,GANGAV ATHI_110,VENKATAGIRI_110	08:21	08:41	00:20	LINE FAULT
892	11-Jan-21	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERA DONA_110,SRNAGAR_110,MALLAP URA_110	01:35	01:45	00:10	LINE FAULT
893	11-Jan-21	GULBARGA	110	SINDHNOOR-RAICHUR2	MANVI_110,MADALAPUR_110,KUR UDICROSS_110	20:10	20:25	00:15	LINE FAULT
894	11-Jan-21	GULBARGA	110	SINDHNOOR-TURVIHAL	TURVIHAL_110	02:55	03:10	00:15	LINE FAULT
895	11-Jan-21	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_IPP	11:15	18:28	07:13	LINE CLEAR AVAILED
896	11-Jan-21	GULBARGA	220	HUMNABAD-HALBARGA	HALBARGA_220	10:35	20:58	10:23	LINE CLEAR AVAILED
897	11-Jan-21	GULBARGA	220	HV2	SHAHAPUR_220	06:10	06:19	00:09	TRANSFORMER FAULT
898	11-Jan-21	GULBARGA	220	HV2	HUMNABAD_220	08:42	09:06	00:24	TRANSFORMER FAULT
899	11-Jan-21	GULBARGA	220	HV2	HUMNABAD_220	09:13	09:18	00:05	TRANSFORMER FAULT
900	11-Jan-21	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	08:36	17:58	09:22	LINE CLEAR AVAILED
901	11-Jan-21	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	1:47(7.1.2021)			LINE OPEN :LINE FAULT
902	11-Jan-21	HASSAN	66	HNPR2-BANDISHETTIHALY	HOLENARASIPURA_220	09:44	10:42	00:58	LINE CLEAR AVAILED
903	11-Jan-21	HASSAN	66	HV1	KANDLI_66	11:45(11.1.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
904	11-Jan-21	HASSAN	66	HV1	BANDISHETTYHALLI_66	14:23	16:07	01:44	LINE CLEAR AVAILED
905	11-Jan-21	HASSAN	66	HV1	BYACHANAHALLI_66	10:48	11:20	00:32	MAIN SUPPLY FAILURE
906	11-Jan-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
907	11-Jan-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
908	11-Jan-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	12:01	12:14	00:13	LINE FAULT
909	11-Jan-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	07:48	10:19	02:31	LINE FAULT
910	11-Jan-21	HASSAN	110	KEMAR-BELMAN	KEMAR_220	10:44	14:50	04:06	LINE CLEAR AVAILED
911	11-Jan-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	07:47	10:20	02:33	LINE FAULT
912	11-Jan-21	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN:LINE CLEAR AVAILED
913	11-Jan-21	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:54	13:43	02:49	LINE CLEAR AVAILED
914	11-Jan-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:52 (7.01.2021)	19:28 (11.01.2021)	100:35 hrs	LINE CHARGED
915	11-Jan-21	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	15:40 (7.01.2021)	19:14 (11.01.2021)	99:33 hrs	LINE CHARGED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
916	11-Jan-21	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	09:49	12:25	02:36	LINE CLEAR AVAILED
917	11-Jan-21	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:54	13:44	02:50	NFBC ISSUED
918	11-Jan-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	03:40	09:07	05:27	LINE FAULT
919	11-Jan-21	HASSAN	220	VARAHI-SHMG3	varahi_gen	09:49	12:25	02:36	LINE CLEAR AVAILED
920	11-Jan-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:01 (9.01.2021)	7:14(11.01.2021)	33:12 hrs	LINE CHARGED
921	11-Jan-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN:LINE CLEAR AVAILED
922	11-Jan-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	6:14	6:20	0:05	LINE FAULT
923	11-Jan-21	MYSORE	66	HANAGODU-PONNAMPETE	NO STATION EFFECTED	11:08	17:50	6:41	LINE CLEAR AVAILED
924	11-Jan-21	MYSORE	66	HEBBANI-MEGHLAPURA	NO STATION EFFECTED	13:04	13:09	0:05	LINE FAULT
925	11-Jan-21	MYSORE	66	HEBBANI-MEGHLAPURA	THUMBLA_66 VYASRAJPURA_66 GARGESHWARI_66 CHIDRAVALLI 66 BGPURA 66	17:54	18:04	0:10	LINE FAULT
926	11-Jan-21	MYSORE	66	HV1	ANEGOLAL_66	10:57 (11.01.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
927	11-Jan-21	MYSORE	66	HV1	DKMAIDANA_66	9:43	9:48	0:04	TRANSFORMER FAULT
928	11-Jan-21	MYSORE	66	HV2	ANEGOLAL_66	11:35	12:05	0:30	LINE CLEAR AVAILED
929	11-Jan-21	MYSORE	66	KUSHALNAGARA 220-BETTADHAPURA	NO STATION EFFECTED	11:03	17:56	6:52	LINE CLEAR AVAILED
930	11-Jan-21	MYSORE	66	KUSHALNAGARA 220-BYLKUPPE	NO STATION EFFECTED	10:18	17:52	7:33	LINE CLEAR AVAILED
931	11-Jan-21	MYSORE	66	KUSHALNAGARA 220-EDCL	NO STATION EFFECTED	10:41	17:51	7:10	LINE CLEAR AVAILED
932	11-Jan-21	MYSORE	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	10:32	17:32	6:59	LINE CLEAR AVAILED
933	11-Jan-21	MYSORE	66	KUSHALNAGARA 220-MYSORE-1	NO STATION EFFECTED	11:03	17:56	6:52	LINE CLEAR AVAILED
934	11-Jan-21	MYSORE	66	KUSHALNAGARA 220-PERIPATNA-1	NO STATION EFFECTED	10:18	17:52	7:33	LINE CLEAR AVAILED
935	11-Jan-21	MYSORE	66	KUSHALNAGARA 220-RAMANATHPURA 1	NO STATION EFFECTED	10:41	18:00	7:19	LINE CLEAR AVAILED
936	11-Jan-21	MYSORE	66	KUSHALNAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	10:32	17:32	6:59	LINE CLEAR AVAILED
937	11-Jan-21	MYSORE	66	MADIKERI-SUNTIKOPPA	SUNTIKOPPA_66	10:01	17:45	7:43	LINE CLEAR AVAILED
938	11-Jan-21	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66	12:51	13:00	0:09	LINE FAULT
939	11-Jan-21	MYSORE	220	CR NAGARA-BEGUR 2	NO STATION EFFECTED	13:20	17:30	4:10	LINE CLEAR AVAILED
940	11-Jan-21	MYSORE	220	HV1	KUSHALNAGARA 220	11:06	17:02	5:55	LINE CLEAR AVAILED
941	11-Jan-21	MYSORE	220	HV2	KUSHALNAGARA 220	11:06	17:03	5:56	LINE CLEAR AVAILED
942	11-Jan-21	MYSORE	220	KADAKOLA-KOZIKODE	NO STATION EFFECTED	8:43	16:15	7:31	NFBC ISSUED
943	11-Jan-21	MYSORE	220	KUSHALNAGARA 220-BASTHIPURA 1	KUSHALANAGARA_66 SOMWARPETE 33	11:44	17:00	5:16	LINE CLEAR AVAILED
944	11-Jan-21	MYSORE	220	KUSHALNAGARA 220-BASTHIPURA 2	KUSHALANAGARA_66 SOMWARPETE 33	11:44	17:00	5:16	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
945	11-Jan-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66,CHIT RAHALLI_66	10:51	11:17	0:26	LINE CLEAR AVAILED
946	11-Jan-21	TUMKUR	66	HIRIYURkV 220kV- SUZLON 2	SUZLON1_IPP_66	11:00	13:03	2:03	LINE CLEAR AVAILED
947	11-Jan-21	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR1	WELSPUN SOLAR 1_IPP_66	6:00	9:49	3:49	LINE FAULT
948	11-Jan-21	TUMKUR	66	RANGANATHAPURA- WLSPNSOLAR2	WELSPUN SOLAR2_IPP_66	6:00	9:00	3:00	LINE FAULT
949	11-Jan-21	TUMKUR	66	THOVINAKERE- ANTHRASANAHALI	THOVINAKERE_66	13:55	15:15	1:20	LINE CLEAR AVAILED
950	11-Jan-21	TUMKUR	66	TR-1	KUNDUR_66	6:00	6:30	0:29	TRANSFORMER FAULT
951	11-Jan-21	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	11:19	11:25	0:05	LINE CLEAR AVAILED
952	11-Jan-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
953	11-Jan-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
954	11-Jan-21	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	9:45:16 PM(04.01.2020)			LINE OPEN:LINE CLEAR AVAILED