

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 19.11.2019 TO 25.11.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	19-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	15:14	23:59	8:45	LINE FAULT
2	19-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	11:09	15:12	4:03	LINE CLEAR AVAILED
3	19-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	15:52	15:56	0:04	HAND TRIPPED
4	19-Nov-19	BAGALKOT	220	ATRIA1-BAGEWADI	BAGEWADI_220	12:50	13:36	0:46	LINE FAULT
5	19-Nov-19	BAGALKOT	220	LINGASUR2-BAGEWADI	BAGEWADI_220	12:47	13:35	0:48	LINE FAULT
6	19-Nov-19	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	BAGEWADI_220,MAMADAPUR_110,NIDAGUNDI_110,MUDDEBI HAL_110,SINDAGI_110	12:47	13:30	0:43	TRANSFORMER FAULT
7	19-Nov-19	BAGALKOT	220	220/110KV,HV1,LV1	SIRSI_220	10:10	18:55	8:45	LINE CLEAR AVAILED
8	19-Nov-19	BAGALKOT	220	220/110KV,HV1,LV1	CHIKKODI_220	9:56	17:18	7:22	LINE CLEAR AVAILED
9	19-Nov-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	18:56	23:59	5:03	LINE CLEAR AVAILED
10	19-Nov-19	BAGALKOT	220	220/110KV,HV1,LV1	SOUDATTI_220	9:06	12:16	3:10	LINE CLEAR AVAILED
11	19-Nov-19	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:40	16:21	3:41	LINE CLEAR AVAILED
12	19-Nov-19	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	11:26	16:40	5:14	LINE CLEAR AVAILED
13	19-Nov-19	BAGALKOT	110	KUDUCHI220-KUDUCHI	KUDUCHI_110	15:08	16:32	1:24	LINE CLEAR AVAILED
14	19-Nov-19	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,HEBBAL_33. KANAGALA_33,ACME SOLAR_33	17:04	17:15	0:11	LINE CLEAR AVAILED
15	19-Nov-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:51	15:33	0:42	LINE FAULT
16	19-Nov-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:51	15:33	0:42	LINE CLEAR AVAILED
17	19-Nov-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	18:28	19:50	1:22	LINE CLEAR AVAILED
18	19-Nov-19	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	15:45	19:49	4:04	LINE FAULT
19	19-Nov-19	BENGALURU	66	HV3	YARANDANAHALLI 220	14:53	15:47	0:54	LINE CLEAR AVAILED
20	19-Nov-19	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANAKUNTE	5:38	5:54	0:16	LINE FAULT
21	19-Nov-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	6:11	6:24	0:13	LINE FAULT
22	19-Nov-19	BENGALURU	66	C STATION - A STATION 220	C STATION	6:20	6:24	0:04	LOAD CHANGEOVER
23	19-Nov-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	15:08	15:20	0:12	MAIN SUPPLY FAILURE
24	19-Nov-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	7:26	7:32	0:06	LINE FAULT
25	19-Nov-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	16:01	16:08	0:07	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
26	19-Nov-19	BENGALURU	66	C STATION - HEBBAL 220	C STATION	5:03	5:08	0:05	LOAD CHANGEVER
27	19-Nov-19	GULBARGA	220	RTPS-LINGASUGUR	LINGASUGUR_220	20:10	20:43	0:33	LINE FAULT
28	19-Nov-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_GLB_110,SRERAMANAG AR_110, YERADONA_110	15:14	15:27	0:13	LINE FAULT
29	19-Nov-19	GULBARGA	110	CHINCHOLI-RNWWND_IPP	CHINCHOLI_110	18:45	21:45	3:00	LINE CLEAR AVAILED
30	19-Nov-19	GULBARGA	110	LINGAPUR -AARESS STELL IPP	LINGAPUR_220	13:21	16:56	3:35	LINE FAULT
31	19-Nov-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	15:02	15:05	0:03	TRANSFORMER FAULT
32	19-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:37	6:37	LINE CLEAR AVAILED
33	19-Nov-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	18:28	23:59	5:31	LINE FAULT
34	19-Nov-19	HASSAN	220	HV2	KEMAR_220	9:50	13:34	3:44	LINE CLEAR AVAILED
35	19-Nov-19	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	18:28	23:59	5:31	LINE FAULT
36	19-Nov-19	HASSAN	110	HV1	BAIKAMPADY_110	14:41	17:12	2:31	LINE CLEAR AVAILED
37	19-Nov-19	HASSAN	110	HV1	BANTWAL_110	9:22	17:06	7:44	LINE CLEAR AVAILED
38	19-Nov-19	HASSAN	110	HV2	BANTWAL_110	9:22	17:06	7:44	LINE CLEAR AVAILED
39	19-Nov-19	HASSAN	110	HV3	BANTWAL_110	9:22	17:06	7:44	LINE CLEAR AVAILED
40	19-Nov-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	9:22	17:08	7:46	LINE CLEAR AVAILED
41	19-Nov-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	8:48	17:29	8:41	LINE CLEAR AVAILED
42	19-Nov-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_!10	15:50	15:58	0:08	MAIN SUPPLY FAILURE
43	19-Nov-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	15:48	15:53	0:05	LINE FAULT
44	19-Nov-19	HASSAN	110	LV2	KEMAR_220	9:49	13:34	3:45	LINE CLEAR AVAILED
45	19-Nov-19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	17:01	17:19	0:18	LINE FAULT
46	19-Nov-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	17:02	17:18	0:16	HAND TRIPPED
47	19-Nov-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	11:07	12:12	1:05	LINE CLEAR AVAILED
48	19-Nov-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	17:03	17:24	0:21	MAIN SUPPLY FAILURE
49	19-Nov-19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	17:02	17:19	0:17	MAIN SUPPLY FAILURE
50	19-Nov-19	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	11:07	12:14	1:07	NFBC ISSUED
51	19-Nov-19	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	10:50	11:29	0:39	LINE CLEAR AVAILED
52	19-Nov-19	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	10:22	12:55	2:33	LINE CLEAR AVAILED
53	19-Nov-19	HASSAN	66	HV2	CHIKMAGALUR_66	16:17	17:37	1:20	LINE CLEAR AVAILED
54	19-Nov-19	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	19:05	19:17	0:12	LINE FAULT
55	19-Nov-19	HASSAN	66	HV1	MAGGE_66	12:04	12:22	0:18	LINE CLEAR AVAILED
56	19-Nov-19	HASSAN	66	HV2	MAGGE_66	12:04	12:22	0:18	LINE CLEAR AVAILED
57	19-Nov-19	MYSORE	66	HV1	DUNDANAHALLI_66	17:05	18:05	1:00	MAIN SUPPLY FAILURE
58	19-Nov-19	MYSORE	66	HV2	DUNDANAHALLI_66	17:05	18:05	1:00	MAIN SUPPLY FAILURE
59	19-Nov-19	MYSORE	66	HV1	DUNDANAHALLI_66	22:55	23:20	0:25	MAIN SUPPLY FAILURE
60	19-Nov-19	MYSORE	66	HV2	DUNDANAHALLI_66	22:55	23:20	0:25	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
61	19-Nov-19	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66, COWDALLI_66, MARTAHALLI_66, RAMAPURA_MYS_66	15:36	17:58	2:21	LINE CLEAR AVAILED
62	19-Nov-19	MYSORE	66	HANNUR-MADHUVANALLI 1	HANNUR_66	16:33	17:58	1:24	LINE CLEAR AVAILED
63	19-Nov-19	MYSORE	66	HANNUR-MADHUVANALLI 2	HANNUR_66	16:40	17:50	1:10	LINE CLEAR AVAILED
64	19-Nov-19	MYSORE	220	HV2	KADAKOLA_220	11:21	13:37	2:16	LINE CLEAR AVAILED
65	19-Nov-19	MYSORE	66	HV2	KRPET_66	15:02	16:37	1:34	LINE CLEAR AVAILED
66	19-Nov-19	MYSORE	220	HV1	MADHUVANAHALLI_220	8:23	14:46	6:23	LINE CLEAR AVAILED
67	19-Nov-19	MYSORE	220	HV2	MADHUVANAHALLI_220	8:23	14:46	6:23	LINE CLEAR AVAILED
68	19-Nov-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:50	11:09	0:19	LINE FAULT
69	19-Nov-19	MYSORE	66	HV1	MADIKERI_66	10:34	16:34	5:59	LINE CLEAR AVAILED
70	19-Nov-19	MYSORE	66	MANDYA-CHIKKMANDYA	BESAGARAHALLI_66, CHIKKA_MANDYA_66, HAMPAPURA_66, KOPPA_66	11:54	12:00	0:06	LINE FAULT
71	19-Nov-19	MYSORE	66	HV1	VIRAJPET_66	14:02	14:14	0:11	TRANSFORMER FAULT
72	19-Nov-19	TUMKUR	110	TR-1	BANDIHALLI_110	10:16	11:18	1:01	LINE CLEAR AVAILED
73	19-Nov-19	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	13:44	13:57	0:12	HAND TRIPPED
74	19-Nov-19	TUMKUR	110	TR-2	SAMPIGE_110	15:14	17:32	2:17	LINE CLEAR AVAILED
75	19-Nov-19	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	17:07	23:06	5:59	LINE FAULT
76	19-Nov-19	TUMKUR	66	BANUVALLI- HONNALLI	NANDIGUDI_66,MALEBENNUR_66	13:01	13:06	0:05	MAIN SUPPLY FAILURE
77	19-Nov-19	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	13:24	15:21	1:57	LINE CLEAR AVAILED
78	19-Nov-19	TUMKUR	66	TR-2	CHITRADURGA_220	11:24	17:43	6:19	LINE CLEAR AVAILED
79	19-Nov-19	TUMKUR	66	TR-2	HIREGUNTANUR_66	13:07	13:15	0:07	TRANSFORMER FAULT
80	19-Nov-19	TUMKUR	66	TR-1	LINGADAHALLY_66	15:10	15:16	0:06	LINE CLEAR AVAILED
81	19-Nov-19	TUMKUR	66	TR-2	LINGADAHALLY_66	15:14	15:56	0:42	LINE CLEAR AVAILED
82	19-Nov-19	TUMKUR	66	TR-1	PAVAGADA_66	13:21	13:46	0:25	LINE CLEAR AVAILED
83	19-Nov-19	TUMKUR	66	TR-2	PAVAGADA_66	13:30	13:47	0:16	LINE CLEAR AVAILED
84	19-Nov-19	TUMKUR	66	TR-2	RANGANATHAPURA_66	9:59	16:19	6:20	LINE CLEAR AVAILED
85	20-Nov-19	BAGALKOT	220	ALAMATTI2-BAGALKOT	BAGALKOT_220	11:42	13:49	2:07	LINE CLEAR AVAILED
86	20-Nov-19	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	10:43	11:28	0:45	LINE CLEAR AVAILED
87	20-Nov-19	BAGALKOT	220	ADPH2-BAGEWADI	BAGEWADI_220	11:27	13:51	2:24	LINE CLEAR AVAILED
88	20-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	11:29	23:59	12:30	LINE CLEAR AVAILED
89	20-Nov-19	BAGALKOT	220	220/110KV,HV1,LV1	CHIKKODI_220	7:26	7:51	0:25	TRANSFORMER FAULT
90	20-Nov-19	BAGALKOT	220	220/110KV,HV1,LV1	CHIKKODI_220	7:54	13:31	5:37	TRANSFORMER FAULT
91	20-Nov-19	BAGALKOT	220	HAVERI220-GUTTUR2	HAVERI_220	11:35	12:44	1:09	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
92	20-Nov-19	BAGALKOT	110	BIDNAL220-P H COMPOUND	P H COMPOUND_110	14:03	15:30	1:27	LINE CLEAR AVAILED
93	20-Nov-19	BAGALKOT	110	110/33KV,HV2	GULEDAGUDDA_110,SHIRUR_33 ,KAMATAGI_33	10:48	11:38	0:50	LINE CLEAR AVAILED
94	20-Nov-19	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	8:44	9:46	1:02	LINE CLEAR AVAILED
95	20-Nov-19	BAGALKOT	110	HIREKERUR-RATTIHALLI	RATTIHALLI_110	12:43	23:59	11:16	LINE CLEAR AVAILED
96	20-Nov-19	BAGALKOT	220	HUBLI-BIDNAL2	HUBLI_220	11:24	15:32	4:08	LINE CLEAR AVAILED
97	20-Nov-19	BAGALKOT	110	HUBLI-PH COMPOUND	P H COMPOUND_110	11:11	16:06	4:55	LINE CLEAR AVAILED
98	20-Nov-19	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	9:04	17:23	8:19	LINE CLEAR AVAILED
99	20-Nov-19	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	9:04	16:59	7:55	LINE CLEAR AVAILED
100	20-Nov-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	9:04	17:02	7:58	LINE CLEAR AVAILED
101	20-Nov-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	9:04	18:10	9:06	LINE CLEAR AVAILED
102	20-Nov-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	9:04	17:20	8:16	LINE CLEAR AVAILED
103	20-Nov-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	9:04	16:55	7:51	LINE CLEAR AVAILED
104	20-Nov-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	9:04	16:49	7:45	LINE CLEAR AVAILED
105	20-Nov-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	9:04	16:38	7:34	LINE CLEAR AVAILED
106	20-Nov-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	9:04	16:45	7:41	LINE CLEAR AVAILED
107	20-Nov-19	BENGALURU	220	HV1	CHINTAMANI 220	9:04	16:30	7:26	LINE CLEAR AVAILED
108	20-Nov-19	BENGALURU	220	HV2	CHINTAMANI 220	9:04	16:30	7:26	LINE CLEAR AVAILED
109	20-Nov-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI, HONNIGANAHALLI	19:34	20:09	0:35	LINE FAULT
110	20-Nov-19	GULBARGA	110	HV1	KOLHAR_110	11:05	17:55	6:50	TRANSFORMER FAULT
111	20-Nov-19	GULBARGA	220	LINGASUGUR-B.BAGEWADI1	B.BAGEWADI_220	14:13	15:39	1:26	LINE CLEAR AVAILED
112	20-Nov-19	GULBARGA	220	HV2	LINGASUGUR_220	2:07	5:40	3:33	TRANSFORMER FAULT
113	20-Nov-19	GULBARGA	110	LINGASUGUR-KAREPOWER_IPP	LINGASUGUR_220	2:07	11:50	9:43	LINE FAULT
114	20-Nov-19	GULBARGA	110	LADHA-RENEWSOLAR_IPP	LADHA_110	18:25	20:10	1:45	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
115	20-Nov-19	GULBARGA	400	JSWVL400-BPS1	BPS_400	10:39	14:46	4:07	NFBC ISSUED
116	20-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	6:24	6:24	LINE CLEAR AVAILED
117	20-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:31	6:31	LINE CLEAR AVAILED
118	20-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:35	23:59	2:24	LINE CLEAR AVAILED
119	20-Nov-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	15:57	16:07	0:10	LINE FAULT
120	20-Nov-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	0:00	15:17	15:17	LINE FAULT
121	20-Nov-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	11:50	13:19	1:29	NFBC ISSUED
122	20-Nov-19	HASSAN	220	KEMAR-KAVOOR3	KEMAR_220	11:49	13:19	1:30	LINE CLEAR AVAILED
123	20-Nov-19	HASSAN	220	KEMAR-NETLAMANDUR	KEMAR_220	15:38	15:52	0:14	LINE FAULT
124	20-Nov-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	15:57	16:07	0:10	LINE FAULT
125	20-Nov-19	HASSAN	220	HV3	MRSMSG_220	9:03	17:36	8:33	LINE CLEAR AVAILED
126	20-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	0:00	15:17	15:17	LINE FAULT
127	20-Nov-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:38	16:21	0:43	LINE FAULT
128	20-Nov-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:38	16:21	0:43	LINE FAULT
129	20-Nov-19	HASSAN	110	KEMAR-Manipal1	KEMAR_220	15:28	15:54	0:26	LINE FAULT
130	20-Nov-19	HASSAN	110	KEMAR-Manipal2	KEMAR_220	15:28	15:55	0:27	LINE FAULT
131	20-Nov-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	15:54	16:22	0:28	LINE FAULT
132	20-Nov-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	15:54	16:22	0:28	LINE FAULT
133	20-Nov-19	HASSAN	110	LV3	MRSMSG_220	9:04	17:37	8:33	LINE CLEAR AVAILED
134	20-Nov-19	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	10:15	10:19	0:04	HAND TRIPPED
135	20-Nov-19	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	15:28	16:02	0:34	MAIN SUPPLY FAILURE
136	20-Nov-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	15:28	16:02	0:34	MAIN SUPPLY FAILURE
137	20-Nov-19	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	15:30	16:06	0:36	MAIN SUPPLY FAILURE
138	20-Nov-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:15	23:59	13:44	LINE CLEAR AVAILED
139	20-Nov-19	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	15:28	15:55	0:27	MAIN SUPPLY FAILURE
140	20-Nov-19	HASSAN	110	MSEZ-GSS31	MSEZ_220	11:44	12:05	0:21	HAND TRIPPED
141	20-Nov-19	HASSAN	110	HV2	PUTTUR_110	10:08	10:48	0:40	LINE CLEAR AVAILED
142	20-Nov-19	HASSAN	110	SAGARA-TAL	SAGARA_110	10:35	12:30	1:55	LINE CLEAR AVAILED
143	20-Nov-19	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	7:05	9:16	2:11	LINE CLEAR AVAILED
144	20-Nov-19	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	9:31	11:07	1:36	LINE CLEAR AVAILED
145	20-Nov-19	HASSAN	66	HASSN220-ARAKALGUD1	HASSAN_220	10:18	11:08	0:50	LINE CLEAR AVAILED
146	20-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	10:40	10:45	0:05	HAND TRIPPED
147	20-Nov-19	HASSAN	66	HV1	MOSALEHOSAHALLY_66	11:54	12:42	0:48	LINE CLEAR AVAILED
148	20-Nov-19	HASSAN	66	HV1	SINGAPURA_66	11:14	11:25	0:11	MAIN SUPPLY FAILURE
149	20-Nov-19	HASSAN	66	HV2	SINGAPURA_66	11:14	11:25	0:11	MAIN SUPPLY FAILURE
150	20-Nov-19	MYSORE	66	HV2	DODDINADUVADI_66	12:36	13:11	0:34	LINE CLEAR AVAILED
151	20-Nov-19	MYSORE	66	HOOTAGALLY-HEBBAL	HEBBAL_66, METAGALLY_66	11:05	14:42	3:36	LINE CLEAR AVAILED
152	20-Nov-19	MYSORE	66	HV1	KIADBMANDYA_66	16:10	16:41	0:31	LINE CLEAR AVAILED
153	20-Nov-19	MYSORE	66	HV2	KIADBMANDYA_66	16:44	17:20	0:36	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
154	20-Nov-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	15:39	16:14	0:34	LINE CLEAR AVAILED
155	20-Nov-19	MYSORE	66	HV2	MADIKERI_66	10:44	13:34	2:50	LINE CLEAR AVAILED
156	20-Nov-19	MYSORE	66	METAGALLY-HEBBAL	METAGALLY_66	14:24	14:48	0:24	LOAD CHANGEOVER
157	20-Nov-19	MYSORE	66	PERIYAPATNA-HANAGODU	HANAGODU_66, PONNAMPET_66, VIRAJPET_66	20:05	20:10	0:05	LINE FAULT
158	20-Nov-19	MYSORE	66	HV1	SINDHUVALLI_66	13:46	14:50	1:03	LINE CLEAR AVAILED
159	20-Nov-19	MYSORE	66	HV2	SINDHUVALLI_66	11:30	13:40	2:10	LINE CLEAR AVAILED
160	20-Nov-19	TUMKUR	110	TR-2	SAMPIGE_110	16:20	17:38	1:18	LINE CLEAR AVAILED
161	20-Nov-19	TUMKUR	66	TR-1	CHANNAGIRI_66	12:17	13:30	1:12	LINE CLEAR AVAILED
162	20-Nov-19	TUMKUR	66	TR-2	HIRIYUR_220	11:50	12:11	0:21	TRANSFORMER FAULT
163	20-Nov-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	11:52	12:40	0:48	HAND TRIPPED
164	20-Nov-19	TUMKUR	66	HIRIYURKV 220kv- SUZLON 2	SUZLON1_IPP_66	11:52	12:40	0:48	HAND TRIPPED
165	20-Nov-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	11:52	12:40	0:48	HAND TRIPPED
166	20-Nov-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	11:52	12:40	0:48	HAND TRIPPED
167	20-Nov-19	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:10	12:13	0:02	LINE FAULT
168	21-Nov-19	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	17:11	17:23	0:12	TRANSFORMER FAULT
169	21-Nov-19	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	14:09	15:10	1:01	LINE CLEAR AVAILED
170	21-Nov-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI1	BIDNAL_220	11:38	14:23	2:45	LINE CLEAR AVAILED
171	21-Nov-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	16:20	23:59	7:39	LINE FAULT
172	21-Nov-19	BAGALKOT	220	220/110KV,HV2&LV2	CHIKKODI_220	8:38	19:42	11:04	LINE CLEAR AVAILED
173	21-Nov-19	BAGALKOT	220	MUDUSHINGI-CHIKKODI	CHIKKODI_220	16:54	23:59	7:05	LINE CLEAR AVAILED
174	21-Nov-19	BAGALKOT	220	TALANDAGI-CHIKKODI	CHIKKODI_220	16:57	23:59	7:02	LINE CLEAR AVAILED
175	21-Nov-19	BAGALKOT	220	MUDUSHINGI-CHIKKODI	CHIKKODI_220	15:30	16:05	0:35	LINE FAULT
176	21-Nov-19	BAGALKOT	220	220/110KV,HV1&LV1	SIRSI_220	13:00	18:00	5:00	LINE CLEAR AVAILED
177	21-Nov-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	13:30	18:06	4:36	LINE CLEAR AVAILED
178	21-Nov-19	BAGALKOT	110	SIRSI220-SIRSI1&2	SIRSI_110	13:42	19:07	5:25	LINE CLEAR AVAILED
179	21-Nov-19	BAGALKOT	110	MFRSOLAR-HIREHAL	HIREHAL_110	10:03	17:17	7:14	LINE CLEAR AVAILED
180	21-Nov-19	BAGALKOT	110	110/11KV,HV1	HIREHAL_110	10:03	17:17	7:14	LINE CLEAR AVAILED
181	21-Nov-19	BAGALKOT	110	110/33KV,HV2	HIREHAL_110,HOLEALLUR_33	10:03	17:17	7:14	LINE CLEAR AVAILED
182	21-Nov-19	BAGALKOT	110	KADANKOPPA-KAVALWADA	KAVALWADA_110	11:22	13:10	1:48	LINE CLEAR AVAILED
183	21-Nov-19	BAGALKOT	110	KADANKOPPA-KAVALWADA	KAVALWADA_110	13:14	13:23	0:09	HAND TRIPPED
184	21-Nov-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	11:26	13:31	2:05	LINE CLEAR AVAILED
185	21-Nov-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	18:16	23:59	5:43	LINE CLEAR AVAILED
186	21-Nov-19	BAGALKOT	110	110/11KV,HV1	KIRUVATTI_110	15:46	16:51	1:05	LINE CLEAR AVAILED
187	21-Nov-19	BAGALKOT	110	110/33KV,HV2	KIRUVATTI_110,YELLAPUR_33	16:55	17:35	0:40	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
188	21-Nov-19	BAGALKOT	110	ANTSLR-KONNUR	KONNUR_110	10:00	16:59	6:59	LINE CLEAR AVAILED
189	21-Nov-19	BAGALKOT	110	110/11KV,HV1	KONNUR_110	10:00	16:59	6:59	LINE CLEAR AVAILED
190	21-Nov-19	BAGALKOT	110	110/33KV,HV2	KONNUR_110,SUEBAN_33KV,EN ORCON_33KV	10:00	16:59	6:59	LINE CLEAR AVAILED
191	21-Nov-19	BAGALKOT	110	SIRSI1&2-KUMTA	KUMTA_110	13:42	14:35	0:53	HAND TRIPPED
192	21-Nov-19	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110	11:56	19:13	7:17	LINE CLEAR AVAILED
193	21-Nov-19	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	10:15	16:51	6:36	LINE CLEAR AVAILED
194	21-Nov-19	BAGALKOT	110	110/11KV,HV1	SIRSI_110	10:08	15:08	5:00	LINE CLEAR AVAILED
195	21-Nov-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	13:40	14:44	1:04	LINE CLEAR AVAILED
196	21-Nov-19	BAGALKOT	110	BAGALKOT220-NAVANAGAR1	NAVANAGAR_110	16:16	16:17	0:01	LINE CLEAR AVAILED
197	21-Nov-19	BAGALKOT	110	HUBLI-KADANKOPPA	KADANKOPPA_110	12:02	12:56	0:54	LINE CLEAR AVAILED
198	21-Nov-19	BENGALURU	66	HV3	CB PURA I/A	9:00	10:30	1:30	LINE CLEAR AVAILED
199	21-Nov-19	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	17:30	17:34	0:04	LOAD CHANGEOVER
200	21-Nov-19	BENGALURU	66	KHB - YELAHANKA 220	KHB	8:45	8:48	0:03	LOAD CHANGEOVER
201	21-Nov-19	BENGALURU	66	KHB - SRS PEENYA 220	KHB	16:48	16:52	0:04	LOAD CHANGEOVER
202	21-Nov-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	5:13	5:21	0:07	LINE FAULT
203	21-Nov-19	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	9:15	9:22	0:07	LOAD CHANGEOVER
204	21-Nov-19	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	16:45	16:54	0:09	LOAD CHANGEOVER
205	21-Nov-19	BENGALURU	66	HV1	CHINTAMANI 66	14:32	14:35	0:03	LINE CLEAR AVAILED
206	21-Nov-19	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	5:51	5:54	0:03	TRANSFORMER FAULT
207	21-Nov-19	BENGALURU	66	HV2	HANUMANTHNAGAR	11:40	11:45	0:05	LINE CLEAR AVAILED
208	21-Nov-19	BENGALURU	66	HV2	HANUMANTHNAGAR	14:10	14:50	0:40	LINE CLEAR AVAILED
209	21-Nov-19	BENGALURU	66	HV2	MATHIKERE	10:13	10:20	0:06	LINE CLEAR AVAILED
210	21-Nov-19	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	18:40	18:45	0:05	LOAD CHANGEOVER
211	21-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:29	7:00	6:31	LINE CLEAR AVAILED
212	21-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:43	6:43	LINE CLEAR AVAILED
213	21-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:57	23:59	2:02	LINE CLEAR AVAILED
214	21-Nov-19	HASSAN	110	HV1	MRSMSG_220	9:29	9:41	0:12	HAND TRIPPED
215	21-Nov-19	HASSAN	110	HV2	MRSMSG_220	9:29	9:41	0:12	HAND TRIPPED
216	21-Nov-19	HASSAN	110	HV3	MRSMSG_220	9:25	9:29	0:04	HAND TRIPPED
217	21-Nov-19	HASSAN	110	HV4	MRSMSG_220	9:25	9:29	0:04	HAND TRIPPED
218	21-Nov-19	HASSAN	110	HV5	MRSMSG_220	9:46	9:49	0:03	HAND TRIPPED
219	21-Nov-19	HASSAN	220	HV1	MSEZ_220	10:29	13:42	3:13	LINE CLEAR AVAILED
220	21-Nov-19	HASSAN	110	LV1	MSEZ_220	10:29	13:43	3:14	LINE CLEAR AVAILED
221	21-Nov-19	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	11:45	12:46	1:01	LINE CLEAR AVAILED
222	21-Nov-19	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	13:10	13:12	0:02	LINE CLEAR AVAILED
223	21-Nov-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:07	13:27	2:20	MAIN SUPPLY FAILURE
224	21-Nov-19	HASSAN	110	HV1	GURUVAYANAKERE_110	10:49	12:54	2:05	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
225	21-Nov-19	HASSAN	110	HV4	GURUVAYANAKERE_110	10:49	12:50	2:01	LINE CLEAR AVAILED
226	21-Nov-19	HASSAN	110	HV2	GURUVAYANAKERE_110	10:49	12:54	2:05	LINE CLEAR AVAILED
227	21-Nov-19	HASSAN	110	HV3	GURUVAYANAKERE_110	10:49	12:54	2:05	LINE CLEAR AVAILED
228	21-Nov-19	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	14:23	14:30	0:07	HAND TRIPPED
229	21-Nov-19	HASSAN	110	HV1	KAVOOR_220	13:22	13:30	0:08	HAND TRIPPED
230	21-Nov-19	HASSAN	110	HV2	KAVOOR_220	13:22	14:00	0:38	HAND TRIPPED
231	21-Nov-19	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	17:03	17:06	0:03	HAND TRIPPED
232	21-Nov-19	HASSAN	110	HV2	KULASHEKHARA_110	10:00	16:30	6:30	LINE CLEAR AVAILED
233	21-Nov-19	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	0:00	2:09	2:09	LINE CLEAR AVAILED
234	21-Nov-19	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	10:02	16:54	6:52	LINE CLEAR AVAILED
235	21-Nov-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	10:44	13:53	3:09	LINE CLEAR AVAILED
236	21-Nov-19	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:33	13:56	3:23	LINE CLEAR AVAILED
237	21-Nov-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	10:11	12:40	2:29	MAIN SUPPLY FAILURE
238	21-Nov-19	HASSAN	66	HV1	DODDAKADANUR_66	10:11	12:42	2:31	MAIN SUPPLY FAILURE
239	21-Nov-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	10:13	12:36	2:23	MAIN SUPPLY FAILURE
240	21-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	10:05	12:38	2:33	LINE CLEAR AVAILED
241	21-Nov-19	HASSAN	66	HNPR2-HNPR2	HOLENARASIPURA_220	10:05	12:38	2:33	LINE CLEAR AVAILED
242	21-Nov-19	HASSAN	66	HV2	HNPURA_66	15:55	17:56	2:01	LINE CLEAR AVAILED
243	21-Nov-19	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	17:38	17:57	0:19	LINE CLEAR AVAILED
244	21-Nov-19	HASSAN	66	HV2	UDAYAPURA_66	12:30	13:00	0:30	LINE CLEAR AVAILED
245	22-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	0:00	8:46	8:46	LINE CLEAR AVAILED
246	22-Nov-19	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	0:00	17:24	17:24	LINE CLEAR AVAILED
247	22-Nov-19	BAGALKOT	220	MUDASHINGI-CHIKKODI	CHIKKODI_220	0:00	15:56	15:56	LINE CLEAR AVAILED
248	22-Nov-19	BAGALKOT	220	TALANDAGI-CHIKKODI	CHIKKODI_220	0:00	15:56	15:56	LINE CLEAR AVAILED
249	22-Nov-19	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	10:46	17:35	6:49	LINE CLEAR AVAILED
250	22-Nov-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGHAD_110	18:20	18:36	0:16	LOAD CURTAILMENT
251	22-Nov-19	BAGALKOT	110	SURYODAY SOLAR-GHATAPRABHA220	GHATAPRABHA_220	9:55	10:12	0:17	LINE FAULT
252	22-Nov-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	9:52	19:34	9:42	LINE CLEAR AVAILED
253	22-Nov-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33	18:20	18:30	0:10	LOAD CURTAILMENT
254	22-Nov-19	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINGAD_33,K ARADI_33,MYTHRA SOLAR_33	8:33	8:39	0:06	TRANSFORMER FAULT
255	22-Nov-19	BAGALKOT	110	BPCL2-ITNAL	ITNAL_110	5:01	5:07	0:06	LINE FAULT
256	22-Nov-19	BAGALKOT	110	110/33KV,HV1	JAMKHANDI_110,HIPPARGI_33K V	11:49	11:56	0:07	TRANSFORMER FAULT
257	22-Nov-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	0:00	10:01	10:01	LINE CLEAR AVAILED
258	22-Nov-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	20:07	23:59	3:52	LINE CLEAR AVAILED
259	22-Nov-19	BAGALKOT	220	220/110KV,HV1	SIRSI_220	10:06	19:54	9:48	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
260	22-Nov-19	BAGALKOT	220	SIRSI-HUBI1&2	SIRSI_220	10:07	19:57	9:50	LINE CLEAR AVAILED
261	22-Nov-19	BAGALKOT	220	JOG1&2-SIRSI1	SIRSI_220	10:08	19:53	9:45	LINE CLEAR AVAILED
262	22-Nov-19	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	10:54	20:24	9:30	LINE CLEAR AVAILED
263	22-Nov-19	BAGALKOT	110	110/11KV,HV1	SIRSI_110	13:06	13:26	0:20	LINE CLEAR AVAILED
264	22-Nov-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	14:17	17:03	2:46	LINE CLEAR AVAILED
265	22-Nov-19	BAGALKOT	110	110/11KV,HV1,HV2.HV3	MUDALAGI_110	10:04	17:25	7:21	LINE CLEAR AVAILED
266	22-Nov-19	BAGALKOT	110	110/11KV,HV2	SANKESKESHWAR_110	18:19	18:29	0:10	LOAD CURTAILMENT
267	22-Nov-19	BAGALKOT	110	110/11KV,HV2	SAVALAGI_110	18:20	18:55	0:35	LINE CLEAR AVAILED
268	22-Nov-19	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	23:09	23:16	0:07	TRANSFORMER FAULT
269	22-Nov-19	BENGALURU	66	HV1	AMARJYOTHI	11:30	11:37	0:07	LOAD CHANGEOVER
270	22-Nov-19	BENGALURU	66	HV1	AMARJYOTHI	14:20	14:24	0:04	LOAD CHANGEOVER
271	22-Nov-19	BENGALURU	66	HV1	KHB	10:25	12:52	2:27	LINE CLEAR AVAILED
272	22-Nov-19	BENGALURU	66	HV2	KHV	12:55	14:10	1:15	LINE CLEAR AVAILED
273	22-Nov-19	BENGALURU	66	KHB - YELAHANKA 220	KHB	12:25	12:50	0:25	LINE CLEAR AVAILED
274	22-Nov-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	6:56	7:06	0:10	LINE FAULT
275	22-Nov-19	GULBARGA	220	HV2	ITTAGI_220	11:47	13:35	1:48	LINE CLEAR AVAILED
276	22-Nov-19	GULBARGA	220	HV1	SEDAM_220	11:59	20:08	8:09	TRANSFORMER FAULT
277	22-Nov-19	GULBARGA	220	HV2	SEDAM_220	18:43	20:08	1:25	TRANSFORMER FAULT
278	22-Nov-19	GULBARGA	110	HV2	HANUMANAL_110	14:00	14:30	0:30	TRANSFORMER FAULT
279	22-Nov-19	GULBARGA	110	SINDHANOOR220-SUZLON1	SINDHANOOR_220	14:33	15:07	0:34	LINE FAULT
280	22-Nov-19	GULBARGA	110	HV2	TAMBRAHALLI_66	5:58	6:28	0:30	LINE CLEAR AVAILED
281	22-Nov-19	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	18:40	22:10	3:30	LINE FAULT
282	22-Nov-19	GULBARGA	66	HV2	CHJHALLI_66	13:50	14:10	0:20	LINE CLEAR AVAILED
283	22-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:59	6:28	5:31	LINE CLEAR AVAILED
284	22-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:15	18:43	7:28	LINE CLEAR AVAILED
285	22-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:43	23:59	1:16	LINE CLEAR AVAILED
286	22-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:11	6:11	LINE CLEAR AVAILED
287	22-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	19:03	23:59	4:56	LINE CLEAR AVAILED
288	22-Nov-19	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	10:25	14:46	4:21	LINE CLEAR AVAILED
289	22-Nov-19	HASSAN	220	HV1	MSEZ_220	9:50	15:40	5:50	LINE CLEAR AVAILED
290	22-Nov-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	10:08	19:52	9:44	LINE CLEAR AVAILED
291	22-Nov-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	10:08	19:53	9:45	LINE CLEAR AVAILED
292	22-Nov-19	HASSAN	220	VARAH1-SHMG3	varahi_gen	10:24	10:47	0:23	LINE CLEAR AVAILED
293	22-Nov-19	HASSAN	110	HV1	KADUR_220	6:46	10:46	4:00	TRANSFORMER FAULT
294	22-Nov-19	HASSAN	110	HV1	MRSMSG_220	9:06	10:17	1:11	LINE CLEAR AVAILED
295	22-Nov-19	HASSAN	110	HV2	MRSMSG_220	9:10	10:18	1:08	LINE CLEAR AVAILED
296	22-Nov-19	HASSAN	110	HV3	MRSMSG_220	10:52	12:40	1:48	LINE CLEAR AVAILED
297	22-Nov-19	HASSAN	110	HV4	MRSMSG_220	10:52	12:41	1:49	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
298	22-Nov-19	HASSAN	110	HV1	BIRUR_110	18:20	18:40	0:20	LOAD CURTAILMENT
299	22-Nov-19	HASSAN	110	HV2	GANDASI_110	18:11	18:24	0:13	LOAD CURTAILMENT
300	22-Nov-19	HASSAN	110	HV1	JAVAGAL_110	18:12	18:22	0:10	LOAD CURTAILMENT
301	22-Nov-19	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	10:38	13:35	2:57	NFBC ISSUED
302	22-Nov-19	HASSAN	110	HV1	BRAHMAVARA_110	18:20	18:24	0:04	LOAD CURTAILMENT
303	22-Nov-19	HASSAN	110	MRSSHM-SS1	MRSMSG_220	11:14	13:17	2:03	LINE CLEAR AVAILED
304	22-Nov-19	HASSAN	110	LV1	MSEZ_220	9:50	15:41	5:51	LINE CLEAR AVAILED
305	22-Nov-19	HASSAN	66	LV1	MRSMSG_220	9:06	10:17	1:11	LINE CLEAR AVAILED
306	22-Nov-19	HASSAN	66	LV2	MRSMSG_220	9:10	10:18	1:08	LINE CLEAR AVAILED
307	22-Nov-19	HASSAN	66	LV3	MRSMSG_220	10:52	12:40	1:48	LINE CLEAR AVAILED
308	22-Nov-19	HASSAN	66	LV4	MRSMSG_220	10:52	12:42	1:50	LINE CLEAR AVAILED
309	22-Nov-19	HASSAN	66	HASSN22-HN PURA	HASSAN_220	8:12	8:38	0:26	LINE FAULT
310	22-Nov-19	HASSAN	66	HASSN22-CRP1	HASSAN_220	8:12	8:40	0:28	LINE FAULT
311	22-Nov-19	HASSAN	66	HASSN22-CRP2	HASSAN_220	8:12	8:41	0:29	LINE FAULT
312	22-Nov-19	HASSAN	66	HASSN22-CRP2	HASSAN_220	9:12	10:31	1:19	LINE CLEAR AVAILED
313	22-Nov-19	HASSAN	66	BANDISH-HNPURA	BANDISHETTYHALLI_66	11:30	18:40	7:10	NFBC ISSUED
314	22-Nov-19	HASSAN	66	HV2	CHIKMAGALUR_66	7:36	23:59	16:23	LINE CLEAR AVAILED
315	22-Nov-19	HASSAN	66	HV1	CHIKMAGALUR_66	14:27	14:50	0:23	MAIN SUPPLY FAILURE
316	22-Nov-19	HASSAN	66	HV1	DIDIGA_66	14:30	14:53	0:23	LINE CLEAR AVAILED
317	22-Nov-19	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	12:30	13:15	0:45	NFBC ISSUED
318	22-Nov-19	HASSAN	66	HV1	DODDAKADANUR_66	12:05	13:15	1:10	NFBC ISSUED
319	22-Nov-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	12:05	13:15	1:10	NFBC ISSUED
320	22-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	12:07	13:23	1:16	LINE CLEAR AVAILED
321	22-Nov-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	12:07	13:24	1:17	LINE CLEAR AVAILED
322	22-Nov-19	HASSAN	66	HV2	HNPUA_66	18:05	18:35	0:30	LINE CLEAR AVAILED
323	22-Nov-19	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	8:10	11:00	2:50	MAIN SUPPLY FAILURE
324	22-Nov-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	18:10	18:20	0:10	LOAD CURTAILMENT
325	22-Nov-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	8:10	10:45	2:35	LINE CLEAR AVAILED
326	22-Nov-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	10:48	11:02	0:14	LINE CLEAR AVAILED
327	22-Nov-19	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMMA_66	8:10	9:20	1:10	MAIN SUPPLY FAILURE
328	22-Nov-19	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMMA_66	10:45	11:05	0:20	HAND TRIPPED
329	22-Nov-19	HASSAN	66	HV2	UDAYAPURA_66	12:45	12:50	0:05	HAND TRIPPED
330	22-Nov-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	18:11	18:16	0:05	LOAD CURTAILMENT
331	22-Nov-19	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	8:10	8:40	0:30	MAIN SUPPLY FAILURE
332	22-Nov-19	HASSAN	66	RAMESWARNAGAR	KIADB_66	8:45	10:35	1:50	LINE CLEAR AVAILED
333	22-Nov-19	MYSORE	66	HV2	BOOKANAKERE_66	18:11	18:21	0:09	LOAD CURTAILMENT
334	22-Nov-19	MYSORE	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66, KOPPA_66	18:52	19:01	0:09	LINE FAULT
335	22-Nov-19	MYSORE	66	HAMPAPURA-BASARALU	BESAGARAHALLI_66, KOPPA_66	19:16	20:07	0:51	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
336	22-Nov-19	MYSORE	66	HV1	HAMPAPURA_66	11:45	11:51	0:06	HAND TRIPPED
337	22-Nov-19	MYSORE	66	HV2	HAMPAPURA_66	11:45	12:12	0:27	HAND TRIPPED
338	22-Nov-19	MYSORE	66	HV1	HANAGODU_66	18:11	18:31	0:19	LOAD CURTAILMENT
339	22-Nov-19	MYSORE	66	HV2	KIRUGAVALU_66	18:11	18:41	0:29	LOAD CURTAILMENT
340	22-Nov-19	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	13:05	13:09	0:04	LINE FAULT
341	22-Nov-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	16:13	16:54	0:41	LINE CLEAR AVAILED
342	22-Nov-19	MYSORE	66	MANDAGERE-HOLENARASIPURA	MANDGERE_66	12:20	13:30	1:10	NFBC ISSUED
343	22-Nov-19	MYSORE	66	HV1	PANDAVAPURA_66	18:12	18:26	0:13	LOAD CURTAILMENT
344	22-Nov-19	MYSORE	66	HV1	RAVANDUR_66	13:15	14:29	1:13	LINE CLEAR AVAILED
345	22-Nov-19	TUMKUR	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	18:15	18:51	0:36	HAND TRIPPED
346	22-Nov-19	TUMKUR	220	TR-3	HIRIYUR_220	16:28	16:46	0:17	LINE CLEAR AVAILED
347	22-Nov-19	TUMKUR	110	TR-2	SAMPIGE_110	18:10	18:13	0:02	LINE CLEAR AVAILED
348	22-Nov-19	TUMKUR	66	CHELLUR-ANTHRASANAHALI	CHELURU_66	12:35	15:28	2:52	MAIN SUPPLY FAILURE
349	22-Nov-19	TUMKUR	66	TR-1	HANGLA_66	18:11	18:37	0:25	TRANSFORMER FAULT
350	22-Nov-19	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	9:37	17:42	8:04	LINE CLEAR AVAILED
351	22-Nov-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	16:27	16:53	0:26	HAND TRIPPED
352	22-Nov-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALI	BEVINAHALI_66	16:26	16:53	0:26	HAND TRIPPED
353	22-Nov-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	16:28	17:06	0:38	HAND TRIPPED
354	22-Nov-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:28	17:06	0:38	HAND TRIPPED
355	22-Nov-19	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	17:52	18:02	0:09	HAND TRIPPED
356	22-Nov-19	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	12:30	15:26	2:56	LINE CLEAR AVAILED
357	23-Nov-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI1	BIDNAL_220	13:00	16:05	3:05	LINE CLEAR AVAILED
358	23-Nov-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI2	BIDNAL_220	0:00	16:04	16:04	LINE CLEAR AVAILED
359	23-Nov-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	10:01	20:12	10:11	LINE CLEAR AVAILED
360	23-Nov-19	BAGALKOT	110	BELGAUM-HATTARAGI	HATTARAGI_110	5:25	5:38	0:13	LINE FAULT
361	23-Nov-19	BAGALKOT	110	110/33KV,HV2	KHANAPUR_110	10:00	18:40	8:40	LINE CLEAR AVAILED
362	23-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	0:00	12:16	12:16	LINE CLEAR AVAILED
363	23-Nov-19	BAGALKOT	110	MK HUBLI220-KHANAPUR	KHANAPUR_110	10:04	17:36	7:32	LINE CLEAR AVAILED
364	23-Nov-19	BAGALKOT	110	110/11KV,HV1	RATTIHAL_110	12:38	13:22	0:44	LINE CLEAR AVAILED
365	23-Nov-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI110	8:46	9:28	0:42	LINE CLEAR AVAILED
366	23-Nov-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:44	11:58	0:14	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
367	23-Nov-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:44	12:06	0:22	LINE FAULT
368	23-Nov-19	GULBARGA	220	SEDAM-CLEANMAX_IPP	SEDAM_220	18:45	19:10	0:25	LINE CLEAR AVAILED
369	23-Nov-19	GULBARGA	220	HV2	SEDAM_220	20:50	21:02	0:12	TRANSFORMER FAULT
370	23-Nov-19	GULBARGA	220	HV2	SEDAM_220	16:40	16:50	0:10	TRANSFORMER FAULT
371	23-Nov-19	GULBARGA	220	HV2	SEDAM_220	11:27	11:45	0:18	TRANSFORMER FAULT
372	23-Nov-19	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	20:50	21:08	0:18	LINE FAULT
373	23-Nov-19	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	11:25	11:40	0:15	LINE FAULT
374	23-Nov-19	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	16:40	16:50	0:10	LINE FAULT
375	23-Nov-19	GULBARGA	110	HV1	HANUMANAL_110	7:30	10:55	3:25	LINE CLEAR AVAILED
376	23-Nov-19	GULBARGA	110	HV2	HANUMANAL_110	12:00	13:15	1:15	LINE CLEAR AVAILED
377	23-Nov-19	GULBARGA	110	PDHALLI-CLEANSOLAR_IPP	PD_HALLI_110	17:17	17:30	0:13	LINE CLEAR AVAILED
378	23-Nov-19	GULBARGA	110	PDHALLI-CLEANSOLAR_IPP	PD_HALLI_110	2:13	5:31	3:18	LINE FAULT
379	23-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	7:54	7:54	LINE CLEAR AVAILED
380	23-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:53	23:59	0:06	HAND TRIPPED
381	23-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:33	6:33	LINE CLEAR AVAILED
382	23-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:43	23:59	2:16	LINE CLEAR AVAILED
383	23-Nov-19	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	8:48	11:58	3:10	LINE CLEAR AVAILED
384	23-Nov-19	HASSAN	110	MRSSHM-SS2	MRSMSG_220	11:33	13:04	1:31	LINE CLEAR AVAILED
385	23-Nov-19	HASSAN	66	HV1	CHIKMAGALUR_66	14:16	16:10	1:54	LINE CLEAR AVAILED
386	23-Nov-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	7:43	7:49	0:06	HAND TRIPPED
387	23-Nov-19	HASSAN	66	HV2	HNPUA_66	8:45	9:05	0:20	MAIN SUPPLY FAILURE
388	23-Nov-19	HASSAN	66	HV1	HNPUA_66	8:45	9:05	0:20	MAIN SUPPLY FAILURE
389	23-Nov-19	HASSAN	66	HV2	HNPUA_66	9:15	9:25	0:10	MAIN SUPPLY FAILURE
390	23-Nov-19	HASSAN	66	HV1	HNPUA_66	11:35	23:59	12:24	LINE CLEAR AVAILED
391	23-Nov-19	HASSAN	66	HNPUA-CRP	HNPUA_66	7:30	8:50	1:20	LINE CLEAR AVAILED
392	23-Nov-19	HASSAN	66	HNPUA-CRP	HNPUA_66	11:05	11:25	0:20	LINE CLEAR AVAILED
393	23-Nov-19	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	5:51	6:05	0:14	LINE FAULT
394	23-Nov-19	HASSAN	66	CHANNAR-SHETTIHALLY	CHANNARAYAPATNA_66	5:51	6:10	0:19	LINE FAULT
395	23-Nov-19	MYSORE	66	BG NAGARA-NAGAMANGALA	BGNAGARA_66	14:45	17:55	3:10	LINE CLEAR AVAILED
396	23-Nov-19	MYSORE	66	BG NAGARA-ANCHEPALYA	ADICHUNCHANAGIRI_66 VADERALLI_66	14:45	17:55	3:10	LINE CLEAR AVAILED
397	23-Nov-19	MYSORE	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	12:49	12:54	0:05	LINE FAULT
398	23-Nov-19	MYSORE	66	HV1	DUNDANAHALLI_66	9:55	10:10	0:15	MAIN SUPPLY FAILURE
399	23-Nov-19	MYSORE	66	HV2	DUNDANAHALLI_66	9:55	10:10	0:15	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
400	23-Nov-19	MYSORE	66	HV1	KIADBMANDYA_66	11:46	12:06	0:20	MAIN SUPPLY FAILURE
401	23-Nov-19	MYSORE	66	HV2	KIADBMANDYA_66	11:46	12:06	0:20	MAIN SUPPLY FAILURE
402	23-Nov-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66, SOMANAHALLI_66	11:41	12:05	0:24	MAIN SUPPLY FAILURE
403	23-Nov-19	MYSORE	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	11:48	12:04	0:16	MAIN SUPPLY FAILURE
404	23-Nov-19	MYSORE	66	HV1	KIKKERI_66	13:39	14:50	1:11	LINE CLEAR AVAILED
405	23-Nov-19	MYSORE	66	KUSHALANAGARA 220-RAMANATHAPURA 1	ALUR SIDDAPUR_66, KANAGAL_66	16:51	16:57	0:05	LINE FAULT
406	23-Nov-19	MYSORE	66	HV1	SUNTIKOPPA_66	9:54	12:07	2:12	LINE CLEAR AVAILED
407	23-Nov-19	TUMKUR	110	TR-2	KBCROSS_220	10:30	11:46	1:16	LINE CLEAR AVAILED
408	23-Nov-19	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	9:57	10:09	0:12	LINE FAULT
409	23-Nov-19	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 2	CHITRADURGA_66	9:30	17:22	7:52	LINE CLEAR AVAILED
410	23-Nov-19	TUMKUR	66	TR-1& TR-2	CHITRADURGA_66	9:30	17:23	7:53	LINE CLEAR AVAILED
411	23-Nov-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	13:14	13:30	0:15	TRANSFORMER FAULT
412	24-Nov-19	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	18:15	18:31	0:16	LINE FAULT
413	24-Nov-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	0:00	11:38	11:38	LINE CLEAR AVAILED
414	24-Nov-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	12:07	18:57	6:50	LINE CLEAR AVAILED
415	24-Nov-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	12:07	18:57	6:50	LINE CLEAR AVAILED
416	24-Nov-19	BAGALKOT	110	SHIVA SUGARS-HIREBEVANUR	HIREBEVANUR_110	18:11	18:14	0:03	LINE FAULT
417	24-Nov-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	16:07	23:59	7:52	LINE FAULT
418	24-Nov-19	BAGALKOT	110	110/11KV,HV2	MUDEBIHAL_110	20:58	21:07	0:09	TRANSFORMER FAULT
419	24-Nov-19	BAGALKOT	110	110/33KV,HV3	TARIHAL_110,DUMMAWAD_33KV,INDUSTRIAL ESTATE_33KV	9:01	23:59	14:58	LINE CLEAR AVAILED
420	24-Nov-19	BAGALKOT	110	VAJRAMATTI220-MANTUR1	MANTUR_110	7:02	7:17	0:15	LINE FAULT
421	24-Nov-19	BAGALKOT	110	SATISH SUGARS-P G HUNSHYAL	P G HUNSHYAL_110	9:55	9:59	0:04	LINE FAULT
422	24-Nov-19	BAGALKOT	110	SHIVASAGAR SUGARS-SALAHALLI	SALAHALLI_110	11:50	14:22	2:32	LINE CLEAR AVAILED
423	24-Nov-19	BAGALKOT	110	GMNAVAR-SALAHALLI	SALAHALLI_110	11:56	14:21	2:25	LINE CLEAR AVAILED
424	24-Nov-19	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	10:31	11:00	0:29	LINE CLEAR AVAILED
425	24-Nov-19	BENGALURU	66	VIKAS TECH PARK 220 -MALUR 220	VIKAS TECH PARK 220	9:07	9:35	0:28	LOAD CHANGEOVER
426	24-Nov-19	BENGALURU	66	VIKAS TECH PARK 220 -HSR 220	VIKAS TECH PARK 220	19:30	19:45	0:15	LOAD CHANGEOVER
427	24-Nov-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:20	20:00	10:40	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
428	24-Nov-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	9:20	20:00	10:40	LINE CLEAR AVAILED
429	24-Nov-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	9:20	20:00	10:40	LINE CLEAR AVAILED
430	24-Nov-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, BUDHIKOTE, TEKAL, KAMASAMUDRA, KYASAMBALLI, DODDAKARI, ANDERSONPET, BEML(EHT)	9:20	20:00	10:40	LINE CLEAR AVAILED
431	24-Nov-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	9:20	20:00	10:40	LINE CLEAR AVAILED
432	24-Nov-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	9:20	20:00	10:40	LINE CLEAR AVAILED
433	24-Nov-19	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	9:20	19:55	10:35	LINE CLEAR AVAILED
434	24-Nov-19	BENGALURU	66	HV1	DODDABELAVANGALA	12:33	12:46	0:13	TRANSFORMER FAULT
435	24-Nov-19	BENGALURU	220	HV1	SARJAPURA 220	9:03	9:20	0:17	MAIN SUPPLY FAILURE
436	24-Nov-19	BENGALURU	220	HV2	SARJAPURA 220	9:03	9:20	0:17	MAIN SUPPLY FAILURE
437	24-Nov-19	BENGALURU	66	CHANDAPURA - SARJAPURA 220	SARJAPURA 220	10:05	10:26	0:21	MAIN SUPPLY FAILURE
438	24-Nov-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	9:03	9:25	0:22	MAIN SUPPLY FAILURE
439	24-Nov-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	SARJAPURA 220	19:35	19:40	0:05	LOAD CHANGEOR
440	24-Nov-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	9:03	9:50	0:47	MAIN SUPPLY FAILURE
441	24-Nov-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:05	10:30	0:25	MAIN SUPPLY FAILURE
442	24-Nov-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	19:35	19:55	0:20	LOAD CHANGEOR
443	24-Nov-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	6:40	7:01	0:21	LINE FAULT
444	24-Nov-19	BENGALURU	66	GOWRIBIDANUR 220 - EFTL		6:40	7:03	0:23	LINE FAULT
445	24-Nov-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	9:20	11:09	1:49	LINE CLEAR AVAILED
446	24-Nov-19	BENGALURU	66	HV2	JIGANI 6	12:02	12:10	0:08	LOAD CHANGEOR
447	24-Nov-19	BENGALURU	66	HV3	JIGANI 6	12:02	12:10	0:08	LOAD CHANGEOR

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
448	24-Nov-19	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	19:35	19:44	0:09	LOAD CHANGEOVER
449	24-Nov-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	9:07	9:35	0:28	MAIN SUPPLY FAILURE
450	24-Nov-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	9:07	9:35	0:28	MAIN SUPPLY FAILURE
451	24-Nov-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	19:35	19:45	0:10	LOAD CHANGEOVER
452	24-Nov-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	19:35	19:45	0:10	LOAD CHANGEOVER
453	24-Nov-19	BENGALURU	66	YERANDANAHALLI 220 - CHANDAPURA	CHANDAPURA, SARJAPURA 220	10:05	10:30	0:25	LINE CLEAR AVAILED
454	24-Nov-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	11:16	11:16	LINE CLEAR AVAILED
455	24-Nov-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	17:05	23:59	6:54	LINE FAULT
456	24-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:51	7:51	LINE CLEAR AVAILED
457	24-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	19:59	23:59	4:00	LINE CLEAR AVAILED
458	24-Nov-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:08	16:01	5:53	NFBC ISSUED
459	24-Nov-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	16:57	23:59	7:02	LINE FAULT
460	24-Nov-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:17	16:14	5:57	NFBC ISSUED
461	24-Nov-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	17:28	23:59	6:31	LINE CLEAR AVAILED
462	24-Nov-19	HASSAN	220	KADUR-DABUSET	KADUR_220	9:50	18:13	8:23	LINE CLEAR AVAILED
463	24-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	10:08	16:00	5:52	LINE CLEAR AVAILED
464	24-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	16:57	23:59	7:02	LINE FAULT
465	24-Nov-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	15:08	20:42	5:34	LINE FAULT
466	24-Nov-19	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	15:08	20:41	5:33	LINE FAULT
467	24-Nov-19	HASSAN	110	KADUR-NERELEKERE	KADUR_220	12:33	13:17	0:44	LINE FAULT
468	24-Nov-19	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	11:50	13:40	1:50	LINE FAULT
469	24-Nov-19	HASSAN	110	HV2	SORABA_110	14:40	15:25	0:45	TRANSFORMER FAULT
470	24-Nov-19	HASSAN	110	HV2	SORABA_110	17:19	17:29	0:10	LINE CLEAR AVAILED
471	24-Nov-19	HASSAN	110	HV2	SORABA_110	17:40	18:35	0:55	LINE CLEAR AVAILED
472	24-Nov-19	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	13:32	14:06	0:34	LINE FAULT
473	24-Nov-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	6:15	6:25	0:10	LINE FAULT
474	24-Nov-19	HASSAN	66	BANDISH-HNPURA	BANDISHETTYHALLI_66	11:02	13:10	2:08	NFBC ISSUED
475	24-Nov-19	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	10:50	11:00	0:10	MAIN SUPPLY FAILURE
476	24-Nov-19	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	18:10	18:20	0:10	MAIN SUPPLY FAILURE
477	24-Nov-19	HASSAN	66	HV1	HALEBEEDU_66	9:20	9:35	0:15	MAIN SUPPLY FAILURE
478	24-Nov-19	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	11:54	18:20	6:26	LINE CLEAR AVAILED
479	24-Nov-19	HASSAN	66	RAMESWARNAGAR	KIADB_66	13:30	13:40	0:10	LINE FAULT
480	24-Nov-19	MYSORE	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	14:24	14:30	0:06	LINE FAULT
481	24-Nov-19	MYSORE	66	CR NAGARA-KOLLEGALA	KOLLEGALA_66	10:23	15:31	5:07	NFBC ISSUED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
482	24-Nov-19	MYSORE	66	KR PETE 220-BOOKANAKERE	BANANGADI_66,BOOKANAKERE_66, CHINAKURALI_66, GANJIGERE_66	23:03	23:10	0:07	LINE FAULT
483	24-Nov-19	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	KOLLEGALA_66	10:31	15:33	5:02	NFBC ISSUED
484	24-Nov-19	TUMKUR	220	TR-1	CHITRADURGA_220	9:41	16:00	6:18	LINE CLEAR AVAILED
485	24-Nov-19	TUMKUR	220	TR-2	CHITRADURGA_220	9:41	16:00	6:18	LINE CLEAR AVAILED
486	24-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	9:05	9:44	0:39	LINE CLEAR AVAILED
487	24-Nov-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	9:05	9:34	0:29	LINE CLEAR AVAILED
488	24-Nov-19	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	9:41	16:00	6:18	LINE CLEAR AVAILED
489	24-Nov-19	TUMKUR	66	CHITRADURGA 220kv- SUZLON 1	SUZLON1_IPP_66	9:44	16:00	6:15	LINE CLEAR AVAILED
490	24-Nov-19	TUMKUR	66	CHITRADURGA 220kv- SUZLON 2	SUZLON1_IPP_66	9:44	16:00	6:15	LINE CLEAR AVAILED
491	24-Nov-19	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	9:42	16:00	6:17	LINE CLEAR AVAILED
492	24-Nov-19	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	9:43	10:01	0:17	MAIN SUPPLY FAILURE
493	24-Nov-19	TUMKUR	66	TR-1	TUMKUR_66	11:54	12:18	0:23	MAIN SUPPLY FAILURE
494	24-Nov-19	TUMKUR	66	TR-2	TUMKUR_66	11:54	12:18	0:23	MAIN SUPPLY FAILURE
495	25-Nov-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	13:12	18:24	5:12	LINE FAULT
496	25-Nov-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	13:48	20:46	6:58	LINE CLEAR AVAILED
497	25-Nov-19	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	11:36	13:02	1:26	LINE CLEAR AVAILED
498	25-Nov-19	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	BHUTNAL_110	12:04	12:11	0:07	LINE FAULT
499	25-Nov-19	BAGALKOT	110	BELGAUM220-BELAGUM	BELGAUM_110	15:42	15:48	0:06	LINE FAULT
500	25-Nov-19	BAGALKOT	110	110/11KV, HV2	BYADAGI_110	13:50	14:45	0:55	TRANSFORMER FAULT
501	25-Nov-19	BAGALKOT	110	110/33KV, HV3	LOKAPUR_110, BADKURKI_33, RSSKN_33	8:41	9:03	0:22	TRANSFORMER FAULT
502	25-Nov-19	BAGALKOT	110	110/11KV, HV1	PG HUNSYAL_110	11:00	13:40	2:40	LINE CLEAR AVAILED
503	25-Nov-19	BAGALKOT	110	110/11KV, HV2	PG HUNSYAL_110	14:46	18:09	3:23	LINE CLEAR AVAILED
504	25-Nov-19	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	17:41	17:45	0:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
505	25-Nov-19	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	17:45	17:50	0:05	LINE FAULT
506	25-Nov-19	BAGALKOT	110	RANEBENNUR220-HIREKERUR	HIREKERUR_110	14:24	14:33	0:09	LINE FAULT
507	25-Nov-19	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	17:51	23:59	6:08	LINE FAULT
508	25-Nov-19	BAGALKOT	220	220/110KV,HV1	SIRSI_220	12:09	12:13	0:04	LINE CLEAR AVAILED
509	25-Nov-19	BAGALKOT	110	SOUDATTI110-ENERCON1	SOUDATTI_110	11:00	18:42	7:42	LINE CLEAR AVAILED
510	25-Nov-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	12:14	18:54	6:40	LINE CLEAR AVAILED
511	25-Nov-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	0:00	13:23	13:23	LINE CLEAR AVAILED
512	25-Nov-19	BAGALKOT	110	110/33KV,HV3	TARIHAL_110,DUMMAVAD_33KV,INDUSTRIAL ESTATE_33KV	0:00	14:40	14:40	LINE CLEAR AVAILED
513	25-Nov-19	BAGALKOT	110	110/33KV,HV3	TARIHAL_110,DUMMAVAD_33KV,INDUSTRIAL ESTATE_33KV	17:59	18:14	0:15	HAND TRIPPED
514	25-Nov-19	BAGALKOT	110	110/11KV,HV2	ZALKI_110	0:00	21:01	21:01	LINE CLEAR AVAILED
515	25-Nov-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	9:40	9:44	0:04	LINE FAULT
516	25-Nov-19	BENGALURU	66	CHIKKENAHALLI - KANAKAPURA 220	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	9:40	9:44	0:04	LINE FAULT
517	25-Nov-19	BENGALURU	66	CHIKKENAHALLI - KANAKAPURA 220	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	12:57	13:12	0:15	LINE CLEAR AVAILED
518	25-Nov-19	BENGALURU	66	HV2	JIGANI 66	22:40	22:45	0:05	LOAD CHANGEOVER
519	25-Nov-19	BENGALURU	66	HV3	JIGANI 66	22:40	22:45	0:05	LOAD CHANGEOVER
520	25-Nov-19	BENGALURU	66	HV1	KEMBODI	11:00	11:05	0:05	LINE CLEAR AVAILED
521	25-Nov-19	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	13:07	14:12	1:05	LINE CLEAR AVAILED
522	25-Nov-19	BENGALURU	66	SURYANAGAR - YERANDANAHALLI 220	SURYANAGAR	11:40	12:35	0:55	LINE CLEAR AVAILED
523	25-Nov-19	BENGALURU	66	SURYANAGAR - ANEKAL.	SURYANAGAR	18:18	18:20	0:02	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
524	25-Nov-19	GULBARGA	400	JSWVL400-GUTTUR	GUTTUR_400	10:02	14:18	4:16	NFBC ISSUED
525	25-Nov-19	GULBARGA	220	SEDAM-RTPS2	RTPS_220	11:24	15:45	4:21	LINE CLEAR AVAILED
526	25-Nov-19	GULBARGA	220	SEDAM-HUMNABAD2	SEDAM_220	15:50	18:55	3:05	LINE CLEAR AVAILED
527	25-Nov-19	GULBARGA	110	HV1	MADIYAL_110	12:22	16:43	4:21	LINE CLEAR AVAILED
528	25-Nov-19	GULBARGA	110	HV3	MADIYAL_110	15:33	16:37	1:04	LINE CLEAR AVAILED
529	25-Nov-19	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	20:00	20:08	0:08	LINE FAULT
530	25-Nov-19	GULBARGA	110	MALLAT-BYAGWAT1	BYAGAWAT_110	20:45	20:50	0:05	LINE FAULT
531	25-Nov-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	11:30	12:30	1:00	LINE FAULT
532	25-Nov-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	20:00	20:10	0:10	LINE FAULT
533	25-Nov-19	GULBARGA	66	HANASI-MUNIRABAD	HANASI_66	22:15	23:00	0:45	MAIN SUPPLY FAILURE
534	25-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	7:58	7:58	LINE CLEAR AVAILED
535	25-Nov-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:33	23:59	2:26	LINE CLEAR AVAILED
536	25-Nov-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	0:00	19:20	19:20	LINE CLEAR AVAILED
537	25-Nov-19	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	12:02	19:16	7:14	LINE CLEAR AVAILED
538	25-Nov-19	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:43	14:00	4:17	LINE CLEAR AVAILED
539	25-Nov-19	HASSAN	110	HV2	MRSMSG_220	9:41	10:05	0:24	HAND TRIPPED
540	25-Nov-19	HASSAN	66	LV2	MRSMSG_220	9:41	10:05	0:24	HAND TRIPPED
541	25-Nov-19	HASSAN	220	HV1	MSEZ_220	9:45	15:34	5:49	LINE CLEAR AVAILED
542	25-Nov-19	HASSAN	110	LV1	MSEZ_220	9:44	15:35	5:51	LINE CLEAR AVAILED
543	25-Nov-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	0:00	19:19	19:19	LINE FAULT
544	25-Nov-19	HASSAN	110	HV4	MANIPAL_110	9:09	9:12	0:03	LINE CLEAR AVAILED
545	25-Nov-19	HASSAN	110	HV4	MANIPAL_110	9:12	17:00	7:48	LINE CLEAR AVAILED
546	25-Nov-19	HASSAN	110	HV2	SORABA_110	4:41	5:15	0:34	TRANSFORMER FAULT
547	25-Nov-19	HASSAN	110	HV2	SORABA_110	17:46	17:54	0:08	LINE CLEAR AVAILED
548	25-Nov-19	HASSAN	110	HV2	SORABA_110	18:28	18:35	0:07	LINE CLEAR AVAILED
549	25-Nov-19	HASSAN	66	HV1	CHIKMAGALUR_66	10:46	11:15	0:29	LINE CLEAR AVAILED
550	25-Nov-19	HASSAN	66	HV1	CHIKMAGALUR_66	12:32	12:38	0:06	LINE CLEAR AVAILED
551	25-Nov-19	HASSAN	66	HV2	CHIKMAGALUR_66	0:00	16:29	16:29	LINE CLEAR AVAILED
552	25-Nov-19	HASSAN	66	HV2	HIRISAVE_66	10:24	10:56	0:32	LINE CLEAR AVAILED
553	25-Nov-19	HASSAN	66	HV2	HIRISAVE_66	12:36	13:53	1:17	LINE CLEAR AVAILED
554	25-Nov-19	HASSAN	66	HV2	HIRISAVE_66	14:47	15:29	0:42	LINE CLEAR AVAILED
555	25-Nov-19	MYSORE	66	BANNUR-MALIYUR	MALIYURU_66	10:30	10:51	0:21	LINE FAULT
556	25-Nov-19	MYSORE	66	HV2	BGNAGARA_66	13:30	14:19	0:48	LINE CLEAR AVAILED
557	25-Nov-19	MYSORE	66	HOOTAGALLI-BOGADHI	BOGADHI_66 KALAMANDIRA_66	15:24	23:59	8:34	LINE FAULT
558	25-Nov-19	MYSORE	66	HV2	HOOTAGALLY_220	16:49	17:47	0:57	TRANSFORMER FAULT
559	25-Nov-19	MYSORE	66	HOOTAGALLI-HV2	HOOTAGALLY_220	17:48	18:10	0:21	HAND TRIPPED
560	25-Nov-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66	18:00	18:07	0:06	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
561	25-Nov-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66	18:16	18:26	0:09	LINE FAULT
562	25-Nov-19	MYSORE	66	KIRUGAVLU-MALIYUR	MALIYURU_66	10:31	10:59	0:28	LINE FAULT
563	25-Nov-19	MYSORE	66	HV1	SINDHUVALLI_66	12:54	13:08	0:13	HAND TRIPPED
564	25-Nov-19	MYSORE	66	HV2	SINDHUVALLI_66	12:54	13:08	0:13	HAND TRIPPED
565	25-Nov-19	MYSORE	66	HV1	SUNTIKOPPA_66	11:22	13:56	2:34	LINE CLEAR AVAILED
566	25-Nov-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	10:29	10:38	0:09	LINE FAULT
567	25-Nov-19	MYSORE	66	HV1	VIJAYANAGRAMYS_66	9:08	11:00	1:52	LINE CLEAR AVAILED
568	25-Nov-19	MYSORE	66	HV1	VIJAYANAGRAMYS_66	13:51	14:11	0:19	HAND TRIPPED
569	25-Nov-19	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	15:38	15:47	0:08	HAND TRIPPED
570	25-Nov-19	TUMKUR	66	TR-1	BALENAHALLI_66	14:38	15:38	0:59	LINE CLEAR AVAILED
571	25-Nov-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	13:00	14:13	1:12	LINE CLEAR AVAILED
572	25-Nov-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	9:43	10:36	0:53	LINE FAULT
573	25-Nov-19	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA4	CHITRADURGA_220	9:43	10:36	0:53	LINE FAULT
574	25-Nov-19	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA3	CHITRADURGA_220	9:43	10:36	0:53	LINE FAULT
575	25-Nov-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	21:38	22:43	1:04	LINE FAULT
576	25-Nov-19	TUMKUR	66	TR-2	HALUVAGALU_66	15:00	15:48	0:48	LINE CLEAR AVAILED
577	25-Nov-19	TUMKUR	66	TR-2	MAVINAKATTE_66	21:52	21:59	0:06	TRANSFORMER FAULT
578	25-Nov-19	TUMKUR	66	TR-2	MELKOTE_66	13:54	14:30	0:36	TRANSFORMER FAULT