

**400/220/110/66 kV TRANSMISSION OUTAGES FROM 18.01.22 TO 24.01.22**

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	18-Jan-22	BAGALKOT	66	66/11KV, HV2	STATION NOT AFFECTED HARIHAR-HOSPET_66	12:20	14:36	2:16	LINE CLEAR AVAILED
2	18-Jan-22	BAGALKOT	110	110/11KV, HV2	MUNDAGANUR_110	13:10	16:20	3:10	TRANSFORMER FAULT
3	18-Jan-22	BAGALKOT	110	110/11KV,HV1	HALAKI_110	7:13	7:23	0:10	TRANSFORMER FAULT
4	18-Jan-22	BAGALKOT	110	110/11KV,HV1	HALAKI_110	7:27	9:36	2:09	TRANSFORMER FAULT
5	18-Jan-22	BAGALKOT	110	110/11KV,HV2	THORVI_110(BICTY)	15:47	15:54	0:07	HAND TRIPPED
6	18-Jan-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	15:30	18:33	3:03	LINE CLEAR AVAILED
7	18-Jan-22	BAGALKOT	110	110/11KV,HV2	MUNDUGANUR_110	14:55	16:25	1:30	TRANSFORMER FAULT
8	18-Jan-22	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_33,MALLUR_33	16:20	17:20	1:00	LINE CLEAR AVAILED
9	18-Jan-22	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKH ED_33 ZALKI_110	5:09	5:13	0:04	TRANSFORMER FAULT
10	18-Jan-22	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKH ED_33 ZALKI_110	5:41	5:56	0:15	TRANSFORMER FAULT
11	18-Jan-22	BAGALKOT	110	AMBEWADI- ANMOD	ANMOD_110	10:00	14:25	4:25	MAIN SUPPLY FAILURE
12	18-Jan-22	BAGALKOT	110	AMBEWADI- ANMOD	ANMOD_110	20:00	20:10	0:10	MAIN SUPPLY FAILURE
13	18-Jan-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWAD)	AMBEWADI_220	8:15	8:29	0:14	HAND TRIPPED
14	18-Jan-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWAD)	KAVALWAD_110	8:10	8:25	0:15	MAIN SUPPLY FAILURE
15	18-Jan-22	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
16	18-Jan-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
17	18-Jan-22	BAGALKOT	110	HAVERI220-HANAGAL	HAVERI_220	8:12	12:20	4:08	LINE FAULT
18	18-Jan-22	BAGALKOT	110	HAVERI220-SAVANUR	HAVERI_220	15:30	18:07	2:37	LINE FAULT
19	18-Jan-22	BAGALKOT	110	KUDUCHI220-CHIKKODI2	KUDUCHI_220	11:09	13:21	2:12	NFBC ISSUED
20	18-Jan-22	BAGALKOT	110	MANTUR- MAREGUDDI	MANTUR(B)_110	13:10	13:25	0:15	LINE FAULT
21	18-Jan-22	BAGALKOT	110	MUKARTIHAL-BAGEWADI 2	MUKARTIHAL_110	14:10	14:56	0:46	MAIN SUPPLY FAILURE
22	18-Jan-22	BAGALKOT	110	MUKARTIHAL-MATRIX	MUKARTIHAL_110 MATRIX IPP_110	14:10	15:00	0:50	MAIN SUPPLY FAILURE
23	18-Jan-22	BAGALKOT	110	MUKARTIHAL-SPV	MUKARTIHAL_110 SPV IPP_110	14:10	15:02	0:52	MAIN SUPPLY FAILURE
24	18-Jan-22	BAGALKOT	110	NAGJHARI1- AMBEWADI	AMBEWADI_220	10:10 (28.12.2021)			LINE OPEN:LINE CLEAR AVAILED
25	18-Jan-22	BAGALKOT	110	RANEENNUR- HONNATTI	RANEENNUR_220	10:33	14:50	4:17	LINE CLEAR AVAILED
26	18-Jan-22	BAGALKOT	110	RANEENNUR-AREMALLAPUR(HONNATTI)	RANEENNUR_220	10:33	14:50	4:17	LINE CLEAR AVAILED
27	18-Jan-22	BAGALKOT	110	UTTUR-MUDHOL	UTTUR_110	7:06	7:13	0:07	LINE FAULT
28	18-Jan-22	BAGALKOT	110	VAJRAMATTI-MANTUR(K.D.JAMBAGI)	VAJRAMATTI_220	19:38 (27.12.2021)			LINE OPEN:LINE FAULT
29	18-Jan-22	BAGALKOT	220	220/110KV,HV2(HV4)	GADAG_220	14:05	18:06	4:01	LINE CLEAR AVAILED
30	18-Jan-22	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	16:23 (17.01.2022)	18:50 (18.01.2022)	26:27HRS	LINE CHARGED
31	18-Jan-22	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	12:34	14:35	2:01	HAND TRIPPED
32	18-Jan-22	BAGALKOT	220	CHIKKODI- GHATAPRABHA(KUDACHI2)	CHIKKODI_220	11:10	13:20	2:10	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
33	18-Jan-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAIED
34	18-Jan-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAIED
35	18-Jan-22	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
36	18-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	19:39 (30.12.2021)			LINE OPEN:LINE CLEAR AVAIED
37	18-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	19:37 (30.12.2021)			LINE OPEN:LINE CLEAR AVAIED
38	18-Jan-22	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	9:46	14:29	4:42	HAND TRIPPED
39	18-Jan-22	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	9:46	14:29	4:42	HAND TRIPPED
40	18-Jan-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
41	18-Jan-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAIED
42	18-Jan-22	BENGALURU	66	HV1	GOLF LINK	11:20	11:25	0:05	LINE CLEAR AVAIED
43	18-Jan-22	BENGALURU	66	HV1	VIJAYANAGARA	16:15	18:10	1:55	LINE CLEAR AVAIED
44	18-Jan-22	BENGALURU	66	HV1	KOLAR 220	16:13	17:07	0:54	MAIN SUPPLY FAILURE
45	18-Jan-22	BENGALURU	66	HV1	KGF	17:05	17:51	0:46	LINE CLEAR AVAIED
46	18-Jan-22	BENGALURU	66	HV2	GOLF LINK	14:01	14:06	0:05	LINE CLEAR AVAIED
47	18-Jan-22	BENGALURU	66	HV2	MATHIKERE	12:20	12:23	0:03	LINE CLEAR AVAIED
48	18-Jan-22	BENGALURU	66	HV2	MATHIKERE	16:15	16:18	0:03	LINE CLEAR AVAIED
49	18-Jan-22	BENGALURU	66	HV2	R R NAGAR	13:40	13:45	0:05	LINE CLEAR AVAIED
50	18-Jan-22	BENGALURU	66	HV2	VIJAYANAGARA	16:15	18:10	1:55	LINE CLEAR AVAIED
51	18-Jan-22	BENGALURU	66	HV2	KOLAR 220	16:13	16:50	0:37	MAIN SUPPLY FAILURE
52	18-Jan-22	BENGALURU	66	HV2	NELAMANGALA 66	13:05	13:45	0:40	LINE CLEAR AVAIED
53	18-Jan-22	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	16:12	17:56	1:44	MAIN SUPPLY FAILURE
54	18-Jan-22	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	16:12	17:56	1:44	MAIN SUPPLY FAILURE
55	18-Jan-22	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	16:12	17:57	1:45	MAIN SUPPLY FAILURE
56	18-Jan-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	16:12	17:56	1:44	MAIN SUPPLY FAILURE
57	18-Jan-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	16:13	17:07	0:54	MAIN SUPPLY FAILURE
58	18-Jan-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	16:13	17:56	1:43	MAIN SUPPLY FAILURE
59	18-Jan-22	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	16:13	17:56	1:43	MAIN SUPPLY FAILURE
60	18-Jan-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	16:12	17:57	1:45	MAIN SUPPLY FAILURE
61	18-Jan-22	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	16:12	17:56	1:44	MAIN SUPPLY FAILURE
62	18-Jan-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	16:12	17:20	1:08	MAIN SUPPLY FAILURE
63	18-Jan-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	16:14	17:58	1:44	MAIN SUPPLY FAILURE
64	18-Jan-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
65	18-Jan-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	8:31	8:42	0:10	LINE FAULT
66	18-Jan-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	16:16	17:05	0:49	MAIN SUPPLY FAILURE
67	18-Jan-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:16	17:05	0:49	MAIN SUPPLY FAILURE
68	18-Jan-22	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	16:16	17:05	0:49	MAIN SUPPLY FAILURE
69	18-Jan-22	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	16:16	17:05	0:49	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
70	18-Jan-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:16	17:05	0:49	MAIN SUPPLY FAILURE
71	18-Jan-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:07	10:13	0:06	LINE FAULT
72	18-Jan-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	12:58	13:05	0:07	LINE FAULT
73	18-Jan-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:16	17:05	0:49	MAIN SUPPLY FAILURE
74	18-Jan-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	16:16	17:05	0:49	MAIN SUPPLY FAILURE
75	18-Jan-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	3:45	3:50	0:05	LINE FAULT
76	18-Jan-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	14:01	14:18	0:17	LINE FAULT
77	18-Jan-22	BENGALURU	66	SRS PEENYA 220 - DG1	NO STATION AFFECTED	6:57	10:02	3:05	LINE CLEAR AVAILED
78	18-Jan-22	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC	6:57	10:02	3:05	LINE FAULT
79	18-Jan-22	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	10:42	10:52	0:10	LINE FAULT
80	18-Jan-22	BENGALURU	220	DABUSPETE 220 - NELAMANGALA 66	NELAMANGALA 66	17:35	19:13	1:38	LINE CLEAR AVAILED
81	18-Jan-22	BENGALURU	220	HV1	KOLAR 220	16:16	17:04	0:48	MAIN SUPPLY FAILURE
82	18-Jan-22	BENGALURU	220	HV1	MALUR 220	16:16	17:02	0:46	MAIN SUPPLY FAILURE
83	18-Jan-22	BENGALURU	220	HV2	KOLAR 220	16:16	17:04	0:48	MAIN SUPPLY FAILURE
84	18-Jan-22	BENGALURU	220	HV2	MALUR 220	16:16	17:02	0:46	MAIN SUPPLY FAILURE
85	18-Jan-22	BENGALURU	220	HV3	KOLAR 220	16:16	17:04	0:48	MAIN SUPPLY FAILURE
86	18-Jan-22	BENGALURU	220	KOLAR 220 - MALUR 1	NO STATION AFFECTED	16:16	17:02	0:46	MAIN SUPPLY FAILURE
87	18-Jan-22	BENGALURU	220	KOLAR 220 - MALUR 3	MALUR 220	16:16	17:03	0:47	MAIN SUPPLY FAILURE
88	18-Jan-22	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	16:27	16:44	0:17	LINE CLEAR AVAILED
89	18-Jan-22	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	16:44	17:55	1:11	LINE CLEAR AVAILED
90	18-Jan-22	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	16:27	16:45	0:18	LINE CLEAR AVAILED
91	18-Jan-22	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 1	RAILWAY TRACTION (EHT)	16:26	17:05	0:39	MAIN SUPPLY FAILURE
92	18-Jan-22	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 2	RAILWAY TRACTION (EHT)	16:26	17:05	0:39	MAIN SUPPLY FAILURE
93	18-Jan-22	BENGALURU	220	LV1	MALUR 220	16:16	17:04	0:48	MAIN SUPPLY FAILURE
94	18-Jan-22	BENGALURU	220	LV2	MALUR 220	16:16	17:04	0:48	MAIN SUPPLY FAILURE
95	18-Jan-22	GULBARGA	66	HANASI-BADALADUKU	HANASI_66	13:05	13:15	0:10	MAIN SUPPLY FAILURE
96	18-Jan-22	GULBARGA	66	HANASI-BADALADUKU	HANASI_66	15:10	15:20	0:10	MAIN SUPPLY FAILURE
97	18-Jan-22	GULBARGA	66	MUNIRABAD-MSD	HANASI_110	8:45	8:50	0:05	LINE FAULT
98	18-Jan-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	MANVI_110	0:50	1:00	0:10	LINE FAULT
99	18-Jan-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	MANVI_110	2:16	2:26	0:10	LINE FAULT
100	18-Jan-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	MANVI_110	4:00	4:09	0:09	LINE FAULT
101	18-Jan-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	MANVI_110	8:50	9:02	0:12	MAIN SUPPLY FAILURE
102	18-Jan-22	GULBARGA	110	ADAVI AMARESHWAR-SINDHANOOR	ADAVI AMARESHWAR_110	13:38	13:54	0:16	MAIN SUPPLY FAILURE
103	18-Jan-22	GULBARGA	110	ADAVI AMARESHWAR-SINDHANOOR	ADAVI AMARESHWAR_110	13:57	14:18	0:21	LINE FAULT
104	18-Jan-22	GULBARGA	110	BENNUR-SINDANOOR	BENNUR_110	13:35	13:55	0:20	MAIN SUPPLY FAILURE
105	18-Jan-22	GULBARGA	110	BENNUR-SINDANOOR	BENNUR_110	14:00	14:25	0:25	MAIN SUPPLY FAILURE
106	18-Jan-22	GULBARGA	110	BENNUR-SINDANOOR	BENNUR_110	15:15	17:15	2:00	MAIN SUPPLY FAILURE
107	18-Jan-22	GULBARGA	110	HV1	SHAKTINAGAR_110	6:00	6:05	0:05	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
108	18-Jan-22	GULBARGA	110	HV1	BENNUR_110	10:40	10:55	0:15	TRANSFORMER FAULT
109	18-Jan-22	GULBARGA	110	HV1,HV2	SHAKTINAGAR_110	19:30	20:06	0:36	LINE CLEAR AVAILED
110	18-Jan-22	GULBARGA	110	HV2	MANVI_110	8:31	8:45	0:14	TRANSFORMER FAULT
111	18-Jan-22	GULBARGA	110	HV3	VALKAMDINNI_110	4:34	4:38	0:04	TRANSFORMER FAULT
112	18-Jan-22	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	13:40	13:50	0:10	MAIN SUPPLY FAILURE
113	18-Jan-22	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	13:55	14:25	0:30	MAIN SUPPLY FAILURE
114	18-Jan-22	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	15:10	17:55	2:45	MAIN SUPPLY FAILURE
115	18-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	9:08	9:15	0:07	LINE FAULT
116	18-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	6:25	6:35	0:10	LINE FAULT
117	18-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	21:56	22:06	0:10	LINE FAULT
118	18-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	22:39	22:48	0:09	LINE FAULT
119	18-Jan-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_110	20:34	20:44	0:10	LINE FAULT
120	18-Jan-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	6:31	6:38	0:07	LINE FAULT
121	18-Jan-22	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	13:49	14:30	0:41	LINE FAULT
122	18-Jan-22	GULBARGA	110	MUDDAPUR-SINDHNOOR	MUDDAPUR_110	13:39	13:55	0:16	MAIN SUPPLY FAILURE
123	18-Jan-22	GULBARGA	110	MUDDAPUR-SINDHNOOR	MUDDAPUR_110	13:55	14:28	0:33	MAIN SUPPLY FAILURE
124	18-Jan-22	GULBARGA	110	MUDDAPUR-SINDHNOOR	MUDDAPUR_110	15:13	17:25	2:12	MAIN SUPPLY FAILURE
125	18-Jan-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
126	18-Jan-22	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110	16:01	17:10	1:09	LOAD CURTAILMENT
127	18-Jan-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	15:57	16:02	0:05	LOAD CURTAILMENT
128	18-Jan-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:06	3:16	0:10	LINE FAULT
129	18-Jan-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	9:07	9:50	0:43	LOAD CURTAILMENT
130	18-Jan-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	12:04	12:06	0:02	LOAD CURTAILMENT
131	18-Jan-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	12:12	12:22	0:10	LOAD CURTAILMENT
132	18-Jan-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	12:29	12:33	0:04	LOAD CURTAILMENT
133	18-Jan-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	14:35	15:27	0:52	LOAD CURTAILMENT
134	18-Jan-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
135	18-Jan-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPUR_110,WAD AGERA_110,SANNATHI_IPP,COREGRE ENSUGARS_IPP	3:28	3:35	0:07	LINE FAULT
136	18-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:08 (18.01.2022)			LINE OPEN:LINE CLEAR AVAILED
137	18-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:40 (17.01.2022)	6:40 (18.01.2022)	11:00 HRS	LINE CHARGED
138	18-Jan-22	GULBARGA	110	SINDHANOOR-ADVAMARESHWARA	ADVI AMRESHWARA_110	15:22	17:15	1:53	LINE CLEAR AVAILED
139	18-Jan-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	12:05	12:30	0:25	LINE FAULT
140	18-Jan-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	15:22	17:15	1:53	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
141	18-Jan-22	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,VALKAMDINNI_110	15:22	17:15	1:53	LINE CLEAR AVAILED
142	18-Jan-22	GULBARGA	110	SINDHANOOR-SUZLONE_JPP	SINDHANOOR_220	21:30	21:45	0:15	LINE FAULT
143	18-Jan-22	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDHINAGAR_110	15:22	17:15	1:53	LINE CLEAR AVAILED
144	18-Jan-22	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	3:55	4:00	0:05	MAIN SUPPLY FAILURE
145	18-Jan-22	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	4:05	5:00	0:55	MAIN SUPPLY FAILURE
146	18-Jan-22	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	13:35	13:44	0:09	MAIN SUPPLY FAILURE
147	18-Jan-22	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	14:00	14:25	0:25	MAIN SUPPLY FAILURE
148	18-Jan-22	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	15:15	17:15	2:00	MAIN SUPPLY FAILURE
149	18-Jan-22	GULBARGA	110	YEREGERA-RAICHUR	YEREGERA_110	15:58	17:08	1:10	MAIN SUPPLY FAILURE
150	18-Jan-22	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
151	18-Jan-22	GULBARGA	220	HV1	SINDHANOOR_220	13:30	13:40	0:10	TRANSFORMER FAULT
152	18-Jan-22	GULBARGA	220	HV1	SINDHANOOR_220	13:50	14:15	0:25	TRANSFORMER FAULT
153	18-Jan-22	GULBARGA	220	HV1	SINDHANOOR_220	15:12	15:22	0:10	TRANSFORMER FAULT
154	18-Jan-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
155	18-Jan-22	GULBARGA	220	HV2	SINDHANOOR_220	13:10	14:22	1:12	LINE CLEAR AVAILED
156	18-Jan-22	GULBARGA	220	HV2	SINDHANOOR_220	15:10	17:15	2:05	LINE CLEAR AVAILED
157	18-Jan-22	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	10:12	17:50	4:02	LINE CLEAR AVAILED
158	18-Jan-22	HASSAN	66	HV1	ARAKALGUD_66	9:16	12:06	21:22	LINE CLEAR AVAILED
159	18-Jan-22	HASSAN	66	HV1	DODDAKADNUR_66	13:11	17:33	6:44	LINE CLEAR AVAILED
160	18-Jan-22	HASSAN	66	HV1	GORUR_66	13:22	13:26	2:48	TRANSFORMER FAULT
161	18-Jan-22	HASSAN	66	HV1	YESLUR_66	12:37	15:25	4:02	NFBC ISSUED
162	18-Jan-22	HASSAN	66	HV1	BASAVAGHATTA_66	10:37	10:44	21:21	HAND TRIPPED
163	18-Jan-22	HASSAN	66	HV1	BASAVAGHATTA_66	14:50	14:55	5:45	HAND TRIPPED
164	18-Jan-22	HASSAN	66	HV2	BASAVAGHATTA_66	20:18(16.01.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
165	18-Jan-22	HASSAN	66	HV2	ARAKALGUD_66	9:16	12:07	21:23	LINE CLEAR AVAILED
166	18-Jan-22	HASSAN	66	HV2	CHANNARAYAPATNA_66	12:35	14:21	2:56	LINE CLEAR AVAILED
167	18-Jan-22	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	12:51	15:22	4:13	MAIN SUPPLY FAILURE
168	18-Jan-22	HASSAN	66	YESLUR-SNVRST	YESLUR_66	12:37	14:52	3:29	NFBC ISSUED
169	18-Jan-22	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	15:32	16:00	7:32	LINE CLEAR AVAILED
170	18-Jan-22	HASSAN	110	BARANG-ANVATTI	BARANGI_110	15:38	15:52	7:30	LINE FAULT
171	18-Jan-22	HASSAN	110	HV1	ALKOLA_110	16:07	16:43	8:50	LINE CLEAR AVAILED
172	18-Jan-22	HASSAN	110	HV1	HOSANGADI_110	15:50	18:10	10:00	LINE CLEAR AVAILED
173	18-Jan-22	HASSAN	110	HV1	KONAJE_110	10:19	10:23	20:42	HAND TRIPPED
174	18-Jan-22	HASSAN	110	HV1	KONAJE_110	12:59	13:02	2:01	HAND TRIPPED
175	18-Jan-22	HASSAN	110	HV1	KONAJE_110	14:41	14:44	5:25	HAND TRIPPED
176	18-Jan-22	HASSAN	110	HV1	KONAJE_110	16:42	16:45	9:27	HAND TRIPPED
177	18-Jan-22	HASSAN	110	HV1	NAVUNDA_110	9:16	14:46	0:02	LINE CLEAR AVAILED
178	18-Jan-22	HASSAN	110	HV1	SHIRALKOPPA_220	13:34	17:55	7:29	LINE CLEAR AVAILED
179	18-Jan-22	HASSAN	110	HV2	KONAJE_110	10:18	10:24	20:42	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
180	18-Jan-22	HASSAN	110	HV2	KONAJE_110	12:59	13:02	2:01	HAND TRIPPED
181	18-Jan-22	HASSAN	110	HV2	KONAJE_110	14:41	14:44	5:25	HAND TRIPPED
182	18-Jan-22	HASSAN	110	HV2	KONAJE_110	16:41	16:46	9:27	HAND TRIPPED
183	18-Jan-22	HASSAN	110	HV2	KUNDAPURA_110	10:14	17:08	3:22	LINE CLEAR AVAILED
184	18-Jan-22	HASSAN	110	HV2	NAVUNDA_110	9:16	15:56	1:12	LINE CLEAR AVAILED
185	18-Jan-22	HASSAN	110	HV3	KONAJE_110	10:19	10:23	20:42	HAND TRIPPED
186	18-Jan-22	HASSAN	110	HV3	KONAJE_110	12:59	13:02	2:01	HAND TRIPPED
187	18-Jan-22	HASSAN	110	HV3	KONAJE_110	14:41	14:47	5:28	HAND TRIPPED
188	18-Jan-22	HASSAN	110	HV3	KONAJE_110	16:41	16:45	9:26	HAND TRIPPED
189	18-Jan-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
190	18-Jan-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
191	18-Jan-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAILED
192	18-Jan-22	HASSAN	110	KADUR-NERELEKERE	KADUR_220	14:48	16:32	7:20	HAND TRIPPED
193	18-Jan-22	HASSAN	110	KADUR-NGNHL	KADUR_220	14:48	16:32	7:20	HAND TRIPPED
194	18-Jan-22	HASSAN	110	KADUR-TNGL	KADUR_220	14:57	16:32	7:29	HAND TRIPPED
195	18-Jan-22	HASSAN	110	KAVOOR-KONAJE	KAVOOR_220	10:36	12:41	23:17	NFBC ISSUED
196	18-Jan-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
197	18-Jan-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
198	18-Jan-22	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	9:20	14:46	0:06	LINE CLEAR AVAILED
199	18-Jan-22	HASSAN	220	HV3	KAVOOR_220	13:54(6.01.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
200	18-Jan-22	HASSAN	220	KAUR-SHIMOGA	KADUR_220	14:33	16:29	7:02	LINE FAULT
201	18-Jan-22	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	14:33	16:31	7:04	LINE FAULT
202	18-Jan-22	MYSORE	66	BANNIMANTAPA-FTS	NO STATIONS EFFECTED	9:28	16:33	7:04	NFBC ISSUED
203	18-Jan-22	MYSORE	66	BANNIMANTAPA-VIJAYANAGARA	BANNIMANTAP_66	10:01	16:08	6:07	NFBC ISSUED
204	18-Jan-22	MYSORE	66	DK MAIDANA-JYOTHINAGARA	DKMAIDANA_66	10:06	16:00	5:54	NFBC ISSUED
205	18-Jan-22	MYSORE	66	HANAGODU-HUNSURU	NO STATIONS EFFECTED	14:04(18.01.22)			LINE OPEN:LINE FAULT
206	18-Jan-22	MYSORE	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
207	18-Jan-22	MYSORE	66	HV1	CHANDAKAVADI_66	11:15	12:14	0:59	LINE CLEAR AVAILED
208	18-Jan-22	MYSORE	66	HV1	SATHEGALA_66	7:45	7:55	0:09	TRANSFORMER FAULT
209	18-Jan-22	MYSORE	66	HV1	SANIVARASANTHE_66	10:29	16:13	5:44	LINE CLEAR AVAILED
210	18-Jan-22	MYSORE	66	HV2	KIADBMANDYA_66	11:33	12:02	0:29	LINE CLEAR AVAILED
211	18-Jan-22	MYSORE	66	HV2	PANDAVAPURA_66	10:48	12:33	1:45	LINE CLEAR AVAILED
212	18-Jan-22	MYSORE	66	HV2	PANDAVAPURA_66	13:01	13:37	0:35	LINE CLEAR AVAILED
213	18-Jan-22	MYSORE	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
214	18-Jan-22	MYSORE	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	9:40	16:46	7:06	NFBC ISSUED
215	18-Jan-22	MYSORE	66	KK HALLI-SHIMSHA-1	NO STATIONS EFFECTED	8:00:00 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
216	18-Jan-22	MYSORE	66	KUNTHUR-DR PETE	JANNUR_66 MUGUR_66 SANTHEMARAHALLI_66 THAYURU_66	3:12	3:18	0:06	LINE FAULT
217	18-Jan-22	MYSORE	66	PERIYAPATNA-HANAGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	2:03	2:14	0:10	LINE FAULT
218	18-Jan-22	MYSORE	66	SANIVARASANTHE-HV2	SANIVARASANTHE_66	10:30	16:15	5:45	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
219	18-Jan-22	MYSORE	66	SANIVARASANTHE-MALLIPATNA	SANIVARASANTHE_66	12:36	15:24	2:48	LINE CLEAR AVAIED
220	18-Jan-22	MYSORE	66	SANIVARASANTHE-MALLIPATNA	SANIVARASANTHE_66	15:26	15:32	0:06	HAND TRIPPED
221	18-Jan-22	MYSORE	66	SANIVARASANTHE-YESSLUR	SANIVARASANTHE_66	12:36	15:25	2:48	LINE CLEAR AVAIED
222	18-Jan-22	MYSORE	66	TALAKADU-ADANI	NO STATIONS EFFECTED	18:37	20:07	1:30	LINE CLEAR AVAIED
223	18-Jan-22	MYSORE	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAIED
224	18-Jan-22	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	3:59	4:15	0:15	LINE FAULT
225	18-Jan-22	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	5:49	6:12	0:22	LINE FAULT
226	18-Jan-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	14:05	14:15	0:10	LINE FAULT
227	18-Jan-22	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	11:09	22:10	11:00	LINE CLEAR AVAIED
228	18-Jan-22	TUMKUR	66	LINGADAHALLI- (NALLUR)	LINGDHALLI_66	9:34	22:04	12:29	NFBC ISSUED
229	18-Jan-22	TUMKUR	66	LINGADAHALLI- SHIMOGASHIMGA	LINGDHALLI_66	9:34	22:10	12:35	NFBC ISSUED
230	18-Jan-22	TUMKUR	66	NAGALAMADIKE- MUNIRAJ SOLAR_IPP_66	MUNIRAJ SOLAR_IPP_66	16:08	18:13	2:05	LINE CLEAR AVAIED
231	18-Jan-22	TUMKUR	66	NAGALAMADIKE- SUNDER RAJU SOLAR_IPP_66	SUNDER RAJU SOLAR_IPP_66	16:08	18:13	2:05	LINE CLEAR AVAIED
232	18-Jan-22	TUMKUR	66	NAGALAMADIKE-RNS INFRA SOLAR_IPP_66	RNS INFRA SOLAR_IPP_66	16:08	18:13	2:05	LINE CLEAR AVAIED
233	18-Jan-22	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	15:20	15:25	0:05	LINE FAULT
234	18-Jan-22	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR2	WELSPUN SOLAR2	10:16	11:05	0:49	LINE FAULT
235	18-Jan-22	TUMKUR	66	TR-1	CHANNAGIRI_66(LING)	9:28	22:06	12:37	LINE CLEAR AVAIED
236	18-Jan-22	TUMKUR	66	TR-1	DEVARAHALLI_66	20:29	22:10	1:40	LINE CLEAR AVAIED
237	18-Jan-22	TUMKUR	66	TR-1	GOWRASAMUDRA_66	11:31	12:12	0:41	LINE CLEAR AVAIED
238	18-Jan-22	TUMKUR	66	TR-1	PULAMGHATTA_66	12:22	12:31	0:08	TRANSFORMER FAULT
239	18-Jan-22	TUMKUR	66	TR-1	PAVAGADA_220	13:12	13:21	0:09	TRANSFORMER FAULT
240	18-Jan-22	TUMKUR	66	TR-1	KORA_66	4:53	11:46	6:52	TRANSFORMER FAULT
241	18-Jan-22	TUMKUR	66	TR-2	CHANNAGIRI_66(LING)	9:28	22:06	12:37	LINE CLEAR AVAIED
242	18-Jan-22	TUMKUR	66	TR-2	MAVINAKATTE_66	9:14	9:28	0:13	LINE CLEAR AVAIED
243	18-Jan-22	TUMKUR	66	TR-2	PULAMGHATTA_66	12:22	12:31	0:08	TRANSFORMER FAULT
244	18-Jan-22	TUMKUR	66	TR-2	PAVAGADA_220	17:55	17:58	0:03	TRANSFORMER FAULT
245	18-Jan-22	TUMKUR	110	TR-1	TIMMANAHALLI_110	14:08	14:20	0:11	HAND TRIPPED
246	19-Jan-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MORATAGI_110	13:11	14:23	1:12	LINE CLEAR AVAIED
247	19-Jan-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED THORVI_110(BICTY)	17:08	18:43	1:35	LINE CLEAR AVAIED
248	19-Jan-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED GOPANAKOPPA_110	14:32	15:35	1:03	LINE CLEAR AVAIED
249	19-Jan-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED MORATAGI_110	13:11	14:23	1:12	LINE CLEAR AVAIED
250	19-Jan-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED HALIYAL_110	12:10	12:20	0:10	TRANSFORMER FAULT
251	19-Jan-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTEDX ANMOD_110	10:00	10:10	0:10	LINE CLEAR AVAIED
252	19-Jan-22	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	8:45	8:57	0:12	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
253	19-Jan-22	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAIED
254	19-Jan-22	BAGALKOT	110	GHATAPRABHA-KABBUR	KABBUR_110	6:24	6:35	0:11	LINE FAULT
255	19-Jan-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAIED
256	19-Jan-22	BAGALKOT	110	HIREBEVANUR-LACHYAN	LACHYAN_110,RODAGI_110	17:15	17:25	0:10	LINE FAULT
257	19-Jan-22	BAGALKOT	110	HUNAGUND-JINDAL EHT	STATION NOT AFFECTED HUNAGUND_110	3:16	3:25	0:09	LINE FAULT
258	19-Jan-22	BAGALKOT	110	HUNGUND-JINDAL	STATION NOT AFFECTED HUNGUND_110	3:16	3:25	0:09	LINE FAULT
259	19-Jan-22	BAGALKOT	110	INDI220-DEVARA HIPPARAGI	DEVAR HIPPARAGI_110,HIREMASALI_110,AT HARGA_110	17:15	17:25	0:10	LINE FAULT
260	19-Jan-22	BAGALKOT	110	KARWAR-KUMTA	STATION NOT AFFECTED KARWAR_220	8:45	13:14	4:29	LINE CLEAR AVAIED
261	19-Jan-22	BAGALKOT	110	KARWAR-SOLARIS(BINAGA)	STATION NOT AFFECTED KARWAR_220	8:43	14:45	6:02	LINE CLEAR AVAIED
262	19-Jan-22	BAGALKOT	110	NAGJHARI1- AMBEWADI	AMBEWADI_220	10:10 (28.12.2021)			LINE OPEN:LINE CLEAR AVAIED
263	19-Jan-22	BAGALKOT	110	VAJRAMATTI-MANTUR(K.D.JAMBAGI)	VAJRAMATTI_220	19:38 (27.12.2021)	13:20 (19.01.2022)	569:42HRS	LINE CHARGED
264	19-Jan-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED MUGALKHOD_220	11:05	13:01	1:56	LINE CLEAR AVAIED
265	19-Jan-22	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED MUGALKHOD_220	9:01	10:59	1:58	LINE CLEAR AVAIED
266	19-Jan-22	BAGALKOT	220	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	15:37	16:25	0:48	LINE FAULT
267	19-Jan-22	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	7:00	18:52	11:52	LINE FAULT
268	19-Jan-22	BAGALKOT	220	BAGALKOT - GADAG1	STATION NOT AFFECTED BAGAKOT_220	13:15	18:19	5:04	LINE CLEAR AVAIED
269	19-Jan-22	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	12:55	13:45	0:50	LINE CLEAR AVAIED
270	19-Jan-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAIED
271	19-Jan-22	BAGALKOT	220	GADAG-BAGALKOT1	STATION NOT AFFECTED GADAG_220	13:15	18:19	5:04	NFBC ISSUED
272	19-Jan-22	BAGALKOT	220	HAVERI-NARENDRA	STATION NOT AFFECTED HAVERI_220	12:21	12:48	0:27	LINE CLEAR AVAIED
273	19-Jan-22	BAGALKOT	220	HAVERI-NARENDRA	STATION NOT AFFECTED HAVERI_220	14:50	19:04	4:14	LINE FAULT
274	19-Jan-22	BAGALKOT	220	HAVERI-NARENDRA1(BIDNAL)	STATION NOT AFFECTED HAVERI_220	12:55	13:44	0:49	LINE CLEAR AVAIED
275	19-Jan-22	BAGALKOT	220	HUBLI-SIRSI-1	STATION NOT AFFECTED HUBLI_220	12:19	17:06	4:47	LINE CLEAR AVAIED
276	19-Jan-22	BAGALKOT	220	HUBLI-SIRSI-2	STATION NOT AFFECTED HUBLI_220	12:21	17:10	4:49	LINE CLEAR AVAIED
277	19-Jan-22	BAGALKOT	220	HUBLI-SIRSI-2	STATION NOT AFFECTED HUBLI_220	17:10	18:23	1:13	LINE FAULT
278	19-Jan-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAIED
279	19-Jan-22	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
280	19-Jan-22	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED NARENDRA_220	12:21	19:04	6:43	LINE FAULT



SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
281	19-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	19:39 (30.12.2021)	12:09 (19.01.2022)	472:30HRS	LINE CHARGED
282	19-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
283	19-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY2	SIRSI_220	19:37 (30.12.2021)	12:09 (19.01.2022)	472:32HRS	LINE CHARGED
284	19-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
285	19-Jan-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	12:08	17:11	5:03	NFBC ISSUED
286	19-Jan-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	12:08	18:05	5:57	NFBC ISSUED
287	19-Jan-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	12:08	18:05	5:57	NFBC ISSUED
288	19-Jan-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
289	19-Jan-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
290	19-Jan-22	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	10:23	10:28	0:05	LINE CLEAR AVAILED
291	19-Jan-22	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	15:20	15:25	0:05	LOAD CHANGE OVER
292	19-Jan-22	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	21:17	21:22	0:05	LOAD CHANGE OVER
293	19-Jan-22	BENGALURU	66	DALSANUR - YELDUR	YELDUR	22:57	23:08	0:11	LINE FAULT
294	19-Jan-22	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	10:25	18:47	8:22	LINE CLEAR AVAILED
295	19-Jan-22	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	10:25	18:50	8:25	LINE CLEAR AVAILED
296	19-Jan-22	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADOSANAHALLI	10:25	18:40	8:15	LINE CLEAR AVAILED
297	19-Jan-22	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA	10:25	18:40	8:15	LINE CLEAR AVAILED
298	19-Jan-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	10:34	18:47	8:13	LINE CLEAR AVAILED
299	19-Jan-22	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA, NITRALLI	10:10	18:50	8:40	LINE CLEAR AVAILED
300	19-Jan-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	10:25	18:50	8:25	LINE CLEAR AVAILED
301	19-Jan-22	BENGALURU	66	HV1	DASHAVARA	15:17	15:23	0:06	TRANSFORMER FAULT
302	19-Jan-22	BENGALURU	66	HV1	ELECTRONIC CITY	14:37	18:50	4:13	LINE CLEAR AVAILED
303	19-Jan-22	BENGALURU	66	HV1	GOWRIBIDANUR 220	10:20	18:38	8:18	LINE CLEAR AVAILED
304	19-Jan-22	BENGALURU	66	HV1	SIRIGIRIPURA	10:59	11:10	0:10	LINE CLEAR AVAILED
305	19-Jan-22	BENGALURU	66	HV2	VIJAYANAGARA	20:40	20:55	0:15	LOAD CHANGE OVER
306	19-Jan-22	BENGALURU	66	HV2	GOWRIBIDANUR 220	10:20	18:38	8:18	LINE CLEAR AVAILED
307	19-Jan-22	BENGALURU	66	HV2	SARJAPURA 220	16:13	16:33	0:19	TRANSFORMER FAULT
308	19-Jan-22	BENGALURU	66	HV3	BANASHANKARI	22:09(19/01/2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
309	19-Jan-22	BENGALURU	66	KEMBODI - KOLAR 220	KEMBODI	11:30	12:20	0:50	LINE CLEAR AVAILED
310	19-Jan-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	1:23	1:36	0:13	LINE FAULT
311	19-Jan-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
312	19-Jan-22	BENGALURU	66	MAGADI 220 - T G HALLI	T G HALLI, TAVARAKERE	13:58	15:02	1:03	LINE CLEAR AVAILED
313	19-Jan-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	10:26	17:58	7:32	LINE CLEAR AVAILED
314	19-Jan-22	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	5:41	5:46	0:05	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
315	19-Jan-22	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	9:55	17:53	7:58	LINE CLEAR AVAILED
316	19-Jan-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	5:42	5:47	0:05	LOAD CHANGEOVER
317	19-Jan-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	10:26	17:58	7:32	LINE CLEAR AVAILED
318	19-Jan-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	5:42	5:47	0:05	LOAD CHANGEOVER
319	19-Jan-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	10:07	17:50	7:43	LINE CLEAR AVAILED
320	19-Jan-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA	10:07	17:50	7:43	LINE CLEAR AVAILED
321	19-Jan-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	5:41	5:46	0:05	LOAD CHANGEOVER
322	19-Jan-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA, MANDIKAL	10:07	17:55	7:48	LINE CLEAR AVAILED
323	19-Jan-22	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	6:27	13:40	7:13	LINE FAULT
324	19-Jan-22	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	10:25	14:46	4:21	LINE CLEAR AVAILED
325	19-Jan-22	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	22:27	22:35	0:08	LINE FAULT
326	19-Jan-22	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	10:51	14:31	3:40	LOAD CURTAILMENT
327	19-Jan-22	BENGALURU	220	GOWRIBIDANUR 220 - MADHUGIRI	MADHUGIRI	14:55	18:30	3:35	LINE CLEAR AVAILED
328	19-Jan-22	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	10:29	17:38	7:09	LINE CLEAR AVAILED
329	19-Jan-22	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	10:29	17:40	7:11	LINE CLEAR AVAILED
330	19-Jan-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	14:15	18:30	4:15	LINE CLEAR AVAILED
331	19-Jan-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	14:15	18:30	4:15	LINE CLEAR AVAILED
332	19-Jan-22	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 1	RVNL	14:15	18:42	4:27	LINE CLEAR AVAILED
333	19-Jan-22	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2	NO STATION AFFECTED	14:15	18:42	4:27	LINE CLEAR AVAILED
334	19-Jan-22	BENGALURU	220	HV1	MITTEMARI 220	10:29	17:39	7:10	LINE CLEAR AVAILED
335	19-Jan-22	BENGALURU	220	HV1	GOWRIBIDANUR 220	10:34	18:35	8:01	LINE CLEAR AVAILED
336	19-Jan-22	BENGALURU	220	HV2	MITTEMARI 220	8:47	17:40	8:53	LINE CLEAR AVAILED
337	19-Jan-22	BENGALURU	220	HV2	GOWRIBIDANUR 220	10:34	18:35	8:01	LINE CLEAR AVAILED
338	19-Jan-22	BENGALURU	220	HV3	GOWRIBIDANUR 220	10:24	18:37	8:13	LINE CLEAR AVAILED
339	19-Jan-22	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 220 1	MITTEMARI 220	10:29	17:38	7:09	LINE CLEAR AVAILED
340	19-Jan-22	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 220 2	MITTEMARI 220	10:29	17:40	7:11	LINE CLEAR AVAILED
341	19-Jan-22	GULBARGA	66	HV3	TELAGI_66	11:25	12:10	0:45	LINE CLEAR AVAILED
342	19-Jan-22	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKANAHALLI_66,HAGARIBOMMANAHALLI_66,RR STEELS_IPP	10:30	10:40	0:10	LINE FAULT
343	19-Jan-22	GULBARGA	110	CHILKAMUKHI-BEVOOR	CHILKAMUKHI_110	17:30	17:50	0:20	MAIN SUPPLY FAILURE
344	19-Jan-22	GULBARGA	110	CHILKAMUKHI-BEVOOR	CHILKAMUKHI_110	17:55	18:30	0:35	MAIN SUPPLY FAILURE
345	19-Jan-22	GULBARGA	110	GALAG-MALLAT	GALAG_110	12:20	12:40	0:20	MAIN SUPPLY FAILURE
346	19-Jan-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	9:35	17:48	8:13	LINE CLEAR AVAILED
347	19-Jan-22	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110	17:01	18:27	1:26	LINE CLEAR AVAILED
348	19-Jan-22	GULBARGA	110	HV1	HUNSIGI_110	12:15	12:25	0:10	TRANSFORMER FAULT
349	19-Jan-22	GULBARGA	110	HV1	HUNSIGI_110	14:40	15:00	0:20	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
350	19-Jan-22	GULBARGA	110	HV1	RAJESHWAR_110	13:45	18:20	4:35	LINE CLEAR AVAILED
351	19-Jan-22	GULBARGA	110	HV1 & HV2	MYLAR_110	14:02	14:12	0:10	LINE CLEAR AVAILED
352	19-Jan-22	GULBARGA	110	HV2	KUKUNOOR_110	11:25	13:35	2:10	LINE CLEAR AVAILED
353	19-Jan-22	GULBARGA	110	HV2	KUSTAGI_220	11:26	11:38	0:12	TRANSFORMER FAULT
354	19-Jan-22	GULBARGA	110	HV2	SHAHAPUR_220	10:58	11:15	0:17	TRANSFORMER FAULT
355	19-Jan-22	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	16:40	17:13	0:33	LINE CLEAR AVAILED
356	19-Jan-22	GULBARGA	110	KAPNOOR-GULBARGA WEST1	GULBARGA WEST_110,GULBARGA SOUTH_110	16:56	17:04	0:08	LINE CLEAR AVAILED
357	19-Jan-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	16:40	17:13	0:33	LINE CLEAR AVAILED
358	19-Jan-22	GULBARGA	110	KUSTAGI-BEVOOR	BEVOOR_110,MANGLORE_110	18:07	18:23	0:16	LINE CLEAR AVAILED
359	19-Jan-22	GULBARGA	110	LV2	KAPNOOR_220	16:52	17:03	0:11	LINE CLEAR AVAILED
360	19-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	0:17	0:27	0:10	LINE FAULT
361	19-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	1:15	1:25	0:10	LINE FAULT
362	19-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	3:32	3:47	0:15	LINE FAULT
363	19-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	4:16	4:26	0:10	LINE FAULT
364	19-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	6:02	6:12	0:10	LINE FAULT
365	19-Jan-22	GULBARGA	110	MANGALORE-BEVOOR	MANGALORE_110	17:30	17:50	0:20	MAIN SUPPLY FAILURE
366	19-Jan-22	GULBARGA	110	MANGALORE-BEVOOR	MANGALORE_110	18:00	18:30	0:30	MAIN SUPPLY FAILURE
367	19-Jan-22	GULBARGA	110	MANGALORE-BEVOOR	MANGALORE_110	18:35	18:40	0:05	MAIN SUPPLY FAILURE
368	19-Jan-22	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	10:53	10:55	0:02	MAIN SUPPLY FAILURE
369	19-Jan-22	GULBARGA	110	METRI-ALIPUR	METRI_110	6:30	6:40	0:10	MAIN SUPPLY FAILURE
370	19-Jan-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAK THINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
371	19-Jan-22	GULBARGA	110	RAJESHWAR-NTTPSOLAR_IPP	RAJESHWAR_110	9:40	18:20	8:40	LINE CLEAR AVAILED
372	19-Jan-22	GULBARGA	110	RAJESHWAR-WARDHASOLAR_IPP	RAJESHWAR_110	17:00	18:25	1:25	LINE CLEAR AVAILED
373	19-Jan-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
374	19-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:44 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
375	19-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:08 (18.01.2022)	10:07 (19.01.2022)	13:59 HRS	LINE CHARGED
376	19-Jan-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	11:55	12:30	0:35	LINE CLEAR AVAILED
377	19-Jan-22	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	11:10	17:20	6:10	LINE CLEAR AVAILED
378	19-Jan-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	10:37	10:57	0:20	LINE FAULT
379	19-Jan-22	GULBARGA	110	TEKKALKOTE-RENEW SOLAR	TEKKALKOTE_110	22:46	23:30	0:44	LINE FAULT
380	19-Jan-22	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	15:26	16:54	1:28	LINE CLEAR AVAILED
381	19-Jan-22	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	17:07	18:02	0:55	LINE CLEAR AVAILED
382	19-Jan-22	GULBARGA	110	YELBURGA-PARAM POOJYA,TALAKUTAI_IPP	YELBURGA_110	12:40	12:50	0:10	LOAD CURTAILMENT
383	19-Jan-22	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	13:00	13:30	0:30	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
384	19-Jan-22	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
385	19-Jan-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
386	19-Jan-22	GULBARGA	220	HV2	SINDHANOOR_220	11:55	12:25	0:30	LINE CLEAR AVAILED
387	19-Jan-22	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	3:22 (17.01.2022)			LINE OPEN:LINE FAULT
388	19-Jan-22	HASSAN	66	AREHALI-SAKLESPUR	AREHALLI_66	9:30	17:25	7:55	MAIN SUPPLY FAILURE
389	19-Jan-22	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLY_66	5:05	5:13	0:08	LINE FAULT
390	19-Jan-22	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	9:30	11:30	2:00	MAIN SUPPLY FAILURE
391	19-Jan-22	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	15:26	17:26	2:00	NFBC ISSUED
392	19-Jan-22	HASSAN	66	HV1	AREHALLI_66	9:30	17:25	7:55	MAIN SUPPLY FAILURE
393	19-Jan-22	HASSAN	66	HV1	DODDAHALLY_66	10:37	14:55	4:18	LINE CLEAR AVAILED
394	19-Jan-22	HASSAN	66	HV1	DODDAKADANUR_66	13:33	18:23	4:50	LINE CLEAR AVAILED
395	19-Jan-22	HASSAN	66	HV1	HANBALU_66	9:30	11:30	2:00	MAIN SUPPLY FAILURE
396	19-Jan-22	HASSAN	66	HV1	HANBALU_66	15:26	17:26	2:00	NFBC ISSUED
397	19-Jan-22	HASSAN	66	HV1	YESLUR_66	12:09	12:56	0:47	LINE CLEAR AVAILED
398	19-Jan-22	HASSAN	66	HV2	BASAVAGHATTA_66	20:18(16.01.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
399	19-Jan-22	HASSAN	66	HV2	MALLAPURA_66	10:45	16:39	5:54	TRANSFORMER FAULT
400	19-Jan-22	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	9:30	11:30	2:00	LINE CLEAR AVAILED
401	19-Jan-22	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	15:26	17:26	2:00	LINE CLEAR AVAILED
402	19-Jan-22	HASSAN	110	HV	PUTTUR_220	9:55	10:10	0:15	HAND TRIPPED
403	19-Jan-22	HASSAN	110	HV1	BIRUR_110	10:00	16:53	6:53	LINE CLEAR AVAILED
404	19-Jan-22	HASSAN	110	HV1	GURUPURA_110	11:00	12:15	1:15	LINE CLEAR AVAILED
405	19-Jan-22	HASSAN	110	HV1	KADUR_220	10:44	10:55	0:11	HAND TRIPPED
406	19-Jan-22	HASSAN	110	HV2	BIRUR_110	10:00	16:53	6:53	LINE CLEAR AVAILED
407	19-Jan-22	HASSAN	110	HV2	KONAJE_110	11:06	15:38	4:32	LINE CLEAR AVAILED
408	19-Jan-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
409	19-Jan-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
410	19-Jan-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAILED
411	19-Jan-22	HASSAN	110	KEMAR-Manipal1	KEMAR_220	12:44	13:35	0:51	NFBC ISSUED
412	19-Jan-22	HASSAN	110	LV1	PUTTUR_220	9:23	10:09	0:46	LINE CLEAR AVAILED
413	19-Jan-22	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	12:44	13:35	0:51	LINE CLEAR AVAILED
414	19-Jan-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
415	19-Jan-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
416	19-Jan-22	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	9:33	10:12	0:39	HAND TRIPPED
417	19-Jan-22	HASSAN	110	PUTTUR-PUTUR2	PUTTUR_220	9:32	10:11	0:39	HAND TRIPPED
418	19-Jan-22	HASSAN	110	PUTTUR-PUTUR2	PUTTUR_220	14:55	15:01	0:06	HAND TRIPPED
419	19-Jan-22	HASSAN	220	GESOPA-TALGUPA2	gerusoppa_gen	15:34	16:37	1:03	NFBC ISSUED
420	19-Jan-22	HASSAN	220	GOPALAP-HNPUR21	GOPALPUA_220	13:00	15:02	2:02	NFBC ISSUED
421	19-Jan-22	HASSAN	220	HNPR2-GPLPR1	HOLENARASIPURA_220	13:00	15:02	2:02	LINE CLEAR AVAILED
422	19-Jan-22	HASSAN	220	HV1	PUTTUR_220	9:23	10:09	0:46	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
423	19-Jan-22	HASSAN	220	HV3	KAVOOR_220	13:54(6.01.2022)	16:56(19.01.2022)	27:04hrs	TRANSFORMER CHARGED
424	19-Jan-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	17:33	20:24	2:51	LINE FAULT
425	19-Jan-22	HASSAN	220	SHARAVATHY-SHIVAMOGGA	sharavathy_gen	17:33	20:24	2:51	LINE FAULT
426	19-Jan-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	15:34	16:37	1:03	LINE CLEAR AVAILED
427	19-Jan-22	MYSURU	66	BETTADAPURA-KUSHALANAGARA	BETTADHAPURA_66	14:58	15:05	0:06	LINE CLEAR AVAILED
428	19-Jan-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAILED
429	19-Jan-22	MYSURU	66	HANAGODU-HUNSURU	NO STATIONS EFFECTED	2:04:00 (18.01.2022)	10:59:30	32:46 Hrs	LINE CHARGED
430	19-Jan-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
431	19-Jan-22	MYSURU	66	HOOTAGALLY-VIJAYANAGARA	BANNIMANTAP_66 VIJAYANAGRAMYS_66	7:22	7:45	0:23	LINE FAULT
432	19-Jan-22	MYSURU	66	HV1	BANNIMANTAP_66	7:22	7:46	0:24	MAIN SUPPLY FAILURE
433	19-Jan-22	MYSURU	66	HV1	BETTADHAPURA_66	14:56	15:05	0:08	LINE CLEAR AVAILED
434	19-Jan-22	MYSURU	66	HV1	KHBCOLONY_66	10:00	15:00	4:59	LINE CLEAR AVAILED
435	19-Jan-22	MYSURU	66	HV1	VIJAYANAGRAMYS_66	7:33	7:46	0:12	MAIN SUPPLY FAILURE
436	19-Jan-22	MYSURU	66	HV2	BANNIMANTAP_66	7:22	7:46	0:24	MAIN SUPPLY FAILURE
437	19-Jan-22	MYSURU	66	HV2	BETTADHAPURA_66	14:56	15:06	0:09	LINE CLEAR AVAILED
438	19-Jan-22	MYSURU	66	HV2	HANGLA_66	17:10	18:11	1:00	LINE CLEAR AVAILED
439	19-Jan-22	MYSURU	66	HV2	KHBCOLONY_66	10:00	15:00	4:59	LINE CLEAR AVAILED
440	19-Jan-22	MYSURU	66	HV2	VIJAYANAGRAMYS_66	7:33	7:46	0:12	MAIN SUPPLY FAILURE
441	19-Jan-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
442	19-Jan-22	MYSURU	66	KHB STATION-BILIKERE	DMG_HALLI_66	10:40	16:42	6:02	NFBC ISSUED
443	19-Jan-22	MYSURU	66	KHB STATION-HOOTAGALLY	KHBCOLONY_66	10:15	14:58	4:43	NFBC ISSUED
444	19-Jan-22	MYSURU	66	KK HALLI-SHIMSHA-1	NO STATIONS EFFECTED	8:00:00 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
445	19-Jan-22	MYSURU	66	SUNTIKOPPA-KUSHALANAGARA	SUNTIKOPPA_66	10:26	11:09	0:43	LINE CLEAR AVAILED
446	19-Jan-22	MYSURU	66	SUNTIKOPPA-MADIKERI	SUNTIKOPPA_66	10:26	11:15	0:48	LINE CLEAR AVAILED
447	19-Jan-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
448	19-Jan-22	MYSURU	66	TUBINAKERE-NAGAMAGALA 1	NO STATIONS EFFECTED	19:12	19:20	0:07	LINE FAULT
449	19-Jan-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:01	17:55	10:53	LINE CLEAR AVAILED
450	19-Jan-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	18:28	18:53	0:24	LINE FAULT
451	19-Jan-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	20:01	20:22	0:21	LINE FAULT
452	19-Jan-22	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	13:57	15:55	1:57	LINE CLEAR AVAILED
453	19-Jan-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:08	18:26	9:18	LINE CLEAR AVAILED
454	19-Jan-22	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	5:44	5:53	0:08	LINE FAULT
455	19-Jan-22	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:09	9:19	0:10	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
456	19-Jan-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	11:28	11:36	0:08	LINE FAULT
457	19-Jan-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	9:00	9:31	0:31	HAND TRIPPED
458	19-Jan-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	18:30	18:35	0:05	HAND TRIPPED
459	19-Jan-22	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	9:31	18:32	9:00	NFBC ISSUED
460	19-Jan-22	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	7:59	8:07	0:08	LINE FAULT
461	19-Jan-22	TUMKUR	66	TR-1	MAVINAKATTE_66	8:09	8:11	0:02	TRANSFORMER FAULT
462	19-Jan-22	TUMKUR	66	TR-1	PANDRAHALLI_66	11:22	12:11	0:49	TRANSFORMER FAULT
463	19-Jan-22	TUMKUR	66	TR-1	PDKOTE_66	11:46	11:52	0:05	TRANSFORMER FAULT
464	19-Jan-22	TUMKUR	66	TR-1	SOKKE_66	14:42	17:18	2:35	MAIN SUPPLY FAILURE
465	19-Jan-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	7:20	7:25	0:05	TRANSFORMER FAULT
466	19-Jan-22	TUMKUR	66	TR-2	CHITRADURGA_66	10:41	11:11	0:29	LINE CLEAR AVAIED
467	19-Jan-22	TUMKUR	66	TR-2	HIREMALANA HOLE_66	7:42	7:53	0:11	TRANSFORMER FAULT
468	19-Jan-22	TUMKUR	66	TR-2	NAYAKANHATTI_66	13:09	13:20	0:10	TRANSFORMER FAULT
469	19-Jan-22	TUMKUR	66	TR-2(LV SIDE )	DAVANGERE_SRS_220	10:34	12:43	2:09	LINE CLEAR AVAIED
470	19-Jan-22	TUMKUR	110	TR-1	HALKURKE_110	11:53	14:30	2:36	LINE CLEAR AVAIED
471	19-Jan-22	TUMKUR	110	TR-1	SAMPIGE_110	0:37	0:52	0:15	TRANSFORMER FAULT
472	19-Jan-22	TUMKUR	110	TR-1	TIMMANAHALLI_110	11:30	16:36	5:05	LINE CLEAR AVAIED
473	19-Jan-22	TUMKUR	110	TR-2	TIMMANAHALLI_110	13:03	14:31	1:27	LINE CLEAR AVAIED
474	19-Jan-22	TUMKUR	220	TR-2(HV SIDE)	DAVANGERE_SRS_220	10:34	12:43	2:09	LINE CLEAR AVAIED
475	20-Jan-22	BAGALKOT	110	110/11KV, HV1	CHIKKODI_220	16:52	19:21	2:29	TRANSFORMER FAULT
476	20-Jan-22	BAGALKOT	110	110/11KV,HV1	GOKAK_110	9:35	11:58	2:23	LINE CLEAR AVAIED
477	20-Jan-22	BAGALKOT	110	110/11KV,HV1	THORVI_110(BICTY)	17:21	18:25	1:04	HAND TRIPPED
478	20-Jan-22	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	13:53	14:42	0:49	LINE CLEAR AVAIED
479	20-Jan-22	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110 &WIND1&WIND2_33	17:34	17:40	0:06	TRANSFORMER FAULT
480	20-Jan-22	BAGALKOT	110	220/110KV, LV2	SOUDATTI_220, SOUDATTI_110, MUNAVALLI_110, RAMDURGA_110, YARGATTI_110, MMCL_110	11:44	12:01	0:17	TRANSFORMER FAULT
481	20-Jan-22	BAGALKOT	110	220/110KV, LV2	SOUDATTI_220, SOUDATTI_110, MUNAVALLI_110, RAMDURGA_110, YARGATTI_110, MMCL_110	12:15	12:29	0:14	TRANSFORMER FAULT
482	20-Jan-22	BAGALKOT	110	220/110KV, LV2	SOUDATTI_220, SOUDATTI_110, MUNAVALLI_110, RAMDURGA_110, YARGATTI_110, MMCL_110	12:45	12:54	0:09	TRANSFORMER FAULT
483	20-Jan-22	BAGALKOT	110	BAGALKOT220-RAMDURG	STATION NOT AFFECTED BAGALKOT_220	16:35	16:40	0:05	HAND TRIPPED
484	20-Jan-22	BAGALKOT	110	CHIKKODI220- BHOJ	BHOJ_110	12:55	17:21	4:26	LINE CLEAR AVAIED
485	20-Jan-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAIED
486	20-Jan-22	BAGALKOT	110	GHATAPRABHA220- GOKAK	GOKAK_110	1:04	1:16	0:12	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
487	20-Jan-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
488	20-Jan-22	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	12:30	13:18	0:48	NFBC ISSUED
489	20-Jan-22	BAGALKOT	110	NARGUND-BPCL	NARAGUND_110 BPCL_110	9:59	17:35	7:36	LINE CLEAR AVAILED
490	20-Jan-22	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	RATTIHALLI_110	12:40	12:55	0:15	LINE FAULT
491	20-Jan-22	BAGALKOT	110	YALLAMMANAWADI-ALBAL	ALBAL_110	21:16	21:31	0:15	LINE FAULT
492	20-Jan-22	BAGALKOT	220	220/110KV, HV1,LV1	STATION NOT AFFECTED SOUDATTI_220	9:03	18:15	9:12	LINE CLEAR AVAILED
493	20-Jan-22	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	12:43 (20.01.2022)			LINE OPEN:LINE CLEAR AVAILED
494	20-Jan-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
495	20-Jan-22	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	10:48	12:53	2:05	LINE CLEAR AVAILED
496	20-Jan-22	BAGALKOT	220	KADRA1- KARWAR	STATION NOT AFFECTED KARWAR_220	15:53	18:11	2:18	HAND TRIPPED
497	20-Jan-22	BAGALKOT	220	KADRA2- KARWAR	STATION NOT AFFECTED KARWAR_220	11:50	15:50	4:00	HAND TRIPPED
498	20-Jan-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
499	20-Jan-22	BAGALKOT	220	NAGJHARI1- AMBEWADI	STATION NOT AFFECTED AMBEWADI_220	10:10 (28.12.2021)	15:07 (20.01.2022)	556:57 hrs	LINE CHARGED
500	20-Jan-22	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
501	20-Jan-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	10:48	12:53	2:05	LINE CLEAR AVAILED
502	20-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
503	20-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
504	20-Jan-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
505	20-Jan-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
506	20-Jan-22	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110,KAKMARI_110,YALLAMA NAWADI_110,TODALABAGI_110,SAV ALAGI_110,ALBAL_110	21:16	21:29	0:13	LINE FAULT
507	20-Jan-22	BENGALURU	66	BANASHANKARI - SUBRAMANYAPURA 220	BANASHANKARI	5:20	5:25	0:05	LOAD CHANGE OVER
508	20-Jan-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	17:53	18:00	0:07	LOAD CHANGE OVER
509	20-Jan-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALIC CROSS, YENNIGADALE	17:53	17:59	0:06	LOAD CHANGE OVER
510	20-Jan-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	16:57	17:55	0:58	LINE CLEAR AVAILED
511	20-Jan-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	6:45	6:47	0:01	LOAD CHANGE OVER
512	20-Jan-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:12	15:17	0:04	LOAD CHANGE OVER
513	20-Jan-22	BENGALURU	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	15:10	15:17	0:07	LOAD CHANGE OVER
514	20-Jan-22	BENGALURU	66	HANUMANTHNAGAR - YEDUMADU	HANUMANTHNAGAR	16:45	16:51	0:06	LOAD CHANGE OVER
515	20-Jan-22	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	12:28	12:45	0:16	LOAD CHANGE OVER
516	20-Jan-22	BENGALURU	66	HV1	CHANDRA LAYOUT	16:38	16:51	0:13	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
517	20-Jan-22	BENGALURU	66	HV1	IRGAMPALLI	15:55	16:15	0:20	LINE CLEAR AVAILED
518	20-Jan-22	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	10:50	10:55	0:05	LINE CLEAR AVAILED
519	20-Jan-22	BENGALURU	66	HV1	THIMMAMPALLI	13:35	13:40	0:05	LOAD CHANGE OVER
520	20-Jan-22	BENGALURU	66	HV2	ATTUR YELAHANKA	13:04	13:34	0:30	LINE CLEAR AVAILED
521	20-Jan-22	BENGALURU	66	HV2	BANGARPET	16:11	16:41	0:29	LINE CLEAR AVAILED
522	20-Jan-22	BENGALURU	66	HV2	CHANDRA LAYOUT	16:38	16:51	0:13	LINE CLEAR AVAILED
523	20-Jan-22	BENGALURU	66	HV2	HSR LAYOUT 220	15:05	15:11	0:06	LINE CLEAR AVAILED
524	20-Jan-22	BENGALURU	66	HV2	IRGAMPALLI	14:37	16:01	1:24	LINE CLEAR AVAILED
525	20-Jan-22	BENGALURU	66	HV2	THIMMAMPALLI	15:45	15:50	0:05	LOAD CHANGE OVER
526	20-Jan-22	BENGALURU	66	HV2	VIJAYNAGAR	16:20	16:30	0:10	LOAD CHANGE OVER
527	20-Jan-22	BENGALURU	66	HV2	VIJAYNAGAR	1:01	1:05	0:04	LOAD CHANGE OVER
528	20-Jan-22	BENGALURU	66	HV3	BANASHANKARI	22:09(19/01/2022)	4:15(20/01/2022)	6:06HRS	TRANSFORMER CHARGED
529	20-Jan-22	BENGALURU	66	HV3	BANGARPET	17:10	17:35	0:25	LINE CLEAR AVAILED
530	20-Jan-22	BENGALURU	66	HV3	KGF	11:00	11:24	0:24	LINE CLEAR AVAILED
531	20-Jan-22	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	9:55	10:00	0:05	LOAD CHANGE OVER
532	20-Jan-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66	14:36	15:08	0:32	LINE FAULT
533	20-Jan-22	BENGALURU	66	NELMANGALA 66 - DABUSPET 220	NELMANGALA 66	13:30	18:36	5:06	LINE CLEAR AVAILED
534	20-Jan-22	BENGALURU	66	NELMANGALA 66 - DABUSPET 220	NELMANGALA 66	18:47	18:53	0:06	LINE CLEAR AVAILED
535	20-Jan-22	BENGALURU	66	NELMANGALA 66 - DABUSPET 220	NELMANGALA 66	19:12	19:40	0:28	LINE CLEAR AVAILED
536	20-Jan-22	BENGALURU	66	NELMANGALA 66 - DABUSPET 220	NELMANGALA 66	19:41	19:43	0:02	LINE CLEAR AVAILED
537	20-Jan-22	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, DIBBURAHALLI	10:03	10:10	0:06	LINE FAULT
538	20-Jan-22	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	5:13	5:25	0:11	LINE FAULT
539	20-Jan-22	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:28	6:43	0:15	LINE FAULT
540	20-Jan-22	GULBARGA	66	HOSAHALLI-BADALADUKU	HOSAHALLI_66	9:10	9:50	0:40	MAIN SUPPLY FAILURE
541	20-Jan-22	GULBARGA	66	HV2	HARAPANAHALLI_66	7:55	8:00	0:05	TRANSFORMER FAULT
542	20-Jan-22	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,MA GALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	7:03	7:22	0:19	LINE FAULT
543	20-Jan-22	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66	9:10	9:30	0:20	LINE FAULT
544	20-Jan-22	GULBARGA	110	GALAG-ALKOD	GALAG_110	10:00	16:40	6:40	MAIN SUPPLY FAILURE
545	20-Jan-22	GULBARGA	110	HV1	METRI_110	7:05	7:15	0:10	TRANSFORMER FAULT
546	20-Jan-22	GULBARGA	110	HV2	KUKUNOOR_110	19:00(20.01.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
547	20-Jan-22	GULBARGA	110	KUDITINI-TORANGALU	TORANGALU_110	10:28	16:23	5:55	NFBC ISSUED
548	20-Jan-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_1 10	0:58	1:08	0:10	LINE FAULT
549	20-Jan-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_1 10	13:40	13:50	0:10	LINE FAULT
550	20-Jan-22	GULBARGA	110	METRI-ALIPUR	METRI_110	10:30	16:20	5:50	MAIN SUPPLY FAILURE
551	20-Jan-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAK THINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
552	20-Jan-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED



SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
553	20-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:40 (20.01.2022)			LINE OPEN:LINE CLEAR AVAILED
554	20-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:44 (19.01.2022)	9:17 (20.01.2022)	11:33 HRS	LINE CHARGED
555	20-Jan-22	GULBARGA	110	TEKKALKOTE-RENEW SOLAR	TEKKALKOTE_110	1:25	1:49	0:24	LINE FAULT
556	20-Jan-22	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
557	20-Jan-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
558	20-Jan-22	GULBARGA	220	LINGASUGUR-KUSTAGI	KUSTAGI_220	8:55	19:06	10:11	LINE CLEAR AVAILED
559	20-Jan-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	18:19	18:36	0:17	LINE FAULT
560	20-Jan-22	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	10:25	14:41	4:16	LINE CLEAR AVAILED
561	20-Jan-22	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	16:17	17:22	1:05	LINE CLEAR AVAILED
562	20-Jan-22	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	3:22 (17.01.2022)	7:00 (20.01.2022)	75:38 HRS	LINE CHARGED
563	20-Jan-22	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	9:29	10:27	0:58	LINE FAULT
564	20-Jan-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	15:27	15:53	0:26	LINE FAULT
565	20-Jan-22	HASSAN	66	HV2	BASAVAGHATTA_66	20:18(16.01.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
566	20-Jan-22	HASSAN	110	HV1	ARASIKERE_110	10:11	18:04	7:53	LINE CLEAR AVAILED
567	20-Jan-22	HASSAN	110	HV1	GURUVAYANKERE_110	10:20	13:30	3:10	LINE CLEAR AVAILED
568	20-Jan-22	HASSAN	110	HV1	GURUVAYANKERE_110	13:45	14:15	0:30	LINE CLEAR AVAILED
569	20-Jan-22	HASSAN	110	HV1	HOSANGADI_110	15:38	16:26	0:48	LINE CLEAR AVAILED
570	20-Jan-22	HASSAN	110	HV2	ARASIKERE_110	10:36	18:23	7:47	LINE CLEAR AVAILED
571	20-Jan-22	HASSAN	110	HV2	KUNDAPURA_110	11:16	11:41	0:25	LINE CLEAR AVAILED
572	20-Jan-22	HASSAN	110	HV3	HIRIYADKA_110	13:58	14:09	0:11	TRANSFORMER FAULT
573	20-Jan-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
574	20-Jan-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
575	20-Jan-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAILED
576	20-Jan-22	HASSAN	110	LV1	SHIRALKOPPA_220	13:12	13:26	0:14	HAND TRIPPED
577	20-Jan-22	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	11:02	16:10	5:08	LINE CLEAR AVAILED
578	20-Jan-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
579	20-Jan-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
580	20-Jan-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:09	13:28	0:19	HAND TRIPPED
581	20-Jan-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:50	13:21	0:31	HAND TRIPPED
582	20-Jan-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:07	13:13	0:06	HAND TRIPPED
583	20-Jan-22	HASSAN	220	HV1	SHIRALKOPPA_220	12:58	13:10	0:12	HAND TRIPPED
584	20-Jan-22	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	15:01	17:24	2:23	LINE CLEAR AVAILED
585	20-Jan-22	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMSG_220	13:32	13:46	0:14	LINE FAULT
586	20-Jan-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:34	13:42	2:08	LINE CLEAR AVAILED
587	20-Jan-22	HASSAN	220	SHRAVTY-SHIMOGA4	gen_sharavthy	11:34	13:42	2:08	NFBC ISSUED
588	20-Jan-22	MYSURU	66	BANNIMANTAPA-FTS	NO STATIONS EFFECTED	7:31	7:51	0:20	MAIN SUPPLY FAILURE
589	20-Jan-22	MYSURU	66	BANNIMANTAPA-VIJAYANAGARA	BANNIMANTAP_66	7:40	14:30	6:49	NFBC ISSUED
590	20-Jan-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAILED
591	20-Jan-22	MYSURU	66	BOOKANAKERE-KR PETE	GANJIGERE_66 SHEELUNERE_66	11:03	14:04	3:00	NFBC ISSUED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
592	20-Jan-22	MYSURU	66	BOOKANAKERE-KR PETE	GANJIGERE_66 SHEELUNERE_66	17:40	18:40	0:59	NFBC ISSUED
593	20-Jan-22	MYSURU	66	HANAGODU-HUNSURU	NO STATIONS EFFECTED	14:20	14:32	0:11	HAND TRIPPED
594	20-Jan-22	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	13:49	14:20	0:31	HAND TRIPPED
595	20-Jan-22	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
596	20-Jan-22	MYSURU	66	HV1	BANNIMANTAP_66	7:32	7:52	0:19	MAIN SUPPLY FAILURE
597	20-Jan-22	MYSURU	66	HV1	DODDINADUVADI_66	12:46	15:00	2:14	LINE CLEAR AVAILED
598	20-Jan-22	MYSURU	66	HV1	HEBBAL_66	17:29	17:36	0:07	TRANSFORMER FAULT
599	20-Jan-22	MYSURU	66	HV1	HEBBAL_66	19:05	19:09	0:03	TRANSFORMER FAULT
600	20-Jan-22	MYSURU	66	HV1	VIJAYANAGRAMYS_66	7:34	7:50	0:16	MAIN SUPPLY FAILURE
601	20-Jan-22	MYSURU	66	HV2	BANNIMANTAP_66	7:32	7:52	0:19	MAIN SUPPLY FAILURE
602	20-Jan-22	MYSURU	66	HV2	DATTAGALLY_66	10:15	18:44	8:28	LINE CLEAR AVAILED
603	20-Jan-22	MYSURU	66	HV2	DEVANOORNGUDU_66	17:05	17:55	0:50	LINE CLEAR AVAILED
604	20-Jan-22	MYSURU	66	HV2	DODDINADUVADI_66	15:00	16:30	1:30	LINE CLEAR AVAILED
605	20-Jan-22	MYSURU	66	HV2	VIJAYANAGRAMYS_66	7:34	7:50	0:16	MAIN SUPPLY FAILURE
606	20-Jan-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
607	20-Jan-22	MYSURU	66	KK HALLI-SHIMSHA-1	NO STATIONS EFFECTED	8:00:00 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
608	20-Jan-22	MYSURU	66	KR PETE 220-BOOKANAKERE	GANJIGERE_66 SHEELUNERE_66	12:05	18:35	6:29	LINE CLEAR AVAILED
609	20-Jan-22	MYSURU	66	KR PETE 220-KR PETE 2	NO STATIONS EFFECTED	12:05	18:34	6:28	LINE CLEAR AVAILED
610	20-Jan-22	MYSURU	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	13:08	13:42	0:34	LINE FAULT
611	20-Jan-22	MYSURU	66	KUSHALANAGARA 220-PERIYAPATNA-1	HANAGODU_66 PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66	13:08	14:06	0:58	LINE FAULT
612	20-Jan-22	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	7:01	7:06	0:04	LINE FAULT
613	20-Jan-22	MYSURU	66	PERIYAPATNA-HANAGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	13:08	14:10	1:01	MAIN SUPPLY FAILURE
614	20-Jan-22	MYSURU	66	PERIYAPATNA-KAMPLAPURA	KAMPALAPURA_66	13:08	14:15	1:06	MAIN SUPPLY FAILURE
615	20-Jan-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
616	20-Jan-22	MYSURU	66	VIJAYANAGARA-BANNIMANTAPA	BANNIMANTAP_66	7:36	14:36	7:00	HAND TRIPPED
617	20-Jan-22	MYSURU	220	MADHUVANAHALLI-WARDHA SOLAR	NO STATIONS EFFECTED	14:07	14:33	0:25	LINE FAULT
618	20-Jan-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	0:17	0:48	0:30	LINE FAULT
619	20-Jan-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	9:36	11:41	2:05	LINE FAULT
620	20-Jan-22	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	7:17	7:30	0:13	LINE FAULT
621	20-Jan-22	TUMKUR	66	SAVALANGA 66kv-HNLI220_NYMT	SAVALANGA_66	12:29	12:34	0:04	HAND TRIPPED
622	20-Jan-22	TUMKUR	66	SAVALANGA 66kv-HNLI220_NYMT	SAVALANGA_66	12:29	12:34	0:04	HAND TRIPPED
623	20-Jan-22	TUMKUR	66	TR-1	HANAGAL_66	17:29	17:35	0:05	TRANSFORMER FAULT
624	20-Jan-22	TUMKUR	66	TR-1	PULAMGHATTA_66	12:00	13:00	1:00	LINE CLEAR AVAILED
625	20-Jan-22	TUMKUR	66	TR-2	BEVINAHALLI_66	13:25	13:45	0:20	LINE CLEAR AVAILED
626	20-Jan-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	8:40	8:45	0:05	TRANSFORMER FAULT
627	20-Jan-22	TUMKUR	66	TR-2	DAVANAGERE_66	10:25	11:10	0:45	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
628	20-Jan-22	TUMKUR	66	TR-2	PULAMGHATTA_66	11:31	13:00	1:28	LINE CLEAR AVAILED
629	20-Jan-22	TUMKUR	66	TR-2	SIRA_66	16:30	16:53	0:22	TRANSFORMER FAULT
630	20-Jan-22	TUMKUR	110	NIITUR 220kV- GUBBI	GUBBI_110, BIDARE_110	11:02	18:17	7:15	LINE CLEAR AVAILED
631	20-Jan-22	TUMKUR	110	TR-1	NIITUR_220	15:19	18:58	3:38	LINE CLEAR AVAILED
632	20-Jan-22	TUMKUR	110	TR-2	NIITUR_220	15:19	18:58	3:39	LINE CLEAR AVAILED
633	21-Jan-22	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	2:50	4:40	1:50	TRANSFORMER FAULT
634	21-Jan-22	BAGALKOT	110	110/11KV,HV1	AREMALLAPUR_110	17:15	18:55	1:40	LINE CLEAR AVAILED
635	21-Jan-22	BAGALKOT	110	110/11KV,HV1	GADAG_110	10:42	11:02	0:20	TRANSFORMER FAULT
636	21-Jan-22	BAGALKOT	110	110/11KV,HV1	GANESHGUDI_110	9:50	10:40	0:50	LINE CLEAR AVAILED
637	21-Jan-22	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	11:15	12:09	0:54	LINE CLEAR AVAILED
638	21-Jan-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED NAVALAGI_110	14:43	14:44	0:01	TRANSFORMER FAULT
639	21-Jan-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED NIDGUNDI_110	9:40	9:44	0:04	TRANSFORMER FAULT
640	21-Jan-22	BAGALKOT	110	110/11KV,HV1	THORVI_110	12:03	17:39	5:36	LINE CLEAR AVAILED
641	21-Jan-22	BAGALKOT	110	BAGEWADI-MAMADAPUR	MAMADAPUR_110	6:42	6:57	0:15	LINE FAULT
642	21-Jan-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
643	21-Jan-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
644	21-Jan-22	BAGALKOT	110	NARENDRA220-UAS DHARWAD	STATION NOT AFFECTED UAS DHRAWAD_110	13:42	22:57	9:15	HAND TRIPPED
645	21-Jan-22	BAGALKOT	110	NARENDRA-BELUR1&2	BELUR_110	13:18	14:02	0:44	HAND TRIPPED
646	21-Jan-22	BAGALKOT	110	NARENDRA-MR NAGAR	MR NAGAR_110	13:18	14:17	0:59	HAND TRIPPED
647	21-Jan-22	BAGALKOT	110	NARENDRA-SHEDBAL	SHEDBAL_110	13:18	14:14	0:56	HAND TRIPPED
648	21-Jan-22	BAGALKOT	110	RANEBENNUR-BYADAGI	STATION NOT AFFECTED RANEBENNUR_220	22:46 (21.01.2022)			LINE OPEN:LINE FAULT
649	21-Jan-22	BAGALKOT	110	SIRSI-UMMACHAGI	UMMACHAGI_110	17:55	18:03	0:08	HAND TRIPPED
650	21-Jan-22	BAGALKOT	110	UDAKERI-NOKOR SOLAR	NOKOR SOLAR_110 STATION NOT AFFECTED UDAKERI_110	18:24	18:50	0:26	LINE CLEAR AVAILED
651	21-Jan-22	BAGALKOT	110	VADAGAON-BELGAUM220	VADAGAON_110	6:50	7:04	0:14	HAND TRIPPED
652	21-Jan-22	BAGALKOT	110	VADAGAON-MACHE	MACHE_110	6:38	7:25	0:47	LINE FAULT
653	21-Jan-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED SOUDATTI_220	9:14	18:40	9:26	LINE CLEAR AVAILED
654	21-Jan-22	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	STATION NOT AFFECTED NARENDRA_220	13:18	13:50	0:32	TRANSFORMER FAULT
655	21-Jan-22	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	12:43 (20.01.2022)	15:12 (21.01.2022)	26:29:00	LINE CHARGED
656	21-Jan-22	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	10:23	15:11	4:48	LINE CLEAR AVAILED
657	21-Jan-22	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220 (STATION NOT AFFECTED)	15:23	15:27	0:04	LINE FAULT
658	21-Jan-22	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	23:52 (21.01.2022)			LINE OPEN:LINE CLEAR AVAILED
659	21-Jan-22	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	12:30	19:28	6:58	LINE FAULT
660	21-Jan-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
661	21-Jan-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
662	21-Jan-22	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:25	15:11	4:46	LINE CLEAR AVAILED
663	21-Jan-22	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
664	21-Jan-22	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	23:52 (21.01.2022)			LINE OPEN:LINE CLEAR AVAILED
665	21-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
666	21-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
667	21-Jan-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
668	21-Jan-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
669	21-Jan-22	BENGALURU	66	ANEKAL - SURYANAGAR	ANEKAL	16:10	16:57	0:47	LINE CLEAR AVAILED
670	21-Jan-22	BENGALURU	66	ANEKAL - YARANDANAHALLI 220	ANEKAL	16:10	16:52	0:42	LINE CLEAR AVAILED
671	21-Jan-22	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	16:08	16:13	0:05	LOAD CHANGEVER
672	21-Jan-22	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	17:20	17:25	0:05	LOAD CHANGEVER
673	21-Jan-22	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	13:55	14:00	0:05	LOAD CHANGEVER
674	21-Jan-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	1:58	2:19	0:21	MAIN SUPPLY FAILURE
675	21-Jan-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	1:58	2:19	0:21	LINE FAULT
676	21-Jan-22	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	10:15	10:20	0:05	LINE CLEAR AVAILED
677	21-Jan-22	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	10:58	11:03	0:05	LOAD CHANGEVER
678	21-Jan-22	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	SHOBHA CITY	10:03	10:04	0:01	MAIN SUPPLY FAILURE
679	21-Jan-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS, PURVANKARA	10:03	10:15	0:12	LINE FAULT
680	21-Jan-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS, PURVANKARA, SHOBHA CITY	8:33	8:40	0:07	LINE FAULT
681	21-Jan-22	BENGALURU	66	HV1	GOWRIBIDANUR 220	18:45	18:50	0:05	TRANSFORMER FAULT
682	21-Jan-22	BENGALURU	66	HV1	SARJAPURA 220	10:19	11:35	1:15	MAIN SUPPLY FAILURE
683	21-Jan-22	BENGALURU	66	HV1	VIDYANAGAR	12:30	12:35	0:05	LINE CLEAR AVAILED
684	21-Jan-22	BENGALURU	66	HV2	EXORA	9:53	10:00	0:07	TRANSFORMER FAULT
685	21-Jan-22	BENGALURU	66	HV2	KENGERI SATELLITE TOWN	1:29	1:52	0:23	TRANSFORMER FAULT
686	21-Jan-22	BENGALURU	66	HV2	TADIGOL CROSS	12:20	14:25	2:05	LINE CLEAR AVAILED
687	21-Jan-22	BENGALURU	66	HV3	BANASAWADI	14:09	14:12	0:03	LOAD CHANGEVER
688	21-Jan-22	BENGALURU	66	HV3	BANASAWADI	16:10	16:13	0:03	LOAD CHANGEVER
689	21-Jan-22	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	11:07	11:20	0:13	LINE FAULT
690	21-Jan-22	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	12:06	12:15	0:09	LINE FAULT
691	21-Jan-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
692	21-Jan-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
693	21-Jan-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	12:02	12:26	0:24	LINE FAULT
694	21-Jan-22	BENGALURU	66	MALUR 220 - LAKKUR	NO STATION AFFECTED	15:18	16:10	0:52	LINE FAULT
695	21-Jan-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	21:09	21:16	0:07	LINE FAULT
696	21-Jan-22	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 2	SHOBHA CITY	8:01	8:25	0:24	LINE FAULT
697	21-Jan-22	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	11:38	11:40	0:02	LOAD CHANGEVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
698	21-Jan-22	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	16:02	16:05	0:03	LOAD CHANGEOVER
699	21-Jan-22	BENGALURU	66	RBI - KHODAYS 220	RBI	15:48	15:52	0:04	LOAD CHANGEOVER
700	21-Jan-22	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	11:13	11:17	0:04	LOAD CHANGEOVER
701	21-Jan-22	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	17:37	17:42	0:05	LOAD CHANGEOVER
702	21-Jan-22	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:10	11:15	0:05	LOAD CHANGEOVER
703	21-Jan-22	BENGALURU	220	HV1	CHINTAMANI 220	1:58	11:32	9:34	TRANSFORMER FAULT
704	21-Jan-22	BENGALURU	220	HV2	SARIJAPURA 220	10:08	16:45	6:37	TRANSFORMER FAULT
705	21-Jan-22	GULBARGA	66	HANSI-BADALADUKU	HANASI_66	7:15	7:25	0:10	MAIN SUPPLY FAILURE
706	21-Jan-22	GULBARGA	66	HV1	BENNEHALLI_66	13:00	13:25	0:25	LINE CLEAR AVAILED
707	21-Jan-22	GULBARGA	66	HV1	BENNEHALLI_66	13:27	14:00	0:33	LINE CLEAR AVAILED
708	21-Jan-22	GULBARGA	66	HV1	BENNEHALLI_66	14:25	14:35	0:10	TRANSFORMER FAULT
709	21-Jan-22	GULBARGA	66	HV1	BENNEHALLI_66	14:36	14:40	0:04	TRANSFORMER FAULT
710	21-Jan-22	GULBARGA	66	HV1	HANASI_66	17:35	17:45	0:10	TRANSFORMER FAULT
711	21-Jan-22	GULBARGA	66	ITTAGI-HIREHADAGALI1,2	HIREHADAGALI_66,GIRIYAPUR_66,M AGALA_66,SOVENHALLI_66,TUNGAB HADRA_IPP	8:50	9:30	0:40	LINE FAULT
712	21-Jan-22	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRIYAPUR_66,M AGALA_66,SOVENHALLI_66,TUNGAB HADRA_IPP	20:05	20:20	0:15	LINE FAULT
713	21-Jan-22	GULBARGA	66	ITTAGI-HIREHADGALI1	HIREHADGALI_66	8:50	9:30	0:40	LINE FAULT
714	21-Jan-22	GULBARGA	110	HUNSAGI-KEMBHAVI	HANSAGI_110	9:35	15:30	5:55	MAIN SUPPLY FAILURE
715	21-Jan-22	GULBARGA	110	HV1	CHOWDAPUR_110	8:15	8:30	0:15	LINE CLEAR AVAILED
716	21-Jan-22	GULBARGA	110	HV1	CHOWDPUR_110	11:50	11:55	0:05	TRANSFORMER FAULT
717	21-Jan-22	GULBARGA	110	HV1	GALAG_110	11:30	11:35	0:05	TRANSFORMER FAULT
718	21-Jan-22	GULBARGA	110	HV1	MYLAR	8:50(21.1.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
719	21-Jan-22	GULBARGA	110	HV3	VALKAMDINNI_110	8:45	8:51	0:06	LINE CLEAR AVAILED
720	21-Jan-22	GULBARGA	110	KADAGANCHI-KAPNOOR	KADAGANCHI_110	14:50	14:55	0:05	MAIN SUPPLY FAILURE
721	21-Jan-22	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_110	18:42	18:45	0:03	LINE FAULT
722	21-Jan-22	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_110	23:50	23:55	0:05	LINE FAULT
723	21-Jan-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_11 0	6:28	6:38	0:10	LINE FAULT
724	21-Jan-22	GULBARGA	110	MUNIRABAD-KOPPAL	KIRLOSHKAR_IPP,HARE KRISHNA_IPP, STATR METALIC_IPP	21:40	21:52	0:12	LINE FAULT
725	21-Jan-22	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110 ,DR NAGAR_110,KARATAGI_110	10:27	10:42	0:15	LINE FAULT
726	21-Jan-22	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110 ,DR NAGAR_110,KARATAGI_110	10:53	11:06	0:13	LINE FAULT
727	21-Jan-22	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110 ,DR NAGAR_110,KARATAGI_110	11:07	12:36	1:29	LINE FAULT
728	21-Jan-22	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110 ,DR NAGAR_110,KARATAGI_110	12:36	14:35	1:59	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
729	21-Jan-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAK THINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
730	21-Jan-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	23:50	23:59	0:09	LINE FAULT
731	21-Jan-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
732	21-Jan-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	9:40	16:30	6:50	LINE CLEAR AVAILED
733	21-Jan-22	GULBARGA	110	SHAHAPUR-KEMBAVI	KEMBAVI_110,UGAR SUGARS_IPP,HUNASAGI_110	9:25	15:08	5:43	LINE CLEAR AVAILED
734	21-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:02(21.01.2022)			LINE OPEN:LINE CLEAR AVAILED
735	21-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:40 (20.01.2022)	7:10 (21.01.2022)	9:30 HRS	LINE CHARGED
736	21-Jan-22	GULBARGA	110	SINDHANOOR-ADVIAWARESHWARA	ADVIAWARESHWARA_110,MANVI_110	19:11	19:21	0:10	LINE FAULT
737	21-Jan-22	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	19:11	19:21	0:10	LINE FAULT
738	21-Jan-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110,JAWALGERA_110	19:11	19:21	0:10	LINE FAULT
739	21-Jan-22	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAPUR_110,MASKI_110,VALAKAMADINNI_110	19:11	19:21	0:10	LINE FAULT
740	21-Jan-22	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,,VALAKAMADINNI_110,	19:11	19:21	0:10	LINE FAULT
741	21-Jan-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110,SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	18:55	19:21	0:26	LINE CLEAR AVAILED
742	21-Jan-22	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDHINAGAR_110	19:11	19:21	0:10	LINE FAULT
743	21-Jan-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	17:03	17:11	0:08	LINE FAULT
744	21-Jan-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	21:41	21:57	0:16	LINE FAULT
745	21-Jan-22	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
746	21-Jan-22	GULBARGA	220	HV1	SINDHANOOR_220	10:40	11:30	0:50	LINE CLEAR AVAILED
747	21-Jan-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
748	21-Jan-22	GULBARGA	220	HV2	SINDHANOOR_220	11:40	17:55	6:15	LINE CLEAR AVAILED
749	21-Jan-22	GULBARGA	220	HV2	SINDHANOOR_220	18:50	19:05	0:15	LINE CLEAR AVAILED
750	21-Jan-22	GULBARGA	220	ITTAGI-BMM	ITTAGI_220	18:25	19:06	0:41	NFBC ISSUED
751	21-Jan-22	GULBARGA	220	LINGAPUR-ARREAS STEEL	LINGAPUR_220	9:12	17:31	8:19	LINE CLEAR AVAILED
752	21-Jan-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	10:32	17:30	6:58	LINE CLEAR AVAILED
753	21-Jan-22	GULBARGA	220	NEELAGUNDA-ITTAGI	NEELAGUNDA_220	13:24	13:40	0:16	LINE FAULT
754	21-Jan-22	GULBARGA	220	NEELAGUNDA-ITTAGI	NEELAGUNDA_220	17:17	17:55	0:38	LINE CLEAR AVAILED
755	21-Jan-22	GULBARGA	220	RTPS-LINGASUGUR3	MALLAT_220	10:17	17:30	7:13	NFBC ISSUED
756	21-Jan-22	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	15:10	17:24	2:14	LINE FAULT
757	21-Jan-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	19:08	19:13	0:05	LINE FAULT
758	21-Jan-22	HASSAN	66	HV1	CRPATNA_220	12:28	13:09	0:41	TRANSFORMER FAULT
759	21-Jan-22	HASSAN	66	HV1	KANDLI_66	12:57	14:46	1:49	LINE CLEAR AVAILED
760	21-Jan-22	HASSAN	66	HV1	KANDLI_66	17:34	17:40	0:06	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
761	21-Jan-22	HASSAN	66	HV1	KANDLI_66	18:39	18:57	0:18	HAND TRIPPED
762	21-Jan-22	HASSAN	66	HV2	BASAVAGHATTA_66	20:18(16.01.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
763	21-Jan-22	HASSAN	66	HV2	DIDIGA_66	15:10	15:58	0:48	TRANSFORMER FAULT
764	21-Jan-22	HASSAN	66	HV2	KANDLI_66	12:58	14:46	1:48	LINE CLEAR AVAIED
765	21-Jan-22	HASSAN	66	HV2	KANDLI_66	17:34	17:40	0:06	HAND TRIPPED
766	21-Jan-22	HASSAN	66	HV2	KANDLI_66	18:39	18:57	0:18	HAND TRIPPED
767	21-Jan-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	9:51	10:13	0:22	LINE FAULT
768	21-Jan-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	4:11	4:15	0:04	LINE FAULT
769	21-Jan-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	11:27	12:24	0:57	NFBC ISSUED
770	21-Jan-22	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJANUR_110	11:23	11:27	0:04	NFBC ISSUED
771	21-Jan-22	HASSAN	110	HV1	SAGARA_110	12:45	14:04	1:19	LINE CLEAR AVAIED
772	21-Jan-22	HASSAN	110	HV2	HOSANGADI_110	15:20	18:52	3:32	LINE CLEAR AVAIED
773	21-Jan-22	HASSAN	110	HV2	HULICAL_110	9:38	18:27	8:49	LINE CLEAR AVAIED
774	21-Jan-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAIED
775	21-Jan-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAIED
776	21-Jan-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAIED
777	21-Jan-22	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	11:37	13:15	1:38	NFBC ISSUED
778	21-Jan-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAIED
779	21-Jan-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAIED
780	21-Jan-22	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	11:27	12:22	0:55	LINE CLEAR AVAIED
781	21-Jan-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:32	12:59	0:27	MAIN SUPPLY FAILURE
782	21-Jan-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:32	13:06	0:34	MAIN SUPPLY FAILURE
783	21-Jan-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:32	12:44	0:12	MAIN SUPPLY FAILURE
784	21-Jan-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:18	12:33	0:15	MAIN SUPPLY FAILURE
785	21-Jan-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:32	13:01	0:29	MAIN SUPPLY FAILURE
786	21-Jan-22	HASSAN	220	HASSN22-CHIKMAGALUR	HASSAN_220	13:32	14:18	0:46	LINE FAULT
787	21-Jan-22	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	4:11	11:33	7:22	LINE FAULT
788	21-Jan-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	12:30	14:27	1:57	LINE FAULT
789	21-Jan-22	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAIED
790	21-Jan-22	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAIED
791	21-Jan-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	12:30	14:27	1:57	LINE FAULT
792	21-Jan-22	HASSAN	220	VARAHI-SHMG3	varahi_gen	4:11	4:32	0:21	LINE FAULT
793	21-Jan-22	HASSAN	220	VARAHI-SHMG3	varahi_gen	11:07	12:45	1:38	LINE CLEAR AVAIED
794	21-Jan-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAIED
795	21-Jan-22	MYSURU	66	HD KOTE-TARAKA	NO STATIONS EFFECTED	18:33	18:47	0:13	LINE FAULT
796	21-Jan-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAIED
797	21-Jan-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	18:48	18:57	0:09	LINE FAULT
798	21-Jan-22	MYSURU	66	HV1	ADICHUNCHANAGIRI_66	6:25	8:25	2:00	MAIN SUPPLY FAILURE
799	21-Jan-22	MYSURU	66	HV1	DEVANOORNGUDU_66	14:13	14:18	0:05	TRANSFORMER FAULT
800	21-Jan-22	MYSURU	66	HV1	ELAVALA_66	11:41	12:10	0:29	LINE CLEAR AVAIED
801	21-Jan-22	MYSURU	66	HV1	HONNALY_MYS_66	11:31	11:36	0:05	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
802	21-Jan-22	MYSURU	66	HV1	MYSORESOUTH_66	14:34	15:37	1:02	LINE CLEAR AVAILED
803	21-Jan-22	MYSURU	66	HV2	DATTAGALLY_66	15:01	15:52	0:50	LINE CLEAR AVAILED
804	21-Jan-22	MYSURU	66	HV2	MYSORESOUTH_66	12:44	14:10	1:26	LINE CLEAR AVAILED
805	21-Jan-22	MYSURU	66	HV2	PANDAVAPURA_66	13:39	13:54	0:14	TRANSFORMER FAULT
806	21-Jan-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
807	21-Jan-22	MYSURU	66	KK HALLI-SHIMSHA-1	NO STATIONS EFFECTED	8:00:00 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
808	21-Jan-22	MYSURU	66	KUSHALNAGARA 220-HARANGI	NO STATIONS EFFECTED	12:42	12:49	0:07	LINE FAULT
809	21-Jan-22	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	6:10	6:14	0:04	LINE FAULT
810	21-Jan-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
811	21-Jan-22	MYSURU	66	TUBINKERE-NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66 SHIVALLY_66	6:25	6:32	0:06	LINE CLEAR AVAILED
812	21-Jan-22	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	6:18	6:28	0:10	LINE FAULT
813	21-Jan-22	MYSURU	220	HV2	TUBINAKERE_220	10:30	10:36	0:06	HAND TRIPPED
814	21-Jan-22	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	9:42	17:48	8:05	NFBC ISSUED
815	21-Jan-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	8:49	16:41	7:51	LINE CLEAR AVAILED
816	21-Jan-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:05	19:15	10:10	LINE CLEAR AVAILED
817	21-Jan-22	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	19:31	19:36	0:04	HAND TRIPPED
818	21-Jan-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:03	19:24	10:21	NFBC ISSUED
819	21-Jan-22	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	12:57	13:02	0:05	LINE FAULT
820	21-Jan-22	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	9:45	10:15	0:30	MAIN SUPPLY FAILURE
821	21-Jan-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	17:15	18:20	1:05	LINE CLEAR AVAILED
822	21-Jan-22	TUMKUR	66	TR-1	KORATAGERE_66	9:35	13:02	3:27	LINE CLEAR AVAILED
823	21-Jan-22	TUMKUR	66	TR-1	PAVAGADA_66	23:03	23:16	0:13	TRANSFORMER FAULT
824	21-Jan-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	7:05	7:10	0:05	TRANSFORMER FAULT
825	21-Jan-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	8:20	8:25	0:05	TRANSFORMER FAULT
826	21-Jan-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	9:15	9:20	0:05	TRANSFORMER FAULT
827	21-Jan-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	21:50	21:55	0:05	TRANSFORMER FAULT
828	21-Jan-22	TUMKUR	66	TR-2	KORA_66	12:24	12:45	0:20	TRANSFORMER FAULT
829	21-Jan-22	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	12:59	14:55	1:55	LINE CLEAR AVAILED
830	21-Jan-22	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	14:40	15:13	0:33	HAND TRIPPED
831	21-Jan-22	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	15:18	15:31	0:13	LINE FAULT
832	21-Jan-22	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	14:39	15:14	0:34	LINE CLEAR AVAILED



SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
833	22-Jan-22	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	2:45	2:55	0:10	TRANSFORMER FAULT
834	22-Jan-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UKKALU_110	11:21	13:10	1:49	TRANSFORMER FAULT
835	22-Jan-22	BAGALKOT	110	110/11KV, HV1	TIKOTA_110	11:00	18:12	7:12	LINE CLEAR AVOIDED
836	22-Jan-22	BAGALKOT	110	110/11KV,HV1	CHAND KAVATE_110	10:53	11:32	0:39	LINE CLEAR AVOIDED
837	22-Jan-22	BAGALKOT	110	110/11KV,HV1	DEVANGOAN_110	18:45	18:55	0:10	TRANSFORMER FAULT
838	22-Jan-22	BAGALKOT	110	110/11KV,HV1	MAREGUDDI_110	10:35	12:15	1:40	LINE CLEAR AVOIDED
839	22-Jan-22	BAGALKOT	110	110/11KV,HV1	MUDEDEBIHAL_110	11:26	12:00	0:34	LINE CLEAR AVOIDED
840	22-Jan-22	BAGALKOT	110	110/11KV,HV1,HV2	SINGATALUR_110	18:45	19:35	0:50	LINE CLEAR AVOIDED
841	22-Jan-22	BAGALKOT	110	110/11KV,HV3	BIJAPUR CITY_110	13:41	13:52	0:11	TRANSFORMER FAULT
842	22-Jan-22	BAGALKOT	110	ANKOLA-KUMATA(L2)	ANKOLA_110 (STATION NOT AFFECTED)	3:21	12:18	8:57	LINE FAULT
843	22-Jan-22	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED NAREGAL_110	10:22	19:05	8:43	NFBC ISSUED
844	22-Jan-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVOIDED
845	22-Jan-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVOIDED
846	22-Jan-22	BAGALKOT	110	MK HUBLI-KITTUR(NARENDRA	KITTUR_110	14:45	18:06	3:21	LINE CLEAR AVOIDED
847	22-Jan-22	BAGALKOT	110	MRUTYUNJANAGAR-GOPNAKOPPAL1	GOPANAKOPPA_110	15:27	16:24	0:57	NFBC ISSUED
848	22-Jan-22	BAGALKOT	110	MRUTYUNJANAGAR-GOPNAKOPPAL2	GOPANAKOPPA_110	15:27	16:24	0:57	NFBC ISSUED
849	22-Jan-22	BAGALKOT	110	NARENDRA220-UAS DHARWAD	STATION NOT AFFECTED UAS DHARWAD_110	12:35	15:27	2:52	NFBC ISSUED
850	22-Jan-22	BAGALKOT	110	NARENDRA220-UAS DHARWAD	UAS DHARWAD_110	9:05	10:25	1:20	HAND TRIPPED
851	22-Jan-22	BAGALKOT	110	NARENDRA-KUD DHARWAD	KUD DHARWAD_110	10:00	17:05	7:05	LINE CLEAR AVOIDED
852	22-Jan-22	BAGALKOT	110	RANEENNUR-BYADAGI	STATION NOT AFFECTED RANEENNUR_220	22:46 (21.01.2022)	9:55 (22.01.2022)	11:09	LINE FAULT
853	22-Jan-22	BAGALKOT	110	TAKKALAKI- TIKOTA	TIKOTA_110	11:09	18:14	7:05	LINE CLEAR AVOIDED
854	22-Jan-22	BAGALKOT	220	220/110KV,HV1,LV1,HV2,LV2	STATION NOT AFFECTED NARENDRA_220	9:06	9:15	0:09	TRANSFORMER FAULT
855	22-Jan-22	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED SOUDATTI_220	8:53	21:10	12:17	LINE CLEAR AVOIDED
856	22-Jan-22	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:34	16:16	4:42	LINE CLEAR AVOIDED
857	22-Jan-22	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	7:53	16:16	8:23	LINE FAULT
858	22-Jan-22	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	23:52 (21.01.2022)	0:36 (22.01.2022)	0:44	LINE CHARGED
859	22-Jan-22	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	6:02	12:36	6:34	LINE FAULT
860	22-Jan-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVOIDED
861	22-Jan-22	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	7:55	10:30	2:35	LINE FAULT
862	22-Jan-22	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	11:34	16:11	4:37	NFBC ISSUED
863	22-Jan-22	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	7:55	16:12	8:17	LINE FAULT
864	22-Jan-22	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	10:35	17:52	7:17	LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
865	22-Jan-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
866	22-Jan-22	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
867	22-Jan-22	BAGALKOT	220	NARENDRA-BELGAUM1	STATION NOT AFFECTED NARENDRA_220	23:52 (21.01.2022)	0:36 (22.01.2022)	0:44	LINE CHARGED
868	22-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
869	22-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
870	22-Jan-22	BAGALKOT	220	SOUDATTI- BIDNAL	SOUDATTI_220	6:00	12:36	6:36	LINE FAULT
871	22-Jan-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
872	22-Jan-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
873	22-Jan-22	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI	13:36	14:10	0:34	MAIN SUPPLY FAILURE
874	22-Jan-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS	7:27	7:40	0:13	MAIN SUPPLY FAILURE
875	22-Jan-22	BENGALURU	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	13:36	14:28	0:52	MAIN SUPPLY FAILURE
876	22-Jan-22	BENGALURU	66	HV1	AMAR JYOTHI	13:36	13:46	0:10	MAIN SUPPLY FAILURE
877	22-Jan-22	BENGALURU	66	HV1	DASHAVARA	13:24	13:30	0:06	TRANSFORMER FAULT
878	22-Jan-22	BENGALURU	66	HV1	JIGANI 66	3:25	4:10	0:45	TRANSFORMER FAULT
879	22-Jan-22	BENGALURU	66	HV1	KORAMANGALA 220	13:36	14:08	0:32	MAIN SUPPLY FAILURE
880	22-Jan-22	BENGALURU	66	HV2	ABBIGERE	10:45	10:50	0:05	LINE CLEAR AVAILED
881	22-Jan-22	BENGALURU	66	HV2	BIDADI 220	1:59	2:38	0:39	TRANSFORMER FAULT
882	22-Jan-22	BENGALURU	66	HV2	KORAMANGALA 220	13:36	14:08	0:32	MAIN SUPPLY FAILURE
883	22-Jan-22	BENGALURU	66	HV2	SARJAPURA 220	4:07	4:21	0:14	TRANSFORMER FAULT
884	22-Jan-22	BENGALURU	66	HV2	VIDYANAGAR	10:45	11:00	0:15	LINE CLEAR AVAILED
885	22-Jan-22	BENGALURU	66	HV3	HSR LAYOUT 220	13:36	14:31	0:55	MAIN SUPPLY FAILURE
886	22-Jan-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	17:46	17:50	1:14	LINE FAULT
887	22-Jan-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
888	22-Jan-22	BENGALURU	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	13:36	14:08	0:32	MAIN SUPPLY FAILURE
889	22-Jan-22	BENGALURU	66	SUBRAMANYAPURA 220 - PADMANABHANAGAR	NO STATION AFFECTED	9:18	11:36	2:18	LINE FAULT
890	22-Jan-22	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	13:36	14:24	0:48	LINE FAULT
891	22-Jan-22	BENGALURU	220	HSR LAYOUT 220 - HOODY 400	HSR LAYOUT 220	13:36	14:24	0:48	LINE FAULT
892	22-Jan-22	BENGALURU	220	HSR LAYOUT 220 - KORMANGALA 220	KORAMANGALA 220	13:36	14:07	0:31	MAIN SUPPLY FAILURE
893	22-Jan-22	BENGALURU	220	HV1	CHINTAMANI 220	7:27	7:40	0:13	TRANSFORMER FAULT
894	22-Jan-22	BENGALURU	220	HV2	HSR LAYOUT 220	13:36	14:26	0:50	MAIN SUPPLY FAILURE
895	22-Jan-22	GULBARGA	66	HALVAGALU-HARVI	HARVI_66	12:45	14:45	2:00	LOAD CURTAILMENT
896	22-Jan-22	GULBARGA	66	NEELAGUNDA-HARAPANAHALLI1	HARAPANAHALLI_66	18:36	18:46	0:10	LINE FAULT
897	22-Jan-22	GULBARGA	66	NEELAGUNDA-TELIGI	TELIGI_66,KURBHAHALLI_66,YEREGU NTA_66	2:02	2:14	0:12	LINE FAULT
898	22-Jan-22	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI_66	2:05	2:20	0:15	LINE FAULT
899	22-Jan-22	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	13:31	15:11	1:40	NFBC ISSUED
900	22-Jan-22	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	11:50	11:54	0:04	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
901	22-Jan-22	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	13:31	15:33	2:02	NFBC ISSUED
902	22-Jan-22	GULBARGA	110	HV1	HUNSAGI_110	11:12	11:24	0:12	TRANSFORMER FAULT
903	22-Jan-22	GULBARGA	110	HV1	MYLAR	8:50(21.1.2022)	16:45(22.1.2022)	7:55:00	TRANSFORMER CHARGED
904	22-Jan-22	GULBARGA	110	KEREHALLI-TALAKUTAI_IPP	KEREHALLI_110	22:05(22.1.2022)			LINE OPEN:LINE FAULT
905	22-Jan-22	GULBARGA	110	KUDITINI-ALIPUR	KUDITINI_110,TORANGALU_110	0:55	1:00	0:05	LINE FAULT
906	22-Jan-22	GULBARGA	110	MUNIRABAD-HAGRI	HAGRI_110,SANKLAPUR_110,RBSNS,K AMALAPUR_110	16:59	17:06	0:07	LINE FAULT
907	22-Jan-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAK THINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
908	22-Jan-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
909	22-Jan-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	4:06	4:14	0:08	LINE FAULT
910	22-Jan-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	19:09	19:14	0:05	LINE FAULT
911	22-Jan-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	4:06	4:14	0:08	LINE FAULT
912	22-Jan-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	19:09	19:14	0:05	LINE FAULT
913	22-Jan-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:28	4:31	0:03	LINE FAULT
914	22-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:06(22.01.2022)			LINE OPEN:LINE CLEAR AVAILED
915	22-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:02(21.01.2022)	09:16(22.01.2022)	12:14HRS	LINE CHARGED
916	22-Jan-22	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	ADAVIAMARESHWARA_110,MANVI_1 10,JAWALGERA_110	11:32	11:40	0:08	LINE FAULT
917	22-Jan-22	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
918	22-Jan-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
919	22-Jan-22	GULBARGA	220	NEELAGUNDA-GUTTUR	NEELAGUNDA_220	11:05	14:10	3:05	NFBC ISSUED
920	22-Jan-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	17:00	17:23	0:23	LINE FAULT
921	22-Jan-22	HASSAN	66	HV1	ARAKALGUD_66	14:12	15:00	0:48	LINE CLEAR AVAILED
922	22-Jan-22	HASSAN	66	HV1	MAGGE_66	12:45	18:00	5:15	LINE CLEAR AVAILED
923	22-Jan-22	HASSAN	66	HV2	BASAVAGHATTA_66	20:18(16.01.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
924	22-Jan-22	HASSAN	66	HV2	MAGGE_66	13:55	17:35	3:40	LINE CLEAR AVAILED
925	22-Jan-22	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	18:26	18:40	0:14	LINE FAULT
926	22-Jan-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:53	18:49	7:56	LINE CLEAR AVAILED
927	22-Jan-22	HASSAN	110	HV2	HULICAL_110	14:44	17:12	2:28	LINE CLEAR AVAILED
928	22-Jan-22	HASSAN	110	HV2	KADUR_220	14:11	14:14	0:03	TRANSFORMER FAULT
929	22-Jan-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
930	22-Jan-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
931	22-Jan-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAILED
932	22-Jan-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
933	22-Jan-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
934	22-Jan-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:01	18:27	8:26	LINE CLEAR AVAILED
935	22-Jan-22	HASSAN	220	ARSK2-HSN	ARASIKERE_220	6:27 (22.01.2022)			LINE OPEN:LINE CLEAR AVAILED
936	22-Jan-22	HASSAN	220	HV3	KAVOOR_220	9:57	17:31	7:34	LINE CLEAR AVAILED
937	22-Jan-22	HASSAN	220	KADUR-DABUSET	KADUR_220	6:17(22.01.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
938	22-Jan-22	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAIED
939	22-Jan-22	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAIED
940	22-Jan-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:00	12:11	0:11	LINE CLEAR AVAIED
941	22-Jan-22	MYSURU	66	BANNIMANTAPA-VIJAYNAGARA	NO STATIONS EFFECTED	7:36	19:11	11:34	HAND TRIPPED
942	22-Jan-22	MYSURU	66	BEGUR-HARVEY	HARVEY_66	6:42	6:47	0:05	LINE FAULT
943	22-Jan-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAIED
944	22-Jan-22	MYSURU	66	FTS-VIJAYNAGARA	NO STATIONS EFFECTED	19:12	21:30	2:17	HAND TRIPPED
945	22-Jan-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAIED
946	22-Jan-22	MYSURU	66	HONNALLY-DR PETE	HONNALLY_66ARAKALAWADI_66 ATTGULIPURA_66	7:30	8:30	1:00	LINE CLEAR AVAIED
947	22-Jan-22	MYSURU	66	HV1	BETTADAPURA_66	9:39	13:40	4:01	HAND TRIPPED
948	22-Jan-22	MYSURU	66	HV1	HONNALLY_66	9:04	9:13	0:09	HAND TRIPPED
949	22-Jan-22	MYSURU	66	HV1	KHONNALKER_66	3:22	3:35	0:12	TRANSFORMER FAULT
950	22-Jan-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAIED
951	22-Jan-22	MYSURU	66	KK HALLI-SHIMSHA-1	NO STATIONS EFFECTED	8:00:00 (13/1/2022)			LINE OPEN:LINE CLEAR AVAIED
952	22-Jan-22	MYSURU	66	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	12:38	12:49	0:11	LINE FAULT
953	22-Jan-22	MYSURU	66	MADHUVANAHALLY-KUNTHUR	NO STATIONS EFFECTED	8:29	8:34	0:04	LINE FAULT
954	22-Jan-22	MYSURU	66	MEGALPURA-SFC	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALI_66BGPURA_66	14:36	15:18	0:41	LINE FAULT
955	22-Jan-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAIED
956	22-Jan-22	TUMKUR	66	HARIYABBE-CHIKKABANAGERE(P D KOTE)	HARIYABBE_66	14:09	19:14	5:05	LINE CLEAR AVAIED
957	22-Jan-22	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	8:00	8:07	0:07	LINE FAULT
958	22-Jan-22	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:38	10:48	0:09	LINE FAULT
959	22-Jan-22	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:20	16:30	0:09	LINE FAULT
960	22-Jan-22	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	14:04	19:31	5:26	LINE CLEAR AVAIED
961	22-Jan-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	10:09	10:15	0:05	LINE FAULT
962	22-Jan-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	14:03	19:29	5:25	LINE CLEAR AVAIED
963	22-Jan-22	TUMKUR	66	PKOTE-HIRIYUR	PKOTE_66	14:10	19:13	5:03	LINE CLEAR AVAIED
964	22-Jan-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	14:03	19:33	5:29	LINE CLEAR AVAIED
965	22-Jan-22	TUMKUR	66	TR-1	NIDASALE_66	11:59	12:09	0:10	TRANSFORMER FAULT
966	22-Jan-22	TUMKUR	66	TR-1	PKOTE_66	14:08	19:15	5:07	LINE CLEAR AVAIED
967	22-Jan-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	8:15	8:20	0:05	TRANSFORMER FAULT
968	22-Jan-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	8:45	8:50	0:05	TRANSFORMER FAULT
969	22-Jan-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	22:15	22:20	0:05	TRANSFORMER FAULT
970	22-Jan-22	TUMKUR	66	TR-2	HONNALLI_66	13:23	15:20	1:56	LINE CLEAR AVAIED
971	22-Jan-22	TUMKUR	66	TR-2	KADAJJI_66	22:30	22:35	0:04	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
972	22-Jan-22	TUMKUR	66	TR-2	NITRAHALLI_66	10:58	12:39	1:40	LINE CLEAR AVAILED
973	22-Jan-22	TUMKUR	66	TR-2	PAVAGADA_66	11:49	12:52	1:02	HAND TRIPPED
974	22-Jan-22	TUMKUR	66	TR-2	PAVAGADA_66	14:30	14:46	0:16	HAND TRIPPED
975	22-Jan-22	TUMKUR	66	TR-2	PAVAGADA_66	18:40	18:44	0:03	TRANSFORMER FAULT
976	22-Jan-22	TUMKUR	66	TR-2	PDKOTE_66	14:08	19:20	5:12	LINE CLEAR AVAILED
977	22-Jan-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	15:06	16:29	1:22	HAND TRIPPED
978	22-Jan-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	16:45	18:08	1:23	HAND TRIPPED
979	22-Jan-22	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	10:35	17:53	7:18	HAND TRIPPED
980	22-Jan-22	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	15:06	16:28	1:22	HAND TRIPPED
981	22-Jan-22	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	16:30	18:08	1:38	HAND TRIPPED
982	22-Jan-22	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	11:03	14:41	3:37	HAND TRIPPED
983	23-Jan-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UKKALI_110	14:05	14:16	0:11	TRANSFORMER FAULT
984	23-Jan-22	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	15:10	15:14	0:04	TRANSFORMER FAULT
985	23-Jan-22	BAGALKOT	110	110/11KV,HV 2	ALMEL_110	14:32	14:42	0:10	HAND TRIPPED
986	23-Jan-22	BAGALKOT	110	110/11KV,HV1	ANKALAGI_110	12:40	13:00	0:20	TRANSFORMER FAULT
987	23-Jan-22	BAGALKOT	110	110/11KV,HV1	NIPPANI_110	15:40	17:05	1:25	LINE CLEAR AVAILED
988	23-Jan-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED NAREGAL_110	14:50	15:04	0:14	TRANSFORMER FAULT
989	23-Jan-22	BAGALKOT	110	110/11KV,HV2	HUKKERI_110	12:20	12:25	0:05	TRANSFORMER FAULT
990	23-Jan-22	BAGALKOT	110	110/11KV,HV2	HUKKERI_110	12:25	12:50	0:25	LINE CLEAR AVAILED
991	23-Jan-22	BAGALKOT	110	110/11KV,HV2	NIPPANI_110	10:05	17:05	7:00	LINE CLEAR AVAILED
992	23-Jan-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED NIPPANI_110,	10:10	17:07	6:57	LINE CLEAR AVAILED
993	23-Jan-22	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:20	12:50	0:30	TRANSFORMER FAULT
994	23-Jan-22	BAGALKOT	110	110/33KV,HV3	MAMADAPUR_110 & DEVARGENNUR_33,LINGADALLI_33	5:44	6:35	0:51	TRANSFORMER FAULT
995	23-Jan-22	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110 & MUNALLI_33&HULIKATTI_33	14:25	15:04	0:39	TRANSFORMER FAULT
996	23-Jan-22	BAGALKOT	110	110/33KV,HV3	NIPPANI_110	10:05	17:05	7:00	LINE CLEAR AVAILED
997	23-Jan-22	BAGALKOT	110	110/33KV,HV3	STATION NOT AFFECTED NIPPANI_110,	10:10	17:07	6:57	LINE CLEAR AVAILED
998	23-Jan-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
999	23-Jan-22	BAGALKOT	110	GHATAPRABHA-GOKAK	GOKAK_110	2:27	2:36	0:09	LINE FAULT
1000	23-Jan-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1001	23-Jan-22	BAGALKOT	110	HOSAHONNATTI-AREMALLAPUR	AREMALLAPUR_110	7:04	7:26	0:22	LINE FAULT
1002	23-Jan-22	BAGALKOT	110	NIPPANI-HSSK	HSSK_IPP STATION NOT AFFECTED NIPPANI_110,	13:16	13:19	0:03	HAND TRIPPED
1003	23-Jan-22	BAGALKOT	110	RAANEBENNUR-HONNATTI	HONNATTI_110	7:05	7:15	0:10	LINE FAULT
1004	23-Jan-22	BAGALKOT	110	TODALABAGI-JAMAKHANDI SUGARS	TODALABAGI_110 JAMAKHANDI SUGARS_110	6:55	7:10	0:15	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1005	23-Jan-22	BAGALKOT	110	UDAKERI-NOKOR SOLAR	NOKOR SOLAR_110 STATION NOT AFFECTED UDAKERI_110	13:37	13:48	0:11	LINE FAULT
1006	23-Jan-22	BAGALKOT	110	UDAKERI-NOKOR SOLAR	NOKOR SOLAR_110 STATION NOT AFFECTED UDAKERI_110	13:53	14:18	0:25	LINE FAULT
1007	23-Jan-22	BAGALKOT	220	BIDNAL-SOUDATTI	STATION NOT AFFECTED BIDNAL_220	14:57	19:26	4:29	LINE FAULT
1008	23-Jan-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1009	23-Jan-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1010	23-Jan-22	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1011	23-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
1012	23-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)			LINE OPEN:LINE CLEAR AVAILED
1013	23-Jan-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1014	23-Jan-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1015	23-Jan-22	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	9:05	9:10	0:05	LOAD CHANGE OVER
1016	23-Jan-22	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	17:30	17:40	0:10	LOAD CHANGE OVER
1017	23-Jan-22	BENGALURU	66	BAGMANE WTC - HOODY 220	BAGMANE WTC	20:30	20:35	0:05	LOAD CHANGE OVER
1018	23-Jan-22	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	8:52	9:05	0:13	LOAD CHANGE OVER
1019	23-Jan-22	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	17:05	17:45	0:40	LOAD CHANGE OVER
1020	23-Jan-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	5:14	5:33	0:19	LINE FAULT
1021	23-Jan-22	BENGALURU	66	DALASNUR - KOLAR 220	DALASNUR	0:30	0:39	0:09	LINE FAULT
1022	23-Jan-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	7:47	7:58	0:11	LINE FAULT
1023	23-Jan-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	6:01	6:12	0:11	LINE FAULT
1024	23-Jan-22	BENGALURU	66	HV1	C STATION	10:40	10:45	0:05	LINE CLEAR AVAILED
1025	23-Jan-22	BENGALURU	66	HV1	DASHAVARA	15:44	15:48	0:04	TRANSFORMER FAULT
1026	23-Jan-22	BENGALURU	66	HV1	HAL 220	19:11	19:25	0:14	TRANSFORMER FAULT
1027	23-Jan-22	BENGALURU	66	HV1	KOLAR 220	9:53	19:39	9:46	LINE CLEAR AVAILED
1028	23-Jan-22	BENGALURU	66	HV1	SARJAPURA 220	9:46	9:51	0:05	LOAD CHANGE OVER
1029	23-Jan-22	BENGALURU	66	HV1	SARJAPURA 220	16:38	17:08	0:29	LOAD CHANGE OVER
1030	23-Jan-22	BENGALURU	66	HV2	APPAREL PARK	13:13	13:19	0:06	TRANSFORMER FAULT
1031	23-Jan-22	BENGALURU	66	HV2	KOLAR 220	9:53	19:40	9:47	LINE CLEAR AVAILED
1032	23-Jan-22	BENGALURU	66	HV2	SARJAPURA 220	9:46	9:52	0:05	LOAD CHANGE OVER
1033	23-Jan-22	BENGALURU	66	HV2	SARJAPURA 220	15:33	15:38	0:05	LOAD CHANGE OVER
1034	23-Jan-22	BENGALURU	66	HV2	THIMMAMPALLI	18:50	18:55	0:05	TRANSFORMER FAULT
1035	23-Jan-22	BENGALURU	66	HV3	JIGANI 66	13:25	13:45	0:20	TRANSFORMER FAULT
1036	23-Jan-22	BENGALURU	66	JAGANI 220 - JIGANI 66	JIGANI 66, JIGANI LINK ROAD, KIRLOSAR (EHT)	10:10	11:10	1:00	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1037	23-Jan-22	BENGALURU	66	JAGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	10:02	10:15	0:13	LINE CLEAR AVAILED
1038	23-Jan-22	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI 66, JIGANI LINK ROAD, KIRLOSKAR (EHT)	17:10	17:20	0:10	LOAD CHANGE OVER
1039	23-Jan-22	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	9:52	20:46	10:54	LINE CLEAR AVAILED
1040	23-Jan-22	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	9:52	20:46	10:54	LINE CLEAR AVAILED
1041	23-Jan-22	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	9:52	20:19	10:27	LINE CLEAR AVAILED
1042	23-Jan-22	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:52	20:08	10:16	LINE CLEAR AVAILED
1043	23-Jan-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	9:55	18:57	9:02	LINE CLEAR AVAILED
1044	23-Jan-22	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	9:52	20:11	10:19	LINE CLEAR AVAILED
1045	23-Jan-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	9:52	20:18	10:26	LINE CLEAR AVAILED
1046	23-Jan-22	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:52	20:07	10:15	LINE CLEAR AVAILED
1047	23-Jan-22	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	9:52	19:03	9:11	LINE CLEAR AVAILED
1048	23-Jan-22	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	20:35	20:41	0:06	LOAD CHANGE OVER
1049	23-Jan-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	9:52	19:04	9:12	LINE CLEAR AVAILED
1050	23-Jan-22	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	9:55	18:56	9:01	LINE CLEAR AVAILED
1051	23-Jan-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
1052	23-Jan-22	BENGALURU	66	KUMBARANAHALLI - YARANDANAHALLI 220	KUMBARANAHALLI, BAGANDODDI	17:35	17:48	0:13	LOAD CHANGE OVER
1053	23-Jan-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:34	17:07	0:33	MAIN SUPPLY FAILURE
1054	23-Jan-22	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	16:34	17:07	0:33	MAIN SUPPLY FAILURE
1055	23-Jan-22	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	16:34	17:07	0:33	MAIN SUPPLY FAILURE
1056	23-Jan-22	BENGALURU	66	MALUR 220 - LAKKUR	NO STATION AFFECTED	16:34	16:52	0:18	MAIN SUPPLY FAILURE
1057	23-Jan-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:34	16:52	0:18	MAIN SUPPLY FAILURE
1058	23-Jan-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:34	16:52	0:18	MAIN SUPPLY FAILURE
1059	23-Jan-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	16:34	16:52	0:18	MAIN SUPPLY FAILURE
1060	23-Jan-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	9:45	10:02	0:17	MAIN SUPPLY FAILURE
1061	23-Jan-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	17:29	17:40	0:11	MAIN SUPPLY FAILURE
1062	23-Jan-22	BENGALURU	66	T GOLLAHALLI 220 - KGF 1	DODDAKARI, KYASAMBALLI, ANDERSONPETE	8:28	8:38	0:10	LINE FAULT
1063	23-Jan-22	BENGALURU	220	HV1	CHINTAMANI 220	5:14	8:58	3:44	TRANSFORMER FAULT
1064	23-Jan-22	BENGALURU	220	HV1	MALUR 220	16:35	16:49	0:14	LOAD CHANGE OVER
1065	23-Jan-22	BENGALURU	220	HV1	MALUR 220	16:49	17:03	0:14	TRANSFORMER FAULT
1066	23-Jan-22	BENGALURU	220	HV2	KOLAR 220	9:58	18:50	8:52	LINE CLEAR AVAILED
1067	23-Jan-22	BENGALURU	220	HV2	MALUR 220	16:35	16:51	0:16	LOAD CHANGE OVER
1068	23-Jan-22	BENGALURU	220	HV3	KOLAR 220	9:58	20:03	10:05	LINE CLEAR AVAILED
1069	23-Jan-22	BENGALURU	220	JIGANI 220 - MYLASANDRA 400	JIGANI 220	10:15	17:18	7:03	LINE CLEAR AVAILED
1070	23-Jan-22	BENGALURU	220	JIGANI 220 - YARANDANAHALLI 220	JIGANI 220	10:15	17:18	7:03	LINE CLEAR AVAILED
1071	23-Jan-22	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	10:30	16:01	5:31	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1072	23-Jan-22	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	10:30	16:01	5:31	LINE CLEAR AVAILED
1073	23-Jan-22	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 1	RAILWAY TRACTION (EHT)	10:30	16:02	5:32	LINE CLEAR AVAILED
1074	23-Jan-22	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 2	RAILWAY TRACTION (EHT)	10:30	16:03	5:33	LINE CLEAR AVAILED
1075	23-Jan-22	BENGALURU	220	MALUR 220 - HOODY 220	MALUR 220	16:34	16:47	0:13	LOAD CHANGEOVER
1076	23-Jan-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
1077	23-Jan-22	BENGALURU	220	MALUR 220 - SOMANHALLI 2	SARIJAPURA 220	16:34	17:06	0:32	LOAD CHANGEOVER
1078	23-Jan-22	BENGALURU	220	MALUR 220 - SOMANHALLI 2	SARIJAPURA 220	9:40	10:00	0:20	LOAD CHANGEOVER
1079	23-Jan-22	GULBARGA	66	BENNEHALLI-ITTAGGI	BENNEHALLI_66	14:35	14:55	0:20	MAIN SUPPLY FAILURE
1080	23-Jan-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATAVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_110,MATRI_110,RBNS FACTORY	4:16	4:46	0:30	LINE FAULT
1081	23-Jan-22	GULBARGA	110	GURMITKAL-KONKAL	GURMITKAL_110	10:35	18:15	7:40	LINE CLEAR AVAILED
1082	23-Jan-22	GULBARGA	110	GURMITKAL-KONKAL	GURMITKAL_110	18:20	18:25	0:05	LINE CLEAR AVAILED
1083	23-Jan-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	16:00	16:07	0:07	LINE FAULT
1084	23-Jan-22	GULBARGA	110	HUNSAGI-KEMBHAVI	HANSAGI_110	8:25	15:20	6:55	MAIN SUPPLY FAILURE
1085	23-Jan-22	GULBARGA	110	HV1	HALAKUNDI_110	16:35	16:45	0:10	TRANSFORMER FAULT
1086	23-Jan-22	GULBARGA	110	KEREHALLI-TALAKUTAI_IPP	KEREHALLI_110	22:05(22.1.2022)	1:55(23.1.2022)	3:50 hrs	LINE CHARGED
1087	23-Jan-22	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110,DR NAGAR_110,KARATAGI_110	15:25	16:42	1:17	LINE CLEAR AVAILED
1088	23-Jan-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
1089	23-Jan-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1090	23-Jan-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	8:28	15:19	6:51	LINE CLEAR AVAILED
1091	23-Jan-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBAVI_110,UGAR SUGARS_IPP,HUNASAGI_110	8:24	15:17	6:53	LINE CLEAR AVAILED
1092	23-Jan-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	5:57	6:03	0:06	LINE FAULT
1093	23-Jan-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	5:57	6:03	0:06	LINE FAULT
1094	23-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:08(23.01.2022)			LINE OPEN:LINE CLEAR AVAILED
1095	23-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:06(22.01.2022)	08:14(22.01.2022)	12:08HRS	LINE CHARGED
1096	23-Jan-22	GULBARGA	110	YELBURGA-PARAMPOOJYA_IPP	YELBURGA_110	20:38	20:45	0:07	LINE FAULT
1097	23-Jan-22	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1098	23-Jan-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1099	23-Jan-22	GULBARGA	220	HV2	MUNIRABAD_220	14:54	16:40	1:46	LINE CLEAR AVAILED
1100	23-Jan-22	GULBARGA	220	HV2,LV2	ALIPUR_220	4:16	4:33	0:17	TRANSFORMER FAULT
1101	23-Jan-22	GULBARGA	220	NEELAGUNDA-ITTAGI	NEELAGUNDA_220	14:34	15:32	0:58	LINE FAULT
1102	23-Jan-22	GULBARGA	220	RAICHUR-JURALA_IPP_2	RAICHUR_220	0:38	1:03	0:25	LINE FAULT
1103	23-Jan-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	6:34	11:11	4:37	LINE FAULT



SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1104	23-Jan-22	HASSAN	66	HV1	HANGRANAHALLY_66	12:09	12:25	0:16	TRANSFORMER FAULT
1105	23-Jan-22	HASSAN	66	HV1	HOLALUR_66	6:07	6:32	0:25	TRANSFORMER FAULT
1106	23-Jan-22	HASSAN	66	HV1	KANDLI_66	9:52	9:55	0:03	HAND TRIPPED
1107	23-Jan-22	HASSAN	66	HV1	KANDLI_66	11:50	11:55	0:05	HAND TRIPPED
1108	23-Jan-22	HASSAN	66	HV1	KUDLIGERE_66	8:04	10:22	2:18	TRANSFORMER FAULT
1109	23-Jan-22	HASSAN	66	HV1	MALALI_66	10:50	11:10	0:20	HAND TRIPPED
1110	23-Jan-22	HASSAN	66	HV1	MALALI_66	14:15	14:20	0:05	TRANSFORMER FAULT
1111	23-Jan-22	HASSAN	66	HV1	SIGEBAGE_66	10:39	11:08	0:29	LINE CLEAR AVAILED
1112	23-Jan-22	HASSAN	66	HV2	BASAVAGHATTA_66	20:18(16.01.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1113	23-Jan-22	HASSAN	66	HV2	KANDLI_66	9:52	9:55	0:03	HAND TRIPPED
1114	23-Jan-22	HASSAN	66	HV2	KANDLI_66	11:53	11:55	0:02	HAND TRIPPED
1115	23-Jan-22	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	7:45	10:18	2:33	MAIN SUPPLY FAILURE
1116	23-Jan-22	HASSAN	66	MALALI-HASSAN	MALALI_66	6:10	11:10	5:00	MAIN SUPPLY FAILURE
1117	23-Jan-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	7:45	8:05	0:20	LINE FAULT
1118	23-Jan-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	8:05	10:17	2:12	LINE FAULT
1119	23-Jan-22	HASSAN	110	HV2	BAIKAMPADY_110	9:30	16:02	6:32	LINE CLEAR AVAILED
1120	23-Jan-22	HASSAN	110	HV3	PUTTUR_110	8:23	8:28	0:05	TRANSFORMER FAULT
1121	23-Jan-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1122	23-Jan-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1123	23-Jan-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1124	23-Jan-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAILED
1125	23-Jan-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMG_220	9:30(9.01.2022)	10:24(23.01.2022)	336:54HRA	LINE CHARGED
1126	23-Jan-22	HASSAN	220	ARSK2-HSN	ARASIKERE_220	6:27 (22.01.2022)	14:59 (23.01.2022)	32:32HRS	LINE CHARGED
1127	23-Jan-22	HASSAN	220	KADUR-DABUSET	KADUR_220	6:17(22.01.2022)	15:09(23.01.2022)	32:52HRS	LINE CHARGED
1128	23-Jan-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	4:19	13:17	8:58	LINE FAULT
1129	23-Jan-22	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMG_220	15:17	17:25	2:08	LINE FAULT
1130	23-Jan-22	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAILED
1131	23-Jan-22	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAILED
1132	23-Jan-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAILED
1133	23-Jan-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1134	23-Jan-22	MYSURU	66	HV1	BETTADAPURA_66	17:02	17:18	0:15	LINE CLEAR AVAILED
1135	23-Jan-22	MYSURU	66	HV1	DEVNUR(N'GUD)_66	13:25	13:31	0:05	TRANSFORMER FAULT
1136	23-Jan-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
1137	23-Jan-22	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	15:04	15:16	0:12	LINE FAULT
1138	23-Jan-22	MYSURU	66	KK HALLI-SHIMSHA-1	NO STATIONS EFFECTED	8:00:00 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
1139	23-Jan-22	MYSURU	66	KR PETE-MADESHWARAPURA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66 JAKKANAHALLY_66MADESWARAPUR A_66	10:37	10:44	0:06	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1140	23-Jan-22	MYSURU	66	KUSHALANAGARA-RAMANTHAPURA1	KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66 RAMANTHPURA_66	4:12	8:26	4:13	LINE FAULT
1141	23-Jan-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
1142	23-Jan-22	TUMKUR	66	HANAGAL-AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	13:50	14:29	0:39	LINE FAULT
1143	23-Jan-22	TUMKUR	66	HANAGAL-AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	14:33	14:35	0:01	LINE FAULT
1144	23-Jan-22	TUMKUR	66	HANAGAL-GUDEKOTE(THALLAK)	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	15:40	16:50	1:10	NFBC ISSUED
1145	23-Jan-22	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	13:50	14:20	0:30	HAND TRIPPED
1146	23-Jan-22	TUMKUR	66	HARIYABBE-CHIKKABANAGERE(P D KOTE)	HARIYABBE_66	14:01	16:52	2:51	LINE CLEAR AVAILED
1147	23-Jan-22	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	8:27	8:39	0:12	LINE FAULT
1148	23-Jan-22	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:49	18:24	8:34	NFBC ISSUED
1149	23-Jan-22	TUMKUR	66	LOKIKERE-KUKKAWADA	KUKKAWADA_66	9:50	18:24	8:34	NFBC ISSUED
1150	23-Jan-22	TUMKUR	66	LOKIKERE-TYAVANAGI	KUKKAWADA_66	9:50	18:25	8:34	NFBC ISSUED
1151	23-Jan-22	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	13:55	14:25	0:30	MAIN SUPPLY FAILURE
1152	23-Jan-22	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	15:35	16:50	1:15	MAIN SUPPLY FAILURE
1153	23-Jan-22	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	13:55	14:25	0:30	MAIN SUPPLY FAILURE
1154	23-Jan-22	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	15:35	16:50	1:15	MAIN SUPPLY FAILURE
1155	23-Jan-22	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	14:00	17:00	3:00	LINE CLEAR AVAILED
1156	23-Jan-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	13:51	17:00	3:09	LINE CLEAR AVAILED
1157	23-Jan-22	TUMKUR	66	PKOTE-HIRIYUR	PKOTE_66	14:03	16:50	2:46	LINE CLEAR AVAILED
1158	23-Jan-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	14:00	17:00	2:59	LINE CLEAR AVAILED
1159	23-Jan-22	TUMKUR	66	THALLAK 220kv - BGKERE 1	BGKERE 1	15:31	16:45	1:14	HAND TRIPPED
1160	23-Jan-22	TUMKUR	66	THALLAK 220kv - BGKERE 2	BGKERE 2	13:51	16:48	2:57	LINE FAULT
1161	23-Jan-22	TUMKUR	66	TR-1	JIDDIGERE_66	10:40	14:44	4:03	LINE CLEAR AVAILED
1162	23-Jan-22	TUMKUR	66	TR-1	PKOTE_66	14:00	16:57	2:56	LINE CLEAR AVAILED
1163	23-Jan-22	TUMKUR	66	TR-2	HIREMALLANA HOLE_66	1:52	2:00	0:07	TRANSFORMER FAULT
1164	23-Jan-22	TUMKUR	66	TR-2	HONNALLI_66	12:32	15:36	3:03	LINE CLEAR AVAILED
1165	23-Jan-22	TUMKUR	66	TR-2	KORTAGERE_66	9:33	11:16	1:42	LINE CLEAR AVAILED
1166	23-Jan-22	TUMKUR	66	TR-2	PKOTE_66	14:00	16:57	2:56	LINE CLEAR AVAILED
1167	23-Jan-22	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	13:46	14:15	0:29	LINE FAULT
1168	23-Jan-22	TUMKUR	110	NITTUR 220kv- KADABA	KADABA_110	0:43	1:49	1:06	LINE CLEAR AVAILED
1169	23-Jan-22	TUMKUR	110	NITTUR 220kv- KALLUR	KALLUR_110	0:43	1:39	0:56	LINE CLEAR AVAILED
1170	23-Jan-22	TUMKUR	110	TR-1(LV SIDE )	NITTUR_220	0:42	17:39	16:57	LINE CLEAR AVAILED
1171	23-Jan-22	TUMKUR	220	GUTTUR 400kv- VISHWIND1(JOGIHALLI)	GUTUR_400	9:35	18:10	8:35	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1172	23-Jan-22	TUMKUR	220	TR-1(HV)	NIITUR_220	0:42	17:33	16:51	LINE CLEAR AVAILED
1173	24-Jan-22	BAGALKOT	110	110/11KV, HV1	MUNDAGNUR_110	12:50	13:20	0:30	TRANSFORMER FAULT
1174	24-Jan-22	BAGALKOT	110	110/11KV, HV2	HALIYAL_110	9:20	16:00	6:40	LINE CLEAR AVAILED
1175	24-Jan-22	BAGALKOT	110	110/11KV, HV2	TUMMINAKATTI_110	11:16	11:25	0:09	TRANSFORMER FAULT
1176	24-Jan-22	BAGALKOT	110	110/11KV,HV1	UMMACHAGI_110	14:45	18:15	3:30	LINE CLEAR AVAILED
1177	24-Jan-22	BAGALKOT	110	110/11KV,HV2	TUMMINAKATTI_110	11:16	11:25	0:09	TRANSFORMER FAULT
1178	24-Jan-22	BAGALKOT	110	110/33KV,HV1	JAMAKHANDI_110	13:46	17:55	4:09	LINE CLEAR AVAILED
1179	24-Jan-22	BAGALKOT	110	110/33KV,HV2	JAMAKHANDI_110	13:45	17:57	4:12	LINE CLEAR AVAILED
1180	24-Jan-22	BAGALKOT	110	ANKALAGI-HIDIKAL	STATION NOT AFFECTED ANKALAGI_110	17:57	18:00	0:03	LINE CLEAR AVAILED
1181	24-Jan-22	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110,KAKMARI_110,YALLAMA NAWADI_110,TODALABAGI_110,SAV ALAGI_110,ALBAL_110	21:47	21:58	0:11	LINE FAULT
1182	24-Jan-22	BAGALKOT	110	BAGALKOT220-RAMDURG	STATION NOT AFFECTED BAGALKOT_220	12:33	12:34	0:01	HAND TRIPPED
1183	24-Jan-22	BAGALKOT	110	BELGAUM220- UCHAGOAN	BELGAUM_220	10:50	13:30	2:40	LINE CLEAR AVAILED
1184	24-Jan-22	BAGALKOT	110	F1 AIGALI-YLWD	AIGALI_110,YALLAMANAWADI_110	21:48	21:58	0:10	MAIN SUPPLY FAILURE
1185	24-Jan-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
1186	24-Jan-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
1187	24-Jan-22	BAGALKOT	110	HAVERI220-TILUVALI(HANAGAL)	HANAGAL_110	11:34	13:16	1:42	LINE CLEAR AVAILED
1188	24-Jan-22	BAGALKOT	110	HIREBEVANUR-SHIVASAGAR SUGARS	STATION NOT AFFECTED HIREBEVANUR_110	23:43 (24.01.2022)			LINE OPEN:LINE FAULT
1189	24-Jan-22	BAGALKOT	110	HIREHAL-RON	HIREHAL_110,RON_110	5:25	5:50	0:25	HAND TRIPPED
1190	24-Jan-22	BAGALKOT	110	HUBLI- RAMANKOPPA	RAMANAKOPPA_110	7:04	8:50	1:46	HAND TRIPPED
1191	24-Jan-22	BAGALKOT	110	HUBLI- RAMANKOPPA	STATION NOT AFFECTED HUBLI_220	6:37	8:11	1:34	LINE FAULT
1192	24-Jan-22	BAGALKOT	110	SIRSI220- UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	11:14	18:01	6:47	HAND TRIPPED
1193	24-Jan-22	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	11:31	12:45	1:14	LINE CLEAR AVAILED
1194	24-Jan-22	BAGALKOT	110	SOUDATTI220-NARGUND(RAMADURGA1)	SOUDATTI_220	12:37	12:39	0:03	HAND TRIPPED
1195	24-Jan-22	BAGALKOT	110	SOUDATTI220-RAMADURGA1	RAMADURGA_110	12:25	12:40	0:15	HAND TRIPPED
1196	24-Jan-22	BAGALKOT	110	SOUDATTI220-RAMADURGA2	RAMADURGA_110	12:25	12:40	0:15	HAND TRIPPED
1197	24-Jan-22	BAGALKOT	110	SOUDATTI220-RAMADURGA2	STATION NOT AFFECTED SOUDATTI_220	12:34	12:37	0:03	HAND TRIPPED
1198	24-Jan-22	BAGALKOT	110	TODALBAGI-JAMKHANDI	TODALBAGI_110	22:02	22:05	0:03	LINE FAULT
1199	24-Jan-22	BAGALKOT	110	UMMACHAGI-KIRUVATTI	UMMACHAGI_110	18:22	20:09	1:47	LINE CLEAR AVAILED
1200	24-Jan-22	BAGALKOT	110	UMMACHAGI-SIRSI	UMMACHAGI_110	11:20	18:22	7:02	LINE CLEAR AVAILED
1201	24-Jan-22	BAGALKOT	110	YLWD-F3 ALBAL	ALBAL_110,YALLAMANAWADI_110	21:47	22:06	0:19	LINE FAULT
1202	24-Jan-22	BAGALKOT	220	AMBEWADI- NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	15:10	15:41	0:31	HAND TRIPPED
1203	24-Jan-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
1204	24-Jan-22	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	12:36	14:49	2:13	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1205	24-Jan-22	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1206	24-Jan-22	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
1207	24-Jan-22	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	12:37	14:49	2:12	LINE CLEAR AVAILED
1208	24-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)	17:58 (24.01.2022)	120:47 hrs	LINE CHARGED
1209	24-Jan-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:11 (19.01.2022)	17:58 (24.01.2022)	120:47 hrs	LINE CHARGED
1210	24-Jan-22	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1211	24-Jan-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1212	24-Jan-22	BENGALURU	66	ALUR - PEENYA 220	ALUR, BIEC	6:58	7:27	0:29	LINE FAULT
1213	24-Jan-22	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	6:53	7:16	0:23	LINE CLEAR AVAILED
1214	24-Jan-22	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPAHALLI	6:53	7:14	0:21	LINE FAULT
1215	24-Jan-22	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	10:52	10:57	0:05	LOAD CHANGEOVER
1216	24-Jan-22	BENGALURU	66	DALSANUR - CHINTAMANI 220	DALSANUR, YELDUR	19:05	19:15	0:10	LOAD CHANGEOVER
1217	24-Jan-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	11:54	12:16	0:22	MAIN SUPPLY FAILURE
1218	24-Jan-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:54	12:16	0:22	MAIN SUPPLY FAILURE
1219	24-Jan-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	11:54	12:15	0:21	MAIN SUPPLY FAILURE
1220	24-Jan-22	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	10:50	10:55	0:05	LOAD CHANGEOVER
1221	24-Jan-22	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT, BELL CERAMICS (EHT)	18:20	18:23	0:03	LOAD CHANGEOVER
1222	24-Jan-22	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	18:23	18:26	0:03	LOAD CHANGEOVER
1223	24-Jan-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	15:03	15:09	0:06	MAIN SUPPLY FAILURE
1224	24-Jan-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	15:00	15:08	0:08	LINE CLEAR AVAILED
1225	24-Jan-22	BENGALURU	66	HV1	ALUR	13:27	14:50	1:22	LINE CLEAR AVAILED
1226	24-Jan-22	BENGALURU	66	HV1	KOLAR 220	0:05	0:14	0:09	LOAD CHANGEOVER
1227	24-Jan-22	BENGALURU	66	HV1	KOLAR 220	17:12	17:16	0:04	TRANSFORMER FAULT
1228	24-Jan-22	BENGALURU	66	HV1	SARIAPURA 220	13:02	13:51	0:49	MAIN SUPPLY FAILURE
1229	24-Jan-22	BENGALURU	66	HV1	SURYANAGAR	13:00	14:33	1:32	LINE CLEAR AVAILED
1230	24-Jan-22	BENGALURU	66	HV2	ALUR	13:27	14:50	1:22	LINE CLEAR AVAILED
1231	24-Jan-22	BENGALURU	66	HV2	BIDADI 220	6:53	7:15	0:22	LINE CLEAR AVAILED
1232	24-Jan-22	BENGALURU	66	HV2	DB PURA 220	11:54	12:13	0:19	LOAD CHANGEOVER
1233	24-Jan-22	BENGALURU	66	HV2	KOLAR 220	0:05	0:14	0:09	LOAD CHANGEOVER
1234	24-Jan-22	BENGALURU	66	HV2	SARIAPURA 220	13:02	13:51	0:49	MAIN SUPPLY FAILURE
1235	24-Jan-22	BENGALURU	66	HV2	THAYALUR	12:20	12:25	0:04	LINE CLEAR AVAILED
1236	24-Jan-22	BENGALURU	66	HV3	BIDADI 220	6:53	7:16	0:23	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1237	24-Jan-22	BENGALURU	66	HV3	NRS 220	10:05	10:08	0:03	LINE CLEAR AVAIED
1238	24-Jan-22	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD, JIGANI 66	10:19	10:22	0:03	LOAD CHANGEOVER
1239	24-Jan-22	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	0:11	0:15	0:04	LOAD CHANGEOVER
1240	24-Jan-22	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	12:18	15:58	3:40	LINE CLEAR AVAIED
1241	24-Jan-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:18	10:38	0:20	LOAD CURTAILMENT
1242	24-Jan-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	14:11	16:05	1:54	LINE CLEAR AVAIED
1243	24-Jan-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	14:11	14:25	0:14	LOAD CHANGEOVER
1244	24-Jan-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	16:48	16:51	0:03	LINE FAULT
1245	24-Jan-22	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	14:11	16:25	2:14	LINE CLEAR AVAIED
1246	24-Jan-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	14:10	14:40	0:30	LINE CLEAR AVAIED
1247	24-Jan-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	12:18	15:56	3:38	LINE CLEAR AVAIED
1248	24-Jan-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	12:18	15:56	3:38	LINE CLEAR AVAIED
1249	24-Jan-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
1250	24-Jan-22	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	13:12	13:48	0:35	LINE FAULT
1251	24-Jan-22	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	13:12	13:48	0:35	LINE FAULT
1252	24-Jan-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:52	16:59	0:07	LINE FAULT
1253	24-Jan-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	14:34	14:43	0:09	LINE FAULT
1254	24-Jan-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	11:56	12:03	0:07	LINE FAULT
1255	24-Jan-22	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	18:28	18:34	0:06	LINE FAULT
1256	24-Jan-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	13:00	13:18	0:18	MAIN SUPPLY FAILURE
1257	24-Jan-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	13:51	14:02	0:11	MAIN SUPPLY FAILURE
1258	24-Jan-22	BENGALURU	66	SARIAPURA 220 - ATTIBELE	ATTIBELE	13:02	14:14	1:12	MAIN SUPPLY FAILURE
1259	24-Jan-22	BENGALURU	66	SARIAPURA 220 - CHANDAPURA	CHANDAPURA	13:02	13:55	0:53	MAIN SUPPLY FAILURE
1260	24-Jan-22	BENGALURU	66	SARIAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:02	13:53	0:51	MAIN SUPPLY FAILURE
1261	24-Jan-22	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	18:25	18:31	0:06	LINE FAULT
1262	24-Jan-22	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	15:03	15:09	0:06	LINE CLEAR AVAIED
1263	24-Jan-22	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:00	13:17	0:17	MAIN SUPPLY FAILURE
1264	24-Jan-22	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	13:51	14:01	0:10	MAIN SUPPLY FAILURE
1265	24-Jan-22	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	13:00	13:17	0:17	MAIN SUPPLY FAILURE
1266	24-Jan-22	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	13:51	14:01	0:10	MAIN SUPPLY FAILURE
1267	24-Jan-22	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:00	13:17	0:17	MAIN SUPPLY FAILURE
1268	24-Jan-22	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:51	14:01	0:10	MAIN SUPPLY FAILURE
1269	24-Jan-22	BENGALURU	220	DABUSPET 220 - KADUR 220	DABUSPET 220	11:03	18:04	7:01	LOAD CURTAILMENT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1270	24-Jan-22	BENGALURU	220	HV1	CHINTAMANI 220	12:16	15:22	3:05	LINE CLEAR AVAILED
1271	24-Jan-22	BENGALURU	220	HV1	CHINTAMANI 220	15:43	16:26	0:43	LINE CLEAR AVAILED
1272	24-Jan-22	BENGALURU	220	HV1	SARIAPURA 220	13:02	13:50	0:48	MAIN SUPPLY FAILURE
1273	24-Jan-22	BENGALURU	220	HV2	KOLAR 220	12:18	13:12	0:54	TRANSFORMER FAULT
1274	24-Jan-22	BENGALURU	220	HV2	KOLAR 220	13:12	15:35	2:23	TRANSFORMER FAULT
1275	24-Jan-22	BENGALURU	220	HV2	SARIAPURA 220	13:02	13:50	0:48	MAIN SUPPLY FAILURE
1276	24-Jan-22	BENGALURU	220	LV1	CHINTAMANI 220	12:16	15:27	3:10	LINE CLEAR AVAILED
1277	24-Jan-22	BENGALURU	220	LV1	CHINTAMANI 220	15:43	16:30	0:47	LINE CLEAR AVAILED
1278	24-Jan-22	BENGALURU	220	LV2	BIDADI 220	6:53	7:09	0:16	TRANSFORMER FAULT
1279	24-Jan-22	BENGALURU	220	MALUR 220 - SOMANAHALLI 2	SARIAPURA 220, VIKAS TEC PARK 220	13:02	13:50	0:48	LINE CLEAR AVAILED
1280	24-Jan-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
1281	24-Jan-22	BENGALURU	220	VIKAS TECH PARK 220 - HSR LAYOUT 220	VIKAS TECH PARK 220	13:51	14:00	0:09	LOAD CHANGEOVER
1282	24-Jan-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	13:00	13:18	0:18	MAIN SUPPLY FAILURE
1283	24-Jan-22	GULBARGA	66	HOSAHALLI-SML_WND	HOSAHALLI_66	18:40	19:05	0:25	LINE FAULT
1284	24-Jan-22	GULBARGA	66	HV1	PUNAB GHATA_66	15:35	15:40	0:05	TRANSFORMER FAULT
1285	24-Jan-22	GULBARGA	66	HV2	TAMBRAHALLI_66	4:09	4:20	0:11	TRANSFORMER FAULT
1286	24-Jan-22	GULBARGA	66	ITTAGI-HIREHADGALI_1&2	HIREHADGALI_66,GIRIYAPUR_66,MA GALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	13:20	13:35	0:15	LINE CLEAR AVAILED
1287	24-Jan-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	17:18	17:30	0:12	MAIN SUPPLY FAILURE
1288	24-Jan-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KUR UGOD_110,SHATAVAHANA_IPP,AGAR WAL_IPP,SUZLON_IPP,KAMALAPUR_1 10,MATRI_110,RBNS FACTORY	4:46	5:06	0:20	LINE FAULT
1289	24-Jan-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KUR UGOD_110,SHATAVAHANA_IPP,AGAR WAL_IPP,SUZLON_IPP,KAMALAPUR_1 10,MATRI_110,RBNS FACTORY	12:25	12:44	0:19	LINE CLEAR AVAILED
1290	24-Jan-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	11:50	12:00	0:10	MAIN SUPPLY FAILURE
1291	24-Jan-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	15:40	17:42	2:02	MAIN SUPPLY FAILURE
1292	24-Jan-22	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	6:10	6:20	0:10	MAIN SUPPLY FAILURE
1293	24-Jan-22	GULBARGA	110	HALBARGA-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	16:50	17:23	0:33	LINE CLEAR AVAILED
1294	24-Jan-22	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_11 0,DIGGI_110	4:58	5:03	0:05	LINE FAULT
1295	24-Jan-22	GULBARGA	110	HV1	NALWAR_110	11:35	12:35	1:00	LINE CLEAR AVAILED
1296	24-Jan-22	GULBARGA	110	JAWALGERA-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	22:00	22:05	0:05	LINE FAULT
1297	24-Jan-22	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVI AMARESHWAR_110	17:17	17:30	0:13	LINE FAULT
1298	24-Jan-22	GULBARGA	110	METRI-ALIPUR	METRI_110	4:15	4:45	0:30	MAIN SUPPLY FAILURE
1299	24-Jan-22	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110 ,DR NAGAR_110,KARATAGI_110	19:15	19:25	0:10	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1300	24-Jan-22	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAK THINAGA_110	5:58 (28.12.2021)			LINE OPEN:LINE FAULT
1301	24-Jan-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	6:12	6:20	0:08	LINE FAULT
1302	24-Jan-22	GULBARGA	110	RAICHUR-SINDHANOOR1	SINDHANOOR_110,MUDDAPUR_110, MASKI_110,HATTI_110	5:50	6:00	0:10	LINE FAULT
1303	24-Jan-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1304	24-Jan-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	6:15	6:29	0:14	LINE FAULT
1305	24-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:48 (24.01.2022)			LINE OPEN:LINE CLEAR AVAILED
1306	24-Jan-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:08(23.01.2022)	08:28(24.01.2022)	12:14HRS	LINE CHARGED
1307	24-Jan-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	9:12	9:22	0:10	LINE FAULT
1308	24-Jan-22	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	4:47	5:07	0:20	MAIN SUPPLY FAILURE
1309	24-Jan-22	GULBARGA	110	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	12:27	12:45	0:18	MAIN SUPPLY FAILURE
1310	24-Jan-22	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1311	24-Jan-22	GULBARGA	220	HV1	SHAHAPUR_220	14:24	17:27	3:03	LINE CLEAR AVAILED
1312	24-Jan-22	GULBARGA	220	HV2	ALIPUR_220	4:46	4:55	0:09	TRANSFORMER FAULT
1313	24-Jan-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1314	24-Jan-22	GULBARGA	220	LINGAPUR-KUSTAGI	LINGAPUR_220	13:04	18:15	5:11	LINE CLEAR AVAILED
1315	24-Jan-22	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	3:44	7:22	3:38	LINE FAULT
1316	24-Jan-22	GULBARGA	220	SHAHABAD-KAPNOOR	SHAHABAD_220	11:05	11:15	0:10	LINE CLEAR AVAILED
1317	24-Jan-22	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	9:44	9:54	0:10	MAIN SUPPLY FAILURE
1318	24-Jan-22	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	9:44	9:54	0:10	MAIN SUPPLY FAILURE
1319	24-Jan-22	HASSAN	66	CRPATNA-S.BELAGOLA1	CRPATNA_220	17:29	17:36	0:07	LINE FAULT
1320	24-Jan-22	HASSAN	66	CRPATNA-S.BELAGOLA1	CRPATNA_220	17:29	17:36	0:07	LINE FAULT
1321	24-Jan-22	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	9:55	10:05	0:10	LINE FAULT
1322	24-Jan-22	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	9:55	10:05	0:10	LINE FAULT
1323	24-Jan-22	HASSAN	66	HV1	BALLUPETE_66	9:44	9:53	0:09	MAIN SUPPLY FAILURE
1324	24-Jan-22	HASSAN	66	HV1	BALLUPETE_66	9:44	9:53	0:09	MAIN SUPPLY FAILURE
1325	24-Jan-22	HASSAN	66	HV1	DUDDA_66	9:19	10:32	1:13	LINE CLEAR AVAILED
1326	24-Jan-22	HASSAN	66	HV1	DUDDA_66	9:19	10:32	1:13	LINE CLEAR AVAILED
1327	24-Jan-22	HASSAN	66	HV1	HNPURA_66	9:55	10:05	0:10	MAIN SUPPLY FAILURE
1328	24-Jan-22	HASSAN	66	HV1	HNPURA_66	9:55	10:05	0:10	MAIN SUPPLY FAILURE
1329	24-Jan-22	HASSAN	66	HV2	BASAVAGHATTA_66	20:18(16.01.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1330	24-Jan-22	HASSAN	66	HV2	BASAVAGHATTA_66	20:18(16.01.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1331	24-Jan-22	HASSAN	66	HV2	HNPURA_66	9:55	10:05	0:10	MAIN SUPPLY FAILURE
1332	24-Jan-22	HASSAN	66	HV2	HNPURA_66	9:55	10:05	0:10	MAIN SUPPLY FAILURE
1333	24-Jan-22	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	9:44	9:47	0:03	HAND TRIPPED
1334	24-Jan-22	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	9:44	9:47	0:03	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1335	24-Jan-22	HASSAN	110	HV1	BIRUR_110	12:16	12:39	0:23	TRANSFORMER FAULT
1336	24-Jan-22	HASSAN	110	HV1	BIRUR_110	12:16	12:39	0:23	TRANSFORMER FAULT
1337	24-Jan-22	HASSAN	110	HV1	HULICAL_110	15:15	18:26	3:11	LINE CLEAR AVAIED
1338	24-Jan-22	HASSAN	110	HV1	HULICAL_110	15:15	18:26	3:11	LINE CLEAR AVAIED
1339	24-Jan-22	HASSAN	110	HV1	KONDENALU_110	13:00	13:21	0:21	LINE CLEAR AVAIED
1340	24-Jan-22	HASSAN	110	HV1	KONDENALU_110	13:00	13:21	0:21	LINE CLEAR AVAIED
1341	24-Jan-22	HASSAN	110	HV2	SORABA_110	17:02	18:17	1:15	LINE CLEAR AVAIED
1342	24-Jan-22	HASSAN	110	HV2	SORABA_110	17:02	18:17	1:15	LINE CLEAR AVAIED
1343	24-Jan-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1344	24-Jan-22	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1345	24-Jan-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1346	24-Jan-22	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1347	24-Jan-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1348	24-Jan-22	HASSAN	110	JOG-NK2	mghejog_gen	11:19(28.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1349	24-Jan-22	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	9:44	9:47	0:03	HAND TRIPPED
1350	24-Jan-22	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	9:44	9:47	0:03	HAND TRIPPED
1351	24-Jan-22	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:14	19:36	9:22	LINE CLEAR AVAIED
1352	24-Jan-22	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:14	19:36	9:22	LINE CLEAR AVAIED
1353	24-Jan-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAIED
1354	24-Jan-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	9:30(9.01.2022)			LINE OPEN:LINE CLEAR AVAIED
1355	24-Jan-22	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	10:18	13:08	2:50	LINE CLEAR AVAIED
1356	24-Jan-22	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	10:18	13:08	2:50	LINE CLEAR AVAIED
1357	24-Jan-22	HASSAN	220	SHRAVY-SIRISI 1	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAIED
1358	24-Jan-22	HASSAN	220	SHRAVY-SIRISI 1	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAIED
1359	24-Jan-22	HASSAN	220	SHRAVY-SIRISI 2	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAIED
1360	24-Jan-22	HASSAN	220	SHRAVY-SIRISI 2	sharavathy_gen	7:46(21.01.2022)			LINE OPEN:LINE CLEAR AVAIED
1361	24-Jan-22	MYSURU	66	BOGADHI-GIS	NO STATIONS EFFECTED	12:54:48 (18.01.2022)			LINE OPEN:LINE CLEAR AVAIED
1362	24-Jan-22	MYSURU	66	BOOKANKERE-CHINNAKURALI	CHINAKURALI_66	2:23	2:30	0:06	LINE FAULT
1363	24-Jan-22	MYSURU	66	BOOKANKERE-CHINNAKURALI	CHINAKURALI_66	3:15	3:27	0:12	LINE FAULT
1364	24-Jan-22	MYSURU	66	BOOKANKERE-CHINNAKURALI	CHINAKURALI_66	4:29	4:34	0:04	LINE FAULT
1365	24-Jan-22	MYSURU	66	BOOKANKERE-CHINNAKURALI	CHINAKURALI_66	5:01	5:07	0:06	LINE FAULT
1366	24-Jan-22	MYSURU	66	BOOKANKERE-CHINNAKURALI	CHINAKURALI_66	6:05	6:10	0:05	LINE FAULT
1367	24-Jan-22	MYSURU	66	BOOKANKERE-CHINNAKURALI	CHINAKURALI_66	13:29	14:20	0:50	LINE CLEAR AVAIED
1368	24-Jan-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAIED
1369	24-Jan-22	MYSURU	66	HUNSUR-PERIYAPATNA	NO STATIONS EFFECTED	9:23	11:08	1:45	LINE FAULT
1370	24-Jan-22	MYSURU	66	HV1	GAMANAHALLI_66	12:54	17:42	4:48	LINE CLEAR AVAIED
1371	24-Jan-22	MYSURU	66	HV1	RKNAGAR_66	11:08	14:12	3:04	LINE CLEAR AVAIED
1372	24-Jan-22	MYSURU	66	HV2	HDKOTE_66	11:41	12:30	0:49	LINE CLEAR AVAIED
1373	24-Jan-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAIED
1374	24-Jan-22	MYSURU	66	KADAKOLA-SARGUR2	HURA_66 HULLALLI_66 DOORA_66	18:45	18:53	0:07	LINE FAULT
1375	24-Jan-22	MYSURU	66	KK HALLI-SHIMSHA-1	NO STATIONS EFFECTED	8:00:00 (13/1/2022)			LINE OPEN:LINE CLEAR AVAIED



SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1376	24-Jan-22	MYSURU	66	PERIYAPATNA-HANGUD	PONNAMPETE_66 VIRAJPETE_66 HANGUD_66	0:17	0:26	0:09	LINE FAULT
1377	24-Jan-22	MYSURU	66	PERIYAPATNA-KAMPLAPURA	KAMPALAPURA_66	3:19	3:27	0:08	LINE FAULT
1378	24-Jan-22	MYSURU	66	PERIYAPATNA-KAMPLAPURA	KAMPALAPURA_66	8:52	9:29	0:37	LINE FAULT
1379	24-Jan-22	MYSURU	66	TN PURA-THAYUR	NO STATIONS EFFECTED	11:57:36 (13/1/2022)			LINE OPEN:LINE CLEAR AVAILED
1380	24-Jan-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:00	18:03	11:03	LINE CLEAR AVAILED
1381	24-Jan-22	TUMKUR	66	CHITRADURGA 220kv- SUZLON 2	SUZLON2_IPP_66	16:04	16:16	0:12	LINE FAULT
1382	24-Jan-22	TUMKUR	66	CHITRADURGA 220kv- SUZLON 2	SUZLON2_IPP_66	16:38	17:19	0:41	LINE FAULT
1383	24-Jan-22	TUMKUR	66	CHITRADURGA 220kv- SUZLON 2	SUZLON2_IPP_66	18:25	18:43	0:18	LINE FAULT
1384	24-Jan-22	TUMKUR	66	JAVAGONDANAHALLI- SIRA (TAVAREKER)	JAVAGONDANAHALLI_66	13:26	14:06	0:39	NFBC ISSUED
1385	24-Jan-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR_IPP_66	CLEAR SOLAR_IPP_66	12:16	12:25	0:08	LINE FAULT
1386	24-Jan-22	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUN SOLAR2	13:20	13:30	0:09	LINE FAULT
1387	24-Jan-22	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUN SOLAR2	14:11	14:25	0:13	LINE FAULT
1388	24-Jan-22	TUMKUR	66	TR-1	BHAKTHARA HALLI_66	8:19	9:12	0:53	LINE CLEAR AVAILED
1389	24-Jan-22	TUMKUR	66	TR-1	CHALLAKERE_66	12:19	12:30	0:11	TRANSFORMER FAULT
1390	24-Jan-22	TUMKUR	66	TR-1	CHANNAGIRI_66	8:14	8:21	0:07	TRANSFORMER FAULT
1391	24-Jan-22	TUMKUR	66	TR-1	CHIKKATOTTLUKERE_66	14:30	15:07	0:36	LINE CLEAR AVAILED
1392	24-Jan-22	TUMKUR	66	TR-1	JIDDIGERE_66	16:12	17:43	1:30	LINE CLEAR AVAILED
1393	24-Jan-22	TUMKUR	66	TR-1	PD KOTE_66	15:39	17:46	2:07	LINE CLEAR AVAILED
1394	24-Jan-22	TUMKUR	66	TR-1	PD KOTE_66	18:01	18:19	0:18	LINE CLEAR AVAILED
1395	24-Jan-22	TUMKUR	66	TR-1(LV SIDE)	DAVANAGERE SRS_220	15:38	15:44	0:05	HAND TRIPPED
1396	24-Jan-22	TUMKUR	66	TR-2	CHANNAGIRI_66	18:21	18:23	0:01	TRANSFORMER FAULT
1397	24-Jan-22	TUMKUR	66	TR-2	KADAJJI_66	21:06	21:12	0:05	TRANSFORMER FAULT
1398	24-Jan-22	TUMKUR	66	TR-2	PD KOTE_66	12:25	15:45	3:20	LINE CLEAR AVAILED
1399	24-Jan-22	TUMKUR	66	TR-2	THALLAK_220	17:21	17:47	0:26	LINE CLEAR AVAILED
1400	24-Jan-22	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	7:46	7:56	0:10	LINE FAULT
1401	24-Jan-22	TUMKUR	110	DODDAGUNI- NITTUR	DODDAGUNI_110	12:30	13:25	0:55	LINE CLEAR AVAILED
1402	24-Jan-22	TUMKUR	110	TR-1	DODDAGUNI_110	12:30	13:25	0:55	LINE CLEAR AVAILED
1403	24-Jan-22	TUMKUR	110	TR-2	DODDAGUNI_110	16:00	16:20	0:20	LINE CLEAR AVAILED
1404	24-Jan-22	TUMKUR	220	TR-1(HV SIDE)	THALLAK_220	17:20	17:46	0:26	LINE CLEAR AVAILED