

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 19.02.2019 to 25.02.2019

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
1	19-Feb-19	BAGALKOT	110	110/11KV, HV1	ACHANUR_110	17:43	17:47	0:04	LOAD CURTAILMENT
2	19-Feb-19	BAGALKOT	110	110/11KV, HV2	AINAPUR_110	17:43	17:46	0:03	LOAD CURTAILMENT
3	19-Feb-19	BAGALKOT	110	110/11KV, HV2	AREMALLAPUR_110	17:46	17:55	0:09	LOAD CURTAILMENT
4	19-Feb-19	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	17:43	18:01	0:18	LOAD CURTAILMENT
5	19-Feb-19	BAGALKOT	110	110/33KV, HV3	BAGALKOT_220, KATGERI_33	17:45	18:06	0:21	LOAD CURTAILMENT
6	19-Feb-19	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	14:44	14:51	0:07	TRANSFORMER FAULT
7	19-Feb-19	BAGALKOT	110	110/11KV, HV4	GAJENDRAGAD_110	17:43	17:52	0:09	LOAD CURTAILMENT
8	19-Feb-19	BAGALKOT	110	110/33KV, HV1	HANGAL_110, PALA_33	17:43	18:04	0:21	LOAD CURTAILMENT
9	19-Feb-19	BAGALKOT	110	110/33KV, HV2	HANGAL_110	17:46	18:04	0:18	LOAD CURTAILMENT
10	19-Feb-19	BAGALKOT	110	110/11KV, HV1	HIDIKAL_110	17:45	17:58	0:13	LOAD CURTAILMENT
11	19-Feb-19	BAGALKOT	110	110/33KV, HV3	HIDIKAL_110, KOLIGUDDA_33	17:43	17:50	0:07	LOAD CURTAILMENT
12	19-Feb-19	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	12:50	13:45	0:55	LINE CLEAR AVAILED
13	19-Feb-19	BAGALKOT	110	KUDACHI220-MORAB	MORAB_110	11:50	15:34	3:44	LINE CLEAR AVAILED
14	19-Feb-19	BAGALKOT	220	DHONI-LINGAPUR	DHONI_400	11:18	16:23	5:05	LINE CLEAR AVAILED
15	19-Feb-19	BAGALKOT	220	DHONI-ARRESS STEEL	DHONI_400	0:00	16:19	16:19	LINE CLEAR AVAILED
16	19-Feb-19	BAGALKOT	110	110/33KV, HV3	KULIGOD_110, TIGADI_33, AREMALATTI_33	17:45	17:55	0:10	LOAD CURTAILMENT
17	19-Feb-19	BAGALKOT	110	110/11KV, HV1	LAXMESHWAR_110	17:44	17:55	0:11	LOAD CURTAILMENT
18	19-Feb-19	BAGALKOT	110	ASHOKA IRON PLANT-MACHE	MACHE_110	0:00	18:27	18:27	LINE CLEAR AVAILED
19	19-Feb-19	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	10:10	19:52	9:42	TRANSFORMER FAULT
20	19-Feb-19	BAGALKOT	110	MKHUBLI220-MK HUBLI	MK HUBLI_110	11:10	23:59	12:49	LINE CLEAR AVAILED
21	19-Feb-19	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	13:42	13:48	0:06	TRANSFORMER FAULT
22	19-Feb-19	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	17:45	17:50	0:05	TRANSFORMER FAULT
23	19-Feb-19	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	22:46	22:51	0:05	TRANSFORMER FAULT
24	19-Feb-19	BAGALKOT	110	ILKAL1&2-HUNGUND	HUNGUND_110	14:39	15:47	1:08	MAIN SUPPLY FAILURE
25	19-Feb-19	BAGALKOT	66	66/33KV,HV4	AREMALLAPUR_33	17:31	17:37	0:06	LOAD CURTAILMENT
26	19-Feb-19	BAGALKOT	66	66/33KV,HV4	AREMALLAPUR_33	17:44	18:22	0:38	LOAD CURTAILMENT
27	19-Feb-19	BAGALKOT	110	110/11KV,HV1	YARAGATTI_110	11:50	12:36	0:46	LINE CLEAR AVAILED
28	19-Feb-19	BAGALKOT	110	110/11KV,HV1	YARAGATTI_110	12:39	12:41	0:02	HAND TRIPPED
29	19-Feb-19	BAGALKOT	110	110/33KV,HV2	YARAGATTI_110,BOSCH_IPP,SHIVAPUR_33,CHUNC HNUR_33	11:50	12:36	0:46	LINE CLEAR AVAILED
30	19-Feb-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	17:44	17:51	0:07	HAND TRIPPED
31	19-Feb-19	BAGALKOT	110	YARAGATTI-KATAKOL	KATAKOL_110	12:36	16:34	3:58	LINE CLEAR AVAILED
32	19-Feb-19	BAGALKOT	110	110/11KV,HV1	TODALABAGI_110	17:27	17:40	0:13	LOAD CURTAILMENT
33	19-Feb-19	BAGALKOT	110	110/11KV,HV1	TILUVALI_110	10:30	12:24	1:54	LINE CLEAR AVAILED
34	19-Feb-19	BAGALKOT	110	110/11KV,HV2	TILUVALI_110	17:46	17:48	0:02	TRANSFORMER FAULT
35	19-Feb-19	BAGALKOT	110	110/11KV,HV2	TILUVALI_110	17:45	17:50	0:05	LOAD CURTAILMENT
36	19-Feb-19	BAGALKOT	110	TARIHAL -IDLE(TADASINKOPPA)	TARIHAL_110 (NO STN INTERRUPTED)	7:54	7:55	0:01	HAND TRIPPED
37	19-Feb-19	BAGALKOT	110	TARIHAL -IDLE(TADASINKOPPA)	TARIHAL_110 (NO STN INTERRUPTED)	17:41	17:45	0:04	HAND TRIPPED
38	19-Feb-19	BAGALKOT	220	220/110KV ,HV3 & LV3	SRSHUBLI_220	10:00	17:05	7:05	LINE CLEAR AVAILED
39	19-Feb-19	BAGALKOT	110	110/11KV ,HV2	SHIRGOAN_110	16:19	16:39	0:20	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
40	19-Feb-19	BAGALKOT	110	110/33KV,HV2	SAVALAGI_110,HIREPADASALAGI_33,KALBILAGI_33,TUNGAL_LIS	17:43	18:02	0:19	LOAD CURTAILMENT
41	19-Feb-19	BAGALKOT	110	110/33KV,HV3	RANEENNUR_220,HALAGERI_33,GUDURMAIDUR_33	17:45	17:56	0:11	LOAD CURTAILMENT
42	19-Feb-19	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	17:47	17:55	0:08	LOAD CURTAILMENT
43	19-Feb-19	BAGALKOT	110	110/11KV,HV2	RAIBAG_110	17:43	17:48	0:05	LOAD CURTAILMENT
44	19-Feb-19	BANGALORE	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	0:00	3:00	3:00	LINE CLEAR AVAILED
45	19-Feb-19	BANGALORE	66	HV2	ATTUR YELAHANKA	20:05	20:25	0:19	TRANSFORMER FAULT
46	19-Feb-19	BANGALORE	66	HV1	VIJAYANAGARA	22:45	22:56	0:11	LOAD CHANGEOVER
47	19-Feb-19	BANGALORE	66	HV2	KHB	23:53	23:59	0:05	TRANSFORMER FAULT
48	19-Feb-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 2	HONNIGANAHALLI, DODDALAHALLI	15:25	18:02	2:37	LINE CLEAR AVAILED
49	19-Feb-19	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI	14:10	14:24	0:14	MAIN SUPPLY FAILURE
50	19-Feb-19	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	14:10	14:22	0:11	MAIN SUPPLY FAILURE
51	19-Feb-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBEL, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	14:10	14:20	0:09	MAIN SUPPLY FAILURE
52	19-Feb-19	BANGALORE	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	14:10	14:20	0:10	MAIN SUPPLY FAILURE
53	19-Feb-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	14:10	14:22	0:11	MAIN SUPPLY FAILURE
54	19-Feb-19	BANGALORE	220	HV1	KANAKAPURA 220	14:10	14:16	0:05	TRANSFORMER FAULT
55	19-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:57	7:04	0:06	LINE FAULT
56	19-Feb-19	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL	14:00	14:32	0:31	LINE CLEAR AVAILED
57	19-Feb-19	BANGALORE	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI, YELDUR	14:00	14:31	0:31	LINE CLEAR AVAILED
58	19-Feb-19	BANGALORE	220	KIADB DB PURA 220 - GOWRIBIDANUR	KIADB DB PURA 220	14:22	14:55	0:33	LINE CLEAR AVAILED
59	19-Feb-19	BANGALORE	66	KIADB DB PURA 220 - APAREL PARK	APAREL PAK	14:19	14:55	0:36	MAIN SUPPLY FAILURE
60	19-Feb-19	BANGALORE	66	HV1	KIADB DB PURA 220	14:21	14:55	0:34	MAIN SUPPLY FAILURE
61	19-Feb-19	BANGALORE	66	HV2	KIADB DB PURA 220	14:21	14:55	0:34	MAIN SUPPLY FAILURE
62	19-Feb-19	BANGALORE	66	HONNIGANAHALLI - KANAKAPURA	HONNIGANAHALLI	15:27	15:35	0:07	LOAD CHANGEOVER
63	19-Feb-19	BANGALORE	66	HONNIGANAHALLI - HALAGUR	HONNIGANAHALLI	18:00	18:05	0:05	LOAD CHANGEOVER
64	19-Feb-19	BANGALORE	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	16:50	16:57	0:07	LINE FAULT
65	19-Feb-19	BANGALORE	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	12:58	13:36	0:37	LINE CLEAR AVAILED
66	19-Feb-19	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	5:52	5:57	0:04	LINE FAULT
67	19-Feb-19	BANGALORE	66	KOLAR 220 - NARASAPURA	NARASAPURA	17:54	18:03	0:09	LINE FAULT
68	19-Feb-19	BANGALORE	66	KOLAR 220 - PGCIL	SUGUTUR, SM MANGALA	23:07	23:30	0:23	LINE FAULT
69	19-Feb-19	BANGALORE	66	KYALANUR - VEMGAL	KYALANUR	13:05	13:31	0:25	LINE CLEAR AVAILED
70	19-Feb-19	BANGALORE	66	NANGALI - KEMPANAHALLI	NANGALI	16:57	17:02	0:05	LINE CLEAR AVAILED
71	19-Feb-19	BANGALORE	66	HV1	NANGALI	13:41	14:24	0:42	LINE CLEAR AVAILED
72	19-Feb-19	BANGALORE	66	HV2	NANGALI	16:27	17:03	0:36	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
73	19-Feb-19	BANGALORE	66	RAMANAGARA - BIDADI	RAMANAGARA	10:27	10:28	0:01	LINE FAULT
74	19-Feb-19	GULBARGA	220	LINGAPUR-GADAG1	LINGAPUR_220	11:18	16:24	5:06	NFBC ISSUED
75	19-Feb-19	GULBARGA	220	HV1	KUSTAGI_220	13:44	17:40	3:56	TRANSFORMER FAULT
76	19-Feb-19	GULBARGA	110	HV1	SINDHANOOR_220	11:00	11:28	0:28	LINE CLEAR AVAILED
77	19-Feb-19	GULBARGA	110	HV2	KEMBHAVI_110	12:42	12:58	0:16	LINE CLEAR AVAILED
78	19-Feb-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110, SHAHTAVAHANA_IPP,AGARWAL_IPP, SUZLON_IPP,KAMALAPUR_110,MATRI_110, RBNS FACTORY	2:04	2:21	0:17	LINE FAULT
79	19-Feb-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,S HAHTAVAHANA_IPP,AGARWAL_IPP, SUZLON_IPP,KAMALAPUR_110,MATRI_110, RBNS FACTORY	5:05	5:23	0:18	LINE FAULT
80	19-Feb-19	GULBARGA	110	HV1	DEODURGA_110	17:31	17:40	0:09	LOAD CURTAILMENT
81	19-Feb-19	GULBARGA	110	HV1	HANUMASAGAR_110	11:35	12:05	0:30	TRANSFORMER FAULT
82	19-Feb-19	GULBARGA	110	LINGASUGUR-LATUR_GAMESH	LINGASUGUR_220	12:10	14:14	2:04	LINE CLEAR AVAILED
83	19-Feb-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	3:05	11:33	8:28	LINE FAULT
84	19-Feb-19	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	14:09	14:20	0:11	LINE CLEAR AVAILED
85	19-Feb-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	BTPS WATER WORKS,MUKKUNDA_110,KAMPLI_GLB_110	23:18	23:31	0:13	LINE FAULT
86	19-Feb-19	GULBARGA	66	HV1	CJHALLI_66	17:31	17:38	0:07	LOAD CURTAILMENT
87	19-Feb-19	HASSAN	220	VMRSSHM-ARAH12	MRSMSG_220	5:59	12:45	6:46	LINE FAULT
88	19-Feb-19	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:03	17:19	4:16	LINE FAULT
89	19-Feb-19	HASSAN	220	SHVARAH1-IMOGA2	varahi-gen	5:59	12:45	6:46	LINE FAULT
90	19-Feb-19	HASSAN	220	SHVARAH1-SHIMOGA2	varahi-gen	13:03	17:19	4:16	LINE FAULT
91	19-Feb-19	HASSAN	110	HV1	NITTUR_110	12:03	14:04	2:01	LINE CLEAR AVAILED
92	19-Feb-19	HASSAN	110	HV1	HALADY_110	17:43	17:51	0:08	MAIN SUPPLY FAILURE
93	19-Feb-19	HASSAN	110	HV2	AJJAMPURA_110	14:12	15:01	0:49	TRANSFORMER FAULT
94	19-Feb-19	HASSAN	110	HV1	ARASIKERE_220	13:04	13:48	0:44	LINE CLEAR AVAILED
95	19-Feb-19	HASSAN	110	HV1	BANAVARA_66	16:17	16:35	0:18	HAND TRIPPED
96	19-Feb-19	HASSAN	110	HV1	GANDASI_110	18:40	18:55	0:15	LINE CLEAR AVAILED
97	19-Feb-19	HASSAN	110	HV2	GANDASI_110	17:43	17:51	0:08	MAIN SUPPLY FAILURE
98	19-Feb-19	HASSAN	110	HV2	GANDASI_110	18:54	19:01	0:07	LINE CLEAR AVAILED
99	19-Feb-19	HASSAN	110	HV2	GERUMARA_110	17:44	17:57	0:13	MAIN SUPPLY FAILURE
100	19-Feb-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	14:11	14:44	0:33	LINE CLEAR AVAILED
101	19-Feb-19	HASSAN	66	RABAGUR-MAPUR	BAGUR_66	21:58	22:00	0:02	LINE FAULT
102	19-Feb-19	HASSAN	66	BANDISH-ADANI	BANDISHETIHALLY_66	17:25	18:56	1:31	LINE FAULT
103	19-Feb-19	HASSAN	66	BANDISH-ADANI	BANDISHETIHALLY_66	23:21	23:59	0:38	LINE FAULT
104	19-Feb-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	13:18	13:36	0:18	LINE FAULT
105	19-Feb-19	HASSAN	66	HV1	DODDAKADNUR_66	17:35	17:40	0:05	TRANSFORMER FAULT
106	19-Feb-19	HASSAN	66	HV1	HANGRANAHALLY_66	17:44	17:51	0:07	MAIN SUPPLY FAILURE
107	19-Feb-19	HASSAN	66	RAMANT-BNDSTHL	RAMNATHPURA_66	8:12	18:38	10:26	LINE FAULT
108	19-Feb-19	HASSAN	66	HV2	RAMESHWARNAGARA_66	17:45	18:00	0:15	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
109	19-Feb-19	HASSAN	66	HV2	SALAGAME_66	17:45	17:49	0:04	MAIN SUPPLY FAILURE
110	19-Feb-19	HASSAN	66	HV1	SATHENAHALLY_66	17:45	17:51	0:06	MAIN SUPPLY FAILURE
111	19-Feb-19	HASSAN	66	UDDURK-CKNDGL	UDDURKOPLU_66	11:25	11:34	0:09	HAND TRIPPED
112	19-Feb-19	HASSAN	66	HV2	CHANNARAYAPATNA_66	17:44	17:51	0:07	MAIN SUPPLY FAILURE
113	19-Feb-19	HASSAN	66	HV2	BASAVAGHATTA_66	17:44	17:51	0:07	MAIN SUPPLY FAILURE
114	19-Feb-19	MYSORE	66	HV2	ADDIHALLI_66	17:43	17:54	0:11	LOAD CURTAILMENT
115	19-Feb-19	MYSORE	66	HV2	AKKIHEBBAL_66	17:43	23:59	6:15	LOAD CURTAILMENT
116	19-Feb-19	MYSORE	66	HV1	BESAGARAHALLI_66	17:45	17:55	0:10	LOAD CURTAILMENT
117	19-Feb-19	MYSORE	66	HV2	BOOKANAKERE_66	17:43	17:56	0:13	LOAD CURTAILMENT
118	19-Feb-19	MYSORE	66	HV2	CHINAKURALI_66	17:45	17:54	0:09	LOAD CURTAILMENT
119	19-Feb-19	MYSORE	66	HV1	DODDINADUVADI_66	17:43	17:49	0:06	LOAD CURTAILMENT
120	19-Feb-19	MYSORE	66	HV2	DODDARAYAPET_66	17:43	17:55	0:11	LOAD CURTAILMENT
121	19-Feb-19	MYSORE	66	HV1	ELAVALA_66	12:13	12:14	0:01	HAND TRIPPED
122	19-Feb-19	MYSORE	66	HV1	ELAVALA_66	12:15	12:24	0:09	HAND TRIPPED
123	19-Feb-19	MYSORE	66	HV2	ELAVALA_66	17:44	17:50	0:05	LOAD CURTAILMENT
124	19-Feb-19	MYSORE	66	HV1	HANAGODU_66	17:43	18:02	0:19	LOAD CURTAILMENT
125	19-Feb-19	MYSORE	66	HV2	HANNUR_66	17:43	18:15	0:31	LOAD CURTAILMENT
126	19-Feb-19	MYSORE	66	HV2	HDKOTE_66	17:43	18:00	0:16	LOAD CURTAILMENT
127	19-Feb-19	MYSORE	66	HV2	JAIPUR_66	17:43	17:57	0:13	LOAD CURTAILMENT
128	19-Feb-19	MYSORE	66	HV1	KIKKERI_66	11:07	14:12	3:05	LINE CLEAR AVAILED
129	19-Feb-19	MYSORE	66	HV2	KIKKERI_66	10:44	11:50	1:05	LINE CLEAR AVAILED
130	19-Feb-19	MYSORE	66	HV3	KIKKERI_66	12:12	14:03	1:51	LINE CLEAR AVAILED
131	19-Feb-19	MYSORE	66	HV2	KIRUGAVALU_66	17:43	18:40	0:56	LOAD CURTAILMENT
132	19-Feb-19	MYSORE	66	HV2	KMDODDI_66	17:43	18:04	0:20	LOAD CURTAILMENT
133	19-Feb-19	MYSORE	66	HV1	KUSHALANAGARA_66	17:43	17:58	0:14	LOAD CURTAILMENT
134	19-Feb-19	MYSORE	66	HV1	PANDAVAPURA_66	17:44	17:56	0:12	LOAD CURTAILMENT
135	19-Feb-19	MYSORE	66	HV2	PONNAMPET_66	17:44	18:00	0:15	LOAD CURTAILMENT
136	19-Feb-19	MYSORE	66	HV1	RAMAPURA_MYS_66	17:44	18:19	0:35	LINE CLEAR AVAILED
137	19-Feb-19	MYSORE	66	HV1	SATHEGALA_66	17:45	17:50	0:04	LOAD CURTAILMENT
138	19-Feb-19	MYSORE	66	HV2	SANTHESARAGUR_66	17:45	17:46	0:01	LOAD CURTAILMENT
139	19-Feb-19	MYSORE	66	HV2	SANTHEMARAHALLI_66	17:45	17:50	0:05	LOAD CURTAILMENT
140	19-Feb-19	MYSORE	66	HV1	YELANDUR_66	17:42	17:44	0:02	LOAD CURTAILMENT
141	19-Feb-19	MYSORE	66	MANDYA-CHIKKA MANDYA	CHIKKA_MANDYA_66 HAMPAPURA(K)_66 BESAGARAHALLI_66 DUNDANAHALLI_66	9:08	9:22	0:14	LINE FAULT
142	19-Feb-19	MYSORE	66	ELAVALA-HOOTAGLLY	ELAVALA_66	14:05	14:07	0:01	LINE FAULT
143	19-Feb-19	MYSORE	66	ELAVALA-HUNSUR	ELAVALA_66	14:05	14:07	0:01	LINE FAULT
144	19-Feb-19	MYSORE	66	VAJMANGALA-MEGLAPURA	MEGALAPURA_66	10:27	10:30	0:03	HAND TRIPPED
145	19-Feb-19	MYSORE	66	HV1	ELAVALA_66	7:28	7:37	0:09	TRANSFORMER FAULT
146	19-Feb-19	MYSORE	66	HV1	ELAVALA_66	10:14	11:05	0:51	TRANSFORMER FAULT
147	19-Feb-19	MYSORE	66	HV3	KUSHALANAGARA_66	20:07	20:18	0:11	TRANSFORMER FAULT
148	19-Feb-19	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	7:57	19:13	11:16	LINE CLEAR AVAILED
149	19-Feb-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	22:08	22:16	0:08	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
150	19-Feb-19	TUMKUR	110	TR-1	GUBBI_110	22:17	22:24	0:06	TRANSFORMER FAULT
151	19-Feb-19	TUMKUR	110	TR-1	HALKURKE_110	8:59	18:02	9:03	LINE CLEAR AVAILED
152	19-Feb-19	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	10:25	12:48	2:22	LINE CLEAR AVAILED
153	19-Feb-19	TUMKUR	66	TR-1	CHANNAGIRI_66	14:04	14:11	0:06	TRANSFORMER FAULT
154	19-Feb-19	TUMKUR	66	TR-1	CHITRADURGA_66	12:40	13:11	0:31	LINE CLEAR AVAILED
155	19-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:23	17:37	9:14	LINE CLEAR AVAILED
156	19-Feb-19	TUMKUR	66	TR-1	HARAPPANAHALLI_66	11:14	14:55	3:41	LINE CLEAR AVAILED
157	19-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:46	12:53	0:07	HAND TRIPPED
158	19-Feb-19	TUMKUR	66	TR-1	LINGADAHALLY_66	0:33	0:42	0:09	TRANSFORMER FAULT
159	19-Feb-19	TUMKUR	66	TR-1	LINGADAHALLY_66	18:50	19:00	0:10	TRANSFORMER FAULT
160	19-Feb-19	TUMKUR	66	TR-2	THOVINAKERE_66	13:35	15:00	1:24	LINE CLEAR AVAILED
161	19-Feb-19	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE_66	18:56	19:07	0:11	MAIN SUPPLY FAILURE
162	19-Feb-19	TUMKUR	66	YEDIYUR- BG NAGARA	BGNAGARA_66	10:27	12:51	2:23	LINE CLEAR AVAILED
163	20-Feb-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	0:00	18:16	18:16	LINE CLEAR AVAILED
164	20-Feb-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	0:00	13:54	13:54	LINE CLEAR AVAILED
165	20-Feb-19	BAGALKOT	220	AMBEWADI-PODA 2	AMBEWADI_220	16:05	23:59	7:54	LINE CLEAR AVAILED
166	20-Feb-19	BAGALKOT	110	AMBEWADI-NK1	HALYAL_110,UMACHAGI_110&KIRUVATTI_110	11:25	11:39	0:14	LINE CLEAR AVAILED
167	20-Feb-19	BAGALKOT	110	AMBEAWDI-NK1&2	HALYAL_110,UMACHAGI_110,KIRUVATTI_110&KAV ALAWAD_110	16:09	16:50	0:41	LINE CLEAR AVAILED
168	20-Feb-19	BAGALKOT	110	110/11KV,HV-1	GULEDGUDD_110	18:30	23:59	5:29	TRANSFORMER FAULT
169	20-Feb-19	BAGALKOT	110	110/11KV,HV-1	ITANAL_110	7:11	7:26	0:15	TRANSFORMER FAULT
170	20-Feb-19	BAGALKOT	110	110/11KV,HV-1	KALADAGI_110	10:00	10:19	0:19	HAND TRIPPED
171	20-Feb-19	BAGALKOT	110	BAGALKOT-KALADAGI	KALADAGI_110,33KV KATWA CEMENT FACTORY&33KV BHANTANUR	10:00	10:19	0:19	HAND TRIPPED
172	20-Feb-19	BAGALKOT	110	KONNUR-ANANT SOLAR	KONNUR_110	21:54	23:59	2:05	LINE CLEAR AVAILED
173	20-Feb-19	BAGALKOT	110	KARAWAR-SOLARIS(BINAGA)	KARAWAR_220	13:11	18:39	5:28	LINE CLEAR AVAILED
174	20-Feb-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	8:26	8:29	0:03	TRANSFORMER FAULT
175	20-Feb-19	BAGALKOT	110	ZALKI-CHADCHAN	CHADCHAN_110	11:32	11:48	0:16	LINE FAULT
176	20-Feb-19	BAGALKOT	110	110/11KV, HV2	TILUVALI_110	9:37	12:10	2:33	LINE CLEAR AVAILED
177	20-Feb-19	BAGALKOT	110	HUBLI220-ANAND NAGAR	ANAND NAGAR_110	10:23	15:44	5:21	LINE CLEAR AVAILED
178	20-Feb-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	16:07	16:17	0:10	HAND TRIPPED
179	20-Feb-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	16:44	16:51	0:07	HAND TRIPPED
180	20-Feb-19	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	12:11	13:58	1:47	LINE CLEAR AVAILED
181	20-Feb-19	BAGALKOT	110	RANEENNUR220-RATTIHALLI	RATTIHALLI_110	8:30	8:48	0:18	LINE FAULT
182	20-Feb-19	BAGALKOT	110	HONNAVAR-MURDESHWAR	MURDESHWAR_110	10:23	13:22	2:59	LINE CLEAR AVAILED
183	20-Feb-19	BAGALKOT	110	RAMANKOPPA-MUNDAGOD	MUNDAGOD_110	16:59	17:18	0:19	LINE CLEAR AVAILED
184	20-Feb-19	BAGALKOT	110	MKHUBLI220-MKHUBLI	MK HUBLI_110	0:00	13:15	13:15	LINE CLEAR AVAILED
185	20-Feb-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	15:54	17:52	1:58	LINE CLEAR AVAILED
186	20-Feb-19	BAGALKOT	110	110/33KV, HV3	TIKOTA_110, BIJARGI_33	15:11	15:29	0:18	LINE CLEAR AVAILED
187	20-Feb-19	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	12:13	12:25	0:11	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
188	20-Feb-19	BANGALORE	66	HV1	POTTERY ROAD	12:13	12:40	0:26	MAIN SUPPLY FAILURE
189	20-Feb-19	BANGALORE	66	HV2	POTTERY ROAD	12:13	12:28	0:15	MAIN SUPPLY FAILURE
190	20-Feb-19	BANGALORE	66	TK HALLI 220 - MANDYA 1	MANDYA	7:55	8:14	0:19	LINE FAULT
191	20-Feb-19	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR	7:55	8:15	0:20	LINE FAULT
192	20-Feb-19	BANGALORE	66	HV1	KHB	7:35	8:10	0:35	TRANSFORMER FAULT
193	20-Feb-19	BANGALORE	66	HV2	ISRO LAYOUT	0:52	1:25	0:32	TRANSFORMER FAULT
194	20-Feb-19	BANGALORE	66	HV1	NANDINI LAYOUT	9:58	12:18	2:20	LINE CLEAR AVAILED
195	20-Feb-19	BANGALORE	66	HV2	NANDINI LAYOUT	9:58	12:18	2:20	LINE CLEAR AVAILED
196	20-Feb-19	BANGALORE	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	16:05	16:10	0:05	LOAD CHANGEVER
197	20-Feb-19	BANGALORE	66	HV2	ANDERSONPET	15:02	15:31	0:29	TRANSFORMER FAULT
198	20-Feb-19	BANGALORE	66	HV1	CHANNAPATNA	10:22	10:23	0:01	LINE CLEAR AVAILED
199	20-Feb-19	BANGALORE	66	HV2	CHANNAPATNA	10:22	10:23	0:01	LINE CLEAR AVAILED
200	20-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:58	11:03	0:05	LINE CLEAR AVAILED
201	20-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:06	15:22	0:15	LINE CLEAR AVAILED
202	20-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:29	16:55	0:25	LINE CLEAR AVAILED
203	20-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:58	11:03	0:05	LINE CLEAR AVAILED
204	20-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	15:06	15:22	0:15	LINE CLEAR AVAILED
205	20-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:29	16:55	0:25	LINE CLEAR AVAILED
206	20-Feb-19	BANGALORE	66	HV2	HOSKOTE 66	15:21	15:54	0:33	LINE CLEAR AVAILED
207	20-Feb-19	BANGALORE	66	MALUR 220 - MASTHI	MAASTHI, DEVANGONDHI, LAKKUR	7:45	8:03	0:17	LINE FAULT
208	20-Feb-19	BANGALORE	66	KOLAR 220 - PGCIL	SUGUTUR, SM MANGALA	0:00	3:25	3:25	LINE FAULT
209	20-Feb-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	8:14	8:21	0:07	LINE FAULT
210	20-Feb-19	BANGALORE	66	HV1	BANGARPET	15:07	15:24	0:16	LINE CLEAR AVAILED
211	20-Feb-19	BANGALORE	66	KYALANUR - VEMGAL	KYALANUR	11:51	12:30	0:38	LINE CLEAR AVAILED
212	20-Feb-19	GULBARGA	220	LINGAPUR-BTPS	BTPS_220	12:45	14:22	1:37	LINE FAULT
213	20-Feb-19	GULBARGA	110	SINDHANOOR220-PGLR_WIND	SIDHANOOR_220	10:46	12:05	1:19	LINE CLEAR AVAILED
214	20-Feb-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	SINDHANOOR_110	11:44	12:03	0:19	LINE FAULT
215	20-Feb-19	GULBARGA	110	MALLAT-BYAGWAT-1	BYAGWAT_110	4:50	5:25	0:35	LINE FAULT
216	20-Feb-19	GULBARGA	110	GABBUR-DEODURGA O/G	DEODURGA_110	20:05	20:10	0:05	LINE FAULT
217	20-Feb-19	GULBARGA	110	KAVITAL-GAMESHA_IPP	KAVITAL_110	12:45	18:50	6:05	LINE CLEAR AVAILED
218	20-Feb-19	GULBARGA	66	KOTTUR-UJJANI	KOTTUR_110	11:43	12:11	0:28	LINE CLEAR AVAILED
219	20-Feb-19	GULBARGA	66	HV1	HAMPASAGAR_66	17:25	17:35	0:10	TRANSFORMER FAULT
220	20-Feb-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:25	23:59	9:34	LINE FAULT
221	20-Feb-19	HASSAN	220	KADUR-SHIMOGA	KADUR_220	14:05	15:28	1:23	LINE FAULT
222	20-Feb-19	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	8:35	19:30	10:55	LINE CLEAR AVAILED
223	20-Feb-19	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	13:17	19:30	6:13	LINE CLEAR AVAILED
224	20-Feb-19	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	14:05	15:29	1:24	LINE FAULT
225	20-Feb-19	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	11:14	15:58	4:44	LINE CLEAR AVAILED
226	20-Feb-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	13:18	19:30	6:12	NFBC ISSUED
227	20-Feb-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:34	19:30	10:56	NFBC ISSUED
228	20-Feb-19	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	10:16	13:42	3:26	LINE CLEAR AVAILED
229	20-Feb-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	12:06	12:22	0:16	HAND TRIPPED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
230	20-Feb-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	18:16	18:30	0:14	HAND TRIPPED
231	20-Feb-19	HASSAN	110	HV1	ANAVATTI_110	12:22	12:30	0:08	HAND TRIPPED
232	20-Feb-19	HASSAN	110	HV1	ANAVATTI_110	18:05	18:07	0:02	HAND TRIPPED
233	20-Feb-19	HASSAN	110	HV2	ANAVATTI_110	12:22	12:30	0:08	HAND TRIPPED
234	20-Feb-19	HASSAN	110	HV2	ANAVATTI_110	18:05	18:07	0:02	HAND TRIPPED
235	20-Feb-19	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	12:06	12:22	0:16	HAND TRIPPED
236	20-Feb-19	HASSAN	110	HV2	HIRIYADKA_110	10:41	13:22	2:41	LINE CLEAR AVAILED
237	20-Feb-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:40	13:30	2:50	LINE CLEAR AVAILED
238	20-Feb-19	HASSAN	110	HV1	KONAJE_110	10:00	15:53	5:53	LINE CLEAR AVAILED
239	20-Feb-19	HASSAN	110	HV2	KONAJE_110	10:01	10:03	0:02	HAND TRIPPED
240	20-Feb-19	HASSAN	110	HV2	KONAJE_110	13:48	13:51	0:03	HAND TRIPPED
241	20-Feb-19	HASSAN	110	HV3	KONAJE_110	10:01	10:03	0:02	HAND TRIPPED
242	20-Feb-19	HASSAN	110	HV3	KONAJE_110	13:48	13:51	0:03	HAND TRIPPED
243	20-Feb-19	HASSAN	110	HV1	MOODABIDRE_110	12:43	14:58	2:15	LINE CLEAR AVAILED
244	20-Feb-19	HASSAN	110	HV2	MOODABIDRE_110	10:15	12:32	2:17	LINE CLEAR AVAILED
245	20-Feb-19	HASSAN	110	HV2	SAGARA_110	19:55	21:10	1:15	LINE CLEAR AVAILED
246	20-Feb-19	HASSAN	110	HV2	SORABA_110	16:15	16:44	0:29	LINE CLEAR AVAILED
247	20-Feb-19	HASSAN	66	HASSN22-HN PURA	HASSAN_220	11:40	11:48	0:08	HAND TRIPPED
248	20-Feb-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	9:23	9:38	0:15	LINE FAULT
249	20-Feb-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	9:40	13:08	3:28	LINE FAULT
250	20-Feb-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	13:52	14:54	1:02	LINE FAULT
251	20-Feb-19	HASSAN	66	BANDISH-ADANI	BANDISHETTHALLY_66	0:00	2:46	2:46	LINE FAULT
252	20-Feb-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	12:41	14:53	2:12	LINE CLEAR AVAILED
253	20-Feb-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	12:03	14:16	2:13	LINE CLEAR AVAILED
254	20-Feb-19	MYSORE	66	HV1	ELAVALA_66	6:52	23:59	17:06	TRANSFORMER FAULT
255	20-Feb-19	MYSORE	66	HV1	FTS_66	11:20	11:44	0:24	HAND TRIPPED
256	20-Feb-19	MYSORE	66	HV2	HAMPAPURA_66	7:16	7:22	0:05	TRANSFORMER FAULT
257	20-Feb-19	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66	7:19	8:50	1:31	LINE CLEAR AVAILED
258	20-Feb-19	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66	18:13	21:04	2:50	LINE CLEAR AVAILED
259	20-Feb-19	MYSORE	66	HV1	K_HONNALGERE_66	7:56	8:17	0:21	HAND TRIPPED
260	20-Feb-19	MYSORE	66	HV1	K_HONNALGERE_66	8:18	8:26	0:07	HAND TRIPPED
261	20-Feb-19	MYSORE	66	HV2	K_HONNALGERE_66	7:56	8:17	0:21	HAND TRIPPED
262	20-Feb-19	MYSORE	66	HV2	K_HONNALGERE_66	8:18	8:26	0:07	HAND TRIPPED
263	20-Feb-19	MYSORE	66	HV1	KIRUGAVALU_66	13:26	15:02	1:36	LINE CLEAR AVAILED
264	20-Feb-19	MYSORE	66	HV2	KIRUGAVALU_66	12:08	13:12	1:04	LINE CLEAR AVAILED
265	20-Feb-19	MYSORE	66	HV1	MANDYA_66	10:26	22:17	11:51	LINE CLEAR AVAILED
266	20-Feb-19	MYSORE	66	HV2	MANDYA_66	22:46	22:50	0:03	TRANSFORMER FAULT
267	20-Feb-19	MYSORE	66	HV1	MYSORESOUTH_66	11:59	13:24	1:25	LINE CLEAR AVAILED
268	20-Feb-19	MYSORE	66	HV2	MYSORESOUTH_66	12:31	12:32	0:01	TRANSFORMER FAULT
269	20-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	6:51	11:35	4:43	LINE CLEAR AVAILED
270	20-Feb-19	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	13:29	13:35	0:05	HAND TRIPPED
271	20-Feb-19	MYSORE	220	HV1	TUBINAKERE_220	10:28	13:41	3:13	LINE CLEAR AVAILED
272	20-Feb-19	MYSORE	66	HV2	TUBINAKERE_220	10:26	17:14	6:48	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
273	20-Feb-19	MYSORE	66	VAJMANGLA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	9:16	9:17	0:01	HAND TRIPPED
274	20-Feb-19	MYSORE	66	VAJMANGLA-MEGHLAPURA	MEGALAPURA_66	9:14	9:16	0:01	HAND TRIPPED
275	20-Feb-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_22	14:10	17:50	3:40	LINE CLEAR AVAILED
276	20-Feb-19	TUMKUR	220	GUTUR 66-DAVANGERE SRS-1	GUTUR_66	14:10	17:49	3:39	LINE CLEAR AVAILED
277	20-Feb-19	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	10:33	17:52	7:18	LINE CLEAR AVAILED
278	20-Feb-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	3:18	3:35	0:17	TRANSFORMER FAULT
279	20-Feb-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	8:21	8:54	0:33	TRANSFORMER FAULT
280	20-Feb-19	TUMKUR	220	TR-1 & TR-2	KBCROSS_220	11:02	16:01	4:58	LINE CLEAR AVAILED
281	20-Feb-19	TUMKUR	220	KB CROSS 220kv- NELAMANGALA	KBCROSS_220	11:06	17:35	6:28	LINE CLEAR AVAILED
282	20-Feb-19	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	MRSMG_220	11:06	15:59	4:52	LINE CLEAR AVAILED
283	20-Feb-19	TUMKUR	110	KB CROSS 220kv- NELAMANGALA	KBCROSS_220	11:02	16:16	5:14	LINE CLEAR AVAILED
284	20-Feb-19	TUMKUR	110	KB CROSS 220kv- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	11:01	17:17	6:15	LINE CLEAR AVAILED
285	20-Feb-19	TUMKUR	110	TR-1 & TR-2(HV SIDE)	KBCROSS_220	11:03	16:32	5:28	LINE CLEAR AVAILED
286	20-Feb-19	TUMKUR	110	TR-1 & TR-2(LV SIDE)	KBCROSS_220	11:02	16:13	5:10	LINE CLEAR AVAILED
287	20-Feb-19	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	11:01	16:38	5:37	LINE CLEAR AVAILED
288	20-Feb-19	TUMKUR	66	TR-1 & TR-2	BEGUR_220	7:42	7:46	0:04	HAND TRIPPED
289	20-Feb-19	TUMKUR	66	TR-2	CHANNAGIRI_66	8:03	8:09	0:06	TRANSFORMER FAULT
290	20-Feb-19	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHLI)	CHANNAGIRI_66	11:27	11:32	0:04	HAND TRIPPED
291	20-Feb-19	TUMKUR	66	DYAVARANAHALI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:06	17:38	9:31	LINE CLEAR AVAILED
292	20-Feb-19	TUMKUR	66	TR-2	GUTTUR_66	8:20	8:30	0:10	TRANSFORMER FAULT
293	20-Feb-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	3:25	3:41	0:16	HAND TRIPPED
294	20-Feb-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	8:58	9:07	0:08	HAND TRIPPED
295	20-Feb-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	3:23	3:39	0:16	HAND TRIPPED
296	20-Feb-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	8:21	9:01	0:40	LINE FAULT
297	20-Feb-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	3:23	3:39	0:16	HAND TRIPPED
298	20-Feb-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	3:22	3:38	0:16	HAND TRIPPED
299	20-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	19:07	19:26	0:18	LINE FAULT
300	20-Feb-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	22:07	22:24	0:16	LINE FAULT
301	20-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:03	0:13	0:09	LINE FAULT
302	20-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	22:59	23:09	0:10	LINE FAULT
303	20-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	22:03	22:10	0:06	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
304	20-Feb-19	TUMKUR	66	TR-2	MALEBENNUR_66	15:09	15:33	0:23	LINE CLEAR AVAILED
305	20-Feb-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	4:34	6:33	1:58	LINE CLEAR AVAILED
306	20-Feb-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	10:13	10:33	0:20	HAND TRIPPED
307	20-Feb-19	TUMKUR	66	TR-2	RAMPURA_66	11:02	11:51	0:48	LINE CLEAR AVAILED
308	20-Feb-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	8:58	9:09	0:11	MAIN SUPPLY FAILURE
309	20-Feb-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	8:58	9:09	0:11	MAIN SUPPLY FAILURE
310	21-Feb-19	BAGALKOT	110	ATHANI220-TAUSHI	TAUSHI_110	7:02	7:11	0:09	LINE FAULT
311	21-Feb-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	11:36	15:56	4:20	LINE CLEAR AVAILED
312	21-Feb-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	0:00	16:17	16:17	LINE CLEAR AVAILED
313	21-Feb-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	16:50	23:59	7:09	LINE FAULT
314	21-Feb-19	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110	2:53	12:00	9:07	LINE FAULT
315	21-Feb-19	BAGALKOT	110	BHUTANAL-TIKOTA	TIKOTA_110	15:00	16:34	1:34	LINE CLEAR AVAILED
316	21-Feb-19	BAGALKOT	110	110/11KV,HV-1	BILAGI_110	10:30	11:20	0:50	LINE CLEAR AVAILED
317	21-Feb-19	BAGALKOT	110	BHUTANAL-TORVI(BJCTY)	TORVI_110,TIKOTA_110&TAKKALAKI_110	15:49	16:18	0:29	LINE CLEAR AVAILED
318	21-Feb-19	BAGALKOT	110	110/11KV,HV-2	GUTTAL_110	10:39	11:51	1:12	LINE CLEAR AVAILED
319	21-Feb-19	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	14:35	19:30	4:55	LINE CLEAR AVAILED
320	21-Feb-19	BAGALKOT	110	110/11KV,HV2	BEDI_110	12:28	13:31	1:03	LINE CLEAR AVAILED
321	21-Feb-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	16:50	16:52	0:02	TRANSFORMER FAULT
322	21-Feb-19	BAGALKOT	110	110/11KV, HV1	YELLAPARHATTI_110	12:12	12:21	0:09	LINE CLEAR AVAILED
323	21-Feb-19	BAGALKOT	110	VAJRAMATTI220-MANTUR2	MANTUR_110	12:23	14:38	2:15	LINE CLEAR AVAILED
324	21-Feb-19	BAGALKOT	110	BELGAUM220-VADAGOAN	VADAGOAN_110	14:55	19:20	4:25	LINE CLEAR AVAILED
325	21-Feb-19	BAGALKOT	110	RANNABELAGALI-UTTUR	UTTUR_110	12:07	23:59	11:52	LINE CLEAR AVAILED
326	21-Feb-19	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	12:46	16:34	3:48	LINE CLEAR AVAILED
327	21-Feb-19	BAGALKOT	110	110/33KV, HV3	TILUVALI_110, KALKERI_33	10:44	15:45	5:01	LINE CLEAR AVAILED
328	21-Feb-19	BAGALKOT	110	110/11KV, HV1	TIKOTA_110	18:35	18:52	0:17	LINE CLEAR AVAILED
329	21-Feb-19	BAGALKOT	110	110/33KV, HV3	TARIHAL_110, DHUMMAWAD_33	7:23	17:19	9:56	LINE CLEAR AVAILED
330	21-Feb-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	9:10	18:54	9:44	LINE CLEAR AVAILED
331	21-Feb-19	BAGALKOT	110	RON-GAJENDRAGAD1&2	GAJENDRAGAD_110	3:40	12:28	8:48	LINE CLEAR AVAILED
332	21-Feb-19	BAGALKOT	110	GAMESHA-RON	RON_110	3:40	4:05	0:25	LINE CLEAR AVAILED
333	21-Feb-19	BAGALKOT	110	RON-HIREHAL	RON_110	12:09	12:10	0:01	HAND TRIPPED
334	21-Feb-19	BAGALKOT	110	NAREGAL-RON	RON_110	11:56	12:06	0:10	HAND TRIPPED
335	21-Feb-19	BAGALKOT	110	110/11KV, HV1	MAREGUDDI_110	8:06	14:08	6:02	LINE CLEAR AVAILED
336	21-Feb-19	BAGALKOT	110	KONNUR-ANANTPUR SOLAR	KONNUR_110	0:00	4:30	4:30	LINE CLEAR AVAILED
337	21-Feb-19	BANGALORE	66	D CROSS - DB PURA 220	D CROSS	17:34	18:24	0:50	LINE CLEAR AVAILED
338	21-Feb-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	8:15	8:32	0:17	LINE FAULT
339	21-Feb-19	BANGALORE	66	HV2	TEMAGONDALU	7:18	7:40	0:21	TRANSFORMER FAULT
340	21-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	18:07	18:24	0:17	LINE FAULT
341	21-Feb-19	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	18:25	18:35	0:09	LINE FAULT
342	21-Feb-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	18:48	19:04	0:16	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
343	21-Feb-19	GULBARGA	220	HV1	KUSTAGI_220	11:33	11:58	0:25	TRANSFORMER FAULT
344	21-Feb-19	GULBARGA	110	HV1	SIRWAR_110	6:45	7:05	0:20	TRANSFORMER FAULT
345	21-Feb-19	GULBARGA	110	HV2	RAICHUR_220	10:52	12:19	1:27	LINE CLEAR AVAILED
346	21-Feb-19	GULBARGA	110	MALLAT-BYAGAWAT	MALLAT_220	5:46	5:51	0:05	LINE FAULT
347	21-Feb-19	GULBARGA	110	HV2	ALIPUR_220	13:49	13:56	0:07	LINE CLEAR AVAILED
348	21-Feb-19	GULBARGA	110	KAVITAL-GAMESHA IPP	KAVITAL_110	10:30	18:00	7:30	LINE CLEAR AVAILED
349	21-Feb-19	GULBARGA	110	HV1	SIRWAR_110	18:25	18:35	0:10	TRANSFORMER FAULT
350	21-Feb-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	12:15	12:15	LINE FAULT
351	21-Feb-19	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	9:14	18:10	8:56	LINE CLEAR AVAILED
352	21-Feb-19	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	9:14	23:59	14:45	LINE CLEAR AVAILED
353	21-Feb-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	10:12	18:18	8:06	LINE CLEAR AVAILED
354	21-Feb-19	HASSAN	220	MRSSHM-SHARAVATHY	MRSMSG_220	11:03	13:33	2:30	LINE CLEAR AVAILED
355	21-Feb-19	HASSAN	220	HV2	MSEZ_220	9:08	18:36	9:28	LINE CLEAR AVAILED
356	21-Feb-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	9:15	18:09	8:54	NFBC ISSUED
357	21-Feb-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	9:15	23:59	14:44	NFBC ISSUED
358	21-Feb-19	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	5:33	8:02	2:29	NFBC ISSUED
359	21-Feb-19	HASSAN	220	HV1	SHIRALKOPPA_220	8:02	11:20	3:18	LINE CLEAR AVAILED
360	21-Feb-19	HASSAN	220	HV2	SHIRALKOPPA_220	11:22	14:27	3:05	LINE CLEAR AVAILED
361	21-Feb-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	10:12	18:18	8:06	NFBC ISSUED
362	21-Feb-19	HASSAN	110	LV2	MSEZ	9:08	18:38	9:30	LINE CLEAR AVAILED
363	21-Feb-19	HASSAN	110	LV1	SHIRALKOPPA_220	8:02	11:21	3:19	LINE CLEAR AVAILED
364	21-Feb-19	HASSAN	110	LV2	SHIRALKOPPA_220	11:22	14:27	3:05	LINE CLEAR AVAILED
365	21-Feb-19	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	8:01	11:25	3:24	LINE CLEAR AVAILED
366	21-Feb-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:05	14:30	3:25	LINE CLEAR AVAILED
367	21-Feb-19	HASSAN	110	HV3	BANTWAL_110	10:07	12:15	2:08	LINE CLEAR AVAILED
368	21-Feb-19	HASSAN	110	HV1	HOSANGADI_110	10:24	14:13	3:49	LINE CLEAR AVAILED
369	21-Feb-19	HASSAN	110	SAGARA-SORABA	SAGARA_110	8:07	8:14	0:07	HAND TRIPPED
370	21-Feb-19	HASSAN	110	SAGARA-SORABA	SAGARA_110	18:14	18:24	0:10	HAND TRIPPED
371	21-Feb-19	HASSAN	110	SORABA-SHR220	SORABA_110	8:00	8:15	0:15	HAND TRIPPED
372	21-Feb-19	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	9:04	18:26	9:22	LINE CLEAR AVAILED
373	21-Feb-19	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	9:04	18:29	9:25	LINE CLEAR AVAILED
374	21-Feb-19	HASSAN	66	HASSN22-HN PURA	HASSAN_220	11:07	12:52	1:45	LINE CLEAR AVAILED
375	21-Feb-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:35	17:38	10:03	MAIN SUPPLY FAILURE
376	21-Feb-19	HASSAN	66	HV2	BELUR_66	15:40	15:49	0:09	TRANSFORMER FAULT
377	21-Feb-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	6:25	6:36	0:11	LINE FAULT
378	21-Feb-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:35	15:39	0:04	LINE FAULT
379	21-Feb-19	HASSAN	66	HV1	BYACHANAHALLI_66	11:45	11:55	0:10	TRANSFORMER FAULT
380	21-Feb-19	HASSAN	66	HV1	BYACHANAHALLI_66	21:50	22:00	0:10	HAND TRIPPED
381	21-Feb-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:31	17:35	10:04	LINE CLEAR AVAILED
382	21-Feb-19	HASSAN	66	HV1	DODDAKADANUR_66	16:13	16:23	0:10	TRANSFORMER FAULT
383	21-Feb-19	HASSAN	66	GORUR-ARAKALGUD	GORUR_66	9:14	18:43	9:29	MAIN SUPPLY FAILURE
384	21-Feb-19	HASSAN	66	GORUR-HASSAN	GORUR_66	9:14	18:28	9:14	MAIN SUPPLY FAILURE
385	21-Feb-19	HASSAN	66	HV1	GORUR_66	9:14	18:43	9:29	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
386	21-Feb-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:50	11:22	0:32	MAIN SUPPLY FAILURE
387	21-Feb-19	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	10:50	12:56	2:06	MAIN SUPPLY FAILURE
388	21-Feb-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	10:40	11:00	0:20	LINE FAULT
389	21-Feb-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	12:05	12:55	0:50	LINE CLEAR AVAILED
390	21-Feb-19	MYSORE	66	BESAGARAHALLI-DUNDANAHALLI	DUNDANAHALLI_66	14:23	18:55	4:32	LINE CLEAR AVAILED
391	21-Feb-19	MYSORE	66	HV1	HOOTAGALLY_220	12:57	13:44	0:47	LINE CLEAR AVAILED
392	21-Feb-19	MYSORE	66	HV1	HOOTAGALLY_220	16:08	16:14	0:05	HAND TRIPPED
393	21-Feb-19	MYSORE	66	HV2	HOOTAGALLY_220	16:08	16:14	0:05	HAND TRIPPED
394	21-Feb-19	MYSORE	66	HV1	K_HONNALGERE_66	10:21	10:36	0:15	HAND TRIPPED
395	21-Feb-19	MYSORE	66	HV2	K_HONNALGERE_66	10:21	10:37	0:15	HAND TRIPPED
396	21-Feb-19	MYSORE	66	HV1	K_HONNALGERE_66	16:02	16:08	0:05	TRANSFORMER FAULT
397	21-Feb-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 MADDUR_66	10:20	10:35	0:15	LINE FAULT
398	21-Feb-19	MYSORE	66	MANDYA-CHIKKMANDYA	CHIKKA_MANDYA_66 HAMPAPURA(K)_66 BESAGARAHALLI_66 DUNDANAHALLI_66 KOPPA_66	9:35	9:40	0:04	LINE FAULT
399	21-Feb-19	MYSORE	66	HV1	MANDYA_66	10:10	14:41	4:31	LINE CLEAR AVAILED
400	21-Feb-19	MYSORE	66	MANDYA-M2	MALAVALLI_66 HADLI_66	9:12	19:23	10:10	LINE CLEAR AVAILED
401	21-Feb-19	MYSORE	66	HV1	PONNAMPET_66	18:05	18:15	0:10	TRANSFORMER FAULT
402	21-Feb-19	MYSORE	66	HV3	PONNAMPET_66	18:53	19:00	0:06	TRANSFORMER FAULT
403	21-Feb-19	MYSORE	66	HV1	SFCSHIVA_66	16:34	16:41	0:07	HAND TRIPPED
404	21-Feb-19	MYSORE	66	HV5	SFCSHIVA_66	12:49	23:59	11:09	LINE CLEAR AVAILED
405	21-Feb-19	MYSORE	66	TUBINAKERE-MC 2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA(K)_66 BESAGARAHALLI_66 DUNDANAHALLI_66	10:13	10:40	0:26	LINE FAULT
406	21-Feb-19	MYSORE	66	HV2	HDKOTE_66	8:06	9:15	1:08	TRANSFORMER FAULT
407	21-Feb-19	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	MRSMSG_220	13:38	14:19	0:40	LINE CLEAR AVAILED
408	21-Feb-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	13:02	15:11	2:09	LINE CLEAR AVAILED
409	21-Feb-19	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	9:10	13:46	4:35	LINE CLEAR AVAILED
410	21-Feb-19	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	13:47	18:54	5:07	LINE CLEAR AVAILED
411	21-Feb-19	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	13:02	13:21	0:18	LINE CLEAR AVAILED
412	21-Feb-19	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	12:58	13:12	0:13	HAND TRIPPED
413	21-Feb-19	TUMKUR	110	TR-1	TURUVEKERE_110	2:18	2:29	0:10	TRANSFORMER FAULT
414	21-Feb-19	TUMKUR	110	TR-1	GUBBI_110	2:10	2:13	0:03	TRANSFORMER FAULT
415	21-Feb-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:44	15:27	4:42	LINE FAULT
416	21-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	9:27	18:18	8:50	LINE CLEAR AVAILED
417	21-Feb-19	TUMKUR	66	TR-2	BELADARA_66	10:59	11:40	0:40	LINE CLEAR AVAILED
418	21-Feb-19	TUMKUR	66	TR-2	BELADARA_66	17:02	17:59	0:56	LINE CLEAR AVAILED
419	21-Feb-19	TUMKUR	66	TR-2	BENNEHALLI_66	12:24	13:42	1:18	LINE CLEAR AVAILED
420	21-Feb-19	TUMKUR	66	TR-2	DAVANAGERE_66	10:56	11:06	0:10	TRANSFORMER FAULT
421	21-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:44	18:02	9:17	LINE CLEAR AVAILED
422	21-Feb-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	15:09	15:36	0:27	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
423	21-Feb-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	16:52	17:40	0:47	LINE CLEAR AVAILED
424	21-Feb-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	13:58	14:23	0:25	HAND TRIPPED
425	21-Feb-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	4:35	4:50	0:15	HAND TRIPPED
426	21-Feb-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	12:43	12:52	0:08	HAND TRIPPED
427	21-Feb-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	10:11	10:21	0:10	LINE FAULT
428	21-Feb-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	13:37	13:39	0:01	MAIN SUPPLY FAILURE
429	21-Feb-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	12:41	12:44	0:03	HAND TRIPPED
430	21-Feb-19	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	12:41	12:44	0:03	HAND TRIPPED
431	21-Feb-19	TUMKUR	66	TR-1	MYLANAHALLI_66	14:52	16:05	1:13	LINE CLEAR AVAILED
432	21-Feb-19	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	10:04	10:13	0:09	LINE CLEAR AVAILED
433	21-Feb-19	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	11:06	18:05	6:58	LINE CLEAR AVAILED
434	21-Feb-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	10:04	10:19	0:15	LINE CLEAR AVAILED
435	21-Feb-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	10:04	10:19	0:15	LINE CLEAR AVAILED
436	21-Feb-19	TUMKUR	66	CHITRADURGA 66kV- DAVANAGERE2	CHITRADURGA_66	10:04	10:23	0:19	LINE CLEAR AVAILED
437	22-Feb-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	12:45	13:17	0:32	LINE FAULT
438	22-Feb-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	13:48	21:21	7:33	LINE FAULT
439	22-Feb-19	BAGALKOT	110	ATHANI 220-HALIYAL LIS	HALIYAL LIS_110	6:47	7:06	0:19	LINE FAULT
440	22-Feb-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	15:40	15:45	0:05	TRANSFORMER FAULT
441	22-Feb-19	BAGALKOT	220	BAGEWADI-BIJAPUR 1&2	BAGEWADI_220,BIJAPUR_220, INDI_220	15:40	16:30	0:50	MAIN SUPPLY FAILURE
442	22-Feb-19	BAGALKOT	220	BAGEWADI-FAORTUNE FIVE 1&2	BAGEWADI_220	15:41	16:38	0:57	MAIN SUPPLY FAILURE
443	22-Feb-19	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	15:41	17:40	1:59	MAIN SUPPLY FAILURE
444	22-Feb-19	BAGALKOT	220	BAGEWADI-ADPH 2	BAGEWADI_220	15:41	16:55	1:14	MAIN SUPPLY FAILURE
445	22-Feb-19	BAGALKOT	110	BAGEWADI-ACHANUR(MUDEDEBIHAL)	MUDEBIHAL_110	15:40	16:35	0:55	MAIN SUPPLY FAILURE
446	22-Feb-19	BAGALKOT	110	BAGEWADI-MAMADPUR 1&2	MAMADAPUR_110	15:41	16:36	0:55	MAIN SUPPLY FAILURE
447	22-Feb-19	BAGALKOT	110	BAGEWADI-RAMPUR(NIDAGUNDI)	NIDAGUNDI_110	15:41	16:35	0:54	MAIN SUPPLY FAILURE
448	22-Feb-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	12:03	19:31	7:28	LINE CLEAR AVAILED
449	22-Feb-19	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	15:02	15:04	0:02	TRANSFORMER FAULT
450	22-Feb-19	BAGALKOT	110	110/33KV, HV3	TILUVALI_110, KALKERI_33	10:10	13:36	3:26	LINE CLEAR AVAILED
451	22-Feb-19	BAGALKOT	110	110/33KV, HV1	HUBLI_220	10:55	11:11	0:16	LINE CLEAR AVAILED
452	22-Feb-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	14:20	17:53	3:33	LINE CLEAR AVAILED
453	22-Feb-19	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	13:21	13:26	0:05	LINE CLEAR AVAILED
454	22-Feb-19	BAGALKOT	110	SINDAGI-ALMEL	ALMEL_110	15:44	16:44	1:00	MAIN SUPPLY FAILURE
455	22-Feb-19	BAGALKOT	110	SADALAGA-BORGAON	BORGAON_110	13:19	14:27	1:08	LINE CLEAR AVAILED
456	22-Feb-19	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	21:19	23:59	2:40	LINE FAULT
457	22-Feb-19	BAGALKOT	110	MUKARTIHAL-SPV SOLAR	MUKARTIHAL_110	15:45	16:38	0:53	MAIN SUPPLY FAILURE
458	22-Feb-19	BAGALKOT	110	NARENDRA1&2-MRUTHYUNJA NAGAR	MRUTHYUNJAY NAGAR_110	12:16	18:17	6:01	LINE CLEAR AVAILED
459	22-Feb-19	BAGALKOT	110	110/11KV, HV1	MRUTHYUNJAY NAGAR_110	12:16	18:17	6:01	LINE CLEAR AVAILED
460	22-Feb-19	BAGALKOT	110	110/11KV, HV2	MRUTHYUNJAY NAGAR_110	12:16	18:33	6:17	LINE CLEAR AVAILED
461	22-Feb-19	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	12:46	13:14	0:28	LINE FAULT
462	22-Feb-19	BAGALKOT	220	220/110KV, LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	16:59	17:10	0:11	TRANSFORMER FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
463	22-Feb-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	7:44	10:41	2:57	LINE CLEAR AVAILED
464	22-Feb-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	10:42	16:09	5:27	LINE CLEAR AVAILED
465	22-Feb-19	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	10:41	12:42	2:01	LINE CLEAR AVAILED
466	22-Feb-19	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	13:43	13:46	0:03	HAND TRIPPED
467	22-Feb-19	BAGALKOT	110	DS SHIVKUMAR SUGARS-HIREBEVANUR	HIREBEVANUR_110	13:17	14:31	1:14	LINE CLEAR AVAILED
468	22-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:39	13:00	0:21	LINE CLEAR AVAILED
469	22-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:41	12:59	0:17	LINE CLEAR AVAILED
470	22-Feb-19	BANGALORE	66	HV1	AGALAKOTE	8:10	9:20	1:10	TRANSFORMER FAULT
471	22-Feb-19	BANGALORE	66	HV2	AGALAKOTE	8:10	9:30	1:20	TRANSFORMER FAULT
472	22-Feb-19	BANGALORE	66	AGALAKOTE - MATHIKERE	MATHIKERE	8:10	9:32	1:22	LINE FAULT
473	22-Feb-19	BANGALORE	66	AGALAKOTE - ANCHEPALYA 220	AGALAKOTE	8:10	9:20	1:10	LINE FAULT
474	22-Feb-19	BANGALORE	66	HV1	AGALAKOTE	9:25	9:29	0:04	LINE CLEAR AVAILED
475	22-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:28	16:32	0:03	LINE FAULT
476	22-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	7:08	7:14	0:06	LINE FAULT
477	22-Feb-19	BANGALORE	66	HV1	HOSKOTE 66	15:52	16:10	0:17	LINE CLEAR AVAILED
478	22-Feb-19	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	15:05	17:37	2:32	LINE FAULT
479	22-Feb-19	BANGALORE	66	HV1	HOSKOTE 220	20:54	21:00	0:05	TRANSFORMER FAULT
480	22-Feb-19	BANGALORE	66	HV1	HOSKOTE 220	22:26	22:30	0:03	TRANSFORMER FAULT
481	22-Feb-19	BANGALORE	66	HV1	HOSKOTE 220	23:40	23:43	0:03	TRANSFORMER FAULT
482	22-Feb-19	BANGALORE	66	HV1	KOLAR 220	6:19	6:30	0:10	TRANSFORMER FAULT
483	22-Feb-19	BANGALORE	66	HV1	KOLAR 220	9:41	9:52	0:10	TRANSFORMER FAULT
484	22-Feb-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:13	13:19	0:06	LINE FAULT
485	22-Feb-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:42	13:57	0:14	LINE FAULT
486	22-Feb-19	BANGALORE	66	HV2	SUGUTUR	18:00	18:06	0:06	LINE CLEAR AVAILED
487	22-Feb-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:05	9:14	0:09	LINE FAULT
488	22-Feb-19	BANGALORE	66	DB PURA 220 - CB PURA 1	TUBUGERE	7:46	7:57	0:11	LINE FAULT
489	22-Feb-19	BANGALORE	66	DB PURA 220 - CB PURA 2	CB PURA I/A, NALLIMARADANAHALLI, CB PURA URBAN	7:46	7:58	0:12	LINE FAULT
490	22-Feb-19	BANGALORE	66	HV1	ABBIGERE	10:47	10:50	0:02	LINE CLEAR AVAILED
491	22-Feb-19	BANGALORE	66	HV2	ABBIGERE	11:59	12:03	0:03	LINE CLEAR AVAILED
492	22-Feb-19	BANGALORE	66	ADUGODI - HAL 2	KC VALLEY, NAL (EHT)	11:09	13:43	2:33	LINE CLEAR AVAILED
493	22-Feb-19	BANGALORE	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), KC VALLEY, NAL (EHT)	13:33	13:38	0:05	LINE CLEAR AVAILED
494	22-Feb-19	BANGALORE	66	AUSTIN TOWN - KORAMANGALA	KORAMANGALA	11:21	13:24	2:02	LINE CLEAR AVAILED
495	22-Feb-19	BANGALORE	66	HV2	BMTC	16:32	17:08	0:35	TRANSFORMER FAULT
496	22-Feb-19	BANGALORE	66	HV2	BTM 4TH PHASE	12:13	14:11	1:58	LINE CLEAR AVAILED
497	22-Feb-19	BANGALORE	66	HV2	KHODAYS 220	9:43	9:46	0:03	LINE CLEAR AVAILED
498	22-Feb-19	BANGALORE	66	HV2	TELECOM LAYOUT	12:36	12:59	0:22	TRANSFORMER FAULT
499	22-Feb-19	BANGALORE	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	11:35	11:50	0:14	LINE FAULT
500	22-Feb-19	BANGALORE	220	HSR LAYOUT 220 - EPIP 220	HSR LAYOUT 220	11:35	11:50	0:14	LINE FAULT
501	22-Feb-19	BANGALORE	220	HSR LAYOUT 220 - NIMHANS 220	NIMHANS 220	11:35	11:50	0:14	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
502	22-Feb-19	BANGALORE	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), KC VALLEY, NAL (EHT)	11:35	12:01	0:25	MAIN SUPPLY FAILURE
503	22-Feb-19	BANGALORE	66	NIMHANS 220 - JAYADEVA	JAYADEVA	11:35	12:02	0:26	MAIN SUPPLY FAILURE
504	22-Feb-19	BANGALORE	66	NIMHANS 220 - JAYANAGARA	JAYANAGARA, PADMANABHANAGARA	11:35	12:01	0:25	MAIN SUPPLY FAILURE
505	22-Feb-19	BANGALORE	220	NIMHANS 220 - EDC 220	EDC 220	11:35	12:00	0:24	MAIN SUPPLY FAILURE
506	22-Feb-19	BANGALORE	66	EDC 220 - BMTC	BMTC	11:35	12:05	0:29	MAIN SUPPLY FAILURE
507	22-Feb-19	BANGALORE	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	11:35	12:03	0:27	MAIN SUPPLY FAILURE
508	22-Feb-19	BANGALORE	66	HV1	TK HALLI 220	11:01	11:07	0:06	TRANSFORMER FAULT
509	22-Feb-19	BANGALORE	66	HV1	TK HALLI 220	11:09	11:16	0:07	TRANSFORMER FAULT
510	22-Feb-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	12:45	12:57	0:11	LINE FAULT
511	22-Feb-19	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	22:42	22:51	0:09	LOAD CHANGEOVER
512	22-Feb-19	BANGALORE	66	HV1	RBI	12:22	12:30	0:08	LINE CLEAR AVAILED
513	22-Feb-19	GULBARGA	220	ITTAGI-ESPLSLR_IPP	ITTAGI_220	19:30	19:59	0:29	HAND TRIPPED
514	22-Feb-19	GULBARGA	110	HV1	SIRWAR_110	6:28	6:34	0:06	TRANSFORMER FAULT
515	22-Feb-19	GULBARGA	110	HV2	RAICHUR_220	14:57	15:03	0:06	TRANSFORMER FAULT
516	22-Feb-19	GULBARGA	110	KAVITAL-GMSH	KAVITAL_110	14:32	14:37	0:05	LINE CLEAR AVAILED
517	22-Feb-19	GULBARGA	110	HV1	KOLHAR_110	16:30	17:16	0:46	LINE CLEAR AVAILED
518	22-Feb-19	GULBARGA	110	PDHALLI-CLEANSOLAR_IPP	PD_HALLI_110	20:41	20:51	0:10	LINE FAULT
519	22-Feb-19	GULBARGA	110	WADAGERA-CLEANSOLAR_IPP	WADAGERA_110	22:48	23:59	1:11	LINE CLEAR AVAILED
520	22-Feb-19	GULBARGA	110	WADAGERA-CLEANSOLAR_IPP	WADAGERA_110	0:00	2:40	2:40	LINE CLEAR AVAILED
521	22-Feb-19	GULBARGA	110	MALLAT-BYAGWAT2	MADALAPURA_110	2:04	2:25	0:21	LINE FAULT
522	22-Feb-19	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	4:05	4:20	0:15	LINE FAULT
523	22-Feb-19	GULBARGA	66	HV1	ITTAGI_220	13:15	13:25	0:10	TRANSFORMER FAULT
524	22-Feb-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	13:33	16:49	3:16	LINE FAULT
525	22-Feb-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	11:39	18:39	7:00	LINE CLEAR AVAILED
526	22-Feb-19	HASSAN	220	HV2	HOLENARASIPURA_220	13:33	14:46	1:13	TRANSFORMER FAULT
527	22-Feb-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	0:00	14:28	14:28	NFBC ISSUED
528	22-Feb-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	8:28	14:28	6:00	NFBC ISSUED
529	22-Feb-19	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	8:29	14:28	5:59	LINE CLEAR AVAILED
530	22-Feb-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	0:00	14:28	14:28	LINE CLEAR AVAILED
531	22-Feb-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	11:39	18:39	7:00	LINE CLEAR AVAILED
532	22-Feb-19	HASSAN	220	HV2	MSEZ_220	11:33	11:40	0:07	HAND TRIPPED
533	22-Feb-19	HASSAN	220	HV2	MSEZ_220	17:50	18:43	0:53	LINE CLEAR AVAILED
534	22-Feb-19	HASSAN	110	LV2	MSEZ_220	11:33	11:40	0:07	HAND TRIPPED
535	22-Feb-19	HASSAN	110	LV2	MSEZ_220	17:50	18:43	0:53	LINE CLEAR AVAILED
536	22-Feb-19	HASSAN	110	HV3	BANTWAL_110	4:54	5:05	0:11	TRANSFORMER FAULT
537	22-Feb-19	HASSAN	110	HV3	BANTWAL_110	5:40	5:53	0:13	TRANSFORMER FAULT
538	22-Feb-19	HASSAN	110	HV1	HOSANGADI_110	11:32	12:56	1:24	LINE CLEAR AVAILED
539	22-Feb-19	HASSAN	110	HV1	KADUR_220	11:05	13:29	2:24	LINE CLEAR AVAILED
540	22-Feb-19	HASSAN	110	HV2	KADUR_220	11:05	13:29	2:24	LINE CLEAR AVAILED
541	22-Feb-19	HASSAN	110	KITTADA-BLGAVE	KITTADAHALLI_110	12:31	13:47	1:16	LINE CLEAR AVAILED
542	22-Feb-19	HASSAN	110	HV1	KITTADAHALLI_110	12:31	13:47	1:16	LINE CLEAR AVAILED
543	22-Feb-19	HASSAN	66	Lv2	HOLENARASIPURA_220	13:33	14:46	1:13	TRANSFORMER FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
544	22-Feb-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	1:59	2:07	0:08	LINE FAULT
545	22-Feb-19	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	18:10	18:22	0:12	LINE FAULT
546	22-Feb-19	HASSAN	66	HV2	BELUR_66	12:12	12:23	0:11	TRANSFORMER FAULT
547	22-Feb-19	HASSAN	66	HV1	DODDAKADANUR_66	18:12	18:25	0:13	MAIN SUPPLY FAILURE
548	22-Feb-19	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	1:59	2:08	0:09	MAIN SUPPLY FAILURE
549	22-Feb-19	HASSAN	66	HV1	GENDEHALLY_66	11:38	12:11	0:33	LINE CLEAR AVAILED
550	22-Feb-19	HASSAN	66	HV1	HARIHARAPURA_66	13:33	13:54	0:21	MAIN SUPPLY FAILURE
551	22-Feb-19	MYSORE	66	HV1	ELAVALA_66	10:00	17:34	7:34	LINE CLEAR AVAILED
552	22-Feb-19	MYSORE	66	HV2	ELAVALA_66	10:00	23:59	13:59	LINE CLEAR AVAILED
553	22-Feb-19	MYSORE	66	HV4	KUSHALNAGARA_220	20:29	20:30	0:01	HAND TRIPPED
554	22-Feb-19	MYSORE	66	BYLUKUPPE-KUSHALANAGARA 220	BYLUKUPPE_66	15:32	17:50	2:17	LINE CLEAR AVAILED
555	22-Feb-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66 GAVADAGERE_66	10:17	16:17	6:00	LINE CLEAR AVAILED
556	22-Feb-19	MYSORE	66	SUTTUR-DEVNUR(N'GUD)	SUTTUR_66	13:32	13:41	0:08	HAND TRIPPED
557	22-Feb-19	MYSORE	66	HV2	CHANDAKAVADI_66	9:00	9:20	0:20	TRANSFORMER FAULT
558	22-Feb-19	MYSORE	66	HV2	CHANDAKAVADI_66	14:01	14:24	0:22	TRANSFORMER FAULT
559	22-Feb-19	MYSORE	66	HV2	NAGAMANGALA_66	17:02	18:10	1:07	LINE CLEAR AVAILED
560	22-Feb-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	0:02	0:14	0:11	HAND TRIPPED
561	22-Feb-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	21:05	21:18	0:12	HAND TRIPPED
562	22-Feb-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	13:15	13:57	0:41	LINE CLEAR AVAILED
563	22-Feb-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	13:15	13:57	0:41	LINE FAULT
564	22-Feb-19	TUMKUR	220	TR-1(HV1 SIDE)	THALLAKK_220	13:15	13:57	0:41	TRANSFORMER FAULT
565	22-Feb-19	TUMKUR	220	TR-1(HV1 SIDE)	THALLAKK_220	14:55	15:15	0:19	TRANSFORMER FAULT
566	22-Feb-19	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	13:15	13:57	0:41	HAND TRIPPED
567	22-Feb-19	TUMKUR	110	TR-1	GUBBI_110	18:40	19:07	0:27	LINE CLEAR AVAILED
568	22-Feb-19	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	14:55	15:17	0:22	TRANSFORMER FAULT
569	22-Feb-19	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	6:37	8:28	1:50	LINE CLEAR AVAILED
570	22-Feb-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	13:15	13:57	0:41	LINE FAULT
571	22-Feb-19	TUMKUR	66	TR-2	BENKIKERE_66	14:01	14:03	0:02	TRANSFORMER FAULT
572	22-Feb-19	TUMKUR	66	CHITRADURGA 220kV- SUZLON 1	SUZLON1_IPP_66, SUZLON2_IPP_66	1:01	1:13	0:12	LINE FAULT
573	22-Feb-19	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	13:07	13:29	0:21	LINE FAULT
574	22-Feb-19	TUMKUR	66	TR-2	HARAPPANAHALLI_66	15:04	19:48	4:43	LINE CLEAR AVAILED
575	22-Feb-19	TUMKUR	66	TR-1	HULIYURDURGA_66	18:08	18:24	0:16	TRANSFORMER FAULT
576	22-Feb-19	TUMKUR	66	TR-1	IDHALLY_66	18:02	18:24	0:22	LINE CLEAR AVAILED
577	22-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	4:20	4:25	0:04	LINE FAULT
578	22-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:55	15:10	0:15	LINE FAULT
579	22-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	20:08	20:14	0:05	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
580	22-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	22:57	22:59	0:01	LINE FAULT
581	22-Feb-19	TUMKUR	66	NEELAGUNDA 220KV-HARAPPANAHALLI	HARAPPANAHALLI_66	18:52	19:05	0:12	LINE FAULT
582	23-Feb-19	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	0:00	16:52	16:52	LINE CLEAR AVAILED
583	23-Feb-19	BAGALKOT	220	RAVIURJA1-ATHANI	ATHANI_220	7:28	14:30	7:02	LINE FAULT
584	23-Feb-19	BAGALKOT	220	220/110KV,LV1	ATHANI_220	13:28	14:16	0:48	LINE CLEAR AVAILED
585	23-Feb-19	BAGALKOT	220	220/110KV,HV2&LV2	ATHANI_220	15:31	17:27	1:56	LINE CLEAR AVAILED
586	23-Feb-19	BAGALKOT	110	BAGALKOT220-NAVANAGAR1	NAVANAGAR(B)_110	11:28	13:18	1:50	LINE CLEAR AVAILED
587	23-Feb-19	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	0:00	11:32	11:32	LINE CLEAR AVAILED
588	23-Feb-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	19:19	23:34	4:15	LINE FAULT
589	23-Feb-19	BAGALKOT	110	110/11KV,HV1	BYADAGI_110	11:06	12:10	1:04	LINE CLEAR AVAILED
590	23-Feb-19	BAGALKOT	110	GHATAPRABHA220-KABBUR(NAGAR MUNAVALLI)	KABBUR(NAGAR MUNAVALLI)_110	12:30	13:20	0:50	LINE CLEAR AVAILED
591	23-Feb-19	BAGALKOT	110	GHATAPRABHA220-SHIRAGAON	SHIRAGAON_110	14:25	15:28	1:03	LINE CLEAR AVAILED
592	23-Feb-19	BAGALKOT	110	110/11KV,HV1	HATTARAGI_110	11:43	14:39	2:56	LINE CLEAR AVAILED
593	23-Feb-19	BAGALKOT	110	110/11KV,HV2	HATTARAGI_110	10:08	14:59	4:51	LINE CLEAR AVAILED
594	23-Feb-19	BAGALKOT	110	HATTARAGI-DADDI	DADDI_110	11:02	15:23	4:21	LINE CLEAR AVAILED
595	23-Feb-19	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	8:39	18:34	9:55	LINE CLEAR AVAILED
596	23-Feb-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI 33KV	13:58	14:10	0:12	TRANSFORMER FAULT
597	23-Feb-19	BAGALKOT	110	110/33KV,HV3	TARIHAL_110,DUMMAWAD 33KV	7:55	10:09	2:14	LINE CLEAR AVAILED
598	23-Feb-19	BAGALKOT	110	110/33KV,HV3	TARIHAL_110,DUMMAWAD 33KV	12:57	12:59	0:02	LINE CLEAR AVAILED
599	23-Feb-19	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,HEBBAL 33KV,KANAGALA 33KV	11:04	11:20	0:16	LINE CLEAR AVAILED
600	23-Feb-19	BAGALKOT	220	SIRSI 220-HUBLI1	SIRSI_220	15:30	18:40	3:10	LINE FAULT
601	23-Feb-19	BAGALKOT	220	NARENDRA-BELGAUM1	NARENDRA_220	19:19	22:10	2:51	LINE FAULT
602	23-Feb-19	BAGALKOT	110	RAMANKOPPA-MUNDAGOD	MUNDAGOD_110	14:21	14:24	0:03	LINE CLEAR AVAILED
603	23-Feb-19	BAGALKOT	110	110/11KV,LV3	MAHALINGAPUR_220	17:01	17:25	0:24	TRANSFORMER FAULT
604	23-Feb-19	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	12:55	14:38	1:43	LINE CLEAR AVAILED
605	23-Feb-19	BANGALORE	66	HV1	CHAKAVELU	6:27	7:00	0:32	TRANSFORMER FAULT
606	23-Feb-19	BANGALORE	220	DABUSPET 220 - KADUR 220	DABUSPET 220	18:23	19:47	1:24	LINE CLEAR AVAILED
607	23-Feb-19	BANGALORE	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	18:11	19:47	1:35	MAIN SUPPLY FAILURE
608	23-Feb-19	BANGALORE	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	18:23	19:47	1:24	MAIN SUPPLY FAILURE
609	23-Feb-19	BANGALORE	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	18:23	19:47	1:24	MAIN SUPPLY FAILURE
610	23-Feb-19	BANGALORE	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	18:23	19:47	1:24	MAIN SUPPLY FAILURE
611	23-Feb-19	BANGALORE	66	HV1	DABUSPET 220	18:23	19:55	1:32	MAIN SUPPLY FAILURE
612	23-Feb-19	BANGALORE	66	HV2	DABUSPET 220	18:23	19:55	1:32	MAIN SUPPLY FAILURE
613	23-Feb-19	BANGALORE	66	DB PURA 220 - DG1	AIR (EHT)	9:33	10:50	1:16	LINE FAULT
614	23-Feb-19	BANGALORE	66	D PALYA - GOWRIBIDANUR 220	D PALYA	13:52	14:16	0:24	LINE FAULT
615	23-Feb-19	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI, AVANI, MULBAGAL	6:02	6:08	0:06	LINE FAULT
616	23-Feb-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:18	5:25	0:07	LINE FAULT
617	23-Feb-19	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:02	10:10	0:08	LOAD CHANGEVER
618	23-Feb-19	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	8:10	8:14	0:04	LOAD CHANGEVER

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
619	23-Feb-19	BANGALORE	66	HV2	BG ROAD	9:57	9:58	0:01	LINE CLEAR AVAILED
620	23-Feb-19	BANGALORE	66	HV2	BRIGADE METROPOLIS	13:46	14:23	0:37	LINE CLEAR AVAILED
621	23-Feb-19	BANGALORE	66	HV1	HEBBAL 220	13:03	14:09	1:05	LINE CLEAR AVAILED
622	23-Feb-19	BANGALORE	66	HV2	HEBBAL 220	14:21	15:19	0:57	LINE CLEAR AVAILED
623	23-Feb-19	BANGALORE	66	HV2	ISRO LAYOUT	11:15	11:48	0:33	TRANSFORMER FAULT
624	23-Feb-19	BANGALORE	66	KADUGODI - ARMY WELFARE ORGANIZATION	ARMY WELFARE ORGANIZATION, ALUMBIC GLASS (EHT), KONDASPURA	12:29	12:34	0:05	LINE CLEAR AVAILED
625	23-Feb-19	BANGALORE	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	15:09	15:16	0:07	LINE FAULT
626	23-Feb-19	BANGALORE	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	15:09	15:13	0:04	LINE FAULT
627	23-Feb-19	BANGALORE	66	HV5	NRS 220	15:09	15:13	0:04	TRANSFORMER FAULT
628	23-Feb-19	BANGALORE	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	15:09	15:13	0:04	LINE FAULT
629	23-Feb-19	BANGALORE	66	HV2	POTTERY ROAD	11:26	14:26	2:59	LINE CLEAR AVAILED
630	23-Feb-19	BANGALORE	66	POTTERY ROAD - HOODY 220	POTTERY ROAD	11:26	12:00	0:33	LINE CLEAR AVAILED
631	23-Feb-19	BANGALORE	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	8:35	9:10	0:35	LOAD CHANGE OVER
632	23-Feb-19	BANGALORE	66	AREHALLI - BANASHANKARI	AREHALLI	17:45	17:50	0:05	LOAD CHANGE OVER
633	23-Feb-19	BANGALORE	66	SRS PEENYA 220 - DG 2	ALUR	7:51	8:14	0:23	LINE FAULT
634	23-Feb-19	BANGALORE	66	ALUR - NELAMANGALA 66	ALUR	10:02	10:10	0:08	LOAD CHANGE OVER
635	23-Feb-19	BANGALORE	66	HV3	YARANADANAHALLI 220	8:32	8:48	0:16	TRANSFORMER FAULT
636	23-Feb-19	BANGALORE	66	ARMY WELFARE ORGANIZATION - KONDASPURA	KONDASPURA	11:25	13:50	2:25	LINE CLEAR AVAILED
637	23-Feb-19	BANGALORE	66	ARMY WELFARE ORGANIZATION - KADUGODI	ARMY WELFARE ORGANIZATION	11:25	12:34	1:09	LINE CLEAR AVAILED
638	23-Feb-19	GULBARGA	220	KAPNOOR-SHAHAPUR1	KAPNOOR_220	11:32	14:50	3:18	LINE CLEAR AVAILED
639	23-Feb-19	GULBARGA	220	KAPNOOR-SHAHABAD	KAPNOOR_220	11:32	14:55	3:23	LINE CLEAR AVAILED
640	23-Feb-19	GULBARGA	110	WADAGERA-CLEANSOLAR_IPP	WADAGERA_110	0:00	2:40	2:40	LINE CLEAR AVAILED
641	23-Feb-19	GULBARGA	110	HV1	SIRWAR_110	6:05	6:10	0:05	TRANSFORMER FAULT
642	23-Feb-19	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	10:05	14:49	4:44	LINE CLEAR AVAILED
643	23-Feb-19	GULBARGA	110	LADHA-RNWSLR	RNWSLR_110	21:08	23:59	2:51	LINE CLEAR AVAILED
644	23-Feb-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	11:47	11:51	0:04	LINE FAULT
645	23-Feb-19	GULBARGA	110	HV3	BEVOOR_110	17:44	18:10	0:26	TRANSFORMER FAULT
646	23-Feb-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	9:43	16:57	7:14	LINE CLEAR AVAILED
647	23-Feb-19	HASSAN	220	GER SOPATA LGUPA2	gerusoppa_gen	10:22	16:30	6:08	NFBC ISSUED
648	23-Feb-19	HASSAN	220	KADUR-DABUSET	KADUR_220	18:29	19:47	1:18	LINE CLEAR AVAILED
649	23-Feb-19	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	12:18	16:28	4:10	LINE FAULT
650	23-Feb-19	HASSAN	220	KEMAR-UPCL2	KEMAR_220	9:43	16:54	7:11	LINE CLEAR AVAILED
651	23-Feb-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:55	12:44	0:49	LINE CLEAR AVAILED
652	23-Feb-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:23	16:29	6:06	LINE CLEAR AVAILED
653	23-Feb-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	12:13	12:22	0:09	NFBC ISSUED
654	23-Feb-19	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	10:39	11:46	1:07	LINE CLEAR AVAILED
655	23-Feb-19	HASSAN	110	HV2	KADUR_220	10:32	12:29	1:57	LINE CLEAR AVAILED
656	23-Feb-19	HASSAN	110	HV4	PUTTUR_110	10:35	12:25	1:50	LINE CLEAR AVAILED
657	23-Feb-19	HASSAN	110	AJAMPU-KADUR	AJJAMPURA_110	21:57	22:30	0:33	LINE FAULT
658	23-Feb-19	HASSAN	110	AJAMPU-SHIVANI	AJJAMPURA_110	21:57	23:00	1:03	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
659	23-Feb-19	HASSAN	110	HV1	ARASIKERE_110	10:30	11:01	0:31	LINE CLEAR AVAILED
660	23-Feb-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	2:33	2:57	0:24	LINE CLEAR AVAILED
661	23-Feb-19	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	10:40	11:47	1:07	MAIN SUPPLY FAILURE
662	23-Feb-19	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	10:40	11:47	1:07	MAIN SUPPLY FAILURE
663	23-Feb-19	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:40	11:47	1:07	MAIN SUPPLY FAILURE
664	23-Feb-19	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	13:22	13:58	0:36	LINE CLEAR AVAILED
665	23-Feb-19	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	13:22	13:58	0:36	LINE CLEAR AVAILED
666	23-Feb-19	HASSAN	66	HASSN22-HSN	HASSAN_220	13:22	13:58	0:36	LINE CLEAR AVAILED
667	23-Feb-19	HASSAN	66	HASSN22-CRP1	HASSAN_220	13:22	13:58	0:36	LINE CLEAR AVAILED
668	23-Feb-19	HASSAN	66	HASSN22-CRP2	HASSAN_220	13:22	13:58	0:36	LINE CLEAR AVAILED
669	23-Feb-19	HASSAN	66	HASSN22-HNPURA	HASSAN_220	13:22	13:58	0:36	LINE CLEAR AVAILED
670	23-Feb-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:35	15:50	8:15	LINE CLEAR AVAILED
671	23-Feb-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:20	15:45	8:25	LINE CLEAR AVAILED
672	23-Feb-19	HASSAN	66	HV1	ALDUR_66	18:09	18:24	0:15	TRANSFORMER FAULT
673	23-Feb-19	HASSAN	66	HV2	ARKD_66	13:25	14:50	1:25	MAIN SUPPLY FAILURE
674	23-Feb-19	HASSAN	66	HV2	CHIKMAGALUR_66	10:45	10:50	0:05	HAND TRIPPED
675	23-Feb-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:20	15:47	8:27	LINE CLEAR AVAILED
676	23-Feb-19	HASSAN	66	HV1	GORUR_66	11:20	11:25	0:05	HAND TRIPPED
677	23-Feb-19	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	19:35	19:45	0:10	LINE FAULT
678	23-Feb-19	HASSAN	66	HV1	SATHENAHALLY_66	16:43	17:08	0:25	LINE CLEAR AVAILED
679	23-Feb-19	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPLU_66	12:59	15:18	2:19	LINE CLEAR AVAILED
680	23-Feb-19	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	12:59	15:18	2:19	LINE CLEAR AVAILED
681	23-Feb-19	MYSORE	66	BANNIMANTAP-VIJAYANAGAR	VIJAYANAGRAMYS_66	10:05	16:07	6:01	NFBC ISSUED
682	23-Feb-19	MYSORE	66	BESAGARAHALLI-DUNDANAHALLI	DUNDANAHALLI_66	12:37	23:59	11:21	LINE CLEAR AVAILED
683	23-Feb-19	MYSORE	66	HV1	GARUDANAUKADDA_66	14:21	16:15	1:54	LINE CLEAR AVAILED
684	23-Feb-19	MYSORE	66	HANAGODU-HUNSURU	HANAGODU_66	10:04	18:00	7:55	NFBC ISSUED
685	23-Feb-19	MYSORE	66	HV1	JAKKANAHALLY_66	6:13	6:19	0:06	TRANSFORMER FAULT
686	23-Feb-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66, K_HONNALGERE_66	11:50	12:39	0:48	LINE CLEAR AVAILED
687	23-Feb-19	MYSORE	66	HV2	KMDODDI_66	11:37	11:50	0:12	TRANSFORMER FAULT
688	23-Feb-19	MYSORE	220	HV1	MADHUVANAHALLI_220	11:07	13:44	2:36	LINE CLEAR AVAILED
689	23-Feb-19	MYSORE	220	HV2	MADHUVANAHALLI_220	15:48	17:43	1:55	LINE CLEAR AVAILED
690	23-Feb-19	MYSORE	66	HV1	MADHUVANAHALLI_220	13:50	15:25	1:35	LINE CLEAR AVAILED
691	23-Feb-19	MYSORE	66	HV2	MADHUVANAHALLI_220	12:25	14:10	1:45	LINE CLEAR AVAILED
692	23-Feb-19	MYSORE	66	HV1	MALAVALLI_66	14:14	15:03	0:49	LINE CLEAR AVAILED
693	23-Feb-19	MYSORE	66	MANDYA-CHIKKAMANDYA	CHIKKA_MANDYA_66, HAMPAPURA, KOPPA_66, BESAGARAHALLI_66, DUNDANAHALLI_66	11:37	11:46	0:09	LINE FAULT
694	23-Feb-19	MYSORE	66	HV2	NAGAMANGALA_66	17:12	17:35	0:22	LINE CLEAR AVAILED
695	23-Feb-19	MYSORE	66	HV3	NAGAMANGALA_66	18:25	18:41	0:15	LINE CLEAR AVAILED
696	23-Feb-19	MYSORE	66	HV1	SFCSHIVA_66	11:28	0:00	12:31	LINE CLEAR AVAILED
697	23-Feb-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66, TARIPURA_66	11:43	11:45	0:02	HAND TRIPPED
698	23-Feb-19	MYSORE	66	HV1	SANTHEBACHALLI_66	12:02	16:19	4:17	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
699	23-Feb-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	8:25	9:42	1:17	LINE CLEAR AVAILED
700	23-Feb-19	TUMKUR	220	TR-1(HV SIDE)	THALLAKK_220	1:41	9:36	7:55	LINE CLEAR AVAILED
701	23-Feb-19	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	13:26	13:32	0:06	HAND TRIPPED
702	23-Feb-19	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	1:41	9:48	8:07	LINE CLEAR AVAILED
703	23-Feb-19	TUMKUR	66	TR--1(LV SIDE	THALLAKK_220	1:41	9:38	7:57	LINE CLEAR AVAILED
704	23-Feb-19	TUMKUR	66	TR--1(LV 2SIDE	THALLAKK_220	13:15	13:27	0:12	TRANSFORMER FAULT
705	23-Feb-19	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	13:15	13:42	0:26	LINE FAULT
706	23-Feb-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:00	15:23	5:23	LINE FAULT
707	23-Feb-19	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	7:00	9:31	2:30	LINE CLEAR AVAILED
708	23-Feb-19	TUMKUR	66	TR-2	BEVINAHALLI_66	14:08	14:12	0:03	TRANSFORMER FAULT
709	23-Feb-19	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	15:49	16:18	0:29	LINE FAULT
710	23-Feb-19	TUMKUR	66	TR-2	KORA_66	12:41	14:26	1:45	LINE CLEAR AVAILED
711	23-Feb-19	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	9:44	9:56	0:11	LINE FAULT
712	23-Feb-19	TUMKUR	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	9:56	9:58	0:02	LINE FAULT
713	23-Feb-19	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	HIREMALLANAHOLE_66	9:58	13:58	4:00	MAIN SUPPLY FAILURE
714	23-Feb-19	TUMKUR	66	NAYAKANAHATTI66-THALLAKK	NAYAKANAHATTI_66	7:45	13:54	6:09	MAIN SUPPLY FAILURE
715	23-Feb-19	TUMKUR	66	TR-1((HV SIDE)	NEELAGUNDA_220	8:22	8:28	0:05	TRANSFORMER FAULT
716	23-Feb-19	TUMKUR	66	TR-1 & TR-2	SIRA_66	12:27	12:50	0:22	LINE CLEAR AVAILED
717	23-Feb-19	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	2:31	3:42	1:11	LINE CLEAR AVAILED
718	23-Feb-19	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	6:17	10:15	3:58	LINE CLEAR AVAILED
719	23-Feb-19	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	13:21	13:28	0:06	LINE CLEAR AVAILED
720	23-Feb-19	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	2:31	3:42	1:10	LINE CLEAR AVAILED
721	23-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	19:17	23:55	4:38	LINE FAULT
722	23-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	20:46	20:51	0:04	HAND TRIPPED
723	24-Feb-19	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	7:42	17:56	10:14	TRANSFORMER FAULT
724	24-Feb-19	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110	20:50	21:08	0:18	TRANSFORMER FAULT
725	24-Feb-19	BAGALKOT	220	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	14:07	15:09	1:02	LINE FAULT
726	24-Feb-19	BAGALKOT	110	110/11KV,HV1	HIDIKAL_110	10:20	19:27	9:07	LINE CLEAR AVAILED
727	24-Feb-19	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	10:20	19:21	9:01	LINE CLEAR AVAILED
728	24-Feb-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33	11:07	19:11	8:04	LINE CLEAR AVAILED
729	24-Feb-19	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110,ALAGAWADI_33	11:07	19:12	8:05	LINE CLEAR AVAILED
730	24-Feb-19	BAGALKOT	66	HONNALLI-HARIHAR HOSPET	HARIHAR HOSPET_66	7:38	8:13	0:35	LINE FAULT
731	24-Feb-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HORTI 33KV	15:18	15:22	0:04	TRANSFORMER FAULT
732	24-Feb-19	BAGALKOT	110	110/33KV,HV3	LOKAPUR_110,BATKURKI_33KV,RS KARKHANE_33KV	14:00	14:09	0:09	TRANSFORMER FAULT
733	24-Feb-19	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	2:03	2:08	0:05	TRANSFORMER FAULT
734	24-Feb-19	BANGALORE	66	HV2	AKKURMOLE	18:05	18:10	0:04	TRANSFORMER FAULT
735	24-Feb-19	BANGALORE	66	HV2	AKKURMOLE	18:12	18:14	0:01	TRANSFORMER FAULT
736	24-Feb-19	BANGALORE	66	HV2	AKKURMOLE	20:11	20:14	0:03	TRANSFORMER FAULT
737	24-Feb-19	BANGALORE	66	HV2	AKKURMOLE	20:22	20:25	0:02	TRANSFORMER FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
738	24-Feb-19	BANGALORE	66	ATTIBELE - SARJAPURA 220	ATTIBELE	10:05	10:50	0:45	MAIN SUPPLY FAILURE
739	24-Feb-19	BANGALORE	66	ATTIBELE - SARJAPURA 220	ATTIBELE	20:05	20:15	0:10	MAIN SUPPLY FAILURE
740	24-Feb-19	BANGALORE	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	10:05	10:15	0:10	MAIN SUPPLY FAILURE
741	24-Feb-19	BANGALORE	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	20:32	20:38	0:05	LOAD CHANGEVER
742	24-Feb-19	BANGALORE	66	HV1	D CROSS	1:23	1:37	0:13	TRANSFORMER FAULT
743	24-Feb-19	BANGALORE	66	HV2	DEVANGONDHI	12:29	14:15	1:45	LINE CLEAR AVAILED
744	24-Feb-19	BANGALORE	66	HV1	DEVANGONDHI	18:50	19:00	0:10	TRANSFORMER FAULT
745	24-Feb-19	BANGALORE	66	DB PURA 220 - CB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	9:59	18:48	8:48	LINE CLEAR AVAILED
746	24-Feb-19	BANGALORE	66	DB PURA 220 - CB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	22:00	22:25	0:25	MAIN SUPPLY FAILURE
747	24-Feb-19	BANGALORE	66	DB PURA 220 - CB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	22:36	23:16	0:40	MAIN SUPPLY FAILURE
748	24-Feb-19	BANGALORE	66	DB PURA 220 - CB PURA 1	TUBUGERE	22:00	22:25	0:25	MAIN SUPPLY FAILURE
749	24-Feb-19	BANGALORE	66	DB PURA 220 - CB PURA 1	TUBUGERE	22:36	23:16	0:40	MAIN SUPPLY FAILURE
750	24-Feb-19	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	17:40	18:09	0:28	LOAD CHANGEVER
751	24-Feb-19	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	13:59	14:09	0:10	LOAD CHANGEVER
752	24-Feb-19	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1 & 2	DEVANAHALLI, KUNDANA	17:40	18:09	0:28	LOAD CHANGEVER
753	24-Feb-19	BANGALORE	66	DB PURA 220 - DG 1	AIR(EHT)	17:40	18:09	0:28	LOAD CHANGEVER
754	24-Feb-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	10:17	10:28	0:10	LOAD CHANGEVER
755	24-Feb-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	22:00	22:23	0:23	MAIN SUPPLY FAILURE
756	24-Feb-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	22:36	23:12	0:36	MAIN SUPPLY FAILURE
757	24-Feb-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	10:17	10:27	0:10	LOAD CHANGEVER
758	24-Feb-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	22:00	22:24	0:24	MAIN SUPPLY FAILURE
759	24-Feb-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	22:36	23:11	0:35	MAIN SUPPLY FAILURE
760	24-Feb-19	BANGALORE	220	LV2	DB PURA 220	22:00	22:23	0:23	TRANSFORMER FAULT
761	24-Feb-19	BANGALORE	220	LV2	DB PURA 220	22:36	23:11	0:35	TRANSFORMER FAULT
762	24-Feb-19	BANGALORE	220	MALUR 220 - SARJAPURA	SARJAPURA 220	10:05	10:25	0:20	LINE CLEAR AVAILED
763	24-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	SARJAPURA 220	19:55	19:59	0:04	LOAD CHANGEVER
764	24-Feb-19	BANGALORE	220	HV1	SARJAPURA 220	19:50	20:00	0:10	MAIN SUPPLY FAILURE
765	24-Feb-19	BANGALORE	220	HV2	SARJAPURA 220	19:50	20:00	0:10	MAIN SUPPLY FAILURE
766	24-Feb-19	BANGALORE	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	20:11	20:17	0:05	LOAD CHANGEVER
767	24-Feb-19	BANGALORE	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	10:05	10:18	0:13	MAIN SUPPLY FAILURE
768	24-Feb-19	BANGALORE	66	KOLAR 220 - BANGARPET 1	BANGARPET	10:03	18:56	8:52	LINE CLEAR AVAILED
769	24-Feb-19	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI, AVANI, MULBAGAL	10:03	19:00	8:56	LINE CLEAR AVAILED
770	24-Feb-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI, NARASAPURA	10:03	18:55	8:51	LINE CLEAR AVAILED
771	24-Feb-19	BANGALORE	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	10:03	18:55	8:51	LINE CLEAR AVAILED
772	24-Feb-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:03	18:56	8:53	LINE CLEAR AVAILED
773	24-Feb-19	BANGALORE	66	KOLAR 220 - DALASNUR	MALLASANDRA, DRDO (EHT), DAALSNUR	10:03	18:55	8:52	LINE CLEAR AVAILED
774	24-Feb-19	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:03	18:58	8:55	LINE CLEAR AVAILED
775	24-Feb-19	BANGALORE	220	KOLAR 220 - PGCIL 1	KOLAR 220	11:46	18:52	7:06	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
776	24-Feb-19	BANGALORE	220	KOLAR 220 - PGCIL 2	KOLAR 220	11:46	19:22	7:36	LINE CLEAR AVAILED
777	24-Feb-19	BANGALORE	220	HV2	KOLAR 220	10:04	18:53	8:48	LINE CLEAR AVAILED
778	24-Feb-19	BANGALORE	66	HV1	KYALANUR	10:03	19:20	9:16	LINE CLEAR AVAILED
779	24-Feb-19	BANGALORE	66	HV2	KYALANUR	10:03	19:24	9:20	LINE CLEAR AVAILED
780	24-Feb-19	BANGALORE	66	HV1	LAKKUR	11:04	11:37	0:32	LINE CLEAR AVAILED
781	24-Feb-19	BANGALORE	66	HV1	LAKKUR	11:46	12:26	0:40	LINE CLEAR AVAILED
782	24-Feb-19	BANGALORE	66	HV1	NANGALI	10:03	19:08	9:05	LINE CLEAR AVAILED
783	24-Feb-19	BANGALORE	66	HV2	NANGALI	10:03	19:11	9:08	LINE CLEAR AVAILED
784	24-Feb-19	BANGALORE	66	JANGAMKOTE - VIJAYAPURA	JANGAMKOTE	10:18	10:27	0:09	LOAD CHANGEOR
785	24-Feb-19	BANGALORE	66	JANGAMKOTE - MELUR	JANGAMKOTE	17:50	17:55	0:05	LOAD CHANGEOR
786	24-Feb-19	BANGALORE	66	JANGAMKOTE - VIJAYAPURA	JANGAMKOTE	22:36	23:25	0:49	LOAD CHANGEOR
787	24-Feb-19	BANGALORE	66	HV1	NARASAPURA	10:03	19:16	9:13	LINE CLEAR AVAILED
788	24-Feb-19	BANGALORE	66	HV2	NARASAPURA	10:03	18:59	8:56	LINE CLEAR AVAILED
789	24-Feb-19	BANGALORE	220	MALUR 220 - KOLAR1	MALUR 220	10:13	11:31	1:18	MAIN SUPPLY FAILURE
790	24-Feb-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:11	11:31	1:19	MAIN SUPPLY FAILURE
791	24-Feb-19	BANGALORE	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:13	11:31	1:18	MAIN SUPPLY FAILURE
792	24-Feb-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	10:13	11:31	1:18	MAIN SUPPLY FAILURE
793	24-Feb-19	BANGALORE	66	MALUR 220 - MALUR 66	MALUR 66	10:13	11:31	1:18	MAIN SUPPLY FAILURE
794	24-Feb-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	13:22	14:52	1:30	MAIN SUPPLY FAILURE
795	24-Feb-19	BANGALORE	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:22	14:52	1:30	MAIN SUPPLY FAILURE
796	24-Feb-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	13:22	14:52	1:30	MAIN SUPPLY FAILURE
797	24-Feb-19	BANGALORE	66	MALUR 220 - MALUR 66	MALUR 66	13:22	14:52	1:30	MAIN SUPPLY FAILURE
798	24-Feb-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	19:31	19:48	0:17	MAIN SUPPLY FAILURE
799	24-Feb-19	BANGALORE	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	19:31	19:48	0:17	MAIN SUPPLY FAILURE
800	24-Feb-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT)	19:31	19:47	0:16	MAIN SUPPLY FAILURE
801	24-Feb-19	BANGALORE	66	MALUR 220 - MALUR 66	MALUR 66	19:31	19:43	0:12	MAIN SUPPLY FAILURE
802	24-Feb-19	BANGALORE	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	13:05	13:15	0:10	LOAD CHANGEOR
803	24-Feb-19	BANGALORE	66	YEDUMADU - HANUMANTHNAGAR	YEDUMADU	16:55	17:09	0:14	LOAD CHANGEOR
804	24-Feb-19	BANGALORE	220	HV2	MALUR 220	13:27	14:52	1:25	MAIN SUPPLY FAILURE
805	24-Feb-19	BANGALORE	66	HV2	ABBIGERE	17:51	18:13	0:22	TRANSFORMER FAULT
806	24-Feb-19	BANGALORE	66	HANUMANTHNAGAR - YEDUMADU	YEDUMADU	13:05	13:15	0:10	LOAD CHANGEOR
807	24-Feb-19	BANGALORE	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	16:55	17:09	0:14	LOAD CHANGEOR
808	24-Feb-19	BANGALORE	66	HV2	ISRO LAYOUT	1:34	2:33	0:59	TRANSFORMER FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
809	24-Feb-19	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON (EHT)	7:38	8:12	0:33	LINE FAULT
810	24-Feb-19	BANGALORE	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	5:15	5:25	0:10	LOAD CHANGEOVER
811	24-Feb-19	BANGALORE	66	PLATINUM CITY - SAHAKARINAGAR	PLATINUM CITY	9:05	9:10	0:05	LOAD CHANGEOVER
812	24-Feb-19	BANGALORE	66	HV1	SOLADEVANAHALLI	12:14	12:20	0:05	LINE CLEAR AVAILED
813	24-Feb-19	BANGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	16:50	16:57	0:07	LOAD CHANGEOVER
814	24-Feb-19	BANGALORE	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	11:41	11:51	0:10	LOAD CHANGEOVER
815	24-Feb-19	BANGALORE	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	5:05	5:10	0:05	LOAD CHANGEOVER
816	24-Feb-19	BANGALORE	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	9:03	9:05	0:02	LOAD CHANGEOVER
817	24-Feb-19	BANGALORE	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	11:47	11:50	0:03	LOAD CHANGEOVER
818	24-Feb-19	BANGALORE	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	17:17	17:20	0:03	LOAD CHANGEOVER
819	24-Feb-19	BANGALORE	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	13:22	14:38	1:16	MAIN SUPPLY FAILURE
820	24-Feb-19	BANGALORE	66	HOODY 220 - PRESTIGE SHANTHIKETHAN	PRESTIGE SHANTHIKETHAN	13:22	14:37	1:15	MAIN SUPPLY FAILURE
821	24-Feb-19	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	13:22	14:29	1:07	MAIN SUPPLY FAILURE
822	24-Feb-19	BANGALORE	66	HOODY 220 - ITI	ITI	13:22	14:27	1:05	MAIN SUPPLY FAILURE
823	24-Feb-19	BANGALORE	66	HOODY 220 - HP (EHT)	HP (EHT)	13:22	14:42	1:20	MAIN SUPPLY FAILURE
824	24-Feb-19	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	13:22	14:33	1:11	MAIN SUPPLY FAILURE
825	24-Feb-19	BANGALORE	66	HOODY 220 - HAL 1 & 2	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT), BANASWADI	13:22	14:30	1:08	MAIN SUPPLY FAILURE
826	24-Feb-19	BANGALORE	66	HOODY 220 - GRAPHITE INDIA(EHT)	GRAPHITE INDIA(EHT)	13:22	14:53	1:31	MAIN SUPPLY FAILURE
827	24-Feb-19	BANGALORE	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	13:22	14:43	1:21	MAIN SUPPLY FAILURE
828	24-Feb-19	BANGALORE	66	HV1	HOODY 220	13:22	14:25	1:03	MAIN SUPPLY FAILURE
829	24-Feb-19	BANGALORE	66	HV2	HOODY 220	13:22	14:10	0:48	MAIN SUPPLY FAILURE
830	24-Feb-19	BANGALORE	220	BUS COUPLER	HOODY 220	13:22	13:52	0:30	LINE FAULT
831	24-Feb-19	BANGALORE	220	HOODY 220 - YELAHANKA 220	YELAHANKA 220	13:22	19:38	6:16	LINE FAULT
832	24-Feb-19	BANGALORE	220	HEBBAL 220 - HOODY 220	HEBBAL 220	13:22	14:27	1:05	LINE FAULT
833	24-Feb-19	BANGALORE	66	HEBBAL 220 - IISC	IISC	13:22	13:45	0:23	MAIN SUPPLY FAILURE
834	24-Feb-19	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	13:22	14:27	1:05	MAIN SUPPLY FAILURE
835	24-Feb-19	BANGALORE	66	HEBBAL 220 - C STATION 1 & 2	C STATION	13:22	14:27	1:05	MAIN SUPPLY FAILURE
836	24-Feb-19	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	13:22	14:27	1:05	MAIN SUPPLY FAILURE
837	24-Feb-19	BANGALORE	66	HV1	HEBBAL 220	13:22	14:27	1:05	MAIN SUPPLY FAILURE
838	24-Feb-19	BANGALORE	66	HV2	HEBBAL 220	13:22	14:27	1:05	MAIN SUPPLY FAILURE
839	24-Feb-19	BANGALORE	66	HEBBAL 220 - IISC	IISC	11:25	11:53	0:28	LOAD CHANGEOVER
840	24-Feb-19	BANGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	11:21	11:54	0:33	LOAD CHANGEOVER
841	24-Feb-19	BANGALORE	66	HEBBAL 220 - C STATION 1 & 2	C STATION	11:24	11:53	0:29	LOAD CHANGEOVER
842	24-Feb-19	BANGALORE	66	HEBBAL 220 - BANASWADI	BANASWADI	11:22	11:53	0:30	LOAD CHANGEOVER
843	24-Feb-19	BANGALORE	66	HV1	HEBBAL 220	11:25	11:53	0:28	LOAD CHANGEOVER
844	24-Feb-19	BANGALORE	66	HV2	HEBBAL 220	11:25	11:53	0:28	LOAD CHANGEOVER
845	24-Feb-19	BANGALORE	66	IISC - NRS 220	IISC	18:08	18:13	0:05	LOAD CHANGEOVER
846	24-Feb-19	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	16:46	18:19	1:32	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
847	24-Feb-19	BANGALORE	66	POTTERY ROAD - HEBBAL 220	POTTERY ROAD, ITC (EHT)	18:57	19:10	0:13	LOAD CHANGEOVER
848	24-Feb-19	BANGALORE	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	10:05	10:16	0:11	MAIN SUPPLY FAILURE
849	24-Feb-19	BANGALORE	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK 66	VIKAS TECH PARK 220	19:55	20:03	0:08	LOAD CHANGEOVER
850	24-Feb-19	BANGALORE	220	HOODY 220 - MALUR 220	MALUR 220	13:22	14:20	0:58	MAIN SUPPLY FAILURE
851	24-Feb-19	GULBARGA	110	LADHA-RNWSLR	RNWSLR_110	0:00	1:17	1:17	LINE CLEAR AVAILED
852	24-Feb-19	GULBARGA	110	SINDHNAOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	2:51	2:59	0:08	LINE FAULT
853	24-Feb-19	GULBARGA	110	SINDHNAOOR-MUNIRABAD2	BTPS WATER WORKS,MUKUNDA_110,KAMPLI_110	11:49	12:06	0:17	LINE FAULT
854	24-Feb-19	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110,DEODURGA_110	12:07	22:58	10:51	LINE FAULT
855	24-Feb-19	GULBARGA	66	HV2	CJHALLI_66	12:09	12:41	0:32	LINE CLEAR AVAILED
856	24-Feb-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	9:06	18:49	9:43	LINE CLEAR AVAILED
857	24-Feb-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	12:30	13:04	0:34	LINE FAULT
858	24-Feb-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	13:04	18:00	4:56	LINE CLEAR AVAILED
859	24-Feb-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	18:00	18:44	0:44	LINE CLEAR AVAILED
860	24-Feb-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	18:21	18:48	0:27	LOAD CURTAILMENT
861	24-Feb-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	12:30	17:58	5:28	LINE FAULT
862	24-Feb-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	17:59	18:09	0:10	HAND TRIPPED
863	24-Feb-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	18:09	18:41	0:32	HAND TRIPPED
864	24-Feb-19	HASSAN	110	HV2	ANANDAPURA_110	7:31	8:19	0:48	TRANSFORMER FAULT
865	24-Feb-19	HASSAN	110	HV1	HOSANGADI_110	12:21	21:39	9:18	LINE CLEAR AVAILED
866	24-Feb-19	HASSAN	110	HV1	SAGARA_110	0:08	1:37	1:29	TRANSFORMER FAULT
867	24-Feb-19	HASSAN	110	HV1	SHIVPURA_110	8:18	8:46	0:28	LINE CLEAR AVAILED
868	24-Feb-19	MYSORE	66	DR PETE-MADHUVANAHALLI	MUGUR_66, SANTHEMARAHALLI_66, THAYURU_66, TNARASIPURA_66	6:52	7:09	0:17	LINE FAULT
869	24-Feb-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	16:45	23:59	7:13	LINE CLEAR AVAILED
870	24-Feb-19	MYSORE	66	G UKKADA-METAGALLY	SRIRANGAPATNA_66	6:37	6:48	0:10	LINE FAULT
871	24-Feb-19	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66, SINDHUVALLI_66	14:15	14:24	0:08	LINE FAULT
872	24-Feb-19	MYSORE	66	HANNUR-COWDALLI	BANDALLI_66, COWDALLI_66, MARTAHALLI_66, RAMAPURA_MYS_66	6:59	7:10	0:10	LINE FAULT
873	24-Feb-19	MYSORE	66	KR PET 220-BOOKANKERE	SHEELUNERE_66, GANJIGERE_66, BOOKANAKERE_66, BANANGADI_66, CHINAKURALI_66	11:12	11:18	0:06	LINE FAULT
874	24-Feb-19	MYSORE	66	MANDYA-CHIKKAMANDYA	CHIKKA_MANDYA_66, HAMPAPURA, KOPPA_66, BESAGARAHALLI_66, DUNDANAHALLI_66,	9:40	9:48	0:08	LINE FAULT
875	24-Feb-19	MYSORE	66	HV2	NAGAMANGALA_66	13:44	13:50	0:05	TRANSFORMER FAULT
876	24-Feb-19	MYSORE	66	HV2	SANTHESARAGUR_66	12:04	18:37	6:32	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
877	24-Feb-19	MYSORE	66	MANDYA-TUBINAKERE	MANDYA_66, CHIKKA_MANDYA_66, HAMPAPURA, KOPPA_66, BESAGARAHALLI_66, DUNDANAHALLI_66, MALAVALLI_66, HADLI_66	13:41	13:54	0:13	LINE FAULT
878	24-Feb-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66, ADDIHALLI_66, HARADANAHALLI(JAK)_66, BGNAGARA_66, ADICHUNCHANAGIRI_66, BASARALU_66, VADERALLI_66	23:27	23:38	0:10	LINE FAULT
879	24-Feb-19	MYSORE	66	HV1	VIJAYANAGRAMYS_66	12:09	14:40	2:30	LINE CLEAR AVAILED
880	24-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:28	18:10	9:41	LINE CLEAR AVAILED
881	24-Feb-19	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	11:30	11:38	0:07	HAND TRIPPED
882	24-Feb-19	TUMKUR	66	TR-1 & TR-2	HIREGUNTANUR_66	11:30	11:38	0:07	HAND TRIPPED
883	24-Feb-19	TUMKUR	66	HIREGUNTANUR- SIRIGERE	SIRIGERE_66, BRAHMASAGARA_IPP_66	11:30	11:38	0:07	HAND TRIPPED
884	24-Feb-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:42	12:53	0:10	HAND TRIPPED
885	24-Feb-19	TUMKUR	66	NEELAGUNDA 220KV-HARAPPANAHALLI	HARAPPANAHALLI_66	7:18	7:30	0:11	LINE FAULT
886	25-Feb-19	BAGALKOT	220	NAGJARI1-AMBEWADI	AMBEWADI_220	13:55	14:26	0:31	LINE FAULT
887	25-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	10:34	12:04	1:30	LINE CLEAR AVAILED
888	25-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	11:28	11:34	0:06	LINE FAULT
889	25-Feb-19	BAGALKOT	220	ALMATTI1&2-BAGALKOT	BAGALKOT_220	11:28	11:30	0:02	LINE FAULT
890	25-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	13:00	13:58	0:58	LINE FAULT
891	25-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	14:01	14:08	0:07	LINE FAULT
892	25-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	14:39	17:55	3:16	LINE FAULT
893	25-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	17:57	17:58	0:01	LINE FAULT
894	25-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	17:59	18:21	0:22	LINE FAULT
895	25-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	18:21	23:59	5:38	LINE FAULT
896	25-Feb-19	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	20:18	23:59	3:41	LINE CLEAR AVAILED
897	25-Feb-19	BAGALKOT	110	BAGALKOT220-LOKAPUR	LOKAPUR_110	11:28	11:39	0:11	LINE FAULT
898	25-Feb-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	8:29	8:34	0:05	TRANSFORMER FAULT
899	25-Feb-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	9:23	9:26	0:03	TRANSFORMER FAULT
900	25-Feb-19	BAGALKOT	220	BIDNAL-HAVERI1	BIDNAL_220	15:12	16:48	1:36	LINE FAULT
901	25-Feb-19	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	9:58	17:03	7:05	LINE CLEAR AVAILED
902	25-Feb-19	BAGALKOT	110	MAHALINGAPUR220-DAVALESHWARA	DAVALESHWARA_110	15:19	23:59	8:40	LINE CLEAR AVAILED
903	25-Feb-19	BAGALKOT	110	GADAG220-SAMBAPUR ROAD	SAMBAPUR ROAD_110	11:39	12:05	0:26	LINE CLEAR AVAILED
904	25-Feb-19	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	10:08	15:38	5:30	LINE CLEAR AVAILED
905	25-Feb-19	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	14:13	14:37	0:24	LINE CLEAR AVAILED
906	25-Feb-19	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	10:13	16:25	6:12	LINE CLEAR AVAILED
907	25-Feb-19	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	15:12	15:43	0:31	LINE FAULT
908	25-Feb-19	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	15:12	16:50	1:38	LINE FAULT
909	25-Feb-19	BAGALKOT	110	BELGAUM220(HUDLI)-ANKALGI	ANKALGI_110	12:15	12:32	0:17	HAND TRIPPED
910	25-Feb-19	BAGALKOT	110	BELGAUM220(HUDLI)-ANKALGI	ANKALGI_110	16:06	23:59	7:53	LINE CLEAR AVAILED
911	25-Feb-19	BAGALKOT	110	ANKALGI-HIDIKAL DAM	HIDIKAL DAM_110	15:20	15:53	0:33	HAND TRIPPED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
912	25-Feb-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	14:44	15:19	0:35	LINE CLEAR AVAILED
913	25-Feb-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	13:16	14:01	0:45	LINE CLEAR AVAILED
914	25-Feb-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	14:19	14:33	0:14	LINE CLEAR AVAILED
915	25-Feb-19	BAGALKOT	110	110/11KV,HV2	RON_110	6:48	7:20	0:32	TRANSFORMER FAULT
916	25-Feb-19	BAGALKOT	110	110/11KV,HV2	RON_110	9:38	11:05	1:27	TRANSFORMER FAULT
917	25-Feb-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	16:29	19:42	3:13	LINE CLEAR AVAILED
918	25-Feb-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	22:52	23:02	0:10	TRANSFORMER FAULT
919	25-Feb-19	BAGALKOT	110	SPV SOLAR-MUKARTHAL	MUKARTHAL_110	18:33	18:43	0:10	LINE FAULT
920	25-Feb-19	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220,RABKAVI_110,DAVALESHWAR_110,BANAHATTI_110	14:13	14:55	0:42	TRANSFORMER FAULT
921	25-Feb-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220,HIDIKAL_110,ITNAL_110	17:52	18:01	0:09	TRANSFORMER FAULT
922	25-Feb-19	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABKAVI_110	14:13	15:12	0:59	LINE FAULT
923	25-Feb-19	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	14:36	15:11	0:35	LINE CLEAR AVAILED
924	25-Feb-19	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	11:57	12:08	0:11	LINE FAULT
925	25-Feb-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_110	13:14	14:01	0:47	LINE CLEAR AVAILED
926	25-Feb-19	BAGALKOT	110	GHATAPRABHA 110-HIDIKAL	HIDIKAL_110	12:40	15:01	2:21	LINE CLEAR AVAILED
927	25-Feb-19	BANGALORE	66	HV1	ATTIBELE	17:21	17:38	0:17	TRANSFORMER FAULT
928	25-Feb-19	BANGALORE	66	BEGUR 220 - HIREHALLI	HIREHALLI	13:25	13:36	0:10	MAIN SUPPLY FAILURE
929	25-Feb-19	BANGALORE	66	BEGUR 220 - BIAL 1	BIAL	13:25	13:41	0:16	MAIN SUPPLY FAILURE
930	25-Feb-19	BANGALORE	66	BEGUR 220 - BOODIGERE	BOODIGERE	13:25	13:36	0:10	MAIN SUPPLY FAILURE
931	25-Feb-19	BANGALORE	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	13:25	13:36	0:10	MAIN SUPPLY FAILURE
932	25-Feb-19	BANGALORE	220	BEGUR 220 - HOODY 220	BEGUR 220	13:25	13:28	0:02	LINE FAULT
933	25-Feb-19	BANGALORE	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220	13:26	13:47	0:21	MAIN SUPPLY FAILURE
934	25-Feb-19	BANGALORE	220	HV1	HOSKOTE 220	13:26	13:50	0:23	MAIN SUPPLY FAILURE
935	25-Feb-19	BANGALORE	220	HV2	HOSKOTE 220	13:26	13:53	0:27	MAIN SUPPLY FAILURE
936	25-Feb-19	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSEHANAHALLI, CHEEMANGALA	17:26	17:36	0:10	LINE FAULT
937	25-Feb-19	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	17:36	21:34	3:58	LINE FAULT
938	25-Feb-19	BANGALORE	66	HV1	DABUSPET 220	9:31	13:41	4:09	TRANSFORMER FAULT
939	25-Feb-19	BANGALORE	66	HV2	DEVANAHALLI	9:11	9:21	0:09	TRANSFORMER FAULT
940	25-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	7:32	7:47	0:15	LINE FAULT
941	25-Feb-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:03	14:27	0:24	MAIN SUPPLY FAILURE
942	25-Feb-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:03	14:27	0:24	MAIN SUPPLY FAILURE
943	25-Feb-19	BANGALORE	220	LV2	DB PURA 220	22:08	22:21	0:13	TRANSFORMER FAULT
944	25-Feb-19	BANGALORE	66	DB PURA 220 - CB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	22:08	22:30	0:22	MAIN SUPPLY FAILURE
945	25-Feb-19	BANGALORE	66	DB PURA 220 - CB PURA 1	TUBUGERE	22:08	22:30	0:22	MAIN SUPPLY FAILURE
946	25-Feb-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	22:08	22:29	0:21	MAIN SUPPLY FAILURE
947	25-Feb-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	23:07	23:18	0:10	LOAD CHANGEOVER
948	25-Feb-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, MELUR	22:08	22:33	0:25	MAIN SUPPLY FAILURE
949	25-Feb-19	BANGALORE	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	15:54	16:01	0:06	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
950	25-Feb-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	6:16	6:31	0:14	LINE FAULT
951	25-Feb-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	13:26	13:57	0:31	MAIN SUPPLY FAILURE
952	25-Feb-19	BANGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	13:26	13:58	0:32	MAIN SUPPLY FAILURE
953	25-Feb-19	BANGALORE	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	13:26	14:00	0:34	MAIN SUPPLY FAILURE
954	25-Feb-19	BANGALORE	66	HOSKOTE 220 - SULIBELE	SULIBELE	13:26	14:00	0:34	MAIN SUPPLY FAILURE
955	25-Feb-19	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	13:26	14:00	0:34	MAIN SUPPLY FAILURE
956	25-Feb-19	BANGALORE	220	KOLAR 220 - MALUR 1	MALUR 220	13:22	13:47	0:24	LINE FAULT
957	25-Feb-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMAGAL , KYALANUR	13:35	13:50	0:15	LINE FAULT
958	25-Feb-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	13:22	13:57	0:35	MAIN SUPPLY FAILURE
959	25-Feb-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	13:22	13:57	0:35	MAIN SUPPLY FAILURE
960	25-Feb-19	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:22	13:57	0:35	MAIN SUPPLY FAILURE
961	25-Feb-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:22	13:57	0:35	MAIN SUPPLY FAILURE
962	25-Feb-19	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A	13:22	13:57	0:35	MAIN SUPPLY FAILURE
963	25-Feb-19	BANGALORE	66	MALUR 220 - MALUR 66	MALUR 66	13:22	13:57	0:35	MAIN SUPPLY FAILURE
964	25-Feb-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	0:10	0:21	0:10	LINE FAULT
965	25-Feb-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	22:06	22:20	0:14	LINE FAULT
966	25-Feb-19	BANGALORE	220	HV1	MALUR 220	13:22	13:57	0:35	MAIN SUPPLY FAILURE
967	25-Feb-19	BANGALORE	220	HV2	MALUR 220	13:22	13:57	0:35	MAIN SUPPLY FAILURE
968	25-Feb-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:03	14:27	0:24	LINE FAULT
969	25-Feb-19	BANGALORE	220	MALUR 220 - KOLAR 1	MALUR 220	13:22	13:57	0:35	LINE FAULT
970	25-Feb-19	BANGALORE	66	HV2	ISRO LAYOUT	23:05	23:20	0:14	TRANSFORMER FAULT
971	25-Feb-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	9:13	9:25	0:12	LINE FAULT
972	25-Feb-19	BANGALORE	66	HV1	KENGERI SATELLITE TOWN	13:35	14:07	0:31	TRANSFORMER FAULT
973	25-Feb-19	BANGALORE	220	HV2	SOMANAHALLI 220	21:44	22:15	0:31	TRANSFORMER FAULT
974	25-Feb-19	BANGALORE	220	HV3	SOMANAHALLI 220	21:44	22:19	0:34	TRANSFORMER FAULT
975	25-Feb-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	21:44	22:18	0:33	LINE FAULT
976	25-Feb-19	BANGALORE	66	SOMANAHALLI 220 - KANAKAPURA 1	YEDMADU, HANUMANTHANAGARA	21:44	22:24	0:39	MAIN SUPPLY FAILURE
977	25-Feb-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 1	RBI	21:44	22:19	0:34	MAIN SUPPLY FAILURE
978	25-Feb-19	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	21:44	21:58	0:13	MAIN SUPPLY FAILURE
979	25-Feb-19	BANGALORE	66	SOMANAHALLI 220 - SUBRAMANYAPURA 2	SHOBHA FOREST, BRIGADE MEADOWS	21:44	22:21	0:36	MAIN SUPPLY FAILURE
980	25-Feb-19	BANGALORE	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	21:44	22:22	0:37	MAIN SUPPLY FAILURE
981	25-Feb-19	BANGALORE	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	21:44	21:55	0:10	MAIN SUPPLY FAILURE
982	25-Feb-19	BANGALORE	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE	21:44	22:23	0:39	LINE FAULT

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
983	25-Feb-19	BANGALORE	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	21:44	21:58	0:13	MAIN SUPPLY FAILURE
984	25-Feb-19	BANGALORE	66	HV1	JIGANI 220	17:28	17:40	0:12	LOAD CHANGEVER
985	25-Feb-19	BANGALORE	66	HV2	JIGANI 220	17:28	17:40	0:12	LOAD CHANGEVER
986	25-Feb-19	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	17:28	17:40	0:12	LOAD CHANGEVER
987	25-Feb-19	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	18:15	18:22	0:07	LOAD CHANGEVER
988	25-Feb-19	BANGALORE	66	HV1	JIGANI 220	18:15	18:22	0:07	LOAD CHANGEVER
989	25-Feb-19	BANGALORE	66	HV2	JIGANI 220	18:15	18:22	0:07	LOAD CHANGEVER
990	25-Feb-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:25	6:31	0:05	LINE FAULT
991	25-Feb-19	GULBARGA	110	DHADESUGUR-VEPSLR	DHADESUGUR_110	10:24	13:22	2:58	LINE CLEAR AVAILED
992	25-Feb-19	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	0:00	6:28	6:28	LINE CLEAR AVAILED
993	25-Feb-19	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	12:45	17:20	4:35	LINE CLEAR AVAILED
994	25-Feb-19	GULBARGA	110	RAICHUR-SHABAD2	GOOGLE_110	13:27	17:25	3:58	NFBC ISSUED
995	25-Feb-19	GULBARGA	110	RAICHUR-SHABAD1,SHABAD2	GABUR_110,DEODURGA_110,GOOGLE_110	2:07	6:07	4:00	NFBC ISSUED
996	25-Feb-19	GULBARGA	110	HV1	KOLHAR_110	14:10	23:59	9:49	LINE CLEAR AVAILED
997	25-Feb-19	GULBARGA	110	KOLHAR-NSSK	KOLHAR_110	17:17	21:18	4:01	LINE CLEAR AVAILED
998	25-Feb-19	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	21:18	21:26	0:08	LINE FAULT
999	25-Feb-19	GULBARGA	66	KOGALI-ITTAGGI	KOGALI_66	10:42	13:13	2:31	LINE CLEAR AVAILED
1000	25-Feb-19	HASSAN	110	HV1	SAGARA_110	0:08	1:37	1:29	TRANSFORMER FAULT
1001	25-Feb-19	HASSAN	220	HASSAN4-SHIMOGA1	SHANTHIGRAMA_400	15:39	15:53	0:14	LINE FAULT
1002	25-Feb-19	HASSAN	220	HASSAN4-SHIMOGA1	SHANTHIGRAMA_400	16:26	22:46	6:20	LINE FAULT
1003	25-Feb-19	HASSAN	220	ARSK2-NITTUR	ARASIKERE_220	13:38	13:49	0:11	HAND TRIPPED
1004	25-Feb-19	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	13:28	13:57	0:29	LINE FAULT
1005	25-Feb-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	11:45	12:33	0:48	LINE CLEAR AVAILED
1006	25-Feb-19	HASSAN	220	KEMAR-UPCL1	KEMAR_220	11:45	12:33	0:48	LINE CLEAR AVAILED
1007	25-Feb-19	HASSAN	220	MRSSHM-ARSIKERE	MRSMSG_220	13:28	13:47	0:19	LINE FAULT
1008	25-Feb-19	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	16:26	22:45	6:19	LINE FAULT
1009	25-Feb-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	11:47	12:25	0:38	HAND TRIPPED
1010	25-Feb-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	11:47	12:21	0:34	HAND TRIPPED
1011	25-Feb-19	HASSAN	110	ARASIK-HV1	ARASIKERE_110	13:35	14:01	0:26	HAND TRIPPED
1012	25-Feb-19	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	13:28	13:58	0:30	LINE FAULT
1013	25-Feb-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	13:48	13:59	0:11	HAND TRIPPED
1014	25-Feb-19	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	13:28	13:58	0:30	LINE FAULT
1015	25-Feb-19	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	13:48	13:59	0:11	HAND TRIPPED
1016	25-Feb-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	12:05	12:22	0:17	LINE CLEAR AVAILED
1017	25-Feb-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	14:01	14:06	0:05	LINE CLEAR AVAILED
1018	25-Feb-19	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	2:28	2:46	0:18	LINE FAULT
1019	25-Feb-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	11:46	12:07	0:21	LOAD CURTAILMENT
1020	25-Feb-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:46	12:07	0:21	LOAD CURTAILMENT
1021	25-Feb-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	14:18	14:25	0:07	LINE FAULT
1022	25-Feb-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	22:58	23:03	0:05	LINE FAULT
1023	25-Feb-19	HASSAN	66	HV1	CHIKMAGALUR_66	11:00	17:40	6:40	LINE CLEAR AVAILED
1024	25-Feb-19	HASSAN	66	HV2	CHIKMAGALUR_66	11:00	17:09	6:09	LINE CLEAR AVAILED

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
1025	25-Feb-19	HASSAN	66	HV1	HANGARANAHALLY_66	11:15	12:15	1:00	LINE CLEAR AVAILED
1026	25-Feb-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:23	18:29	0:06	LINE FAULT
1027	25-Feb-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	18:30	23:59	5:29	LINE FAULT
1028	25-Feb-19	HASSAN	66	HV1	MAGGE_66	0:52	17:15	16:23	TRANSFORMER FAULT
1029	25-Feb-19	HASSAN	66	HV2	MAGGE_66	7:15	8:25	1:10	LINE CLEAR AVAILED
1030	25-Feb-19	HASSAN	66	HV2	MAGGE_66	10:30	11:50	1:20	LINE CLEAR AVAILED
1031	25-Feb-19	HASSAN	66	HV2	KIADB_66	5:45	6:03	0:18	TRANSFORMER FAULT
1032	25-Feb-19	HASSAN	66	HV2	BASAVAGHATTA_66	11:35	11:50	0:15	LINE CLEAR AVAILED
1033	25-Feb-19	MYSORE	66	JYOTHINAGARA-DK MAIDANA	DKMAIDANA_66	12:24	12:53	0:29	LINE FAULT
1034	25-Feb-19	MYSORE	220	HV1	KADAKOLA_220	10:05	23:59	13:53	LINE CLEAR AVAILED
1035	25-Feb-19	MYSORE	66	HV1	KADAKOLA_220	12:49	12:56	0:07	TRANSFORMER FAULT
1036	25-Feb-19	MYSORE	66	HV1	KADAKOLA_220	22:05	22:18	0:12	TRANSFORMER FAULT
1037	25-Feb-19	MYSORE	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	12:49	13:22	0:33	LINE FAULT
1038	25-Feb-19	MYSORE	66	HV1	K_HONNALGERE_66	16:22	16:39	0:17	HAND TRIPPED
1039	25-Feb-19	MYSORE	66	HV2	K_HONNALGERE_66	16:22	16:39	0:17	HAND TRIPPED
1040	25-Feb-19	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	6:33	6:42	0:08	LINE FAULT
1041	25-Feb-19	MYSORE	66	MANDYA-CHIKKMANDYA	CHIKKA_MANDYA_66, HAMPAPURA, KOPPA_66, BESAGARAHALLI_66, DUNDANAHALLI_66	15:54	16:07	0:12	LINE FAULT
1042	25-Feb-19	MYSORE	66	NANJANAGUDU-THANDYA	NANJANGUD STATION INTERRUPTED	12:48	15:13	2:25	LINE FAULT
1043	25-Feb-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66	15:52	16:03	0:10	LINE FAULT
1044	25-Feb-19	MYSORE	66	HV1	VAJAMANGALA_220	12:16	13:09	0:53	TRANSFORMER FAULT
1045	25-Feb-19	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	10:14	16:25	6:11	LINE CLEAR AVAILED
1046	25-Feb-19	TUMKUR	220	NITTUR 220kV- HASSAN	NITTUR_220	13:28	13:48	0:20	LINE FAULT
1047	25-Feb-19	TUMKUR	110	TR-1	GUBBI_110	18:43	18:48	0:05	TRANSFORMER FAULT
1048	25-Feb-19	TUMKUR	110	TR-1	KADABA_110	12:19	13:39	1:19	LINE CLEAR AVAILED
1049	25-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	10:40	12:23	1:43	LINE CLEAR AVAILED
1050	25-Feb-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	12:38	14:23	1:44	LINE CLEAR AVAILED
1051	25-Feb-19	TUMKUR	66	TR-1	CHANNAGIRI_66	2:20	2:25	0:05	TRANSFORMER FAULT
1052	25-Feb-19	TUMKUR	66	TR-2	CHANNAGIRI_66	21:57	22:08	0:10	TRANSFORMER FAULT
1053	25-Feb-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:30	16:48	0:18	HAND TRIPPED
1054	25-Feb-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:05	17:53	9:48	LINE CLEAR AVAILED
1055	25-Feb-19	TUMKUR	66	TR-1	HARAPPANAHALLI_66	12:04	17:10	5:05	LINE CLEAR AVAILED
1056	25-Feb-19	TUMKUR	66	HARAPPANAHALLI-ITTAGI	HARAPPANAHALLI_66	16:00	17:16	1:16	LINE CLEAR AVAILED
1057	25-Feb-19	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	10:52	11:40	0:48	MAIN SUPPLY FAILURE

Sl.No.	Dinanka	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REMARKS
1058	25-Feb-19	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	6:29	7:57	1:28	LINE FAULT