

400/220/110/66 kV TRANSMISSION OUTAGES FROM :31st August 2021 TO 06th September 2021

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|-----------|----------|---------|------------------------------------------|--------------------------------------------------------------|-----------------------|-----------|----------|------------------------------------|
| 1 | 31-Aug-21 | BAGALKOT | 66 | HONNALLI(BANUVALLI)-HARIHAR HOSPET | STATION NOT AFFECTED HARIHAR HOSPET_66 | 12:45 (04.09.2020) | | | LINE OPEN:LINE CLEAR AVAILED |
| 2 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED TODALBAGI_110 | 15:30 | 15:50 | 0:20 | HAND TRIPPED |
| 3 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED PH COMPOUND_110 | 11:25 | 12:41 | 1:16 | LINE CLEAR AVAILED |
| 4 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED MUGALKHOD_220 | 17:45 | 19:03 | 1:18 | TRANSFORMER FAULT |
| 5 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED AREMALLAPUR_110 | 11:33 | 17:30 | 5:57 | LINE CLEAR AVAILED |
| 6 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED ALMEL_110 | 12:00 | 12:08 | 0:08 | LINE CLEAR AVAILED |
| 7 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV, HV2 | STATION NOT AFFECTED ALMEL_110 | 17:50 | 18:00 | 0:10 | HAND TRIPPED |
| 8 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV, HV3 | STATION NOT AFFECTED MUDALAGI_110 | 15:56 | 16:20 | 0:24 | HAND TRIPPED |
| 9 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV,HV1 | MUGALKOD_110 | 17:40 | 19:05 | 1:25 | TRANSFORMER FAULT |
| 10 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV,HV1 | DEVAGOAN_110 | 17:40 | 17:55 | 0:15 | LINE CLEAR AVAILED |
| 11 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV,HV2 | BANAHATTI_110 | 17:12 (29.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 12 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV,HV2 | AINAPUR_110 | 12:20 | 14:10 | 1:50 | LINE CLEAR AVAILED |
| 13 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV,HV4 | BELUR_110 | 10:53 | 11:33 | 00:40 | LINE CLEAR AVAILED |
| 14 | 31-Aug-21 | BAGALKOT | 110 | 110/11KV,HV4 | BELUR_110 | 15:31 | 15:52 | 0:21 | LINE CLEAR AVAILED |
| 15 | 31-Aug-21 | BAGALKOT | 110 | 110/33KV, HV4 | DADDINAGANUR LIS_33 STATION NOT AFFECTED HUKKERI_110 | 10:03 | 17:53 | 7:50 | LINE CLEAR AVAILED |
| 16 | 31-Aug-21 | BAGALKOT | 110 | 220/110KV,LV1 | HAVERI_220 | 17:03 | 19:17 | 2:14 | LINE CLEAR AVAILED |
| 17 | 31-Aug-21 | BAGALKOT | 110 | AMBEWADI-HALIYAL(NK1) | STATION NOT AFFECTED AMBEWADI_220 | 9:54 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 18 | 31-Aug-21 | BAGALKOT | 110 | AMBEWADI-KAVALWADA(NK2) | STATION NOT AFFECTED AMBEWADI_220 | 9:52 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 19 | 31-Aug-21 | BAGALKOT | 110 | GOPANKOPPA-BIDNAL- NVLKD(NARAGUND) | STATION NOT AFFECTED GOPANAKOPPA_110 | 18:15 (24.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 20 | 31-Aug-21 | BAGALKOT | 110 | HATTARAGI-DADDI | DADDI_110 | 15:20 | 15:40 | 0:20 | LOAD CHANGE OVER |
| 21 | 31-Aug-21 | BAGALKOT | 110 | HATTARAGI-DADDI | DADDI_110 | 17:20 | 17:40 | 0:20 | LOAD CHANGE OVER |
| 22 | 31-Aug-21 | BAGALKOT | 110 | HAVERI220-BASAVANAKATTI | HAVERI_220 | 17:02 | 19:26 | 2:24 | LOAD CHANGE OVER |
| 23 | 31-Aug-21 | BAGALKOT | 110 | HAVERI220-BYADAGI | HAVERI_220 | 16:45 | 19:23 | 2:38 | LINE CLEAR AVAILED |
| 24 | 31-Aug-21 | BAGALKOT | 110 | HAVERI220-HAVERI | HAVERI_220 | 16:58 | 17:17 | 0:19 | LOAD CHANGE OVER |
| 25 | 31-Aug-21 | BAGALKOT | 110 | HAVERI220-KNNL | HAVERI_220 | 17:11 | 19:05 | 1:54 | LINE CLEAR AVAILED |
| 26 | 31-Aug-21 | BAGALKOT | 110 | HUKKERI-KOTAWAGI | KOTAWAGI_110 HUKKERI_110 | 15:20 | 17:53 | 2:33 | LINE CLEAR AVAILED |
| 27 | 31-Aug-21 | BAGALKOT | 110 | MUDEDEBIHAL-KNM SOLAR | KNM SOLAR IPP_110 STATION NOT AFFECTED MUDEDEBIHAL_110 | 18:20 | 19:32 | 1:12 | LINE CLEAR AVAILED |
| 28 | 31-Aug-21 | BAGALKOT | 110 | RANEBENNUR220- HONNATTI (AREMALLAPUR) | NO STATION AFFECTED RANEBENNUR_220 | 13:16 (17.11.2020) | | | LINE OPEN:LINE FAULT |
| 29 | 31-Aug-21 | BAGALKOT | 110 | SADALAGA-CHIKKODI220 | SADALAGA_110 | 7:05 | 12:14 | 5:09 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|-----------|-----------|---------|----------------------------|------------------------------------------|-----------------------|-----------|----------|------------------------------|
| 30 | 31-Aug-21 | BAGALKOT | 110 | SANKESHWAR-HUKKERI | HUKKERI_110 | 15:24 | 17:35 | 2:11 | LINE CLEAR AVAILED |
| 31 | 31-Aug-21 | BAGALKOT | 110 | SOUDATTI220-SOUDATTI2 | SOUDATTI_110 | 11:48 | 16:08 | 4:20 | LINE CLEAR AVAILED |
| 32 | 31-Aug-21 | BAGALKOT | 220 | 220/110KV,HV1 | HAVERI_220 | 19:11 | 19:17 | 0:06 | LINE CLEAR AVAILED |
| 33 | 31-Aug-21 | BAGALKOT | 220 | 220/110KV,HV2,LV2 | HAVERI_220 | 11:34 | 15:43 | 4:09 | TRANSFORMER FAULT |
| 34 | 31-Aug-21 | BAGALKOT | 220 | AMBEWADI-NAGJHARI2 | AMBEWADI_220 | 12:15 | 12:32 | 0:16 | LINE FAULT |
| 35 | 31-Aug-21 | BAGALKOT | 220 | AMBEWADI-PONDA1(XELDOM) | AMBEWADI_220 | 11:07 | 14:03 | 2:57 | LINE FAULT |
| 36 | 31-Aug-21 | BAGALKOT | 220 | AMBEWADI-PONDA1(XELDOM) | AMBEWADI_220 | 15:07 | 16:17 | 1:08 | LINE FAULT |
| 37 | 31-Aug-21 | BAGALKOT | 220 | BELGAUM -CHIKKODI 2 | BELGAUM_220 | 9:31 (26.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 38 | 31-Aug-21 | BAGALKOT | 220 | BIDNAL-HARTHI1 | STATION NOT AFFECTED BIDNAL_220 | 18:43 (01.08.2021) | | | LINE OPEN:LINE FAULT |
| 39 | 31-Aug-21 | BAGALKOT | 220 | GADAG-HARTI1 | STATION NOT AFFECTED GADAG_220 | 9:52 (24.08.2021) | | | LINE OPEN:LINE FAULT |
| 40 | 31-Aug-21 | BAGALKOT | 220 | HUBLI-NARENDRA2 | HUBLI_220 | 10:55 | 15:25 | 4:30 | LINE CLEAR AVAILED |
| 41 | 31-Aug-21 | BAGALKOT | 220 | MAHALINGAPUR-VAJRAMATTI 2 | STATION NOT AFFECTED MAHALINGAPUR_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 42 | 31-Aug-21 | BAGALKOT | 220 | NARENDRA-AMBEWADI2 | STATION NOT AFFECTED NARENDRA_220 | 17:22 (30.03.2021) | | | LINE OPEN:LINE FAULT |
| 43 | 31-Aug-21 | BAGALKOT | 220 | NARENDRA-HUBLI2 | NARENDRA_220 | 10:55 | 15:16 | 4:21 | LINE CLEAR AVAILED |
| 44 | 31-Aug-21 | BAGALKOT | 220 | SIRSI220-SHARAVATHI2 | SIRSI_220 | 12:20 | 12:49 | 0:29 | LINE CLEAR AVAILED |
| 45 | 31-Aug-21 | BAGALKOT | 220 | SIRSI-HUBLI 1 | SIRSI_220 | 17:59 (30.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 46 | 31-Aug-21 | BAGALKOT | 220 | VAJRAMATTI- MAHALINGAPUR1 | STATION NOT AFFECTED VAJRAMATTI_220 | 16:17 (23.02.2021) | | | LINE OPEN:LINE FAULT |
| 47 | 31-Aug-21 | BAGALKOT | 220 | VAJRAMATTI-MAHALINGAPUR2 | STATION NOT AFFECTED VAJRAMATTI_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 48 | 31-Aug-21 | BENGALURU | 66 | BG ROAD - JIGANI LINK ROAD | NO STATION AFFECTED | 9:41 | 15:14 | 5:33 | LINE FAULT |
| 49 | 31-Aug-21 | BENGALURU | 66 | DB PURA 220 - DG 1 | AIR(EHT) | 6:54 | 7:02 | 0:07 | LINE FAULT |
| 50 | 31-Aug-21 | BENGALURU | 66 | DB PURA 220 - DG 1 | AIR(EHT) | 7:13 | 10:58 | 3:45 | LINE CLEAR AVAILED |
| 51 | 31-Aug-21 | BENGALURU | 66 | DB PURA 220 - DG 1 | AIR(EHT) | 11:42 | 11:43 | 0:01 | LINE CLEAR AVAILED |
| 52 | 31-Aug-21 | BENGALURU | 66 | HV1 | AMAR JYOTHI | 10:06 | 10:12 | 0:06 | LOAD CHANGE OVER |
| 53 | 31-Aug-21 | BENGALURU | 66 | HV1 | IISc | 14:11 | 14:15 | 0:04 | LOAD CHANGE OVER |
| 54 | 31-Aug-21 | BENGALURU | 66 | HV1 | IISc | 14:30 | 14:33 | 0:03 | LOAD CHANGE OVER |
| 55 | 31-Aug-21 | BENGALURU | 66 | HV1 | BANGARPET | 8:36 | 9:14 | 0:38 | LINE CLEAR AVAILED |
| 56 | 31-Aug-21 | BENGALURU | 66 | HV1 | GOWRIBIDANUR 220 | 12:20 | 12:50 | 0:30 | LINE CLEAR AVAILED |
| 57 | 31-Aug-21 | BENGALURU | 66 | HV1 | MAGADI 66 | 12:05 | 12:28 | 0:22 | LINE CLEAR AVAILED |
| 58 | 31-Aug-21 | BENGALURU | 66 | HV1 | MAGADI 66 | 14:53 | 15:45 | 0:51 | LINE CLEAR AVAILED |
| 59 | 31-Aug-21 | BENGALURU | 66 | HV1 | SIDDALAGATTA | 15:20 | 15:46 | 0:25 | TRANSFORMER FAULT |
| 60 | 31-Aug-21 | BENGALURU | 66 | HV1 | VIJAYAPURA | 9:15 | 11:00 | 1:45 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|-----------|-----------|---------|----------------------------------------|-------------------------------------------|-------------------|-----------|----------|-------------------------------------|
| 61 | 31-Aug-21 | BENGALURU | 66 | HV1 | DALASNUR | 12:19 | 12:41 | 0:21 | LINE CLEAR AVAILED |
| 62 | 31-Aug-21 | BENGALURU | 66 | HV2 | MAASTHI | 10:25 | 10:39 | 0:14 | LINE CLEAR AVAILED |
| 63 | 31-Aug-21 | BENGALURU | 66 | HV2 | SM MANGALA | 16:54 | 17:00 | 0:05 | TRANSFORMER FAULT |
| 64 | 31-Aug-21 | BENGALURU | 66 | HV2 | VIJAYAPURA | 10:49 | 12:00 | 1:10 | LINE CLEAR AVAILED |
| 65 | 31-Aug-21 | BENGALURU | 66 | HV3 | BANGARPET | 7:30 | 8:30 | 1:00 | LINE CLEAR AVAILED |
| 66 | 31-Aug-21 | BENGALURU | 66 | R R NAGAR - VRISHABHAVATHI 220 | R R NAGAR | 6:16 | 6:28 | 0:12 | LOAD CHANGE OVER |
| 67 | 31-Aug-21 | BENGALURU | 66 | RAJANUKUNTE - YELAHANKA 220 | RAJANUKUNTE | 11:30 | 11:55 | 0:25 | LINE CLEAR AVAILED |
| 68 | 31-Aug-21 | BENGALURU | 66 | REMCO - VRISHABHAVATHI 220 | REMCO | 6:06 | 6:11 | 0:05 | LOAD CHANGE OVER |
| 69 | 31-Aug-21 | BENGALURU | 66 | SUBRAMANYAPURA 220 - SARAKKI 2 | SARAKKI | 5:45 | 6:07 | 0:22 | LINE FAULT |
| 70 | 31-Aug-21 | BENGALURU | 66 | SUBRAMANYAPURA 66 - SOMANAHALLI 220 | SUBRAMANYAPURA 66, ISKON | 10:39 | 10:42 | 0:03 | LOAD CHANGE OVER |
| 71 | 31-Aug-21 | BENGALURU | 66 | SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220 | SUBRAMANYAPURA 66, ISKON | 15:48 | 15:56 | 0:08 | LOAD CHANGE OVER |
| 72 | 31-Aug-21 | BENGALURU | 66 | VIDHURASTRWATHA - GUNDLU KOTTURU | GUNDLU KOTTURU | 3:29 | 3:35 | 0:05 | LINE FAULT |
| 73 | 31-Aug-21 | BENGALURU | 220 | BEGUR 220 - HOODY 220 | NO STATION AFFECTED | 15:58 | 17:23 | 1:25 | LINE FAULT |
| 74 | 31-Aug-21 | BENGALURU | 220 | HOODY 220 - BEGUR 220 | NO STATION AFFECTED | 15:57 | 17:28 | 1:31 | LINE FAULT |
| 75 | 31-Aug-21 | BENGALURU | 220 | SRS PEENYA 220 - SUBRAMANYAPURA 220 | NO STATION AFFECTED | 16:17 | 18:09 | 1:52 | LINE FAULT |
| 76 | 31-Aug-21 | GULBARGA | 66 | HIRAHADAGALLI-MAGALA | MAGALA_66 | 12:20 | 13:10 | 0:50 | LINE CLEAR AVAILED |
| 77 | 31-Aug-21 | GULBARGA | 66 | HV2 | HANASI_66 | 12:10 | 12:40 | 0:30 | LINE CLEAR AVAILED |
| 78 | 31-Aug-21 | GULBARGA | 66 | MUNIRABAD-MSD LINE | HANSI_66 | 9:05 | 15:51 | 6:46 | LINE CLEAR AVAILED |
| 79 | 31-Aug-21 | GULBARGA | 110 | BENUR-YERADONA | BENUR_110 | 8:45 | 8:50 | 0:05 | MAIN SUPPLY FAILURE |
| 80 | 31-Aug-21 | GULBARGA | 110 | GULBARGASOUTH-GULBARGA UNIVERSITY | GULBARGAUNIVERSITY_110 | 18:35(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 81 | 31-Aug-21 | GULBARGA | 110 | GURUMITAKAL-KONKAL | KONKAL_110 | 22:11 | 22:20 | 0:09 | LINE FAULT |
| 82 | 31-Aug-21 | GULBARGA | 110 | HALBARGA-HALIKED | HALIKED_110 | 11:19 | 13:25 | 2:06 | LINE CLEAR AVAILED |
| 83 | 31-Aug-21 | GULBARGA | 110 | HALBARGA-SANTHAPUR | SANTHAPUR_110 | 19:00 | 19:05 | 0:05 | LINE FAULT |
| 84 | 31-Aug-21 | GULBARGA | 110 | HV2 | VALKAMDINNI_110 | 11:15(31.08.2021) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 85 | 31-Aug-21 | GULBARGA | 110 | KADAGANCHI-KBS_SOLAR | KADAGANCHI_110 | 19:28 | 20:32 | 1:04 | LINE FAULT |
| 86 | 31-Aug-21 | GULBARGA | 110 | KADAGANCHI-KBS_SOLAR | KADAGANCHI_110 | 21:09 | 21:25 | 0:16 | LINE FAULT |
| 87 | 31-Aug-21 | GULBARGA | 110 | KOLHAR-NSSK | JANAWADA_110,NSSK SUGAR FACTORY_IPP | 18:35(31.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 88 | 31-Aug-21 | GULBARGA | 110 | KOLHAR-NSSK | JANAWADA_110,NSSK SUGAR FACTORY_IPP | 17:00 | 18:26 | 1:26 | LINE CLEAR AVAILED |
| 89 | 31-Aug-21 | GULBARGA | 110 | MALLAT-BYGWAT2 | ADAVI AMARESHWAR_110 | 23:31 | 23:45 | 0:14 | LINE CLEAR AVAILED |
| 90 | 31-Aug-21 | GULBARGA | 110 | RAICHUR-APMC1 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 20:33 | 22:20 | 1:47 | LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|-----------|----------|---------|-------------------------------|-------------------------------------------|----------------------|-------------------|----------|------------------------------|
| 91 | 31-Aug-21 | GULBARGA | 110 | RAICHUR-APMC1&2 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 18:43 | 18:50 | 0:07 | LINE FAULT |
| 92 | 31-Aug-21 | GULBARGA | 110 | RAICHUR-APMC2 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 20:33 | 21:02 | 0:29 | LINE FAULT |
| 93 | 31-Aug-21 | GULBARGA | 110 | RAICHUR-MALIYABAD | MALIYABAD_110,VADAVATI_110,YERAGERA_110 | 23:45(30.08.2021) | 00:40(31.08.2021) | 00:55HRS | LOAD CURTAILMENT |
| 94 | 31-Aug-21 | GULBARGA | 110 | RAICHUR-MALIYABAD | MALIYABAD_110,VADAVATI_110,YERAGERA_110 | 12:00 | 12:40 | 0:40 | LINE FAULT |
| 95 | 31-Aug-21 | GULBARGA | 110 | RAICHUR-SHAHAPUR12 | GOOGLE_110 | 20:33 | 21:04 | 0:31 | LINE FAULT |
| 96 | 31-Aug-21 | GULBARGA | 110 | RAICHUR-SHAHAPUR2 | GOOGLE_110 | 18:30 | 18:56 | 0:26 | LINE FAULT |
| 97 | 31-Aug-21 | GULBARGA | 110 | SEDAM-VICAT SAGAR | SEDAM_220 | 06:46(30.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 98 | 31-Aug-21 | GULBARGA | 110 | SEDAM-VICAT SAGAR | SEDAM_220 | 4:40 | 4:47 | 0:07 | LINE FAULT |
| 99 | 31-Aug-21 | GULBARGA | 110 | SEDAM-VICAT SAGAR | SEDAM_220 | 5:26 | 6:00 | 0:34 | LINE FAULT |
| 100 | 31-Aug-21 | GULBARGA | 110 | SEDAM-VICAT SAGAR | SEDAM_220 | 6:32 | 6:46 | 0:14 | LINE FAULT |
| 101 | 31-Aug-21 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 14:55(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 102 | 31-Aug-21 | GULBARGA | 110 | SHAHABAD-GULBARGA UNIVERSITY2 | GULBARGA UNIVERSITY_110 | 09:17(14.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 103 | 31-Aug-21 | GULBARGA | 110 | SHAHPUR-YADGIR | YADGIR_110 | 22:20 | 22:30 | 0:10 | LINE FAULT |
| 104 | 31-Aug-21 | GULBARGA | 110 | YELBURGA-TALT_SLR | YELBURGA_110 | 19:50(30.8.2021) | 6:27(31.08.2021) | 10:37HRS | LOAD CURTAILMENT |
| 105 | 31-Aug-21 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 5:45 | 6:07 | 0:22 | LINE FAULT |
| 106 | 31-Aug-21 | GULBARGA | 220 | SHAHAPUR-LINGASUGUR | SHAHAPUR_220 | 23:22 | 23:37 | 0:15 | LINE FAULT |
| 107 | 31-Aug-21 | HASSAN | 66 | BAGUR-RAMAPUR | BAGUR_66 | 7:47 | 8:01 | 0:14 | LINE FAULT |
| 108 | 31-Aug-21 | HASSAN | 66 | HV1 | BALLUPETE_66 | 9:49 | 10:21 | 0:32 | LINE CLEAR AVAILED |
| 109 | 31-Aug-21 | HASSAN | 66 | HV1 | MAGGE_66 | 13:42 | 14:05 | 0:23 | LINE CLEAR AVAILED |
| 110 | 31-Aug-21 | HASSAN | 66 | HV2 | MAGGE_66 | 10:48 | 10:53 | 0:05 | HAND TRIPPED |
| 111 | 31-Aug-21 | HASSAN | 66 | HV2 | MAGGE_66 | 11:14 | 11:30 | 0:16 | LINE CLEAR AVAILED |
| 112 | 31-Aug-21 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 8:29(7.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 113 | 31-Aug-21 | HASSAN | 66 | TAVAREC-HONNALLI | TAVARECHATNAHALLI_66 | 18:33 | 18:50 | 0:17 | LINE FAULT |
| 114 | 31-Aug-21 | HASSAN | 110 | HV1 | BANTWAL_110 | 10:23 | 12:20 | 1:57 | LINE CLEAR AVAILED |
| 115 | 31-Aug-21 | HASSAN | 110 | LPH-MGHE 1 | lph_gen | 11:13 (20.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 116 | 31-Aug-21 | HASSAN | 220 | GESOPA-TALGUPA2 | gerusoppa_gen | 0:14 | 7:53 | 7:39 | HAND TRIPPED |
| 117 | 31-Aug-21 | HASSAN | 220 | KEMAR-Varahi1 | KEMAR_220 | 15:52 | 16:01 | 0:09 | LINE FAULT |
| 118 | 31-Aug-21 | HASSAN | 220 | MRSSHM-CHMLR | MRSMSG_220 | 14:44 | 16:34 | 1:50 | LINE CLEAR AVAILED |
| 119 | 31-Aug-21 | HASSAN | 220 | MRSSHM-DVG2 | MRSMSG_220 | 17:08 (30.08.2021) | | | LINE OPEN:LINE FAULT |
| 120 | 31-Aug-21 | HASSAN | 220 | MRSSHM-SHARAVATHY3 | MRSMSG_220 | 11:03 | 13:58 | 2:55 | LINE CLEAR AVAILED |
| 121 | 31-Aug-21 | HASSAN | 220 | PUTTUR-KEMAR2 | PUTTUR_220 | 20:43 | 20:59 | 0:16 | LINE FAULT |
| 122 | 31-Aug-21 | HASSAN | 220 | SHRAVITY-SHIMOGA3 | sharavathy_gen | 11:03 | 13:59 | 2:56 | NFBC ISSUED |
| 123 | 31-Aug-21 | HASSAN | 220 | SHRAVITY-SIRISI 2 | sharavathy_gen | 12:20 | 12:49 | 0:29 | HAND TRIPPED |
| 124 | 31-Aug-21 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 22:22(31.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 125 | 31-Aug-21 | MYSURU | 66 | CHUNKANAKATTE-KR NAGARA | NO STATIONS EFFECTED | 8:20 (19/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 126 | 31-Aug-21 | MYSURU | 66 | HUNSUR-ELWALA | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 127 | 31-Aug-21 | MYSURU | 66 | HUNSUR-HOOTAGALLI | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|-----------|----------|---------|------------------------------------|-------------------------------------------|-----------------------|-------------------|----------|---------------------------------------|
| 128 | 31-Aug-21 | MYSURU | 66 | HV1 | HOSURGATE_66 | 14:25 | 15:15 | 0:49 | LINE CLEAR AVAILED |
| 129 | 31-Aug-21 | MYSURU | 66 | HV1 | KIKKERI_66 | 11:24 | 14:54 | 3:29 | LINE CLEAR AVAILED |
| 130 | 31-Aug-21 | MYSURU | 66 | HV1 | MAHADESHWARAPURA_66 | 12:53 | 13:26 | 0:33 | LINE CLEAR AVAILED |
| 131 | 31-Aug-21 | MYSURU | 66 | HV1 | MYSORE SOUTH_66 | 13:04 | 13:24 | 0:20 | LINE CLEAR AVAILED |
| 132 | 31-Aug-21 | MYSURU | 66 | HV1 | SUTTUR_66 | 9:45 (30/8/2021) | 15:47 (31/8/2021) | 31:02HRS | LOAD CURTAILMENT |
| 133 | 31-Aug-21 | MYSURU | 66 | HV2 | ADDIHALLI_66 | 1:44 | 1:49 | 0:04 | TRANSFORMER FAULT |
| 134 | 31-Aug-21 | MYSURU | 66 | HV2 | BETTADAPURA_66 | 15:01 | 15:38 | 0:37 | LINE CLEAR AVAILED |
| 135 | 31-Aug-21 | MYSURU | 66 | HV2 | HONNALLY_66 | 11:02 | 16:39 | 5:37 | LINE CLEAR AVAILED |
| 136 | 31-Aug-21 | MYSURU | 66 | HV2 | HOSURGATE_66 | 11:20 | 14:25 | 3:05 | LINE CLEAR AVAILED |
| 137 | 31-Aug-21 | MYSURU | 66 | HV2 | KIRUGAVALU_66 | 16:26 | 16:41 | 0:15 | LINE CLEAR AVAILED |
| 138 | 31-Aug-21 | MYSURU | 66 | HV2 | MALAVALLI_66 | 11:03 | 19:34 | 8:30 | LINE CLEAR AVAILED |
| 139 | 31-Aug-21 | MYSURU | 66 | HV2 | MYSORE SOUTH_66 | 13:28 | 13:54 | 0:25 | LINE CLEAR AVAILED |
| 140 | 31-Aug-21 | MYSURU | 66 | HV2 | SATHEGALA_66 | 11:43 | 12:22 | 0:38 | LINE CLEAR AVAILED |
| 141 | 31-Aug-21 | MYSURU | 66 | HV3 | PONNAMPETE_66 | 11:20 | 14:09 | 2:49 | LINE CLEAR AVAILED |
| 142 | 31-Aug-21 | MYSURU | 66 | KADAKOLA-DK MAIDANA | NO STATIONS EFFECTED | 6:22 | 6:28 | 0:05 | LINE FAULT |
| 143 | 31-Aug-21 | MYSURU | 66 | KR NAGARA-MYSORE-1 | NO STATIONS EFFECTED | 20:02 18/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 144 | 31-Aug-21 | MYSURU | 66 | SANTESARGUR-KADAKOLA 1 | HD KOTE_66 ANTHARASANTHE_66 | 12:30 | 14:20 | 1:50 | NFBC ISSUED |
| 145 | 31-Aug-21 | MYSURU | 66 | SANTESARGUR-KADAKOLA 1 | HD KOTE_66 ANTHARASANTHE_66 | 16:50 | 17:00 | 0:10 | NFBC ISSUED |
| 146 | 31-Aug-21 | MYSURU | 66 | SUTTUR-DEVNUR(N'GUD) | SUTTUR_66 | 15:36 | 15:44 | 0:07 | HAND TRIPPED |
| 147 | 31-Aug-21 | TUMKUR | 66 | DAVANGERE SRS- CHITRADURGA1 | CHITRADURGA_220 | 5:05 | 5:16 | 0:11 | LINE FAULT |
| 148 | 31-Aug-21 | TUMKUR | 66 | DAVANGERE SRS- CHITRADURGA1 | CHITRADURGA_220 | 12:50 | 13:01 | 0:10 | LINE FAULT |
| 149 | 31-Aug-21 | TUMKUR | 66 | HANAGAL- B G KERE | BGKERE_66,DUDEKOTE_66 | 17:13 | 18:03 | 0:49 | LINE CLEAR AVAILED |
| 150 | 31-Aug-21 | TUMKUR | 66 | HARIYABBE-CHIKKABANAGERE | HARIYABBE_66 | 12:28 | 12:30 | 0:02 | HAND TRIPPED |
| 151 | 31-Aug-21 | TUMKUR | 66 | HARIYABBE-HIRIYUR | HARIYABBE_66 | 12:24 | 12:29 | 0:05 | LINE FAULT |
| 152 | 31-Aug-21 | TUMKUR | 66 | JAVAGONDANAHALLI- BEVINAHALLI | JAVAGONDANAHALLI_66 | 14:15 | 14:45 | 0:29 | MAIN SUPPLY FAILURE |
| 153 | 31-Aug-21 | TUMKUR | 66 | JAVAGONDANAHALLI-INFOSYS-1_IPP_66 | INFOSYS-1_IPP_66 | 10:34 | 10:42 | 0:07 | MAIN SUPPLY FAILURE |
| 154 | 31-Aug-21 | TUMKUR | 66 | MIDIGESHI-PAVAGADA66 | MEDIGESHI_66 | 12:20 | 12:35 | 0:15 | LINE FAULT |
| 155 | 31-Aug-21 | TUMKUR | 66 | TR-1 | HANGAL_66 | 12:52 | 13:05 | 0:12 | LINE CLEAR AVAILED |
| 156 | 31-Aug-21 | TUMKUR | 66 | TR-2 | BENNEHALLI_66 | 11:23 | 11:30 | 0:07 | TRANSFORMER FAULT |
| 157 | 31-Aug-21 | TUMKUR | 66 | TR-2 | BENNEHALLI_66 | 15:52 | 15:56 | 0:04 | LINE CLEAR AVAILED |
| 158 | 31-Aug-21 | TUMKUR | 66 | TR-2 | CHITRADURGA_66 | 14:08 | 14:32 | 0:23 | TRANSFORMER FAULT |
| 159 | 31-Aug-21 | TUMKUR | 66 | TR-2 | NITRAHALLI_66 | 12:02 | 14:00 | 1:57 | LINE CLEAR AVAILED |
| 160 | 1-Sep-21 | BAGALKOT | 66 | HONNALLI(BANUVALLI)-HARIHAR HOSPET | STATION NOT AFFECTED HARIHAR HOSPET_66 | 12:45 (04.09.2020) | | | LINE OPEN:LINE CLEAR AVAILED |
| 161 | 1-Sep-21 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED NAREGAL_110 | 11:40 | 11:53 | 0:13 | TRANSFORMER FAULT |
| 162 | 1-Sep-21 | BAGALKOT | 110 | 110/11KV,HV2 | BANAHATTI_110 | 17:12 (29.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 163 | 1-Sep-21 | BAGALKOT | 110 | 110/11KV,HV2 | KHADAKLAT_110 | 12:15 | 12:55 | 0:40 | LINE CLEAR AVAILED |
| 164 | 1-Sep-21 | BAGALKOT | 110 | 110/1KV, HV2 | STATION NOT AFFECTED YALPARHATTI_110 | 16:30 | 16:50 | 0:20 | TRANSFORMER FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|----------|-----------|---------|------------------------------------------|------------------------------------------|-----------------------|-----------|----------|------------------------------|
| 165 | 1-Sep-21 | BAGALKOT | 110 | AMBEWADI-HALIYAL(NK1) | STATION NOT AFFECTED AMBEWADI_220 | 9:54 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 166 | 1-Sep-21 | BAGALKOT | 110 | AMBEWADI-KAVALWADA(NK2) | STATION NOT AFFECTED AMBEWADI_220 | 9:52 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 167 | 1-Sep-21 | BAGALKOT | 110 | BAGALKOT-NEERBUDIHAI | NEERBUDIHAI_110 | 4:22 | 5:10 | 0:48 | LINE FAULT |
| 168 | 1-Sep-21 | BAGALKOT | 110 | BAGALKOT-RAMDURGA | STATION NOT AFFECTED BAGALKOT_220 | 12:17 | 12:23 | 0:06 | LINE FAULT |
| 169 | 1-Sep-21 | BAGALKOT | 110 | GOPANKOPPA-BIDNAL- NVLKD(NARAGUND) | STATION NOT AFFECTED GOPANAKOPPA_110 | 18:15 (24.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 170 | 1-Sep-21 | BAGALKOT | 110 | MAHALINGAPUR-GSML 1 | STATION NOT AFFECTED MAHALINGAPUR_220 | 13:05 | 15:25 | 2:20 | LINE CLEAR AVAILED |
| 171 | 1-Sep-21 | BAGALKOT | 110 | MAHALINGAPUR-GSML 2 | STATION NOT AFFECTED MAHALINGAPUR_220 | 9:35 | 0:00 | 14:25 | LINE CLEAR AVAILED |
| 172 | 1-Sep-21 | BAGALKOT | 110 | NDI220-ZALKI2 | STATION NOT AFFECTED INDI_220 | 9:18 | 9:29 | 0:11 | LINE FAULT |
| 173 | 1-Sep-21 | BAGALKOT | 110 | RANEBENNUR220- HONNATTI (AREMALLAPUR) | NO STATION AFFECTED RANEBENNUR_220 | 13:16 (17.11.2020) | | | LINE OPEN:LINE FAULT |
| 174 | 1-Sep-21 | BAGALKOT | 110 | SHIROL-MANTUR | SHIROL_110 | 12:10 | 14:15 | 2:05 | LINE CLEAR AVAILED |
| 175 | 1-Sep-21 | BAGALKOT | 110 | SIRSI220-SIRSI1 | STATION NOT AFFECTED SIRSI_220 | 12:30 | 14:58 | 2:28 | LINE CLEAR AVAILED |
| 176 | 1-Sep-21 | BAGALKOT | 110 | SIRSI-KUMTA2 | STATION NOT AFFECTED SIRSI_110 | 12:05 | 15:00 | 2:55 | HAND TRIPPED |
| 177 | 1-Sep-21 | BAGALKOT | 220 | AMBEWADI-PONDA1(XELDOM) | AMBEWADI_220 | 9:47 | 16:30 | 6:43 | LINE FAULT |
| 178 | 1-Sep-21 | BAGALKOT | 220 | BELGAUM -CHIKKODI 2 | BELGAUM_220 | 9:31 (26.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 179 | 1-Sep-21 | BAGALKOT | 220 | BIDNAL-HARTHI1 | STATION NOT AFFECTED BIDNAL_220 | 18:43 (01.08.2021) | | | LINE OPEN:LINE FAULT |
| 180 | 1-Sep-21 | BAGALKOT | 220 | GADAG-HARTI1 | STATION NOT AFFECTED GADAG_220 | 9:52 (24.08.2021) | | | LINE OPEN:LINE FAULT |
| 181 | 1-Sep-21 | BAGALKOT | 220 | MAHALINGAPUR-VAJRAMATTI 2 | STATION NOT AFFECTED MAHALINGAPUR_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 182 | 1-Sep-21 | BAGALKOT | 220 | NARENDRA-AMBEWADI2 | STATION NOT AFFECTED NARENDRA_220 | 17:22 (30.03.2021) | | | LINE OPEN:LINE FAULT |
| 183 | 1-Sep-21 | BAGALKOT | 220 | SIRSI-HUBLI 1 | SIRSI_220 | 17:59 (30.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 184 | 1-Sep-21 | BAGALKOT | 220 | VAJRAMATTI- MAHALINGAPUR1 | STATION NOT AFFECTED VAJRAMATTI_220 | 16:17 (23.02.2021) | | | LINE OPEN:LINE FAULT |
| 185 | 1-Sep-21 | BAGALKOT | 220 | VAJRAMATTI -MAHALINGAPUR2 | STATION NOT AFFECTED VAJRAMATTI_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 186 | 1-Sep-21 | BENGALURU | 66 | HOSKOTE 220 - HOSKOTE 2 | HBR LAYOUT, BELL CERAMICS (EHT) | 6:26 | 6:54 | 0:27 | LINE FAULT |
| 187 | 1-Sep-21 | BENGALURU | 66 | HV1 | ALLIMARADANAHALLI | 15:41 | 15:54 | 0:13 | TRANSFORMER FAULT |
| 188 | 1-Sep-21 | BENGALURU | 66 | HV1 | HOODY 220 | 9:46 | 10:08 | 0:22 | LINE CLEAR AVAILED |
| 189 | 1-Sep-21 | BENGALURU | 66 | HV1 | N G HULKUR | 18:30 | 18:35 | 0:05 | LINE CLEAR AVAILED |
| 190 | 1-Sep-21 | BENGALURU | 66 | HV1 | MITTEMARI 220 | 15:14 | 17:56 | 2:41 | LINE CLEAR AVAILED |
| 191 | 1-Sep-21 | BENGALURU | 66 | HV1 | HOSKOTE 66 | 12:00 | 12:20 | 0:19 | LINE CLEAR AVAILED |
| 192 | 1-Sep-21 | BENGALURU | 66 | HV1 | CHINTAMANI 66 | 12:17 | 12:20 | 0:03 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|----------|-----------|---------|-----------------------------------|-------------------------------------------------|-------------------|-----------------|-----------|-------------------------------------|
| 193 | 1-Sep-21 | BENGALURU | 66 | HV1 | JIGANI 220 | 15:15 | 15:54 | 0:39 | LINE CLEAR AVAILED |
| 194 | 1-Sep-21 | BENGALURU | 66 | HV2 | KADUGODI | 12:03 | 12:30 | 0:27 | TRANSFORMER FAULT |
| 195 | 1-Sep-21 | BENGALURU | 66 | HV2 | JIGANI 220 | 13:54 | 14:34 | 0:40 | LINE CLEAR AVAILED |
| 196 | 1-Sep-21 | BENGALURU | 66 | JIGANI 220 - JIGANI 66 | JIGANI 66, JIGANI LINK ROAD | 15:43 | 15:56 | 0:13 | MAIN SUPPLY FAILURE |
| 197 | 1-Sep-21 | BENGALURU | 220 | HV1 | JIGANI 220 | 15:44 | 15:52 | 0:08 | LOAD CHANGE OVER |
| 198 | 1-Sep-21 | BENGALURU | 220 | HV2 | JIGANI 220 | 15:43 | 18:33 | 2:50 | LINE CLEAR AVAILED |
| 199 | 1-Sep-21 | GULBARGA | 66 | HANASI-KUDLIGI | HANASI_66 | 13:00 | 13:25 | 0:25 | MAIN SUPPLY FAILURE |
| 200 | 1-Sep-21 | GULBARGA | 66 | HANASI-KUDLIGI | HANASI_66 | 14:50 | 15:00 | 0:10 | MAIN SUPPLY FAILURE |
| 201 | 1-Sep-21 | GULBARGA | 110 | CHITAGUPPA-ACME SOLAR | CHITAGUPPA_110 | 6:05 | 7:03 | 0:58 | LINE FAULT |
| 202 | 1-Sep-21 | GULBARGA | 110 | CHITAGUPPA-HUMNABAD | CHITAGUPPA_110,NIRNA_110 | 6:05 | 6:45 | 0:40 | LINE FAULT |
| 203 | 1-Sep-21 | GULBARGA | 110 | GULBARGASOUTH-GULBARGA UNIVERSITY | GULBARGAUNIVERSITY_110 | 18:35(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 204 | 1-Sep-21 | GULBARGA | 110 | HALBARGA-BALKI | BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP | 11:19 | 11:29 | 0:10 | LINE FAULT |
| 205 | 1-Sep-21 | GULBARGA | 110 | HALKUNDI-BELLARY NORTH | HALKUNDI_110 | 5:25 | 6:53 | 1:28 | MAIN SUPPLY FAILURE |
| 206 | 1-Sep-21 | GULBARGA | 110 | HATTI-SOMANAMARDI_IPP | HATTI_110 | 6:23 | 6:33 | 0:10 | LINE FAULT |
| 207 | 1-Sep-21 | GULBARGA | 110 | HV1 | MANVI_110 | 14:02 | 16:42 | 2:40 | LINE CLEAR AVAILED |
| 208 | 1-Sep-21 | GULBARGA | 110 | HV1 | KURKUNTA_110 | 15:05 | 15:15 | 0:10 | TRANSFORMER FAULT |
| 209 | 1-Sep-21 | GULBARGA | 110 | HV1 | KURKUNTA_110 | 15:20 | 15:50 | 0:30 | TRANSFORMER FAULT |
| 210 | 1-Sep-21 | GULBARGA | 110 | HV1 | KURKUNTA_110 | 16:15 | 17:10 | 0:55 | TRANSFORMER FAULT |
| 211 | 1-Sep-21 | GULBARGA | 110 | HV1 | KURKUNTA_110 | 17:25 | 17:30 | 0:05 | TRANSFORMER FAULT |
| 212 | 1-Sep-21 | GULBARGA | 110 | HV2 | VALKAMDINNI_110 | 11:15(31.08.2021) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 213 | 1-Sep-21 | GULBARGA | 110 | HV2 | MANVI_110 | 11:10 | 14:15 | 3:05 | LINE CLEAR AVAILED |
| 214 | 1-Sep-21 | GULBARGA | 110 | KADAGANCHI-KAPANOOR | KADAGANCHI_110 | 6:15 | 6:25 | 0:10 | MAIN SUPPLY FAILURE |
| 215 | 1-Sep-21 | GULBARGA | 110 | KAPNOOR-HUMNABAD2 | ALAND_110,KADAGANCHI_110 | 16:14 | 16:23 | 0:09 | LINE FAULT |
| 216 | 1-Sep-21 | GULBARGA | 110 | KOLHAR-NSSK | JANAWADA_110,NSSK SUGAR FACTORY_IPP | 18:35(31.08.2021) | 9:05(1.09.2021) | 14:30 HRS | LINE CHARGED |
| 217 | 1-Sep-21 | GULBARGA | 110 | MALLAT-BYGWAT2 | ADAVI AMARESHWAR_110 | 22:39 | 22:46 | 0:07 | LINE FAULT |
| 218 | 1-Sep-21 | GULBARGA | 110 | MUNIRABAD-VYSANAKERE1 | DONIMALAI_110 | 6:20 | 6:32 | 0:12 | LINE FAULT |
| 219 | 1-Sep-21 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 4:30 | 5:00 | 0:30 | LINE FAULT |
| 220 | 1-Sep-21 | GULBARGA | 110 | RAICHUR-APMC1 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 11:20 | 14:55 | 3:35 | LINE FAULT |
| 221 | 1-Sep-21 | GULBARGA | 110 | RAICHUR-APMC2 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 11:20 | 14:12 | 2:52 | LINE FAULT |
| 222 | 1-Sep-21 | GULBARGA | 110 | RAICHUR-SHAHAPUR1 | GABBUR_110,DEODURGA_110 | 21:12 | 21:19 | 0:07 | LINE FAULT |
| 223 | 1-Sep-21 | GULBARGA | 110 | RAICHUR-SHAHAPUR2 | GOOGLE_110 | 21:12 | 21:19 | 0:07 | LINE FAULT |
| 224 | 1-Sep-21 | GULBARGA | 110 | RAICHUR-SINDHANOOR1 | SINDHANOOR_110 | 23:38 | 23:43 | 0:05 | LINE FAULT |
| 225 | 1-Sep-21 | GULBARGA | 110 | SEDAM-CHINCHOLLI | CHINCHOLLI_110 | 4:38 | 4:44 | 0:06 | LINE FAULT |
| 226 | 1-Sep-21 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 4:56 | 5:01 | 0:05 | LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|----------|----------|---------|-------------------------------|---------------------------------|----------------------|-----------|----------|------------------------------------|
| 227 | 1-Sep-21 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 14:55(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 228 | 1-Sep-21 | GULBARGA | 110 | SHAHABAD-GULBARGA UNIVERSITY2 | GULBARGA UNIVERSITY_110 | 09:17(14.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 229 | 1-Sep-21 | GULBARGA | 110 | SINDHANOOR-ADVIAMARESHWAR | ADAVI AMARESHWAR_110 | 12:10 | 12:20 | 0:10 | LINE FAULT |
| 230 | 1-Sep-21 | GULBARGA | 110 | SINDHANOOR-THURVIHAL | THURVIHAL_110 | 22:12 | 22:22 | 0:10 | LINE FAULT |
| 231 | 1-Sep-21 | GULBARGA | 110 | STAR METALLIC-MUNIRABAD | MUNIRABAD_220 | 6:17 | 6:29 | 0:12 | LINE FAULT |
| 232 | 1-Sep-21 | GULBARGA | 220 | HV2 | KUDLIGI_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 233 | 1-Sep-21 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 9:38 | 10:40 | 1:02 | LINE FAULT |
| 234 | 1-Sep-21 | GULBARGA | 220 | SEDAM-RTPS2 | SEDAM_220 | 4:05 | 4:36 | 0:31 | LINE FAULT |
| 235 | 1-Sep-21 | GULBARGA | 220 | SHAHABAD-SHAHAPUR | SHAHABAD_220 | 6:05 | 8:33 | 2:28 | LINE FAULT |
| 236 | 1-Sep-21 | HASSAN | 66 | HV1 | HANUBALu_55 | 14:56 | 15:14 | 0:18 | LINE CLEAR AVAILED |
| 237 | 1-Sep-21 | HASSAN | 66 | HV1 | MALLIPATNA_66 | 11:35 | 12:19 | 0:44 | LINE CLEAR AVAILED |
| 238 | 1-Sep-21 | HASSAN | 66 | HV1 | SAKLESH PURA_66 | 16:47 | 17:18 | 0:31 | LINE CLEAR AVAILED |
| 239 | 1-Sep-21 | HASSAN | 66 | HV2 | UDAYAPURA_66 | 12:14 | 12:25 | 0:11 | LINE CLEAR AVAILED |
| 240 | 1-Sep-21 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 8:29(7.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 241 | 1-Sep-21 | HASSAN | 66 | MALLIPA-ARAKALGUD | MALLIPATna_66 | 11:34 | 12:03 | 0:29 | LINE CLEAR AVAILED |
| 242 | 1-Sep-21 | HASSAN | 66 | MALLIPA-SANIVARSANTE | MALLIPATNA_66 | 11:34 | 12:03 | 0:29 | LINE CLEAR AVAILED |
| 243 | 1-Sep-21 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESH PURA_66 | 9:35 | 9:50 | 0:15 | LINE FAULT |
| 244 | 1-Sep-21 | HASSAN | 110 | BANTWA-SALATTUR | BANTWAL_110 | 9:58 | 10:05 | 0:07 | HAND TRIPPED |
| 245 | 1-Sep-21 | HASSAN | 110 | BANTWA-SALATTUR | BANTWAL_110 | 12:32 | 12:36 | 0:04 | HAND TRIPPED |
| 246 | 1-Sep-21 | HASSAN | 110 | LPH-MGHE 1 | lph_gen | 11:13 (20.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 247 | 1-Sep-21 | HASSAN | 220 | KAVOOR-KEMR2 | KAVOOR_220 | 9:28 | 16:29 | 7:01 | LINE CLEAR AVAILED |
| 248 | 1-Sep-21 | HASSAN | 220 | MRSSH-M-DVG2 | MRSMSG_220 | 17:08 (30.08.2021) | | | LINE OPEN:LINE FAULT |
| 249 | 1-Sep-21 | HASSAN | 220 | MRSSH-M-VARAH13 | MRSMSG_220 | 10:14 | 13:48 | 3:34 | LINE CLEAR AVAILED |
| 250 | 1-Sep-21 | HASSAN | 220 | MSEZ-KAVOOR2 | MSEZ_220 | 9:28 | 16:28 | 7:00 | NFBC ISSUED |
| 251 | 1-Sep-21 | HASSAN | 220 | VARAH1-SHMG3 | varahi_gen | 10:14 | 13:48 | 3:34 | LINE CLEAR AVAILED |
| 252 | 1-Sep-21 | MYSURU | 66 | CHUNKANAKATTE-KR NAGARA | NO STATIONS EFFECTED | 8:20 (19/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 253 | 1-Sep-21 | MYSURU | 66 | HD KOTE-TARAKA | NO STATIONS EFFECTED | 7:19 | 7:28 | 0:08 | LINE FAULT |
| 254 | 1-Sep-21 | MYSURU | 66 | HUNSUR-ELWALA | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 255 | 1-Sep-21 | MYSURU | 66 | HUNSUR-HOOTAGALLI | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 256 | 1-Sep-21 | MYSURU | 66 | HV1 | BETTADHAPURA_66 | 9:44 | 9:57 | 0:13 | TRANSFORMER FAULT |
| 257 | 1-Sep-21 | MYSURU | 66 | HV1 | BILIKERE_66 | 12:31 | 13:36 | 1:04 | LINE CLEAR AVAILED |
| 258 | 1-Sep-21 | MYSURU | 66 | HV1 | MADDUR_66 | 19:07 | 8:40 | 13:32 | HAND TRIPPED |
| 259 | 1-Sep-21 | MYSURU | 66 | HV1 | MALAVALLI_66 | 11:25 | 17:35 | 6:10 | LINE CLEAR AVAILED |
| 260 | 1-Sep-21 | MYSURU | 66 | HV1 | SATHEGALA_66 | 11:15 | 11:38 | 0:23 | LINE CLEAR AVAILED |
| 261 | 1-Sep-21 | MYSURU | 66 | HV2 | JAKKANAHALLY_66 | 9:17 | 0:02 | 14:44 | LINE CLEAR AVAILED |
| 262 | 1-Sep-21 | MYSURU | 66 | KR NAGARA-MYSORE-1 | NO STATIONS EFFECTED | 20:02 18/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 263 | 1-Sep-21 | MYSURU | 220 | VAJMANGALA-TK HALLI | NO STATIONS EFFECTED | 9:12 | 19:25 | 10:13 | NFBC ISSUED |
| 264 | 1-Sep-21 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- KORA | KORA_66, THOVINAKERE_66 | 11:27 | 11:39 | 0:12 | LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|-----------------------------------------|----------------------------------------------|-----------------------|-----------|----------|---------------------------------------|
| 265 | 1-Sep-21 | TUMKUR | 66 | DEVARAHALLI- CHANNAGIRI | DEVARAHALLI_66 | 16:31 | 17:08 | 0:37 | HAND TRIPPED |
| 266 | 1-Sep-21 | TUMKUR | 66 | JAVAGONDANAHALLI- SIRA | JAVAGONDANAHALLI_66 | 10:51 | 12:45 | 1:54 | NFBC ISSUED |
| 267 | 1-Sep-21 | TUMKUR | 66 | KORA- ANTHRASANAHALLI | KORA_66 | 11:29 | 11:44 | 0:15 | MAIN SUPPLY FAILURE |
| 268 | 1-Sep-21 | TUMKUR | 66 | KORA- BRAHMASANDRA | KORA_66, BRAHMASANDRA_66, THOVINAKERE_66 | 11:29 | 11:48 | 0:18 | MAIN SUPPLY FAILURE |
| 269 | 1-Sep-21 | TUMKUR | 66 | KUKKAWADA- LINGADAHALLI | LINGAAHALLI_66 | 15:12 | 15:32 | 0:20 | LINE FAULT |
| 270 | 1-Sep-21 | TUMKUR | 66 | TR-1 | CHANNAGIRI_66 | 15:10 | 15:53 | 0:43 | HAND TRIPPED |
| 271 | 1-Sep-21 | TUMKUR | 66 | TR-1 | KANCHIPURA_66 | 15:18 | 15:23 | 0:05 | TRANSFORMER FAULT |
| 272 | 1-Sep-21 | TUMKUR | 66 | TR-1 | RAMAPURA_66 | 11:18 | 12:48 | 1:30 | LINE CLEAR AVAILED |
| 273 | 1-Sep-21 | TUMKUR | 66 | TR-2 | HOLALKERE_66 | 12:20 | 13:40 | 1:20 | LINE CLEAR AVAILED |
| 274 | 1-Sep-21 | TUMKUR | 66 | TR-2 | THOVINAKERE_66 | 13:15 | 13:26 | 0:11 | TRANSFORMER FAULT |
| 275 | 1-Sep-21 | TUMKUR | 66 | TR-2 | URDIGERE_66 | 12:15 | 12:32 | 0:17 | LINE CLEAR AVAILED |
| 276 | 1-Sep-21 | TUMKUR | 66 | URDIGERE-KOLALA | KOLALA_66 | 12:16 | 12:32 | 0:15 | LINE CLEAR AVAILED |
| 277 | 1-Sep-21 | TUMKUR | 110 | SAMPIGE- DODDAGUNI | DODDAGUNI_110,AMMASANDRA_110,SAMPI GE_110 | 16:30 | 16:47 | 0:17 | LINE CLEAR AVAILED |
| 278 | 1-Sep-21 | TUMKUR | 110 | SAMPIGE- RENEWIND_IPP | RENEW_WIND_IPP_110 | 16:31 | 16:48 | 0:16 | LINE CLEAR AVAILED |
| 279 | 1-Sep-21 | TUMKUR | 110 | TR-1 | CHIKKANAYAKANAHALLI_110 | 12:10 | 12:34 | 0:23 | LINE CLEAR AVAILED |
| 280 | 1-Sep-21 | TUMKUR | 110 | TR-1 | SAMPIGE_110 | 16:30 | 17:09 | 0:38 | LINE CLEAR AVAILED |
| 281 | 1-Sep-21 | TUMKUR | 110 | TR-2 | CHIKKANAYAKANAHALLI_110 | 11:43 | 12:08 | 0:24 | LINE CLEAR AVAILED |
| 282 | 1-Sep-21 | TUMKUR | 110 | TR-2 | SAMPIGE_110 | 16:31 | 16:48 | 0:17 | LINE CLEAR AVAILED |
| 283 | 1-Sep-21 | TUMKUR | 220 | CHITRADURGA 220kV- HIRIYUR | IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66 | 9:48 | 13:39 | 3:50 | LINE CLEAR AVAILED |
| 284 | 1-Sep-21 | TUMKUR | 220 | THALLAK 220kV-CHITRADURGA | CHITRADURGA_220 | 9:40 | 13:37 | 3:57 | LINE CLEAR AVAILED |
| 285 | 2-Sep-2021 | BAGALKOT | 66 | HONNALLI(BANUVALLI)-HARIHAR HOSPET | STATION NOT AFFECTED HARIHAR HOSPET_66 | 12:45 (04.09.2020) | | | LINE OPEN:LINE CLEAR AVAILED |
| 286 | 2-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1 | STATION NOT AFFECTED KANABARGI LAYOUT_110 | 11:38 | 12:55 | 1:17 | LINE CLEAR AVAILED |
| 287 | 2-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1 | HOSAHONNATTI_110 | 10:47 | 17:29 | 6:42 | LINE CLEAR AVAILED |
| 288 | 2-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | BANAHATTI_110 | 17:12 (29.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 289 | 2-Sep-2021 | BAGALKOT | 110 | AMBEWADI-HALIYAL(NK1) | STATION NOT AFFECTED AMBEWADI_220 | 9:54 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 290 | 2-Sep-2021 | BAGALKOT | 110 | AMBEWADI-KAVALWADA(NK2) | STATION NOT AFFECTED AMBEWADI_220 | 9:52 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 291 | 2-Sep-2021 | BAGALKOT | 110 | BABALESHWAR-MAMADAPURA | STATION NOT AFFECTED MAMADAPUR(B)_110 | 17:27 | 19:14 | 1:47 | LINE CLEAR AVAILED |
| 292 | 2-Sep-2021 | BAGALKOT | 110 | GADAG-LAXMESHWAR2 | STATION NOT AFFECTED GADAG_220 | 0:24 | 11:07 | 10:43 | LINE FAULT |
| 293 | 2-Sep-2021 | BAGALKOT | 110 | GOPANKOPPA-BIDNAL- NVLKD(NARAGUND) | STATION NOT AFFECTED GOPANAKOPPA_110 | 18:15 (24.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 294 | 2-Sep-2021 | BAGALKOT | 110 | HOSAHONNATTI-GUTTAL | HOSAHONNATTI_110 | 13:50 | 17:29 | 3:39 | LINE CLEAR AVAILED |
| 295 | 2-Sep-2021 | BAGALKOT | 110 | LAKSMESHWAR-GADAG1 | STATION NOT AFFECTED LAKSHAMESHWAR_110 | 0:24 | 11:15 | 10:51 | LINE FAULT |
| 296 | 2-Sep-2021 | BAGALKOT | 110 | RANEENNUR220- HONNATTI (AREMALLAPUR) | NO STATION AFFECTED RANEENNUR_220 | 13:16 (17.11.2020) | | | LINE OPEN:LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|---------------------------------|----------------------------------------------------------------|-----------------------|-----------|----------|------------------------------|
| 297 | 2-Sep-2021 | BAGALKOT | 110 | SAVANUR-ASIAN FEBTECH SOLAR | ASIAN FEBTECH SOLAR_110 STATION NOT AFFECTED SAVANUR_110 | 6:10 | 6:17 | 0:07 | LINE FAULT |
| 298 | 2-Sep-2021 | BAGALKOT | 110 | SHIRAGUPPI-BISNAL | SHIRAGUPPI_110 | 7:20 | 8:05 | 0:45 | LINE CLEAR AVAILED |
| 299 | 2-Sep-2021 | BAGALKOT | 110 | TARIHAL-HUBLI220 | STATION NOT AFFECTED TARIHAL_110 | 16:05 | 16:12 | 0:07 | HAND TRIPPED |
| 300 | 2-Sep-2021 | BAGALKOT | 110 | VAJRAMATTI-SHIRAGUPPI | SHIRAGUPPI_110 | 7:20 | 8:00 | 0:40 | LINE CLEAR AVAILED |
| 301 | 2-Sep-2021 | BAGALKOT | 220 | AMBEWADI-PONDA1 | STATION NOT AFFECTED AMBEWADI_220 | 15:47 | 18:53 | 3:06 | LINE FAULT |
| 302 | 2-Sep-2021 | BAGALKOT | 220 | AMBEWADI-PONDA2 | STATION NOT AFFECTED AMBEWADI_220 | 12:31 | 13:52 | 1:21 | LINE FAULT |
| 303 | 2-Sep-2021 | BAGALKOT | 220 | BELGAUM -CHIKKODI 2 | BELGAUM_220 | 9:31 (26.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 304 | 2-Sep-2021 | BAGALKOT | 220 | BIDNAL-HARTHI1 | STATION NOT AFFECTED BIDNAL_220 | 18:43 (01.08.2021) | | | LINE OPEN:LINE FAULT |
| 305 | 2-Sep-2021 | BAGALKOT | 220 | GADAG-HARTI1 | STATION NOT AFFECTED GADAG_220 | 9:52 (24.08.2021) | | | LINE OPEN:LINE FAULT |
| 306 | 2-Sep-2021 | BAGALKOT | 220 | HUBLI-NAGJHARI2 | STATION NOT AFFECTED HUBLI_220 | 17:43 | 18:09 | 0:26 | LINE FAULT |
| 307 | 2-Sep-2021 | BAGALKOT | 220 | HUBLI-NAGJHARI2 | STATION NOT AFFECTED HUBLI_220 | 18:37 (02.09.221) | | | LINE OPEN:LINE CLEAR AVAILED |
| 308 | 2-Sep-2021 | BAGALKOT | 220 | KUDUCHI-CHIKKODI2 | STATION NOT AFFECTED KUDUCHI_220 | 11:03 | 12:53 | 1:50 | NFBC ISSUED |
| 309 | 2-Sep-2021 | BAGALKOT | 220 | KUDUCHI-MAHALINGAPUR | STATION NOT AFFECTED KUDUCHI_220 | 17:12 | 17:13 | 0:01 | HAND TRIPPED |
| 310 | 2-Sep-2021 | BAGALKOT | 220 | MAHALINGAPUR-VAJRAMATTI 2 | STATION NOT AFFECTED MAHALINGAPUR_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 311 | 2-Sep-2021 | BAGALKOT | 220 | NARENDRA-AMBEWADI1 | STATION NOT AFFECTED NARENDRA_220 | 15:47 | 18:53 | 3:06 | LINE FAULT |
| 312 | 2-Sep-2021 | BAGALKOT | 220 | NARENDRA-AMBEWADI2 | STATION NOT AFFECTED NARENDRA_220 | 17:22 (30.03.2021) | | | LINE OPEN:LINE FAULT |
| 313 | 2-Sep-2021 | BAGALKOT | 220 | SIRSI-HUBLI 1 | SIRSI_220 | 17:59 (30.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 314 | 2-Sep-2021 | BAGALKOT | 220 | VAJRAMATTI- MAHALINGAPUR1 | STATION NOT AFFECTED VAJRAMATTI_220 | 16:17 (23.02.2021) | | | LINE OPEN:LINE FAULT |
| 315 | 2-Sep-2021 | BAGALKOT | 220 | VAJRAMATTI -MAHALINGAPUR2 | STATION NOT AFFECTED VAJRAMATTI_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 316 | 2-Sep-2021 | BENGALURU | 66 | BOODIGERE - BEGUR 220 | BOODIGERE | 21:05 | 21:10 | 0:05 | LOAD CHANGE OVER |
| 317 | 2-Sep-2021 | BENGALURU | 66 | C STATION 1 & 2 - A STATION 220 | C STATION | 17:32 | 17:38 | 0:06 | LOAD CHANGE OVER |
| 318 | 2-Sep-2021 | BENGALURU | 66 | C STATION 1 & 2 - HEBBALA 220 | C STATION | 7:37 | 7:45 | 0:08 | LOAD CHANGE OVER |
| 319 | 2-Sep-2021 | BENGALURU | 66 | CHINTAMANI 220 - IRGAMPALLI | IRAGAMPALLI, M GOLLAHALLI | 2:05 | 2:15 | 0:10 | LINE FAULT |
| 320 | 2-Sep-2021 | BENGALURU | 66 | DABUSPETE 220 - NELAMANGALA 66 | NELAMANGALA 66 | 9:31 | 10:07 | 0:36 | LINE FAULT |
| 321 | 2-Sep-2021 | BENGALURU | 66 | DB PURA 220 - DG 1 | AIR(EHT) | 6:02 | 6:18 | 0:16 | LINE FAULT |
| 322 | 2-Sep-2021 | BENGALURU | 66 | HEBBALA 220 - L R BANDE | L R BANDE | 10:00 | 16:52 | 6:52 | LINE CLEAR AVAILED |
| 323 | 2-Sep-2021 | BENGALURU | 66 | HENNUR CROSS - VIDYANAGARA | HENNUR CROSS | 21:25 | 21:29 | 0:04 | LOAD CHANGE OVER |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|--------------------------------------|--------------------------------------------------------------------------------------------------|-------------------|-----------------|----------|-------------------------------------|
| 324 | 2-Sep-2021 | BENGALURU | 66 | HV1 | BANASAWADI | 9:05 | 9:10 | 0:05 | LOAD CHANGE OVER |
| 325 | 2-Sep-2021 | BENGALURU | 66 | HV1 | BANASAWADI | 16:51 | 16:57 | 0:06 | LOAD CHANGE OVER |
| 326 | 2-Sep-2021 | BENGALURU | 66 | HV1 | KGF | 18:08 | 18:20 | 0:11 | LINE CLEAR AVAILED |
| 327 | 2-Sep-2021 | BENGALURU | 66 | HV2 | KGF | 18:04 | 18:50 | 0:45 | TRANSFORMER FAULT |
| 328 | 2-Sep-2021 | BENGALURU | 66 | HV2 | DODDABELAVANGALA | 21:47 | 23:39 | 1:52 | TRANSFORMER FAULT |
| 329 | 2-Sep-2021 | BENGALURU | 66 | HV3 | BANASAWADI | 9:05 | 9:10 | 0:05 | LOAD CHANGE OVER |
| 330 | 2-Sep-2021 | BENGALURU | 66 | HV3 | BANASAWADI | 16:51 | 16:57 | 0:06 | LOAD CHANGE OVER |
| 331 | 2-Sep-2021 | BENGALURU | 66 | HV3 | KGF | 18:04 | 18:50 | 0:45 | TRANSFORMER FAULT |
| 332 | 2-Sep-2021 | BENGALURU | 66 | IIsc - HEBBALA 220 | IIsc | 9:55 | 10:00 | 0:05 | LOAD CHANGE OVER |
| 333 | 2-Sep-2021 | BENGALURU | 66 | IIsc - NRS 220 | IIsc | 17:28 | 17:31 | 0:03 | LOAD CHANGE OVER |
| 334 | 2-Sep-2021 | BENGALURU | 66 | MITTEMARI 220 - BAGEPALLI 2 | BAGEPALLI, GUNDLU KOTTUR | 18:32 | 18:42 | 0:10 | LINE FAULT |
| 335 | 2-Sep-2021 | BENGALURU | 66 | T GOLLAHALLI 220 - KGF 1 | KYSAMBALLI, ANDERSONPETE, DODDAKARI | 13:17 | 15:10 | 1:53 | LINE CLEAR AVAILED |
| 336 | 2-Sep-2021 | BENGALURU | 66 | T K HALLI 220 - SIMSHA | NO STATION AFFECTED | 6:14 | 6:27 | 0:13 | LINE FAULT |
| 337 | 2-Sep-2021 | BENGALURU | 220 | GOWRIBIDANUR 220 - PGCIL 1 | NO STATION AFFECTED | 9:55 | 14:44 | 4:49 | LINE CLEAR AVAILED |
| 338 | 2-Sep-2021 | BENGALURU | 220 | GOWRIBIDANUR 220 - PGCIL 2 | NO STATION AFFECTED | 11:45(1-9-2021) | 16:40(2-9-2021) | 4:54HRS | LINE CHARGED |
| 339 | 2-Sep-2021 | BENGALURU | 220 | HEBBALA 220 - MANYATHA TECH PARK 220 | HEBBALA 220 | 10:10 | 16:30 | 6:20 | LINE CLEAR AVAILED |
| 340 | 2-Sep-2021 | GULBARGA | 66 | HV1 | KUDLIGI_220 | 11:10 | 11:25 | 0:15 | TRANSFORMER FAULT |
| 341 | 2-Sep-2021 | GULBARGA | 110 | ALIPUR-BELLARY NORTH1 | SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110, BISIHALI_110,JANAKI_IPP,BASAI STEEL_IPP | 5:59 | 6:11 | 0:12 | LINE FAULT |
| 342 | 2-Sep-2021 | GULBARGA | 110 | GULBARGASOUTH-GULBARGA UNIVERSITY | GULBARGAUNIVERSITY_110 | 18:35(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 343 | 2-Sep-2021 | GULBARGA | 110 | HV1 | NALWAR_110 | 18:03 | 18:25 | 0:22 | LINE CLEAR AVAILED |
| 344 | 2-Sep-2021 | GULBARGA | 110 | HV1 | KAVITAL_110 | 15:05 | 15:20 | 0:15 | LINE CLEAR AVAILED |
| 345 | 2-Sep-2021 | GULBARGA | 110 | HV2 | VALKAMDINNI_110 | 11:15(31.08.2021) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 346 | 2-Sep-2021 | GULBARGA | 110 | HV2 | DEODURGA_110 | 1:40 | 2:20 | 0:40 | TRANSFORMER FAULT |
| 347 | 2-Sep-2021 | GULBARGA | 110 | HV2 | GULBARGA UNIVERSITY_110 | 10:20 | 11:20 | 1:00 | LINE CLEAR AVAILED |
| 348 | 2-Sep-2021 | GULBARGA | 110 | HV2 | KAVITAL_110 | 16:07 | 16:40 | 0:33 | LINE CLEAR AVAILED |
| 349 | 2-Sep-2021 | GULBARGA | 110 | KAPNOOR-HUMNABAD2 | ALAND_110,KADAGANCHI_110 | 4:44 | 4:57 | 0:13 | LINE FAULT |
| 350 | 2-Sep-2021 | GULBARGA | 110 | RAICHUR-SHAHAPUR1&2 | GABBUR_110,DEODURGA_110,GOOGLE_110, BP SOLAR_IPP | 20:51 | 21:18 | 0:27 | LINE FAULT |
| 351 | 2-Sep-2021 | GULBARGA | 110 | RAICHUR-SINDHANOOR1(IDLE LINE) | SINDHANOOR_110 | 0:09 | 13:40 | 13:31 | LINE FAULT |
| 352 | 2-Sep-2021 | GULBARGA | 110 | SEDAM-KURKUNTA | KURKUNTA_110 | 14:08 | 14:19 | 0:11 | LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|-------------------------------|-------------------------------------------------------------------------------|--------------------|-----------|----------|------------------------------------|
| 353 | 2-Sep-2021 | GULBARGA | 110 | SHAHABAD-BAGEWADI1 | MADEWAL_110,MORATAGI_110,DEVANGAO N_110,RENUKA_IPP,AFZALPUR_110,KARAJAG I_110 | 20:41 | 20:46 | 0:05 | LINE FAULT |
| 354 | 2-Sep-2021 | GULBARGA | 110 | SHAHABAD-BAGEWADI2 | YADRAMI_110,MORATAGI_110 | 11:45 | 13:45 | 2:00 | LINE CLEAR AVAILED |
| 355 | 2-Sep-2021 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 14:55(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 356 | 2-Sep-2021 | GULBARGA | 110 | SHAHABAD-GULBARGA UNIVERSITY2 | GULBARGA UNIVERSITY_110 | 09:17(14.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 357 | 2-Sep-2021 | GULBARGA | 110 | SINDHANOOR-ADVIAMARESHWAR | ADAVI AMARESHWAR_110 | 21:50 | 22:05 | 0:15 | LINE FAULT |
| 358 | 2-Sep-2021 | GULBARGA | 220 | HV2 | KUDLIGI_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 359 | 2-Sep-2021 | GULBARGA | 220 | LINGAPUR-HALWARTHY | LINGAPUR_220 | 8:53 | 15:17 | 6:24 | LINE CLEAR AVAILED |
| 360 | 2-Sep-2021 | GULBARGA | 220 | LINGASUGUR-BAGEWADI1 | BAGEWADI_220 | 13:35 | 14:13 | 0:38 | LINE FAULT |
| 361 | 2-Sep-2021 | GULBARGA | 220 | LINGASUGUR-SHAHAPUR | SHAHAPUR_220 | 4:42 | 5:03 | 0:21 | LINE FAULT |
| 362 | 2-Sep-2021 | GULBARGA | 220 | MALLAT-LINGASUGUR | MALLAT_220 | 14:33 | 15:12 | 0:39 | LINE FAULT |
| 363 | 2-Sep-2021 | GULBARGA | 220 | SEDAM-SHAHAPUR | SHAHAPUR_220 | 11:40 | 12:04 | 0:24 | LINE FAULT |
| 364 | 2-Sep-2021 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 10:16 | 16:31 | 6:15 | LINE CLEAR AVAILED |
| 365 | 2-Sep-2021 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 10:10 | 16:30 | 6:20 | LINE CLEAR AVAILED |
| 366 | 2-Sep-2021 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARAYAPATNA_66 | 10:21 | 10:47 | 0:26 | LINE FAULT |
| 367 | 2-Sep-2021 | HASSAN | 66 | HNPR2-HASS3 | HOLENARASIPURA_220 | 23:52(2.9.2021) | | | LINE OPEN:LINE FAULT |
| 368 | 2-Sep-2021 | HASSAN | 66 | HV1 | ALDUR_66 | 10:17 | 16:33 | 6:16 | LINE CLEAR AVAILED |
| 369 | 2-Sep-2021 | HASSAN | 66 | HV1 | AREHALLI_66 | 16:43 | 17:41 | 0:58 | LINE CLEAR AVAILED |
| 370 | 2-Sep-2021 | HASSAN | 66 | HV1 | HIEMAGALUR_66 | 0:28 | 0:48 | 0:20 | TRANSFORMER FAULT |
| 371 | 2-Sep-2021 | HASSAN | 66 | HV1 | SALAGAME_66 | 13:54 | 14:54 | 1:00 | LINE CLEAR AVAILED |
| 372 | 2-Sep-2021 | HASSAN | 66 | HV2 | SALAGAME_66 | 11:53 | 13:59 | 2:06 | LINE CLEAR AVAILED |
| 373 | 2-Sep-2021 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 8:29(7.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 374 | 2-Sep-2021 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 11:46 | 12:29 | 0:43 | LINE CLEAR AVAILED |
| 375 | 2-Sep-2021 | HASSAN | 66 | MRSSH-MOLUR | MRS MG_220 | 12:07 | 13:15 | 1:08 | LINE FAULT |
| 376 | 2-Sep-2021 | HASSAN | 66 | SALAGAM-HIREMANGLUR | SALAGAME_66 | 14:32 | 15:20 | 0:48 | LINE CLEAR AVAILED |
| 377 | 2-Sep-2021 | HASSAN | 66 | TAVAREC-HONNALLI | TAVARECHATNAHALLY_66 | 13:22 | 13:29 | 0:07 | MAIN SUPPLY FAILURE |
| 378 | 2-Sep-2021 | HASSAN | 110 | HV1 | MSEZ_220 | 10:18 | 14:07 | 3:49 | LINE CLEAR AVAILED |
| 379 | 2-Sep-2021 | HASSAN | 110 | HV1 | SAGARA_110 | 13:05 | 16:45 | 3:40 | LINE CLEAR AVAILED |
| 380 | 2-Sep-2021 | HASSAN | 110 | HV2 | MSEZ_220 | 10:18 | 15:42 | 5:24 | LINE CLEAR AVAILED |
| 381 | 2-Sep-2021 | HASSAN | 110 | HV2 | NERALAKERE_110 | 7:23 | 7:40 | 0:17 | TRANSFORMER FAULT |
| 382 | 2-Sep-2021 | HASSAN | 110 | HV2 | SAGARA_110 | 17:05 | 17:50 | 0:45 | LINE CLEAR AVAILED |
| 383 | 2-Sep-2021 | HASSAN | 110 | HV3 | SAGARA_110 | 16:00 | 16:10 | 0:10 | LINE CLEAR AVAILED |
| 384 | 2-Sep-2021 | HASSAN | 110 | LPH-MGHE 1 | lph_gen | 11:13 (20.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 385 | 2-Sep-2021 | HASSAN | 110 | MANIPAL-BRAMVR | MANIPAL_110 | 10:05 | 15:10 | 5:05 | LINE CLEAR AVAILED |
| 386 | 2-Sep-2021 | HASSAN | 110 | PUTTUR-PUTUR 1 | PUTTUR_220 | 10:53 | 13:40 | 2:47 | LINE CLEAR AVAILED |
| 387 | 2-Sep-2021 | HASSAN | 220 | GERSOPA-TALGUPA1 | gerusoppa_gen | 12:01 | 14:24 | 2:23 | LINE CLEAR AVAILED |
| 388 | 2-Sep-2021 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 12:30(02.09.2021) | | | LINE OPEN:LINE FAULT |
| 389 | 2-Sep-2021 | HASSAN | 220 | MRSSH-DVG2 | MRS MG_220 | 17:08 (30.08.2021) | | | LINE OPEN:LINE FAULT |
| 390 | 2-Sep-2021 | HASSAN | 220 | MRSSH-STRP1 | MRS MG_220 | 12:01 | 14:24 | 2:23 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|---------|---------|-----------------------------------|----------------------------------------------------------|-----------------------|----------------|----------|------------------------------------|
| 391 | 2-Sep-2021 | HASSAN | 220 | SHRAVITY-SIRISI 1 | sharavathy_gen | 21:22(2.09.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 392 | 2-Sep-2021 | HASSAN | 220 | TALAGU-STRP2 | TALAGUPPA_400 | 12:30(2.9.2021) | | | LINE OPEN:LINE FAULT |
| 393 | 2-Sep-2021 | HASSAN | 400 | UPCL-HASSAN2 | upcl_gen | 22:06(01.09.2021) | 6:58(2.9.2021) | 8:52hrs | LINE CHARGED |
| 394 | 2-Sep-2021 | HASSAN | 400 | UPCL-HASSAN2 | upcl_gen | 22:54(02.09.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 395 | 2-Sep-2021 | MYSURU | 66 | CHUNKANAKATTE-KR NAGARA | NO STATIONS EFFECTED | 8:20 (19/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 396 | 2-Sep-2021 | MYSURU | 66 | HANNUR-AMP SOLAR | NO STATIONS EFFECTED | 15:33 | 15:47 | 0:13 | LINE FAULT |
| 397 | 2-Sep-2021 | MYSURU | 66 | HUNSUR-ELWALA | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 398 | 2-Sep-2021 | MYSURU | 66 | HUNSUR-HOOTAGALLI | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 399 | 2-Sep-2021 | MYSURU | 66 | HV1 | ADDIHALLI_66 | 11:23 | 17:21 | 5:58 | LINE CLEAR AVAILED |
| 400 | 2-Sep-2021 | MYSURU | 66 | HV1 | BYLUKUPPE_66 | 15:19 | 15:23 | 0:03 | TRANSFORMER FAULT |
| 401 | 2-Sep-2021 | MYSURU | 66 | HV1 | DUNDANAHALLI_66 | 12:41 | 13:08 | 0:26 | LINE CLEAR AVAILED |
| 402 | 2-Sep-2021 | MYSURU | 66 | HV1 | GUNDULPET_66 | 12:17 | 12:56 | 0:38 | LINE CLEAR AVAILED |
| 403 | 2-Sep-2021 | MYSURU | 66 | HV1 | HARADANAHALLI(JAK)_66 | 22:18:00 (02/09/2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 404 | 2-Sep-2021 | MYSURU | 66 | KR NAGARA-MYSORE-1 | NO STATIONS EFFECTED | 20:02 18/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 405 | 2-Sep-2021 | MYSURU | 66 | KUSHALNAGARA 220-RAMANTHAPURA 1 | CB HALLI_66 KANGAL_66 ALLURSIDDAPURA_66 RUDRAPATNA_66 | 3:24 | 3:37 | 0:12 | LINE FAULT |
| 406 | 2-Sep-2021 | MYSURU | 66 | MADDUR-KIADB MANDYA | MADDUR_66 SOMANAHALLI_66 | 8:18 | 8:43 | 0:24 | HAND TRIPPED |
| 407 | 2-Sep-2021 | MYSURU | 220 | VAJMANGALA-TK HALLI | NO STATIONS EFFECTED | 7:13 | 19:18 | 12:05 | NFBC ISSUED |
| 408 | 2-Sep-2021 | TUMKUR | 66 | ANTHRASANAHALLI 220kV- KORATAGERE | CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66 | 8:58 | 13:54 | 4:55 | LINE FAULT |
| 409 | 2-Sep-2021 | TUMKUR | 66 | ANTHRASANAHALLI 220kV- KORATAGERE | CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66 | 8:58 | 13:54 | 4:55 | LINE FAULT |
| 410 | 2-Sep-2021 | TUMKUR | 66 | CHITRADURGA 220kV- PANDARAHALLI 1 | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66 | 6:45 | 6:52 | 0:07 | LINE FAULT |
| 411 | 2-Sep-2021 | TUMKUR | 66 | CHITRADURGA 220kV- PANDARAHALLI 1 | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66 | 6:45 | 6:52 | 0:07 | LINE FAULT |
| 412 | 2-Sep-2021 | TUMKUR | 66 | HIRIYUR 220KV-CHALLAKERE | CHALLAKERE_66, SANIKERE_66 | 0:00 | 0:14 | 0:13 | LINE FAULT |
| 413 | 2-Sep-2021 | TUMKUR | 66 | HIRIYUR 220KV-CHALLAKERE | CHALLAKERE_66, SANIKERE_66 | 0:00 | 0:14 | 0:13 | LINE FAULT |
| 414 | 2-Sep-2021 | TUMKUR | 66 | I D HALLI- KODIGENAHALLI | IDHALLY_66 | 6:30 | 8:10 | 1:40 | LINE FAULT |
| 415 | 2-Sep-2021 | TUMKUR | 66 | I D HALLI- KODIGENAHALLI | IDHALLY_66 | 6:30 | 8:10 | 1:40 | LINE FAULT |
| 416 | 2-Sep-2021 | TUMKUR | 66 | I D HALLI- MEDIGESHI | IDHALLY_66 | 6:30 | 7:44 | 1:14 | LINE FAULT |
| 417 | 2-Sep-2021 | TUMKUR | 66 | I D HALLI- MEDIGESHI | IDHALLY_66 | 6:30 | 7:44 | 1:14 | LINE FAULT |
| 418 | 2-Sep-2021 | TUMKUR | 66 | MATHOD- ENERCON1_IPP_66 | ENERCON1_IPP_66 | 5:01 | 5:12 | 0:10 | LINE FAULT |
| 419 | 2-Sep-2021 | TUMKUR | 66 | MATHOD- ENERCON1_IPP_66 | ENERCON1_IPP_66 | 5:01 | 5:12 | 0:10 | LINE FAULT |
| 420 | 2-Sep-2021 | TUMKUR | 66 | NITRAHALLI 66 - CLEAN SOLAR | CLEANMAXSOLAR_IPP_66 | 11:39 | 12:01 | 0:22 | LINE CLEAR AVAILED |
| 421 | 2-Sep-2021 | TUMKUR | 66 | NITRAHALLI 66 - CLEAN SOLAR | CLEANMAXSOLAR_IPP_66 | 12:11 | 12:26 | 0:14 | LINE CLEAR AVAILED |
| 422 | 2-Sep-2021 | TUMKUR | 66 | NITRAHALLI 66 - CLEAN SOLAR | CLEANMAXSOLAR_IPP_66 | 11:39 | 12:01 | 0:22 | LINE CLEAR AVAILED |
| 423 | 2-Sep-2021 | TUMKUR | 66 | NITRAHALLI 66 - CLEAN SOLAR | CLEANMAXSOLAR_IPP_66 | 12:11 | 12:26 | 0:14 | LINE CLEAR AVAILED |
| 424 | 2-Sep-2021 | TUMKUR | 66 | TR-1 | BENKIKERE_66 | 16:01 | 16:12 | 0:11 | HAND TRIPPED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|------------------------------------------|-------------------------------------------|-----------------------|-----------|----------|---------------------------------------|
| 425 | 2-Sep-2021 | TUMKUR | 66 | TR-1 | BENKIKERE_66 | 16:01 | 16:12 | 0:11 | HAND TRIPPED |
| 426 | 2-Sep-2021 | TUMKUR | 66 | TR-2 | BENKIKERE_66 | 16:00 | 16:12 | 0:11 | HAND TRIPPED |
| 427 | 2-Sep-2021 | TUMKUR | 66 | TR-2 | BENKIKERE_66 | 16:00 | 16:12 | 0:11 | HAND TRIPPED |
| 428 | 2-Sep-2021 | TUMKUR | 66 | TR-3 | HARIYABBE_66 | 17:14 | 17:59 | 0:45 | LINE CLEAR AVAILED |
| 429 | 2-Sep-2021 | TUMKUR | 66 | TR-3 | HARIYABBE_66 | 17:14 | 17:59 | 0:45 | LINE CLEAR AVAILED |
| 430 | 2-Sep-2021 | TUMKUR | 110 | TR-1 | KATHRIKEHAL_110 | 12:17 | 12:51 | 0:34 | MAIN SUPPLY FAILURE |
| 431 | 2-Sep-2021 | TUMKUR | 110 | TR-1 | KATHRIKEHAL_110 | 12:17 | 12:51 | 0:34 | MAIN SUPPLY FAILURE |
| 432 | 2-Sep-2021 | TUMKUR | 220 | KDBVNP_PGCL | KDBVNP_220 | 11:04 | 17:34 | 6:29 | NFBC ISSUED |
| 433 | 2-Sep-2021 | TUMKUR | 220 | KDBVNP_PGCL | KDBVNP_220 | 11:04 | 17:34 | 6:29 | NFBC ISSUED |
| 434 | 2-Sep-2021 | TUMKUR | 400 | GUTUR_400-BEERANAHALLI-1 | GUTUR_400 | 10:18 | 16:33 | 6:15 | LINE CLEAR AVAILED |
| 435 | 2-Sep-2021 | TUMKUR | 400 | GUTUR_400-BEERANAHALLI-1 | GUTUR_400 | 10:18 | 16:33 | 6:15 | LINE CLEAR AVAILED |
| 436 | 3-Sep-2021 | BAGALKOT | 66 | HONNALLI(BANUVALLI)-HARIHAR HOSPET | STATION NOT AFFECTED HARIHAR HOSPET_66 | 12:45 (04.09.2020) | | | LINE OPEN:LINE CLEAR AVAILED |
| 437 | 3-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV1 | KALADAGI_110 | 17:39 | 17:46 | 0:07 | HAND TRIPPED |
| 438 | 3-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | BANAHATTI_110 | 17:12 (29.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 439 | 3-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | KULAGERI CROSS_110 | 11:52 | 14:20 | 2:28 | LINE CLEAR AVAILED |
| 440 | 3-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | KUD DHARWAD_110 | 19:10 | 19:15 | 0:05 | TRANSFORMER FAULT |
| 441 | 3-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | YELPARHATTI_110 | 13:00 | 13:35 | 0:35 | TRANSFORMER FAULT |
| 442 | 3-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV3 | JAMAKHANDI-110 | 10:30 | 17:05 | 6:35 | LINE CLEAR AVAILED |
| 443 | 3-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV4 | SADALAGA_110 | 12:13 | 13:25 | 1:12 | LINE CLEAR AVAILED |
| 444 | 3-Sep-2021 | BAGALKOT | 110 | 110/33KV,HV3 | ZALKI_110 | 14:57 | 14:59 | 0:02 | HAND TRIPPED |
| 445 | 3-Sep-2021 | BAGALKOT | 110 | 110/33KV,HV3 | HORTH_33 ZALKI_110 | 15:25 | 15:55 | 0:30 | HAND TRIPPED |
| 446 | 3-Sep-2021 | BAGALKOT | 110 | AINAPUR-ATHANI SUGARS | AINAPUR_110 | 6:11 | 6:30 | 0:19 | LINE FAULT |
| 447 | 3-Sep-2021 | BAGALKOT | 110 | AMBEWADI-HALIYAL(NK1) | STATION NOT AFFECTED AMBEWADI_220 | 9:54 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 448 | 3-Sep-2021 | BAGALKOT | 110 | AMBEWADI-KAVALWADA(NK2) | STATION NOT AFFECTED AMBEWADI_220 | 9:52 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 449 | 3-Sep-2021 | BAGALKOT | 110 | BIJAPUR22-BAGEWADI(ENERCON) | BIJAPUR_220 | 6:21 | 6:37 | 0:16 | LINE FAULT |
| 450 | 3-Sep-2021 | BAGALKOT | 110 | CHIKKODI220-DKSSK | STATION NOT AFFECTED CHIKKODI_220 | 12:03 | 14:13 | 2:10 | LINE CLEAR AVAILED |
| 451 | 3-Sep-2021 | BAGALKOT | 110 | CHIKKODI-SANKESHWAR | STATION NOT AFFECTED CHIKKODI_220 | 15:59 | 16:02 | 0:03 | LINE FAULT |
| 452 | 3-Sep-2021 | BAGALKOT | 110 | GOPANKOPPA-BIDNAL- NVLKD(NARAGUND) | STATION NOT AFFECTED GOPANAKOPPA_110 | 18:15 (24.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 453 | 3-Sep-2021 | BAGALKOT | 110 | KONNUR-KERUR | KONNUR_110 | 13:30 | 13:35 | 0:05 | HAND TRIPPED |
| 454 | 3-Sep-2021 | BAGALKOT | 110 | RANEBENNUR220- HONNATTI (AREMALLAPUR) | NO STATION AFFECTED RANEBENNUR_220 | 13:16 (17.11.2020) | | | LINE OPEN:LINE FAULT |
| 455 | 3-Sep-2021 | BAGALKOT | 220 | 220/110KV,HV2 & LV2 | BIJAPUR_220 | 6:21 | 6:33 | 0:12 | TRANSFORMER FAULT |
| 456 | 3-Sep-2021 | BAGALKOT | 220 | AMBEWADI-PONDA2 | AMBEWADI_220 | 9:22 | 15:18 | 5:56 | LINE CLEAR AVAILED |
| 457 | 3-Sep-2021 | BAGALKOT | 220 | BELGAUM -CHIKKODI 2 | BELGAUM_220 | 9:31 (26.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 458 | 3-Sep-2021 | BAGALKOT | 220 | BIDNAL-HARTHI1 | STATION NOT AFFECTED BIDNAL_220 | 18:43 (01.08.2021) | | | LINE OPEN:LINE FAULT |
| 459 | 3-Sep-2021 | BAGALKOT | 220 | GADAG-HARTI1 | STATION NOT AFFECTED GADAG_220 | 9:52 (24.08.2021) | | | LINE OPEN:LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|-----------------------------------------|------------------------------------------------------------------------|-----------------------|---------------------|----------|---------------------------------------|
| 460 | 3-Sep-2021 | BAGALKOT | 220 | HUBLI-NAGJHARI2 | STATION NOT AFFECTED HUBLI_220 | 18:37 (02.09.221) | 19:0 (3.09.2021) | 1:23HRS | LINE CHARGED |
| 461 | 3-Sep-2021 | BAGALKOT | 220 | MAHALINGAPUR-VAJRAMATTI 2 | STATION NOT AFFECTED MAHALINGAPUR_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 462 | 3-Sep-2021 | BAGALKOT | 220 | NARENDRA-AMBEWADI2 | STATION NOT AFFECTED NARENDRA_220 | 17:22 (30.03.2021) | | | LINE OPEN:LINE FAULT |
| 463 | 3-Sep-2021 | BAGALKOT | 220 | SIRSI-HUBLI 1 | SIRSI_220 | 17:59 (30.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 464 | 3-Sep-2021 | BAGALKOT | 220 | VAJRAMATTI- MAHALINGAPUR1 | STATION NOT AFFECTED VAJRAMATTI_220 | 16:17 (23.02.2021) | | | LINE OPEN:LINE FAULT |
| 465 | 3-Sep-2021 | BAGALKOT | 220 | VAJRAMATTI -MAHALINGAPUR2 | STATION NOT AFFECTED VAJRAMATTI_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 466 | 3-Sep-2021 | BENGALURU | 66 | DEVANAHALLI - DB PURA 2 | DEVANAHALLI | 16:14 | 19:11 | 2:56 | LINE CLEAR AVAILED |
| 467 | 3-Sep-2021 | BENGALURU | 66 | HV1 | GUDEMARAMAHALLI | 8:34 | 8:55 | 0:20 | TRANSFORMER FAULT |
| 468 | 3-Sep-2021 | BENGALURU | 66 | HV1 | DODDABELAVANGALA | 3:40 | 4:33 | 0:53 | TRANSFORMER FAULT |
| 469 | 3-Sep-2021 | BENGALURU | 66 | HV1 | KIADB HARDWARE PARK DEVANAHALLI 220 | 0:22 | 0:24 | 0:02 | TRANSFORMER FAULT |
| 470 | 3-Sep-2021 | BENGALURU | 66 | HV1 | KIADB HARDWARE PARK DEVANAHALLI 220 | 10:19 | 10:33 | 0:13 | TRANSFORMER FAULT |
| 471 | 3-Sep-2021 | BENGALURU | 66 | HV1 | KIADB HARDWARE PARK DEVANAHALLI 220 | 2:44 | 2:54 | 0:10 | TRANSFORMER FAULT |
| 472 | 3-Sep-2021 | BENGALURU | 66 | HV1 | Y HUNSENHALLI | 12:12 | 12:52 | 0:40 | LINE CLEAR AVAILED |
| 473 | 3-Sep-2021 | BENGALURU | 66 | HV2 | DEVARABISANAHALLI | 22:14 | 22:30 | 0:16 | TRANSFORMER FAULT |
| 474 | 3-Sep-2021 | BENGALURU | 66 | HV2 | RMV | 14:41 | 14:42 | 0:01 | LINE CLEAR AVAILED |
| 475 | 3-Sep-2021 | BENGALURU | 66 | HV2 | GUDEMARAMAHALLI | 9:00 | 9:10 | 0:10 | TRANSFORMER FAULT |
| 476 | 3-Sep-2021 | BENGALURU | 66 | HV2 | CHAKAVELU | 14:56 | 15:00 | 0:03 | LINE CLEAR AVAILED |
| 477 | 3-Sep-2021 | BENGALURU | 66 | HV2 | HUKUNDA | 11:50 | 12:00 | 0:09 | TRANSFORMER FAULT |
| 478 | 3-Sep-2021 | BENGALURU | 66 | HV2 | KANAKAPURA 66 | 4:02 | 4:16 | 0:14 | TRANSFORMER FAULT |
| 479 | 3-Sep-2021 | BENGALURU | 66 | HV2 | DODDABELAVANGALA | 0:07(3-9-2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 480 | 3-Sep-2021 | BENGALURU | 66 | HV2 | SARJAPURA 220 | 23:54(03-9-21) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 481 | 3-Sep-2021 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NO STATION AFFECTED | 18:34 | 18:43 | 0:08 | LINE FAULT |
| 482 | 3-Sep-2021 | BENGALURU | 66 | NAGNATHPURA 220 - ELECTRONIC CITY | ELECTRONIC CITY, INFOSYS(EHT) | 5:57 | 6:37 | 0:40 | LINE CLEAR AVAILED |
| 483 | 3-Sep-2021 | BENGALURU | 66 | NAGNATHPURA 220 - ELECTRONIC CITY P2 S1 | ELECTRONIC CITY P2 S1 | 5:57 | 6:38 | 0:41 | LINE CLEAR AVAILED |
| 484 | 3-Sep-2021 | BENGALURU | 66 | NAGNATHPURA 220 - ELECTRONIC CITY P2 S2 | ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA | 5:57 | 6:35 | 0:38 | LINE CLEAR AVAILED |
| 485 | 3-Sep-2021 | BENGALURU | 220 | HSR LAYOUT 220 - NAGNATHPURA 220 | NAGNATHPURA 220 | 5:57 | 6:30 | 0:33 | LINE FAULT |
| 486 | 3-Sep-2021 | BENGALURU | 220 | HV2 | BEGUR 220 | 11:53 | 13:14 | 1:21 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|-----------------------------------|---------------------------------------------------------------|-------------------|-----------|----------|-------------------------------------|
| 487 | 3-Sep-2021 | BENGALURU | 220 | NAGNATHPURA 220 - SOMANAHALLI 220 | NAGNATHPURA 220 | 5:57 | 6:33 | 0:36 | LINE FAULT |
| 488 | 3-Sep-2021 | BENGALURU | 220 | SOMANAHALLI 220 - NAGNATHPURA 220 | NAGNATHPURA 220 | 5:57 | 6:33 | 0:36 | LINE FAULT |
| 489 | 3-Sep-2021 | GULBARGA | 110 | ALIPUR-BELLARY SOUTH | BELLARY SOUTH_110,HALAKUNDI_110 | 18:06 | 18:14 | 0:08 | LINE FAULT |
| 490 | 3-Sep-2021 | GULBARGA | 110 | ALIPUR-BELLARY SOUTH | BELLARY SOUTH_110,HALAKUNDI_110 | 18:59 | 19:34 | 0:35 | LINE FAULT |
| 491 | 3-Sep-2021 | GULBARGA | 110 | GULBARGASOUTH-GULBARGA UNIVERSITY | GULBARGAUNIVERSITY_110 | 18:35(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 492 | 3-Sep-2021 | GULBARGA | 110 | GURMITKAL-KONKAL | KONKAL_110 | 10:35 | 10:40 | 0:05 | LINE FAULT |
| 493 | 3-Sep-2021 | GULBARGA | 110 | HV1,HV2 | MYLAR_110 | 17:26 | 17:49 | 0:23 | LINE CLEAR AVAILED |
| 494 | 3-Sep-2021 | GULBARGA | 110 | HV2 | VALKAMDINNI_110 | 11:15(31.08.2021) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 495 | 3-Sep-2021 | GULBARGA | 110 | HV2 | TEKKALKOTE_110 | 18:00 | 18:05 | 0:05 | TRANSFORMER FAULT |
| 496 | 3-Sep-2021 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 11:50 | 11:55 | 0:05 | TRANSFORMER FAULT |
| 497 | 3-Sep-2021 | GULBARGA | 110 | KAPNOOR-GULBARGAWEST | GULBARGAWEST_110,GULBARGASOUTH_110 | 22:13 | 22:20 | 0:07 | LINE FAULT |
| 498 | 3-Sep-2021 | GULBARGA | 110 | MALLAT-BYGWAT2 | ADAVI AMARESHWAR_110 | 20:11 | 20:22 | 0:11 | LINE FAULT |
| 499 | 3-Sep-2021 | GULBARGA | 110 | MARGUTTI-KAPNOOR | MARGUTTI_110 | 18:15 | 18:20 | 0:05 | LINE CLEAR AVAILED |
| 500 | 3-Sep-2021 | GULBARGA | 110 | MARGUTTI-KAPNOOR | MARGUTTI_110 | 18:30 | 18:40 | 0:10 | LINE CLEAR AVAILED |
| 501 | 3-Sep-2021 | GULBARGA | 110 | MASKI-HATTI | HATTI_110 | 1:37 | 7:20 | 5:43 | LINE FAULT |
| 502 | 3-Sep-2021 | GULBARGA | 110 | MASKI-SINDHANOOR | MASKI_110 | 1:37 | 1:42 | 0:05 | LINE FAULT |
| 503 | 3-Sep-2021 | GULBARGA | 110 | MASKI-SINDHANOOR | MASKI_110 | 21:50 | 21:56 | 0:06 | MAIN SUPPLY FAILURE |
| 504 | 3-Sep-2021 | GULBARGA | 110 | METRI-ALIPUR | METRI_110 | 15:35 | 15:45 | 0:10 | MAIN SUPPLY FAILURE |
| 505 | 3-Sep-2021 | GULBARGA | 110 | MUDDAPUR-SINDHANOOR | MUDDAPURA_110 | 21:50 | 21:53 | 0:03 | MAIN SUPPLY FAILURE |
| 506 | 3-Sep-2021 | GULBARGA | 110 | MUNIRABAD-SINDHANOOR1 | VENKATAGIRI_110,GANGAVATHI_110,DR NAGAR_110,KARATAGI_110 | 5:44 | 6:03 | 0:19 | LINE FAULT |
| 507 | 3-Sep-2021 | GULBARGA | 110 | NALWAR-SHAHABAD | NALWAR_110,JEWARGI_110 | 0:58 | 1:06 | 0:08 | MAIN SUPPLY FAILURE |
| 508 | 3-Sep-2021 | GULBARGA | 110 | RAICHUR-SHAHAPUR1&2 | GABBUR_110,DEODURGA_110,GOOGLE_110 | 23:08 | 23:20 | 0:12 | LINE FAULT |
| 509 | 3-Sep-2021 | GULBARGA | 110 | RAICHUR-SINDHANOOR1(IDLE LINE) | SINDHANOOR_110 | 23:23(03.09.2021) | | | LINE OPEN:LINE FAULT |
| 510 | 3-Sep-2021 | GULBARGA | 110 | SEDAM-GURMITKAL | GURMITKAL_110,KONKAL_110 | 2:55 | 3:00 | 0:05 | LINE FAULT |
| 511 | 3-Sep-2021 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 14:55(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 512 | 3-Sep-2021 | GULBARGA | 110 | SHAHABAD-GULBARGA UNIVERSITY2 | GULBARGA UNIVERSITY_110 | 09:17(14.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 513 | 3-Sep-2021 | GULBARGA | 110 | SHAHAPUR-KBJNL | KBJNL_110 | 11:38 | 13:42 | 2:04 | LINE CLEAR AVAILED |
| 514 | 3-Sep-2021 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110,UGARSUGAR_110 | 19:41 | 19:55 | 0:14 | LINE FAULT |
| 515 | 3-Sep-2021 | GULBARGA | 110 | SINDHANOOR-MUNIRABAD2 | MUKUNDA_110,KAMPLI_110,YERDONA_110, SRNAGAR_110,MALLAPURA_110 | 11:40 | 11:50 | 0:10 | LINE FAULT |
| 516 | 3-Sep-2021 | GULBARGA | 110 | VALKAMDINNI-SINDHANOOR | VALKAMDINNI_110 | 21:50 | 22:10 | 0:20 | MAIN SUPPLY FAILURE |
| 517 | 3-Sep-2021 | GULBARGA | 110 | YELBURGA-TALT_SLR | YELBURGA_110 | 18:45(03.09.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 518 | 3-Sep-2021 | GULBARGA | 220 | ALIPUR-BTPS | BTPS_220 | 15:34 | 17:04 | 1:30 | HAND TRIPPED |
| 519 | 3-Sep-2021 | GULBARGA | 220 | ALIPUR-RAGALAPADU | RAGALAPADU_110 | 15:34 | 15:54 | 0:20 | HAND TRIPPED |
| 520 | 3-Sep-2021 | GULBARGA | 220 | HV1 | SHAHABAD_220 | 0:55 | 1:20 | 0:25 | TRANSFORMER FAULT |
| 521 | 3-Sep-2021 | GULBARGA | 220 | LINGASUGUR-RTPS2 | LINGASUGUR_220 | 5:17 | 5:35 | 0:18 | LINE FAULT |
| 522 | 3-Sep-2021 | GULBARGA | 220 | SEDAM-RTPS2 | SEDAM_220 | 2:35 | 3:10 | 0:35 | LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|-------------------------|----------------------|----------------------|-----------------|-----------|------------------------------|
| 523 | 3-Sep-2021 | GULBARGA | 400 | BTPS-GUTTUR | GUTTUR_400 | 13:10 | 13:25 | 0:15 | LINE FAULT |
| 524 | 3-Sep-2021 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 12:00 | 12:20 | 0:20 | LINE CLEAR AVAILED |
| 525 | 3-Sep-2021 | HASSAN | 66 | DODDAHA-HOOTGALLI | DODDAHALLY_66 | 7:46 | 7:48 | 0:02 | LINE FAULT |
| 526 | 3-Sep-2021 | HASSAN | 66 | DODDAKA-KRNAGARA | DODDAKADANUR_66 | 7:14 | 7:41 | 0:27 | LINE FAULT |
| 527 | 3-Sep-2021 | HASSAN | 66 | HNPR2-HASS3 | HOLENARASIPURA_220 | 23:52(2.9.2021) | 0:01(3.9.2021) | 09:00hrs | LINE CHARGED |
| 528 | 3-Sep-2021 | HASSAN | 66 | HNPR2-HASS3 | HOLENARASIPURA_220 | 6:59 | 8:27 | 1:28 | LINE CLEAR AVAILED |
| 529 | 3-Sep-2021 | HASSAN | 66 | HV1 | MALLAPURA_66 | 11:01 | 11:28 | 0:27 | LINE CLEAR AVAILED |
| 530 | 3-Sep-2021 | HASSAN | 66 | HV1 | MOSALEHOSAHALLY_66 | 0:35 | 0:48 | 0:13 | LOAD CHANGE OVER |
| 531 | 3-Sep-2021 | HASSAN | 66 | HV1 | MOSALEHOSAHALLY_66 | 8:31 | 8:38 | 0:07 | LOAD CHANGE OVER |
| 532 | 3-Sep-2021 | HASSAN | 66 | HV1 | SALAGAME_66 | 10:14 | 17:17 | 7:03 | LINE CLEAR AVAILED |
| 533 | 3-Sep-2021 | HASSAN | 66 | HV2 | ARAKALGUD_66 | 1:58 | 2:08 | 0:10 | TRANSFORMER FAULT |
| 534 | 3-Sep-2021 | HASSAN | 66 | HV2 | MALLAPURA_66 | 11:01 | 11:29 | 0:28 | LINE CLEAR AVAILED |
| 535 | 3-Sep-2021 | HASSAN | 66 | HV2 | SALAGAME_66 | 10:14 | 18:26 | 8:12 | LINE CLEAR AVAILED |
| 536 | 3-Sep-2021 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 8:29(7.8.2021) | 13:04(3.9.2021) | 604:35hrs | LINE CHARGED |
| 537 | 3-Sep-2021 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 13:20 | 15:17 | 1:57 | LINE CLEAR AVAILED |
| 538 | 3-Sep-2021 | HASSAN | 66 | MALLAPUR-SHIMOGA | MALLAPURA_66 | 11:04 | 11:28 | 0:24 | LINE CLEAR AVAILED |
| 539 | 3-Sep-2021 | HASSAN | 66 | MOSALEH-HNPRA | MOSALEHOSAHALLY_66 | 0:10 | 8:38 | 8:28 | HAND TRIPPED |
| 540 | 3-Sep-2021 | HASSAN | 66 | SALAGAM-HIREMANGLUR | SALAGAME_66 | 10:14 | 17:12 | 6:58 | LINE CLEAR AVAILED |
| 541 | 3-Sep-2021 | HASSAN | 66 | UDDURKO-CHIKMANGLUR | UDDURKOPLU_66 | 10:14(3.9.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 542 | 3-Sep-2021 | HASSAN | 110 | HV1 | HULICAL_110 | 9:11 | 16:51 | 7:40 | LINE CLEAR AVAILED |
| 543 | 3-Sep-2021 | HASSAN | 110 | HV1 | JAVAGA_66 | 11:31 | 11:53 | 0:22 | HAND TRIPPED |
| 544 | 3-Sep-2021 | HASSAN | 110 | HV2 | NAVUNDA_110 | 12:46 | 13:08 | 0:22 | LINE CLEAR AVAILED |
| 545 | 3-Sep-2021 | HASSAN | 110 | HV2 | SAGARA_110 | 9:29 | 17:55 | 8:26 | LINE CLEAR AVAILED |
| 546 | 3-Sep-2021 | HASSAN | 110 | LPH-MGHE 1 | lph_gen | 11:13 (20.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 547 | 3-Sep-2021 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 12:30(02.09.2021) | 14:46(3.9.2021) | 26:16hrs | LINE CHARGED |
| 548 | 3-Sep-2021 | HASSAN | 220 | KAVOOR-KEMAR1 | KAVOOR_220 | 10:02 | 16:47 | 6:45 | LINE CLEAR AVAILED |
| 549 | 3-Sep-2021 | HASSAN | 220 | KEMAR-Kavoor2 | KEMAR_220 | 20:45 | 21:58 | 1:13 | LINE CLEAR AVAILED |
| 550 | 3-Sep-2021 | HASSAN | 220 | MRSSHM-DVG2 | MRSMSG_220 | 17:08 (30.08.2021) | | | LINE OPEN:LINE FAULT |
| 551 | 3-Sep-2021 | HASSAN | 220 | MRSSHM-SHARAVATHY3 | MRSMSG_220 | 15:29 | 17:53 | 2:24 | LINE FAULT |
| 552 | 3-Sep-2021 | HASSAN | 220 | MSEZ-KAVOOR2 | MSEZ_220 | 10:03 | 16:47 | 6:44 | NFBC ISSUED |
| 553 | 3-Sep-2021 | HASSAN | 220 | MSEZ-KEMAR2 | MSEZ_220 | 20:46 | 21:58 | 1:12 | NFBC ISSUED |
| 554 | 3-Sep-2021 | HASSAN | 220 | SHRAVTY-SHIMOGA3 | sharavathy_gen | 15:29 | 17:53 | 2:24 | LINE FAULT |
| 555 | 3-Sep-2021 | HASSAN | 220 | SHRAVTY-SIRISI 1 | sharavathy_gen | 21:22(2.09.2021) | 7:56(3.9.2021) | 10:34hrs | LINE CHARGED |
| 556 | 3-Sep-2021 | HASSAN | 220 | TALAGU-STRP2 | TALAGUPPA_400 | 12:30(2.9.2021) | 14:45(3.9.2021) | 26:15hrs | LINE CHARGED |
| 557 | 3-Sep-2021 | HASSAN | 400 | UPCL-HASSAN2 | upcl_gen | 23:03(3.9.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 558 | 3-Sep-2021 | HASSAN | 400 | UPCL-HASSAN2 | upcl_gen | 22:54(2.9.2021) | 7:51(3.9.2021) | 8:57hrs | LINE CHARGED |
| 559 | 3-Sep-2021 | MYSURU | 66 | AKKIHEBBAL-KAVERI HYDRO | NO STATIONS EFFECTED | 12:21 | 12:35 | 0:14 | LINE FAULT |
| 560 | 3-Sep-2021 | MYSURU | 66 | CHUNKANAKATTE-KR NAGARA | NO STATIONS EFFECTED | 8:20 (19/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 561 | 3-Sep-2021 | MYSURU | 66 | CR NAGARA-YALANDUR | NO STATIONS EFFECTED | 7:00 | 7:08 | 0:08 | LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|---------|---------|---------------------------|-------------------------------------------|-----------------------|----------------------|----------|------------------------------|
| 562 | 3-Sep-2021 | MYSURU | 66 | HARVEY-CR NAGARA | NO STATIONS EFFECTED | 9:24:49 AM (3/9/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 563 | 3-Sep-2021 | MYSURU | 66 | HUNSUR-ELWALA | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 564 | 3-Sep-2021 | MYSURU | 66 | HUNSUR-HOOTAGALLI | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 565 | 3-Sep-2021 | MYSURU | 66 | HV1 | ARAKERE_66 | 18:18 | 19:23 | 1:04 | LINE CLEAR AVAILED |
| 566 | 3-Sep-2021 | MYSURU | 66 | HV1 | JAKKANAHALLY_66 | 10:55 | 12:32 | 1:37 | LINE CLEAR AVAILED |
| 567 | 3-Sep-2021 | MYSURU | 66 | HV1 | KIRUGAVALU_66 | 14:02 | 14:46 | 0:44 | LINE CLEAR AVAILED |
| 568 | 3-Sep-2021 | MYSURU | 66 | HV1 | MANDGERE_66 | 12:30 | 12:40 | 0:10 | HAND TRIPPED |
| 569 | 3-Sep-2021 | MYSURU | 66 | HV1 | HARADANAHALLI(JAK)_66 | 22:18:00 (02/09/2021) | 5:56:00 (03/09/2021) | 19:37HRS | TRANSFORMER CHARGED |
| 570 | 3-Sep-2021 | MYSURU | 66 | HV2 | HARADANAHALLI(JAK)_66 | 17:55 | 18:30 | 0:35 | LINE CLEAR AVAILED |
| 571 | 3-Sep-2021 | MYSURU | 66 | HV2 | KMDODDI_66 | 15:26 | 15:54 | 0:28 | TRANSFORMER FAULT |
| 572 | 3-Sep-2021 | MYSURU | 66 | HV2 | NAGAMANGALA_66 | 16:41 | 16:55 | 0:14 | HAND TRIPPED |
| 573 | 3-Sep-2021 | MYSURU | 66 | HV2 | SANTHEBACHALLI_66 | 0:32 | 0:42 | 0:10 | TRANSFORMER FAULT |
| 574 | 3-Sep-2021 | MYSURU | 66 | KOLLEGALA-MADHUVANAHALLI | NO STATIONS EFFECTED | 15:51 | 15:57 | 0:06 | LINE FAULT |
| 575 | 3-Sep-2021 | MYSURU | 66 | KOLLEGALA-SATHEGALA | SATHEGALA_66 | 11:20 | 11:34 | 0:13 | LINE FAULT |
| 576 | 3-Sep-2021 | MYSURU | 66 | KR NAGARA-MYSORE-1 | NO STATIONS EFFECTED | 20:02 18/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 577 | 3-Sep-2021 | MYSURU | 66 | MALLAVALLI-TK HALLI | MALAVALLI_66 | 14:24 | 14:27 | 0:03 | LINE CLEAR AVAILED |
| 578 | 3-Sep-2021 | MYSURU | 66 | PERIYAPATNA-HUNSUR | KAMPLAPURA_66 | 6:37 | 6:46 | 0:08 | LINE FAULT |
| 579 | 3-Sep-2021 | MYSURU | 66 | SANTESARGUR-KADAKOLA 1 | ANTHARSANTHE_66 HDKOTE_66 | 13:00 | 13:35 | 0:35 | NFBC ISSUED |
| 580 | 3-Sep-2021 | MYSURU | 66 | SFC SIVA-10MW | NO STATIONS EFFECTED | 11:22 | 11:27 | 0:05 | LINE FAULT |
| 581 | 3-Sep-2021 | MYSURU | 66 | TUBINKERE-ARAKERE | ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 | 11:00 | 12:25 | 1:25 | LINE CLEAR AVAILED |
| 582 | 3-Sep-2021 | TUMKUR | 66 | BENNEHALLI-RBPL SOLAR | BENNEHALLI_66 | 21:25 | 22:37 | 1:12 | LINE FAULT |
| 583 | 3-Sep-2021 | TUMKUR | 66 | BENNEHALLI-RBPL SOLAR | BENNEHALLI_66 | 21:25 | 22:37 | 1:12 | LINE FAULT |
| 584 | 3-Sep-2021 | TUMKUR | 66 | HANAGAL-GUDEKOTE(THALLAK) | HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66 | 6:00 | 6:45 | 0:45 | LINE FAULT |
| 585 | 3-Sep-2021 | TUMKUR | 66 | HANAGAL-GUDEKOTE(THALLAK) | HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66 | 6:00 | 6:45 | 0:45 | LINE FAULT |
| 586 | 3-Sep-2021 | TUMKUR | 66 | HARIYABBE-CHIKKABANAGERE | HARIYABBE_66 | 13:51 | 14:22 | 0:31 | HAND TRIPPED |
| 587 | 3-Sep-2021 | TUMKUR | 66 | HARIYABBE-CHIKKABANAGERE | HARIYABBE_66 | 13:51 | 14:22 | 0:31 | HAND TRIPPED |
| 588 | 3-Sep-2021 | TUMKUR | 66 | HIRIYUR 220kv- PR PURA | PR PURA_66 | 13:42 | 14:10 | 0:28 | LINE FAULT |
| 589 | 3-Sep-2021 | TUMKUR | 66 | HIRIYUR 220kv- PR PURA | PR PURA_66 | 13:42 | 14:10 | 0:28 | LINE FAULT |
| 590 | 3-Sep-2021 | TUMKUR | 66 | PKOTE-HARIYABBE | PKOTE_66 | 13:40 | 14:19 | 0:39 | LINE FAULT |
| 591 | 3-Sep-2021 | TUMKUR | 66 | PKOTE-HARIYABBE | PKOTE_66 | 13:40 | 14:19 | 0:39 | LINE FAULT |
| 592 | 3-Sep-2021 | TUMKUR | 66 | THALLAK 220kv - BGKERE 1 | BGKERE 1 | 10:30 | 11:42 | 1:12 | LINE CLEAR AVAILED |
| 593 | 3-Sep-2021 | TUMKUR | 66 | THALLAK 220kv - BGKERE 1 | BGKERE 1 | 10:30 | 11:42 | 1:12 | LINE CLEAR AVAILED |
| 594 | 3-Sep-2021 | TUMKUR | 66 | THALLAK 220kv - BGKERE 2 | BGKERE 2 | 5:56 | 7:43 | 1:47 | LINE FAULT |
| 595 | 3-Sep-2021 | TUMKUR | 66 | THALLAK 220kv - BGKERE 2 | BGKERE 2 | 5:56 | 7:43 | 1:47 | LINE FAULT |
| 596 | 3-Sep-2021 | TUMKUR | 66 | TR-1 | TMTP_66 | 12:09 | 13:45 | 1:36 | LINE CLEAR AVAILED |
| 597 | 3-Sep-2021 | TUMKUR | 66 | TR-1 | TMTP_66 | 12:09 | 13:45 | 1:36 | LINE CLEAR AVAILED |
| 598 | 3-Sep-2021 | TUMKUR | 66 | TR-1(LV-1) | THALLAK_220 | 5:56 | 6:40 | 0:44 | TRANSFORMER FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|------------------------------------|------------------------------------------------|-----------------------|-----------|----------|------------------------------------|
| 599 | 3-Sep-2021 | TUMKUR | 66 | TR-1(LV-1) | THALLAK_220 | 5:56 | 6:40 | 0:44 | TRANSFORMER FAULT |
| 600 | 3-Sep-2021 | TUMKUR | 66 | TR-2 | TMTP_66 | 12:09 | 13:46 | 1:36 | LINE CLEAR AVAILED |
| 601 | 3-Sep-2021 | TUMKUR | 66 | TR-2 | TMTP_66 | 12:09 | 13:46 | 1:36 | LINE CLEAR AVAILED |
| 602 | 3-Sep-2021 | TUMKUR | 66 | TR-3 | HONNALLI_66 | 4:04 | 5:04 | 1:00 | LINE CLEAR AVAILED |
| 603 | 3-Sep-2021 | TUMKUR | 66 | TR-3 | HONNALLI_66 | 4:04 | 5:04 | 1:00 | LINE CLEAR AVAILED |
| 604 | 3-Sep-2021 | TUMKUR | 110 | TR-1 | TURUVEKERE_110 | 1:20 | 2:14 | 0:54 | TRANSFORMER FAULT |
| 605 | 3-Sep-2021 | TUMKUR | 110 | TR-1 | TURUVEKERE_110 | 1:20 | 2:14 | 0:54 | TRANSFORMER FAULT |
| 606 | 3-Sep-2021 | TUMKUR | 110 | TR-2 | CHIKKANAYAKANAHALLI_110 | 19:16 | 19:40 | 0:24 | TRANSFORMER FAULT |
| 607 | 3-Sep-2021 | TUMKUR | 110 | TR-2 | CHIKKANAYAKANAHALLI_110 | 19:16 | 19:40 | 0:24 | TRANSFORMER FAULT |
| 608 | 3-Sep-2021 | TUMKUR | 220 | TR-1 | THALLAK_220 | 5:56 | 6:30 | 0:34 | TRANSFORMER FAULT |
| 609 | 3-Sep-2021 | TUMKUR | 220 | TR-1 | THALLAK_220 | 5:56 | 6:30 | 0:34 | TRANSFORMER FAULT |
| 610 | 3-Sep-2021 | TUMKUR | 400 | GUTTUR 400KV- BEERANAHALLI2 | BEERANAHALLI2 | 10:20 | 16:48 | 6:28 | LINE CLEAR AVAILED |
| 611 | 3-Sep-2021 | TUMKUR | 400 | GUTTUR 400KV- BEERANAHALLI2 | BEERANAHALLI2 | 10:20 | 16:48 | 6:28 | LINE CLEAR AVAILED |
| 612 | 4-Sep-2021 | BAGALKOT | 66 | HONNALLI(BANUVALLI)-HARIHAR HOSPET | STATION NOT AFFECTED HARIHAR HOSPET_66 | 12:45 (04.09.2020) | | | LINE OPEN:LINE CLEAR AVAILED |
| 613 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1 | SHIRGOAN_110 | 21:02 | 21:16 | 0:14 | TRANSFORMER FAULT |
| 614 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1 | GIRISAGAR_110 | 10:10 | 10:15 | 0:05 | TRANSFORMER FAULT |
| 615 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV2 | MUKARTIHAL_110 | 7:51 | 8:00 | 0:09 | TRANSFORMER FAULT |
| 616 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV2 | KUDACHI_110 | 17:36 | 18:15 | 0:39 | LINE CLEAR AVAILED |
| 617 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV1 | GULEDGUDD_110 | 11:28 | 12:15 | 0:47 | LINE CLEAR AVAILED |
| 618 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV1 | HIREKERUR_110 | 13:30 | 13:35 | 0:05 | HAND TRIPPED |
| 619 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV1 | HUDLI_110 | 9:55 | 15:00 | 5:05 | LINE CLEAR AVAILED |
| 620 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | BANAHATTI_110 | 17:12 (29.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 621 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | AREMALLAPUR_110 | 11:05 | 18:35 | 7:30 | LINE CLEAR AVAILED |
| 622 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | JAMAKHANDI_110 | 11:29 | 12:15 | 0:46 | LINE CLEAR AVAILED |
| 623 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV3 | JAMAKHANDI_110 | 11:10 | 11:15 | 0:05 | LINE CLEAR AVAILED |
| 624 | 4-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV4 | BAGALKOT_220 | 17:03 | 17:06 | 0:03 | TRANSFORMER FAULT |
| 625 | 4-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV2 | HUBLI_220 | 11:55 | 18:53 | 6:58 | LINE CLEAR AVAILED |
| 626 | 4-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV2 | MATTIHAL_110, KOLAR WATER SUPPLY_33, LIS_33 | 20:29 | 21:13 | 0:44 | TRANSFORMER FAULT |
| 627 | 4-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV2 | MATTIHAL_110, KOLAR WATER SUPPLY_33, LIS_33 | 21:17 | 21:20 | 0:03 | TRANSFORMER FAULT |
| 628 | 4-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV2 | MATTIHAL_110, KOLAR WATER SUPPLY_33, LIS_33 | 21:20 | 22:24 | 1:04 | TRANSFORMER FAULT |
| 629 | 4-Sep-2021 | BAGALKOT | 110 | 110/33KV,HV2 | GULEDGUDD_110 & KAMATAGI &SHIRUR_33 | 12:15 | 12:35 | 0:20 | LINE CLEAR AVAILED |
| 630 | 4-Sep-2021 | BAGALKOT | 110 | 11011KV,HV2A | JAMAKHANDI_110 | 11:25 | 11:28 | 0:03 | LINE CLEAR AVAILED |
| 631 | 4-Sep-2021 | BAGALKOT | 110 | AMBEWADI-HALIYAL(NK1) | STATION NOT AFFECTED AMBEWADI_220 | 9:54 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 632 | 4-Sep-2021 | BAGALKOT | 110 | AMBEWADI-KAVALWADA(NK2) | STATION NOT AFFECTED AMBEWADI_220 | 9:52 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 633 | 4-Sep-2021 | BAGALKOT | 110 | ATHANI220- SATTI | SATTI_110 | 6:11 | 6:23 | 0:12 | LINE FAULT |
| 634 | 4-Sep-2021 | BAGALKOT | 110 | GHATAPRABHA-SHIRAGOAN | SHIRAGOAN_110 | 20:57 | 21:15 | 0:18 | LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|---------------------------------------------|------------------------------------------|-----------------------|--------------------|-----------|------------------------------|
| 635 | 4-Sep-2021 | BAGALKOT | 110 | GOPANKOPPA-BIDNAL- NVLKD(NARAGUND) | STATION NOT AFFECTED GOPANAKOPPA_110 | 18:15 (24.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 636 | 4-Sep-2021 | BAGALKOT | 110 | JAMAKHANDI-PRABHULINGESHWAR | JAMAKHANDI_110 | 10:47 | 10:51 | 0:04 | LINE CLEAR AVAILED |
| 637 | 4-Sep-2021 | BAGALKOT | 110 | RANEBENNUR220- HONNATTI (AREMALLAPUR) | NO STATION AFFECTED RANEBENNUR_220 | 13:16 (17.11.2020) | | | LINE OPEN:LINE FAULT |
| 638 | 4-Sep-2021 | BAGALKOT | 110 | SAVANUR- ASF SOLAR | SAVANUR_110 | 8:07 | 8:13 | 0:06 | LINE FAULT |
| 639 | 4-Sep-2021 | BAGALKOT | 110 | SAVANUR- ASF SOLAR | SAVANUR_110 | 8:21 | 8:30 | 0:09 | LINE FAULT |
| 640 | 4-Sep-2021 | BAGALKOT | 110 | SAVANUR- ASF SOLAR | SAVANUR_110 | 12:14 | 12:28 | 0:14 | LINE FAULT |
| 641 | 4-Sep-2021 | BAGALKOT | 110 | SUPA 1-AMBEWADI | AMBEWADI_220 | 10:42 | 10:46 | 0:04 | HAND TRIPPED |
| 642 | 4-Sep-2021 | BAGALKOT | 220 | 220/110KV, HV1&LV1 | HUBLI_220 | 11:35 | 17:52 | 6:17 | LINE CLEAR AVAILED |
| 643 | 4-Sep-2021 | BAGALKOT | 220 | AMBEWADI-PONDA 1 | AMBEWADI_220 | 13:50 | 14:49 | 0:59 | LINE FAULT |
| 644 | 4-Sep-2021 | BAGALKOT | 220 | BELGAUM -CHIKKODI 2 | BELGAUM_220 | 9:31 (26.08.2021) | 14:25 (05.09.2021) | 244:54HRS | LINE CHARGED |
| 645 | 4-Sep-2021 | BAGALKOT | 220 | BIDNAL-HARTHI1 | STATION NOT AFFECTED BIDNAL_220 | 18:43 (01.08.2021) | | | LINE OPEN:LINE FAULT |
| 646 | 4-Sep-2021 | BAGALKOT | 220 | GADAG-HARTI1 | STATION NOT AFFECTED GADAG_220 | 9:52 (24.08.2021) | | | LINE OPEN:LINE FAULT |
| 647 | 4-Sep-2021 | BAGALKOT | 220 | HUBLI- NAGJHARI3 | HUBLI_220 | 15:35 | 18:01 | 2:26 | LINE CLEAR AVAILED |
| 648 | 4-Sep-2021 | BAGALKOT | 220 | HUBLI- NARENDRA1 | HUBLI_220 | 10:47 | 14:49 | 4:02 | NFBC ISSUED |
| 649 | 4-Sep-2021 | BAGALKOT | 220 | MAHALINGAPUR-VAJRAMATTI 2 | STATION NOT AFFECTED MAHALINGAPUR_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 650 | 4-Sep-2021 | BAGALKOT | 220 | NARENDRA- HUBLI1 | NARENDRA_220 | 10:47 | 14:48 | 4:01 | NFBC ISSUED |
| 651 | 4-Sep-2021 | BAGALKOT | 220 | NARENDRA-AMBEWADI2 | STATION NOT AFFECTED NARENDRA_220 | 17:22 (30.03.2021) | | | LINE OPEN:LINE FAULT |
| 652 | 4-Sep-2021 | BAGALKOT | 220 | SIRSI-HUBLI 1 | SIRSI_220 | 17:59 (30.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 653 | 4-Sep-2021 | BAGALKOT | 220 | VAJRAMATTI- MAHALINGAPUR1 | STATION NOT AFFECTED VAJRAMATTI_220 | 16:17 (23.02.2021) | | | LINE OPEN:LINE FAULT |
| 654 | 4-Sep-2021 | BAGALKOT | 220 | VAJRAMATTI -MAHALINGAPUR2 | STATION NOT AFFECTED VAJRAMATTI_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 655 | 4-Sep-2021 | BENGALURU | 66 | A STATION 220 - A STATION 1 | A STATION 66 | 19:47 | 19:55 | 0:08 | LINE CLEAR AVAILED |
| 656 | 4-Sep-2021 | BENGALURU | 66 | A STATION 220 - KANTEERAVA STADIUM | KANTEERAVA STADIUM | 19:47 | 19:55 | 0:08 | LINE CLEAR AVAILED |
| 657 | 4-Sep-2021 | BENGALURU | 66 | A STATION 220 - SHOBHA INDRAPRASTA | SHOBHA INDRAPRASTA | 19:47 | 19:55 | 0:08 | LINE CLEAR AVAILED |
| 658 | 4-Sep-2021 | BENGALURU | 66 | ADUGODI - NIMHANS 220 | ADUGODI, BOSCH(EHT) | 19:47 | 20:15 | 0:28 | LOAD CHANGE OVER |
| 659 | 4-Sep-2021 | BENGALURU | 66 | AUSTIN TOWN - EAST DIVISION COMPOUND 220 | AUSTIN TOWN | 19:47 | 20:22 | 0:35 | MAIN SUPPLY FAILURE |
| 660 | 4-Sep-2021 | BENGALURU | 66 | BANASHANKARI - AREHALLI | BANASHANKARI | 17:35 | 17:40 | 0:05 | LOAD CHANGE OVER |
| 661 | 4-Sep-2021 | BENGALURU | 66 | BANASHANKARI - VRISHBHAVATHI 220 | BANASHANKARI | 11:22 | 11:30 | 0:08 | LOAD CHANGE OVER |
| 662 | 4-Sep-2021 | BENGALURU | 66 | BMTC - EAST DIVISION COMPOUND 220 | BMTC | 19:47 | 20:22 | 0:35 | MAIN SUPPLY FAILURE |
| 663 | 4-Sep-2021 | BENGALURU | 66 | CHANDRA LAYOUT - NRS 220 | CHANDRA LAYOUT | 17:40 | 17:45 | 0:05 | LOAD CHANGE OVER |
| 664 | 4-Sep-2021 | BENGALURU | 66 | CHANDRA LAYOUT - VRISHABHAVATHI 220 | CHANDRA LAYOUT | 11:24 | 11:29 | 0:05 | LOAD CHANGE OVER |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|----------------------------------------|------------------------------------------------|---------|-----------|----------|---------------------|
| 665 | 4-Sep-2021 | BENGALURU | 66 | CHIKKENAHALLI - CHANNAPATNA | VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI | 10:58 | 11:03 | 0:05 | LINE FAULT |
| 666 | 4-Sep-2021 | BENGALURU | 66 | DB PURA 220 - D CROSS | D CROSS | 16:04 | 16:13 | 0:09 | LINE FAULT |
| 667 | 4-Sep-2021 | BENGALURU | 66 | DB PURA 220 - DG 1 | AIR(EHT) | 5:49 | 6:06 | 0:17 | LINE FAULT |
| 668 | 4-Sep-2021 | BENGALURU | 66 | EAST DIVISION COMPOUND 220 - B STATION | B STATION | 19:47 | 20:23 | 0:36 | LINE CLEAR AVAILED |
| 669 | 4-Sep-2021 | BENGALURU | 66 | ELECTRONIC CITY - HULIMANGALA | HULIMANGALA | 10:06 | 15:09 | 5:03 | LINE CLEAR AVAILED |
| 670 | 4-Sep-2021 | BENGALURU | 66 | ELITA PROMENEDE - RBI | ELITA PROMENEDE | 10:23 | 10:31 | 0:08 | MAIN SUPPLY FAILURE |
| 671 | 4-Sep-2021 | BENGALURU | 66 | ELITA PROMENEDE - RBI | ELITA PROMENEDE | 15:54 | 16:11 | 0:17 | LOAD CHANGE OVER |
| 672 | 4-Sep-2021 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 2 | MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE | 7:25 | 7:41 | 0:16 | LINE FAULT |
| 673 | 4-Sep-2021 | BENGALURU | 66 | GOWRIBIDANUR 220 - DB PURA 2 | MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE | 20:15 | 20:25 | 0:10 | LINE FAULT |
| 674 | 4-Sep-2021 | BENGALURU | 66 | HAL 220 - ADUGODI 1 | LEELA VENTURE | 19:47 | 20:22 | 0:35 | LINE CLEAR AVAILED |
| 675 | 4-Sep-2021 | BENGALURU | 66 | HAL 220 - ADUGODI 2 | GOLF LINKS, AMARJYOTHI | 19:47 | 20:23 | 0:36 | LINE CLEAR AVAILED |
| 676 | 4-Sep-2021 | BENGALURU | 66 | HAL 220 - HOODY 1 | ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT) | 19:47 | 20:28 | 0:41 | LINE CLEAR AVAILED |
| 677 | 4-Sep-2021 | BENGALURU | 66 | HAL 220 - HOODY 2 | BAGMANE TECH PARK, GTRE (EHT) | 19:47 | 20:22 | 0:35 | LINE CLEAR AVAILED |
| 678 | 4-Sep-2021 | BENGALURU | 66 | HAL 220 - ISRO (EHT) | ISRO (EHT), NAL (EHT) | 19:47 | 20:26 | 0:39 | LINE CLEAR AVAILED |
| 679 | 4-Sep-2021 | BENGALURU | 66 | HAMUMANTHNAGAR - KANAKAPURA 220 | HANUMANTHNAGAR | 15:20 | 15:40 | 0:20 | MAIN SUPPLY FAILURE |
| 680 | 4-Sep-2021 | BENGALURU | 66 | HANUMANTHNAGAR - SOMANAHALLI 220 | HANUMANTHNAGAR | 9:10 | 9:15 | 0:05 | LOAD CHANGE OVER |
| 681 | 4-Sep-2021 | BENGALURU | 66 | HOSKOTE 66 - HOODY 220 | HOSKOTE 66 | 10:00 | 10:05 | 0:05 | LOAD CHANGE OVER |
| 682 | 4-Sep-2021 | BENGALURU | 66 | HOSKOTE 66 - HOSKOTE 220 | HOSKOTE 66 | 18:10 | 18:15 | 0:05 | LOAD CHANGE OVER |
| 683 | 4-Sep-2021 | BENGALURU | 66 | HV1 | EAST DIVISION COMPOUND 220 | 19:47 | 20:21 | 0:34 | LINE CLEAR AVAILED |
| 684 | 4-Sep-2021 | BENGALURU | 66 | HV1 | HAL 220 | 19:47 | 20:14 | 0:27 | LINE CLEAR AVAILED |
| 685 | 4-Sep-2021 | BENGALURU | 66 | HV1 | ITI 220 | 12:56 | 13:00 | 0:04 | LINE CLEAR AVAILED |
| 686 | 4-Sep-2021 | BENGALURU | 66 | HV1 | VRISHBHAVATHI 220 | 12:10 | 17:26 | 5:16 | LINE CLEAR AVAILED |
| 687 | 4-Sep-2021 | BENGALURU | 66 | HV1 | VIKAS TECH PARK 220 | 11:45 | 11:50 | 0:05 | LOAD CHANGE OVER |
| 688 | 4-Sep-2021 | BENGALURU | 66 | HV1 | VIJAYANAGAR | 12:04 | 12:21 | 0:17 | LOAD CHANGE OVER |
| 689 | 4-Sep-2021 | BENGALURU | 66 | HV1 | VIJAYANAGAR | 18:20 | 18:31 | 0:11 | LOAD CHANGE OVER |
| 690 | 4-Sep-2021 | BENGALURU | 66 | HV1 | CHANDAPURA | 9:44 | 9:47 | 0:03 | LINE CLEAR AVAILED |
| 691 | 4-Sep-2021 | BENGALURU | 66 | HV2 | ABBIGERE | 5:32 | 8:05 | 2:33 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|------------------------------------------------|---------------------------------------------------------------------|-----------------|--------------|----------|-------------------------------------|
| 692 | 4-Sep-2021 | BENGALURU | 66 | HV2 | EAST DIVISION COMPOUND 220 | 19:47 | 20:28 | 0:41 | LINE CLEAR AVAILED |
| 693 | 4-Sep-2021 | BENGALURU | 66 | HV2 | HAL 220 | 19:47 | 20:15 | 0:28 | LINE CLEAR AVAILED |
| 694 | 4-Sep-2021 | BENGALURU | 66 | HV2 | ITI 220 | 10:06 | 10:20 | 0:14 | LINE CLEAR AVAILED |
| 695 | 4-Sep-2021 | BENGALURU | 66 | HV2 | KADUGODI | 21:18 | 21:45 | 0:27 | TRANSFORMER FAULT |
| 696 | 4-Sep-2021 | BENGALURU | 66 | HV2 | VRISHBHAVATHI 220 | 12:10 | 17:30 | 5:20 | LINE CLEAR AVAILED |
| 697 | 4-Sep-2021 | BENGALURU | 66 | HV2 | REMC0 | 12:05 | 12:27 | 0:22 | LOAD CHANGE OVER |
| 698 | 4-Sep-2021 | BENGALURU | 66 | HV2 | REMC0 | 17:52 | 17:59 | 0:07 | LOAD CHANGE OVER |
| 699 | 4-Sep-2021 | BENGALURU | 66 | HV2 | YEDUMADU | 18:20 | 18:43 | 0:23 | TRANSFORMER FAULT |
| 700 | 4-Sep-2021 | BENGALURU | 66 | HV2 | THIMMAMPALLI | 9:54 | 10:19 | 0:25 | LINE CLEAR AVAILED |
| 701 | 4-Sep-2021 | BENGALURU | 66 | HV2 | BAGHMANE WORLD TECH PARK | 9:55 | 10:15 | 0:20 | LINE CLEAR AVAILED |
| 702 | 4-Sep-2021 | BENGALURU | 66 | HV2 | ATTIBELE | 23:25(4-9-2021) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 703 | 4-Sep-2021 | BENGALURU | 66 | HV2 | SARIAPURA 220 | 23:54:39 | 0:03(4-9-21) | 0:09:00 | TRANSFORMER CHARGED |
| 704 | 4-Sep-2021 | BENGALURU | 66 | JAKKASANDRA - ADUGODI | JAKKASANDRA | 19:47 | 19:59 | 0:12 | MAIN SUPPLY FAILURE |
| 705 | 4-Sep-2021 | BENGALURU | 66 | KANAKAPURA 220 - SOMANAHALLI 1 | CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU | 18:20 | 18:38 | 0:18 | LINE FAULT |
| 706 | 4-Sep-2021 | BENGALURU | 66 | KENGERI SATELLITE TOWN - KUMBALAGODU | KENGERI SATELLITE TOWN | 18:07 | 18:14 | 0:07 | LOAD CHANGE OVER |
| 707 | 4-Sep-2021 | BENGALURU | 66 | KENGERI SATELLITE TOWN - SIR MV LAYOUT | KENGERI SATELLITE TOWN | 11:24 | 11:47 | 0:23 | MAIN SUPPLY FAILURE |
| 708 | 4-Sep-2021 | BENGALURU | 66 | KORAMANGALA 220 - GOLF LINK HAL 2 | K & C VALLEY | 18:29 | 18:57 | 0:28 | LINE FAULT |
| 709 | 4-Sep-2021 | BENGALURU | 66 | MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66 | MANYATHA TECH PARK 66 | 10:08 | 17:08 | 7:00 | LINE CLEAR AVAILED |
| 710 | 4-Sep-2021 | BENGALURU | 66 | NAGANATHPURA 220 - SOMANAHALLI 220 | NAGANATHPURA 220 | 15:55 | 16:08 | 0:13 | MAIN SUPPLY FAILURE |
| 711 | 4-Sep-2021 | BENGALURU | 66 | NAGNATHPURA 220 - ELECTRONIC CITY | ELECTRONIC CITY, INFOSYS(EHT) | 15:55 | 16:11 | 0:16 | LINE CLEAR AVAILED |
| 712 | 4-Sep-2021 | BENGALURU | 66 | NAGNATHPURA 220 - ELECTRONIC CITY P2 S1 | ELECTRONIC CITY P2 S1 | 15:55 | 16:09 | 0:14 | LINE CLEAR AVAILED |
| 713 | 4-Sep-2021 | BENGALURU | 66 | NAGNATHPURA 220 - ELECTRONIC CITY P2 S2 | ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA | 15:55 | 16:10 | 0:15 | LINE CLEAR AVAILED |
| 714 | 4-Sep-2021 | BENGALURU | 66 | NANDAGUDI - HOSKOTE 220 | NANDAGUDI | 12:15 | 12:25 | 0:10 | LINE FAULT |
| 715 | 4-Sep-2021 | BENGALURU | 66 | PADMANABHANAGARA - NIMHANS 220 | PADMANABHANAGARA | 19:47 | 19:53 | 0:06 | LOAD CHANGE OVER |
| 716 | 4-Sep-2021 | BENGALURU | 66 | RAJANUKUNTE - YELAHANKA 220 | RAJANUKUNTE | 20:05 | 20:35 | 0:30 | MAIN SUPPLY FAILURE |
| 717 | 4-Sep-2021 | BENGALURU | 66 | RBI - ELITA PROMENEDE | RBI | 16:54 | 16:58 | 0:04 | LOAD CHANGE OVER |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|--------------------------------------------|-----------------------------------------------------------------------------------------------|-------------------|-----------|----------|----------------------|
| 718 | 4-Sep-2021 | BENGALURU | 66 | RBI - SOMANAHALLI 220 | RBI, SOUTH CITY | 10:23 | 10:32 | 0:09 | MAIN SUPPLY FAILURE |
| 719 | 4-Sep-2021 | BENGALURU | 66 | RBI - SOMANAHALLI 220 | RBI | 15:55 | 16:10 | 0:15 | LOAD CHANGE OVER |
| 720 | 4-Sep-2021 | BENGALURU | 66 | SOMANAHALLI 220 - JIGANI 1 | NO STATION AFFECTED | 15:55 | 16:28 | 0:33 | LINE FAULT |
| 721 | 4-Sep-2021 | BENGALURU | 66 | SOUTH CITY - KHODAYS 220 | SOUTH CITY | 17:03 | 17:08 | 0:05 | LOAD CHANGE OVER |
| 722 | 4-Sep-2021 | BENGALURU | 66 | SOUTH CITY - RBI | SOUTH CITY | 15:55 | 16:32 | 0:37 | LOAD CHANGE OVER |
| 723 | 4-Sep-2021 | BENGALURU | 66 | VRISHBHAVATHI 220 - BMRL (EHT) | BMRL (EHT) | 11:25 | 23:59 | 12:34 | LINE CLEAR AVAILED |
| 724 | 4-Sep-2021 | BENGALURU | 66 | VRISHBHAVATHI 220 - REMCO | REMCO | 12:06 | 17:50 | 5:44 | LINE CLEAR AVAILED |
| 725 | 4-Sep-2021 | BENGALURU | 66 | VRISHBHAVATHI 220 - SIR MV LAYOUT | KNGERI SATELLITE TOWN, SIR MV LAYOUT | 11:24 | 17:37 | 6:13 | LINE CLEAR AVAILED |
| 726 | 4-Sep-2021 | BENGALURU | 66 | VRISHBHAVATHI 220 - TATAGUNI 220 (EHT) | VRISHBHAVATHI 220 | 12:10 | 17:14 | 5:04 | LINE CLEAR AVAILED |
| 727 | 4-Sep-2021 | BENGALURU | 66 | YEDUMADU - KANAKPURA 220 | YEDUMADU | 9:35 | 9:40 | 0:05 | LOAD CHANGE OVER |
| 728 | 4-Sep-2021 | BENGALURU | 66 | YELAHANKA 220 - LINE8 | RAJANKUNTE | 20:05 | 20:35 | 0:29 | LINE FAULT |
| 729 | 4-Sep-2021 | BENGALURU | 220 | A STATION 220 - EAST DIVISION COMPOUND 220 | A STATION 220 | 19:47 | 20:37 | 0:50 | MAIN SUPPLY FAILURE |
| 730 | 4-Sep-2021 | BENGALURU | 220 | EAST DIVISION COMPOUND 220 - HAL 220 | EAST DIVISION COMPOUND 220 | 19:47 | 20:20 | 0:33 | MAIN SUPPLY FAILURE |
| 731 | 4-Sep-2021 | BENGALURU | 220 | HAL 220 1 - HOODY 400 | HAL 220 | 19:47 | 20:11 | 0:24 | MAIN SUPPLY FAILURE |
| 732 | 4-Sep-2021 | BENGALURU | 220 | HAL 220 2 - HOODY 400 | HAL 220 | 19:57 | 20:14 | 0:17 | MAIN SUPPLY FAILURE |
| 733 | 4-Sep-2021 | BENGALURU | 220 | HAL 220 - EAST DIVISION COMPOUND 220 | EAST DIVISION COMPOUND 220 | 19:47 | 20:20 | 0:33 | LINE CLEAR AVAILED |
| 734 | 4-Sep-2021 | BENGALURU | 220 | HOODY 400 - HAL - 1 | HAL 220 | 19:47 | 20:12 | 0:25 | LINE FAULT |
| 735 | 4-Sep-2021 | BENGALURU | 220 | HOODY 400 - HAL - 2 | HAL 220 | 19:57 | 20:14 | 0:17 | LINE FAULT |
| 736 | 4-Sep-2021 | BENGALURU | 220 | HSR LAYOUT - NAGNATHPURA 220 | NAGNATHPURA 220 | 15:55 | 16:07 | 0:12 | LINE FAULT |
| 737 | 4-Sep-2021 | BENGALURU | 220 | MYLSANDRA 400 - SOMANAHALLI 220 | NO STATION AFFECTED | 15:54(04/09/2021) | | | LINE OPEN:LINE FAULT |
| 738 | 4-Sep-2021 | BENGALURU | 220 | SOMANAHALLI 220 - MYLSANDRA 400 | NO STATION AFFECTED | 15:54(04/09/2021) | | | LINE OPEN:LINE FAULT |
| 739 | 4-Sep-2021 | BENGALURU | 220 | SOMANAHALLI 220 - NAGNATHPURA 220 | NAGNATHPURA 220 | 15:55 | 16:08 | 0:13 | LINE FAULT |
| 740 | 4-Sep-2021 | GULBARGA | 110 | ALIPUR-BELLARY NORTH1 | SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELA | 13:50 | 14:12 | 0:22 | LINE CLEAR AVAILED |
| 741 | 4-Sep-2021 | GULBARGA | 110 | ALIPUR-BELLARY NORTH1 | SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELA | 19:10 | 19:15 | 0:05 | LINE FAULT |
| 742 | 4-Sep-2021 | GULBARGA | 110 | GABBUR-RAICHUR | GABBUR_110,DEODURGA_110 | 0:10 | 0:45 | 0:35 | MAIN SUPPLY FAILURE |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|-----------------------------------|----------------------------------------------------------|-------------------|-------------------|----------|-------------------------------------|
| 743 | 4-Sep-2021 | GULBARGA | 110 | GABBUR-RAICHUR | GABBUR_110,DEODURGA_111 | 2:35 | 6:25 | 3:50 | MAIN SUPPLY FAILURE |
| 744 | 4-Sep-2021 | GULBARGA | 110 | GULBARGASOUTH-GULBARGA UNIVERSITY | GULBARGAUNIVERSITY_110 | 18:35(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 745 | 4-Sep-2021 | GULBARGA | 110 | GURMITKAL-SEDAM | GURMITKAL_110 | 14:10 | 14:15 | 0:05 | MAIN SUPPLY FAILURE |
| 746 | 4-Sep-2021 | GULBARGA | 110 | GURMITKAL-SEDAM | GURMITKAL_110 | 22:35 | 22:40 | 0:05 | MAIN SUPPLY FAILURE |
| 747 | 4-Sep-2021 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP | 16:54 | 16:59 | 0:05 | LINE FAULT |
| 748 | 4-Sep-2021 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP | 22:13 | 22:19 | 0:06 | LINE FAULT |
| 749 | 4-Sep-2021 | GULBARGA | 110 | HUMNABAD-MANEKHELI | MANEKHELI_110 | 6:24 | 6:41 | 0:17 | LINE FAULT |
| 750 | 4-Sep-2021 | GULBARGA | 110 | HV1 | LADHA_110 | 10:10 | 10:20 | 0:10 | TRANSFORMER FAULT |
| 751 | 4-Sep-2021 | GULBARGA | 110 | HV2 | VALKAMDINNI_110 | 11:15(31.08.2021) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 752 | 4-Sep-2021 | GULBARGA | 110 | HV2 | VALKAMDINNI_110 | 11:15(31.08.2021) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 753 | 4-Sep-2021 | GULBARGA | 110 | KAPNOOR-ALAND | ALAND_110,KADGANCHI_110 | 6:50 | 6:55 | 0:05 | LINE FAULT |
| 754 | 4-Sep-2021 | GULBARGA | 110 | LADHA-BHALKI | LADHA_110 | 14:10 | 14:20 | 0:10 | MAIN SUPPLY FAILURE |
| 755 | 4-Sep-2021 | GULBARGA | 110 | LADHA-BHALKI | LADHA_110 | 22:10 | 22:15 | 0:05 | MAIN SUPPLY FAILURE |
| 756 | 4-Sep-2021 | GULBARGA | 110 | MALLAT-ALKOD | ALKOD_110 | 1:19 | 1:30 | 0:11 | LINE FAULT |
| 757 | 4-Sep-2021 | GULBARGA | 110 | MARGUTTI-CLEAN SOLAR_IPP | MARGUTTI_110 | 5:35 | 6:15 | 0:40 | LINE FAULT |
| 758 | 4-Sep-2021 | GULBARGA | 110 | MARGUTTI-CLEAN SOLAR_IPP | MARGUTTI_110 | 9:20 | 11:15 | 1:55 | LINE CLEAR AVAILED |
| 759 | 4-Sep-2021 | GULBARGA | 110 | MARUGUTTI-CLN SLR | MARUGUTTI_110 | 19:30(04.09.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 760 | 4-Sep-2021 | GULBARGA | 110 | MASKI-HATTI | HATTI_110 | 3:30 | 11:42 | 8:12 | LINE FAULT |
| 761 | 4-Sep-2021 | GULBARGA | 110 | MASKI-SINDHANOOR | MASKI_110 | 3:30 | 3:38 | 0:08 | LINE FAULT |
| 762 | 4-Sep-2021 | GULBARGA | 110 | MUNIRABAD-SINDHANOOR1 | VENKATAGIRI_110,GANGAVATHI_110,DR NAGAR_110,KARATAGI_110 | 8:49 | 8:57 | 0:08 | LINE FAULT |
| 763 | 4-Sep-2021 | GULBARGA | 110 | MUNIRABAD-SINDHANOOR2 | KAMPLI_110,MUKUNDA_110,KEREHALLI_110, MALLAPUR_110 | 9:01 | 14:28 | 5:27 | LINE CLEAR AVAILED |
| 764 | 4-Sep-2021 | GULBARGA | 110 | NALWAR-CLEAN SOLAR_IPP | NALWAR_110 | 6:19 | 6:33 | 0:14 | LINE FAULT |
| 765 | 4-Sep-2021 | GULBARGA | 110 | RAICHUR-APMC1 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 13:20 | 15:29 | 2:09 | LINE CLEAR AVAILED |
| 766 | 4-Sep-2021 | GULBARGA | 110 | RAICHUR-APMC1 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 23:23 | 23:40 | 0:17 | LINE FAULT |
| 767 | 4-Sep-2021 | GULBARGA | 110 | RAICHUR-APMC2 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 23:44 | 23:58 | 0:14 | LINE FAULT |
| 768 | 4-Sep-2021 | GULBARGA | 110 | RAICHUR-SHAHAPUR1&2 | GABBUR_110,DEODURGA_110,GOOGLE_110 | 9:16 | 17:20 | 8:04 | LINE CLEAR AVAILED |
| 769 | 4-Sep-2021 | GULBARGA | 110 | RAICHUR-SINDHANOOR1(IDLE LINE) | SINDHANOOR_110 | 23:23(03.09.2021) | 08:39(04.09.2021) | 09:16HRS | LINE CHARGED |
| 770 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-CHINCHOLI | CHINCHOLI_110 | 6:27 | 6:36 | 0:09 | LINE FAULT |
| 771 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 23:22(4.09.2021) | | | LINE OPEN:LINE FAULT |
| 772 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 0:02 | 0:10 | 0:08 | LINE FAULT |
| 773 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 1:53 | 2:03 | 0:10 | LINE FAULT |
| 774 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 3:05 | 3:27 | 0:22 | LINE FAULT |
| 775 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 3:41 | 4:10 | 0:29 | LINE FAULT |
| 776 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 16:25 | 18:28 | 2:03 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|-------------------------------|---------------------------------|-------------------|------------------|-----------|------------------------------|
| 777 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 22:27 | 22:37 | 0:10 | LINE FAULT |
| 778 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-GURUMITKAL | GURUMITKAL_110 | 14:12 | 14:19 | 0:07 | LINE FAULT |
| 779 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-KURKUNTA | KURKUNTA_110 | 3:15 | 3:21 | 0:06 | LINE FAULT |
| 780 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-KURKUNTA | KURKUNTA_110 | 5:00 | 5:50 | 0:50 | LINE FAULT |
| 781 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-ULTRATECHCEMENTS_IPP | SEDAM_220 | 6:21 | 6:34 | 0:13 | LINE FAULT |
| 782 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-VCATSAGAR_IPP | SEDAM_220 | 4:25(04.09.2021) | | | LINE OPEN:LINE FAULT |
| 783 | 4-Sep-2021 | GULBARGA | 110 | SEDAM-VICATSAGAR_IPP | SEDAM_220 | 4:25 | 20:45 | 16:20 | LINE FAULT |
| 784 | 4-Sep-2021 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 14:55(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 785 | 4-Sep-2021 | GULBARGA | 110 | SHAHABAD-GULBARGA UNIVERSITY2 | GULBARGA UNIVERSITY_110 | 09:17(14.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 786 | 4-Sep-2021 | GULBARGA | 110 | SINDHANOOR-ADVIAMARESHWAR | ADAVI AMARESHWAR_110 | 21:35 | 21:50 | 0:15 | LINE FAULT |
| 787 | 4-Sep-2021 | GULBARGA | 110 | VALKAMDINNI-SINDHANOOR | VALKAMDINNI_110 | 0:30 | 0:40 | 0:10 | MAIN SUPPLY FAILURE |
| 788 | 4-Sep-2021 | GULBARGA | 110 | YELBURGA-TALT_SLR | YELBURGA_110 | 18:45(03.09.2021) | 5:01(04.09.2021) | 10:16 HRS | LINE CHARGED |
| 789 | 4-Sep-2021 | GULBARGA | 220 | ALIPUR-RAGALPADU | ALIPUR_220 | 0:03 | 0:38 | 0:35 | LINE FAULT |
| 790 | 4-Sep-2021 | GULBARGA | 220 | KAPNOOR-SHAHABAD | SHAHABAD_220 | 5:47 | 6:04 | 0:17 | LINE FAULT |
| 791 | 4-Sep-2021 | GULBARGA | 220 | KAPNOOR-SHAHABAD | KAPNOOR_220 | 8:13 | 8:35 | 0:22 | LINE FAULT |
| 792 | 4-Sep-2021 | GULBARGA | 220 | KAPNOOR-SHAHAPUR | SHAHAPUR_220 | 8:12 | 8:58 | 0:46 | LINE FAULT |
| 793 | 4-Sep-2021 | GULBARGA | 220 | LINGASUGUR-SHAHAPUR | LINGASUGUR_220 | 5:37 | 6:18 | 0:41 | LINE FAULT |
| 794 | 4-Sep-2021 | GULBARGA | 220 | MALLAT-RTPS | MALLAT_220 | 5:26 | 6:27 | 1:01 | LINE FAULT |
| 795 | 4-Sep-2021 | GULBARGA | 220 | SEDAM-RTPS2 | SEDAM_220 | 2:15 | 10:30 | 8:15 | LINE FAULT |
| 796 | 4-Sep-2021 | GULBARGA | 220 | SHAHAPUR-KAPNOOR | KAPNOOR_220 | 8:10 | 8:58 | 0:48 | LINE FAULT |
| 797 | 4-Sep-2021 | GULBARGA | 220 | SHAHAPUR-SEDAM | SEDAM_220 | 21:03(04.09.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 798 | 4-Sep-2021 | GULBARGA | 220 | SHAHAPUR-SEDAM | SEDAM_220 | 4:19 | 15:48 | 11:29 | LINE FAULT |
| 799 | 4-Sep-2021 | GULBARGA | 400 | RTPS-BTP5 | RTPS_400 | 2:40 | 14:41 | 12:01 | LINE FAULT |
| 800 | 4-Sep-2021 | HASSAN | 66 | ALDUR-CHIKKAMAGLUR | ALDUR_66 | 10:45 | 13:08 | 2:23 | NFBC ISSUED |
| 801 | 4-Sep-2021 | HASSAN | 66 | BANDISH-RAMNATHPURA | BANDISHETTIHALLI_66 | 11:02 | 13:42 | 2:40 | LINE CLEAR AVAILED |
| 802 | 4-Sep-2021 | HASSAN | 66 | BYACHAN-HNPURA | BYACHANAHALLI_66 | 11:00 | 13:42 | 2:42 | NFBC ISSUED |
| 803 | 4-Sep-2021 | HASSAN | 66 | GANGUR-HASSAN | GANGUR_66 | 10:09 | 16:44 | 6:35 | LINE CLEAR AVAILED |
| 804 | 4-Sep-2021 | HASSAN | 66 | HAGARE-HASSAN | HAGARE_66 | 10:10 | 16:42 | 6:32 | MAIN SUPPLY FAILURE |
| 805 | 4-Sep-2021 | HASSAN | 66 | HNPR2-RNPR1 | HNPUR_220 | 11:05 | 12:30 | 1:25 | LINE CLEAR AVAILED |
| 806 | 4-Sep-2021 | HASSAN | 66 | HNPR2-RNPR2 | HNPUR_220 | 11:07 | 12:49 | 1:42 | LINE CLEAR AVAILED |
| 807 | 4-Sep-2021 | HASSAN | 66 | HV1 | AREHALLI_66 | 10:38 | 12:41 | 2:03 | LINE CLEAR AVAILED |
| 808 | 4-Sep-2021 | HASSAN | 66 | HV1 | AREHALLI_66 | 12:48 | 13:55 | 1:07 | LINE CLEAR AVAILED |
| 809 | 4-Sep-2021 | HASSAN | 66 | HV1 | BYACHANAHALLI_66 | 11:00 | 13:42 | 2:42 | MAIN SUPPLY FAILURE |
| 810 | 4-Sep-2021 | HASSAN | 66 | HV1 | GANGUR_66 | 10:10 | 16:45 | 6:35 | LINE CLEAR AVAILED |
| 811 | 4-Sep-2021 | HASSAN | 66 | HV1 | HAGARE_66 | 10:40 | 17:10 | 6:30 | LINE CLEAR AVAILED |
| 812 | 4-Sep-2021 | HASSAN | 66 | HV1 | HAGARE_66 | 17:40 | 18:45 | 1:05 | LINE CLEAR AVAILED |
| 813 | 4-Sep-2021 | HASSAN | 66 | HV1 | HALEBEEDU_66 | 10:10 | 17:08 | 6:58 | MAIN SUPPLY FAILURE |
| 814 | 4-Sep-2021 | HASSAN | 66 | HV2 | HALEBEEDU_66 | 10:10 | 19:07 | 8:57 | MAIN SUPPLY FAILURE |
| 815 | 4-Sep-2021 | HASSAN | 66 | RAMNAT-KADVINKOTE | RAMNATHPURA_66 | 10:05 | 15:00 | 4:55 | LINE CLEAR AVAILED |
| 816 | 4-Sep-2021 | HASSAN | 66 | RAMNAT-KADVINKOTE | RAMNATHPURA_66 | 10:25 | 12:05 | 1:40 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|---------|---------|----------------------------|----------------------------|----------------------|-----------------|------------|-------------------------------------|
| 817 | 4-Sep-2021 | HASSAN | 66 | RAMNAT-KATTEPURA_MINIH | RAMNATHPURA_66 | 10:05 | 15:00 | 4:55 | LINE CLEAR AVAILED |
| 818 | 4-Sep-2021 | HASSAN | 66 | SALAGAM-HIREMANGLUR | SALAGAME_66 | 10:30 | 14:50 | 4:20 | LINE CLEAR AVAILED |
| 819 | 4-Sep-2021 | HASSAN | 66 | UDDURKO-CHIKMANGLUR | UDDURKOPLU_66 | 10:14(3.9.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 820 | 4-Sep-2021 | HASSAN | 66 | UDDURKO-CHIKMANGLUR | UDDURKOPPLU_66 | 10:14(03.09.2021) | 10:42(4.9.2021) | 24:27 hrs | LINE CHARGED |
| 821 | 4-Sep-2021 | HASSAN | 110 | BANTWA-KAVOOR | BANTWALA_110 | 10:01 | 10:44 | 0:43 | LINE CLEAR AVAILED |
| 822 | 4-Sep-2021 | HASSAN | 110 | HV1 | GURUVAYANAKERE_110 | 9:42 | 13:32 | 3:50 | LINE CLEAR AVAILED |
| 823 | 4-Sep-2021 | HASSAN | 110 | HV1 | KEMAR_220 | 10:38 | 13:39 | 3:01 | LINE CLEAR AVAILED |
| 824 | 4-Sep-2021 | HASSAN | 110 | HV1 | KONDENALU_110 | 14:11 | 15:17 | 1:06 | LINE CLEAR AVAILED |
| 825 | 4-Sep-2021 | HASSAN | 110 | HV1 | SAGARA_110 | 10:15 | 18:01 | 7:46 | LINE CLEAR AVAILED |
| 826 | 4-Sep-2021 | HASSAN | 110 | HV3 | SAGARA_110 | 17:57 | 18:00 | 0:03 | LINE CLEAR AVAILED |
| 827 | 4-Sep-2021 | HASSAN | 110 | LPH-MGHE 1 | lph_gen | 11:13 (20.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 828 | 4-Sep-2021 | HASSAN | 220 | MRSSH-MDVG2 | MRSMDG_220 | 17:08 (30.08.2021) | | | LINE OPEN:LINE FAULT |
| 829 | 4-Sep-2021 | HASSAN | 220 | MRSSH-HONNALLI | MRSMDG_220 | 13:47 | 16:07 | 2:20 | HAND TRIPPED |
| 830 | 4-Sep-2021 | HASSAN | 400 | UPCL-HASSAN2 | upcl_gen | 23:03(03.09.2021) | 9:40(4.9.2021) | 130:36 hrs | LINE CHARGED |
| 831 | 4-Sep-2021 | MYSURU | 66 | CHUNKANAKATTE-KR NAGARA | NO STATIONS EFFECTED | 8:20 (19/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 832 | 4-Sep-2021 | MYSURU | 66 | HANAGOD-PONNAMPETE | PONNAMPETE_66 VIRAJPETE_66 | 10:27 | 18:50 | 8:22 | NFBC ISSUED |
| 833 | 4-Sep-2021 | MYSURU | 66 | HARADANAHALLI(JAK)-LAXJEET | NO STATIONS EFFECTED | 13:00 | 13:10 | 0:10 | LINE FAULT |
| 834 | 4-Sep-2021 | MYSURU | 66 | HARVEY-CR NAGARA | NO STATIONS EFFECTED | 9:24 (3/9/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 835 | 4-Sep-2021 | MYSURU | 66 | HUNSUR-ELWALA | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 836 | 4-Sep-2021 | MYSURU | 66 | HUNSUR-HOOTAGALLI | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 837 | 4-Sep-2021 | MYSURU | 66 | HV1 | HONNALLY_66 | 11:39 | 16:53 | 5:13 | LINE CLEAR AVAILED |
| 838 | 4-Sep-2021 | MYSURU | 66 | HV1 | KIKKERI_66 | 10:35 | 17:17 | 6:42 | LINE CLEAR AVAILED |
| 839 | 4-Sep-2021 | MYSURU | 66 | HV1 | MADDUR_66 | 9:58 | 16:50 | 6:51 | LINE CLEAR AVAILED |
| 840 | 4-Sep-2021 | MYSURU | 66 | HV1 | MADHUVANALLI_66 | 15:48 | 17:00 | 1:11 | LINE CLEAR AVAILED |
| 841 | 4-Sep-2021 | MYSURU | 66 | HV1 | PERIAPATNA_66 | 15:12 | 16:03 | 0:51 | LINE CLEAR AVAILED |
| 842 | 4-Sep-2021 | MYSURU | 66 | HV1 | PONNAMPETE_66 | 6:29(4.09.21) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 843 | 4-Sep-2021 | MYSURU | 66 | HV2 | HONNALLY_66 | 14:57 | 15:06 | 0:08 | TRANSFORMER FAULT |
| 844 | 4-Sep-2021 | MYSURU | 66 | HV2 | HULLAHALLI_66 | 16:28 | 16:47 | 0:18 | LINE CLEAR AVAILED |
| 845 | 4-Sep-2021 | MYSURU | 66 | HV2 | KR PETE_66 | 14:12 | 14:33 | 0:20 | HAND TRIPPED |
| 846 | 4-Sep-2021 | MYSURU | 66 | HV2 | MADDUR_66 | 9:58 | 16:43 | 6:44 | LINE CLEAR AVAILED |
| 847 | 4-Sep-2021 | MYSURU | 66 | HV2 | PERIAPATNA_66 | 14:01 | 16:13 | 2:11 | LINE CLEAR AVAILED |
| 848 | 4-Sep-2021 | MYSURU | 66 | HV3 | KIKKERI_66 | 12:07 | 16:50 | 4:43 | LINE CLEAR AVAILED |
| 849 | 4-Sep-2021 | MYSURU | 66 | HV3 | KR PETE_66 | 15:51 | 17:20 | 1:29 | LINE CLEAR AVAILED |
| 850 | 4-Sep-2021 | MYSURU | 66 | KIADB MANDYA-MADDUR | MADDUR_66 | 13:03 | 13:49 | 0:46 | LINE CLEAR AVAILED |
| 851 | 4-Sep-2021 | MYSURU | 66 | KIADB MANDYA-THUMBEGERE | TUMBEGERE_66 | 10:11 | 15:02 | 4:51 | LINE CLEAR AVAILED |
| 852 | 4-Sep-2021 | MYSURU | 66 | KOLLEGALA-SATHEGALA | NO STATIONS EFFECTED | 4:07 | 4:23 | 0:15 | LINE FAULT |
| 853 | 4-Sep-2021 | MYSURU | 66 | KR NAGARA-MYSORE-1 | NO STATIONS EFFECTED | 20:02 18/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 854 | 4-Sep-2021 | MYSURU | 66 | KR PETE220-KR PETE | NO STATIONS EFFECTED | 18:04 | 18:19 | 0:14 | HAND TRIPPED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|---------|---------|--------------------------------------------|-------------------------------------------------------------------|---------|-----------|----------|---------------------|
| 855 | 4-Sep-2021 | MYSURU | 66 | KUSHALNAGARA-RAMANTHAPURA | CB HALLI,ALLURSIDDAPURA,KANGAL & RUDRAPATNA STATIONS INTERRUPTED. | 0:03 | 0:10 | 0:06 | LINE FAULT |
| 856 | 4-Sep-2021 | MYSURU | 66 | MADHUVANALLIDODDAINDUVADI | NO STATIONS EFFECTED | 13:34 | 14:21 | 0:47 | LINE CLEAR AVAILED |
| 857 | 4-Sep-2021 | MYSURU | 66 | MADHUVANALLI-HANNUR1 | NO STATIONS EFFECTED | 9:17 | 11:24 | 2:06 | LINE CLEAR AVAILED |
| 858 | 4-Sep-2021 | MYSURU | 66 | MADHUVANALLI-HANNUR2 | NO STATIONS EFFECTED | 9:17 | 11:24 | 2:06 | LINE CLEAR AVAILED |
| 859 | 4-Sep-2021 | MYSURU | 66 | MADHUVANALLI-HEBBANI | NO STATIONS EFFECTED | 12:46 | 14:02 | 1:16 | LINE CLEAR AVAILED |
| 860 | 4-Sep-2021 | MYSURU | 66 | MADHUVANALLI-KOLLEGALA | NO STATIONS EFFECTED | 11:32 | 13:08 | 1:36 | LINE CLEAR AVAILED |
| 861 | 4-Sep-2021 | MYSURU | 66 | MADHUVANALLI-KUNTUR | NO STATIONS EFFECTED | 12:27 | 13:20 | 0:52 | LINE CLEAR AVAILED |
| 862 | 4-Sep-2021 | MYSURU | 66 | MADHUVANALLI-MAMBALLI | NO STATIONS EFFECTED | 10:45 | 13:28 | 2:43 | LINE CLEAR AVAILED |
| 863 | 4-Sep-2021 | MYSURU | 66 | TUBINKERE-NAGAMANGLA | NO STATIONS EFFECTED | 11:03 | 13:15 | 2:12 | LINE CLEAR AVAILED |
| 864 | 4-Sep-2021 | MYSURU | 220 | HV1 | KR PETE220_66 | 9:47 | 14:12 | 4:25 | LINE CLEAR AVAILED |
| 865 | 4-Sep-2021 | MYSURU | 220 | HV2 | KR PETE220_66 | 14:32 | 17:29 | 2:57 | LINE CLEAR AVAILED |
| 866 | 4-Sep-2021 | MYSURU | 220 | VAJMANGALA-TK HALLI | NO STATIONS EFFECTED | 7:23 | 19:24 | 12:00 | NFBC ISSUED |
| 867 | 4-Sep-2021 | TUMKUR | 66 | BENNEHALLI66-RISHAB BUILDWELL SOLAR_IPP_66 | RISHAB BUILDWELL SOLAR_IPP_66 | 19:22 | 21:18 | 1:56 | LINE CLEAR AVAILED |
| 868 | 4-Sep-2021 | TUMKUR | 66 | BENNEHALLI66-RISHAB BUILDWELL SOLAR_IPP_66 | RISHAB BUILDWELL SOLAR_IPP_66 | 19:22 | 21:18 | 1:56 | LINE CLEAR AVAILED |
| 869 | 4-Sep-2021 | TUMKUR | 66 | HANAGAL-AVADASOLAR_IPP_66 | AVADASOLAR_IPP_66 | 10:31 | 17:55 | 7:24 | LINE CLEAR AVAILED |
| 870 | 4-Sep-2021 | TUMKUR | 66 | HANAGAL-AVADASOLAR_IPP_66 | AVADASOLAR_IPP_66 | 10:31 | 17:55 | 7:24 | LINE CLEAR AVAILED |
| 871 | 4-Sep-2021 | TUMKUR | 66 | BUKKAPATNA-GOLDEN HATCHERIES_IPP_66 | GOLDEN HATCHERIES_IPP_66 | 20:42 | 20:48 | 10:16 | HAND TRIPPED |
| 872 | 4-Sep-2021 | TUMKUR | 66 | BUKKAPATNA-GOLDEN HATCHERIES_IPP_66 | GOLDEN HATCHERIES_IPP_66 | 20:42 | 20:48 | 0:05 | HAND TRIPPED |
| 873 | 4-Sep-2021 | TUMKUR | 66 | DAVANGERE SRS- AVAREGERE66 | AVAREGERE_66,MELLEKATTE_66,KADAJJI_66 | 6:10 | 6:42 | 0:32 | LINE FAULT |
| 874 | 4-Sep-2021 | TUMKUR | 66 | DAVANGERE SRS- AVAREGERE66 | AVAREGERE_66,MELLEKATTE_66,KADAJJI_66 | 6:10 | 6:42 | 0:32 | LINE FAULT |
| 875 | 4-Sep-2021 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 8:11 | 8:21 | 2:10 | LINE FAULT |
| 876 | 4-Sep-2021 | TUMKUR | 66 | DAVANGERE SRS- HARIHARA | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 8:11 | 8:21 | 0:09 | LINE FAULT |
| 877 | 4-Sep-2021 | TUMKUR | 66 | GULIGENAHALLI- SIRA | GULIGENAHALLI_66 | 8:30 | 19:47 | 11:35 | LINE CLEAR AVAILED |
| 878 | 4-Sep-2021 | TUMKUR | 66 | GULIGENAHALLI- SIRA | GULIGENAHALLI_66 | 8:30 | 19:47 | 11:16 | LINE CLEAR AVAILED |
| 879 | 4-Sep-2021 | TUMKUR | 66 | HANAGAL- B G KERE | BGKERE_66,GUDEKOTE_66 | 10:18 | 18:19 | 9:48 | LINE CLEAR AVAILED |
| 880 | 4-Sep-2021 | TUMKUR | 66 | HANAGAL- B G KERE | BGKERE_66,GUDEKOTE_66 | 10:18 | 18:19 | 8:00 | LINE CLEAR AVAILED |
| 881 | 4-Sep-2021 | TUMKUR | 66 | HANAGAL-GUDEKOTE | HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66 | 10:18 | 17:55 | 7:37 | LINE CLEAR AVAILED |
| 882 | 4-Sep-2021 | TUMKUR | 66 | HANAGAL-GUDEKOTE | HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66 | 10:18 | 17:55 | 7:37 | LINE CLEAR AVAILED |
| 883 | 4-Sep-2021 | TUMKUR | 66 | HANAGAL-NAGASAMUDRA66 | NAGASAMUDRA_66 | 10:31 | 17:55 | 7:37 | LINE CLEAR AVAILED |
| 884 | 4-Sep-2021 | TUMKUR | 66 | HANAGAL-NAGASAMUDRA66 | NAGASAMUDRA_66 | 10:31 | 17:55 | 7:24 | LINE CLEAR AVAILED |
| 885 | 4-Sep-2021 | TUMKUR | 66 | HANGAL66-RAMPURA | RAMPURA_66,NAGASAMUDRA_66 | 10:03 | 17:55 | 7:24 | LINE CLEAR AVAILED |
| 886 | 4-Sep-2021 | TUMKUR | 66 | HANGAL66-RAMPURA | RAMPURA_66,NAGASAMUDRA_66 | 10:03 | 17:55 | 7:51 | LINE CLEAR AVAILED |
| 887 | 4-Sep-2021 | TUMKUR | 66 | HARIYABBE-PD KOTE | HARIYABBE_66 | 6:52 | 6:55 | 0:03 | HAND TRIPPED |
| 888 | 4-Sep-2021 | TUMKUR | 66 | HARIYABBE-PD KOTE | HARIYABBE_66 | 6:52 | 6:55 | 0:03 | HAND TRIPPED |
| 889 | 4-Sep-2021 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 15:21 | 15:48 | 8:56 | MAIN SUPPLY FAILURE |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|------------------------------------|-------------------------------------------|-----------------------|-----------|----------|------------------------------|
| 890 | 4-Sep-2021 | TUMKUR | 66 | HOLALKERE- RAMGIRI 1 | HOLALKERE_66 | 15:21 | 15:48 | 0:27 | MAIN SUPPLY FAILURE |
| 891 | 4-Sep-2021 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 6:18 | 6:32 | 0:14 | LINE FAULT |
| 892 | 4-Sep-2021 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 15:12 | 15:18 | 9:00 | MAIN SUPPLY FAILURE |
| 893 | 4-Sep-2021 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 6:18 | 6:32 | 0:14 | LINE FAULT |
| 894 | 4-Sep-2021 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 15:12 | 15:18 | 9:00 | MAIN SUPPLY FAILURE |
| 895 | 4-Sep-2021 | TUMKUR | 66 | HONNALLI- NALLUR | NALLUR_66 | 5:31 | 5:40 | 0:08 | LINE FAULT |
| 896 | 4-Sep-2021 | TUMKUR | 66 | HONNALLI- NALLUR | NALLUR_66 | 5:31 | 5:40 | 0:08 | LINE FAULT |
| 897 | 4-Sep-2021 | TUMKUR | 66 | KIADBVNPURA_220- TMTP | TMTP_66 | 10:53 | 11:06 | 0:12 | LINE CLEAR AVAILED |
| 898 | 4-Sep-2021 | TUMKUR | 66 | KIADBVNPURA_220- TMTP | TMTP_66 | 10:53 | 11:06 | 0:12 | LINE CLEAR AVAILED |
| 899 | 4-Sep-2021 | TUMKUR | 66 | MADHUGIRI 220- KALLAMBELLA | SIRA_66, KALLAMBELLA_66 | 8:46 | 20:16 | 11:30 | LINE CLEAR AVAILED |
| 900 | 4-Sep-2021 | TUMKUR | 66 | MADHUGIRI 220- KALLAMBELLA | SIRA_66, KALLAMBELLA_66 | 8:46 | 20:16 | 11:30 | LINE CLEAR AVAILED |
| 901 | 4-Sep-2021 | TUMKUR | 66 | MADHUGIRI- KALAMBELLA | SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66 | 8:46 | 20:16 | 11:30 | LINE CLEAR AVAILED |
| 902 | 4-Sep-2021 | TUMKUR | 66 | MADHUGIRI- KALAMBELLA | SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66 | 8:46 | 20:16 | 11:30 | LINE CLEAR AVAILED |
| 903 | 4-Sep-2021 | TUMKUR | 66 | MATHOD- ENERCON1_IPP_66 | ENERCON1_IPP_66 | 18:50 | 18:59 | 0:09 | LINE FAULT |
| 904 | 4-Sep-2021 | TUMKUR | 66 | MATHOD- ENERCON1_IPP_66 | ENERCON1_IPP_66 | 18:50 | 18:59 | 0:09 | LINE FAULT |
| 905 | 4-Sep-2021 | TUMKUR | 66 | PAVAGADA 220kV- SHYLAPURA | SHYLAPURA_66 | 14:15 | 14:19 | 0:04 | LINE CLEAR AVAILED |
| 906 | 4-Sep-2021 | TUMKUR | 66 | PAVAGADA 220kV- SHYLAPURA | SHYLAPURA_66 | 14:15 | 14:19 | 0:04 | LINE CLEAR AVAILED |
| 907 | 4-Sep-2021 | TUMKUR | 66 | TR-2 | HOSAKERE_66 | 8:11 | 8:15 | 0:04 | TRANSFORMER FAULT |
| 908 | 4-Sep-2021 | TUMKUR | 66 | TR-2 | HONNUDIKE_66 | 14:31 | 14:35 | 0:04 | LINE CLEAR AVAILED |
| 909 | 4-Sep-2021 | TUMKUR | 66 | TR-2 | HOSAKERE_66 | 8:11 | 8:15 | 0:04 | TRANSFORMER FAULT |
| 910 | 4-Sep-2021 | TUMKUR | 66 | TR-2 | HONNUDIKE_66 | 14:31 | 14:35 | 0:04 | LINE CLEAR AVAILED |
| 911 | 4-Sep-2021 | TUMKUR | 66 | URDIGERE-KOLALA | KOLALA_66 | 13:07 | 13:49 | 0:41 | LINE CLEAR AVAILED |
| 912 | 4-Sep-2021 | TUMKUR | 110 | TR-3 | GUBBI_110 | 17:13 | 17:44 | 0:31 | LINE CLEAR AVAILED |
| 913 | 4-Sep-2021 | TUMKUR | 110 | TR-3 | GUBBI_110 | 17:13 | 17:44 | 0:31 | LINE CLEAR AVAILED |
| 914 | 4-Sep-2021 | TUMKUR | 220 | TR-1 | KIADBVNPURA_220 | 12:48 | 12:59 | 0:10 | LINE CLEAR AVAILED |
| 915 | 4-Sep-2021 | TUMKUR | 220 | TR-1 | KIADBVNPURA_220 | 12:48 | 12:59 | 0:10 | LINE CLEAR AVAILED |
| 916 | 4-Sep-2021 | TUMKUR | 220 | TR-2 | KIADBVNPURA_220 | 12:48 | 12:59 | 0:10 | LINE CLEAR AVAILED |
| 917 | 4-Sep-2021 | TUMKUR | 220 | TR-2 | KIADBVNPURA_220 | 12:48 | 12:59 | 0:10 | LINE CLEAR AVAILED |
| 918 | 5-Sep-2021 | BAGALKOT | 66 | HONNALLI(BANUVALLI)-HARIHAR HOSPET | STATION NOT AFFECTED HARIHAR HOSPET_66 | 12:45 (04.09.2020) | | | LINE OPEN:LINE CLEAR AVAILED |
| 919 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1 | UCHAGOAN_110 | 9:56 | 15:16 | 5:20 | LINE CLEAR AVAILED |
| 920 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1 | SOUDATTI_220 | 10:07 | 17:15 | 7:08 | LINE CLEAR AVAILED |
| 921 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1 | NIPPANI_110 | 10:09 | 17:10 | 7:01 | LINE CLEAR AVAILED |
| 922 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1 | MKHUBLI_220 | 9:22 | 12:46 | 3:24 | LINE CLEAR AVAILED |
| 923 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1 | NAVALAGI_110 | 8:40 | 8:50 | 0:10 | LINE CLEAR AVAILED |
| 924 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV1&HV2 | KANABARGI LAYOUT_110 | 9:55 | 17:10 | 7:15 | LINE CLEAR AVAILED |
| 925 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV2 | MAMADAPUR(B)_110 | 18:48 | 19:40 | 0:52 | TRANSFORMER FAULT |
| 926 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV, HV2 | NAVALAGI_110 | 8:40 | 8:50 | 0:10 | LINE CLEAR AVAILED |
| 927 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV1 | HOSAHONNATTI_110 | 13:20 | 13:40 | 0:20 | HAND TRIPPED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|--------------------------------------|--------------------------------------------|-----------------------|-----------|----------|------------------------------------|
| 928 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV1 | HOSAHONNATTI_110 | 15:30 | 15:40 | 0:10 | HAND TRIPPED |
| 929 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV1 | JAMAKHANDI_110 | 9:10 | 10:30 | 1:20 | TRANSFORMER FAULT |
| 930 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | BANAHATTI_110 | 17:12 (29.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 931 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | AMBEWADI_220 | 12:14 | 13:31 | 1:17 | HAND TRIPPED |
| 932 | 5-Sep-2021 | BAGALKOT | 110 | 110/11KV,HV2 | AMBEWADI_220 | 23:30 | 23:44 | 0:14 | HAND TRIPPED |
| 933 | 5-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV2 | HUBLI_220 | 9:58 | 12:16 | 2:18 | LINE CLEAR AVAILED |
| 934 | 5-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV3 | NIPPANI_110, BENADI_33 | 10:09 | 17:10 | 7:01 | LINE CLEAR AVAILED |
| 935 | 5-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV3 | MUNAVALLI_110 | 17:44 | 17:49 | 0:05 | LINE CLEAR AVAILED |
| 936 | 5-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV3 | MUDALGI_110 | 10:39 | 11:50 | 1:11 | LINE CLEAR AVAILED |
| 937 | 5-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV4 | KANABARGI LAYOUT_110, KAKATI_33, SUZLON_33 | 9:55 | 17:10 | 7:15 | LINE CLEAR AVAILED |
| 938 | 5-Sep-2021 | BAGALKOT | 110 | 110/33KV, HV4 | KANABARGI LAYOUT_110, KAKATI_33, SUZLON_33 | 9:55 | 17:10 | 7:15 | LINE CLEAR AVAILED |
| 939 | 5-Sep-2021 | BAGALKOT | 110 | AMBEWADI-HALIYAL(NK1) | STATION NOT AFFECTED AMBEWADI_220 | 9:54 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 940 | 5-Sep-2021 | BAGALKOT | 110 | AMBEWADI-KAVALWADA(NK2) | STATION NOT AFFECTED AMBEWADI_220 | 9:52 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 941 | 5-Sep-2021 | BAGALKOT | 110 | ANKALAGI-HIDIKAL | ANKALAGI_110 | 14:30 | 21:57 | 7:27 | LOAD CHANGE OVER |
| 942 | 5-Sep-2021 | BAGALKOT | 110 | BAGALKOT-KATARAKI(NEERBUDIHAL) | NEERBUDIHAL_110 | 3:16 | 3:30 | 0:14 | LINE FAULT |
| 943 | 5-Sep-2021 | BAGALKOT | 110 | BELGAUM220- KANABARGI LAYOUT | KANABARGI LAYOUT_110 | 9:56 | 16:02 | 6:06 | LINE CLEAR AVAILED |
| 944 | 5-Sep-2021 | BAGALKOT | 110 | BELGAUM220- VODAGOAN | VODAGOAN_110 | 9:35 | 18:02 | 8:27 | LINE CLEAR AVAILED |
| 945 | 5-Sep-2021 | BAGALKOT | 110 | BELGAUM-KANABARGI LAY OUT | KANABARGI LAY OUT_110 | 10:33 | 15:22 | 4:49 | LINE CLEAR AVAILED |
| 946 | 5-Sep-2021 | BAGALKOT | 110 | BIJAPUR220-BAGEWADI(ENERCON) | BIJAPUR_220 | 22:33 | 22:39 | 0:06 | LINE FAULT |
| 947 | 5-Sep-2021 | BAGALKOT | 110 | BPCL- NARAGUND | NARAGUND_110 | 21:05 | 21:59 | 0:54 | LINE FAULT |
| 948 | 5-Sep-2021 | BAGALKOT | 110 | CHIKKODI-SANKESHWAR | SANKESHWAR_110 | 13:40 | 16:59 | 3:19 | LINE CLEAR AVAILED |
| 949 | 5-Sep-2021 | BAGALKOT | 110 | DHAVALSHWAR-SAIDAPUR | SAIDAPUR_110 | 7:18 | 7:35 | 0:17 | LINE FAULT |
| 950 | 5-Sep-2021 | BAGALKOT | 110 | GOPANKOPPA-BIDNAL- NVLKD(NARAGUND) | STATION NOT AFFECTED GOPANAKOPPA_110 | 18:15 (24.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 951 | 5-Sep-2021 | BAGALKOT | 110 | HUBLI- KALGHATAGI | KALGHATAGI_110 | 6:47 | 7:53 | 1:06 | LINE FAULT |
| 952 | 5-Sep-2021 | BAGALKOT | 110 | HUBLI220- TARIHAL1 | TARIHAL_110 | 11:51 | 15:59 | 4:08 | NFBC ISSUED |
| 953 | 5-Sep-2021 | BAGALKOT | 110 | HUBLI220- TARIHAL2 | TARIHAL_110 | 11:51 | 15:59 | 4:08 | NFBC ISSUED |
| 954 | 5-Sep-2021 | BAGALKOT | 110 | KANABARGI LAYOUT- NEHRU NAGAR | KANABARGI LAYOUT_110 | 9:56 | 17:50 | 7:54 | LINE CLEAR AVAILED |
| 955 | 5-Sep-2021 | BAGALKOT | 110 | KHADAKLAT- NIPPANI | NIPPANI_110 | 10:30 | 17:05 | 6:35 | LINE CLEAR AVAILED |
| 956 | 5-Sep-2021 | BAGALKOT | 110 | MUGALKOD220(ITANAL)- RAIBAG1&2 | RAIBAG_110 | 10:06 | 18:15 | 8:09 | LINE CLEAR AVAILED |
| 957 | 5-Sep-2021 | BAGALKOT | 110 | RANEENNUR220- HONNATTI (AREMALLAPUR) | NO STATION AFFECTED RANEENNUR_220 | 13:16 (17.11.2020) | | | LINE OPEN:LINE FAULT |
| 958 | 5-Sep-2021 | BAGALKOT | 110 | SOUDATTI110-ENERCON1&2 | SOUDATTI_110 | 10:06 | 17:38 | 7:32 | LINE CLEAR AVAILED |
| 959 | 5-Sep-2021 | BAGALKOT | 110 | SOUDATTI220- MUNAVALLY | MUNAVALLI_110 | 10:14 | 17:15 | 7:01 | LINE CLEAR AVAILED |
| 960 | 5-Sep-2021 | BAGALKOT | 110 | SOUDATTI220- RAMDURG | RAMDURG_110 | 10:07 | 17:37 | 7:30 | LINE CLEAR AVAILED |
| 961 | 5-Sep-2021 | BAGALKOT | 110 | SOUDATTI220- SOUDATTI1&2 | SOUDATTI_110 | 10:07 | 16:26 | 6:19 | LINE CLEAR AVAILED |
| 962 | 5-Sep-2021 | BAGALKOT | 110 | SOUDATTI220- UDIKERI | UDIKERI_110 | 10:20 | 17:41 | 7:21 | LINE CLEAR AVAILED |
| 963 | 5-Sep-2021 | BAGALKOT | 110 | TODALBAGI-JAMKHANDI SUGARS | TODALBAGI_110 | 23:47 | 23:57 | 0:10 | LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|-------------------------------------|------------------------------------------|-----------------------|-----------|----------|------------------------------|
| 964 | 5-Sep-2021 | BAGALKOT | 110 | UDIKERI- NOKAR SOLAR | UDIKERI_110 | 10:20 | 17:40 | 7:20 | LINE CLEAR AVAILED |
| 965 | 5-Sep-2021 | BAGALKOT | 220 | 220/110KV,HV1&HV2 &LV1&LV2 | BELGAUM_220 | 10:08 | 14:04 | 3:56 | LINE CLEAR AVAILED |
| 966 | 5-Sep-2021 | BAGALKOT | 220 | BELGAUM-CHIKKODI 1 | BELGAUM_220 | 10:13 | 14:25 | 4:12 | LINE CLEAR AVAILED |
| 967 | 5-Sep-2021 | BAGALKOT | 220 | BELGAUM-KANABARGI 1&2 | BELGAUM_220 | 10:13 | 14:02 | 3:49 | LINE CLEAR AVAILED |
| 968 | 5-Sep-2021 | BAGALKOT | 220 | BIDNAL-HARTHI1 | STATION NOT AFFECTED BIDNAL_220 | 18:43 (01.08.2021) | | | LINE OPEN:LINE FAULT |
| 969 | 5-Sep-2021 | BAGALKOT | 220 | CHIKKODI-BELGAUM 1&2 | CHIKKODI_220 | 8:30 | 14:26 | 5:56 | LINE CLEAR AVAILED |
| 970 | 5-Sep-2021 | BAGALKOT | 220 | GADAG-HARTI1 | STATION NOT AFFECTED GADAG_220 | 9:52 (24.08.2021) | | | LINE OPEN:LINE FAULT |
| 971 | 5-Sep-2021 | BAGALKOT | 220 | MAHALINGAPUR-VAJRAMATTI 2 | STATION NOT AFFECTED MAHALINGAPUR_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 972 | 5-Sep-2021 | BAGALKOT | 220 | MKHUBLI- NARENDRA1 | MKHUBLI_220 | 9:10 | 11:44 | 2:34 | LINE CLEAR AVAILED |
| 973 | 5-Sep-2021 | BAGALKOT | 220 | MKHUBLI- NARENDRA2 | MKHUBLI_220 | 11:59 | 13:34 | 1:35 | LINE CLEAR AVAILED |
| 974 | 5-Sep-2021 | BAGALKOT | 220 | NAGJHARI1-AMBEWADI | AMBEWADI_220 | 23:40 (05.09.2021) | | | LINE OPEN:LINE FAULT |
| 975 | 5-Sep-2021 | BAGALKOT | 220 | NARENDRA-AMBEWADI2 | STATION NOT AFFECTED NARENDRA_220 | 17:22 (30.03.2021) | | | LINE OPEN:LINE FAULT |
| 976 | 5-Sep-2021 | BAGALKOT | 220 | SIRSI-HUBLI 1 | SIRSI_220 | 17:59 (30.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 977 | 5-Sep-2021 | BAGALKOT | 220 | VAJRAMATTI- MAHALINGAPUR1 | STATION NOT AFFECTED VAJRAMATTI_220 | 16:17 (23.02.2021) | | | LINE OPEN:LINE FAULT |
| 978 | 5-Sep-2021 | BAGALKOT | 220 | VAJRAMATTI-MAHALINGAPUR2 | STATION NOT AFFECTED VAJRAMATTI_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 979 | 5-Sep-2021 | BAGALKOT | 400 | DHONI- GUDDADAHALLI | DHONI_400 | 20:49 (05.09.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 980 | 5-Sep-2021 | BENGALURU | 66 | BANASHANKARI - AREHALLI | BANASHANKARI | 20:37 | 20:45 | 0:08 | LOAD CHANGE OVER |
| 981 | 5-Sep-2021 | BENGALURU | 66 | BANASHANKARI - VRISHBHAVATHI 220 | BANASHANKARI | 9:23 | 9:30 | 0:07 | LOAD CHANGE OVER |
| 982 | 5-Sep-2021 | BENGALURU | 66 | BYADRAHALLI 220 - KODIGEHALI | KODIGEHALI, TAVAREKERE | 8:40 | 17:40 | 9:00 | LINE CLEAR AVAILED |
| 983 | 5-Sep-2021 | BENGALURU | 66 | BYADRAHALLI 220 - SRS PEENYA 220 | BYADRAHALLI | 8:40 | 18:45 | 10:05 | LINE CLEAR AVAILED |
| 984 | 5-Sep-2021 | BENGALURU | 66 | CHANDAPURA - SARIJAPURA 220 | CHANDAPURA | 10:04 | 10:08 | 0:04 | LINE CLEAR AVAILED |
| 985 | 5-Sep-2021 | BENGALURU | 66 | CHANDAPURA - SARIJAPURA 220 | CHANDAPURA | 12:10 | 12:13 | 0:03 | LINE CLEAR AVAILED |
| 986 | 5-Sep-2021 | BENGALURU | 66 | CHANDRA LAYOUT - NRS 220 | CHANDRA LAYOUT | 18:45 | 18:48 | 0:03 | LOAD CHANGE OVER |
| 987 | 5-Sep-2021 | BENGALURU | 66 | CHANDRA LAYOUT - VRISHABHAVATHI 220 | CHANDRA LAYOUT | 16:47 | 17:17 | 0:30 | LOAD CHANGE OVER |
| 988 | 5-Sep-2021 | BENGALURU | 66 | ELITA PROMENEDE - KHODAYS 220 | ELITA PROMENEDE | 9:44 | 9:49 | 0:05 | LOAD CHANGE OVER |
| 989 | 5-Sep-2021 | BENGALURU | 66 | GURUVINAPURA - B V HALLI | B V HALLI | 6:42 | 6:52 | 0:10 | LINE FAULT |
| 990 | 5-Sep-2021 | BENGALURU | 66 | H1 | ALLIMARADANAHALLI | 19:49 | 19:56 | 0:07 | TRANSFORMER FAULT |
| 991 | 5-Sep-2021 | BENGALURU | 66 | HV1 | REMCO | 11:04 | 11:07 | 0:03 | LOAD CHANGE OVER |
| 992 | 5-Sep-2021 | BENGALURU | 66 | HV1 | REMCO | 9:57 | 10:02 | 0:05 | LOAD CHANGE OVER |
| 993 | 5-Sep-2021 | BENGALURU | 66 | HV1 | KOLAR 220 | 11:35 | 17:45 | 6:10 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|----------------------------------------|------------------------------------------------------|-----------------|----------------|----------|---------------------|
| 994 | 5-Sep-2021 | BENGALURU | 66 | HV2 | KHODAYS 220 | 10:01 | 10:06 | 0:05 | TRANSFORMER FAULT |
| 995 | 5-Sep-2021 | BENGALURU | 66 | HV2 | NRS 220 | 9:37 | 9:46 | 0:09 | LOAD CHANGE OVER |
| 996 | 5-Sep-2021 | BENGALURU | 66 | HV2 | NRS 220 | 16:18 | 16:25 | 0:07 | LOAD CHANGE OVER |
| 997 | 5-Sep-2021 | BENGALURU | 66 | HV2 | NRS 220 | 22:18 | 22:19 | 0:01 | LOAD CHANGE OVER |
| 998 | 5-Sep-2021 | BENGALURU | 66 | HV2 | T K HALLI 220 | 8:10 | 8:12 | 0:02 | LINE CLEAR AVAILED |
| 999 | 5-Sep-2021 | BENGALURU | 66 | HV2 | SARJAPURA 220 | 10:33 | 10:48 | 0:14 | TRANSFORMER FAULT |
| 1000 | 5-Sep-2021 | BENGALURU | 66 | HV2 | NARASAPURA | 10:35 | 22:15 | 11:40 | LINE CLEAR AVAILED |
| 1001 | 5-Sep-2021 | BENGALURU | 66 | HV2 | KACHMARANAHALLI | 19:23 | 19:28 | 0:05 | TRANSFORMER FAULT |
| 1002 | 5-Sep-2021 | BENGALURU | 66 | HV2 | KOLAR 220 | 11:35 | 17:45 | 6:10 | LINE CLEAR AVAILED |
| 1003 | 5-Sep-2021 | BENGALURU | 66 | HV2 | ATTIBELE | 23:25(4-9-2021) | 0:20(5-9-2021) | 0:55HRS | TRANSFORMER CHARGED |
| 1004 | 5-Sep-2021 | BENGALURU | 66 | HV3 | ELECTRONIC CITY | 15:36 | 15:43 | 0:07 | TRANSFORMER FAULT |
| 1005 | 5-Sep-2021 | BENGALURU | 66 | HV3 | NELEMANGALA 66 | 0:02 | 0:20 | 0:17 | TRANSFORMER FAULT |
| 1006 | 5-Sep-2021 | BENGALURU | 66 | JIGANI 220 - JIGANI 66 | JIGANI 66, JIGANI LINK ROAD | 13:42 | 13:52 | 0:10 | LOAD CHANGE OVER |
| 1007 | 5-Sep-2021 | BENGALURU | 66 | KENGERI SATELLITE TOWN - KUMBALAGODU | KENGERI SATELLITE TOWN | 19:22 | 19:31 | 0:09 | LOAD CHANGE OVER |
| 1008 | 5-Sep-2021 | BENGALURU | 66 | KENGERI SATELLITE TOWN - SIR MV LAYOUT | KENGERI SATELLITE TOWN | 11:00 | 11:07 | 0:07 | LOAD CHANGE OVER |
| 1009 | 5-Sep-2021 | BENGALURU | 66 | KODIGEHALI - ANCHEPALYA 220 | KODIGEHALI, TAVAREKERE | 19:00 | 19:10 | 0:10 | LOAD CHANGE OVER |
| 1010 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - BANGARPET 1 | NO STATION AFFECTED | 11:35 | 17:40 | 6:05 | LINE CLEAR AVAILED |
| 1011 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - BANGARPET 2 | BANGARPET | 11:35 | 17:40 | 6:05 | LINE CLEAR AVAILED |
| 1012 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - MULBAGAL | AVANI, MULBAGAL | 10:10 | 17:24 | 7:14 | LOAD CHANGE OVER |
| 1013 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - NANGALI | KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI | 10:10 | 17:30 | 7:20 | LOAD CHANGE OVER |
| 1014 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 1 | NARASAPURA, HONDA (EHT), KC VALLEY (EHT) | 10:27 | 17:30 | 7:03 | LINE CLEAR AVAILED |
| 1015 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - NARASAPURA 2 | NO STATION AFFECTED | 10:27 | 17:30 | 7:03 | LINE CLEAR AVAILED |
| 1016 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - PGCIL | PGCIL, SUGUTUR, SM MANGALA | 12:05 | 17:37 | 5:32 | LINE CLEAR AVAILED |
| 1017 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - SRINIVASAPURA | MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR | 11:35 | 17:35 | 6:00 | LINE CLEAR AVAILED |
| 1018 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - THAYLUR | THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI | 10:10 | 17:39 | 7:29 | LOAD CHANGE OVER |
| 1019 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - VEMGAL | TALAGUNDA, VEMGAL, KYALANUR | 10:46 | 17:33 | 6:47 | LINE CLEAR AVAILED |
| 1020 | 5-Sep-2021 | BENGALURU | 66 | KOLAR 220 - VOKKALERI | NO STATION AFFECTED | 10:27 | 17:42 | 7:15 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|-----------|---------|---------------------------------------|-------------------------------------------------|-------------------|------------------|----------|------------------------------|
| 1021 | 5-Sep-2021 | BENGALURU | 66 | KORAMANGALA 220 - GOLF LINK HAL 2 | K & C VALLEY | 13:24 | 13:48 | 0:24 | LINE FAULT |
| 1022 | 5-Sep-2021 | BENGALURU | 66 | MATHIKERE - GOKULA | MATHIKERE | 10:50 | 19:14 | 8:24 | LOAD CHANGE OVER |
| 1023 | 5-Sep-2021 | BENGALURU | 66 | MATHIKERE - HEBBAL 220 | MATHIKERE | 17:20 | 17:24 | 0:04 | LOAD CHANGE OVER |
| 1024 | 5-Sep-2021 | BENGALURU | 66 | PADMANABHANAGARA - SUBRAMANYAPURA 220 | PADMANABHANAGARA | 6:48 | 6:53 | 0:05 | LOAD CHANGE OVER |
| 1025 | 5-Sep-2021 | BENGALURU | 66 | RAJANKUNTE - DB PURA 220 | RAJANKUNTE | 9:55 | 10:00 | 0:05 | LOAD CHANGE OVER |
| 1026 | 5-Sep-2021 | BENGALURU | 66 | RAJANUKUNTE - D B PURA 220 | RAJANUKUNTE | 9:55 | 10:00 | 0:05 | LOAD CHANGE OVER |
| 1027 | 5-Sep-2021 | BENGALURU | 66 | RBI - SOMANAHALLI 220 | RBI, SOUTH CITY | 8:43 | 8:49 | 0:06 | LOAD CHANGE OVER |
| 1028 | 5-Sep-2021 | BENGALURU | 66 | RMV - GOKULA | RMV, TATA INSTITUTE (EHT) | 10:22 | 10:25 | 0:03 | LOAD CHANGE OVER |
| 1029 | 5-Sep-2021 | BENGALURU | 66 | RMV - HEBBAL 220 | RMV, TATA INSTITUTE (EHT) | 17:15 | 17:21 | 0:06 | LOAD CHANGE OVER |
| 1030 | 5-Sep-2021 | BENGALURU | 66 | SRIGANDA KAVALU - SRS PEENYA 220 | SRIGANDA KAVALU | 8:40 | 18:40 | 10:00 | LINE CLEAR AVAILED |
| 1031 | 5-Sep-2021 | BENGALURU | 66 | T G HALLI - BYDARAHALLI | BYADARAHALLI | 8:55 | 10:07 | 1:11 | LINE CLEAR AVAILED |
| 1032 | 5-Sep-2021 | BENGALURU | 66 | TK HALLI 220 - AKKURMOLE | AKKURMOLE, IGGALUR, K HONALGERE | 10:08 | 10:19 | 0:11 | LINE FAULT |
| 1033 | 5-Sep-2021 | BENGALURU | 66 | YELAHANKA 220 - LINE7 | KANASWADI | 5:47 | 5:57 | 0:10 | LINE FAULT |
| 1034 | 5-Sep-2021 | BENGALURU | 220 | GOWRIBIDANUR 220 - MITTEMARI 1 | NO STATION AFFECTED | 17:14(5-9-21) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1035 | 5-Sep-2021 | BENGALURU | 220 | HV1 | KOLAR 220 | 11:35 | 17:35 | 6:00 | LINE CLEAR AVAILED |
| 1036 | 5-Sep-2021 | BENGALURU | 220 | HV3 | KOLAR 220 | 11:35 | 17:29 | 5:54 | LINE CLEAR AVAILED |
| 1037 | 5-Sep-2021 | BENGALURU | 220 | MYLSANDRA 400 - SOMANAHALLI 220 | NO STATION AFFECTED | 15:54(04/09/2021) | 1:40(05/09/2021) | 9:46HRS | LINE CHARGED |
| 1038 | 5-Sep-2021 | BENGALURU | 220 | NELAMANGALA 400 - SRS PEENYA 4 | SRS PEENYA 220 | 10:15 | 17:08 | 6:53 | LINE CLEAR AVAILED |
| 1039 | 5-Sep-2021 | BENGALURU | 220 | SOMANAHALLI 220 - MYLSANDRA 400 | NO STATION AFFECTED | 15:54(04/09/2021) | 1:40(05/09/2021) | 9:46HRS | LINE CHARGED |
| 1040 | 5-Sep-2021 | GULBARGA | 66 | KUDLIGI-BANAVEKAL | BANAVEKAL_66 | 18:25 | 18:35 | 0:10 | LINE FAULT |
| 1041 | 5-Sep-2021 | GULBARGA | 66 | NEELGUND-TELGI | TELGI_66 | 14:29 | 14:38 | 0:09 | LINE FAULT |
| 1042 | 5-Sep-2021 | GULBARGA | 110 | CHITGUPPA-HUMNABAD | CHITGUPPA_110,NIRNA_110 | 6:40 | 6:50 | 0:10 | MAIN SUPPLY FAILURE |
| 1043 | 5-Sep-2021 | GULBARGA | 110 | CHITGUPPA-HUMNABAD | CHITGUPPA_110,NIRNA_110 | 7:00 | 7:05 | 0:05 | MAIN SUPPLY FAILURE |
| 1044 | 5-Sep-2021 | GULBARGA | 110 | CHITGUPPA-HUMNABAD | CHITGUPPA_110,NIRNA_110 | 12:20 | 15:15 | 2:55 | LINE FAULT |
| 1045 | 5-Sep-2021 | GULBARGA | 110 | GULBARGASOUTH-GULBARGA UNIVERSITY | GULBARGAUNIVERSITY_110 | 18:35(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1046 | 5-Sep-2021 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP | 16:54 | 16:59 | 0:05 | LINE FAULT |
| 1047 | 5-Sep-2021 | GULBARGA | 110 | HUMNABAD-CHITGUPPA | CHITGUPPA_110,NIRNA_110 | 6:39 | 6:48 | 0:09 | LINE FAULT |
| 1048 | 5-Sep-2021 | GULBARGA | 110 | HUMNABAD-CHITGUPPA | CHITGUPPA_110,NIRNA_110 | 7:01 | 7:05 | 0:04 | LINE FAULT |
| 1049 | 5-Sep-2021 | GULBARGA | 110 | HV1 | MADIYAL_110 | 8:44 | 9:17 | 0:33 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|-------------------------------|--------------------------------------------------------------|--------------------|------------------|-----------|----------------------------------------|
| 1050 | 5-Sep-2021 | GULBARGA | 110 | HV2 | VALKAMDINNI_110 | 11:15(31.08.2021) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 1051 | 5-Sep-2021 | GULBARGA | 110 | HV2 | SHAHAPUR_220 | 6:48 | 7:08 | 0:20 | TRANSFORMER FAULT |
| 1052 | 5-Sep-2021 | GULBARGA | 110 | HV2 | SHAHAPUR_220 | 7:15 | 7:20 | 0:05 | TRANSFORMER FAULT |
| 1053 | 5-Sep-2021 | GULBARGA | 110 | LADHA-BHALKI | LADHA_110 | 16:55 | 17:00 | 0:05 | MAIN SUPPLY FAILURE |
| 1054 | 5-Sep-2021 | GULBARGA | 110 | MALLAT-BYGWAT2 | ADAVI AMARESHWAR_110 | 21:53 | 22:03 | 0:10 | LINE FAULT |
| 1055 | 5-Sep-2021 | GULBARGA | 110 | MALLAT-KAVITHAL | KAVITHAL_110 | 5:22 | 5:32 | 0:10 | LINE FAULT |
| 1056 | 5-Sep-2021 | GULBARGA | 110 | MARUGUTTI-CLN SLR | MARUGUTTI_110 | 19:30(04.09.2021) | 5:51(5.09.2021) | 10:21 HRS | LINE CHARGED |
| 1057 | 5-Sep-2021 | GULBARGA | 110 | RAICHUR-APMC1 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 1:16 | 1:36 | 0:20 | LINE FAULT |
| 1058 | 5-Sep-2021 | GULBARGA | 110 | RAICHUR-APMC1 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 21:36 | 21:52 | 0:16 | LINE FAULT |
| 1059 | 5-Sep-2021 | GULBARGA | 110 | RAICHUR-APMC1&2 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 5:47 | 6:07 | 0:20 | LINE FAULT |
| 1060 | 5-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 23:22(4.09.2021) | 1:15(05.09.2021) | 1:53HRS | LINE CHARGED |
| 1061 | 5-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 1:45 | 2:05 | 0:20 | LINE FAULT |
| 1062 | 5-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 3:00 | 3:11 | 0:11 | LINE FAULT |
| 1063 | 5-Sep-2021 | GULBARGA | 110 | SEDAM-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 6:02 | 6:15 | 0:13 | LINE FAULT |
| 1064 | 5-Sep-2021 | GULBARGA | 110 | SEDAM-VICATSAGAR_110 | SEDAM_220 | 8:03 | 8:25 | 0:22 | LINE FAULT |
| 1065 | 5-Sep-2021 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 14:55(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1066 | 5-Sep-2021 | GULBARGA | 110 | SHAHABAD-GULBARGA UNIVERSITY2 | GULBARGA UNIVERSITY_110 | 09:17(14.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1067 | 5-Sep-2021 | GULBARGA | 110 | SHAHAPUR-KEMBHAVI | KEMBHAVI_110 | 0:20 | 0:30 | 0:10 | LINE FAULT |
| 1068 | 5-Sep-2021 | GULBARGA | 110 | SINDHANOOR-SIRAGUPPA | SIRAGUPPA_110,DADESUGUR_110,NSL SUGAR IPP,TEKKALAKOTE_110 | 1:40 | 1:50 | 0:10 | LINE FAULT |
| 1069 | 5-Sep-2021 | GULBARGA | 110 | SINDHANOOR-THURVIHAL | THURVIHAL_110 | 2:01 | 2:11 | 0:10 | LINE FAULT |
| 1070 | 5-Sep-2021 | GULBARGA | 110 | YELBURGA-KUSHTAGI | YELBURGA_110 | 19:40 | 21:50 | 2:10 | MAIN SUPPLY FAILURE |
| 1071 | 5-Sep-2021 | GULBARGA | 220 | HV2 | KUSHTAGI_220 | 19:39 | 21:35 | 1:56 | TRANSFORMER FAULT |
| 1072 | 5-Sep-2021 | GULBARGA | 220 | SHAHAPUR-SEDAM | SEDAM_220 | 22:10(5.09.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1073 | 5-Sep-2021 | GULBARGA | 220 | SHAHAPUR-SEDAM | SEDAM_220 | 21:03(04.09.2021) | 8:58(05.09.2021) | 11:55HRS | LINE CHARGED |
| 1074 | 5-Sep-2021 | HASSAN | 66 | HV1 | HALEBEEDU_66 | 14:33 | 15:59 | 1:26 | LINE CLEAR AVAILED |
| 1075 | 5-Sep-2021 | HASSAN | 66 | HV2 | HALEBEEDU_66 | 10:20 | 13:04 | 2:44 | LINE CLEAR AVAILED |
| 1076 | 5-Sep-2021 | HASSAN | 66 | HV2 | RAMNATHPURA_66 | 8:50 | 15:00 | 6:10 | LINE CLEAR AVAILED |
| 1077 | 5-Sep-2021 | HASSAN | 66 | HV2 | RAMNATHPURA_66 | 10:25 | 12:05 | 1:40 | LINE CLEAR AVAILED |
| 1078 | 5-Sep-2021 | HASSAN | 66 | KUDLIGE-ANVRPP | KUDLIGERE_66 | 11:30 | 14:15 | 2:45 | MAIN SUPPLY FAILURE |
| 1079 | 5-Sep-2021 | HASSAN | 66 | KUDLIGE-SIGEBAGI | KUDLIGERE_66 | 11:30 | 14:15 | 2:45 | MAIN SUPPLY FAILURE |
| 1080 | 5-Sep-2021 | HASSAN | 66 | RAMNAT-KATTEPURA_MINIH | RAMNATHPURA_66 | 10:25 | 12:15 | 1:50 | LINE CLEAR AVAILED |
| 1081 | 5-Sep-2021 | HASSAN | 66 | SIGEBAG-KDLGRE | SIGEBAGE_66 | 11:28 | 14:14 | 2:46 | LINE FAULT |
| 1082 | 5-Sep-2021 | HASSAN | 66 | UDDURKO-CHIKMANGLUR | UDDURKOPLU_66 | 10:14(3.9.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1083 | 5-Sep-2021 | HASSAN | 110 | ESSUR-BELIGAVI | ESSUR_110 | 12:35 | 15:10 | 2:35 | LINE FAULT |
| 1084 | 5-Sep-2021 | HASSAN | 110 | HV1 | ESSUR_110 | 12:35 | 15:10 | 2:35 | TRANSFORMER FAULT |
| 1085 | 5-Sep-2021 | HASSAN | 110 | HV2 | ESSUR_110 | 12:35 | 15:25 | 2:50 | TRANSFORMER FAULT |
| 1086 | 5-Sep-2021 | HASSAN | 110 | LPH-MGHE 1 | lph_gen | 11:13 (20.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1087 | 5-Sep-2021 | HASSAN | 220 | MRSSHM-DVG2 | MRSMSG_220 | 17:08 (30.08.2021) | | | LINE OPEN:LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|---------|---------|-------------------------------------|-------------------------------------------------------------------------------------|----------------------|-----------|----------|------------------------------|
| 1088 | 5-Sep-2021 | HASSAN | 220 | SHRAVITY-TALAGUPPA 2 | sharavathy_gen | 23:23 (5.09.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1089 | 5-Sep-2021 | HASSAN | 400 | UPCL-HASSAN1 | upcl_gen | 1:14(05.09.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1090 | 5-Sep-2021 | MYSURU | 66 | CHUNKANAKATTE-KR NAGARA | NO STATIONS EFFECTED | 8:20 (19/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1091 | 5-Sep-2021 | MYSURU | 66 | HARVEY-CR NAGARA | NO STATIONS EFFECTED | 9:24 (3/9/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1092 | 5-Sep-2021 | MYSURU | 66 | HUNSUR-ELWALA | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1093 | 5-Sep-2021 | MYSURU | 66 | HUNSUR-HOOTAGALLI | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1094 | 5-Sep-2021 | MYSURU | 66 | HV1 | PONNAMPETE_66 | 6:29 (4/9/2021) | 20:53 | 26:23 | TRANSFORMER CHARGED |
| 1095 | 5-Sep-2021 | MYSURU | 66 | HV2 | SANTHEMARALLI_66 | 14:06 | 14:13 | 0:06 | TRANSFORMER FAULT |
| 1096 | 5-Sep-2021 | MYSURU | 66 | HV2 | SANTHEMARALLI_66 | 11:24 | 13:46 | 2:21 | LINE CLEAR AVAILED |
| 1097 | 5-Sep-2021 | MYSURU | 66 | HV2 | TALKADU_66 | 10:15 | 18:41 | 8:25 | LINE CLEAR AVAILED |
| 1098 | 5-Sep-2021 | MYSURU | 66 | HV2 | TALKADU_66 | 18:43 | 18:53 | 0:09 | TRANSFORMER FAULT |
| 1099 | 5-Sep-2021 | MYSURU | 66 | HV2 | TUBINKERE_66 | 12:40 | 12:44 | 0:04 | TRANSFORMER FAULT |
| 1100 | 5-Sep-2021 | MYSURU | 66 | KR NAGARA-MYSORE-1 | NO STATIONS EFFECTED | 20:02 18/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1101 | 5-Sep-2021 | MYSURU | 66 | SFC SIVA-10MW | NO STATIONS EFFECTED | 9:26 | 17:47 | 8:20 | NFBC ISSUED |
| 1102 | 5-Sep-2021 | TUMKUR | 66 | CHITRADURGA 66KV- PANDARAHALLI 1 | CHITRADURGA_66, PANDARAHALLI_66,CHITRAHALLI_66,HDPURA_66,HOLALKERE_66,RAMGIRI_66 | 10:08 | 17:20 | 7:12 | LINE CLEAR AVAILED |
| 1103 | 5-Sep-2021 | TUMKUR | 66 | CHITRADURGA 66KV- PANDARAHALLI 1 | CHITRADURGA_66, PANDARAHALLI_66,CHITRAHALLI_66,HDPURA_66,HOLALKERE_66,RAMGIRI_66 | 10:08 | 17:20 | 7:12 | LINE CLEAR AVAILED |
| 1104 | 5-Sep-2021 | TUMKUR | 66 | DYAVARANAHALLI-MYLANAHALLI(THALLAK) | DYAVARANAHALLI_66 | 7:20 | 8:20 | 1:00 | LINE CLEAR AVAILED |
| 1105 | 5-Sep-2021 | TUMKUR | 66 | DYAVARANAHALLI-MYLANAHALLI(THALLAK) | DYAVARANAHALLI_66 | 7:20 | 8:20 | 1:00 | LINE CLEAR AVAILED |
| 1106 | 5-Sep-2021 | TUMKUR | 66 | H D PURA- SUZLON | SUZLON_IPP_66 | 19:47 | 20:55 | 1:07 | LINE CLEAR AVAILED |
| 1107 | 5-Sep-2021 | TUMKUR | 66 | H D PURA- SUZLON | SUZLON_IPP_66 | 19:47 | 20:55 | 1:07 | LINE CLEAR AVAILED |
| 1108 | 5-Sep-2021 | TUMKUR | 66 | HARIYABBE-PD KOTE | HARIYABBE_66 | 6:03 | 8:46 | 2:43 | LINE CLEAR AVAILED |
| 1109 | 5-Sep-2021 | TUMKUR | 66 | HARIYABBE-PD KOTE | HARIYABBE_66 | 6:03 | 8:46 | 2:43 | LINE CLEAR AVAILED |
| 1110 | 5-Sep-2021 | TUMKUR | 66 | HD PURA- CHITRADURGA | HDPURA_66 | 10:36 | 17:44 | 7:07 | LINE CLEAR AVAILED |
| 1111 | 5-Sep-2021 | TUMKUR | 66 | HD PURA- CHITRADURGA | HDPURA_66 | 10:36 | 17:44 | 7:07 | LINE CLEAR AVAILED |
| 1112 | 5-Sep-2021 | TUMKUR | 66 | TR-1 | KANCHIPURA_66 | 16:15 | 16:24 | 0:09 | TRANSFORMER FAULT |
| 1113 | 5-Sep-2021 | TUMKUR | 66 | TR-1 | TUMKUR_66 | 8:09 | 12:53 | 4:44 | TRANSFORMER FAULT |
| 1114 | 5-Sep-2021 | TUMKUR | 66 | TR-1 | DYAVARANAHALLI_66 | 7:20 | 8:20 | 1:00 | LINE CLEAR AVAILED |
| 1115 | 5-Sep-2021 | TUMKUR | 66 | TR-1 | KANCHIPURA_66 | 16:15 | 16:24 | 0:09 | TRANSFORMER FAULT |
| 1116 | 5-Sep-2021 | TUMKUR | 66 | TR-1 | TUMKUR_66 | 8:09 | 12:53 | 4:44 | TRANSFORMER FAULT |
| 1117 | 5-Sep-2021 | TUMKUR | 66 | TR-1 | DYAVARANAHALLI_66 | 7:20 | 8:20 | 1:00 | LINE CLEAR AVAILED |
| 1118 | 5-Sep-2021 | TUMKUR | 66 | TR-2 | HOSAKERE_66 | 11:36 | 13:15 | 1:38 | LINE CLEAR AVAILED |
| 1119 | 5-Sep-2021 | TUMKUR | 66 | TR-2 | HOLALKERE_66 | 9:23 | 17:33 | 8:09 | LINE CLEAR AVAILED |
| 1120 | 5-Sep-2021 | TUMKUR | 66 | TR-2 | HOSAKERE_66 | 11:36 | 13:15 | 1:38 | LINE CLEAR AVAILED |
| 1121 | 5-Sep-2021 | TUMKUR | 66 | TR-2 | HOLALKERE_66 | 9:23 | 17:33 | 8:09 | LINE CLEAR AVAILED |
| 1122 | 5-Sep-2021 | TUMKUR | 110 | TR-1 | KEREGODI_110 | 14:09 | 14:15 | 3:59 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|------------|----------|---------|------------------------------------------|---------------------------------------------------|-----------------------|-----------|----------|---------------------------------------|
| 1123 | 5-Sep-2021 | TUMKUR | 110 | TR-1 | KEREGODI_110 | 14:09 | 14:15 | 0:05 | LINE CLEAR AVAILED |
| 1124 | 6-Sep-21 | BAGALKOT | 66 | HONNALLI(BANUVALLI)-HARIHAR HOSPET | STATION NOT AFFECTED HARIHAR HOSPET_66 | 12:45 (04.09.2020) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1125 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV1 | VAJRAMATTI_110 | 5:00 | 5:19 | 0:19 | TRANSFORMER FAULT |
| 1126 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV1 | TILUVALLI_110 | 11:45 | 12:40 | 0:55 | LINE CLEAR AVAILED |
| 1127 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV1 | TILUVALLI_110 | 17:43 | 18:29 | 0:46 | LINE CLEAR AVAILED |
| 1128 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV1 | NAGNUR_110 | 5:50 | 6:00 | 0:10 | MAIN SUPPLY FAILURE |
| 1129 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV1 | NAGNUR_110 | 17:00 | 17:25 | 0:25 | MAIN SUPPLY FAILURE |
| 1130 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV1 | NAVANAGAR UNIT I_110 | 12:15 | 13:00 | 1:45 | LINE CLEAR AVAILED |
| 1131 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV1 | NAVANAGAR UNIT I_110 | 11:30 | 13:10 | 2:45 | LINE CLEAR AVAILED |
| 1132 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV2 | RANNABELAGALI_110 | 8:05 | 8:15 | 0:10 | TRANSFORMER FAULT |
| 1133 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV2 | NAGNUR_110 | 5:50 | 6:00 | 0:10 | MAIN SUPPLY FAILURE |
| 1134 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV2 | NAGNUR_110 | 17:00 | 17:25 | 0:25 | MAIN SUPPLY FAILURE |
| 1135 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV, HV2 | BORGOAN_110 | 12:00 | 13:05 | 1:05 | LINE CLEAR AVAILED |
| 1136 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV,HV2 | BANAHATTI_110 | 17:12 (29.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 1137 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV,HV2 | AIGALI_110 | 0:44 | 0:58 | 0:14 | TRANSFORMER FAULT |
| 1138 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV,HV4 | HIDIKAL_110 | 11:57 | 12:20 | 0:23 | TRANSFORMER FAULT |
| 1139 | 6-Sep-21 | BAGALKOT | 110 | 110/11KV,HV4 | KULIGOD_110 | 16:26 | 18:00 | 1:34 | TRANSFORMER FAULT |
| 1140 | 6-Sep-21 | BAGALKOT | 110 | 110/33KV, HV2 | YELPARHATTI_110, SAPTASAGAR_33, YELPARHATTI_33 | 10:35 | 13:57 | 3:22 | LINE CLEAR AVAILED |
| 1141 | 6-Sep-21 | BAGALKOT | 110 | AIMEL-JAMAKHANDI SUGARS | ALMEL_110 | 9:34 | 9:44 | 0:10 | LINE FAULT |
| 1142 | 6-Sep-21 | BAGALKOT | 110 | AIMEL-KPR SUGARS | ALMEL_110 | 9:34 | 9:42 | 0:08 | LINE FAULT |
| 1143 | 6-Sep-21 | BAGALKOT | 110 | AINAPUR-ATHANI SUGARS | AINAPUR_110 | 8:30 | 17:09 | 8:39 | LINE CLEAR AVAILED |
| 1144 | 6-Sep-21 | BAGALKOT | 110 | AMBEWADI-HALIYAL(NK1) | STATION NOT AFFECTED AMBEWADI_220 | 9:54 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1145 | 6-Sep-21 | BAGALKOT | 110 | AMBEWADI-KAVALWADA(NK2) | STATION NOT AFFECTED AMBEWADI_220 | 9:52 (22.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1146 | 6-Sep-21 | BAGALKOT | 110 | BIJAPUR220-BAGEWADI(ENERCON) | BIJAPUR_220 | 18:42 | 19:02 | 0:20 | LINE FAULT |
| 1147 | 6-Sep-21 | BAGALKOT | 110 | GHATAPRABHA220-PG HUNASYAL | PG HUNASYAL_110 | 16:57 | 17:01 | 0:04 | LINE FAULT |
| 1148 | 6-Sep-21 | BAGALKOT | 110 | GOPANKOPPA-BIDNAL- NVLKD(NARAGUND) | STATION NOT AFFECTED GOPANAKOPPA_110 | 18:15 (24.06.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1149 | 6-Sep-21 | BAGALKOT | 110 | HUNGUND-JINDAL | HUNGUND_110 | 16:10 | 16:57 | 0:47 | LINE CLEAR AVAILED |
| 1150 | 6-Sep-21 | BAGALKOT | 110 | MAMADAPUR(G)- GOKAK | GOKAK_110 | 1:05 | 1:10 | 0:05 | LINE FAULT |
| 1151 | 6-Sep-21 | BAGALKOT | 110 | NAGNUR- MUDALGI | MUDALGI_110 | 5:50 | 6:00 | 0:10 | HAND TRIPPED |
| 1152 | 6-Sep-21 | BAGALKOT | 110 | NAGNUR- MUDALGI | MUDALGI_110 | 17:00 | 17:25 | 0:25 | MAIN SUPPLY FAILURE |
| 1153 | 6-Sep-21 | BAGALKOT | 110 | PG HUNSHYAL- NAGNUR | NAGNUR_110 | 5:50 | 6:00 | 0:10 | LINE FAULT |
| 1154 | 6-Sep-21 | BAGALKOT | 110 | PG HUNSHYAL- NAGNUR | NAGNUR_110 | 17:00 | 17:25 | 0:25 | MAIN SUPPLY FAILURE |
| 1155 | 6-Sep-21 | BAGALKOT | 110 | PGHUNSHYAL- MUDALGI (NAGANUR) | NAGNUR_110 | 5:50 | 6:02 | 0:12 | LINE FAULT |
| 1156 | 6-Sep-21 | BAGALKOT | 110 | RANEBENNUR220- HONNATTI (AREMALLAPUR) | NO STATION AFFECTED RANEBENNUR_220 | 13:16 (17.11.2020) | | | LINE OPEN:LINE FAULT |
| 1157 | 6-Sep-21 | BAGALKOT | 110 | SATTI- RABAKAVI | SATTI_110 | 12:35 | 12:39 | 0:04 | HAND TRIPPED |
| 1158 | 6-Sep-21 | BAGALKOT | 110 | SATTI- RABAKAVI | SATTI_110 | 13:52 | 14:26 | 0:34 | HAND TRIPPED |
| 1159 | 6-Sep-21 | BAGALKOT | 110 | SINDAGI- CHANDKAVATE | CHANDKAVATE_110 | 5:45 | 6:00 | 0:15 | LINE FAULT |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|----------|-----------|---------|-------------------------------|------------------------------------------------|-----------------------|---------------------|----------|------------------------------------|
| 1160 | 6-Sep-21 | BAGALKOT | 110 | TUMMINKATTI- RATTIHALLI | RATTIHALLI_110 | 16:23 | 18:30 | 2:07 | LINE CLEAR AVAILED |
| 1161 | 6-Sep-21 | BAGALKOT | 110 | ZALKI- INCHAGERI | INCHAGERI_110 | 10:15 | 11:00 | 0:45 | LINE CLEAR AVAILED |
| 1162 | 6-Sep-21 | BAGALKOT | 220 | BIDNAL-HARTHI1 | STATION NOT AFFECTED BIDNAL_220 | 18:43 (01.08.2021) | | | LINE OPEN:LINE FAULT |
| 1163 | 6-Sep-21 | BAGALKOT | 220 | CHIKKODI- KUDACHI2 | CHIKKODI_220 | 2:00 | 2:30 | 0:30 | LINE FAULT |
| 1164 | 6-Sep-21 | BAGALKOT | 220 | GADAG-HARTI1 | STATION NOT AFFECTED GADAG_220 | 9:52 (24.08.2021) | | | LINE OPEN:LINE FAULT |
| 1165 | 6-Sep-21 | BAGALKOT | 220 | MAHALINGAPUR-VAJRAMATTI 2 | STATION NOT AFFECTED MAHALINGAPUR_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1166 | 6-Sep-21 | BAGALKOT | 220 | NAGIHARI1-AMBEWADI | AMBEWADI_220 | 23:40 (05.09.2021) | 00::44 (06.09.2021) | 1:04 | LINE FAULT |
| 1167 | 6-Sep-21 | BAGALKOT | 220 | NARENDRA- HUBLI1 | NARENDRA_220 | 12:58 | 15:00 | 2:02 | LINE CLEAR AVAILED |
| 1168 | 6-Sep-21 | BAGALKOT | 220 | NARENDRA-AMBEWADI2 | STATION NOT AFFECTED NARENDRA_220 | 17:22 (30.03.2021) | | | LINE OPEN:LINE FAULT |
| 1169 | 6-Sep-21 | BAGALKOT | 220 | SIRSI-HUBLI 1 | SIRSI_220 | 17:59 (30.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1170 | 6-Sep-21 | BAGALKOT | 220 | VAJRAMATTI- MAHALINGAPUR1 | STATION NOT AFFECTED VAJRAMATTI_220 | 16:17 (23.02.2021) | | | LINE OPEN:LINE FAULT |
| 1171 | 6-Sep-21 | BAGALKOT | 220 | VAJRAMATTI -MAHALINGAPUR2 | STATION NOT AFFECTED VAJRAMATTI_220 | 10:07 (24.02.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1172 | 6-Sep-21 | BAGALKOT | 400 | DHONI- GUDDADAHALLI | DHONI_400 | 20:49 (05.09.2021) | 7:46 (06.09.2021) | 11:07 | LINE CHARGED |
| 1173 | 6-Sep-21 | BENGALURU | 66 | BG ROAD - JIGANI 220 | BG ROAD | 17:16 | 17:26 | 0:10 | LOAD CHANGE OVER |
| 1174 | 6-Sep-21 | BENGALURU | 66 | BTM 4TH PHASE - SOUTH CITY | BTM 4TH PHASE | 6:09 | 6:17 | 0:08 | LOAD CHANGE OVER |
| 1175 | 6-Sep-21 | BENGALURU | 66 | HAL 220 - HOODY 1 | ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT) | 20:46 | 21:35 | 0:49 | LINE FAULT |
| 1176 | 6-Sep-21 | BENGALURU | 66 | HONNIGANAHALLI - HALAGUR | HALAGUR | 12:45 | 14:30 | 1:45 | LINE CLEAR AVAILED |
| 1177 | 6-Sep-21 | BENGALURU | 66 | HV1 | DODDABELAVANGALA | 2:21 | 2:27 | 0:06 | TRANSFORMER FAULT |
| 1178 | 6-Sep-21 | BENGALURU | 66 | HV2 | GOKULA | 21:27 | 21:41 | 0:14 | TRANSFORMER FAULT |
| 1179 | 6-Sep-21 | BENGALURU | 66 | HV2 | SOMANAHALLI 220 | 13:10 | 13:42 | 0:32 | LINE CLEAR AVAILED |
| 1180 | 6-Sep-21 | BENGALURU | 66 | HV2 | BAIRAKURU | 6:10 | 6:33 | 0:23 | TRANSFORMER FAULT |
| 1181 | 6-Sep-21 | BENGALURU | 66 | HV2 | DODDABELAVANGALA | 0:07(3-9-2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 1182 | 6-Sep-21 | BENGALURU | 66 | KADUBISANAHALLI - CESSNA | KADUBISANAHALLI | 22:12 | 22:14 | 0:02 | LOAD CHANGE OVER |
| 1183 | 6-Sep-21 | BENGALURU | 66 | KHODAYS 220 - BTM 4TH PHASE | BTM 4TH PHASE | 10:04 | 10:07 | 0:03 | LOAD CHANGE OVER |
| 1184 | 6-Sep-21 | BENGALURU | 66 | KHODAYS 220 - ELITE PROMENEDE | ELITE PROMENEDE | 10:04 | 10:07 | 0:03 | LOAD CHANGE OVER |
| 1185 | 6-Sep-21 | BENGALURU | 66 | KOLAR 220 - MULBAGAL | NO STATION AFFECTED | 5:42 | 6:55 | 1:13 | MAIN SUPPLY FAILURE |
| 1186 | 6-Sep-21 | BENGALURU | 66 | KOLAR 220 - MULBAGAL | NO STATION AFFECTED | 8:50 | 9:48 | 0:58 | LINE CLEAR AVAILED |
| 1187 | 6-Sep-21 | BENGALURU | 66 | KOLAR 220 - NANGALI | KEMBODI | 5:42 | 6:54 | 1:12 | MAIN SUPPLY FAILURE |
| 1188 | 6-Sep-21 | BENGALURU | 66 | KOLAR 220 - NANGALI | KEMBODI | 8:50 | 9:48 | 0:58 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|----------|-----------|---------|-----------------------------------|------------------------------------------------------|-------------------|--------------|-----------|----------------------------------------|
| 1189 | 6-Sep-21 | BENGALURU | 66 | KOLAR 220 - PGCIL | PGCIL, SUGUTUR, SM MANGALA | 5:42 | 6:53 | 1:11 | MAIN SUPPLY FAILURE |
| 1190 | 6-Sep-21 | BENGALURU | 66 | KOLAR 220 - SRINIVASAPURA | MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR | 5:42 | 7:02 | 1:20 | MAIN SUPPLY FAILURE |
| 1191 | 6-Sep-21 | BENGALURU | 66 | KOLAR 220 - SRINIVASAPURA | MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR | 7:18 | 9:50 | 2:32 | LINE CLEAR AVAILED |
| 1192 | 6-Sep-21 | BENGALURU | 66 | KOLAR 220 - THAYLUR | NO STATION AFFECTED | 5:42 | 6:55 | 1:13 | MAIN SUPPLY FAILURE |
| 1193 | 6-Sep-21 | BENGALURU | 66 | KOLAR 220 - THAYLUR | NO STATION AFFECTED | 8:50 | 9:48 | 0:58 | LINE CLEAR AVAILED |
| 1194 | 6-Sep-21 | BENGALURU | 66 | KUTGALLU - JALAMANGALA | KUTGALLU | 10:05 | 15:10 | 5:05 | LINE CLEAR AVAILED |
| 1195 | 6-Sep-21 | BENGALURU | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI | 15:38 | 15:58 | 0:19 | LINE FAULT |
| 1196 | 6-Sep-21 | BENGALURU | 66 | SOMANAHALLI 220 - JIGANI 1 | RBI, SOUTH CITY | 14:33 | 14:53 | 0:20 | LINE FAULT |
| 1197 | 6-Sep-21 | BENGALURU | 66 | SOMANAHALLI 220 - JIGANI 2 | BG ROAD, JIGANI 66, JIGANI LINK ROAD | 11:29 | 11:53 | 0:24 | LINE FAULT |
| 1198 | 6-Sep-21 | BENGALURU | 66 | SOMANAHALLI 220 - JIGANI 2 | BG ROAD, JIGANI 66, JIGANI LINK ROAD | 14:33 | 14:56 | 0:23 | LINE FAULT |
| 1199 | 6-Sep-21 | BENGALURU | 66 | SRS PEENYA 220 - BYADRAHALLI | BYADRAHALLI, TAVAREKERE, KODIGEHALLI | 18:53 | 19:40 | 0:47 | LINE FAULT |
| 1200 | 6-Sep-21 | BENGALURU | 66 | T GOLLAHALLI 220 - AVANI | AVANI, MULBAGAL | 18:29 | 19:49 | 1:20 | LINE FAULT |
| 1201 | 6-Sep-21 | BENGALURU | 66 | T GOLLAHALLI 220 - NANGLI | MUDIYANUR, H GOLLAHALLI, BAIRKUR, NANGLI | 6:11 | 6:21 | 0:10 | LINE FAULT |
| 1202 | 6-Sep-21 | BENGALURU | 66 | T K HALLI 220 - SIMSHA | NO STATION AFFECTED | 5:51 | 7:06 | 1:15 | LINE FAULT |
| 1203 | 6-Sep-21 | BENGALURU | 220 | GOWRIBIDANUR 220 - MITTEMARI 1 | NO STATION AFFECTED | 17:14(5-9-21) | 7:35(6-9-21) | 14:20 hrs | LINE CHARGED |
| 1204 | 6-Sep-21 | BENGALURU | 220 | HV1 | KOLAR 220 | 5:42 | 6:50 | 1:08 | TRANSFORMER FAULT |
| 1205 | 6-Sep-21 | BENGALURU | 220 | KOTIPURA 220 - MELLAHALLI | KOTIPURA 220 | 17:50 | 18:15 | 0:25 | LOAD CHANGE OVER |
| 1206 | 6-Sep-21 | BENGALURU | 220 | KOTIPURA 220 - TUBINAKERE 220 | KOTIPURA 220 | 9:25 | 9:45 | 0:20 | LOAD CHANGE OVER |
| 1207 | 6-Sep-21 | GULBARGA | 110 | GULBARGASOUTH-GULBARGA UNIVERSITY | GULBARGAUNIVERSITY_110 | 18:35(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1208 | 6-Sep-21 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,MGSSK_IPP,BHALKIS UGAR_IPP | 6:29 | 6:32 | 0:03 | LINE FAULT |
| 1209 | 6-Sep-21 | GULBARGA | 110 | HALBARGA-BHALKI | BHALKI_110,LADHA_110,MGSSK_IPP,BHALKIS UGAR_IPP | 12:32 | 14:38 | 2:06 | LINE CLEAR AVAILED |
| 1210 | 6-Sep-21 | GULBARGA | 110 | HALBARGA-SANTHPUR | SANTHPUR_110,DONGARGAON_110 | 12:32 | 13:33 | 1:01 | LINE CLEAR AVAILED |
| 1211 | 6-Sep-21 | GULBARGA | 110 | HV1 | NALWAR_110 | 10:16 | 11:40 | 1:24 | LINE CLEAR AVAILED |
| 1212 | 6-Sep-21 | GULBARGA | 110 | HV1 | NALWAR_110 | 17:16 | 17:57 | 0:41 | LINE CLEAR AVAILED |
| 1213 | 6-Sep-21 | GULBARGA | 110 | HV1 | HALBARGA_220 | 12:17 | 12:28 | 0:11 | LINE CLEAR AVAILED |
| 1214 | 6-Sep-21 | GULBARGA | 110 | HV1 | CHORNOOR_110 | 10:45 | 16:50 | 6:05 | LINE CLEAR AVAILED |
| 1215 | 6-Sep-21 | GULBARGA | 110 | HV2 | VALKAMDINNI_110 | 11:15(31.08.2021) | | | TRANSFORMER OPEN:LINE CLEAR AVAILED |
| 1216 | 6-Sep-21 | GULBARGA | 110 | HV2 | CHORNOOR_110 | 14:40 | 14:45 | 0:05 | LINE CLEAR AVAILED |
| 1217 | 6-Sep-21 | GULBARGA | 110 | HV2 | CHORNOOR_110 | 16:15 | 16:50 | 0:35 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|----------|----------|---------|-------------------------------|-------------------------------------------|----------------------|------------------|----------|------------------------------------|
| 1218 | 6-Sep-21 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 21:35 | 21:40 | 0:05 | TRANSFORMER FAULT |
| 1219 | 6-Sep-21 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 19:34 | 19:40 | 0:06 | TRANSFORMER FAULT |
| 1220 | 6-Sep-21 | GULBARGA | 110 | HV3 | VALKAMDINNI_110 | 21:00 | 21:17 | 0:17 | TRANSFORMER FAULT |
| 1221 | 6-Sep-21 | GULBARGA | 110 | MALLAT-BYGWAT2 | ADAVI AMARESHWAR_110 | 20:56 | 21:06 | 0:10 | LINE FAULT |
| 1222 | 6-Sep-21 | GULBARGA | 110 | MUDDAPUR-SINDHANOOR | MUDDAPURA_110,MASKI_110 | 1:11 | 1:20 | 0:09 | MAIN SUPPLY FAILURE |
| 1223 | 6-Sep-21 | GULBARGA | 110 | MUDDAPUR-SINDHANOOR | MUDDAPURA_110,MASKI_110 | 2:58 | 3:08 | 0:10 | MAIN SUPPLY FAILURE |
| 1224 | 6-Sep-21 | GULBARGA | 110 | MUDDAPUR-SINDHANOOR | MUDDAPURA_110,MASKI_110 | 13:28 | 13:53 | 0:25 | LINE FAULT |
| 1225 | 6-Sep-21 | GULBARGA | 110 | NIRNA-CHITGUPPA | NIRNA_110 | 6:20 | 6:35 | 0:15 | MAIN SUPPLY FAILURE |
| 1226 | 6-Sep-21 | GULBARGA | 110 | RAICHUR-APMC1 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 10:57 | 11:45 | 0:48 | LINE CLEAR AVAILED |
| 1227 | 6-Sep-21 | GULBARGA | 110 | RAICHUR-APMC2 | APMC_110,CHIKKASUGUR_110,SHAKTHINAG A_110 | 10:57 | 11:04 | 0:07 | LINE CLEAR AVAILED |
| 1228 | 6-Sep-21 | GULBARGA | 110 | RAICHUR-SHAHAPUR1 | GABBUR_110,DEODURGA_110, | 8:17 | 8:30 | 0:13 | LINE FAULT |
| 1229 | 6-Sep-21 | GULBARGA | 110 | RAICHUR-SHAHAPUR2 | GOOGLE_110 | 8:17 | 8:30 | 0:13 | LINE FAULT |
| 1230 | 6-Sep-21 | GULBARGA | 110 | RAICHUR-SHAHAPUR2 | GOOGLE_110 | 13:40 | 13:50 | 0:10 | LINE FAULT |
| 1231 | 6-Sep-21 | GULBARGA | 110 | SHAHABAD-CHITAPUR | CHITAPUR_110,KORAWAR TEMPLE_110 | 14:55(30.07.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1232 | 6-Sep-21 | GULBARGA | 110 | SHAHABAD-GULBARGA UNIVERSITY2 | GULBARGA UNIVERSITY_110 | 09:17(14.08.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1233 | 6-Sep-21 | GULBARGA | 220 | HV2 | KUDLIGI_220 | 16:18(12.08.2021) | | | TRANSFORMER OPEN:TRANSFORMER FAULT |
| 1234 | 6-Sep-21 | GULBARGA | 220 | LINGAPUR-KUSHTAGI | KUSHTAGI_220 | 13:14 | 18:14 | 5:00 | NFBC ISSUED |
| 1235 | 6-Sep-21 | GULBARGA | 220 | MALLAT-RTPS | RTPS_220 | 21:07 | | | LINE OPEN:LINE FAULT |
| 1236 | 6-Sep-21 | GULBARGA | 220 | SHAHAPUR-SEDAM | SEDAM_220 | 22:10(5.09.2021) | 7:07(06.09.2021) | 8:57HRS | LINE CHARGED |
| 1237 | 6-Sep-21 | GULBARGA | 400 | DONI-GDHALLI | GDHALLI_400 | 20:49(04.09.2021) | 7:46(06.09.2021) | 34:57HRS | LINE CHARGED |
| 1238 | 6-Sep-21 | HASSAN | 66 | HV1 | BASAVAGHATTA_66 | 12:33 | 15:42 | 3:09 | LINE CLEAR AVAILED |
| 1239 | 6-Sep-21 | HASSAN | 66 | HV2 | RAMESHWARNAGARA_66 | 4:05 | 4:26 | 0:21 | TRANSFORMER FAULT |
| 1240 | 6-Sep-21 | HASSAN | 66 | HV2 | RAMESHWARNAGARA_66 | 5:42 | 6:15 | 0:33 | LINE CLEAR AVAILED |
| 1241 | 6-Sep-21 | HASSAN | 66 | HV2 | BASAVAGHATTA_66 | 11:11 | 12:25 | 1:14 | LINE CLEAR AVAILED |
| 1242 | 6-Sep-21 | HASSAN | 110 | HV2 | BARANGI_110 | 13:57 | 16:43 | 2:46 | LINE CLEAR AVAILED |
| 1243 | 6-Sep-21 | HASSAN | 110 | HV3 | GURUVAYANAKERE_110 | 10:33 | 13:35 | 3:02 | LINE CLEAR AVAILED |
| 1244 | 6-Sep-21 | HASSAN | 110 | HV4 | SHIRALKOPPA_110 | 17:25 | 17:40 | 0:15 | LINE CLEAR AVAILED |
| 1245 | 6-Sep-21 | HASSAN | 110 | LPH-MGHE 1 | lph_gen | 11:13 (20.8.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1246 | 6-Sep-21 | HASSAN | 220 | MRSSHM-DVG2 | MRSMSG_220 | 17:08 (30.08.2021) | | | LINE OPEN:LINE FAULT |
| 1247 | 6-Sep-21 | HASSAN | 220 | SHRAVITY-TALAGUPPA 2 | sharavathy_gen | 23:23 (5.09.2021) | 14:50(6.9.2021) | 15:27hrs | LINE CHARGED |
| 1248 | 6-Sep-21 | HASSAN | 220 | TALAGU-SGS2 | TALAGUPPA_400 | 8:41 | 14:49 | 6:08 | LINE CLEAR AVAILED |
| 1249 | 6-Sep-21 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 23:56(6.9.2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1250 | 6-Sep-21 | HASSAN | 400 | TALAGU-NELAMANGALA#2 | TALAGUPPA_400 | 3:02 | 7:05 | 4:03 | HAND TRIPPED |
| 1251 | 6-Sep-21 | HASSAN | 400 | UPCL-HASSAN1 | upcl_gen | 1:14(05.09.2021) | 9:11(6.9.2021) | 31:57hrs | LINE CHARGED |
| 1252 | 6-Sep-21 | MYSURU | 66 | CHUNKANAKATTE-KR NAGARA | NO STATIONS EFFECTED | 8:20 (19/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1253 | 6-Sep-21 | MYSURU | 66 | DR PETE-KUNTUR | NO STATIONS EFFECTED | 13:37 | 17:41 | 4:04 | LINE CLEAR AVAILED |
| 1254 | 6-Sep-21 | MYSURU | 66 | HARVEY-CR NAGARA | NO STATIONS EFFECTED | 9:24 (3/9/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1255 | 6-Sep-21 | MYSURU | 66 | HUNSUR-ELWALA | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|----------|---------|---------|-----------------------------|---------------------------------------------------------------------------------|----------------------|-----------|----------|------------------------------|
| 1256 | 6-Sep-21 | MYSURU | 66 | HUNSUR-HOOTAGALLI | NO STATIONS EFFECTED | 14:03 (18/8/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1257 | 6-Sep-21 | MYSURU | 66 | HV1 | BANNUR_66 | 11:23 | 15:09 | 3:46 | LINE CLEAR AVAILED |
| 1258 | 6-Sep-21 | MYSURU | 66 | HV1 | BASARALU_66 | 9:33 | 15:52 | 6:19 | LINE CLEAR AVAILED |
| 1259 | 6-Sep-21 | MYSURU | 66 | HV1 | HALAGUR_66 | 9:06 | 15:45 | 6:38 | LINE CLEAR AVAILED |
| 1260 | 6-Sep-21 | MYSURU | 66 | HV1 | NAGAMANGLA_66 | 10:08 | 17:55 | 7:46 | LINE CLEAR AVAILED |
| 1261 | 6-Sep-21 | MYSURU | 66 | HV2 | BASARALU_66 | 9:33 | 15:53 | 6:19 | LINE CLEAR AVAILED |
| 1262 | 6-Sep-21 | MYSURU | 66 | HV2 | NAGAMANGLA_66 | 10:08 | 14:25 | 4:16 | LINE CLEAR AVAILED |
| 1263 | 6-Sep-21 | MYSURU | 66 | HV2 | NAGAMANGLA_66 | 17:49 | 17:55 | 0:05 | HAND TRIPPED |
| 1264 | 6-Sep-21 | MYSURU | 66 | HV3 | POONAMPETE_66 | 9:25 | 10:40 | 1:14 | LINE CLEAR AVAILED |
| 1265 | 6-Sep-21 | MYSURU | 66 | KM DODDI-TK HALLI | KM DODDI_66 | 10:37 | 15:09 | 4:32 | LINE CLEAR AVAILED |
| 1266 | 6-Sep-21 | MYSURU | 66 | KR NAGARA-MYSORE-1 | NO STATIONS EFFECTED | 20:02 18/08/2021) | | | LINE OPEN:LINE CLEAR AVAILED |
| 1267 | 6-Sep-21 | MYSURU | 66 | MADDUR-K HONALGERE | SOMANAHALLI_66 | 10:06 | 17:23 | 7:16 | LINE CLEAR AVAILED |
| 1268 | 6-Sep-21 | MYSURU | 66 | MEGHLAPURA-HEBBANI | THUMBLA_66 GARGESHWARI_66 VYASARAJAPUR_66 CHIDRAVALLI_66 BG PURA_66 | 6:12 | 6:36 | 0:24 | LINE FAULT |
| 1269 | 6-Sep-21 | MYSURU | 66 | NAGAMANGLA-KR PETE 220 | NAGAMANGLA_66 | 10:08 | 17:55 | 7:47 | LINE CLEAR AVAILED |
| 1270 | 6-Sep-21 | MYSURU | 66 | TALAGWADI-TK HALLI | KIADB MANDYA_66 KK DODDI_66 THUMBKERE_66 MADDUR_66 | 12:15 | 12:30 | 0:15 | LINE CLEAR AVAILED |
| 1271 | 6-Sep-21 | MYSURU | 66 | TUBINKERE-MANDYA4 | NO STATIONS EFFECTED | 12:47 | 13:43 | 0:56 | LINE CLEAR AVAILED |
| 1272 | 6-Sep-21 | MYSURU | 220 | HV1 | TUBINKERE_66 | 10:22 | 15:04 | 4:41 | LINE CLEAR AVAILED |
| 1273 | 6-Sep-21 | MYSURU | 220 | VAJMANGALA-TK HALLI | NO STATIONS EFFECTED | 7:08 | 19:03 | 11:55 | NFBC ISSUED |
| 1274 | 6-Sep-21 | TUMKUR | 66 | ANCHEPALYA 66KV-HEBBUR66 | HEBBUR_66,THIMMASANDRA_66,HONNENA HALLI_66 | 13:54 | 16:07 | 2:12 | LINE CLEAR AVAILED |
| 1275 | 6-Sep-21 | TUMKUR | 66 | DAVANGERE SRS- KUKKAWADA | KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 10:05 | 14:38 | 4:32 | LINE CLEAR AVAILED |
| 1276 | 6-Sep-21 | TUMKUR | 66 | DEVARABELIKERE- HONNALLI | DEVARABELIKERE_66 | 12:22 | 15:39 | 3:17 | MAIN SUPPLY FAILURE |
| 1277 | 6-Sep-21 | TUMKUR | 66 | HIRIYUR 220KV- BEVINAHALLI | BEVINAHALLI_66 | 12:40 | 12:50 | 0:10 | LINE FAULT |
| 1278 | 6-Sep-21 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | CHIKKAJAJUR_66,MAYAKONDA_66,SASALUHA LLA_66 | 7:21 | 7:27 | 0:05 | LINE FAULT |
| 1279 | 6-Sep-21 | TUMKUR | 66 | HOLALKERE-PANDRAHALLI2 | HOLALKERE_66 | 7:21 | 7:27 | 0:05 | LINE FAULT |
| 1280 | 6-Sep-21 | TUMKUR | 66 | HONNALI 220-HONNALLI 66 | HONNALI_66 | 12:53 | 13:06 | 0:13 | LOAD CHANGE OVER |
| 1281 | 6-Sep-21 | TUMKUR | 66 | HONNALI 220-HONNALLI 66 | HONNALI_66 | 18:46 | 18:51 | 0:05 | LOAD CHANGE OVER |
| 1282 | 6-Sep-21 | TUMKUR | 66 | HONNALLI 220kv- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 12:15 | 15:52 | 3:37 | LINE CLEAR AVAILED |
| 1283 | 6-Sep-21 | TUMKUR | 66 | HONNALLI 220kv- KUNDUR | KUNDUR_66, MALEBENNUR_66, DEVARABELKERE_66 | 12:15 | 15:52 | 3:37 | LINE CLEAR AVAILED |
| 1284 | 6-Sep-21 | TUMKUR | 66 | HONNALLI 220KV- NYAMATHI | CHILLUR_66, NYAMATHI_66, SAVALANGA_66 | 12:53 | 13:06 | 0:13 | LOAD CHANGE OVER |
| 1285 | 6-Sep-21 | TUMKUR | 66 | HONNALLI 220KV- NYAMATHI | CHILLUR_66, NYAMATHI_66, SAVALANGA_66 | 18:46 | 18:58 | 0:12 | LOAD CHANGE OVER |
| 1286 | 6-Sep-21 | TUMKUR | 66 | HONNALLI 220KV- SASUVEHALLI | SASUVEHALLI_66,CHANNAGIRI_66 | 13:09 | 13:16 | 0:07 | LINE FAULT |
| 1287 | 6-Sep-21 | TUMKUR | 66 | KUNDUR- HONNALLI | KUNDUR_66 | 12:23 | 17:55 | 5:31 | LINE CLEAR AVAILED |
| 1288 | 6-Sep-21 | TUMKUR | 66 | SHYAGALE- KUKKAWADA | SHYAGALE_66, KERECHILCHI_66, TYAVANAGI_66, SANTEBENNUR_66, BASAVAPATNA_66 | 10:00 | 15:00 | 5:00 | LINE CLEAR AVAILED |

| SL NO | Dinanka | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | Open_at | Closed_At | Duration | REMARKS |
|-------|----------|---------|---------|----------------------------------------|---------------------|---------|-----------|----------|--------------------|
| 1289 | 6-Sep-21 | TUMKUR | 66 | THALLAK 220- SEIDIAMOND_IPP_66 | SEIDIAMOND_IPP_66 | 18:26 | 18:34 | 0:08 | HAND TRIPPED |
| 1290 | 6-Sep-21 | TUMKUR | 66 | THALLAK 220- SEIVENUS_IPP_66 | SEIVENUS_IPP_66 | 18:26 | 18:34 | 0:08 | HAND TRIPPED |
| 1291 | 6-Sep-21 | TUMKUR | 66 | TR-1 | PURUVARA_66 | 9:54 | 10:30 | 0:35 | LINE CLEAR AVAILED |
| 1292 | 6-Sep-21 | TUMKUR | 66 | TR-1 | SHYAGALE_66 | 6:15 | 6:24 | 0:09 | TRANSFORMER FAULT |
| 1293 | 6-Sep-21 | TUMKUR | 66 | TR-1 &2 | HONNALLI_220 | 13:07 | 13:16 | 0:08 | HAND TRIPPED |
| 1294 | 6-Sep-21 | TUMKUR | 66 | TR-1 &2 | PULAMGATTA_66 | 13:00 | 13:50 | 0:50 | LINE CLEAR AVAILED |
| 1295 | 6-Sep-21 | TUMKUR | 66 | TR-1 (12.5MVA) | PAVAGADA_220 | 17:14 | 17:20 | 0:05 | TRANSFORMER FAULT |
| 1296 | 6-Sep-21 | TUMKUR | 220 | TR-2 100MVA | HONNALLI_220 | 13:19 | 15:40 | 2:21 | LINE CLEAR AVAILED |
| 1297 | 6-Sep-21 | TUMKUR | 400 | JAGALUR 400kv- BELLARY POOLING STATION | BPS1_400 | 10:50 | 15:47 | 4:57 | LINE CLEAR AVAILED |