

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 21.04.2020 TO 27.04.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	21-Apr-2020	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	7:17	9:02	1:45	LINE FAULT
2	21-Apr-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	8:56	8:56	LINE CLEAR AVAILED
3	21-Apr-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:44	9:04	0:20	LINE FAULT
4	21-Apr-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	9:05	15:22	6:17	LINE CLEAR AVAILED
5	21-Apr-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	15:19	19:28	4:09	LINE CLEAR AVAILED
6	21-Apr-2020	BAGALKOT	220	BIDNAL-NAGJHARI2	BIDNAL_220	0:00	15:56	15:56	LINE CLEAR AVAILED
7	21-Apr-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	CHIKKODI_200	15:19	23:59	8:40	LINE CLEAR AVAILED
8	21-Apr-2020	BAGALKOT	220	DHONI-LINGAPUR2(HALVARTI)2	DHONI_400	20:28	23:59	3:31	LINE CLEAR AVAILED
9	21-Apr-2020	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	14:19	15:22	1:03	LINE CLEAR AVAILED
10	21-Apr-2020	BAGALKOT	110	MK HUBLI 220-MK HUBLI110	MK HUBLI_110	8:49	19:20	10:31	MAIN SUPPLY FAILURE
11	21-Apr-2020	BAGALKOT	220	220/110KV, HV1&LV1	MK HUBLI_220	0:00	16:31	16:31	LINE CLEAR AVAILED
12	21-Apr-2020	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	16:31	22:12	5:41	LINE CLEAR AVAILED
13	21-Apr-2020	BAGALKOT	110	UMMACHAGI-KIRUVATTI	UMMACHAGI_110	13:33	23:59	10:26	LINE FAULT
14	21-Apr-2020	BENGALURU	66	SIR MV LAYOUT - VRUSHABHAVATHI 220	SIR MV LAYOUT, KENGERI SATELLITE TOWN, KUMBALGODU, CHANDRAPPA CIRCLE, PROVIDENT HOUSING (EHT)	14:20	14:32	0:12	LINE FAULT
15	21-Apr-2020	BENGALURU	66	SIR MV LAYOUT - VRUSHABHAVATHI 220	SIR MV LAYOUT, KENGERI SATELLITE TOWN, KUMBALGODU, CHANDRAPPA CIRCLE, PROVIDENT HOUSING (EHT)	15:10	15:22	0:12	LINE FAULT
16	21-Apr-2020	BENGALURU	220	KANAKAPURA 220 - BWSSB(EHT)	KANAKAPURA 220	14:15	14:40	0:25	MAIN SUPPLY FAILURE
17	21-Apr-2020	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	14:15	14:40	0:25	MAIN SUPPLY FAILURE
18	21-Apr-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	14:15	14:40	0:25	MAIN SUPPLY FAILURE
19	21-Apr-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HALLIMARANAHALLI	14:15	14:40	0:25	MAIN SUPPLY FAILURE
20	21-Apr-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	14:15	14:40	0:25	MAIN SUPPLY FAILURE
21	21-Apr-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	14:15	14:40	0:25	MAIN SUPPLY FAILURE
22	21-Apr-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	14:15	14:40	0:25	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
23	21-Apr-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	14:15	14:40	0:25	MAIN SUPPLY FAILURE
24	21-Apr-2020	BENGALURU	66	HV2	THAYALUR	13:03	13:33	0:29	LINE CLEAR AVAILED
25	21-Apr-2020	BENGALURU	66	HV1	THAYALUR	16:23	17:20	0:56	LINE CLEAR AVAILED
26	21-Apr-2020	BENGALURU	66	HV1	NANGALI	6:02	6:28	0:25	TRANSFORMER FAULT
27	21-Apr-2020	BENGALURU	66	HV2	HOSUR RAMAPURA	6:28	6:46	0:17	TRANSFORMER FAULT
28	21-Apr-2020	BENGALURU	66	HV2	HOSUR RAMAPURA	6:51	7:08	0:17	TRANSFORMER FAULT
29	21-Apr-2020	BENGALURU	66	HV1	D CROSS	10:58	11:06	0:08	MAIN SUPPLY FAILURE
30	21-Apr-2020	BENGALURU	66	HV2	D CROSS	10:58	11:06	0:08	MAIN SUPPLY FAILURE
31	21-Apr-2020	BENGALURU	66	HV1	D CROSS	12:15	12:25	0:10	MAIN SUPPLY FAILURE
32	21-Apr-2020	BENGALURU	66	HV2	D CROSS	12:15	12:25	0:10	MAIN SUPPLY FAILURE
33	21-Apr-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	22:02	22:16	0:13	LINE CLEAR AVAILED
34	21-Apr-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	18:16	18:22	0:05	LINE FAULT
35	21-Apr-2020	BENGALURU	220	BEGUR 220 - HOODY 220	BEGUR 220	15:02	18:46	3:44	LINE FAULT
36	21-Apr-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	1:36	1:44	0:07	LINE FAULT
37	21-Apr-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	4:48	6:10	1:21	LINE FAULT
38	21-Apr-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	16:03	16:10	0:07	LOAD CHANGE OVER
39	21-Apr-2020	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	18:34	19:04	0:29	LINE CLEAR AVAILED
40	21-Apr-2020	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	18:36	19:01	0:24	LINE CLEAR AVAILED
41	21-Apr-2020	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALGODU	KUMBALGODU, CHANDRAPPA CIRCLE, PROVIDENT HOUSING (EHT)	15:22	16:10	0:48	MAIN SUPPLY FAILURE
42	21-Apr-2020	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	0:00	11:15	11:15	LINE FAULT
43	21-Apr-2020	GULBARGA	220	HV1	ITTAGI_220	15:20	15:40	0:20	LINE CLEAR AVAILED
44	21-Apr-2020	GULBARGA	220	HV2	KUSTAGI_220	15:55	19:20	3:25	LINE CLEAR AVAILED
45	21-Apr-2020	GULBARGA	220	HV1	KUSTAGI_220	14:50	15:12	0:22	TRANSFORMER FAULT
46	21-Apr-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSLSUGARS_IPP	17:55	18:00	0:05	LINE FAULT
47	21-Apr-2020	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB,BTPS_WATER WORKS	12:20	13:20	1:00	LINE CLEAR AVAILED
48	21-Apr-2020	GULBARGA	110	HV1	RAICHUR_220	8:17	8:27	0:10	TRANSFORMER FAULT
49	21-Apr-2020	GULBARGA	110	SEDAM-SHAHBAD	CHITAPUR_110, RAJSHRECEMENTS_IPP, KORWARTEMPLE_110	5:50	6:10	0:20	LINE FAULT
50	21-Apr-2020	GULBARGA	66	ITTAGI-SUZLON1_IPP	ITTAGI_220	20:17	20:20	0:03	LINE FAULT
51	21-Apr-2020	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15			LINE OPEN DUE TO LINE FAULT.

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
52	21-Apr-2020	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15			LINE OPEN DUE TO LINE FAULT.
53	21-Apr-2020	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	5:58	11:56	5:58	LINE FAULT
54	21-Apr-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	12:56	13:47	0:51	LINE FAULT
55	21-Apr-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	17:03	20:40	3:37	LINE FAULT
56	21-Apr-2020	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	5:58	11:56	5:58	LINE FAULT
57	21-Apr-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	17:57	18:08	0:11	LINE FAULT
58	21-Apr-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	18:08	23:59	5:51	LINE FAULT
59	21-Apr-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	17:05	17:49	0:44	LINE FAULT
60	21-Apr-2020	HASSAN	220	VARAH1-KEMAR3	varahi_gen	17:03	20:40	3:37	LINE FAULT
61	21-Apr-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	17:56	23:59	6:03	LINE FAULT
62	21-Apr-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	17:04	17:49	0:45	LINE FAULT
63	21-Apr-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	10:35	10:38	0:03	HAND TRIPPED
64	21-Apr-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:56	12:42	1:46	LINE CLEAR AVAILED
65	21-Apr-2020	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	10:34	13:05	2:31	LINE CLEAR AVAILED
66	21-Apr-2020	HASSAN	110	HV1	HALADY_110	8:37	10:03	1:26	LINE CLEAR AVAILED
67	21-Apr-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	10:37	13:02	2:25	LINE CLEAR AVAILED
68	21-Apr-2020	HASSAN	110	HV1	KONDENALU_110	11:00	14:26	3:26	LINE CLEAR AVAILED
69	21-Apr-2020	HASSAN	110	HV1	SHIRALKOPPA_110	10:20	11:30	1:10	LINE CLEAR AVAILED
70	21-Apr-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:15	12:47	0:32	LINE FAULT
71	21-Apr-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:03	16:21	0:18	LINE FAULT
72	21-Apr-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:43	16:52	0:09	LINE FAULT
73	21-Apr-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	15:37	15:58	0:21	LINE FAULT
74	21-Apr-2020	HASSAN	66	HV1	DODDAKADANUR_66	9:48	10:00	0:12	MAIN SUPPLY FAILURE
75	21-Apr-2020	HASSAN	66	HV1	GANGUR_66	18:10	18:57	0:47	LINE CLEAR AVAILED
76	21-Apr-2020	HASSAN	66	HV1	KANDLI_66	12:45	12:50	0:05	TRANSFORMER FAULT
77	21-Apr-2020	HASSAN	66	HV2	KANDLI_66	12:00	12:45	0:45	LINE CLEAR AVAILED
78	21-Apr-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	16:18	16:22	0:04	LINE FAULT
79	21-Apr-2020	HASSAN	66	HV2	SHANTHIGRAMMA_66	13:01	13:15	0:14	LINE CLEAR AVAILED
80	21-Apr-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:17	10:28	0:11	LINE FAULT
81	21-Apr-2020	MYSURU	66	HV1	ANEGOLAL_66	21:30	21:34	0:03	TRANSFORMER FAULT
82	21-Apr-2020	MYSURU	66	HV1	BANNUR_66	11:37	15:16	3:39	LINE CLEAR AVAILED
83	21-Apr-2020	MYSURU	66	HV1	GARUDANAUKADDA_66	11:00	12:35	1:34	LINE CLEAR AVAILED
84	21-Apr-2020	MYSURU	66	HOOTAGALLY-HUNSUR	BANNIKUPPE_66, HANAGODU_66, HOSURGATE_66, HUNSUR_66	12:56	13:07	0:10	LINE FAULT
85	21-Apr-2020	MYSURU	66	ELWALA-HOOTAGALLI	ELAVALA_66, GAVADAGERE_66	12:57	13:11	0:14	LINE FAULT
86	21-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	11:07	11:08	0:01	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
87	21-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	11:38	11:41	0:02	LINE FAULT
88	21-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 2	B MATKERE_66, CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66, SANTHESARAGUR_66	15:29	15:33	0:03	LINE FAULT
89	21-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	11:07	11:08	0:01	LINE FAULT
90	21-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	11:38	11:40	0:02	LINE FAULT
91	21-Apr-2020	MYSURU	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66,	15:29	15:33	0:03	LINE FAULT
92	21-Apr-2020	MYSURU	66	KIRUGAVALU-VADKEPURA	KIRUGAVALU_66, VADKEPURA_66	21:30	21:41	0:11	LINE FAULT
93	21-Apr-2020	MYSURU	66	HV2	MEGALAPURA_66	13:05	14:24	1:19	LINE CLEAR AVAILED
94	21-Apr-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	16:13	16:20	0:06	LINE FAULT
95	21-Apr-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	12:31	13:38	1:07	LINE CLEAR AVAILED
96	21-Apr-2020	TUMKUR	110	TR-2	HUNSEGHATTA_110	12:00	13:34	1:35	LINE CLEAR AVAILED
97	21-Apr-2020	TUMKUR	110	TR-2	KADEHALLI_110	13:41	14:40	0:59	LINE CLEAR AVAILED
98	21-Apr-2020	TUMKUR	110	TR-1	KADEHALLI_110	14:00	14:35	0:35	LINE CLEAR AVAILED
99	21-Apr-2020	TUMKUR	110	SHETTIKERE- HANDANKERE	SHEITYKERE_110	12:18	16:33	4:15	LINE CLEAR AVAILED
100	21-Apr-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	10:18	10:28	0:10	LINE FAULT
101	21-Apr-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	13:16	13:27	0:10	LINE FAULT
102	21-Apr-2020	TUMKUR	66	TR-2	HALUVAGALU_66	20:17	22:03	1:46	TRANSFORMER FAULT
103	21-Apr-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66	16:13	16:41	0:28	LINE FAULT
104	21-Apr-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	16:06	16:17	0:10	LINE FAULT
105	21-Apr-2020	TUMKUR	66	TR-2	HONNUDIKE_66	12:35	15:23	2:48	LINE CLEAR AVAILED
106	21-Apr-2020	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	1:50	2:03	0:12	LINE FAULT
107	21-Apr-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:42	16:47	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
108	21-Apr-2020	TUMKUR	66	MADHUGIRI 220kV-KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	12:54	13:09	0:15	HAND TRIPPED
109	21-Apr-2020	TUMKUR	66	TR-2	MATHOD_66	6:44	6:51	0:06	TRANSFORMER FAULT
110	21-Apr-2020	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	20:22	21:37	1:15	LINE FAULT
111	21-Apr-2020	TUMKUR	66	TR-1	PATTANAYAKANAHALLI_66	13:06	14:25	1:18	LINE CLEAR AVOIDED
112	21-Apr-2020	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	14:21	14:25	0:04	LINE CLEAR AVOIDED
113	21-Apr-2020	TUMKUR	220	TR-1	PAVAGADA_220	18:28	18:34	0:05	TRANSFORMER FAULT
114	22-Apr-2020	BAGALKOT	110	110/11KV,HV2	KALAGHATAGI_110	1:16	1:38	0:22	TRANSFORMER FAULT
115	22-Apr-2020	BAGALKOT	110	110/11KV,HV2	KALAGHATAGI_110	13:44	14:26	0:42	HAND TRIPPED
116	22-Apr-2020	BAGALKOT	110	110/33KV, HV1	TIKOTA_110, BIJJARGI_33	10:52	10:55	0:03	TRANSFORMER FAULT
117	22-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALI_110HALASANGI_33,NEVAR GI_33,DULKHED_33	5:46	6:12	0:26	TRANSFORMER FAULT
118	22-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALI_110HALASANGI_33,NEVAR GI_33,DULKHED_33	9:59	10:05	0:06	TRANSFORMER FAULT
119	22-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALI_110HALASANGI_33,NEVAR GI_33,DULKHED_33	10:55	11:00	0:05	TRANSFORMER FAULT
120	22-Apr-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	13:04	13:13	0:09	HAND TRIPPED
121	22-Apr-2020	BAGALKOT	110	CHIKKODI 220-ANKALI	ANKALI_110	11:50	13:05	1:15	LINE CLEAR AVOIDED
122	22-Apr-2020	BAGALKOT	110	KARWAR-ARGA	ARAGA_110	11:24	12:37	1:13	LINE CLEAR AVOIDED
123	22-Apr-2020	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	17:20	18:10	0:50	LINE CLEAR AVOIDED
124	22-Apr-2020	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	11:30	13:30	2:00	LINE CLEAR AVOIDED
125	22-Apr-2020	BAGALKOT	110	RANEENNUR-AREMALLAPUR(HONNATTI)	AREMALLAPUR_110, HONNATTI_110	11:07	23:59	12:52	LINE CLEAR AVOIDED
126	22-Apr-2020	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	11:06	23:59	12:53	LINE CLEAR AVOIDED
127	22-Apr-2020	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	17:20	18:10	0:50	LINE CLEAR AVOIDED
128	22-Apr-2020	BAGALKOT	220	220/110KV, LV2	MK HUBLI_220	11:24	23:59	12:35	LINE CLEAR AVOIDED
129	22-Apr-2020	BAGALKOT	220	BALLIGAVI(SHIROLKOPPA)-RANEENNUR	RANEENNUR_220	0:00	11:16	11:16	LINE CLEAR AVOIDED
130	22-Apr-2020	BAGALKOT	220	DHONI-LINGAPUR2(HALVARTI2)	DHONI_400	0:00	8:40	8:40	LINE CLEAR AVOIDED
131	22-Apr-2020	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	11:16	23:59	12:43	LINE CLEAR AVOIDED
132	22-Apr-2020	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	0:00	11:46	11:46	LINE CLEAR AVOIDED
133	22-Apr-2020	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	0:00	11:46	11:46	LINE CLEAR AVOIDED
134	22-Apr-2020	BAGALKOT	220	SRISI-HUBLI1	SIRSI_220	11:45	23:59	12:14	LINE CLEAR AVOIDED
135	22-Apr-2020	BAGALKOT	220	SRISI-HUBLI2	SIRSI_220	11:46	23:59	12:13	LINE CLEAR AVOIDED
136	22-Apr-2020	BENGALURU	66	ELITE PROMENEDE -RBI	ELITE PROMENEDE	10:15	10:25	0:10	LOAD CHANGE OVER
137	22-Apr-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	2:57	3:12	0:15	LINE FAULT
138	22-Apr-2020	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSUR RAMAPURA, NITTRALLI	6:46	7:20	0:33	LINE FAULT
139	22-Apr-2020	BENGALURU	66	HV2	SOMAYAJANAHALLI	8:50	9:15	0:25	LINE CLEAR AVOIDED
140	22-Apr-2020	GULBARGA	110	SIDHANOOR220-SUZLON_IPP	SIDHANOOR_220	14:30	16:00	1:30	LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
141	22-Apr-2020	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	11:19	11:41	0:22	LINE FAULT
142	22-Apr-2020	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	11:19	11:42	0:23	LINE FAULT
143	22-Apr-2020	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	11:19	11:43	0:24	LINE FAULT
144	22-Apr-2020	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	12:51	13:21	0:30	LINE FAULT
145	22-Apr-2020	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15			LINE OPEN DUE TO LINE FAULT.
146	22-Apr-2020	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15			LINE OPEN DUE TO LINE FAULT.
147	22-Apr-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	14:58	19:38	4:40	LINE FAULT
148	22-Apr-2020	HASSAN	66	HV1	HALEBEEDU_66	18:25	18:42	0:17	LINE CLEAR AVAILED
149	22-Apr-2020	HASSAN	66	HV1	HALEBEEDU_66	20:01	20:45	0:44	TRANSFORMER FAULT
150	22-Apr-2020	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	18:46	21:34	2:48	LINE CLEAR AVAILED
151	22-Apr-2020	HASSAN	66	KULIGE-ANVRPP	KUDLIGERE_66	17:35	22:51	5:16	LINE FAULT
152	22-Apr-2020	HASSAN	66	KULIGE-ANVRPP	KUDLIGERE_66	22:51	23:59	1:08	LINE FAULT
153	22-Apr-2020	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	17:52	21:33	3:41	LINE FAULT
154	22-Apr-2020	HASSAN	110	HV2	ESSUR_110	15:32	16:33	1:01	LINE CLEAR AVAILED
155	22-Apr-2020	HASSAN	110	HV2	BARANGI_110	12:23	13:20	0:57	LINE CLEAR AVAILED
156	22-Apr-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	17:50	18:52	1:02	LINE FAULT
157	22-Apr-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:03	10:22	0:19	HAND TRIPPED
158	22-Apr-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:08	17:01	6:53	LINE CLEAR AVAILED
159	22-Apr-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	19:03	20:26	1:23	LINE CLEAR AVAILED
160	22-Apr-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	17:33	19:33	2:00	LINE FAULT
161	22-Apr-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	17:33	19:34	2:01	LINE FAULT
162	22-Apr-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:08	23:59	13:51	LINE CLEAR AVAILED
163	22-Apr-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:09	23:59	13:50	LINE CLEAR AVAILED
164	22-Apr-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	0:00	12:18	12:18	LINE FAULT
165	22-Apr-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	10:07	23:59	13:52	LINE CLEAR AVAILED
166	22-Apr-2020	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	10:08	23:59	13:51	LINE CLEAR AVAILED
167	22-Apr-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	17:33	19:38	2:05	LINE FAULT
168	22-Apr-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	17:33	19:39	2:06	LINE FAULT
169	22-Apr-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	0:00	12:18	12:18	LINE FAULT
170	22-Apr-2020	MYSURU	66	HV1	MADIKERI_66	9:27	13:15	3:47	LINE CLEAR AVAILED
171	22-Apr-2020	MYSURU	66	HV1	MADHUVANAHALLI_220	13:00	13:05	0:05	TRANSFORMER FAULT
172	22-Apr-2020	MYSURU	66	HV2	HULLAHALLI_66	9:25	10:00	0:34	LINE CLEAR AVAILED
173	22-Apr-2020	MYSURU	66	HV2	KRPET_66	17:30	17:55	0:25	LINE CLEAR AVAILED
174	22-Apr-2020	MYSURU	66	HV2	KRPET_220	15:47	16:04	0:17	TRANSFORMER FAULT
175	22-Apr-2020	MYSURU	66	HV5	SFCSHIVA_66	1:25	18:10	16:44	LINE CLEAR AVAILED
176	22-Apr-2020	MYSURU	66	MADHUVANAHALLI -PG PALYA	PGPALYA_66	2:32	2:40	0:08	LINE FAULT
177	22-Apr-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	19:21	19:26	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
178	22-Apr-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	17:34	17:41	0:07	LINE FAULT
179	22-Apr-2020	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	17:29	18:08	0:39	LINE CLEAR AVAILED
180	22-Apr-2020	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:17	18:35	0:18	LINE FAULT
181	22-Apr-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	DAVANGERE_SRS_220	13:00	14:10	1:09	LINE FAULT
182	22-Apr-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:45	12:00	0:14	LINE FAULT
183	22-Apr-2020	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	14:10	14:12	0:01	HAND TRIPPED
184	22-Apr-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	19:24	19:26	0:01	MAIN SUPPLY FAILURE
185	22-Apr-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:50	7:03	0:12	LINE FAULT
186	22-Apr-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:04	10:23	0:19	LINE FAULT
187	22-Apr-2020	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	14:07	14:41	0:33	HAND TRIPPED
188	22-Apr-2020	TUMKUR	66	TR-1	KUNIGAL_66	12:48	13:13	0:25	LINE CLEAR AVAILED
189	22-Apr-2020	TUMKUR	66	TR-1	YEDIYUR_66	14:05	14:12	0:06	LINE CLEAR AVAILED
190	22-Apr-2020	TUMKUR	66	TR-1(HV SIDE)	HONNALLI_220	19:24	19:26	0:01	MAIN SUPPLY FAILURE
191	22-Apr-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	4:35	4:47	0:11	TRANSFORMER FAULT
192	22-Apr-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	19:56	20:00	0:04	TRANSFORMER FAULT
193	22-Apr-2020	TUMKUR	110	TR-1	KALLUR_110	2:22	2:41	0:18	TRANSFORMER FAULT
194	22-Apr-2020	TUMKUR	110	TR-1	KGTEMPLE_110	11:44	12:49	1:05	LINE CLEAR AVAILED
195	22-Apr-2020	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	18:07	19:59	1:52	MAIN SUPPLY FAILURE
196	22-Apr-2020	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	18:07	20:01	1:53	MAIN SUPPLY FAILURE
197	22-Apr-2020	TUMKUR	220	TR-1	HONNALLI_220	18:37	19:24	0:47	MAIN SUPPLY FAILURE
198	23-Apr-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	12:03	23:59	11:56	LINE CLEAR AVAILED
199	23-Apr-2020	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	14:00	14:51	0:51	LINE CLEAR AVAILED
200	23-Apr-2020	BAGALKOT	110	BELGAUM220-NEHARU NAGAR	NEHARU NAGAR_110	21:25	21:50	0:25	LINE FAULT
201	23-Apr-2020	BAGALKOT	110	BELGAUM220-NEHARU NAGAR	NEHARU NAGAR_110	21:51	23:59	2:08	LINE FAULT
202	23-Apr-2020	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	0:00	12:03	12:03	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
203	23-Apr-2020	BAGALKOT	110	HIDIKAL DAM-ANKALAGI	HIDIKAL DAM_110	13:58	14:59	1:01	LINE CLEAR AVAILED
204	23-Apr-2020	BAGALKOT	110	110/11KKV,HV 3	RAIBAG_110	7:04	7:08	0:04	TRANSFORMER FAULT
205	23-Apr-2020	BAGALKOT	220	DHONI-GADAG 2	DHONI_400	13:10	18:05	4:55	LINE FAULT
206	23-Apr-2020	BAGALKOT	220	DHONI-GADAG 1	DHONI_400	16:07	18:05	1:58	NFBC ISSUED
207	23-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALI_110HALASANGI_33,NEVAR GI_33,DULKHED_33	11:51	12:10	0:19	TRANSFORMER FAULT
208	23-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALI_110HALASANGI_33,NEVAR GI_33,DULKHED_33	13:19	13:26	0:07	TRANSFORMER FAULT
209	23-Apr-2020	BAGALKOT	110	110/33KV,HV4	MACHE_110, ASHOK IRON PLANT_33, KHANAPUR_33	12:47	13:35	0:48	TRANSFORMER FAULT
210	23-Apr-2020	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220	4:35	6:08	1:33	TRANSFORMER FAULT
211	23-Apr-2020	BAGALKOT	110	KUDACHI220-SHIRGUPPI	SHIRGUPPI_110	4:35	5:25	0:50	LINE FAULT
212	23-Apr-2020	BAGALKOT	220	HARTI1-GADAG	GADAG_220	0:00	16:02	16:02	LINE CLEAR AVAILED
213	23-Apr-2020	BAGALKOT	220	HARTI1-GADAG	GADAG_220	18:08	23:59	5:51	LINE CLEAR AVAILED
214	23-Apr-2020	BAGALKOT	220	GADAG-BAGALKOT2	GADAG_220	15:12	15:26	0:14	HAND TRIPPED
215	23-Apr-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	9:56	10:05	0:09	LINE FAULT
216	23-Apr-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	13:04	13:44	0:40	LINE CLEAR AVAILED
217	23-Apr-2020	BENGALURU	66	HV2	JAYADEVA	10:56	12:02	1:06	LINE CLEAR AVAILED
218	23-Apr-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	0:00	0:47	0:47	LOAD CURTAILMENT
219	23-Apr-2020	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI,ADDAGAL	6:05	6:10	0:05	LINE FAULT
220	23-Apr-2020	BENGALURU	66	HV1	L R BANDE	10:10	10:15	0:05	LINE CLEAR AVAILED
221	23-Apr-2020	BENGALURU	66	HV1	L R BANDE	21:18	21:20	0:02	LINE CLEAR AVAILED
222	23-Apr-2020	BENGALURU	66	HV1	L R BANDE	21:45	21:50	0:05	LINE CLEAR AVAILED
223	23-Apr-2020	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	DIBBURAHALLI	22:49	22:57	0:07	LINE FAULT
224	23-Apr-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SIDHANOOR_220	12:45	15:20	2:35	LINE FAULT
225	23-Apr-2020	GULBARGA	220	HV1, HV2	KUSTAGI_220	14:20	14:46	0:26	TRANSFORMER FAULT
226	23-Apr-2020	GULBARGA	220	KUSTAGI-OSTROWIND_IPP	KUSTAGI_220	14:20	17:25	3:05	LINE FAULT
227	23-Apr-2020	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110, HUNSAGI_110, ASKI_110	3:35	3:42	0:07	LINE FAULT
228	23-Apr-2020	GULBARGA	66	HV2	GUDEKOTE_110	8:25	8:30	0:05	LINE CLEAR AVAILED
229	23-Apr-2020	GULBARGA	66	HV2	GUDEKOTE_110	12:30	12:50	0:20	LINE CLEAR AVAILED
230	23-Apr-2020	GULBARGA	66	HV1	GUDEKOTE_110	5:00	5:05	0:05	TRANSFORMER FAULT
231	23-Apr-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	17:35	18:05	0:30	LINE CLEAR AVAILED
232	23-Apr-2020	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15			LINE OPEN DUE TO LINE FAULT.
233	23-Apr-2020	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15			LINE OPEN DUE TO LINE FAULT.
234	23-Apr-2020	HASSAN	400	TALAGU-NELAMANG2	TALAGUPPA_400	17:41	23:59	6:18	LINE FAULT
235	23-Apr-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	19:35	23:59	4:24	LINE CLEAR AVAILED
236	23-Apr-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	9:50	12:42	2:52	LINE CLEAR AVAILED
237	23-Apr-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	19:35	23:59	4:24	LINE CLEAR AVAILED
238	23-Apr-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:50	12:42	2:52	LINE CLEAR AVAILED
239	23-Apr-2020	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:05	16:17	6:12	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
240	23-Apr-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:40	12:57	1:17	LINE CLEAR AVAILED
241	23-Apr-2020	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	9:50	10:43	0:53	LINE CLEAR AVAILED
242	23-Apr-2020	HASSAN	66	HV1	HALEBEEDU_66	11:28	15:47	4:19	LINE CLEAR AVAILED
243	23-Apr-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	0:00	10:38	10:38	LINE FAULT
244	23-Apr-2020	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:19	12:45	1:26	NFBC ISSUED
245	23-Apr-2020	HASSAN	66	HV2	MATTNAVILE_66	16:33	18:28	1:55	TRANSFORMER FAULT
246	23-Apr-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	10:01	13:53	3:52	LINE CLEAR AVAILED
247	23-Apr-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	10:01	13:53	3:52	LINE CLEAR AVAILED
248	23-Apr-2020	HASSAN	66	SHANTHI-MALALI	SHANTHIGRAMMA_66	11:22	12:46	1:24	LINE CLEAR AVAILED
249	23-Apr-2020	HASSAN	66	UDAYAP-CRPATNA	UDAYAPURA_66	11:40	12:45	1:05	NFBC ISSUED
250	23-Apr-2020	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	6:03	6:20	0:17	LINE FAULT
251	23-Apr-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	11:36	12:41	1:05	LINE CLEAR AVAILED
252	23-Apr-2020	MYSURU	66	HOOTAGALLI-ELWALA	ELAVALA_66, GAVADAGERE_66	6:41	6:56	0:14	LINE FAULT
253	23-Apr-2020	MYSURU	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66, HANAGODU_66, HOSURGATE_66, HUNSUR_66	6:41	6:58	0:16	LINE FAULT
254	23-Apr-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	16:31	16:37	0:06	LINE FAULT
255	23-Apr-2020	MYSURU	66	HV1	TUMBEKERE_66	10:08	11:35	1:27	LINE CLEAR AVAILED
256	23-Apr-2020	MYSURU	66	SANTHEBACHALLI- HUYGONAHALLI	SANTHEBACHALLI_66 HARIYALDAMMATEMPLE_66	20:12	20:17	0:05	LINE FAULT
257	23-Apr-2020	MYSURU	66	K M DODDI-TK HALLI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	20:26	21:06	0:40	LINE FAULT
258	23-Apr-2020	MYSURU	66	K HONNALAGERE -IGGALUR	K_HONNALGERE_66	20:25	20:50	0:25	HAND TRIPPED
259	23-Apr-2020	MYSURU	66	K HONNALAGERE -IGGALUR	K_HONNALGERE_66	17:00	17:10	0:10	HAND TRIPPED
260	23-Apr-2020	MYSURU	66	KADU KOTHANAHALLI - MALAVALLI	MALAVALLI_66 HADLI_66	20:00	20:10	0:10	LINE FAULT
261	23-Apr-2020	MYSURU	66	YATTAMBADI -TK HALLI	YETHAMBADI_66	20:25	20:50	0:25	HAND TRIPPED
262	23-Apr-2020	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	17:45	18:19	0:33	LINE CLEAR AVAILED
263	23-Apr-2020	TUMKUR	110	TR-2	SAMPIGE_110	11:34	13:17	1:42	LINE CLEAR AVAILED
264	23-Apr-2020	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	10:09	20:06	9:57	LINE CLEAR AVAILED
265	23-Apr-2020	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	12:10	17:33	5:23	LINE CLEAR AVAILED
266	23-Apr-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	3:28	3:46	0:18	TRANSFORMER FAULT
267	23-Apr-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	13:12	14:25	1:13	TRANSFORMER FAULT
268	23-Apr-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	17:04	17:22	0:17	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
269	23-Apr-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	10:07	10:11	0:04	HAND TRIPPED
270	23-Apr-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	20:45	20:47	0:01	HAND TRIPPED
271	23-Apr-2020	TUMKUR	66	TR-1	BELADARA_66	10:07	10:12	0:04	HAND TRIPPED
272	23-Apr-2020	TUMKUR	66	TR-1	BELADARA_66	20:45	20:47	0:02	HAND TRIPPED
273	23-Apr-2020	TUMKUR	66	TR-2	BELADARA_66	10:07	10:12	0:04	HAND TRIPPED
274	23-Apr-2020	TUMKUR	66	TR-2	BELADARA_66	20:45	20:47	0:02	HAND TRIPPED
275	23-Apr-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	6:09	6:13	0:04	TRANSFORMER FAULT
276	23-Apr-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	8:58	9:04	0:05	TRANSFORMER FAULT
277	23-Apr-2020	TUMKUR	66	TR-2	HIREGUNTANUR_66	9:49	9:53	0:03	TRANSFORMER FAULT
278	23-Apr-2020	TUMKUR	66	HIREHALLI - ANTHRASANAHALLI	HIREHALLY_66	10:13	20:53	10:40	LOAD CHANGE OVER
279	23-Apr-2020	TUMKUR	66	HIREHALLI - BADDIHALLI	HIREHALLY_66	11:48	20:29	8:41	LOAD CHANGE OVER
280	23-Apr-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	3:50	3:57	0:07	LINE FAULT
281	23-Apr-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	13:40	13:46	0:06	LINE FAULT
282	23-Apr-2020	TUMKUR	66	TR-2	MELKOTE_66	10:51	11:16	0:25	LINE CLEAR AVAILED
283	23-Apr-2020	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	16:20	16:32	0:12	MAIN SUPPLY FAILURE
284	23-Apr-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	13:31	13:56	0:25	LINE CLEAR AVAILED
285	23-Apr-2020	TUMKUR	66	TR-1	TUMKUR_66	20:46	20:52	0:06	HAND TRIPPED
286	23-Apr-2020	TUMKUR	66	TR-2	TUMKUR_66	20:46	20:51	0:05	HAND TRIPPED
287	24-Apr-2020	BAGALKOT	110	110/11KV,HV 1	BAGALKOT_110	10:21	11:50	1:29	LINE CLEAR AVAILED
288	24-Apr-2020	BAGALKOT	110	110/11KV,HV1	BILAGI_110	11:02	11:08	0:06	TRANSFORMER FAULT
289	24-Apr-2020	BAGALKOT	110	110/11KV,HV2	SHIROL_110	16:58	18:17	1:19	LINE CLEAR AVAILED
290	24-Apr-2020	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	17:00	17:04	0:04	TRANSFORMER FAULT
291	24-Apr-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110	6:13	6:20	0:07	TRANSFORMER FAULT
292	24-Apr-2020	BAGALKOT	110	110/33KV,HV2	UTTUR_110,YADAVAD_33,VANT AGODI_33	13:26	13:37	0:11	TRANSFORMER FAULT
293	24-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DUL AKED_33,NEVARGI_33	8:06	8:11	0:05	TRANSFORMER FAULT
294	24-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DUL AKED_33,NEVARGI_33	9:43	9:46	0:03	TRANSFORMER FAULT
295	24-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DUL AKED_33,NEVARGI_33	11:41	12:02	0:21	TRANSFORMER FAULT
296	24-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DUL AKED_33,NEVARGI_33	13:53	14:01	0:08	TRANSFORMER FAULT
297	24-Apr-2020	BAGALKOT	110	BELGAUM220-BELGAUM110	BELGAUM_110	0:00	1:53	1:53	LINE CLEAR AVAILED
298	24-Apr-2020	BAGALKOT	110	GADAG-LAXMESHWAR 2	LAXMESHWAR_110,BELLATTI_110	18:39	23:59	5:20	LINE FAULT
299	24-Apr-2020	BAGALKOT	110	GADAG-SHIRAHATTI	SHIRAHATTI_110	18:33	23:59	5:26	LINE FAULT
300	24-Apr-2020	BAGALKOT	110	ITNAL-HIDIKAL	ITNAL_110	9:16	18:23	9:07	LINE CLEAR AVAILED
301	24-Apr-2020	BAGALKOT	110	KUD DHARWAD(NARENDRA)-TADASINAKOPPA	TADASINAKOPPA_110	10:33	15:58	5:25	LINE CLEAR AVAILED
302	24-Apr-2020	BAGALKOT	110	LAXMESHWAR-GADAG 1	LAXMESHWAR_110	18:39	23:59	5:20	LINE FAULT
303	24-Apr-2020	BAGALKOT	110	MK HUBLI-BAILHONGAL	BAILHONGAL_110	10:47	10:54	0:07	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
304	24-Apr-2020	BAGALKOT	110	RANEENNUR-AREMALLAPUR(HONNATTI)	HONNATTI_110	0:00	12:17	12:17	LINE CLEAR AVAILED
305	24-Apr-2020	BAGALKOT	110	SIRSI-KUMTA1&2	KUMTA_110	9:19	13:10	3:51	NFBC ISSUED
306	24-Apr-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	TADASINAKOPPA_110	15:58	23:59	8:01	LINE CLEAR AVAILED
307	24-Apr-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	TADASINAKOPPA_110	0:00	10:33	10:33	LINE CLEAR AVAILED
308	24-Apr-2020	BAGALKOT	110	VAJRAMATTI220-KATARAKI	KATARAKI_110	2:35	2:40	0:05	LINE FAULT
309	24-Apr-2020	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	3:53	3:57	0:04	HAND TRIPPED
310	24-Apr-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	RANEENNUR_220	11:43	23:59	12:16	LINE CLEAR AVAILED
311	24-Apr-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	RANEENNUR_220	0:09	23:59	23:50	LINE CLEAR AVAILED
312	24-Apr-2020	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	15:33	15:45	0:12	LOAD CHANGE OVER
313	24-Apr-2020	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	6:50	7:32	0:42	MAIN SUPPLY FAILURE
314	24-Apr-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	6:58	7:34	0:36	LINE FAULT
315	24-Apr-2020	BENGALURU	66	HV1	PATHPALYA	15:28	15:46	0:17	TRANSFORMER FAULT
316	24-Apr-2020	BENGALURU	66	HV1	PATHPALYA	16:01	16:09	0:07	TRANSFORMER FAULT
317	24-Apr-2020	BENGALURU	66	HV1	MULABAGALU	8:31	9:18	0:47	TRANSFORMER FAULT
318	24-Apr-2020	BENGALURU	66	HV1	MULABAGALU	9:19	9:35	0:15	LINE CLEAR AVAILED
319	24-Apr-2020	BENGALURU	66	HV1	DEVANAHALLI	6:16	6:30	0:14	TRANSFORMER FAULT
320	24-Apr-2020	BENGALURU	66	HV1	D CROSS	6:06	6:13	0:06	TRANSFORMER FAULT
321	24-Apr-2020	BENGALURU	66	HV1	D CROSS	6:32	7:44	1:12	TRANSFORMER FAULT
322	24-Apr-2020	BENGALURU	66	HV1	CHELUR	16:30	17:31	1:00	LINE CLEAR AVAILED
323	24-Apr-2020	BENGALURU	66	HV1	KHODAYS 220	12:23	12:30	0:07	LOAD CHANGE OVER
324	24-Apr-2020	BENGALURU	66	HV1	T K HALLI 220	2:01	2:03	0:02	TRANSFORMER FAULT
325	24-Apr-2020	BENGALURU	66	HV2	MULABAGALU	19:20	19:50	0:29	TRANSFORMER FAULT
326	24-Apr-2020	BENGALURU	66	HV2	KHODAYS 220	12:23	12:30	0:07	LOAD CHANGE OVER
327	24-Apr-2020	BENGALURU	66	HV2	NIMHANS	8:48	9:01	0:13	TRANSFORMER FAULT
328	24-Apr-2020	BENGALURU	66	HV3	DEVANAHALLI	6:10	6:30	0:20	TRANSFORMER FAULT
329	24-Apr-2020	BENGALURU	66	IISC - HEBBAL 220	IISC	6:50	7:00	0:10	MAIN SUPPLY FAILURE
330	24-Apr-2020	BENGALURU	66	IISC - NRS 220	IISC	12:40	12:45	0:05	LOAD CHANGE OVER
331	24-Apr-2020	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	12:23	12:30	0:07	LOAD CHANGE OVER
332	24-Apr-2020	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	5:59	7:27	1:27	LINE FAULT
333	24-Apr-2020	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	14:19	14:38	0:18	LINE CLEAR AVAILED
334	24-Apr-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	14:37	14:43	0:06	LINE CLEAR AVAILED
335	24-Apr-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	18:11	18:15	0:03	LINE CLEAR AVAILED
336	24-Apr-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	14:37	14:43	0:05	LINE CLEAR AVAILED
337	24-Apr-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:11	18:15	0:03	LINE CLEAR AVAILED
338	24-Apr-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:27	10:35	0:08	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
339	24-Apr-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	14:00	14:08	0:08	LINE CLEAR AVAILED
340	24-Apr-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:27	10:35	0:08	LINE CLEAR AVAILED
341	24-Apr-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	14:00	14:08	0:08	LINE CLEAR AVAILED
342	24-Apr-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDI, LAKKUR	14:37	14:43	0:05	LINE CLEAR AVAILED
343	24-Apr-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDI, LAKKUR	18:11	18:15	0:03	LINE CLEAR AVAILED
344	24-Apr-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	10:27	10:35	0:08	LINE CLEAR AVAILED
345	24-Apr-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	14:00	14:08	0:08	LINE CLEAR AVAILED
346	24-Apr-2020	BENGALURU	66	MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66	MANYATHA TECH PARK 66	6:50	7:18	0:28	MAIN SUPPLY FAILURE
347	24-Apr-2020	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY(EHT)	SHOBHA CITY(EHT)	6:50	7:18	0:28	MAIN SUPPLY FAILURE
348	24-Apr-2020	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	12:08	12:15	0:07	LOAD CHANGE OVER
349	24-Apr-2020	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	8:37	8:41	0:04	LOAD CHANGE OVER
350	24-Apr-2020	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	12:21	12:25	0:04	LOAD CHANGE OVER
351	24-Apr-2020	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	18:25	18:30	0:05	LOAD CHANGE OVER
352	24-Apr-2020	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	12:05	12:10	0:05	LOAD CHANGE OVER
353	24-Apr-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	12:12	12:20	0:08	LOAD CHANGE OVER
354	24-Apr-2020	BENGALURU	220	HEBBAL 220 - MANYATHA TECH PARK 220	HEBBAL 220	6:50	7:14	0:24	MAIN SUPPLY FAILURE
355	24-Apr-2020	BENGALURU	220	HEBBAL 220 - PEENYA 220	HEBBAL 220	10:02	10:03	0:01	LOAD CHANGE OVER
356	24-Apr-2020	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	MANYATHA TECH PARK 220	6:50	7:18	0:28	MAIN SUPPLY FAILURE
357	24-Apr-2020	BENGALURU	220	YELAHANKA 220 - MANYATHA 220	HEBBAL 220, MANYATHA 220	6:50	9:35	2:44	LINE FAULT
358	24-Apr-2020	GULBARGA	66	ITTAGI-SUZLON1_IPP,SUZLON2_IPP	ITTAGI_220	11:08	18:05	6:57	LINE CLEAR AVAILED
359	24-Apr-2020	GULBARGA	66	TAMBRAHALLI-ITTAGI	TAMBRAHALLI_66	18:30	23:59	5:29	LINE CLEAR AVAILED
360	24-Apr-2020	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110, KONKAL_110	5:00	5:05	0:05	LINE FAULT
361	24-Apr-2020	GULBARGA	110	HV1	HANUMASAGAR_110, HIREGONNAGAR_110, HANUMANAL_110	14:15	14:25	0:10	TRANSFORMER FAULT
362	24-Apr-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	19:45	19:55	0:10	LINE FAULT
363	24-Apr-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	19:56	20:00	0:04	LINE FAULT
364	24-Apr-2020	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	23:38	23:54	0:16	LINE FAULT
365	24-Apr-2020	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	23:20	23:30	0:10	LINE FAULT
366	24-Apr-2020	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	3:25	3:35	0:10	LINE FAULT
367	24-Apr-2020	GULBARGA	220	RTPS-SHAHPUR2	SHAHPUR_220	9:48	23:59	14:11	LINE CLEAR AVAILED
368	24-Apr-2020	GULBARGA	220	RTPS-SHAHPUR2	SHAHPUR_220	0:00	12:36	12:36	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
369	24-Apr-2020	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15			LINE OPEN DUE TO LINE FAULT.
370	24-Apr-2020	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15			LINE OPEN DUE TO LINE FAULT.
371	24-Apr-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	5:02	5:15	0:13	LINE FAULT
372	24-Apr-2020	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	6:00	6:07	0:07	LINE FAULT
373	24-Apr-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:45	18:22	8:37	LINE CLEAR AVAILED
374	24-Apr-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:45	18:32	8:47	LINE CLEAR AVAILED
375	24-Apr-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:47	12:03	0:16	LINE CLEAR AVAILED
376	24-Apr-2020	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	11:48	12:12	0:24	LINE CLEAR AVAILED
377	24-Apr-2020	HASSAN	110	GUURUVA-KEMAR1	GURUVAYANAKERE_110	10:25	13:03	2:38	NFBC ISSUED
378	24-Apr-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:25	13:03	2:38	LINE CLEAR AVAILED
379	24-Apr-2020	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:07	13:17	0:10	LINE FAULT
380	24-Apr-2020	HASSAN	220	ARSK2-HSN	ARASIKERE_220	10:43	12:08	1:25	LINE CLEAR AVAILED
381	24-Apr-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:07	23:59	8:52	NFBC ISSUED
382	24-Apr-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	0:00	14:51	14:51	LINE CLEAR AVAILED
383	24-Apr-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:07	23:59	8:52	LINE CLEAR AVAILED
384	24-Apr-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	0:00	14:51	14:51	LINE CLEAR AVAILED
385	24-Apr-2020	MYSURU	66	CR NAGARA-GUNDLUPETE	BEGUR_66, BHARGI_66, BOMMALAPURA_66, GUNDULPET_66, HANGLA_66, SINDHUVALI_66, TERAKANAMBE_66	5:41	5:53	0:12	LINE FAULT
386	24-Apr-2020	MYSURU	66	CR NAGARA-KABBALLI	HARVEY_66, KABHALLY_66.	5:41	5:54	0:12	LINE FAULT
387	24-Apr-2020	MYSURU	66	GUDDENAHALLI-JAKKANAHALLI	GUDDENAHALLI STATION INTERRUPTED.	15:41	16:32	0:50	LINE CLEAR AVAILED
388	24-Apr-2020	MYSURU	66	GUDDENAHALLI-JAKKANAHALLI	GUDDENAHALLI STATION INTERRUPTED.	23:10	23:59	0:48	LINE CLEAR AVAILED
389	24-Apr-2020	MYSURU	66	HV1	DKMAIDANA_66	20:11	20:16	0:05	TRANSFORMER FAULT
390	24-Apr-2020	MYSURU	66	HV1	SANIVARASANTHE_66	19:41	19:56	0:14	TRANSFORMER FAULT
391	24-Apr-2020	MYSURU	66	HV2	KMDODDI_66	3:23	3:44	0:20	TRANSFORMER FAULT
392	24-Apr-2020	MYSURU	66	HV2	KOPPA_66	9:42	10:11	0:29	LINE CLEAR AVAILED
393	24-Apr-2020	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 ,KITTUR_6 6 RAVANDUR_66	22:47	23:05	0:18	LINE FAULT
394	24-Apr-2020	MYSURU	66	MALLAVALLI-K K HALLI	MALAVALLI_66 HADLI_66	10:30	12:59	2:28	LINE CLEAR AVAILED
395	24-Apr-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	5:46	5:53	0:07	LINE FAULT
396	24-Apr-2020	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	14:04	14:09	0:04	LINE FAULT
397	24-Apr-2020	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	10:07	18:48	8:41	LINE CLEAR AVAILED
398	24-Apr-2020	TUMKUR	66	ANTHRASANAHALI 220KV- KORA	KORA_66, THOVINAKERE_66	10:07	19:17	9:10	LINE CLEAR AVAILED
399	24-Apr-2020	TUMKUR	66	ANTHRASANAHALI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:06	19:24	9:17	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
400	24-Apr-2020	TUMKUR	66	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	10:07	19:15	9:08	LINE CLEAR AVAILED
401	24-Apr-2020	TUMKUR	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	10:05	19:21	9:15	LINE CLEAR AVAILED
402	24-Apr-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	9:45	9:47	0:02	LINE CLEAR AVAILED
403	24-Apr-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	10:02	19:24	9:22	LINE CLEAR AVAILED
404	24-Apr-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:35	6:44	0:09	LINE FAULT
405	24-Apr-2020	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	10:51	19:21	8:29	LINE CLEAR AVAILED
406	24-Apr-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:54	13:46	0:52	LINE CLEAR AVAILED
407	24-Apr-2020	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	11:35	19:18	7:43	LINE CLEAR AVAILED
408	24-Apr-2020	TUMKUR	66	TR-1	BELADARA_66	9:45	9:47	0:02	LINE CLEAR AVAILED
409	24-Apr-2020	TUMKUR	66	TR-1	BELADARA_66	10:02	14:20	4:18	LINE CLEAR AVAILED
410	24-Apr-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	11:35	19:18	7:43	LINE CLEAR AVAILED
411	24-Apr-2020	TUMKUR	66	TR-2	BELADARA_66	9:45	9:47	0:02	LINE CLEAR AVAILED
412	24-Apr-2020	TUMKUR	66	TR-2	BEVINAHALLI_66	12:40	13:18	0:38	TRANSFORMER FAULT
413	24-Apr-2020	TUMKUR	66	TR-2	KUNIGAL_66	10:37	12:18	1:40	LINE CLEAR AVAILED
414	24-Apr-2020	TUMKUR	110	HONNAVALI 110- KADUR	HONNAVALI_110	14:58	16:43	1:44	LINE CLEAR AVAILED
415	24-Apr-2020	TUMKUR	110	HONNAVALI 110-ADAN SOLAR	ADAN SOLAR_IPP_66	17:55	17:56	0:01	HAND TRIPPED
416	24-Apr-2020	TUMKUR	110	HONNAVALI 110-DMKURKE	DMKURKE_110	14:58	16:43	1:44	LINE CLEAR AVAILED
417	24-Apr-2020	TUMKUR	220	NITTUR 220kv-HASSAN(ARASIKERE)	NITTUR_220	10:44	12:12	1:28	LINE CLEAR AVAILED
418	24-Apr-2020	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	10:08	18:47	8:38	LINE CLEAR AVAILED
419	24-Apr-2020	TUMKUR	220	TR-1	PAVAGADA_220	16:04	16:24	0:19	TRANSFORMER FAULT
420	24-Apr-2020	TUMKUR	220	TR-2	PAVAGADA_220	16:04	16:24	0:19	TRANSFORMER FAULT
421	25-Apr-2020	BAGALKOT	110	10/11KV,HV1	LAXMESHWAR_110	3:59	4:08	0:09	HAND TRIPPED
422	25-Apr-2020	BAGALKOT	110	10/11KV,HV1	LAXMESHWAR_110	19:52	20:00	0:08	HAND TRIPPED
423	25-Apr-2020	BAGALKOT	110	110/11KV,HV 1	AKSHAYA COLOY_110	12:07	12:53	0:46	LINE CLEAR AVAILED
424	25-Apr-2020	BAGALKOT	110	110/11KV,HV 1&2	BELGAUM_110	10:40	15:08	4:28	LINE CLEAR AVAILED
425	25-Apr-2020	BAGALKOT	110	110/11KV,HV 1&2	BELGAUM_110	10:40	15:09	4:29	LINE CLEAR AVAILED
426	25-Apr-2020	BAGALKOT	110	110/11KV,HV1	SANKESHWAR_110	10:53	11:08	0:15	LINE CLEAR AVAILED
427	25-Apr-2020	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	16:13	16:22	0:09	TRANSFORMER FAULT
428	25-Apr-2020	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	11:08	11:16	0:08	LINE CLEAR AVAILED
429	25-Apr-2020	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	1:51	1:55	0:04	TRANSFORMER FAULT
430	25-Apr-2020	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	22:49	22:51	0:02	TRANSFORMER FAULT
431	25-Apr-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110	14:06	14:10	0:04	TRANSFORMER FAULT
432	25-Apr-2020	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,HEBBAL_33, KANAGALA_33	10:41	11:08	0:27	LINE CLEAR AVAILED
433	25-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DUL AKED_33,NEVARGI_33	5:39	5:50	0:11	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
434	25-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DULAKED_33,NEVARGI_33	10:09	10:23	0:14	TRANSFORMER FAULT
435	25-Apr-2020	BAGALKOT	110	ATHANI220-THOUSHI	THASAVI_110	1:20	1:32	0:12	LINE FAULT
436	25-Apr-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	22:20	22:41	0:21	LINE FAULT
437	25-Apr-2020	BAGALKOT	110	BELGAUM SOLAR-MAMADAPUR	MAMADAPUR(B)_110	22:49	22:52	0:03	LINE FAULT
438	25-Apr-2020	BAGALKOT	110	BELGAUM220-BELGAUM110	BELGAUM_110	10:40	15:07	4:27	LINE CLEAR AVAILED
439	25-Apr-2020	BAGALKOT	110	BELGAUM220-BELGAUM110	BELGAUM_110	9:05	14:36	5:31	LINE CLEAR AVAILED
440	25-Apr-2020	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	3:58	4:15	0:17	HAND TRIPPED
441	25-Apr-2020	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	19:53	20:02	0:09	HAND TRIPPED
442	25-Apr-2020	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	4:00	4:15	0:15	HAND TRIPPED
443	25-Apr-2020	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	19:52	20:17	0:25	HAND TRIPPED
444	25-Apr-2020	BAGALKOT	110	GADAG-LAXMESHWAR 2	LAXMESHWAR_110,BELLATTI_110	0:00	19:46	19:46	LINE CLEAR AVAILED
445	25-Apr-2020	BAGALKOT	110	GADAG-SHIRAHATTI	SHIRAHATTI_110	0:00	3:34	3:34	LINE CLEAR AVAILED
446	25-Apr-2020	BAGALKOT	110	GADAG-SHIRAHATTI	SHIRAHATTI_110	12:32	19:43	7:11	LINE CLEAR AVAILED
447	25-Apr-2020	BAGALKOT	110	ILKAL-HUNGUND 1&2	HUNGUND_110	18:15	18:21	0:06	HAND TRIPPED
448	25-Apr-2020	BAGALKOT	110	ITNAL-HIDIKAL	ITNAL_110	10:04	17:35	7:31	LINE CLEAR AVAILED
449	25-Apr-2020	BAGALKOT	110	KANABARGI LAY OUT-BELGAUM110	KANABARGI LAYOUT_110	9:25	15:01	5:36	LINE CLEAR AVAILED
450	25-Apr-2020	BAGALKOT	110	LAXMESHWAR-GADAG 1	LAXMESHWAR_110	0:00	20:00	20:00	LINE CLEAR AVAILED
451	25-Apr-2020	BAGALKOT	110	MANTUR-SHIROL	SHIROL_110	7:44	23:59	16:15	LINE CLEAR AVAILED
452	25-Apr-2020	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	17:06	23:59	6:53	LINE CLEAR AVAILED
453	25-Apr-2020	BAGALKOT	220	GUTTUR-RANEBENNUR	RANEBENNUR_220	0:00	0:09	0:09	LINE CLEAR AVAILED
454	25-Apr-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEBENNUR	RANEBENNUR_220	0:00	17:06	17:06	LINE CLEAR AVAILED
455	25-Apr-2020	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	18:20	19:56	1:36	MAIN SUPPLY FAILURE
456	25-Apr-2020	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	10:54	11:00	0:06	LOAD CHANGE OVER
457	25-Apr-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:18	18:23	1:05	LINE FAULT
458	25-Apr-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	17:18	18:23	1:05	LINE FAULT
459	25-Apr-2020	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - BPH (EHT)	BPH (EHT)	18:19	20:01	1:42	MAIN SUPPLY FAILURE
460	25-Apr-2020	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - SHELL (EHT)	SHELL (EHT)	18:19	20:01	1:42	MAIN SUPPLY FAILURE
461	25-Apr-2020	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	21:29	21:34	0:05	LOAD CHANGE OVER
462	25-Apr-2020	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	8:14	9:07	0:53	LINE FAULT
463	25-Apr-2020	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	6:20	6:58	0:38	LINE FAULT
464	25-Apr-2020	BENGALURU	66	HOSKOTE 220 - BEGUR 220	HOSKOTE 220	18:19	20:12	1:53	MAIN SUPPLY FAILURE
465	25-Apr-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	18:19	20:12	1:53	MAIN SUPPLY FAILURE
466	25-Apr-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	18:19	20:12	1:53	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
467	25-Apr-2020	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	18:19	20:12	1:53	MAIN SUPPLY FAILURE
468	25-Apr-2020	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	18:19	20:12	1:53	MAIN SUPPLY FAILURE
469	25-Apr-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	18:19	20:12	1:53	MAIN SUPPLY FAILURE
470	25-Apr-2020	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:00	6:15	0:14	LINE FAULT
471	25-Apr-2020	BENGALURU	66	HV1	D CROSS	17:51	18:12	0:20	TRANSFORMER FAULT
472	25-Apr-2020	BENGALURU	66	HV1	HAROBEL	20:21	20:35	0:13	TRANSFORMER FAULT
473	25-Apr-2020	BENGALURU	66	HV1	KHODAYS 220	10:34	10:42	0:08	LOAD CHANGE OVER
474	25-Apr-2020	BENGALURU	66	HV2	THAYALUR	14:47	14:52	0:05	TRANSFORMER FAULT
475	25-Apr-2020	BENGALURU	66	HV2	SM MANGALA	11:12	11:21	0:09	LINE CLEAR AVOIDED
476	25-Apr-2020	BENGALURU	66	HV2	SM MANGALA	13:43	13:49	0:05	LINE CLEAR AVOIDED
477	25-Apr-2020	BENGALURU	66	HV2	DODDABELAVANGALA	16:39	16:52	0:13	TRANSFORMER FAULT
478	25-Apr-2020	BENGALURU	66	HV2	KADUBISANAHALLI	19:15	19:32	0:17	TRANSFORMER FAULT
479	25-Apr-2020	BENGALURU	66	HV2	KHODAYS 220	10:34	10:42	0:08	LOAD CHANGE OVER
480	25-Apr-2020	BENGALURU	66	HV2	KENGERI SATELLITE TOWN	11:25	11:41	0:16	TRANSFORMER FAULT
481	25-Apr-2020	BENGALURU	66	KACHMARANAHALLI - SHAMRAJ TEC PARK	KACHMARANAHALLI	17:17	18:05	0:48	LINE CLEAR AVOIDED
482	25-Apr-2020	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	10:34	10:42	0:08	LOAD CHANGE OVER
483	25-Apr-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:57	17:06	2:08	LINE FAULT
484	25-Apr-2020	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	22:12	23:04	0:52	LINE FAULT
485	25-Apr-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	22:12	22:28	0:16	LINE FAULT
486	25-Apr-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	10:56	11:05	0:09	LOAD CHANGE OVER
487	25-Apr-2020	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	13:40	13:45	0:05	LOAD CHANGE OVER
488	25-Apr-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:09	11:19	0:10	LOAD CHANGE OVER
489	25-Apr-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	13:04	13:09	0:05	LOAD CHANGE OVER
490	25-Apr-2020	BENGALURU	220	BEGUR 220 - DB PURA 220		18:19	19:20	1:01	LINE FAULT
491	25-Apr-2020	BENGALURU	220	BEGUR 220 - HOODY 220	DEVANAHALLI HARDWARE PARK 220, HOSKOTE 220, BEGUR 220	18:19	19:20	1:01	LINE FAULT
492	25-Apr-2020	BENGALURU	220	BEGUR 220 - HOSKOTE 220	DEVANAHALLI HARDWARE PARK 220, HOSKOTE 220	18:19	20:01	1:42	MAIN SUPPLY FAILURE
493	25-Apr-2020	BENGALURU	220	HV1	DEVANAHALLI HARDWARE PARK 220	18:19	20:01	1:42	MAIN SUPPLY FAILURE
494	25-Apr-2020	BENGALURU	220	HV2	DEVANAHALLI HARDWARE PARK 220	18:19	20:01	1:42	MAIN SUPPLY FAILURE
495	25-Apr-2020	GULBARGA	66	HV1	ITTAGI_220	13:52	13:58	0:06	TRANSFORMER FAULT
496	25-Apr-2020	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	6:20	6:50	0:30	TRANSFORMER FAULT
497	25-Apr-2020	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	12:00	13:45	1:45	LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
498	25-Apr-2020	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, GIRIYAPURA_66, SOVENAHALLI_66,MAGALA_66,T BDAM	5:15	5:20	0:05	LINE FAULT
499	25-Apr-2020	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66,HOLAGU NDI_66	18:45	19:00	0:15	LINE FAULT
500	25-Apr-2020	GULBARGA	66	ITTAGI- SUZLON1_IPP,SUZLON2_IPP	ITTAGI_220	10:35	17:35	7:00	LINE CLEAR AVAILED
501	25-Apr-2020	GULBARGA	66	TAMBRAHALLI-ITTAGI	TAMBRAHALLI_66	0:00	2:50	2:50	LINE CLEAR AVAILED
502	25-Apr-2020	GULBARGA	110	HV1	YELBURGA_110	1:12	1:23	0:11	TRANSFORMER FAULT
503	25-Apr-2020	GULBARGA	110	HV1,HV2	YELBURGA_110	11:20	11:33	0:13	LINE CLEAR AVAILED
504	25-Apr-2020	GULBARGA	110	HV2	DEODURGA_110	9:30	9:40	0:10	TRANSFORMER FAULT
505	25-Apr-2020	GULBARGA	110	HV2	DEODURGA_110	9:55	10:10	0:15	TRANSFORMER FAULT
506	25-Apr-2020	GULBARGA	400	JSWVL-BTPS1	BTPS_400	9:47	20:05	10:18	NFBC ISSUED
507	25-Apr-2020	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	9:59	19:25	9:26	NFBC ISSUED
508	25-Apr-2020	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15			LINE OPEN DUE TO LINE FAULT.
509	25-Apr-2020	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15			LINE OPEN DUE TO LINE FAULT.
510	25-Apr-2020	HASSAN	66	HV1	SINGAPURA_66	14:05	18:01	3:56	MAIN SUPPLY FAILURE
511	25-Apr-2020	HASSAN	66	HV2	MATTHAVILE_66	13:35	14:24	0:49	MAIN SUPPLY FAILURE
512	25-Apr-2020	HASSAN	66	HV2	SINGAPURA_66	14:05	18:01	3:56	MAIN SUPPLY FAILURE
513	25-Apr-2020	HASSAN	66	MATTHAV-DIDGTHL	MATTHAVILE_66	13:35	14:08	0:33	MAIN SUPPLY FAILURE
514	25-Apr-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	10:00	16:37	6:37	LINE CLEAR AVAILED
515	25-Apr-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	10:00	16:37	6:37	LINE CLEAR AVAILED
516	25-Apr-2020	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	14:05	18:01	3:56	MAIN SUPPLY FAILURE
517	25-Apr-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	16:06	22:32	6:26	LINE CLEAR AVAILED
518	25-Apr-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	0:00	10:37	10:37	NFBC ISSUED
519	25-Apr-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	0:00	10:37	10:37	LINE CLEAR AVAILED
520	25-Apr-2020	MYSURU	66	HV1	BANNUR_66	11:21	11:23	0:02	HAND TRIPPED
521	25-Apr-2020	MYSURU	66	HV1	SHIVALLY_66	10:24	10:51	0:26	LINE CLEAR AVAILED
522	25-Apr-2020	MYSURU	66	HV2	HDKOTE_66	15:57	16:25	0:27	LINE CLEAR AVAILED
523	25-Apr-2020	MYSURU	66	HV2	THALAKADU_66	10:45	11:59	1:13	LINE CLEAR AVAILED
524	25-Apr-2020	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	7:14	14:51	7:36	LINE CLEAR AVAILED
525	25-Apr-2020	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITUR_66 RAVANDUR_66	11:29	11:40	0:10	LINE FAULT
526	25-Apr-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	18:10	18:13	0:02	HAND TRIPPED
527	25-Apr-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	13:06	13:16	0:09	LINE FAULT
528	25-Apr-2020	TUMKUR	66	TR-1	BELADARA_66	18:10	18:13	0:02	HAND TRIPPED
529	25-Apr-2020	TUMKUR	66	TR-1	RAMPURA_66	18:02	18:04	0:01	TRANSFORMER FAULT
530	25-Apr-2020	TUMKUR	66	TR-2	BELADARA_66	18:10	18:13	0:02	HAND TRIPPED
531	25-Apr-2020	TUMKUR	110	TR-1	HANDANKERE_110	13:39	14:08	0:28	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
532	25-Apr-2020	TUMKUR	110	TR-1	SAMPIGE_110	14:59	15:32	0:32	LINE CLEAR AVAILED
533	25-Apr-2020	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	10:18	16:22	6:03	LINE CLEAR AVAILED
534	26-Apr-2020	BAGALKOT	110	110/11KV,HV1	KANABARGI LAYOUT_110	11:21	11:46	0:25	HAND TRIPPED
535	26-Apr-2020	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	11:08	11:19	0:11	TRANSFORMER FAULT
536	26-Apr-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	9:45	9:47	0:02	TRANSFORMER FAULT
537	26-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DULAKED_33,NEVARGI_33	11:11	11:17	0:06	TRANSFORMER FAULT
538	26-Apr-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DULAKED_33,NEVARGI_33	13:15	13:26	0:11	TRANSFORMER FAULT
539	26-Apr-2020	BAGALKOT	110	HUBLI220-TADASINAKOPPA	TADASINAKOPPA_110	20:30	23:59	3:29	LINE FAULT
540	26-Apr-2020	BAGALKOT	110	ITNAL-RABAG 2	RAIBAG_110	2:57	6:34	3:37	LINE FAULT
541	26-Apr-2020	BAGALKOT	110	JOG1(SIDDAPUR)-SIRSI	SIRSI_110	3:05	3:25	0:20	HAND TRIPPED
542	26-Apr-2020	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	3:05	23:59	20:54	LINE CLEAR AVAILED
543	26-Apr-2020	BAGALKOT	110	MAHALINGAPUR-DAVALESHWAR	DAVALESHWAR_110	6:05	6:12	0:07	LINE FAULT
544	26-Apr-2020	BAGALKOT	220	BIDNAL-(TADAS)HIREBENDIGERI 1&2	BIDNAL_220	8:53	15:27	6:34	NFBC ISSUED
545	26-Apr-2020	BAGALKOT	220	HARTI1-GADAG	GADAG_220	0:00	11:10	11:10	LINE CLEAR AVAILED
546	26-Apr-2020	BAGALKOT	220	HARTI1-GADAG	GADAG_220	11:10	23:59	12:49	LINE CLEAR AVAILED
547	26-Apr-2020	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	0:00	11:31	11:31	LINE CLEAR AVAILED
548	26-Apr-2020	BAGALKOT	220	SIRSI-HUBLI 2	SIRSI_220	0:00	11:31	11:31	LINE CLEAR AVAILED
549	26-Apr-2020	BAGALKOT	220	SIRSI-HUBLI1&2	SIRSI_220	13:06	23:59	10:53	LINE CLEAR AVAILED
550	26-Apr-2020	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	12:50	13:35	0:45	LOAD CHANGE OVER
551	26-Apr-2020	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	6:53	7:03	0:10	LOAD CHANGE OVER
552	26-Apr-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	18:25	18:30	0:05	LINE FAULT
553	26-Apr-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:51	11:56	0:04	LOAD CHANGE OVER
554	26-Apr-2020	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	11:51	12:10	0:19	LINE CLEAR AVAILED
555	26-Apr-2020	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	5:46	5:55	0:09	LOAD CHANGE OVER
556	26-Apr-2020	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	13:00	13:10	0:10	LOAD CHANGE OVER
557	26-Apr-2020	BENGALURU	66	HV1	BRINDAVANA	10:17	10:29	0:12	LOAD CHANGE OVER
558	26-Apr-2020	BENGALURU	66	HV1	D CROSS	10:19	10:37	0:18	LINE CLEAR AVAILED
559	26-Apr-2020	BENGALURU	66	HV2	NANDINI LAYOUT	6:27	6:29	0:02	LINE CLEAR AVAILED
560	26-Apr-2020	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:15	10:25	0:10	LOAD CHANGE OVER
561	26-Apr-2020	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	12:44	12:52	0:08	LOAD CHANGE OVER
562	26-Apr-2020	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	6:27	6:32	0:05	LOAD CHANGE OVER
563	26-Apr-2020	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	5:35	5:40	0:05	LOAD CHANGE OVER
564	26-Apr-2020	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	13:23	13:28	0:05	LOAD CHANGE OVER
565	26-Apr-2020	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	12:45	12:50	0:05	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
566	26-Apr-2020	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	6:20	6:25	0:05	LOAD CHANGE OVER
567	26-Apr-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	6:50	6:51	0:01	LOAD CHANGE OVER
568	26-Apr-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	12:54	12:56	0:01	LOAD CHANGE OVER
569	26-Apr-2020	BENGALURU	66	PLATINUM CITY - DG 3	PLATINUM CITY	12:50	12:55	0:05	LOAD CHANGE OVER
570	26-Apr-2020	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	6:35	6:40	0:05	LOAD CHANGE OVER
571	26-Apr-2020	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	5:24	5:27	0:03	LOAD CHANGE OVER
572	26-Apr-2020	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	13:08	13:17	0:09	LOAD CHANGE OVER
573	26-Apr-2020	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	12:10	12:26	0:16	LINE FAULT
574	26-Apr-2020	BENGALURU	66	TEKAL - MALUR	TEKAL, BUDIKOTE	6:17	9:06	2:48	LINE CLEAR AVAILED
575	26-Apr-2020	BENGALURU	66	VIJAYAPURA - D B PURA 220	VIJAYAPURA, JANGAMKOTE	9:20	9:30	0:10	LOAD CHANGE OVER
576	26-Apr-2020	BENGALURU	66	VIJAYAPURA - MELUR	VIJAYAPURA, JANGAMKOTE	16:35	16:45	0:10	LOAD CHANGE OVER
577	26-Apr-2020	GULBARGA	66	HV1	KOTTUR_66	21:40	21:45	0:05	TRANSFORMER FAULT
578	26-Apr-2020	GULBARGA	66	ITTAGI-KUDLIGI2	CJHALLI_66, GUDEKOTE_66,BANAVEKAL_66, CHORNOOR_66,HOSAHALLI_66	20:30	21:45	1:15	LINE FAULT
579	26-Apr-2020	GULBARGA	66	ITTAGI-SUZLON1_IPP,SUZLON2_IPP	ITTAGI_220	10:20	17:25	7:05	LINE CLEAR AVAILED
580	26-Apr-2020	GULBARGA	110	HALBURGA-BHALKI	BHALKI_110	19:01	21:05	2:04	LINE FAULT
581	26-Apr-2020	GULBARGA	110	HV1	HALBURGA_220	16:52	20:15	3:23	TRANSFORMER FAULT
582	26-Apr-2020	GULBARGA	110	HV2	YEDRAMI_110	10:40	12:00	1:20	TRANSFORMER FAULT
583	26-Apr-2020	GULBARGA	110	HV3	SHORAPUR_110	18:08	18:18	0:10	TRANSFORMER FAULT
584	26-Apr-2020	GULBARGA	110	HV3	SHORAPUR_110	18:20	18:30	0:10	TRANSFORMER FAULT
585	26-Apr-2020	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	5:08	5:18	0:10	LINE FAULT
586	26-Apr-2020	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15			LINE OPEN DUE TO LINE FAULT.
587	26-Apr-2020	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15			LINE OPEN DUE TO LINE FAULT.
588	26-Apr-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	2:01	2:06	0:05	LINE FAULT
589	26-Apr-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:00	10:09	0:09	LINE FAULT
590	26-Apr-2020	HASSAN	66	HV1	SHANTHIGRAMMA_66	21:50	21:55	0:05	TRANSFORMER FAULT
591	26-Apr-2020	HASSAN	66	HV2	BAGUR_66	19:06	19:07	0:01	HAND TRIPPED
592	26-Apr-2020	HASSAN	66	HV2	SHANTHIGRAMMA_66	21:50	22:00	0:10	TRANSFORMER FAULT
593	26-Apr-2020	HASSAN	66	KIADBH-RAMESWARNAGAR	KIADB_66	16:37	19:29	2:52	LINE FAULT
594	26-Apr-2020	HASSAN	66	KIADBH-RAMESWARNAGAR	KIADB_66	20:00	20:50	0:50	LINE CLEAR AVAILED
595	26-Apr-2020	HASSAN	66	MALALI-HASSAN	MALALI_66	17:15	19:50	2:35	MAIN SUPPLY FAILURE
596	26-Apr-2020	HASSAN	66	MOSALH-HNPRA	MOSALEHOSAHALLI_66	18:41	21:26	2:45	NFBC ISSUED
597	26-Apr-2020	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	16:35	19:30	2:55	MAIN SUPPLY FAILURE
598	26-Apr-2020	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	19:55	20:50	0:55	MAIN SUPPLY FAILURE
599	26-Apr-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:01	17:24	8:23	LINE CLEAR AVAILED
600	26-Apr-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:01	17:24	8:23	LINE CLEAR AVAILED
601	26-Apr-2020	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	19:05	23:20	4:15	NFBC ISSUED
602	26-Apr-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:54	16:32	0:38	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
603	26-Apr-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:54	16:36	0:42	MAIN SUPPLY FAILURE
604	26-Apr-2020	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	16:10	16:41	0:31	MAIN SUPPLY FAILURE
605	26-Apr-2020	HASSAN	110	HV	PUTTUR_220	18:11	20:53	2:42	TRANSFORMER FAULT
606	26-Apr-2020	HASSAN	110	HV2	NAVUNDA_110	6:12	6:34	0:22	TRANSFORMER FAULT
607	26-Apr-2020	HASSAN	110	HV4	BAIKAMPADI_110	11:01	12:07	1:06	LINE CLEAR AVAILED
608	26-Apr-2020	HASSAN	110	JOG-NK1	mghejog_gen	7:57	12:22	4:25	LINE CLEAR AVAILED
609	26-Apr-2020	HASSAN	110	JOG-NK2	mghejog_gen	7:57	12:26	4:29	LINE CLEAR AVAILED
610	26-Apr-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:54	16:33	0:39	LINE FAULT
611	26-Apr-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:54	16:35	0:41	LINE FAULT
612	26-Apr-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	18:58	19:30	0:32	MAIN SUPPLY FAILURE
613	26-Apr-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	19:37	20:25	0:48	HAND TRIPPED
614	26-Apr-2020	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	17:35	18:06	0:31	LINE FAULT
615	26-Apr-2020	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	18:58	19:21	0:23	LINE FAULT
616	26-Apr-2020	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	19:35	23:59	4:24	LINE CLEAR AVAILED
617	26-Apr-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	16:37	17:45	1:08	NFBC ISSUED
618	26-Apr-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	9:05	19:14	10:09	NFBC ISSUED
619	26-Apr-2020	HASSAN	220	VARAHI-KEMAR2	varahi_gen	9:05	19:16	10:11	LINE CLEAR AVAILED
620	26-Apr-2020	MYSURU	66	HV1	DUNDANAHALLI_66	12:12	12:47	0:35	LINE CLEAR AVAILED
621	26-Apr-2020	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	19:07	19:12	0:04	LINE FAULT
622	26-Apr-2020	TUMKUR	66	BELADADARA-KORATAGERE	BELADARA_66	6:17	6:46	0:29	LINE FAULT
623	26-Apr-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:14	8:24	0:10	LINE FAULT
624	26-Apr-2020	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	6:44	6:57	0:13	LINE FAULT
625	26-Apr-2020	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	21:01	23:58	2:57	LINE FAULT
626	26-Apr-2020	TUMKUR	110	TR-2	TURUVEKERE_110	2:04	13:06	11:02	TRANSFORMER FAULT
627	27-Apr-2020	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	7:40	7:47	0:07	HAND TRIPPED
628	27-Apr-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	5:09	6:12	1:03	LINE FAULT
629	27-Apr-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR 2	MAMADAPUR_110	5:09	6:13	1:04	LINE FAULT
630	27-Apr-2020	BAGALKOT	110	110/33KV,HV1	CHIKKODI_110,KABBUR_33,VIJA YNAGAR_33	3:12	3:23	0:11	TRANSFORMER FAULT
631	27-Apr-2020	BAGALKOT	110	GAJENDRAGHAD-KUSTAGI	KUSTAGI_110	18:01	23:59	5:58	LINE CLEAR AVAILED
632	27-Apr-2020	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110,RUSTUMPUR LIS_33,BELAGAVI EATER SUPPLY STAGE 1_33,BELAGAVI WATER SUPPLY STAGE2&3_33	10:48	16:28	5:40	LINE CLEAR AVAILED
633	27-Apr-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	12:01	13:00	0:59	LINE CLEAR AVAILED
634	27-Apr-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	13:57	13:58	0:01	HAND TRIPPED
635	27-Apr-2020	BAGALKOT	110	ILKAL1&2-HUNGUND	HUNGUND_110	16:14	17:00	0:46	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
636	27-Apr-2020	BAGALKOT	110	BAGEWADI-HUNGUND	HUNGUND_110	16:14	17:00	0:46	LINE CLEAR AVAILED
637	27-Apr-2020	BAGALKOT	110	ITNAL-HIDIKAL	HIDIKAL_110	8:27	23:59	15:32	LINE CLEAR AVAILED
638	27-Apr-2020	BAGALKOT	110	MK HUBLI-KITTUR	KITTUR_110	8:53	9:06	0:13	LINE FAULT
639	27-Apr-2020	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	13:53	13:59	0:06	TRANSFORMER FAULT
640	27-Apr-2020	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	11:35	14:28	2:53	LINE CLEAR AVAILED
641	27-Apr-2020	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220,HIDIKAL_110,BABALESHWAR_110,ITNAL_110	13:55	16:10	2:15	TRANSFORMER FAULT
642	27-Apr-2020	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	13:56	16:27	2:31	LINE FAULT
643	27-Apr-2020	BAGALKOT	110	110/33KV,HV2	MAHALINGAPUR_220,HALLUR_33,MALALI_33	3:04	3:20	0:16	TRANSFORMER FAULT
644	27-Apr-2020	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	6:27	6:36	0:09	TRANSFORMER FAULT
645	27-Apr-2020	BENGALURU	66	HV1	DEVARABISANAHALLI	16:30	19:10	2:40	LINE CLEAR AVAILED
646	27-Apr-2020	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	10:07	10:18	0:11	LINE FAULT
647	27-Apr-2020	BENGALURU	66	HV1	HOODY 220	10:44	11:23	0:39	LINE CLEAR AVAILED
648	27-Apr-2020	BENGALURU	66	HV1	IISc	7:11	7:15	0:04	LINE CLEAR AVAILED
649	27-Apr-2020	BENGALURU	66	HV2	PADMANABHANAGAR	10:32	10:34	0:02	LINE CLEAR AVAILED
650	27-Apr-2020	BENGALURU	220	HV2	KHODAYS 220	14:45	14:52	0:07	LOAD CHANGE OVER
651	27-Apr-2020	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	14:45	14:52	0:07	LOAD CHANGE OVER
652	27-Apr-2020	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	14:45	14:52	0:07	LOAD CHANGE OVER
653	27-Apr-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	22:30	22:32	0:02	LINE CLEAR AVAILED
654	27-Apr-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	22:34	22:37	0:03	LINE CLEAR AVAILED
655	27-Apr-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	22:20	22:24	0:04	LINE CLEAR AVAILED
656	27-Apr-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	22:27	22:30	0:02	LINE CLEAR AVAILED
657	27-Apr-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	14:50	15:22	0:31	LINE FAULT
658	27-Apr-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	10:48	10:54	0:06	LINE FAULT
659	27-Apr-2020	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	18:02	18:10	0:08	LINE FAULT
660	27-Apr-2020	BENGALURU	66	HV1	ATTIBELE	11:10	13:11	2:01	LINE CLEAR AVAILED
661	27-Apr-2020	BENGALURU	66	HV1	KIADB DB PURA 220	15:23	16:58	1:34	LINE CLEAR AVAILED
662	27-Apr-2020	BENGALURU	66	HV2	KIADB DB PURA 220	13:06	15:15	2:08	LINE CLEAR AVAILED
663	27-Apr-2020	BENGALURU	66	HV1	D CROSS	10:28	10:37	0:08	LINE CLEAR AVAILED
664	27-Apr-2020	BENGALURU	66	HV2	DODALAHALLI	4:26	4:29	0:02	TRANSFORMER FAULT
665	27-Apr-2020	BENGALURU	66	HV1	KODIHALLI	13:56	13:59	0:03	LINE CLEAR AVAILED
666	27-Apr-2020	BENGALURU	66	HV1	KODIHALLI	14:45	14:49	0:03	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
667	27-Apr-2020	BENGALURU	66	HV2	KODIHALLI	13:56	14:00	0:03	LINE CLEAR AVAILED
668	27-Apr-2020	BENGALURU	66	HV2	KODIHALLI	14:46	14:49	0:03	LINE CLEAR AVAILED
669	27-Apr-2020	BENGALURU	66	HV1	KYALANUR	18:01	18:10	0:09	TRANSFORMER FAULT
670	27-Apr-2020	BENGALURU	66	HV1	WEL CAST STEEL	11:31	11:36	0:04	LINE CLEAR AVAILED
671	27-Apr-2020	BENGALURU	66	HV2	WEL CAST STEEL	13:41	14:21	0:40	LINE CLEAR AVAILED
672	27-Apr-2020	BENGALURU	66	MELEHALLI - JALAMANGALA	JALAMANGALA, KUTAGALLU, CHIKKAGANGANAVADI	10:47	12:16	1:29	LINE FAULT
673	27-Apr-2020	BENGALURU	66	MELEHALLI - JALAMANGALA	JALAMANGALA, KUTAGALLU, CHIKKAGANGANAVADI	15:45	16:52	1:07	LINE CLEAR AVAILED
674	27-Apr-2020	GULBARGA	400	JSWVL-BTPS	BTPS_400	7:48	10:17	2:29	LINE CLEAR AVAILED
675	27-Apr-2020	GULBARGA	220	BUS1, BUS2	KUSTAGI_220	16:10	17:52	1:42	LINE CLEAR AVAILED
676	27-Apr-2020	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	16:15	17:41	1:26	MAIN SUPPLY FAILURE
677	27-Apr-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110, MANVI_110	12:48	12:58	0:10	LINE FAULT
678	27-Apr-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110, MANVI_110	4:04	4:14	0:10	LINE FAULT
679	27-Apr-2020	GULBARGA	110	LADHA-BHALKI	LADHA_110	15:20	16:40	1:20	LINE CLEAR AVAILED
680	27-Apr-2020	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	17:15			LINE OPEN DUE TO LINE FAULT.
681	27-Apr-2020	GULBARGA	220	KAPNOOR-SHAHPUR	SHAHPUR_220	17:15			LINE OPEN DUE TO LINE FAULT.
682	27-Apr-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	5:29	23:59	18:30	LINE CLEAR AVAILED
683	27-Apr-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	17:10	20:31	3:21	NFBC ISSUED
684	27-Apr-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	7:37	7:44	0:07	HAND TRIPPED
685	27-Apr-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	18:23	21:07	2:44	LINE CLEAR AVAILED
686	27-Apr-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	21:34	23:59	2:25	LINE CLEAR AVAILED
687	27-Apr-2020	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	7:37	23:59	16:22	LINE CLEAR AVAILED
688	27-Apr-2020	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	15:20	16:15	0:55	LINE CLEAR AVAILED
689	27-Apr-2020	HASSAN	110	MRSSHM-MPM	MRSMSG_220	18:04	18:07	0:03	HAND TRIPPED
690	27-Apr-2020	HASSAN	110	HV2	BARANGI_110	12:23	15:20	2:57	LINE CLEAR AVAILED
691	27-Apr-2020	HASSAN	110	HV1	MANIPAL_110	10:06	10:58	0:52	LINE CLEAR AVAILED
692	27-Apr-2020	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	0:00	2:50	2:50	LINE CLEAR AVAILED
693	27-Apr-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	19:10	19:13	0:03	HAND TRIPPED
694	27-Apr-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	20:50	20:52	0:02	HAND TRIPPED
695	27-Apr-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	14:50	15:20	0:30	LINE CLEAR AVAILED
696	27-Apr-2020	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	14:45	15:15	0:30	MAIN SUPPLY FAILURE
697	27-Apr-2020	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	14:40	17:28	2:48	LINE CLEAR AVAILED
698	27-Apr-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	14:46	15:02	0:16	LINE FAULT
699	27-Apr-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:42	14:35	2:53	NFBC ISSUED
700	27-Apr-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:39	10:53	0:14	HAND TRIPPED
701	27-Apr-2020	HASSAN	66	HV1	MAGGE_66	11:55	15:17	3:22	MAIN SUPPLY FAILURE
702	27-Apr-2020	HASSAN	66	HV2	MAGGE_66	11:55	15:18	3:23	MAIN SUPPLY FAILURE
703	27-Apr-2020	HASSAN	66	HV1	MATTANAVILE_66	18:45	18:50	0:05	MAIN SUPPLY FAILURE
704	27-Apr-2020	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	11:47	14:36	2:49	NFBC ISSUED
705	27-Apr-2020	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	9:00	17:46	8:46	LINE CLEAR AVAILED
706	27-Apr-2020	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	9:00	17:53	8:53	LINE CLEAR AVAILED
707	27-Apr-2020	MYSURU	66	HV1	ANEGOLAL_66	12:03	12:50	0:47	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
708	27-Apr-2020	MYSURU	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66, HONNALLY_MYS_66	18:07	18:13	0:06	LINE FAULT
709	27-Apr-2020	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66, SUTTUR_66	15:35	15:47	0:11	LINE FAULT
710	27-Apr-2020	MYSURU	66	GUDDENAHALLI- JAKKANAHALLY	GUDDENAHALLI_66	16:30	16:51	0:21	LINE CLEAR AVAILED
711	27-Apr-2020	MYSURU	66	HV2	HAMPAPURA_66	21:05	21:09	0:03	TRANSFORMER FAULT
712	27-Apr-2020	MYSURU	66	HV2	HDKOTE_66	11:00	12:45	1:44	LINE CLEAR AVAILED
713	27-Apr-2020	MYSURU	66	HV1	JAKKANAHALLY_66	21:10	21:25	0:15	TRANSFORMER FAULT
714	27-Apr-2020	MYSURU	66	KADAKOLA-SARAGUR 2	DOORA_66, HULLAHALLI_66, HURA_66,	12:15	12:21	0:06	LINE FAULT
715	27-Apr-2020	MYSURU	66	HV2	KIRUGAVALU_66	12:12	14:32	2:20	LINE CLEAR AVAILED
716	27-Apr-2020	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	2:05	2:09	0:04	LINE FAULT
717	27-Apr-2020	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	2:11	2:17	0:05	LINE FAULT
718	27-Apr-2020	TUMKUR	220	TR-1(HV SIDE)	ANCHEPALYA_220	11:14	12:01	0:46	LINE CLEAR AVAILED
719	27-Apr-2020	TUMKUR	220	TR-2(HV SIDE)	ANCHEPALYA_220	12:03	12:57	0:53	LINE CLEAR AVAILED
720	27-Apr-2020	TUMKUR	220	HIRIYUR220-MADHUGIRI	HIRIYUR_220	14:01	14:46	0:45	LINE FAULT
721	27-Apr-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	7:12	7:28	0:15	TRANSFORMER FAULT
722	27-Apr-2020	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	11:14	12:02	0:47	LINE CLEAR AVAILED
723	27-Apr-2020	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	12:03	12:58	0:54	LINE CLEAR AVAILED
724	27-Apr-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	23:01	23:12	0:10	LINE FAULT
725	27-Apr-2020	TUMKUR	66	TR-2	BAGUR_TMK_66	18:18	18:40	0:21	HAND TRIPPED
726	27-Apr-2020	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	19:01	19:17	0:16	LINE FAULT
727	27-Apr-2020	TUMKUR	66	TR-1	GOWRASAMUDRA_66	15:58	16:47	0:48	TRANSFORMER FAULT
728	27-Apr-2020	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	11:58	12:08	0:09	HAND TRIPPED
729	27-Apr-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:31	10:43	0:11	LINE FAULT
730	27-Apr-2020	TUMKUR	66	TR-1	KUNIGAL_66	15:16	15:23	0:06	LINE CLEAR AVAILED
731	27-Apr-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	8:50	9:01	0:11	LINE FAULT
732	27-Apr-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	8:34	8:55	0:21	TRANSFORMER FAULT
733	27-Apr-2020	TUMKUR	66	PANDARAHALLI- SPML_WIND _IPP_66	SPML_WIND_IPP_66	8:36	8:50	0:13	LINE FAULT
734	27-Apr-2020	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	9:05	9:07	0:02	LINE FAULT