

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 09.04.2019 to 15.04.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	9-Apr-19	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	15:26	15:51	0:25	LINE CLEAR AVAILED
2	9-Apr-19	BAGALKOT	110	110/33KV,HV2	GULEDAGUDDA_110,KAMATAGI_33	14:18	14:41	0:23	HAND TRIPPED
3	9-Apr-19	BAGALKOT	110	110/33KV,HV2	GULEDAGUDDA_110,KAMATAGI_33	16:01	16:32	0:31	HAND TRIPPED
4	9-Apr-19	BAGALKOT	220	HAVERI-GUTTUR 1	HAVERI_220	10:48	13:09	2:21	LINE CLEAR AVAILED
5	9-Apr-19	BAGALKOT	220	HAVERI-GUTTUR 2	HAVERI_220	13:10	13:47	0:37	LINE CLEAR AVAILED
6	9-Apr-19	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	14:40	15:21	0:41	LINE CLEAR AVAILED
7	9-Apr-19	BAGALKOT	220	220/110KV,HV2&LV2	HAVERI_220	16:42	17:21	0:39	LINE CLEAR AVAILED
8	9-Apr-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	16:03	17:24	1:21	LINE CLEAR AVAILED
9	9-Apr-19	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	16:08	17:29	1:21	LINE CLEAR AVAILED
10	9-Apr-19	BAGALKOT	110	RAIBAG-ITNAL	ITNAL_110	15:23	15:37	0:14	HAND TRIPPED
11	9-Apr-19	BAGALKOT	110	ITNAL-HIDIKAL	HIDIKAL_110	16:30	17:33	1:03	LINE FAULT
12	9-Apr-19	BAGALKOT	110	RAIBAG-ITNAL	ITNAL_110	17:34	17:40	0:06	LINE FAULT
13	9-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_33KV	13:35	13:43	0:08	TRANSFORMER FAULT
14	9-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_33KV	22:05	22:10	0:05	TRANSFORMER FAULT
15	9-Apr-19	BAGALKOT	220	VAJRAMATTI-KAVATAGI LIS	VAJRAMATTI_220	9:53	17:48	7:55	LINE CLEAR AVAILED
16	9-Apr-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGHATAGI_110	0:50	1:23	0:33	LINE FAULT
17	9-Apr-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	6:43	13:35	6:52	LINE FAULT
18	9-Apr-19	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	1:47	1:58	0:11	TRANSFORMER FAULT
19	9-Apr-19	BAGALKOT	110	110/11KV,HV1	MUDDEBIHAL_110	13:48	14:42	0:54	TRANSFORMER FAULT
20	9-Apr-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220,HIDIKAK_110,ITNAL_110	13:19	17:17	3:58	LINE CLEAR AVAILED
21	9-Apr-19	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	13:18	17:37	4:19	LINE CLEAR AVAILED
22	9-Apr-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	0:00	13:13	13:13	LINE CLEAR AVAILED
23	9-Apr-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	13:34	23:59	10:25	LINE CLEAR AVAILED
24	9-Apr-19	BAGALKOT	110	110/33KV,HV2	KIRUVATTI_110,YELLAPUR_33KV	12:02	12:56	0:54	LINE CLEAR AVAILED
25	9-Apr-19	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	11:21	12:02	0:41	LINE CLEAR AVAILED
26	9-Apr-19	BENGALURU	66	VR DODDI - TK HALLI 220	VR DODDI	17:02	17:05	0:03	LOAD CHANGEOVER
27	9-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	1:27	1:38	0:11	LINE FAULT
28	9-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	1:38	1:49	0:10	LINE FAULT
29	9-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	2:12	2:21	0:09	LINE FAULT
30	9-Apr-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	13:43	14:21	0:37	LINE CLEAR AVAILED
31	9-Apr-19	BENGALURU	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB 4 (EHT)	15:19	15:53	0:34	LINE FAULT
32	9-Apr-19	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL (EHT)	1:08	7:51	6:43	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
33	9-Apr-19	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	1:08	1:35	0:27	MAIN SUPPLY FAILURE
34	9-Apr-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	18:47	18:50	0:03	LOAD CHANGEOVER
35	9-Apr-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE	14:54	15:55	1:01	MAIN SUPPLY FAILURE
36	9-Apr-19	BENGALURU	66	NIMHANS 220 - BMTC	BMTC	14:54	15:50	0:55	MAIN SUPPLY FAILURE
37	9-Apr-19	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	14:54	15:52	0:58	MAIN SUPPLY FAILURE
38	9-Apr-19	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	14:54	15:18	0:23	MAIN SUPPLY FAILURE
39	9-Apr-19	BENGALURU	66	HV2	NIMHANS 220	11:24	11:26	0:01	LINE CLEAR AVAILED
40	9-Apr-19	BENGALURU	220	HV1	NIMHANS 220	14:54	15:58	1:04	MAIN SUPPLY FAILURE
41	9-Apr-19	BENGALURU	220	HV2	NIMHANS 220	14:54	15:51	0:56	MAIN SUPPLY FAILURE
42	9-Apr-19	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	13:35	13:59	0:23	LOAD CHANGEOVER
43	9-Apr-19	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	13:39	13:57	0:18	LOAD CHANGEOVER
44	9-Apr-19	BENGALURU	66	HV1	BTM 4TH PHASE	13:35	13:57	0:22	MAIN SUPPLY FAILURE
45	9-Apr-19	BENGALURU	66	HV2	BTM 4TH PHASE	13:35	13:57	0:22	MAIN SUPPLY FAILURE
46	9-Apr-19	BENGALURU	66	HV1	KHODAYS 220	13:36	13:58	0:22	LOAD CHANGEOVER
47	9-Apr-19	BENGALURU	66	HV2	KHODAYS 220	13:36	13:58	0:22	LOAD CHANGEOVER
48	9-Apr-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, HUNSENAHALLI, KODIHALLI, BIJJAALLI, HUKUNDA	14:59	15:14	0:15	LINE FAULT
49	9-Apr-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, HUNSENAHALLI, KODIHALLI, BIJJAALLI, HUKUNDA	15:14	15:49	0:34	LINE FAULT
50	9-Apr-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, HUNSENAHALLI, KODIHALLI, BIJJAALLI, HUKUNDA	15:49	19:26	3:37	LINE FAULT
51	9-Apr-19	BENGALURU	66	HSR LAYOUT 220 - KORMANGALA	KORMANGALA	14:54	15:42	0:48	MAIN SUPPLY FAILURE
52	9-Apr-19	BENGALURU	66	HV1	BOODIGERE	21:23	21:43	0:20	TRANSFORMER FAULT
53	9-Apr-19	BENGALURU	66	HV1	BOODIGERE	22:48	23:03	0:14	TRANSFORMER FAULT
54	9-Apr-19	BENGALURU	66	HSR LAYOUT 220 - ADUGODI	ADUGODI, BOSCH (EHT), K & C VALLEY, NAL (EHT)	14:54	15:45	0:50	LINE FAULT
55	9-Apr-19	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	14:54	15:42	0:48	LINE FAULT
56	9-Apr-19	BENGALURU	220	HOODY 400 - ITPL (EHT)	ITPL (EHT), EPIP 220	14:54	15:31	0:36	LINE FAULT
57	9-Apr-19	BENGALURU	220	HV1	EPIP 220	14:54	15:32	0:38	MAIN SUPPLY FAILURE
58	9-Apr-19	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI	0:00	0:04	0:04	LINE FAULT
59	9-Apr-19	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI	0:04	1:03	0:59	LINE FAULT
60	9-Apr-19	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	0:00	0:05	0:05	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
61	9-Apr-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	0:00	0:05	0:05	MAIN SUPPLY FAILURE
62	9-Apr-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	0:00	0:05	0:05	MAIN SUPPLY FAILURE
63	9-Apr-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	0:00	0:05	0:05	MAIN SUPPLY FAILURE
64	9-Apr-19	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI	0:00	0:05	0:05	MAIN SUPPLY FAILURE
65	9-Apr-19	BENGALURU	66	HV1	AKKURMOLE	8:12	8:24	0:12	TRANSFORMER FAULT
66	9-Apr-19	BENGALURU	66	HV2	AKKURMOLE	8:11	8:23	0:11	TRANSFORMER FAULT
67	9-Apr-19	BENGALURU	66	AKKURMOLE - TK HALLI 220	AKKURMOLE	8:17	8:23	0:06	LINE CLEAR AVAILED
68	9-Apr-19	BENGALURU	66	HV2	AKKURMOLE	22:38	22:52	0:14	TRANSFORMER FAULT
69	9-Apr-19	BENGALURU	66	HV2	CHANNAPATNA	11:04	11:25	0:21	LINE CLEAR AVAILED
70	9-Apr-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	0:00	0:18	0:18	MAIN SUPPLY FAILURE
71	9-Apr-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	12:04	14:11	2:06	LINE CLEAR AVAILED
72	9-Apr-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	5:55	6:15	0:20	LINE FAULT
73	9-Apr-19	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	0:25	0:38	0:12	LINE FAULT
74	9-Apr-19	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	0:38	1:07	0:28	LINE FAULT
75	9-Apr-19	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	16:48	17:05	0:17	LINE FAULT
76	9-Apr-19	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	16:48	17:20	0:32	LINE FAULT
77	9-Apr-19	BENGALURU	400	KEMBODI - KOLAR 220	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	19:01	19:18	0:17	LINE CLEAR AVAILED
78	9-Apr-19	BENGALURU	66	HV2	THIMMAMPALLI	12:02	19:16	7:14	TRANSFORMER FAULT
79	9-Apr-19	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	6:10	6:27	0:17	LINE FAULT
80	9-Apr-19	GULBARGA	110	GURGUNTA-LINGASUGUR	GURGUNTA_110,KHEL_IPP	2:09	2:20	0:11	LINE FAULT
81	9-Apr-19	GULBARGA	110	GURGUNTA-KHEL_IPP	KHEL_IPP	2:09	2:23	0:14	LINE FAULT
82	9-Apr-19	GULBARGA	110	BHALKI-HALBARGA	BHALKI_110,LADHA_110	12:45	13:25	0:40	LINE CLEAR AVAILED
83	9-Apr-19	GULBARGA	110	KUDITINI-IDLE	TORANGALLU_110	9:53	18:57	9:04	LINE CLEAR AVAILED
84	9-Apr-19	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,MADALAPURA_110	7:48	12:13	4:25	LINE CLEAR AVAILED
85	9-Apr-19	GULBARGA	110	RAICHUR-SINDHANOOR1	ALKOD_110,SIRWAR_110,VALKAMDINNI_110	8:15	11:19	3:04	LINE CLEAR AVAILED
86	9-Apr-19	GULBARGA	110	HV1	YELBURGA_110	11:40	11:44	0:04	LINE CLEAR AVAILED
87	9-Apr-19	GULBARGA	110	HV4	YELBURGA_110	14:16	15:35	1:19	LINE CLEAR AVAILED
88	9-Apr-19	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	7:23	7:36	0:13	LINE CLEAR AVAILED
89	9-Apr-19	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	15:58	16:03	0:05	TRANSFORMER FAULT
90	9-Apr-19	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	9:16	10:29	1:13	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
91	9-Apr-19	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	10:20	10:26	0:06	LINE FAULT
92	9-Apr-19	HASSAN	220	GOPALP-BASTIPURA	GOPALPURA_220	0:00	0:07	0:07	LINE FAULT
93	9-Apr-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	13:45	14:34	0:49	LINE CLEAR AVAILED
94	9-Apr-19	HASSAN	110	HV4	MANIPAL-110	12:06	14:01	1:55	LINE CLEAR AVAILED
95	9-Apr-19	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	19:50	23:42	3:52	LINE FAULT
96	9-Apr-19	HASSAN	110	HV1	MSEZ_220	10:05	16:08	6:03	LINE CLEAR AVAILED
97	9-Apr-19	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	17:27	17:33	0:06	LINE FAULT
98	9-Apr-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	19:48	20:34	0:46	LINE FAULT
99	9-Apr-19	HASSAN	66	HASSN22-BELUR	HASSAN_220	22:24	23:59	1:35	LINE FAULT
100	9-Apr-19	HASSAN	66	HV1	CHIKMAGALUR_66	10:04	12:00	1:56	MAIN SUPPLY FAILURE
101	9-Apr-19	HASSAN	66	HV2	CHIKMAGALUR_66	10:04	12:00	1:56	MAIN SUPPLY FAILURE
102	9-Apr-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLI_66	14:08	14:27	0:19	LINE CLEAR AVAILED
103	9-Apr-19	HASSAN	66	HV1	GENDEHALLI_66	14:18	14:27	0:09	LINE CLEAR AVAILED
104	9-Apr-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLI_66	14:12	14:28	0:16	LINE CLEAR AVAILED
105	9-Apr-19	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	11:50	12:09	0:19	LINE CLEAR AVAILED
106	9-Apr-19	HASSAN	66	HIREMAN-RDL	HIREMANGALUR_66	10:02	11:50	1:48	LINE CLEAR AVAILED
107	9-Apr-19	HASSAN	66	HV1	SHANTHIGRAMA_66	12:11	15:15	3:04	LINE CLEAR AVAILED
108	9-Apr-19	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	14:32	15:14	0:42	LINE CLEAR AVAILED
109	9-Apr-19	MYSORE	66	HV2	HAMPAPURA_66	0:40	1:13	0:33	TRANSFORMER FAULT
110	9-Apr-19	MYSORE	66	HV2	HAMPAPURA_66	8:10	8:21	0:11	TRANSFORMER FAULT
111	9-Apr-19	MYSORE	66	HV2	HAMPAPURA_66	8:32	8:38	0:06	TRANSFORMER FAULT
112	9-Apr-19	MYSORE	66	HEBBAL-HOOTAGALLY	HEBBAL_66 METAGALLY_66	21:53	22:39	0:45	LINE FAULT
113	9-Apr-19	MYSORE	66	KESLAGERE-NAGAMANGALA 2	BASARALU_66 KESLAGERE_66	18:45	18:55	0:10	LINE FAULT
114	9-Apr-19	MYSORE	66	KM DODDI-MANDYA	K_HONNALGERE_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 TUMBEKERE_66	1:33	1:48	0:14	LINE FAULT
115	9-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	12:22	23:59	11:36	LINE CLEAR AVAILED
116	9-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 KESLAGERE_66	8:58	9:07	0:09	LINE FAULT
117	9-Apr-19	MYSORE	66	HV2	TNARASIPURA_66	10:44	12:41	1:56	LINE CLEAR AVAILED
118	9-Apr-19	MYSORE	66	HV3	TNARASIPURA_66	10:44	12:41	1:56	LINE CLEAR AVAILED
119	9-Apr-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66	17:32	17:51	0:19	LINE FAULT
120	9-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	12:57	13:12	0:15	HAND TRIPPED
121	9-Apr-19	TUMKUR	66	TR-1	AMRUTHUR_66	10:38	14:13	3:34	LINE CLEAR AVAILED
122	9-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:06	12:55	2:49	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
123	9-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:09	15:17	0:08	LINE FAULT
124	9-Apr-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:29	17:48	0:19	LINE FAULT
125	9-Apr-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	23:51	23:56	0:05	HAND TRIPPED
126	9-Apr-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	11:40	11:54	0:13	HAND TRIPPED
127	9-Apr-19	TUMKUR	66	TR-2	MALEBENNUR_66	18:09	18:42	0:33	TRANSFORMER FAULT
128	10-Apr-19	BAGALKOT	220	HAVERI-GUTTUR 2	HAVERI_220	10:24	14:09	3:45	NFBC ISSUED
129	10-Apr-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	17:25	17:41	0:16	LINE FAULT
130	10-Apr-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	19:13	23:59	4:46	LINE FAULT
131	10-Apr-19	BAGALKOT	110	BPCL-ITANAL	ITANAL_110	9:51	11:00	1:09	LINE CLEAR AVAILED
132	10-Apr-19	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	13:38	14:20	0:42	LINE CLEAR AVAILED
133	10-Apr-19	BAGALKOT	110	SHIRAGUPPI SUGARS-KAGAWADA	KAGAWADA_110	6:17	6:21	0:04	LINE FAULT
134	10-Apr-19	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110,ALNAVAR_33	18:35	19:08	0:33	TRANSFORMER FAULT
135	10-Apr-19	BAGALKOT	110	110/11KV,HV3	MUDALAGI_110	14:08	14:35	0:27	LINE CLEAR AVAILED
136	10-Apr-19	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	9:39	10:20	0:41	LINE CLEAR AVAILED
137	10-Apr-19	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	10:28	17:21	6:53	LINE FAULT
138	10-Apr-19	BAGALKOT	220	220/110KV,HV1	RANEENNUR_220,GUDUGURMAIDUR_33,H ALAGERI_33,KUPPELUR_33,R S NAGAR_33	17:25	18:30	1:05	LINE CLEAR AVAILED
139	10-Apr-19	BAGALKOT	110	110/11KV,HV5	RANEENNUR_220	18:30	23:59	5:29	LINE CLEAR AVAILED
140	10-Apr-19	BAGALKOT	110	RANEENNUR220-TIMMANKATTI	TIMMANKATTI_110	18:30	18:37	0:07	LINE CLEAR AVAILED
141	10-Apr-19	BAGALKOT	110	RANEENNUR220-RATHIHALLI	RATHIHALLI_110	17:21	17:35	0:14	LINE FAULT
142	10-Apr-19	BAGALKOT	110	SHIGGOAN-SAVANUR	SAVANUR_110	15:27	15:46	0:19	LINE FAULT
143	10-Apr-19	BAGALKOT	110	GM NAVAR-SALAHALLI	SALAHALLI_110	9:38	16:17	6:39	LINE CLEAR AVAILED
144	10-Apr-19	BAGALKOT	110	110/33KV,HV3	SALAHALLI_110,HULKUND_33	11:02	11:59	0:57	LINE CLEAR AVAILED
145	10-Apr-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:15	14:10	1:55	LINE CLEAR AVAILED
146	10-Apr-19	BAGALKOT	110	SIRSI-KAVALWADA	KAVALWADA_110	18:09	18:43	0:34	MAIN SUPPLY FAILURE
147	10-Apr-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	18:24	18:43	0:19	HAND TRIPPED
148	10-Apr-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	23:49	23:58	0:09	HAND TRIPPED
149	10-Apr-19	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	13:20	14:36	1:16	LINE FAULT
150	10-Apr-19	BAGALKOT	220	SIRSI-HUBLI 2	SIRSI_220	14:42	17:18	2:36	LINE FAULT
151	10-Apr-19	BAGALKOT	110	MAHALINGAPUR220-JAMKHANDI	JAMKHANDI_110	0:00	10:49	10:49	LINE CLEAR AVAILED
152	10-Apr-19	BAGALKOT	110	MAHALINGAPUR220-JAMKHANDI	JAMKHANDI_110	12:14	23:59	11:45	LINE CLEAR AVAILED
153	10-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110	10:17	10:20	0:03	TRANSFORMER FAULT
154	10-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110	10:39	10:45	0:06	TRANSFORMER FAULT
155	10-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110	22:20	22:25	0:05	TRANSFORMER FAULT
156	10-Apr-19	BAGALKOT	220	VAJRAMATTI220-KAVATAGI LIS	VAJRAMATTI_220	10:27	13:00	2:33	LINE CLEAR AVAILED
157	10-Apr-19	BAGALKOT	110	UGAR SUGAR-UGAR KHUD	UGAR KHUD_110	5:47	6:16	0:29	LINE FAULT
158	10-Apr-19	BAGALKOT	110	UGAR KHUD-KAGWADA	KAGWADA_110	5:47	6:14	0:27	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
159	10-Apr-19	BAGALKOT	110	HUBLI220-TARIHAL	TARIHAL_110	19:08	20:25	1:17	MAIN SUPPLY FAILURE
160	10-Apr-19	BAGALKOT	110	TARIHAL-TADASINAKOPPA	TARIHAL_110	20:25	20:34	0:09	HAND TRIPPED
161	10-Apr-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	13:20	17:38	4:18	LINE FAULT
162	10-Apr-19	BAGALKOT	220	HUBLI-BIDNAL1	HUBLI_220	18:14	23:59	5:45	LINE FAULT
163	10-Apr-19	BAGALKOT	220	220/110KV,HV1,LV1	HUBLI_220,ANAND NAGAR_110,TARIHAL1&2_110,KALAGHATAGI _110,P H COMPOUND_110,BIDNAL1&2	18:14	19:45	1:31	TRANSFORMER FAULT
164	10-Apr-19	BAGALKOT	220	220/110KV,HV2&LV2	HUBLI_220,ANAND NAGAR_110,TARIHAL1&2_110,KALAGHATAGI _110,P H COMPOUND_110,BIDNAL1&2	18:14	20:07	1:53	TRANSFORMER FAULT
165	10-Apr-19	BAGALKOT	220	220/110KV,HV3&LV3	HUBLI_22,RAMANKOPPA_110,KADANKOPPA _110	18:14	20:08	1:54	TRANSFORMER FAULT
166	10-Apr-19	BAGALKOT	220	HUBLI-BIDNAL2	HUBLI_220	18:14	19:36	1:22	LINE FAULT
167	10-Apr-19	BAGALKOT	220	HUBLI-NAGHJARI1&2	HUBLI_220	18:14	20:13	1:59	LINE FAULT
168	10-Apr-19	BAGALKOT	220	HUBLI-NAGHJARI3	HUBLI_220	18:14	19:59	1:45	LINE FAULT
169	10-Apr-19	BAGALKOT	220	HUBLI-NARENDRA1&2	HUBLI_220	18:14	20:38	2:24	LINE FAULT
170	10-Apr-19	BAGALKOT	220	HUBLI-SIRSI1&2	HUBLI_220	18:14	20:33	2:19	LINE FAULT
171	10-Apr-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	21:09	22:30	1:21	LINE FAULT
172	10-Apr-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	21:09	23:59	2:50	LINE FAULT
173	10-Apr-19	BAGALKOT	110	HUBLI-KADANKOPPA	KADANKOPPA	18:14	23:00	4:46	LINE FAULT
174	10-Apr-19	BAGALKOT	110	HUBLI-KALAGHATAGI	KALAGHATAGI_110	18:14	23:03	4:49	LINE FAULT
175	10-Apr-19	BAGALKOT	110	HUBLI-KALAGHATAGI	KALAGHATAGI_110	23:03	23:59	0:56	LINE FAULT
176	10-Apr-19	BAGALKOT	110	HUBLI-RAMANKOPPA	RAMANKOPPA_110	18:14	20:20	2:06	LINE FAULT
177	10-Apr-19	BAGALKOT	110	HUBLI-TARIHAL1	TARIHAL_110	18:14	22:34	4:20	LINE FAULT
178	10-Apr-19	BAGALKOT	110	HUBLI-BIDNAL2	HUBLI_220	18:14	22:35	4:21	LINE FAULT
179	10-Apr-19	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)	8:31	10:56	2:25	LINE CLEAR AVAILED
180	10-Apr-19	BAGALKOT	110	110/33KV,HV1	KUMTA_110,ANKOLA_33KV,HONNAVAR_33K V	10:01	17:51	7:50	LINE CLEAR AVAILED
181	10-Apr-19	BAGALKOT	110	KUMTA-SIRSI	KUMTA_110,	0:00	18:30	18:30	LINE CLEAR AVAILED
182	10-Apr-19	BENGALURU	66	YERANDANAHALLI 220 - TOI (EHT)	TOI (EHT)	6:44	7:10	0:26	LOAD CHANGE OVER
183	10-Apr-19	BENGALURU	66	YERANDANAHALLI 220 - TOI (EHT)	TOI (EHT)	8:55	8:58	0:03	LOAD CHANGE OVER
184	10-Apr-19	BENGALURU	66	HV1	YERANDANAHALLI 220	8:44	8:50	0:06	LOAD CHANGE OVER
185	10-Apr-19	BENGALURU	66	HV2	YERANDANAHALLI 220	8:44	8:50	0:06	LOAD CHANGE OVER
186	10-Apr-19	BENGALURU	66	HV3	YERANDANAHALLI 220	8:44	8:57	0:13	LOAD CHANGE OVER
187	10-Apr-19	BENGALURU	66	HV1	YERANDANAHALLI 220	6:34	6:53	0:19	LOAD CHANGE OVER
188	10-Apr-19	BENGALURU	66	HV2	YERANDANAHALLI 220	6:34	6:53	0:19	LOAD CHANGE OVER
189	10-Apr-19	BENGALURU	66	HV3	YERANDANAHALLI 220	6:34	6:53	0:19	LOAD CHANGE OVER
190	10-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ATTIBELE	8:40	8:52	0:12	LOAD CHANGE OVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
191	10-Apr-19	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	8:40	9:04	0:24	LOAD CHANGEOVER
192	10-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1 & 2	SURYANAGAR, ATTIBELE	6:34	6:53	0:19	LINE CLEAR AVAILED
193	10-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	7:01	8:57	1:55	LINE CLEAR AVAILED
194	10-Apr-19	BENGALURU	66	HV2	SARAKKI	10:00	17:04	7:04	LINE CLEAR AVAILED
195	10-Apr-19	BENGALURU	66	HV2	TAVAREKERE	10:15	10:25	0:10	TRANSFORMER FAULT
196	10-Apr-19	BENGALURU	66	HV1	TK HALLI 220	14:26	14:30	0:04	TRANSFORMER FAULT
197	10-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:47	19:03	0:16	LINE FAULT
198	10-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:47	19:03	0:16	LINE FAULT
199	10-Apr-19	BENGALURU	66	HV1	NRS 220	15:23	16:58	1:35	LINE CLEAR AVAILED
200	10-Apr-19	BENGALURU	66	HV2	NRS 220	11:46	11:50	0:03	LINE CLEAR AVAILED
201	10-Apr-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	8:58	9:02	0:04	LOAD CHANGEOVER
202	10-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	BIOCON (EHT), BOMMASANDRA I/A	5:51	5:57	0:06	LOAD CHANGEOVER
203	10-Apr-19	BENGALURU	66	HV1	GOLF LINKS	7:15	7:25	0:10	LINE CLEAR AVAILED
204	10-Apr-19	BENGALURU	66	HV1	C STATION	18:57	21:17	2:20	LINE CLEAR AVAILED
205	10-Apr-19	BENGALURU	66	HV2	C STATION	23:00	23:15	0:15	LINE CLEAR AVAILED
206	10-Apr-19	BENGALURU	66	HV2	BRIGADE METROPOLIS	11:45	11:49	0:04	TRANSFORMER FAULT
207	10-Apr-19	BENGALURU	66	HV1	DALASNUR	13:30	15:19	1:48	LINE CLEAR AVAILED
208	10-Apr-19	BENGALURU	66	HV1	AMARIYOTHI	7:15	7:16	0:01	LINE CLEAR AVAILED
209	10-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	9:52	10:40	0:48	LINE FAULT
210	10-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	10:40	11:42	1:02	LINE FAULT
211	10-Apr-19	GULBARGA	400	BTPSG-RTPS	BTPSG_400	12:59	14:23	1:24	LINE CLEAR AVAILED
212	10-Apr-19	GULBARGA	400	RTPS-MEHBOOB NAGAR	MEHBOOB NAGAR_400	15:52	16:52	1:00	LINE CLEAR AVAILED
213	10-Apr-19	GULBARGA	400	RTPS-MUNIRABAD	GDHALLI_400	17:16	17:57	0:41	LINE CLEAR AVAILED
214	10-Apr-19	GULBARGA	400	YTPS-BTPS2	YPTS_400	17:40	20:44	3:04	LINE FAULT
215	10-Apr-19	GULBARGA	220	HV2	HALBURGA_220	15:00	15:05	0:05	TRANSFORMER FAULT
216	10-Apr-19	GULBARGA	110	LV1	HALBURGA_220	8:28	8:33	0:05	TRANSFORMER FAULT
217	10-Apr-19	GULBARGA	110	HV4	YELBURGA_110	18:40	19:05	0:25	TRANSFORMER FAULT
218	10-Apr-19	GULBARGA	110	HV3	HATTI_110	21:15	21:20	0:05	TRANSFORMER FAULT
219	10-Apr-19	GULBARGA	110	KUSHTAGI-INR_SLR	KUSHTAGI_220	16:59	18:00	1:01	LINE FAULT
220	10-Apr-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGAL_110	20:30	23:50	3:20	LINE FAULT
221	10-Apr-19	GULBARGA	110	HV1	RAICHUR_220	18:16	18:23	0:07	TRANSFORMER FAULT
222	10-Apr-19	GULBARGA	110	HV1	RAICHUR_220	20:02	20:18	0:16	TRANSFORMER FAULT
223	10-Apr-19	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KEMBHAVI2_110	18:38	23:59	5:21	LINE FAULT
224	10-Apr-19	HASSAN	220	GOPALAPURA-HNPUR21	GOPALAPURA_220	6:53	7:07	0:14	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
225	10-Apr-19	HASSAN	110	HV3	KONAJE_110	10:30	14:34	4:04	LINE CLEAR AVAILED
226	10-Apr-19	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	3:40	7:21	3:41	LINE FAULT
227	10-Apr-19	HASSAN	110	HV1		0:59	1:11	0:12	TRANSFORMER FAULT
228	10-Apr-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	10:05	10:17	0:12	LINE FAULT
229	10-Apr-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	18:15	18:30	0:15	LINE FAULT
230	10-Apr-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	10:10	10:20	0:10	MAIN SUPPLY FAILURE
231	10-Apr-19	HASSAN	66	HV1	HANGARANAHALLY_66	11:35	13:44	2:09	LINE CLEAR AVAILED
232	10-Apr-19	HASSAN	66	HASSN220-BELUR	HASSAN_220	7:11	10:25	3:14	LINE FAULT
233	10-Apr-19	HASSAN	66	HASSN220-MALLALI	HASSAN_220	10:30	11:17	0:47	LINE CLEAR AVAILED
234	10-Apr-19	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	6:53	7:01	0:08	LINE FAULT
235	10-Apr-19	HASSAN	66	HV2	KANDLI_66	7:02	7:08	0:06	TRANSFORMER FAULT
236	10-Apr-19	HASSAN	66	KUDLIG-ANVRPP	KUDLIGERE_66	8:30	9:15	0:45	LINE FAULT
237	10-Apr-19	HASSAN	66	KUDLIG-ANVRPP	KUDLIGERE_66	9:35	9:40	0:05	HAND TRIPPED
238	10-Apr-19	HASSAN	66	KUDLIG-ANVRPP	KUDLIGERE_66	9:40	9:45	0:05	LINE FAULT
239	10-Apr-19	HASSAN	66	KUDLIG-ANVRPP	KUDLIGERE_66	17:40	17:50	0:10	HAND TRIPPED
240	10-Apr-19	HASSAN	66	HV2	MATNAVILE_66	10:05	10:25	0:20	LINE CLEAR AVAILED
241	10-Apr-19	HASSAN	66	HV1	SINGAPURA_66	16:33	16:40	0:07	HAND TRIPPED
242	10-Apr-19	HASSAN	66	HV2	SINGAPURA_66	16:33	16:40	0:07	HAND TRIPPED
243	10-Apr-19	HASSAN	66	HV1	SINGAPURA_66	18:12	18:16	0:04	HAND TRIPPED
244	10-Apr-19	HASSAN	66	HV2	SINGAPURA_66	18:12	18:16	0:04	HAND TRIPPED
245	10-Apr-19	MYSORE	66	HV1	JAKKANAHALLY_66	13:10	14:01	0:50	LINE CLEAR AVAILED
246	10-Apr-19	MYSORE	66	HV1	K_HONNALGERE_66	18:53	23:59	5:05	LINE CLEAR AVAILED
247	10-Apr-19	MYSORE	66	HV1	KIADBMANDYA_66	18:54	19:11	0:16	HAND TRIPPED
248	10-Apr-19	MYSORE	66	HV2	KIADBMANDYA_66	18:54	19:12	0:17	HAND TRIPPED
249	10-Apr-19	MYSORE	66	HV1	KIKKERI_66	17:04	17:20	0:16	HAND TRIPPED
250	10-Apr-19	MYSORE	66	KM DODDI-TK HALLI	KM DODDI, KOLKARANADODDI_66 MADDUR_66 TUMBEKERE_66 SOMNAHALLI_66	18:47	19:07	0:20	LINE FAULT
251	10-Apr-19	MYSORE	66	HV2	MYSORESOUTH_66	15:39	16:09	0:29	TRANSFORMER FAULT
252	10-Apr-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	6:56	7:00	0:04	LINE FAULT
253	10-Apr-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	5:16	10:33	5:17	LINE CLEAR AVAILED
254	10-Apr-19	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	12:26	15:57	3:31	LINE CLEAR AVAILED
255	10-Apr-19	TUMKUR	110	TR-2	KBCROSS_220	15:20	16:07	0:47	LINE CLEAR AVAILED
256	10-Apr-19	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	15:52	17:42	1:50	TRANSFORMER FAULT
257	10-Apr-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	8:00	9:33	1:32	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
258	10-Apr-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66,DEVARAHALLI_66, BENKIKERE_66,TAVAREKERE(C)_66, GOPPENAHALLI_66	9:30	9:44	0:13	HAND TRIPPED
259	10-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	9:30	9:44	0:13	HAND TRIPPED
260	10-Apr-19	TUMKUR	66	LINGADHALLI-CHANNAGIRI	CHANNAGIRI_66,DEVARAHALLI_66,BENKIKER E_66,GOPPENAHALLI_66	9:45	15:20	5:34	LINE CLEAR AVAILED
261	10-Apr-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	14:25	18:36	4:10	LINE FAULT
262	10-Apr-19	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	14:21	15:05	0:43	LINE CLEAR AVAILED
263	11-Apr-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	10:32	11:46	1:14	LINE CLEAR AVAILED
264	11-Apr-19	BAGALKOT	110	110/11KV,HV3	BAILHONGAL_110	8:07	8:50	0:43	LINE CLEAR AVAILED
265	11-Apr-19	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	18:37	23:59	5:22	LINE CLEAR AVAILED
266	11-Apr-19	BAGALKOT	110	BAGEWADI220-NIDAGUNDI	NIDAGUNDI_110	15:52	23:59	8:07	LINE FAULT
267	11-Apr-19	BAGALKOT	110	BAGEWADI220-MUDEBIHAL	MUDEBIHAL_110	5:58	6:27	0:29	LINE FAULT
268	11-Apr-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1&2	MAMADAPUR_110	1:37	1:45	0:08	LINE FAULT
269	11-Apr-19	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	8:15	8:27	0:12	LINE FAULT
270	11-Apr-19	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	18:38	18:49	0:11	LINE CLEAR AVAILED
271	11-Apr-19	BAGALKOT	220	HAVERI-GUTTUR 1	HAVERI_220	9:35	19:58	10:23	LINE CLEAR AVAILED
272	11-Apr-19	BAGALKOT	110	HAVERI 220-BYADAGI	BYADAGI_110	0:00	10:24	10:24	LINE CLEAR AVAILED
273	11-Apr-19	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110,RUSTUMPUR LIS_33	11:40	20:33	8:53	LINE CLEAR AVAILED
274	11-Apr-19	BAGALKOT	110	110/11KV,HV3	INDI_110	4:00	16:28	12:28	TRANSFORMER FAULT
275	11-Apr-19	BAGALKOT	110	110/11KV,HV5	INDI_110	20:25	20:33	0:08	HAND TRIPPED
276	11-Apr-19	BAGALKOT	110	110/11,HV1	JAMBAGI_110	14:25	15:05	0:40	LINE CLEAR AVAILED
277	11-Apr-19	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KAVALWADA_110	1:41	9:19	7:38	LINE CLEAR AVAILED
278	11-Apr-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	7:40	8:46	1:06	LINE CLEAR AVAILED
279	11-Apr-19	BAGALKOT	110	110/11KV,HV1	KIRUVATTI_110	10:30	11:55	1:25	LINE CLEAR AVAILED
280	11-Apr-19	BAGALKOT	110	110/33KV,HV2	KIRUVATTI_110,YALLAPUR_33	12:00	13:31	1:31	LINE CLEAR AVAILED
281	11-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV.DHULKED_33KV	6:15	6:17	0:02	TRANSFORMER FAULT
282	11-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV.DHULKED_33KV	10:14	10:17	0:03	TRANSFORMER FAULT
283	11-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV.DHULKED_33KV	12:02	12:06	0:04	TRANSFORMER FAULT
284	11-Apr-19	BAGALKOT	110	110/11KV,HV2	SUVARNA SOUDA_110	12:06	12:42	0:36	LINE CLEAR AVAILED
285	11-Apr-19	BAGALKOT	110	110/11KV,HV1	SUVARNA SOUDA_110	12:45	13:04	0:19	LINE CLEAR AVAILED
286	11-Apr-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_110	0:00	7:03	7:03	LINE CLEAR AVAILED
287	11-Apr-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_110	7:03	13:33	6:30	LINE CLEAR AVAILED
288	11-Apr-19	BAGALKOT	220	HUBLI-BIDNAL1	HUBLI_110	0:00	13:41	13:41	LINE CLEAR AVAILED
289	11-Apr-19	BAGALKOT	110	HUBLI-KALGHATAGI	KALGHATAGI_110	0:00	8:28	8:28	LINE CLEAR AVAILED
290	11-Apr-19	BAGALKOT	110	HUBLI-KALGHATAGI	KALGHATAGI_110	18:14	18:34	0:20	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
291	11-Apr-19	BAGALKOT	220	HUBLI-SHARAVATY1&2	HUBLI_220	13:20	13:35	0:15	HAND TRIPPED
292	11-Apr-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	8:34	8:38	0:04	HAND TRIPPED
293	11-Apr-19	BAGALKOT	110	GM NAVAR-SALAHALLI	SALAHALLI_110	9:45	18:38	8:53	LINE CLEAR AVAILED
294	11-Apr-19	BAGALKOT	110	110/11KV,HV5	RANEBENNUR_220	0:00	16:45	16:45	LINE CLEAR AVAILED
295	11-Apr-19	BAGALKOT	110	BALAJI SUGARS-MUDDEBIHAL	MUDDEBIHAL_110	6:28	7:33	1:05	LINE FAULT
296	11-Apr-19	BAGALKOT	110	BALAJI SUGARS-MUDDEBIHAL	MUDDEBIHAL_110	15:52	16:04	0:12	LINE FAULT
297	11-Apr-19	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	9:25	23:59	14:34	LINE CLEAR AVAILED
298	11-Apr-19	BAGALKOT	220	220/11KV,HV1,LV1&HV2&LV2	KUDUCHI_220,UGAR KHUD_110,MORAB_110,AINAPUR_110,KUDU CHI_110,YELLAPHARATTI_110,TERDAL_110	14:05	14:16	0:11	TRANSFORMER FAULT
299	11-Apr-19	BAGALKOT	110	MATRIX-MUKARTIHAL	MUKARTIHAL_110	16:35	19:12	2:37	LINE FAULT
300	11-Apr-19	BAGALKOT	110	SPV-MUKARTHAL	MUKARTIHAL_110	16:35	19:12	2:37	LINE FAULT
301	11-Apr-19	BAGALKOT	110	BAGEWADI-MUKARTIHAL	MUKARTIHAL_110	15:50	16:20	0:30	MAIN SUPPLY FAILURE
302	11-Apr-19	BAGALKOT	110	BAGEWADI-MUKARTIHAL	MUKARTIHAL_110	19:12	23:59	4:47	LINE CLEAR AVAILED
303	11-Apr-19	BENGALURU	66	HV2	C STATION	3:00	5:42	2:42	LINE CLEAR AVAILED
304	11-Apr-19	BENGALURU	66	HOODY 220 - ITI	ITI, BANASWADI	13:01	13:16	0:14	LINE FAULT
305	11-Apr-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD. ITC (EHT)	13:01	13:14	0:12	LINE FAULT
306	11-Apr-19	BENGALURU	66	HV2	JAYANAGARA	9:34	9:40	0:05	LINE CLEAR AVAILED
307	11-Apr-19	BENGALURU	66	HV2	NIMHANS 220	11:53	11:57	0:03	LINE CLEAR AVAILED
308	11-Apr-19	BENGALURU	66	HV1	NRS 220	8:29	8:31	0:01	LINE CLEAR AVAILED
309	11-Apr-19	BENGALURU	66	HV1	SHOBHA APARTMENT	22:54	23:30	0:36	LINE CLEAR AVAILED
310	11-Apr-19	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	13:00	13:50	0:50	MAIN SUPPLY FAILURE
311	11-Apr-19	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:00	13:50	0:50	MAIN SUPPLY FAILURE
312	11-Apr-19	BENGALURU	220	HV1	VIKAS TECH PARK 220	13:00	13:50	0:50	MAIN SUPPLY FAILURE
313	11-Apr-19	BENGALURU	220	HV2	VIKAS TECH PARK 220	13:00	13:50	0:50	MAIN SUPPLY FAILURE
314	11-Apr-19	BENGALURU	66	HV2	KIADB DB PURA 220	7:54	8:28	0:34	TRANSFORMER FAULT
315	11-Apr-19	BENGALURU	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	12:21	14:13	1:52	LINE CLEAR AVAILED
316	11-Apr-19	BENGALURU	66	HV2	DODDABELAVANGALA	10:54	11:17	0:23	TRANSFORMER FAULT
317	11-Apr-19	BENGALURU	66	HV1	LAKKUR	11:09	14:04	2:55	LINE CLEAR AVAILED
318	11-Apr-19	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	13:49	14:25	0:36	LINE CLEAR AVAILED
319	11-Apr-19	BENGALURU	66	HV1	CHAKAVELU	13:49	14:56	1:07	LINE CLEAR AVAILED
320	11-Apr-19	BENGALURU	66	HV2	CHAKAVELU	13:49	14:38	0:49	LINE CLEAR AVAILED
321	11-Apr-19	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	13:00	13:46	0:46	MAIN SUPPLY FAILURE
322	11-Apr-19	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	13:00	13:46	0:46	MAIN SUPPLY FAILURE
323	11-Apr-19	BENGALURU	220	CHINTAMANI 220 - PGCIL 1 & 2	CHINTAMANI 220	13:00	13:49	0:49	MAIN SUPPLY FAILURE
324	11-Apr-19	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:00	13:48	0:48	MAIN SUPPLY FAILURE
325	11-Apr-19	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT), JADIGENAHALLI	13:00	13:57	0:57	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
326	11-Apr-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	13:00	13:57	0:57	MAIN SUPPLY FAILURE
327	11-Apr-19	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, BUDHIKOTE, TEKAL, KAMASAMUDRA, KYASAMBALLI, DODDAKARI, ANDERSONPET, BEML(EHT)	13:00	13:57	0:57	MAIN SUPPLY FAILURE
328	11-Apr-19	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	13:00	13:57	0:57	MAIN SUPPLY FAILURE
329	11-Apr-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	13:00	13:57	0:57	MAIN SUPPLY FAILURE
330	11-Apr-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	13:00	13:46	0:46	MAIN SUPPLY FAILURE
331	11-Apr-19	BENGALURU	66	KOLAR 220 - RAILWAYS 1 & 2 (EHT)	BANGARPET RAILWAYS (EHT)	13:00	13:46	0:46	MAIN SUPPLY FAILURE
332	11-Apr-19	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	13:00	13:46	0:46	MAIN SUPPLY FAILURE
333	11-Apr-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	13:00	13:46	0:46	MAIN SUPPLY FAILURE
334	11-Apr-19	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA	13:00	13:46	0:46	MAIN SUPPLY FAILURE
335	11-Apr-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	13:00	13:46	0:46	MAIN SUPPLY FAILURE
336	11-Apr-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	13:00	13:46	0:46	MAIN SUPPLY FAILURE
337	11-Apr-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:00	13:46	0:46	MAIN SUPPLY FAILURE
338	11-Apr-19	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:00	13:46	0:46	MAIN SUPPLY FAILURE
339	11-Apr-19	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:00	13:52	0:52	MAIN SUPPLY FAILURE
340	11-Apr-19	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:00	13:55	0:55	MAIN SUPPLY FAILURE
341	11-Apr-19	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:00	13:58	0:58	MAIN SUPPLY FAILURE
342	11-Apr-19	BENGALURU	66	HV1	SARJAPURA 220	13:00	13:56	0:56	MAIN SUPPLY FAILURE
343	11-Apr-19	BENGALURU	66	HV2	SARJAPURA 220	13:00	13:56	0:56	MAIN SUPPLY FAILURE
344	11-Apr-19	BENGALURU	66	HV1	KOLAR 220	13:00	13:46	0:46	MAIN SUPPLY FAILURE
345	11-Apr-19	BENGALURU	66	HV2	KOLAR 220	13:00	13:46	0:46	MAIN SUPPLY FAILURE
346	11-Apr-19	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	13:00	13:49	0:49	MAIN SUPPLY FAILURE
347	11-Apr-19	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	13:00	13:49	0:49	MAIN SUPPLY FAILURE
348	11-Apr-19	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	13:00	13:49	0:49	MAIN SUPPLY FAILURE
349	11-Apr-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA, SUGUTUR	13:00	13:49	0:49	MAIN SUPPLY FAILURE
350	11-Apr-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:00	13:49	0:49	MAIN SUPPLY FAILURE
351	11-Apr-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	13:00	13:49	0:49	MAIN SUPPLY FAILURE
352	11-Apr-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI	13:00	13:49	0:49	MAIN SUPPLY FAILURE
353	11-Apr-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	SRINIVASPURA, KODIHALLI	13:00	13:49	0:49	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
354	11-Apr-19	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	13:00	13:49	0:49	MAIN SUPPLY FAILURE
355	11-Apr-19	BENGALURU	220	HV1	DB PURA 220	10:53	11:11	0:18	TRANSFORMER FAULT
356	11-Apr-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	10:53	11:13	0:20	MAIN SUPPLY FAILURE
357	11-Apr-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	10:53	11:13	0:20	MAIN SUPPLY FAILURE
358	11-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	10:53	11:07	0:14	MAIN SUPPLY FAILURE
359	11-Apr-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:53	11:14	0:21	MAIN SUPPLY FAILURE
360	11-Apr-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	10:53	11:07	0:14	MAIN SUPPLY FAILURE
361	11-Apr-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	11:17	12:56	1:38	LINE CLEAR AVAILED
362	11-Apr-19	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	11:17	12:56	1:38	LINE CLEAR AVAILED
363	11-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	12:57	13:04	0:06	LOAD CHANGEOR
364	11-Apr-19	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	12:56	13:07	0:11	LOAD CHANGEOR
365	11-Apr-19	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:20	12:53	1:33	LINE CLEAR AVAILED
366	11-Apr-19	BENGALURU	66	HV1	DB PURA 220	11:20	12:53	1:33	LINE CLEAR AVAILED
367	11-Apr-19	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	12:10	13:17	1:07	LINE CLEAR AVAILED
368	11-Apr-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	16:37	18:16	1:39	LINE CLEAR AVAILED
369	11-Apr-19	GULBARGA	110	BYAGWAT-ACMBSLR_IPP	BYAGAWAT_110	13:26	13:39	0:13	LINE FAULT
370	11-Apr-19	GULBARGA	110	HV2	HANUMANAL_110	8:10	9:00	0:50	LINE CLEAR AVAILED
371	11-Apr-19	GULBARGA	110	HV1	HANUMASAGAR_110	15:05	15:10	0:05	TRANSFORMER FAULT
372	11-Apr-19	GULBARGA	110	HV2	KAMPLI_GLB_110	9:25	9:42	0:17	TRANSFORMER FAULT
373	11-Apr-19	GULBARGA	110	PDHALLI-BASAI_IPP	PD_HALLI_110	9:45	10:20	0:35	LINE CLEAR AVAILED
374	11-Apr-19	GULBARGA	110	SINDHANOOR-MUNIRABD1	KARTAGI_110, GANGAVATHI_110, SRERAMANAGAR_110, VENKATAGIRI_110	12:50	13:15	0:25	LINE FAULT
375	11-Apr-19	GULBARGA	110	HV1	SIRWAR_110	11:25	11:35	0:10	LINE CLEAR AVAILED
376	11-Apr-19	GULBARGA	66	UPANAYAKANAHALLI-MUNIRABAD	UPANAYAKANAHALLI_66	13:05	13:35	0:30	LINE CLEAR AVAILED
377	11-Apr-19	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	9:44	13:54	4:10	NFBC ISSUED
378	11-Apr-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	7:05	12:12	5:07	LINE CLEAR AVAILED
379	11-Apr-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	9:44	13:54	4:10	LINE CLEAR AVAILED
380	11-Apr-19	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	13:15	13:40	0:25	HAND TRIPPED
381	11-Apr-19	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	13:15	13:40	0:25	HAND TRIPPED
382	11-Apr-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	7:06	12:13	5:07	NFBC ISSUED
383	11-Apr-19	HASSAN	110	HV4	PUTTUR_110	17:37	17:54	0:17	TRANSFORMER FAULT
384	11-Apr-19	HASSAN	110	HV1	BAIKAMPADY_110	16:51	18:00	1:09	LINE CLEAR AVAILED
385	11-Apr-19	HASSAN	110	HV1	BAIKAMPADY_110	19:14	19:21	0:07	HAND TRIPPED
386	11-Apr-19	HASSAN	110	HV1	BANTWAL_110	17:57	18:29	0:32	MAIN SUPPLY FAILURE
387	11-Apr-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	17:57	18:29	0:32	MAIN SUPPLY FAILURE
388	11-Apr-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	17:57	18:29	0:32	MAIN SUPPLY FAILURE
389	11-Apr-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:38	18:26	0:48	MAIN SUPPLY FAILURE
390	11-Apr-19	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	11:09	13:22	2:13	LINE CLEAR AVAILED
391	11-Apr-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	15:31	18:02	2:31	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
392	11-Apr-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	18:02	19:31	1:29	LINE FAULT
393	11-Apr-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	19:31	23:59	4:28	LINE FAULT
394	11-Apr-19	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	17:38	18:02	0:24	LINE FAULT
395	11-Apr-19	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	18:02	18:07	0:05	LINE FAULT
396	11-Apr-19	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	19:31	19:38	0:07	LINE FAULT
397	11-Apr-19	HASSAN	110	HV1	SINGATGERE_110	14:03	16:05	2:02	LINE CLEAR AVAILED
398	11-Apr-19	HASSAN	110	SINGATG-YAGATI	SINGATGERE_110	14:03	16:05	2:02	LINE CLEAR AVAILED
399	11-Apr-19	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	16:21	16:48	0:27	LINE FAULT
400	11-Apr-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:19	16:29	9:10	LINE CLEAR AVAILED
401	11-Apr-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:31	16:26	8:55	MAIN SUPPLY FAILURE
402	11-Apr-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	16:45	17:06	0:21	LINE FAULT
403	11-Apr-19	HASSAN	66	BYARAPU-BAGUR	BYARAPURA_66	16:45	17:10	0:25	MAIN SUPPLY FAILURE
404	11-Apr-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:23	16:22	8:59	LINE CLEAR AVAILED
405	11-Apr-19	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	16:48	17:17	0:29	LINE FAULT
406	11-Apr-19	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	18:32	21:33	3:01	LINE CLEAR AVAILED
407	11-Apr-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:14	15:36	0:22	LINE FAULT
408	11-Apr-19	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLY_66	16:50	17:15	0:25	MAIN SUPPLY FAILURE
409	11-Apr-19	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLY_66	17:25	21:40	4:15	NFBC ISSUED
410	11-Apr-19	HASSAN	66	HV1	MOSALEHOSAHALLY_66	16:50	17:15	0:25	MAIN SUPPLY FAILURE
411	11-Apr-19	HASSAN	66	HV1	MOSALEHOSAHALLY_66	17:25	21:40	4:15	NFBC ISSUED
412	11-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	3:40	4:56	1:16	LINE FAULT
413	11-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	3:40	4:56	1:16	LINE FAULT
414	11-Apr-19	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	16:21	16:53	0:32	LINE FAULT
415	11-Apr-19	MYSORE	66	DEVNUR(MYS)-VAJAMANGALA	DEVANOORMYS_66 RAJEEVNAGARA_66	11:54	13:03	1:09	LINE CLEAR AVAILED
416	11-Apr-19	MYSORE	66	DEVNUR(MYS)-RAJEEV NAGARA	DEVANOORMYS_66 RAJEEVNAGARA_66	12:01	13:07	1:06	LINE CLEAR AVAILED
417	11-Apr-19	MYSORE	66	ELAVALA-HUNSUR	GAVADAGERE_66	19:22	19:30	0:07	LINE FAULT
418	11-Apr-19	MYSORE	66	BANNIKUPPE-HUNSUR	HANAGODU_66 HUNSUR_66 HOSURGATE_66	19:26	19:32	0:06	LINE FAULT
419	11-Apr-19	MYSORE	66	KOTTANUR-DODDINDUVADI	KOTTANUR_66	16:03	16:15	0:12	LINE FAULT
420	11-Apr-19	MYSORE	66	KOTTANUR-HANNUR	KOTTANUR_66	16:27	16:39	0:12	LINE FAULT
421	11-Apr-19	MYSORE	66	HANNUR-KOTTANUR	KOTTANUR_66	16:40	16:47	0:07	LINE FAULT
422	11-Apr-19	MYSORE	66	KABHALLY-ATRIA SOLAR	KABHALLY_66	16:39	17:11	0:32	LINE CLEAR AVAILED
423	11-Apr-19	MYSORE	66	KABHALLY-CLEAN SOLAR	KABHALLY_66	16:39	17:11	0:32	LINE CLEAR AVAILED
424	11-Apr-19	MYSORE	66	KABHALLY-GUNDALUPETE	KABHALLY_66	16:39	17:11	0:31	LINE CLEAR AVAILED
425	11-Apr-19	MYSORE	66	KABHALLY-CR NAGARA	KABHALLY_66	16:40	17:11	0:31	LINE CLEAR AVAILED
426	11-Apr-19	MYSORE	66	HV2	KIKKERI_66	17:02	17:22	0:20	LINE CLEAR AVAILED
427	11-Apr-19	MYSORE	66	KUSHALANAGARA 220-BETTADAPURA	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	6:19	6:29	0:09	LINE FAULT
428	11-Apr-19	MYSORE	66	MADHUVANAHALLY-PG PALYA	PGPALYA_66	15:10	15:15	0:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
429	11-Apr-19	MYSORE	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	10:31	15:54	5:22	LINE CLEAR AVAILED
430	11-Apr-19	MYSORE	66	HV2	THALAKADU_66	14:25	14:32	0:06	TRANSFORMER FAULT
431	11-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66	7:07	7:14	0:06	LINE FAULT
432	11-Apr-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	5:24	11:38	6:14	LINE CLEAR AVAILED
433	11-Apr-19	TUMKUR	110	TR-2	KADABA_110	13:23	13:39	0:16	LINE CLEAR AVAILED
434	11-Apr-19	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	9:49	12:56	3:06	TRANSFORMER FAULT
435	11-Apr-19	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	13:05	15:28	2:23	LINE CLEAR AVAILED
436	11-Apr-19	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	2:44	4:03	1:19	TRANSFORMER FAULT
437	11-Apr-19	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	18:48	19:43	0:54	TRANSFORMER FAULT
438	11-Apr-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	13:09	13:43	0:33	LINE CLEAR AVAILED
439	11-Apr-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	17:02	17:08	0:05	HAND TRIPPED
440	11-Apr-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	19:48	20:06	0:18	HAND TRIPPED
441	11-Apr-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:15	13:03	3:47	LINE CLEAR AVAILED
442	11-Apr-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:00	17:09	0:08	LINE FAULT
443	11-Apr-19	TUMKUR	66	TR-2	HINDASGHATTA_66	10:59	11:56	0:56	HAND TRIPPED
444	11-Apr-19	TUMKUR	66	LINGADHALLI-CHANNAGIRI	CHANNAGIRI_66,DEVARAHALLI_66,BENKIKER E_66,GOPPENAHALLI_66	16:12	18:27	2:14	LINE CLEAR AVAILED
445	11-Apr-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	16:13	16:20	0:07	LINE FAULT
446	11-Apr-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	3:06	3:10	0:03	LINE FAULT
447	11-Apr-19	TUMKUR	66	MIDIGESHI-IDHALLI	IDHALLY_66,KODIGENAHALLI_6	13:05	13:32	0:26	LINE FAULT
448	11-Apr-19	TUMKUR	66	TR-2	SHYLAPURA_66	13:52	13:58	0:05	TRANSFORMER FAULT
449	11-Apr-19	TUMKUR	66	TR-2	SHYLAPURA_66	15:10	15:15	0:04	TRANSFORMER FAULT
450	11-Apr-19	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	8:31	14:12	5:41	LINE CLEAR AVAILED
451	11-Apr-19	TUMKUR	66	TR-1	SAVALANGA_66	8:30	14:13	5:42	LINE CLEAR AVAILED
452	12-Apr-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	10:43	12:31	1:48	LINE CLEAR AVAILED
453	12-Apr-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	23:49	23:59	0:10	LINE FAULT
454	12-Apr-19	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	0:00	12:33	12:33	LINE CLEAR AVAILED
455	12-Apr-19	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	12:44	12:53	0:09	HAND TRIPPED
456	12-Apr-19	BAGALKOT	110	BAGEWADI220-NIDAGUNDI	NIDAGUNDI_110	0:00	17:15	17:15	LINE CLEAR AVAILED
457	12-Apr-19	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	8:48	16:01	7:13	LINE FAULT
458	12-Apr-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	7:55	16:13	8:18	LINE CLEAR AVAILED
459	12-Apr-19	BAGALKOT	110	ITANAL-RAIBAG	RAIBAG_110	21:15	21:38	0:23	LINE FAULT
460	12-Apr-19	BAGALKOT	110	110/11KV, HV1	JAMBAGI_110	13:55	14:09	0:14	TRANSFORMER FAULT
461	12-Apr-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINAKOPPA_110	11:34	11:36	0:02	LINE CLEAR AVAILED
462	12-Apr-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TADASINAKOPPA_110	14:47	15:15	0:28	LINE CLEAR AVAILED
463	12-Apr-19	BAGALKOT	110	GM NAVAR-SALAHALLI	SALAHALLI_110	9:54	14:11	4:17	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
464	12-Apr-19	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	9:38	13:58	4:20	LINE FAULT
465	12-Apr-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	9:38	13:59	4:21	LINE FAULT
466	12-Apr-19	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	20:36	20:44	0:08	TRANSFORMER FAULT
467	12-Apr-19	BAGALKOT	220	SHARAVATHI 1-SIRSI	SIRSI_220	10:13	14:04	3:51	LINE CLEAR AVAILED
468	12-Apr-19	BAGALKOT	220	SHARAVATHI 2-SIRSI	SIRSI_220	10:42	14:05	3:23	LINE CLEAR AVAILED
469	12-Apr-19	BAGALKOT	110	110/33KV,HV3	NIPPANI_110,BENADI_33	17:09	17:51	0:42	LINE CLEAR AVAILED
470	12-Apr-19	BAGALKOT	110	110/11KV,HV1	MURDESHWARA_110	20:02	20:12	0:10	LINE CLEAR AVAILED
471	12-Apr-19	BAGALKOT	110	BAGEWADI-MUKARTIHAL	MUKARTIHAL-110	0:00	17:22	17:22	LINE CLEAR AVAILED
472	12-Apr-19	BAGALKOT	110	KUD DHARAWAD-LAKAMANAHALLI	LAKAMANAHALLI_110	11:46	14:06	2:20	LINE CLEAR AVAILED
473	12-Apr-19	BAGALKOT	220	220/110KV,HV1&LV1	KUDUCHI_220	23:49	23:59	0:10	TRANSFORMER FAULT
474	12-Apr-19	BAGALKOT	110	KUDUCHI220-YELLAPARATTI	YELLAPARATTI_110	23:49	23:59	0:10	LINE FAULT
475	12-Apr-19	BAGALKOT	66	DAVANAGERE-HARIHAR HOSPET	HARIHAR HOSPET_66	0:00	6:30	6:30	LINE CLEAR AVAILED
476	12-Apr-19	BAGALKOT	66	DAVANAGERE-HARIHAR HOSPET	HARIHAR HOSPET_66	12:13	23:59	11:46	LINE CLEAR AVAILED
477	12-Apr-19	BAGALKOT	66	HONNALLI-HARIHAR HOSPET	HARIHAR HOSPET_66	6:30	12:13	5:43	LINE CLEAR AVAILED
478	12-Apr-19	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, CESSNO PARK	15:15	15:23	0:07	LINE FAULT
479	12-Apr-19	BENGALURU	66	HV2	BMTC	13:10	13:20	0:10	TRANSFORMER FAULT
480	12-Apr-19	BENGALURU	66	HV2	BMTC	17:35	17:40	0:05	TRANSFORMER FAULT
481	12-Apr-19	BENGALURU	66	HV2	HOODY 220	15:28	15:45	0:16	TRANSFORMER FAULT
482	12-Apr-19	BENGALURU	66	HV2	TAVAREKERE	8:37	8:45	0:08	TRANSFORMER FAULT
483	12-Apr-19	BENGALURU	66	HV2	BMTC	15:08	15:50	0:41	LINE CLEAR AVAILED
484	12-Apr-19	BENGALURU	66	HV1	YARANDANAHALLI 220	10:08	10:40	0:32	MAIN SUPPLY FAILURE
485	12-Apr-19	BENGALURU	66	HV2	YARANDANAHALLI 220	10:08	10:35	0:27	MAIN SUPPLY FAILURE
486	12-Apr-19	BENGALURU	66	HV2	YARANDANAHALLI 220	19:10	19:12	0:02	LOAD CHANGEOVER
487	12-Apr-19	BENGALURU	66	HV3	YARANDANAHALLI 220	10:08	10:45	0:37	MAIN SUPPLY FAILURE
488	12-Apr-19	BENGALURU	66	HV1	CHAKAVELU	10:23	10:28	0:04	TRANSFORMER FAULT
489	12-Apr-19	BENGALURU	66	HV1	CHAKAVELU	12:50	12:55	0:05	TRANSFORMER FAULT
490	12-Apr-19	BENGALURU	66	HV1	CHAKAVELU	13:25	13:30	0:05	TRANSFORMER FAULT
491	12-Apr-19	BENGALURU	66	HV1	CHAKAVELU	14:20	14:50	0:30	TRANSFORMER FAULT
492	12-Apr-19	BENGALURU	66	HV2	CHAKAVELU	6:59	7:17	0:17	TRANSFORMER FAULT
493	12-Apr-19	BENGALURU	66	HV2	CHAKAVELU	11:30	11:35	0:05	TRANSFORMER FAULT
494	12-Apr-19	BENGALURU	66	HV2	CHAKAVELU	13:50	13:55	0:05	TRANSFORMER FAULT
495	12-Apr-19	BENGALURU	66	HV2	CHAKAVELU	14:15	14:45	0:30	TRANSFORMER FAULT
496	12-Apr-19	BENGALURU	220	HV2	CHINTAMANI 220	11:30	11:49	0:19	TRANSFORMER FAULT
497	12-Apr-19	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	11:30	11:50	0:20	LINE FAULT
498	12-Apr-19	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	11:38	11:48	0:10	LOAD CHANGEOVER
499	12-Apr-19	BENGALURU	66	D PALYA - GOWRIBIDANUR	D PALYA,GUDIBANDE, PERESANDRA	10:31	13:30	2:58	LINE CLEAR AVAILED
500	12-Apr-19	BENGALURU	66	HV2	NALLIMARADANAHALLI	11:07	12:25	1:17	LINE CLEAR AVAILED
501	12-Apr-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:05	9:10	0:05	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
502	12-Apr-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	20:43	21:19	0:36	LINE FAULT
503	12-Apr-19	BENGALURU	66	HV2	CHANDAPURA	11:56	12:03	0:07	TRANSFORMER FAULT
504	12-Apr-19	GULBARGA	220	HV2	HALBURGA_220	5:47	5:57	0:10	TRANSFORMER FAULT
505	12-Apr-19	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGRAGOA_110, KAMALNAGAR_110	5:49	6:00	0:11	LINE FAULT
506	12-Apr-19	GULBARGA	110	WADAGERA-RENEWSOLAR_IPP	WADAGERA_110	18:10	21:40	3:30	LINE CLEAR AVAILED
507	12-Apr-19	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:57	20:26	9:29	NFBC ISSUED
508	12-Apr-19	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	10:18	11:37	1:19	LINE FAULT
509	12-Apr-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	9:44	14:05	4:21	LINE CLEAR AVAILED
510	12-Apr-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:38	14:10	4:32	LINE FAULT
511	12-Apr-19	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:06	12:20	1:14	NFBC ISSUED
512	12-Apr-19	HASSAN	110	HV3	ALKOLA_110	9:43	10:03	0:20	LINE CLEAR AVAILED
513	12-Apr-19	HASSAN	110	KARAYA-PUTTUR	KARAYA_110	10:00	11:54	1:54	LINE CLEAR AVAILED
514	12-Apr-19	HASSAN	110	HV1	KONAJE_110	0:14	0:17	0:03	HAND TRIPPED
515	12-Apr-19	HASSAN	110	HV2	KONAJE_110	0:14	0:17	0:03	HAND TRIPPED
516	12-Apr-19	HASSAN	110	HV3	KONAJE_110	0:14	0:17	0:03	HAND TRIPPED
517	12-Apr-19	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	0:00	0:08	0:08	LINE FAULT
518	12-Apr-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	14:49	15:15	0:26	LINE FAULT
519	12-Apr-19	MYSORE	66	HV1	K_HONNALGERE_66	10:09	13:27	3:18	LINE CLEAR AVAILED
520	12-Apr-19	MYSORE	66	HV2	K_HONNALGERE_66	10:09	23:59	13:49	LINE CLEAR AVAILED
521	12-Apr-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMNAHALLI_66	10:10	12:33	2:23	LINE CLEAR AVAILED
522	12-Apr-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	14:21	14:26	0:04	LINE FAULT
523	12-Apr-19	MYSORE	66	HV3	NANJANGUDU_66	19:07	19:51	0:44	HAND TRIPPED
524	12-Apr-19	MYSORE	66	HV1	SANTHESARAGUR_66	8:57	9:05	0:07	TRANSFORMER FAULT
525	12-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	10:27	23:59	13:32	LINE CLEAR AVAILED
526	12-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66	5:31	5:42	0:10	LINE FAULT
527	12-Apr-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	5:31	11:10	5:38	LINE CLEAR AVAILED
528	12-Apr-19	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	15:05	15:14	0:09	LINE CLEAR AVAILED
529	12-Apr-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66	19:44	20:01	0:17	LINE FAULT
530	12-Apr-19	TUMKUR	66	TR-1	CHITRADURGA_66	8:57	9:33	0:36	LINE CLEAR AVAILED
531	12-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:11	0:26	0:15	LINE FAULT
532	12-Apr-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:44	10:36	0:52	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
533	12-Apr-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	19:42	20:02	0:19	HAND TRIPPED
534	12-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALI	SASUVEHALI_66	19:42	20:02	0:20	HAND TRIPPED
535	13-Apr-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	0:00	0:03	0:03	LINE CLEAR AWAILED
536	13-Apr-19	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	6:44	10:50	4:06	LINE CLEAR AWAILED
537	13-Apr-19	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	8:02	23:59	15:57	LINE CLEAR AWAILED
538	13-Apr-19	BAGALKOT	220	HARTI1-BIDNAL	BIDNAL_220	18:54	22:34	3:40	LINE FAULT
539	13-Apr-19	BAGALKOT	220	HARTI2-BIDNAL	BIDNAL_220	21:28	23:59	2:31	LINE FAULT
540	13-Apr-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	16:53	22:21	5:28	LINE FAULT
541	13-Apr-19	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220,CHIKKODI_110, NIPPANI_110, SADALAGA_110, ANKALI_110	5:34	6:22	0:48	TRANSFORMER FAULT
542	13-Apr-19	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	22:16	23:59	1:43	LINE CLEAR AWAILED
543	13-Apr-19	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110, WIND1&2_33	21:54	22:32	0:38	TRANSFORMER FAULT
544	13-Apr-19	BAGALKOT	110	110/11KV, HV4	GHATAPRABHA_110	5:58	6:03	0:05	TRANSFORMER FAULT
545	13-Apr-19	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	22:38	23:41	1:03	LINE FAULT
546	13-Apr-19	BAGALKOT	110	KONNUR-KERUR	KERUR_110	6:19	7:18	0:59	LINE CLEAR AWAILED
547	13-Apr-19	BAGALKOT	110	110/11KV, HV2	KHANAPUR_110	8:34	9:25	0:51	LINE CLEAR AWAILED
548	13-Apr-19	BAGALKOT	110	BELGAUM-VADAGOAN	VADAGOAN_110	20:34	21:13	0:39	LINE CLEAR AWAILED
549	13-Apr-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD	19:43	19:47	0:04	TRANSFORMER FAULT
550	13-Apr-19	BAGALKOT	110	ENERCON1&2-SOUDATTI	SOUDATTI_110	10:39	16:40	6:01	LINE CLEAR AWAILED
551	13-Apr-19	BAGALKOT	110	110/11KV,HV1	SOUDATTI_220	19:03	19:50	0:47	MAIN SUPPLY FAILURE
552	13-Apr-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	20:30	20:45	0:15	LINE FAULT
553	13-Apr-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	8:05	23:59	15:54	NFBC ISSUED
554	13-Apr-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	19:03	19:41	0:38	LINE FAULT
555	13-Apr-19	BAGALKOT	220	NARENDRA-BELGAUM 1	NARENDRA_220	17:01	22:06	5:05	LINE FAULT
556	13-Apr-19	BAGALKOT	220	M K HUBLI-NARENDRA 2	M K HUBLI_220	8:25	12:13	3:48	NFBC ISSUED
557	13-Apr-19	BAGALKOT	110	M K HUBLI220-M K HUBLI 110	M K HUBLI_110	8:20	14:32	6:12	LINE CLEAR AWAILED
558	13-Apr-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	9:15	9:19	0:04	HAND TRIPPED
559	13-Apr-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	13:09	13:17	0:08	HAND TRIPPED
560	13-Apr-19	BAGALKOT	220	220/110KV,HV1&LV1	KUDUCHI_220	0:00	0:01	0:01	LINE CLEAR AWAILED
561	13-Apr-19	BAGALKOT	110	KUDUCHI220-YELLAPARATTI	YELLAPARATTI_110	0:00	0:04	0:04	LINE CLEAR AWAILED
562	13-Apr-19	BAGALKOT	110	110/33KV,HV3	LAXMESWAR_110	20:00	20:55	0:55	TRANSFORMER FAULT
563	13-Apr-19	BENGALURU	220	HEBBAL 220 - HOODY 220	HEBBAL 220	11:25	11:35	0:10	LINE CLEAR AWAILED
564	13-Apr-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	11:25	11:35	0:10	LINE CLEAR AWAILED
565	13-Apr-19	BENGALURU	66	HEBBAL 220 - C STATION	C STATION	11:25	11:35	0:10	LINE CLEAR AWAILED
566	13-Apr-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	11:25	11:35	0:10	LINE CLEAR AWAILED
567	13-Apr-19	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, NELAMANGALA 66, BIEC	5:45	6:07	0:22	LINE FAULT
568	13-Apr-19	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	7:00	7:05	0:05	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
569	13-Apr-19	BENGALURU	66	BIEC - SRS PEENYA 220	BIEC	5:45	5:55	0:10	LINE CLEAR AVAILED
570	13-Apr-19	BENGALURU	66	HV2	CHANDAPURA	10:00	10:10	0:09	TRANSFORMER FAULT
571	13-Apr-19	BENGALURU	66	HV2	CHANDAPURA	14:00	14:05	0:05	LINE CLEAR AVAILED
572	13-Apr-19	BENGALURU	66	HV2	CHANDAPURA	14:30	14:35	0:05	LINE CLEAR AVAILED
573	13-Apr-19	BENGALURU	66	HV1	DABUSPET 220	11:45	13:06	1:21	LINE CLEAR AVAILED
574	13-Apr-19	BENGALURU	66	DABUSPET 220 - KOLALA	KOLALA	11:00	11:15	0:15	LINE FAULT
575	13-Apr-19	BENGALURU	66	DABUSPET 220 - KOLALA	KOLALA	12:04	12:54	0:50	LINE FAULT
576	13-Apr-19	BENGALURU	66	D PALYA - GOWRIBIDANUR	D PALYA,GUDIBANDE, PERESANDRA	18:16	21:54	3:37	LINE CLEAR AVAILED
577	13-Apr-19	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	6:20	6:36	0:16	LINE FAULT
578	13-Apr-19	BENGALURU	66	HV2	NANGLI	11:53	12:15	0:21	LINE CLEAR AVAILED
579	13-Apr-19	BENGALURU	66	TG HALLI - ANCHEPALYA 220	GUDEMARANAHALLI, TG HALLI, MAGADI 66	9:30	10:30	1:00	MAIN SUPPLY FAILURE
580	13-Apr-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:12	12:16	0:04	LINE FAULT
581	13-Apr-19	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	5:45	6:05	0:20	MAIN SUPPLY FAILURE
582	13-Apr-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	6:02	6:05	0:03	LOAD CHANGEOVER
583	13-Apr-19	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	7:04	7:14	0:10	LOAD CHANGEOVER
584	13-Apr-19	GULBARGA	220	RTPS-RAICHUR1	RAICHUR_220	10:02	10:53	0:51	LINE CLEAR AVAILED
585	13-Apr-19	GULBARGA	110	HV1	HAMPASAGAR_66	21:17	21:21	0:04	TRANSFORMER FAULT
586	13-Apr-19	GULBARGA	110	HV1	HAMPASAGAR_66	21:33	21:38	0:05	TRANSFORMER FAULT
587	13-Apr-19	GULBARGA	110	HV1	HAMPASAGAR_66	23:15	23:20	0:05	TRANSFORMER FAULT
588	13-Apr-19	GULBARGA	110	HV2	GULBARGASOUTH_110	10:24	10:48	0:24	LINE CLEAR AVAILED
589	13-Apr-19	GULBARGA	110	HV1, HV2	MASKI_110	8:43	13:16	4:33	LINE CLEAR AVAILED
590	13-Apr-19	GULBARGA	110	WADAGERA-RENEWSOLAR_IPP	WADAGERA_110	19:10	21:30	2:20	LINE CLEAR AVAILED
591	13-Apr-19	GULBARGA	110	WADAGERA-RENEWSOLAR_IPP	WADAGERA_110	21:33	21:53	0:20	LINE CLEAR AVAILED
592	13-Apr-19	GULBARGA	110	WADAGERA-RENEWSOLAR_IPP	WADAGERA_110	22:10	22:25	0:15	LINE CLEAR AVAILED
593	13-Apr-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:36	11:53	0:17	LINE FAULT
594	13-Apr-19	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	11:24	11:53	0:29	LINE FAULT
595	13-Apr-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	9:23	9:25	0:02	HAND TRIPPED
596	13-Apr-19	HASSAN	110	KAVOOR-GURUPURA	KAVOOR_220	9:23	9:25	0:02	HAND TRIPPED
597	13-Apr-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	4:45	4:55	0:10	MAIN SUPPLY FAILURE
598	13-Apr-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	16:30	20:41	4:11	LINE FAULT
599	13-Apr-19	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	4:47	4:57	0:10	LINE FAULT
600	13-Apr-19	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	BGPURA_66 KOLLEGALA_66 PARINAMIPURA_66 SATHEGALA_66 THALAKADU_66	6:05	6:10	0:04	LINE FAULT
601	13-Apr-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALLI, MEGLAPURA & THUMBLA	18:55	19:13	0:18	LINE FAULT
602	13-Apr-19	TUMKUR	220	KB CROSS 220KV- NELAMANGALA	KBCROSS_220	10:31	11:56	1:24	LINE CLEAR AVAILED
603	13-Apr-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	5:33	11:06	5:32	LINE CLEAR AVAILED
604	13-Apr-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	6:02	14:17	8:15	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
605	13-Apr-19	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	8:27	14:16	5:48	LINE CLEAR AVAILED
606	13-Apr-19	TUMKUR	66	TR-2	BEVINAHALLI_66	15:38	18:08	2:29	LINE CLEAR AVAILED
607	13-Apr-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	11:49	11:52	0:03	HAND TRIPPED
608	13-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	22:03	23:48	1:44	LINE CLEAR AVAILED
609	13-Apr-19	TUMKUR	66	TR-2	KUKKAWADA_66	8:53	11:56	3:02	TRANSFORMER FAULT
610	13-Apr-19	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	18:22	23:02	4:39	LINE CLEAR AVAILED
611	14-Apr-19	BAGALKOT	220	HARTI2-BIDNAL	BIDNAL_220	0:00	8:45	8:45	LINE CLEAR AVAILED
612	14-Apr-19	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	12:09	15:18	3:09	LINE CLEAR AVAILED
613	14-Apr-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	21:39	23:59	2:20	LINE FAULT
614	14-Apr-19	BAGALKOT	110	ENERCON-BIJAPUR220	BIJAPUR_220	15:42	15:48	0:06	LINE FAULT
615	14-Apr-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	18:44	23:59	5:15	LINE FAULT
616	14-Apr-19	BAGALKOT	220	CHIKKODI-BELGAUM1	CHIKKODI_220	0:00	12:56	12:56	LINE CLEAR AVAILED
617	14-Apr-19	BAGALKOT	220	GADAG-BAGALKOT1	GADAG_220	11:56	16:13	4:17	LINE FAULT
618	14-Apr-19	BAGALKOT	220	GADAG-BAGALKOT2	GADAG_220	11:56	16:13	4:17	LINE FAULT
619	14-Apr-19	BAGALKOT	110	INDI220-INDI	INDI_110	8:14	8:31	0:17	LINE FAULT
620	14-Apr-19	BAGALKOT	110	AMBEWADI-KADANKOPPA	KADANKOPPA_110	22:21	22:23	0:02	HAND TRIPPED
621	14-Apr-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	20:52	21:04	0:12	LINE FAULT
622	14-Apr-19	BAGALKOT	220	SHARAVATHI 1-SIRSI	SIRSI_220	9:31	17:21	7:50	LINE CLEAR AVAILED
623	14-Apr-19	BAGALKOT	220	SHARAVATHI 2-SIRSI	SIRSI_220	9:32	17:22	7:50	LINE CLEAR AVAILED
624	14-Apr-19	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	9:36	17:12	7:36	LINE CLEAR AVAILED
625	14-Apr-19	BAGALKOT	220	SIRSI-HUBLI 2	SIRSI_220	9:36	17:17	7:41	LINE CLEAR AVAILED
626	14-Apr-19	BAGALKOT	220	NARENDRA-BELGAUM 1	NARENDRA_220	18:44	23:59	5:15	LINE FAULT
627	14-Apr-19	BAGALKOT	110	KUMTA-SIRSI 1	KUMTA_110	0:00	23:39	23:39	LINE CLEAR AVAILED
628	14-Apr-19	BAGALKOT	110	KUMTA-SIRSI 1	KUMTA_110	23:46	23:59	0:13	LINE CLEAR AVAILED
629	14-Apr-19	BAGALKOT	110	110/11KV,HV1	LAXMESWAR_110	10:22	17:35	7:13	TRANSFORMER FAULT
630	14-Apr-19	BAGALKOT	110	110/11KV,HV2	LAXMESWAR_110	12:20	13:19	0:59	HAND TRIPPED
631	14-Apr-19	BAGALKOT	110	KARWAR220-KUMTA	KUMTA_110	23:08	23:45	0:37	LINE FAULT
632	14-Apr-19	BAGALKOT	110	110/33KV,HV1	SOUDATTI_110, CHULKI_33, UDAKERI_33, SUZLON_33	7:04	7:33	0:29	LINE CLEAR AVAILED
633	14-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	23:37	23:43	0:05	LOAD CHANGEOVER
634	14-Apr-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	15:17	15:52	0:35	LINE FAULT
635	14-Apr-19	BENGALURU	66	HV2	HEJJALA	12:55	13:33	0:37	LINE CLEAR AVAILED
636	14-Apr-19	BENGALURU	66	HV1	HEJJALA	10:35	12:20	1:45	LINE CLEAR AVAILED
637	14-Apr-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	8:28	8:35	0:07	LOAD CHANGEOVER
638	14-Apr-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	6:02	6:10	0:07	LOAD CHANGEOVER
639	14-Apr-19	BENGALURU	66	TK HALLI 220 - IGGALURU	AKKURMOLE, IGGALUR	16:31	17:03	0:31	LINE FAULT
640	14-Apr-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	5:45	6:45	1:00	LINE FAULT
641	14-Apr-19	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	7:51	8:35	0:43	LOAD CHANGEOVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
642	14-Apr-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	11:20	11:25	0:05	LOAD CHANGEOVER
643	14-Apr-19	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	8:05	8:33	0:27	LOAD CHANGEOVER
644	14-Apr-19	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	11:23	11:29	0:06	LOAD CHANGEOVER
645	14-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	19:25	19:31	0:05	LINE FAULT
646	14-Apr-19	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	11:01	11:07	0:06	LINE FAULT
647	14-Apr-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	15:46	15:54	0:08	LINE FAULT
648	14-Apr-19	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:03	9:08	0:05	LINE FAULT
649	14-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	13:52	15:09	1:17	LINE FAULT
650	14-Apr-19	BENGALURU	66	ANEKAL - ATTIBELE	ANEKAL	17:55	18:10	0:15	LOAD CHANGEOVER
651	14-Apr-19	BENGALURU	66	HV2	ANEKAL	6:21	7:01	0:40	LINE CLEAR AVAILED
652	14-Apr-19	GULBARGA	220	HV2	HALBURGA_220	18:20	18:24	0:04	TRANSFORMER FAULT
653	14-Apr-19	GULBARGA	220	SEDAM-SHREECEMENT_IPP	SEDAM_220	18:25	18:50	0:25	LINE FAULT
654	14-Apr-19	GULBARGA	110	HV2	HAGARIBOMMANAHALLI_66	21:10	21:15	0:05	TRANSFORMER FAULT
655	14-Apr-19	GULBARGA	110	HV1	KAMPLI_GLB_110	0:25	0:50	0:25	TRANSFORMER FAULT
656	14-Apr-19	GULBARGA	110	HV3	KOPPAL_110	19:19	19:23	0:04	LINE CLEAR AVAILED
657	14-Apr-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110,MARAGUTTI_110	17:48	17:56	0:08	LINE FAULT
658	14-Apr-19	GULBARGA	110	KUSTAGI-ILKAL1,2	ILKAL_110	10:28	11:18	0:50	NFBC ISSUED
659	14-Apr-19	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110,BTPS_WA TERWORKS	5:47	5:57	0:10	LINE FAULT
660	14-Apr-19	GULBARGA	110	SINDHANOOR-SUZLON1	SINDHANOOR_220	18:36	19:09	0:33	LINE FAULT
661	14-Apr-19	GULBARGA	110	SINDHANOOR-PGLR_WIND_IPP	SIDHANOOR_220	23:04	23:59	0:55	LINE FAULT
662	14-Apr-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	13:03	13:49	0:46	LINE FAULT
663	14-Apr-19	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	13:03	13:45	0:42	LINE FAULT
664	14-Apr-19	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	15:57	23:59	8:02	LINE FAULT
665	14-Apr-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	9:30	17:21	7:51	LINE CLEAR AVAILED
666	14-Apr-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:31	17:24	7:53	LINE CLEAR AVAILED
667	14-Apr-19	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	15:57	23:59	8:02	LINE FAULT
668	14-Apr-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	16:00	16:55	0:55	MAIN SUPPLY FAILURE
669	14-Apr-19	HASSAN	110	SORABA-SHR220	SORABA_110	16:00	17:00	1:00	MAIN SUPPLY FAILURE
670	14-Apr-19	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	15:38	15:49	0:11	HAND TRIPPED
671	14-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 2	DOORA, HURA & HULLALLI	18:53	19:01	0:08	LINE FAULT
672	14-Apr-19	MYSORE	66	HV2	K_HONNALGERE_66	16:34	20:29	3:55	LINE CLEAR AVAILED
673	14-Apr-19	MYSORE	66	KUNTHUR-DR PETE	MUGUR, SANTHE MARALLI, THAYUR & TN PURA	6:07	6:17	0:10	LINE FAULT
674	14-Apr-19	MYSORE	66	MADHUVANAHALLI-YELANDUR	MAMBALLI & YELANDUR	16:08	16:13	0:04	LINE FAULT
675	14-Apr-19	MYSORE	66	MADHUVANAHALLI-YELANDUR	MAMBALLI & YELANDUR	18:04	18:12	0:08	LINE FAULT
676	14-Apr-19	MYSORE	66	HV1	SANTHESARAGUR_66	12:11	12:19	0:07	TRANSFORMER FAULT
677	14-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	13:14	23:59	10:44	LINE CLEAR AVAILED
678	14-Apr-19	TUMKUR	220	TR-1	HONNALLI_220	14:29	15:54	1:24	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
679	14-Apr-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	5:27	18:26	12:59	LINE CLEAR AVAILED
680	14-Apr-19	TUMKUR	220	THALLAK 220KV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	12:45	12:56	0:10	HAND TRIPPED
681	14-Apr-19	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	7:36	7:54	0:17	HAND TRIPPED
682	14-Apr-19	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	10:58	10:59	0:01	HAND TRIPPED
683	14-Apr-19	TUMKUR	66	TR-1	CHITRADURGA_66	11:46	12:02	0:16	LINE CLEAR AVAILED
684	14-Apr-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:54	13:13	0:19	HAND TRIPPED
685	14-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:05	18:21	0:16	LINE FAULT
686	14-Apr-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:34	15:10	0:35	HAND TRIPPED
687	14-Apr-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:40	16:27	0:47	HAND TRIPPED
688	14-Apr-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	16:50	17:06	0:16	HAND TRIPPED
689	14-Apr-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	3:55	4:38	0:42	HAND TRIPPED
690	14-Apr-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	4:38	12:38	7:59	LINE CLEAR AVAILED
691	14-Apr-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	13:34	14:34	0:59	HAND TRIPPED
692	14-Apr-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	15:40	16:00	0:20	HAND TRIPPED
693	14-Apr-19	TUMKUR	66	TR-1	HONNALI_66	14:29	14:54	0:24	TRANSFORMER FAULT
694	14-Apr-19	TUMKUR	66	TR-1	HONNALI_66	15:30	15:58	0:28	TRANSFORMER FAULT
695	14-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	6:17	6:23	0:05	LINE FAULT
696	14-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	15:40	16:01	0:21	LINE CLEAR AVAILED
697	14-Apr-19	TUMKUR	66	TR-1 & 2	HULIYURDURGA_66	14:10	15:29	1:19	LINE CLEAR AVAILED
698	14-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	10:25	10:56	0:30	LINE CLEAR AVAILED
699	14-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	10:16	10:56	0:39	LINE CLEAR AVAILED
700	14-Apr-19	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	9:29	11:21	1:52	LINE CLEAR AVAILED
701	14-Apr-19	TUMKUR	66	TR-2	LINGADAHALLY_66	7:50	8:37	0:47	LINE CLEAR AVAILED
702	14-Apr-19	TUMKUR	66	TR-2	LINGADAHALLY_66	8:48	8:52	0:03	LINE CLEAR AVAILED
703	14-Apr-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	15:34	15:46	0:12	LINE FAULT
704	15-Apr-19	BAGALKOT	110	GOPANAKOPPA-BIDNAL- NVLKD(NARAGUND)	NARAGUND_110	9:19	9:23	0:04	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
705	15-Apr-19	BAGALKOT	110	110/33KV,HV-3	HIDIKAL DAM_110&RUSTUM PUR,W/S1&2_33KV	17:22	17:45	0:23	TRANSFORMER FAULT
706	15-Apr-19	BAGALKOT	110	110/11KV,HV-1	JAMBAGI_110	15:41	15:43	0:02	TRANSFORMER FAULT
707	15-Apr-19	BAGALKOT	110	110/11KV,HV-1	JAMBAGI_110	15:53	15:54	0:01	TRANSFORMER FAULT
708	15-Apr-19	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	0:00	13:50	13:50	LINE CLEAR AVAILED
709	15-Apr-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	0:00	13:49	13:49	LINE CLEAR AVAILED
710	15-Apr-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	11:26	11:32	0:06	TRANSFORMER FAULT
711	15-Apr-19	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	16:44	17:23	0:39	LINE CLEAR AVAILED
712	15-Apr-19	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	10:10	11:08	0:58	LINE CLEAR AVAILED
713	15-Apr-19	BAGALKOT	110	MATRIX WIND-MUKARTIHAL	MUKARTIHAL_110	14:21	15:29	1:08	LINE CLEAR AVAILED
714	15-Apr-19	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	12:44	15:19	2:35	LINE CLEAR AVAILED
715	15-Apr-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	9:42	9:53	0:11	LINE CLEAR AVAILED
716	15-Apr-19	BAGALKOT	220	220/110KV, HV1	RANEENNUR_220	11:04	11:52	0:48	TRANSFORMER FAULT
717	15-Apr-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	0:00	4:19	4:19	LINE CLEAR AVAILED
718	15-Apr-19	BAGALKOT	110	BIDNAL220-GADAG	GADAG_110	1:07	4:20	3:13	LINE CLEAR AVAILED
719	15-Apr-19	BENGALURU	66	HV1	BUDIGERE	18:05	18:37	0:32	LOAD CHANGEOVER
720	15-Apr-19	BENGALURU	66	HV2	BUDIGERE	16:59	17:45	0:45	LOAD CHANGEOVER
721	15-Apr-19	BENGALURU	66	REMCO - VRISHBHAVATHI 220	REMCO	11:27	11:36	0:09	LINE FAULT
722	15-Apr-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	7:36	7:52	0:15	LOAD CHANGEOVER
723	15-Apr-19	BENGALURU	66	REMCO - MYSORE ROAD 1	VIJAYANAGARA	11:27	11:50	0:23	LINE FAULT
724	15-Apr-19	BENGALURU	66	HV1	LR BANDE	11:40	12:10	0:30	LINE CLEAR AVAILED
725	15-Apr-19	BENGALURU	66	HV1	LR BANDE	17:33	18:40	1:07	LINE CLEAR AVAILED
726	15-Apr-19	BENGALURU	66	HV2	CHANDAPURA	10:53	10:55	0:01	LINE CLEAR AVAILED
727	15-Apr-19	BENGALURU	66	HV2	CHANDAPURA	11:41	11:42	0:01	LINE CLEAR AVAILED
728	15-Apr-19	BENGALURU	66	HV2	CHANDAPURA	12:46	12:51	0:04	TRANSFORMER FAULT
729	15-Apr-19	BENGALURU	66	HV2	CHANDAPURA	19:06	19:09	0:02	TRANSFORMER FAULT
730	15-Apr-19	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	6:58	9:15	2:17	LINE CLEAR AVAILED
731	15-Apr-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	16:19	16:26	0:06	LOAD CHANGEOVER
732	15-Apr-19	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	17:37	17:41	0:04	LOAD CHANGEOVER
733	15-Apr-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	16:28	17:35	1:06	LOAD CURTAILMENT
734	15-Apr-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:26	11:33	0:07	LINE FAULT
735	15-Apr-19	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	12:01	12:45	0:43	LINE CLEAR AVAILED
736	15-Apr-19	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	13:05	13:33	0:28	LINE CLEAR AVAILED
737	15-Apr-19	BENGALURU	220	HV2	KOLAR 220	16:29	17:34	1:05	LINE CLEAR AVAILED
738	15-Apr-19	BENGALURU	66	HV2	MAGADI 66	10:26	11:27	1:00	LINE CLEAR AVAILED
739	15-Apr-19	BENGALURU	66	HV2	MAGADI 66	11:39	12:11	0:31	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
740	15-Apr-19	BENGALURU	66	HV2	MAGADI_66	15:11	15:36	0:25	LINE CLEAR AVAILED
741	15-Apr-19	BENGALURU	66	HV2	MAGADI_66	18:19	18:37	0:18	LINE CLEAR AVAILED
742	15-Apr-19	GULBARGA	110	HV2	KAMPLI_110	10:42	10:47	0:05	TRANSFORMER FAULT
743	15-Apr-19	GULBARGA	110	HV1	KAMPLI_110	7:35	7:45	0:10	TRANSFORMER FAULT
744	15-Apr-19	GULBARGA	110	KAPNOOR-HUMNABD1	MAHAGOAN_110,MARAGUTTI_110	10:50	10:56	0:06	LINE FAULT
745	15-Apr-19	GULBARGA	110	KAPNOOR-HUMNABD1	MAHAGOAN_110,MARAGUTTI_110	11:20	11:25	0:05	LINE FAULT
746	15-Apr-19	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	0:32	1:13	0:41	LINE FAULT
747	15-Apr-19	GULBARGA	110	SINDHANOOR-PGLR_WIND_IPP	SIDHANOOR_220	0:00	19:15	19:15	LINE FAULT
748	15-Apr-19	MYSORE	66	HV2	BOOKANAKERE_66	17:19	17:53	0:34	LINE CLEAR AVAILED
749	15-Apr-19	MYSORE	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	13:33	23:59	10:25	LINE CLEAR AVAILED
750	15-Apr-19	MYSORE	66	MADHUVANAHALLI-KOLLEGALA 1	BGPURA_66 KOLLEGALA_66 PARINAMIPURA_66 SATHEGALA_66 THALAKADU_66	6:01	6:10	0:08	LINE FAULT
751	15-Apr-19	MYSORE	66	HV1	SANTHESARAGUR_66	15:40	15:43	0:03	TRANSFORMER FAULT
752	15-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	16:02	22:55	6:52	LINE CLEAR AVAILED