

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 05.03.2019 to 11.03.2019**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	5-Mar-19	BAGALKOT	110	110/11KV,HV-1	ANANDNAGAR_110	7:42	7:52	0:10	TRANSFORMER FAULT
2	5-Mar-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	10:31	11:55	1:24	TRANSFORMER FAULT
3	5-Mar-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	13:04	13:52	0:48	TRANSFORMER FAULT
4	5-Mar-19	BAGALKOT	110	110/11KV,HV-1	BILAGI_110	12:29	14:09	1:40	LINE CLEAR AVAILED
5	5-Mar-19	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	6:04	6:09	0:05	LINE FAULT
6	5-Mar-19	BAGALKOT	110	110/11KV,HV-1	GOPANAKOPPA_110	11:39	23:59	12:20	LINE CLEAR AVAILED
7	5-Mar-19	BAGALKOT	110	KIRUVATTI-SIRSI	KIRUVATTI_110	5:57	6:40	0:43	LINE FAULT
8	5-Mar-19	BAGALKOT	110	110/11KV,HV-1	KUDACHI_110	12:49	13:21	0:32	LINE CLEAR AVAILED
9	5-Mar-19	BAGALKOT	110	110/11KV,HV-2	TERADAL_110	11:58	13:42	1:44	LINE CLEAR AVAILED
10	5-Mar-19	BAGALKOT	110	MAHALINGAPUR-TERADAL	TERADAL_110	13:28	13:40	0:12	LINE CLEAR AVAILED
11	5-Mar-19	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	16:00	16:46	0:46	LINE CLEAR AVAILED
12	5-Mar-19	BAGALKOT	110	SIRSI220-SIRSI	SIRSI_110	13:24	14:08	0:44	LINE CLEAR AVAILED
13	5-Mar-19	BAGALKOT	110	SIRSI220-SIRSI	SIRSI_110	15:16	17:45	2:29	LINE CLEAR AVAILED
14	5-Mar-19	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	15:41	17:06	1:25	LINE CLEAR AVAILED
15	5-Mar-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	16:41	17:03	0:22	LINE CLEAR AVAILED
16	5-Mar-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	17:04	18:45	1:41	LINE CLEAR AVAILED
17	5-Mar-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT2	VAJRAMATTI_220	10:37	13:21	2:44	LINE CLEAR AVAILED
18	5-Mar-19	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	14:17	15:34	1:17	LINE CLEAR AVAILED
19	5-Mar-19	BAGALKOT	110	110/11KV, HV1	SATTI_110	12:50	12:57	0:07	TRANSFORMER FAULT
20	5-Mar-19	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	6:15	6:17	0:02	MAIN SUPPLY FAILURE
21	5-Mar-19	BAGALKOT	220	SHARAVATHY1-SIRSI220	SIRSI_220	1:54	14:51	12:57	LINE FAULT
22	5-Mar-19	BAGALKOT	220	SIRISI220-HUBLI	SIRSI_220	8:44	16:52	8:08	LINE FAULT
23	5-Mar-19	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	11:48	13:05	1:17	LINE CLEAR AVAILED
24	5-Mar-19	BAGALKOT	110	110/33KV, HV3	MUDEDEBIHAL_110, NALATAWAD_33, DHAVALAGI_33, TANGADAGI_33	8:16	8:24	0:08	TRANSFORMER FAULT
25	5-Mar-19	BAGALKOT	110	110/11KV, HV2	MUNVALLY_110	0:23	0:31	0:08	TRANSFORMER FAULT
26	5-Mar-19	BAGALKOT	110	110/33KV, HV4	LAKMANAHALLI_110, ALNAVAR_33	10:05	10:16	0:11	HAND TRIPPED
27	5-Mar-19	BAGALKOT	110	CHIKKODI1-RAIBAG	RAIBAG_110	20:40	20:44	0:04	MAIN SUPPLY FAILURE
28	5-Mar-19	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAY NAGAR	MRUTHYUNJAY NAGAR_110	0:00	12:58	12:58	LINE CLEAR AVAILED
29	5-Mar-19	BENGALORE	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	10:48	10:53	0:05	LOAD CHANGE OVER
30	5-Mar-19	BENGALORE	66	AREHALLI - BANASHANKARI	AREHALLI	15:43	15:49	0:06	LOAD CHANGE OVER
31	5-Mar-19	BENGALORE	66	HV2	ISRO LAYOUT	15:48	15:58	0:09	LINE CLEAR AVAILED
32	5-Mar-19	BENGALORE	66	HV2	TELECOM LAYOUT	13:38	13:43	0:04	LINE CLEAR AVAILED
33	5-Mar-19	BENGALORE	66	TK HALLI 220 - MANDYA 1	MANDYA	7:34	7:45	0:10	LINE FAULT
34	5-Mar-19	BENGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, K HONALGERE	7:34	7:45	0:10	LINE FAULT
35	5-Mar-19	BENGALORE	66	HV3	YARANDANAHALLI 220	12:57	15:48	2:51	LINE CLEAR AVAILED
36	5-Mar-19	BENGALORE	66	HV1	ATTUR YELAHANKA	15:15	16:09	0:54	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
37	5-Mar-19	BENGALORE	66	HV2	ATTUR YELAHANKA	16:17	18:11	1:53	LINE CLEAR AVAILED
38	5-Mar-19	BENGALORE	66	HV2	RMV	15:23	15:25	0:02	LINE CLEAR AVAILED
39	5-Mar-19	BENGALORE	66	VR DODDI - SOMANAHALLI 220	VR DODDI	18:30	19:10	0:40	LINE CLEAR AVAILED
40	5-Mar-19	BENGALORE	66	VR DODDI - SOMANAHALLI 220	VR DODDI	11:35	14:00	2:25	LOAD CHANGEOVER
41	5-Mar-19	BENGALORE	66	AKKURMOLE - TK HALLI 220	AKKURMOLE	6:58	7:10	0:11	LINE FAULT
42	5-Mar-19	BENGALORE	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:59	6:10	0:10	LINE FAULT
43	5-Mar-19	BENGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	14:02	14:07	0:05	LINE FAULT
44	5-Mar-19	BENGALORE	66	GANJIGUNTE - CHINTAMANI 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	5:59	6:10	0:10	LINE FAULT
45	5-Mar-19	BENGALORE	66	HV1	KOLAR 220	16:52	16:57	0:04	LINE CLEAR AVAILED
46	5-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:05	5:15	0:10	LINE FAULT
47	5-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 1	JADIGENAHALLI	21:32	21:40	0:08	LINE FAULT
48	5-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A	14:17	14:37	0:19	LOAD CHANGEOVER
49	5-Mar-19	BENGALORE	66	MALUR 220 - MALUR 66	MALUR 66	14:17	14:21	0:03	LOAD CHANGEOVER
50	5-Mar-19	BENGALORE	66	MALUR 220 - MALUR 66	MALUR 66	14:34	14:39	0:04	LINE FAULT
51	5-Mar-19	BENGALORE	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	14:34	14:36	0:01	LOAD CHANGEOVER
52	05-Mar-19	GULBARGA	110	HV2	KAMPLI_110	11:00	11:12	0:12	LINE CLEAR AVAILED
53	05-Mar-19	GULBARGA	110	HV2	KAMPLI_110	14:48	14:58	0:10	LINE CLEAR AVAILED
54	05-Mar-19	GULBARGA	110	HV2	KAMPLI_110	14:37	14:52	0:15	TRANSFORMER FAULT
55	05-Mar-19	GULBARGA	110	HV3	KAMPLI_110	0:00	15:35	15:35	LINE CLEAR AVAILED
56	05-Mar-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	4:23	4:26	0:03	LINE FAULT
57	05-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	12:34	13:09	0:35	LINE CLEAR AVAILED
58	05-Mar-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	1:54	14:53	12:59	LINE FAULT
59	05-Mar-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	3:01	3:07	0:06	LINE FAULT
60	05-Mar-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	14:08	14:13	0:05	LINE FAULT
61	05-Mar-19	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	11:26	12:29	1:03	LINE FAULT
62	05-Mar-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	6:38	6:50	0:12	LINE FAULT
63	5-Mar-19	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	7:35	7:45	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
64	5-Mar-19	MYSORE	66	MANDYA-CHIKKMANDYA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	14:15	14:21	0:06	LINE FAULT
65	5-Mar-19	MYSORE	66	HV2	MYSORESOUTH_66	10:45	11:57	1:12	TRANSFORMER FAULT
66	5-Mar-19	MYSORE	66	HV1	SRIRANGAPATNA_66	16:00	16:10	0:10	TRANSFORMER FAULT
67	5-Mar-19	MYSORE	66	HV1	SRIRANGAPATNA_66	16:15	16:34	0:18	TRANSFORMER FAULT
68	5-Mar-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	6:47	12:48	6:01	LINE FAULT
69	5-Mar-19	MYSORE	66	TUBINAKERE-G UKKADA	DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 PANDAVAPURA_66 ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 BASARALU_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	7:02	7:15	0:13	HAND TRIPPED
70	5-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 PANDAVAPURA_66 ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 BASARALU_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	7:02	7:09	0:07	HAND TRIPPED
71	5-Mar-19	MYSORE	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 GARUDANAUKADDA_66 SRIRANGAPATNA_66 PANDAVAPURA_66 ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 BASARALU_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	7:02	7:16	0:14	HAND TRIPPED
72	5-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 BASARALU_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	18:57	19:08	0:11	LINE FAULT
73	5-Mar-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_22	11:18	14:54	3:35	LINE CLEAR AVAILED
74	5-Mar-19	TUMKUR	110	TR-1	GUBBI_110	19:22	19:27	0:04	TRANSFORMER FAULT
75	5-Mar-19	TUMKUR	110	SHETTIKERE- HANDANKERE	SHETYKERE_110	13:43	14:31	0:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
76	5-Mar-19	TUMKUR	110	TR-1 & TR-2	SHETYKERE_110	13:43	14:34	0:50	LINE CLEAR AVAILED
77	5-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:46	6:53	0:07	LINE FAULT
78	5-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	21:41	21:52	0:11	LINE FAULT
79	5-Mar-19	TUMKUR	66	TR-1	LINGADAHALLY_66	21:11	21:19	0:07	TRANSFORMER FAULT
80	5-Mar-19	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	0:49	1:02	0:12	LINE FAULT
81	5-Mar-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	6:23	6:30	0:07	LINE FAULT
82	6-Mar-19	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	10:03	10:07	0:04	HAND TRIPPED
83	6-Mar-19	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	11:22	11:34	0:12	HAND TRIPPED
84	6-Mar-19	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	7:20	7:32	0:12	LINE FAULT
85	6-Mar-19	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	11:04	11:26	0:22	LINE FAULT
86	6-Mar-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	14:15	14:21	0:06	TRANSFORMER FAULT
87	6-Mar-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	14:56	15:05	0:09	TRANSFORMER FAULT
88	6-Mar-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	18:56	19:05	0:09	TRANSFORMER FAULT
89	6-Mar-19	BAGALKOT	110	BELGAUM- MACHE	BELGAUM_110	2:30	6:31	4:01	LINE CLEAR AVAILED
90	6-Mar-19	BAGALKOT	220	BELGAUM-KANABARGI 1	BELGAUM_220	1:56	12:12	10:16	LINE FAULT
91	6-Mar-19	BAGALKOT	220	BELGAUM-KANABARGI 2	BELGAUM_220	2:23	12:12	9:49	LINE FAULT
92	6-Mar-19	BAGALKOT	110	BELGAUM220-BELGAUM110	BELGAUM_110	1:55	6:46	4:51	LINE FAULT
93	6-Mar-19	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	6:38	16:10	9:32	LINE FAULT
94	6-Mar-19	BAGALKOT	220	220/110KV,HV-2&LV-2	CHIKKODI_220	5:49	5:58	0:09	TRANSFORMER FAULT
95	6-Mar-19	BAGALKOT	110	CHIKKODI-SANKESHAWAR	SANKESHWAR_110	4:40	11:35	6:55	LINE FAULT
96	6-Mar-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA110	GHATAPRABHA_110	11:44	12:10	0:26	LINE FAULT
97	6-Mar-19	BAGALKOT	110	110/11KV,HV-1	HIDIKAL_110	15:29	15:43	0:14	HAND TRIPPED
98	6-Mar-19	BAGALKOT	110	110/11KV,HV-4	HUKKERI_110	5:49	7:36	1:47	TRANSFORMER FAULT
99	6-Mar-19	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	7:00	12:50	5:50	MAIN SUPPLY FAILURE
100	6-Mar-19	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	7:33	15:02	7:29	LINE FAULT
101	6-Mar-19	BAGALKOT	220	NARENDRA-KNBRG 1 (BELGAUM)	NARENDRA_220	2:25	12:12	9:47	LINE FAULT
102	6-Mar-19	BAGALKOT	110	MAHALINGAPUR-TERADAL	TERADAL_110	4:53	12:10	7:17	LINE FAULT
103	6-Mar-19	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	6:10	14:52	8:42	LINE FAULT
104	6-Mar-19	BAGALKOT	110	110/11KV, HV3	ZALKI_110, HORTI_33	4:36	5:05	0:29	TRANSFORMER FAULT
105	6-Mar-19	BAGALKOT	110	SUVARNA SOUDA-MACHE	MACHE_110	5:12	5:48	0:36	LINE FAULT
106	6-Mar-19	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	6:15	17:11	10:56	LINE FAULT
107	6-Mar-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	5:38	12:18	6:40	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
108	6-Mar-19	BAGALKOT	220	220/110KV, HV1, LV1, HV2&LV2	SOUDATTI_220, MUNVALLY_110, YARGATTI_110, SOUDATTI_110, RAMDURGA_110	6:15	12:19	6:04	MAIN SUPPLY FAILURE
109	6-Mar-19	BAGALKOT	110	ENERCON1&2-SOUDATTI	SOUDATTI_110	12:51	13:15	0:24	LINE FAULT
110	6-Mar-19	BAGALKOT	110	ENERCON2-SOUDATTI	SOUDATTI_110	13:16	13:22	0:06	HAND TRIPPED
111	6-Mar-19	BAGALKOT	110	SIRSI220-SIRSI1	SIRSI_110	9:30	11:36	2:06	LINE CLEAR AVAILED
112	6-Mar-19	BAGALKOT	110	SIRSI220-SIRSI2	SIRSI_110	9:32	11:36	2:04	LINE CLEAR AVAILED
113	6-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	9:34	11:35	2:01	LINE CLEAR AVAILED
114	6-Mar-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	9:41	11:32	1:51	LINE CLEAR AVAILED
115	6-Mar-19	BAGALKOT	110	SIRSI220-SIRSI1&2	SIRSI_110	14:25	18:32	4:07	LINE CLEAR AVAILED
116	6-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	14:28	18:23	3:55	LINE CLEAR AVAILED
117	6-Mar-19	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	14:29	18:24	3:55	LINE CLEAR AVAILED
118	6-Mar-19	BAGALKOT	110	110/11KV, HV1	SIRSI_220	9:41	18:34	8:53	LINE CLEAR AVAILED
119	6-Mar-19	BAGALKOT	110	SATTI-RABKAVI	RABKAVI_110	7:17	17:15	9:58	LINE FAULT
120	6-Mar-19	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	13:35	18:33	4:58	LINE FAULT
121	6-Mar-19	BAGALKOT	110	110/33KV, HV3	MUDDEBIHAL_110	7:41	7:47	0:06	TRANSFORMER FAULT
122	6-Mar-19	BAGALKOT	220	SHIRALKOPPA-RANEENNUR	RANEENNUR_220	0:00	14:59	14:59	LINE CLEAR AVAILED
123	6-Mar-19	BAGALKOT	220	SHIRALKOPPA-RANEENNUR	RANEENNUR_220	20:38	23:59	3:21	LINE CLEAR AVAILED
124	6-Mar-19	BAGALKOT	220	220/110KV, HV1, LV1, HV2&LV2	KUDACHI_220, KUDACHI_110, YELLAPARATTI_110, MORAB_110, AINAPUR_110, UGARKHUD_110, TERDAL_110	5:39	5:50	0:11	TRANSFORMER FAULT
125	6-Mar-19	BAGALKOT	220	220/110KV, HV1, LV1, HV2&LV2	KUDACHI_220, KUDACHI_110, YELLAPARATTI_110, MORAB_110, AINAPUR_110, UGARKHUD_110, TERDAL_110	7:21	7:24	0:03	TRANSFORMER FAULT
126	6-Mar-19	BAGALKOT	110	KUDACHI-MORAB	MORAB_110	5:39	8:13	2:34	LINE FAULT
127	6-Mar-19	BAGALKOT	220	220/110KV, HV3&LV3	HUBLI_220	7:19	11:15	3:56	TRANSFORMER FAULT
128	6-Mar-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGHATAGI_110	7:27	7:32	0:05	HAND TRIPPED
129	6-Mar-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGHATAGI_110	8:50	12:23	3:33	LINE CLEAR AVAILED
130	6-Mar-19	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGHATAGI_110	12:26	12:29	0:03	HAND TRIPPED
131	6-Mar-19	BAGALKOT	110	HUBLI220-RAMANKOPPA	RAMANKOPPA_110	7:34	7:39	0:05	HAND TRIPPED
132	6-Mar-19	BAGALKOT	110	HUBLI220-RAMANKOPPA	RAMANKOPPA_110	11:23	11:26	0:03	HAND TRIPPED
133	6-Mar-19	BAGALKOT	110	HUBLI220-KADANKOPPA	KADANKOPPA_110	6:45	12:34	5:49	LINE FAULT
134	6-Mar-19	BAGALKOT	110	CHIKKODI2-RAIBAG	RAIBAG_110	5:14	13:13	7:59	LINE CLEAR AVAILED
135	6-Mar-19	BENGALORE	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	7:32	8:00	0:28	MAIN SUPPLY FAILURE
136	6-Mar-19	BENGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	7:32	7:40	0:08	LOAD CHANGEOVER
137	6-Mar-19	BENGALORE	66	HV1	KHODAYS 220	7:32	7:40	0:08	LOAD CHANGEOVER
138	6-Mar-19	BENGALORE	66	HV2	KHODAYS 220	7:32	7:40	0:08	LOAD CHANGEOVER
139	6-Mar-19	BENGALORE	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	17:52	17:55	0:03	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
140	6-Mar-19	BENGALORE	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	17:52	17:58	0:06	LOAD CHANGEOVER
141	6-Mar-19	BENGALORE	66	HV1	KHODAYS 220	17:52	17:58	0:06	LOAD CHANGEOVER
142	6-Mar-19	BENGALORE	66	HV2	KHODAYS 220	17:52	17:58	0:06	LOAD CHANGEOVER
143	6-Mar-19	BENGALORE	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	7:02	7:17	0:14	LINE FAULT
144	6-Mar-19	BENGALORE	66	RBI - SOMANAHALLI 220	RBI	7:02	7:55	0:52	LINE FAULT
145	6-Mar-19	BENGALORE	66	SOMANAHALLI 220 - JIGANI 1	RBI	7:02	7:55	0:52	LINE FAULT
146	6-Mar-19	BENGALORE	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	17:50	17:55	0:05	LOAD CHANGEOVER
147	6-Mar-19	BENGALORE	66	RBI - ELITE PROMENEDE	RBI	9:20	9:25	0:05	LOAD CHANGEOVER
148	6-Mar-19	BENGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	9:26	15:44	6:18	LINE FAULT
149	6-Mar-19	BENGALORE	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	9:26	9:45	0:18	MAIN SUPPLY FAILURE
150	6-Mar-19	BENGALORE	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	15:55	16:00	0:05	LOAD CHANGEOVER
151	6-Mar-19	BENGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA	6:34	6:45	0:11	LINE FAULT
152	6-Mar-19	BENGALORE	66	SOLDEVANAHALLI - YELAHANKA 220	SOLDEVANAHALLI	15:09	15:21	0:12	LOAD CHANGEOVER
153	6-Mar-19	BENGALORE	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	16:35	16:41	0:06	LOAD CHANGEOVER
154	6-Mar-19	BENGALORE	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT), BANASWADI	13:09	14:26	1:16	LINE FAULT
155	6-Mar-19	BENGALORE	66	HOODY 220 - HAL 2	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT), BANASWADI	13:09	14:26	1:16	LINE FAULT
156	6-Mar-19	BENGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	7:48	7:58	0:09	LINE FAULT
157	6-Mar-19	BENGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	17:13	17:33	0:20	LINE FAULT
158	6-Mar-19	BENGALORE	66	HV2	KIADB DB PURA 220	10:59	11:25	0:25	LINE CLEAR AVAILED
159	6-Mar-19	BENGALORE	66	HV1	DEVANAHALLI	10:30	10:35	0:05	LINE CLEAR AVAILED
160	6-Mar-19	BENGALORE	66	KOLAR 220 - BANGARPET 2	BANGARPET	18:26	18:30	0:03	LINE FAULT
161	6-Mar-19	BENGALORE	66	KOLAR 220 - BANGARPET 2	BANGARPET	16:48	17:05	0:16	LINE FAULT
162	6-Mar-19	BENGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	6:08	6:20	0:12	LINE FAULT
163	6-Mar-19	BENGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	17:20	17:27	0:07	LINE FAULT
164	6-Mar-19	BENGALORE	66	HV1	KEMBODI	12:28	14:10	1:41	LINE CLEAR AVAILED
165	6-Mar-19	BENGALORE	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	14:15	15:08	0:53	LINE CLEAR AVAILED
166	6-Mar-19	BENGALORE	66	KYALANUR - VEMGAL	KYALANUR	7:28	7:47	0:19	LINE FAULT
167	6-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A	18:26	18:31	0:05	LINE FAULT
168	6-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A	18:41	18:46	0:05	LINE CLEAR AVAILED
169	6-Mar-19	BENGALORE	66	YELAHANKA 220 - LINE 6	SOLDEVANAHALLI	4:22	4:36	0:14	LINE FAULT
170	6-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	4:10	4:20	0:10	LINE FAULT
171	6-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	14:13	14:18	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
172	6-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	15:40	15:48	0:08	LINE FAULT
173	6-Mar-19	BENGALORE	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	6:40	6:56	0:16	LINE FAULT
174	6-Mar-19	BENGALORE	66	HAROBEL - KANAKAPURA 220	HAROBEL	14:54	15:27	0:33	LINE FAULT
175	6-Mar-19	BENGALORE	66	HAROBEL - KANAKAPURA 220	HAROBEL	16:16	16:45	0:28	LINE FAULT
176	6-Mar-19	BENGALORE	66	HAROBEL - HUKUNDA	HUKUNDA, KODIHALLI, HUNSENAHALLI,	14:54	15:27	0:33	LINE FAULT
177	6-Mar-19	BENGALORE	66	HAROBEL - HUKUNDA	HUKUNDA, KODIHALLI, HUNSENAHALLI,	16:16	16:45	0:28	LINE FAULT
178	6-Mar-19	BENGALORE	66	HV1	HAROBEL	14:54	15:27	0:33	TRANSFORMER FAULT
179	6-Mar-19	BENGALORE	66	HV1	HAROBEL	16:16	16:45	0:28	TRANSFORMER FAULT
180	6-Mar-19	BENGALORE	66	BAGMANE WORLD TECH PARK - HOODY 1	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT), BANASWADI	13:09	14:30	1:20	LINE FAULT
181	6-Mar-19	GULBARGA	220	LINGAPUR-JINDAL2	LINGAPUR_220	18:14	19:20	1:06	NFBC ISSUED
182	6-Mar-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:31	5:38	0:07	LINE FAULT
183	6-Mar-19	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	2:09	2:15	0:06	LINE FAULT
184	6-Mar-19	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	3:45	3:51	0:06	LINE FAULT
185	6-Mar-19	GULBARGA	110	SHAHAPUR-KBGNL	KBGNL	3:51	4:06	0:15	LINE FAULT
186	6-Mar-19	GULBARGA	110	WADAGERA-RENEWSOLAR	WADAGERA_110	18:30	23:00	4:30	LINE CLEAR AVAILED
187	6-Mar-19	GULBARGA	66	ITTAGI-RNWSLR2_IPP	RNWSLR_IPP	9:47	10:01	0:14	LINE CLEAR AVAILED
188	6-Mar-19	HASSAN	220	KADUR-DABUSET	KADUR_220	9:10	23:59	14:49	LINE CLEAR AVAILED
189	6-Mar-19	HASSAN	220	MRSSH-M-ANTRSNH	MRSMSG_220	16:48	17:47	0:59	LINE FAULT
190	6-Mar-19	HASSAN	220	MRSHM-VARAH13	MRSMSG_220	9:36	11:16	1:40	LINE CLEAR AVAILED
191	6-Mar-19	HASSAN	220	VARAH1-SHMG3	varahi_gen	9:36	11:16	1:40	LINE CLEAR AVAILED
192	6-Mar-19	HASSAN	110	HV1	KADUR_220	10:38	13:06	2:28	LINE CLEAR AVAILED
193	6-Mar-19	HASSAN	110	HV1	KADUR_220	14:16	16:55	2:39	LINE CLEAR AVAILED
194	6-Mar-19	HASSAN	110	HV2	KADUR_220	10:38	13:06	2:28	LINE CLEAR AVAILED
195	6-Mar-19	HASSAN	110	HV2	KADUR_220	14:17	18:55	4:38	LINE CLEAR AVAILED
196	6-Mar-19	HASSAN	110	HV1	KONAJE_110	16:19	16:32	0:13	TRANSFORMER FAULT
197	6-Mar-19	HASSAN	110	HV2	KONAJE_110	14:30	14:49	0:19	HAND TRIPPED
198	6-Mar-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	16:19	16:48	0:29	LINE FAULT
199	6-Mar-19	HASSAN	66	MRSSH-M-BD-2	MRSMSG_220	0:00	9:36	9:36	LINE CLEAR AVAILED
200	6-Mar-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	14:29	16:07	1:38	LINE FAULT
201	6-Mar-19	HASSAN	66	HV2	BELUR_66	15:24	15:33	0:09	TRANSFORMER FAULT
202	6-Mar-19	HASSAN	66	HV2	BELUR_66	18:22	18:32	0:10	TRANSFORMER FAULT
203	6-Mar-19	HASSAN	66	BHADRA-SHMG2	bhadra_gen	0:00	10:49	10:49	LINE CLEAR AVAILED
204	6-Mar-19	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	13:15	13:20	0:05	LINE FAULT
205	6-Mar-19	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	14:40	14:42	0:02	LINE FAULT
206	6-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	13:21	13:22	0:01	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
207	6-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	14:40	14:44	0:04	TRANSFORMER FAULT
208	6-Mar-19	HASSAN	66	HV2	SATHENAHALLY_66	13:16	13:51	0:35	LINE CLEAR AVAILED
209	6-Mar-19	MYSORE	66	GUNDLUPETE-BEGUR	BEGUR_66 SINDHUVALI_66	6:21	6:38	0:16	LINE FAULT
210	6-Mar-19	MYSORE	66	HV1	JAKKANAHALLY_66	2:56	23:59	21:03	TRANSFORMER FAULT
211	6-Mar-19	MYSORE	66	HV1	KADAKOLA_220	10:40	12:11	1:31	LINE CLEAR AVAILED
212	6-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	11:21	11:30	0:08	HAND TRIPPED
213	6-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	11:21	11:30	0:08	HAND TRIPPED
214	6-Mar-19	MYSORE	66	HV1	KIADBMANDYA_66	11:23	11:31	0:08	HAND TRIPPED
215	6-Mar-19	MYSORE	66	HV2	KIADBMANDYA_66	11:23	11:32	0:08	HAND TRIPPED
216	6-Mar-19	MYSORE	66	HV4	KUSHALNAGARA_220	11:25	11:48	0:22	LINE CLEAR AVAILED
217	6-Mar-19	MYSORE	66	HV1	RAMAPURA_MYS_66	2:30	2:42	0:12	TRANSFORMER FAULT
218	6-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:05	11:58	6:52	LINE CLEAR AVAILED
219	6-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	15:42	16:11	0:28	HAND TRIPPED
220	6-Mar-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	12:46	16:06	3:20	LINE CLEAR AVAILED
221	6-Mar-19	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	12:08	12:24	0:15	LOAD CURTAILMENT
222	6-Mar-19	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	11:35	13:32	1:56	LOAD CURTAILMENT
223	6-Mar-19	TUMKUR	110	TR-1	TURUVEKERE_110	7:13	7:28	0:15	MAIN SUPPLY FAILURE
224	6-Mar-19	TUMKUR	110	TURUVEKERE110-KBCROSS	TURUVEKERE_110	7:14	7:29	0:14	MAIN SUPPLY FAILURE
225	6-Mar-19	TUMKUR	66	TR-3( HV SIDE )	CHITRADURGA_220	14:17	16:11	1:54	MAIN SUPPLY FAILURE
226	6-Mar-19	TUMKUR	66	TR-1 & TR-2(LV SIDE)	THALLAKK_220	14:26	16:02	1:35	MAIN SUPPLY FAILURE
227	6-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	11:06	11:35	0:29	LINE FAULT
228	6-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	11:06	12:17	1:10	LINE FAULT
229	6-Mar-19	TUMKUR	66	TR-1	BELADARA_66	11:04	11:35	0:30	LINE CLEAR AVAILED
230	6-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:04	9:09	0:05	HAND TRIPPED
231	6-Mar-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	11:27	11:32	0:04	LINE FAULT
232	6-Mar-19	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	12:47	12:49	0:02	LINE FAULT
233	6-Mar-19	TUMKUR	66	TR-2	HIREGUNTANUR_66	8:10	8:15	0:05	HAND TRIPPED
234	6-Mar-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	5:18	5:29	0:10	LINE FAULT
235	6-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	9:59	10:00	0:01	LINE FAULT
236	6-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:23	18:29	0:06	LINE FAULT
237	6-Mar-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	11:40	11:42	0:02	HAND TRIPPED
238	6-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:09	15:24	0:14	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
239	6-Mar-19	TUMKUR	66	TR-1	LINGADAHALLY_66	21:16	21:28	0:11	TRANSFORMER FAULT
240	6-Mar-19	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	12:00	14:14	2:14	LINE CLEAR AVAILED
241	6-Mar-19	TUMKUR	66	TR-1 & TR-2	PAVAGADA_66	12:00	14:14	2:14	LINE CLEAR AVAILED
242	6-Mar-19	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	15:30	16:59	1:29	LINE CLEAR AVAILED
243	7-Mar-19	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	15:56	16:02	0:06	LINE FAULT
244	7-Mar-19	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	5:33	5:51	0:18	LINE FAULT
245	7-Mar-19	BAGALKOT	110	110/11KV,HV-2	AMBEWADI_220	18:01	18:04	0:03	TRANSFORMER FAULT
246	7-Mar-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	14:59	23:59	9:00	LINE CLEAR AVAILED
247	7-Mar-19	BAGALKOT	220	ATHANI-RAVI URJA 1	ATHANI_220	10:11	19:11	9:00	LINE CLEAR AVAILED
248	7-Mar-19	BAGALKOT	220	ATHANI-RAVI URJA 2	ATHANI_220	10:11	23:59	13:48	LINE CLEAR AVAILED
249	7-Mar-19	BAGALKOT	110	110/11KV,HV-1	BILAGI_110	15:21	15:42	0:21	TRANSFORMER FAULT
250	7-Mar-19	BAGALKOT	110	110/11KV,HV-1	BILAGI_110	16:10	16:25	0:15	TRANSFORMER FAULT
251	7-Mar-19	BAGALKOT	220	BAGEWADI-BIJAPUR 2	BAGEWADI_220	14:12	23:59	9:47	LINE FAULT
252	7-Mar-19	BAGALKOT	220	220/110KV,HV2 & LV-2	BELGAUM_220	14:29	15:29	1:00	LINE CLEAR AVAILED
253	7-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	15:59	21:32	5:33	LINE FAULT
254	7-Mar-19	BAGALKOT	220	HAVERI 220-GUTTUR 1	HAVERI_220	7:32	16:04	8:32	LINE FAULT
255	7-Mar-19	BAGALKOT	220	HAVERI 220-GUTTUR 2	HAVERI_220	12:52	14:36	1:44	LINE CLEAR AVAILED
256	7-Mar-19	BAGALKOT	220	HAVERI 220-BIDNAL(NARENDRA 1)	HAVERI_220	3:59	13:07	9:08	LINE FAULT
257	7-Mar-19	BAGALKOT	220	HAVERI 220-NARENDRA (NARENDRA 2)	HAVERI_220	4:24	11:41	7:17	LINE FAULT
258	7-Mar-19	BAGALKOT	110	HAVERI 220-SAVANUR	SAVANUR_110	5:59	10:00	4:01	LINE FAULT
259	7-Mar-19	BAGALKOT	110	HAVERI 220-HANGAL(TILUVALI)	HANAGAL_110	7:33	14:00	6:27	LINE FAULT
260	7-Mar-19	BAGALKOT	110	INDI-LACHYAN -HIREBEVANUR	HIREBEVANUR_110	7:10	19:10	12:00	LINE CLEAR AVAILED
261	7-Mar-19	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,PALA_33	7:32	14:07	6:35	LINE CLEAR AVAILED
262	7-Mar-19	BAGALKOT	110	110/33KV,HV2	HANAGAL_110,BOMMNAHALLI_33,BELGAL PET_33 ,LAXIMIPURA_33 ,AKKI ALUR_33	7:32	15:45	8:13	LINE CLEAR AVAILED
263	7-Mar-19	BAGALKOT	110	110/11KV,HV2	KADANAKOPPA_110	3:45	13:22	9:37	TRANSFORMER FAULT
264	7-Mar-19	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	4:05	5:30	1:25	MAIN SUPPLY FAILURE
265	7-Mar-19	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	5:30	15:12	9:42	LINE CLEAR AVAILED
266	7-Mar-19	BAGALKOT	110	AMBEWADI -KADANAKOPPA	KADANAKOPPA_110	15:12	23:59	8:47	LINE CLEAR AVAILED
267	7-Mar-19	BAGALKOT	110	HUBLI-KALAGHATAGI	KALAGHATAGI_110	4:56	13:30	8:34	LINE FAULT
268	7-Mar-19	BAGALKOT	220	220/110KV HV1 ,HV2& LV1,LV2	KUDACHI_220,UGAR KHUD_110,KUDACHI_110,AINAPUR_110,M ORAB_110,YELAPARATTI_110,TERDAL_110	15:32	15:40	0:08	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
269	7-Mar-19	BAGALKOT	220	220/110KV HV1 ,HV2& LV1,LV2	KUDACHI_220,UGAR KHUD_110,KUDACHI_110,AINAPUR_110,M ORAB_110,YELAPARATTI_110,TERDAL_110	18:51	19:02	0:11	TRANSFORMER FAULT
270	7-Mar-19	BAGALKOT	220	220/110KV HV1 ,HV2& LV1,LV2	KUDACHI_220,UGAR KHUD_110,KUDACHI_110,AINAPUR_110,M ORAB_110,YELAPARATTI_110,TERDAL_110	20:14	20:30	0:16	TRANSFORMER FAULT
271	7-Mar-19	BAGALKOT	110	KUDACHI 220-AINAPUR	AINAPUR_110	15:37	15:52	0:15	LINE FAULT
272	7-Mar-19	BAGALKOT	110	110/33KV,HV4	LAKKAMANAHALLI_110ALNAVAR_33KV,NI GADI_33KV	12:13	16:23	4:10	TRANSFORMER FAULT
273	7-Mar-19	BAGALKOT	110	110/33,HV2	MATTIHAL_110,WATER SUPPLY_33KV,NTPC_33KV,	16:40	16:51	0:11	TRANSFORMER FAULT
274	7-Mar-19	BAGALKOT	110	MK HUBLI220-MKHUBLI	MKHUBLI_110	4:54	5:58	1:04	LINE FAULT
275	7-Mar-19	BAGALKOT	110	110/11KV,HV3	MUDALAGI_110	16:25	17:00	0:35	LINE CLEAR AVAILED
276	7-Mar-19	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	16:56	18:19	1:23	TRANSFORMER FAULT
277	7-Mar-19	BAGALKOT	220	NAREANDRA220-HAVERI 1	NARENDRA_220	6:13	13:25	7:12	LINE FAULT
278	7-Mar-19	BAGALKOT	220	BIDANL-SOUDATTI	BIDANL_220	6:08	23:12	17:04	LINE FAULT
279	7-Mar-19	BAGALKOT	220	BIDANL-HARTI1	BIDANL_220	6:05	19:55	13:50	LINE FAULT
280	7-Mar-19	BAGALKOT	220	BIDANL-HARTI2	BIDANL_220	17:18	19:56	2:38	LINE CLEAR AVAILED
281	7-Mar-19	BAGALKOT	220	BIDANL-HUBLI 1	BIDANL_220	17:21	22:34	5:13	LINE FAULT
282	7-Mar-19	BAGALKOT	220	BIDANL-HAVERI	BIDANL_220	4:03	13:07	9:04	LINE FAULT
283	7-Mar-19	BAGALKOT	220	BIDANL-NAGJHARI	BIDANL_220	5:47	18:51	13:04	LINE FAULT
284	7-Mar-19	BAGALKOT	220	BIDANL-NARENDRA	BIDANL_220	4:20	13:25	9:05	LINE FAULT
285	7-Mar-19	BAGALKOT	66	HARIHAR HOSPET-BANUVALLY	HARIHAR HOSPET_66	11:35	15:13	3:38	LINE CLEAR AVAILED
286	7-Mar-19	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33	15:57	16:01	0:04	TRANSFORMER FAULT
287	7-Mar-19	BAGALKOT	110	KUDACHI220-YELLAPARHATTI	YELLAPARHATTI_110	16:09	16:17	0:08	HAND TRIPPED
288	7-Mar-19	BAGALKOT	110	110/11KV, HV1	YELLAPARHATTI_110	16:09	16:19	0:10	HAND TRIPPED
289	7-Mar-19	BAGALKOT	110	RANNABELAGALI-UTTUR	UTTUR_110	0:00	17:17	17:17	LINE CLEAR AVAILED
290	7-Mar-19	BAGALKOT	110	UGAR SUGAR-UGARKHUD	UGARKHUD_110	15:35	15:57	0:22	LINE FAULT
291	7-Mar-19	BAGALKOT	110	UGAR SUGAR-UGARKHUD	UGARKHUD_110	18:50	19:45	0:55	LINE FAULT
292	7-Mar-19	BAGALKOT	110	UDYAMBAG-MACHE	MACHE_110	12:30	14:03	1:33	LINE CLEAR AVAILED
293	7-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	5:33	5:55	0:22	LINE FAULT
294	7-Mar-19	BAGALKOT	220	NAGJHARI3-HUBLI	HUBLI_220	13:05	19:06	6:01	LINE FAULT
295	7-Mar-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	16:03	16:11	0:08	HAND TRIPPED
296	7-Mar-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	16:19	20:15	3:56	LINE CLEAR AVAILED
297	7-Mar-19	BAGALKOT	110	SIRSI220-SIRSI	SIRSI_110	6:04	6:30	0:26	HAND TRIPPED
298	7-Mar-19	BAGALKOT	220	SHIRALKOPPA-RANEENNUR	RANEENNUR_220	0:00	7:50	7:50	LINE CLEAR AVAILED
299	7-Mar-19	BAGALKOT	220	SHIRALKOPPA-RANEENNUR	RANEENNUR_220	14:24	15:24	1:00	LINE CLEAR AVAILED
300	7-Mar-19	BAGALKOT	110	GADAG220-SAMBAPUR ROAD	SAMBAPUR ROAD_110	11:51	18:52	7:01	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
301	7-Mar-19	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	15:45	16:22	0:37	TRANSFORMER FAULT
302	7-Mar-19	BENGALORE	66	HEBBAL 220 - LR BANDE	LR BANDE	13:30	14:45	1:15	LINE CLEAR AVAILED
303	7-Mar-19	BENGALORE	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	10:20	10:30	0:10	LOAD CHANGEOVER
304	7-Mar-19	BENGALORE	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	17:07	17:13	0:06	LOAD CHANGEOVER
305	7-Mar-19	BENGALORE	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	22:33	22:44	0:11	LOAD CHANGEOVER
306	7-Mar-19	BENGALORE	66	HV1	SOLDEVANAHALLI	17:57	18:27	0:29	LINE CLEAR AVAILED
307	7-Mar-19	BENGALORE	66	HV2	SOLDEVANAHALLI	16:15	17:32	1:17	LINE CLEAR AVAILED
308	7-Mar-19	BENGALORE	220	HV2	HOODY 220	22:05	23:37	1:32	TRANSFORMER FAULT
309	7-Mar-19	BENGALORE	220	HV3	HOODY 220	22:05	23:37	1:32	TRANSFORMER FAULT
310	7-Mar-19	BENGALORE	66	HOODY 220 - GRAPHITE INDIA(EHT)	GRAPHITE INDIA(EHT)	22:05	23:59	1:54	MAIN SUPPLY FAILURE
311	7-Mar-19	BENGALORE	66	HOODY 220 - HAL 1 & 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	22:05	23:59	1:54	MAIN SUPPLY FAILURE
312	7-Mar-19	BENGALORE	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	22:05	23:59	1:54	MAIN SUPPLY FAILURE
313	7-Mar-19	BENGALORE	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	22:05	23:59	1:54	MAIN SUPPLY FAILURE
314	7-Mar-19	BENGALORE	66	HOODY 220 - ITI	ITI, BANASWADI	22:05	23:59	1:54	MAIN SUPPLY FAILURE
315	7-Mar-19	BENGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	22:05	23:59	1:54	MAIN SUPPLY FAILURE
316	7-Mar-19	BENGALORE	66	HV2	HOODY 220	22:05	23:59	1:54	MAIN SUPPLY FAILURE
317	7-Mar-19	BENGALORE	66	HOODY 220 - HAL 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	11:22	13:55	2:33	LINE CLEAR AVAILED
318	7-Mar-19	BENGALORE	66	CB PURA I/A - DB PURA 1	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	14:17	14:45	0:27	LINE FAULT
319	7-Mar-19	BENGALORE	66	HV1	CB PURA I/A	14:17	15:04	0:47	TRANSFORMER FAULT
320	7-Mar-19	BENGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	9:01	9:13	0:12	LINE FAULT
321	7-Mar-19	BENGALORE	66	DB PURA 220 - CB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	14:17	14:38	0:20	LINE FAULT
322	7-Mar-19	BENGALORE	66	HV1	HAROBEL	13:51	13:55	0:03	LINE CLEAR AVAILED
323	7-Mar-19	BENGALORE	66	HAROBEL - KODIHALLI	HUKUNDA, KODIHALLI, BIJJALAHALLI, HUNSENAHALLI	18:50	18:55	0:05	LINE CLEAR AVAILED
324	7-Mar-19	BENGALORE	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	0:31	1:10	0:39	LINE FAULT
325	7-Mar-19	BENGALORE	66	HV1	VG DODDI	16:02	17:52	1:49	LINE CLEAR AVAILED
326	7-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	21:11	22:13	1:02	MAIN SUPPLY FAILURE
327	7-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	18:48	21:10	2:22	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
328	7-Mar-19	BENGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	18:48	22:12	3:24	MAIN SUPPLY FAILURE
329	7-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:48	21:11	2:23	MAIN SUPPLY FAILURE
330	7-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A	21:11	22:09	0:58	MAIN SUPPLY FAILURE
331	7-Mar-19	BENGALORE	66	MALUR 220 - MALUR 66	MALUR 66	21:11	22:07	0:56	MAIN SUPPLY FAILURE
332	7-Mar-19	BENGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	17:42	18:08	0:26	LINE FAULT
333	7-Mar-19	BENGALORE	220	HV1	MALUR 220	18:48	22:05	3:17	TRANSFORMER FAULT
334	7-Mar-19	BENGALORE	220	HV2	MALUR 220	21:12	22:05	0:53	LOAD CHANGEOVER
335	7-Mar-19	BENGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	17:42	18:08	0:26	MAIN SUPPLY FAILURE
336	7-Mar-19	BENGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:42	18:17	0:35	MAIN SUPPLY FAILURE
337	7-Mar-19	BENGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	17:42	18:08	0:26	MAIN SUPPLY FAILURE
338	7-Mar-19	BENGALORE	220	LV1	MALUR 220	18:48	22:05	3:17	TRANSFORMER FAULT
339	7-Mar-19	BENGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR	7:38	14:17	6:38	LINE CLEAR AVAILED
340	7-Mar-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	15:01	22:53	7:52	LINE FAULT
341	7-Mar-19	HASSAN	220	KADUR-DABUSET	KADUR_220	0:00	17:15	17:15	LINE CLEAR AVAILED
342	7-Mar-19	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	8:58	17:30	8:32	LINE CLEAR AVAILED
343	7-Mar-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	13:22	15:07	1:45	LINE FAULT
344	7-Mar-19	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	14:50	15:22	0:32	LINE FAULT
345	7-Mar-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:57	17:30	8:33	NFBC ISSUED
346	7-Mar-19	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	14:56	15:33	0:37	LINE FAULT
347	7-Mar-19	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:00	18:01	8:01	LOAD CURTAILMENT
348	7-Mar-19	HASSAN	110	HV1	BANAVARA_110	14:24	15:08	0:44	LINE CLEAR AVAILED
349	7-Mar-19	HASSAN	110	HV1	BANAVARA_110	17:05	17:25	0:20	LINE CLEAR AVAILED
350	7-Mar-19	HASSAN	110	BARANG-ANVATTI	BARANGI_110	10:10	16:25	6:15	NFBC ISSUED
351	7-Mar-19	HASSAN	110	HV2	GANDASI_110	13:11	13:19	0:08	LINE CLEAR AVAILED
352	7-Mar-19	HASSAN	110	HV2	KONAJE_110	11:57	14:42	2:45	LINE CLEAR AVAILED
353	7-Mar-19	HASSAN	110	SAGARA-SORABA	SAGARA_110	10:35	13:06	2:31	LINE CLEAR AVAILED
354	7-Mar-19	HASSAN	110	SHRLKP-SGS	SHIRALKOPPA_220	14:56	15:33	0:37	LOAD CURTAILMENT
355	7-Mar-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:07	16:10	6:03	LINE CLEAR AVAILED
356	7-Mar-19	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	15:02	15:41	0:39	LOAD CURTAILMENT
357	7-Mar-19	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	15:02	15:40	0:38	LOAD CURTAILMENT
358	7-Mar-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	15:02	15:42	0:40	LOAD CURTAILMENT
359	7-Mar-19	HASSAN	110	HV2	SORABA_110	0:07	0:57	0:50	TRANSFORMER FAULT
360	7-Mar-19	HASSAN	110	HV2	SORABA_110	14:55	15:50	0:55	LINE CLEAR AVAILED
361	7-Mar-19	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	15:05	15:17	0:12	LINE FAULT
362	7-Mar-19	HASSAN	66	HV2	CHIKMAGALUR_66	14:16	14:30	0:14	TRANSFORMER FAULT
363	7-Mar-19	MYSORE	66	HV1	BOOKANAKERE_66	7:38	11:59	4:20	LINE CLEAR AVAILED
364	7-Mar-19	MYSORE	66	HV2	BOOKANAKERE_66	7:38	23:59	16:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
365	7-Mar-19	MYSORE	66	BOOKANAKERE-PANDAVAPURA	BANANGADI_66 CHINAKURALI_66 GARUDANAUKADDA_66 DODDABYADARAHALLI_66 PANDAVAPURA_66 SRIRANGAPATNA_66	9:41	9:53	0:11	LINE FAULT
366	7-Mar-19	MYSORE	66	CR NAGARA-KOLLEGALA	KOLLEGALA_66	20:49	21:13	0:23	LINE FAULT
367	7-Mar-19	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	20:49	21:12	0:22	LINE FAULT
368	7-Mar-19	MYSORE	66	HV2	DUNDANAHALLI_66	14:45	16:45	2:00	LINE CLEAR AVAILED
369	7-Mar-19	MYSORE	66	HV2	DUNDANAHALLI_66	10:06	16:48	6:41	LINE CLEAR AVAILED
370	7-Mar-19	MYSORE	66	HV1	HANGLA_66	16:45	23:59	7:14	TRANSFORMER FAULT
371	7-Mar-19	MYSORE	66	HONNALLY-CR NAGARA	HONNALLY_MYS_66	18:20	21:50	3:30	LINE FAULT
372	7-Mar-19	MYSORE	66	HONNALLY-ATTAGULIPURA	ATTIGULIPURA_66	18:55	21:59	3:03	LINE CLEAR AVAILED
373	7-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 2	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	9:59	10:07	0:07	LINE FAULT
374	7-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 1	HURA_66, HULLAHALLI_66, DOORA_66	9:59	10:06	0:06	LINE FAULT
375	7-Mar-19	MYSORE	66	K HONNALAGERE-MADDUR	K_HONNALGERE_66	9:54	10:45	0:51	HAND TRIPPED
376	7-Mar-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66, KIADBMANDYA_66 & MADDUR_66 K_HONNALGERE_66	7:38	9:44	2:05	NFBC ISSUED
377	7-Mar-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66, KIADBMANDYA_66 & MADDUR_66 K_HONNALGERE_66	12:31	14:17	1:45	LINE CLEAR AVAILED
378	7-Mar-19	MYSORE	66	HV4	KUSHALNAGARA_220	16:45	17:02	0:17	LINE CLEAR AVAILED
379	7-Mar-19	MYSORE	66	MADDUR-KIADB MANDYA	KIADBMANDYA_66	8:26	10:04	1:38	LINE CLEAR AVAILED
380	7-Mar-19	MYSORE	220	MADHUVANAHALLI-HV1	BGPURA_66 KOLLEGALA_66 PARINAMIPURA_66 SATHEGALA_66 THALAKADU_66 MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66	20:49	21:04	0:15	LINE FAULT
381	7-Mar-19	MYSORE	66	HV1	NANJANAGUDU	10:03	15:09	5:06	LINE CLEAR AVAILED
382	7-Mar-19	MYSORE	66	HV1	PANDAVAPURA_66	10:59	14:16	3:16	LINE CLEAR AVAILED
383	7-Mar-19	MYSORE	66	HV2	PANDAVAPURA_66	16:09	18:03	1:53	LINE CLEAR AVAILED
384	7-Mar-19	MYSORE	66	PANDAVAPURA-TUBINAKERE	DODDABYADARAHALLI_66	15:15	16:12	0:56	LINE CLEAR AVAILED
385	7-Mar-19	MYSORE	66	HV2	SANTHESARAGUR_66	12:03	14:26	2:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
386	7-Mar-19	MYSORE	220	TUBINAKERE-BASTIPURA	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 TARIPURA_66 ARAKERE_66 GAMANAHALLY_66 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66	7:07	20:04	12:57	LINE CLEAR AVAILED
387	7-Mar-19	MYSORE	220	TUBINAKERE-HUYOGANAHALLI	SHIVALLY_66 ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 TARIPURA_66 ARAKERE_66 GAMANAHALLY_66 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66	7:07	19:14	12:07	LINE CLEAR AVAILED
388	7-Mar-19	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	7:24	18:27	11:02	MAIN SUPPLY FAILURE
389	7-Mar-19	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	14:52	15:26	0:34	HAND TRIPPED
390	7-Mar-19	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	14:50	15:26	0:36	LINE FAULT
391	7-Mar-19	TUMKUR	66	TR-1 & TR-2(HV SIDE)	HONNALLI_220	7:25	15:41	8:15	MAIN SUPPLY FAILURE
392	7-Mar-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	7:25	15:39	8:14	MAIN SUPPLY FAILURE
393	7-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	7:25	15:38	8:13	MAIN SUPPLY FAILURE
394	7-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:27	22:39	4:12	MAIN SUPPLY FAILURE
395	7-Mar-19	TUMKUR	66	TR-1 & TR-2( LV SIDE)	HONNALLI_220	7:26	15:29	8:03	MAIN SUPPLY FAILURE
396	7-Mar-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	7:25	15:41	8:15	MAIN SUPPLY FAILURE
397	7-Mar-19	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	15:05	15:23	0:17	HAND TRIPPED
398	7-Mar-19	TUMKUR	66	DASUDI-M/S CLEAN SOLAR	M/S CLEAN SOLAR_66	15:33	15:45	0:11	HAND TRIPPED
399	7-Mar-19	TUMKUR	66	TR-1	HALUVAGALU_66	14:30	14:40	0:10	HAND TRIPPED
400	7-Mar-19	TUMKUR	66	HARIHARA-DAVANGERE_HARIHAR	HARIHAR_66	14:05	14:22	0:17	LINE CLEAR AVAILED
401	7-Mar-19	TUMKUR	66	TR-1 & TR-2	HARIHAR_66	14:05	14:24	0:18	LINE CLEAR AVAILED
402	7-Mar-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	14:50	15:04	0:13	HAND TRIPPED
403	7-Mar-19	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	14:00	14:07	0:07	HAND TRIPPED
404	7-Mar-19	TUMKUR	66	TR-1	TAVAREKERE(C)_66	18:36	18:40	0:03	TRANSFORMER FAULT
405	7-Mar-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	7:23	7:43	0:19	MAIN SUPPLY FAILURE
406	7-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	7:23	7:43	0:19	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
407	7-Mar-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	7:24	7:48	0:24	MAIN SUPPLY FAILURE
408	7-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:23	7:47	0:23	MAIN SUPPLY FAILURE
409	7-Mar-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJHALLI_66	14:18	14:22	0:04	MAIN SUPPLY FAILURE
410	8-Mar-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	11:48	17:05	5:17	LINE CLEAR AVAILED
411	8-Mar-19	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	13:25	13:46	0:21	LINE FAULT
412	8-Mar-19	BAGALKOT	220	ATHANI-RAVI URJA 2	ATHANI_220	0:00	19:46	19:46	LINE CLEAR AVAILED
413	8-Mar-19	BAGALKOT	110	BAGALKOT220-BAGALKOT110	BAGALKOT_110	15:03	15:09	0:06	LINE FAULT
414	8-Mar-19	BAGALKOT	220	GADAG-BAGALKOT 1	GADAG_220	12:29	18:56	6:27	LINE CLEAR AVAILED
415	8-Mar-19	BAGALKOT	220	GADAG-BAGALKOT 2	GADAG_220	12:29	18:57	6:28	LINE CLEAR AVAILED
416	8-Mar-19	BAGALKOT	220	GADAG-HARTHI 1	GADAG_220	12:28	15:49	3:21	LINE CLEAR AVAILED
417	8-Mar-19	BAGALKOT	220	GADAG-HARTHI 2	GADAG_220	12:29	15:50	3:21	LINE CLEAR AVAILED
418	8-Mar-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	12:51	15:11	2:20	LINE CLEAR AVAILED
419	8-Mar-19	BAGALKOT	220	BAGEWADI-BIJAPUR 2	BAGEWADI_220	0:00	12:23	12:23	LINE CLEAR AVAILED
420	8-Mar-19	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	11:36	17:43	6:07	LINE FAULT
421	8-Mar-19	BAGALKOT	110	110/33KV ,HV-3	GOPANAKOPPA_110& KUSUGAL_33	12:37	12:51	0:14	LINE CLEAR AVAILED
422	8-Mar-19	BAGALKOT	110	110/33KV ,HV-1	GOPANAKOPPA_110	13:43	13:53	0:10	LINE CLEAR AVAILED
423	8-Mar-19	BAGALKOT	110	110/33KV,HV3	TILUVALI_110,KALKERE_33KV,GUDDADMALLAPUR_33KV	15:00	17:12	2:12	LINE CLEAR AVAILED
424	8-Mar-19	BAGALKOT	220	VAJRAMATTI220-MAHALINGAPUR2	VAJRAMATTI_220	14:05	14:50	0:45	LINE FAULT
425	8-Mar-19	BAGALKOT	110	HUBLI220-TARIHAL	TARIHAL_110	8:23	13:20	4:57	NFBC ISSUED
426	8-Mar-19	BAGALKOT	220	SIRSI220-HUBLI2	SIRSI_220	14:06	15:17	1:11	LINE FAULT
427	8-Mar-19	BAGALKOT	220	SIRSI220-HUBLI1	SIRSI_220	14:10	15:06	0:56	LINE FAULT
428	8-Mar-19	BAGALKOT	220	SIRSI220-SHARAVATI1	SIRSI_220	14:53	15:39	0:46	LINE CLEAR AVAILED
429	8-Mar-19	BAGALKOT	220	SIRSI220-SHARAVATI2	SIRSI_220	14:53	15:25	0:32	LINE CLEAR AVAILED
430	8-Mar-19	BAGALKOT	110	110/11KV,HV2	SATTI_110	11:19	11:25	0:06	TRANSFORMER FAULT
431	8-Mar-19	BAGALKOT	110	SIRSI220-SIRSI	SIRSI_110	12:11	18:02	5:51	LINE CLEAR AVAILED
432	8-Mar-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	20:10	20:20	0:10	TRANSFORMER FAULT
433	8-Mar-19	BAGALKOT	110	110/11KV,HV3	MUDALGI_110	13:09	13:29	0:20	LINE CLEAR AVAILED
434	8-Mar-19	BAGALKOT	110	220/110KV, LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	16:31	18:53	2:22	LINE CLEAR AVAILED
435	8-Mar-19	BAGALKOT	110	110/33KV, HV4	HIDIKAL_110, ALAGAWADI_33	15:07	15:17	0:10	TRANSFORMER FAULT
436	8-Mar-19	BAGALKOT	110	RAIBAG-ITANAL	RAIBAG_110	18:59	23:59	5:00	LINE CLEAR AVAILED
437	8-Mar-19	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	11:10	13:15	2:05	LINE CLEAR AVAILED
438	8-Mar-19	BENGALORE	66	YELAHANKA 220 - KANASWADI	KANASWADI	8:39	9:37	0:58	LINE FAULT
439	8-Mar-19	BENGALORE	66	HV1	GOWRIBIDANUR 220	6:32	6:47	0:15	TRANSFORMER FAULT
440	8-Mar-19	BENGALORE	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	12:45	13:12	0:27	LINE FAULT
441	8-Mar-19	BENGALORE	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	12:45	13:12	0:27	LINE FAULT
442	8-Mar-19	BENGALORE	220	GOWRIBIDANUR 220 - MADHUGIRI	GOWRIBIDANUR 220	12:45	13:12	0:27	LINE FAULT
443	8-Mar-19	BENGALORE	66	YELAHANKA 220 - LINE8	RAJANKUNTE	17:53	18:11	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
444	8-Mar-19	BENGALORE	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	23:00	23:18	0:18	LOAD CHANGEOVER
445	8-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	19:12	19:46	0:34	MAIN SUPPLY FAILURE
446	8-Mar-19	BENGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	19:40	19:52	0:12	MAIN SUPPLY FAILURE
447	8-Mar-19	BENGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	19:40	19:52	0:12	MAIN SUPPLY FAILURE
448	8-Mar-19	BENGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	7:18	7:48	0:30	LINE FAULT
449	8-Mar-19	BENGALORE	66	KOLAR 220 - NANGALI	KEMBODI	14:57	18:51	3:53	LINE CLEAR AVAILED
450	8-Mar-19	BENGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	14:58	17:02	2:04	LINE CLEAR AVAILED
451	8-Mar-19	BENGALORE	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	14:57	19:04	4:06	LINE CLEAR AVAILED
452	8-Mar-19	BENGALORE	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	12:45	13:12	0:27	MAIN SUPPLY FAILURE
453	8-Mar-19	BENGALORE	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR, BAGEPALLI	12:45	13:12	0:27	MAIN SUPPLY FAILURE
454	8-Mar-19	BENGALORE	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, ACC (EHT)	12:45	13:12	0:27	MAIN SUPPLY FAILURE
455	8-Mar-19	BENGALORE	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	12:45	13:12	0:27	MAIN SUPPLY FAILURE
456	8-Mar-19	BENGALORE	66	D PALYA - GOWRIBIDANUR 220	D PALYA	12:44	13:26	0:41	LINE FAULT
457	8-Mar-19	BENGALORE	66	HV2	DODDABELAVANGALA	22:03	22:17	0:14	TRANSFORMER FAULT
458	8-Mar-19	BENGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	11:07	11:14	0:07	LINE FAULT
459	8-Mar-19	BENGALORE	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	11:07	11:14	0:07	LINE FAULT
460	8-Mar-19	BENGALORE	66	DALASNUR - MALLASANDRA	DALASNUR, YELDUR	13:10	13:21	0:10	LOAD CURTAILMENT
461	8-Mar-19	BENGALORE	66	HV1	AKKURMOLE	18:12	18:17	0:05	TRANSFORMER FAULT
462	8-Mar-19	BENGALORE	66	HV2	BMTC	11:46	12:16	0:29	TRANSFORMER FAULT
463	8-Mar-19	BENGALORE	66	ADUGODI - HAL 2	KC VALLEY, NAL (EHT), KORMANGALA	8:45	8:52	0:07	LINE CLEAR AVAILED
464	8-Mar-19	BENGALORE	66	HANUMANTH NAGAR - YEDUMADU	HANUMANTH NAGAR, MARALWADI, GODUR	23:00	23:14	0:14	LOAD CHANGEOVER
465	8-Mar-19	BENGALORE	66	JAYADEVA - NIMHANS 220	JAYADEVA	8:21	8:33	0:12	LINE FAULT
466	8-Mar-19	BENGALORE	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODI	13:53	14:56	1:02	LINE CLEAR AVAILED
467	8-Mar-19	BENGALORE	66	HV1	MEI LAYOUT	14:00	17:08	3:07	LINE CLEAR AVAILED
468	8-Mar-19	BENGALORE	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	18:01	18:18	0:16	LOAD CURTAILMENT
469	8-Mar-19	BENGALORE	66	NRS 220 - VIJAYANAGAR 1	VIJAYANAGAR	20:54	21:23	0:28	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
470	8-Mar-19	BENGALORE	66	SUBRAMANYAPURA 220 - SOMANAHALLI 1	ISKON	18:28	18:35	0:06	LOAD CHANGEOVER
471	8-Mar-19	BENGALORE	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	10:50	10:56	0:06	LOAD CHANGEOVER
472	8-Mar-19	BENGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	18:35	18:42	0:07	LOAD CHANGEOVER
473	8-Mar-19	BENGALORE	66	HV1	VIJAYANAGAR	20:54	21:23	0:29	TRANSFORMER FAULT
474	8-Mar-19	BENGALORE	66	HV2	YERANDANAHALLI 220	20:15	20:25	0:10	TRANSFORMER FAULT
475	8-Mar-19	BENGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:58	17:05	0:07	LINE FAULT
476	8-Mar-19	BENGALORE	220	HSR LAYOUT 220 -EPIP	EPIP 220	17:55	18:23	0:28	LINE FAULT
477	8-Mar-19	BENGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	2:24	2:55	0:30	LOAD CHANGEOVER
478	8-Mar-19	BENGALORE	66	HOODY 220 - HP (EHT)	HP (EHT)	9:53	10:02	0:09	LOAD CHANGEOVER
479	8-Mar-19	BENGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	19:31	20:36	1:05	LOAD CHANGEOVER
480	8-Mar-19	BENGALORE	66	HV2	HOODY 220	2:24	2:53	0:29	LOAD CHANGEOVER
481	8-Mar-19	BENGALORE	66	HV2	HOODY 220	19:36	20:35	0:59	LOAD CHANGEOVER
482	8-Mar-19	BENGALORE	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK, NGEF, NGEF (EHT)	20:28	20:30	0:02	LOAD CHANGEOVER
483	8-Mar-19	BENGALORE	66	EPIP 220 - HOODY	HOODY 220	18:23	18:30	0:07	LOAD CHANGEOVER
484	8-Mar-19	BENGALORE	66	HOODY-BMRCL	BMRCL	0:36	3:13	2:36	LOAD CHANGEOVER
485	8-Mar-19	BENGALORE	66	HOODY-EPIP2	HOODY 220	2:35	2:55	0:20	LOAD CHANGEOVER
486	8-Mar-19	BENGALORE	66	EPIP 220 - GEITOR (EHT)	GEITOR(EHT)	18:27	18:30	0:03	MAIN SUPPLY FAILURE
487	8-Mar-19	GULBARGA	110	HV1	KOLHAR_110	11:50	12:00	0:10	LINE CLEAR AVAILED
488	8-Mar-19	GULBARGA	110	HV1	KOLHAR	14:45	17:52	3:07	LINE CLEAR AVAILED
489	8-Mar-19	GULBARGA	110	HV2	KOLHAR _110	19:05	19:50	0:45	LINE CLEAR AVAILED
490	8-Mar-19	GULBARGA	110	KOGALI-ATRSOLAR_IPP	ATRSOLAR_IPP	11:30	16:50	5:20	LINE CLEAR AVAILED
491	8-Mar-19	GULBARGA	110	HV1	PD HALLI_110	7:50	8:10	0:20	HAND TRIPPED
492	8-Mar-19	GULBARGA	110	HV1	SREERAMNAGAR_110	11:17	12:59	1:42	TRANSFORMER FAULT
493	8-Mar-19	GULBARGA	66	HV1 & HV2	ITTAGI	10:30	16:20	5:50	LINE CLEAR AVAILED
494	8-Mar-19	GULBARGA	66	ITTAGI-HUVINAHADAGALLI	HUVINAHADAGALLI	10:20	17:17	6:57	LINE CLEAR AVAILED
495	8-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	18:55	19:20	0:25	HAND TRIPPED
496	8-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	17:30	18:50	1:20	LINE CLEAR AVAILED
497	8-Mar-19	HASSAN	400	TAQLGU-NELAMANGALA#2	TALAGUPPA_400	4:16	9:12	4:56	LINE FAULT
498	8-Mar-19	HASSAN	400	TAQLGU-NELAMANGALA#2	TALAGUPPA_400	16:40	23:59	7:19	LINE FAULT
499	8-Mar-19	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	14:12	15:54	1:42	LINE FAULT
500	8-Mar-19	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	14:12	15:24	1:12	LINE FAULT
501	8-Mar-19	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	8:56	17:00	8:04	LINE CLEAR AVAILED
502	8-Mar-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	15:53	18:59	3:06	LINE CLEAR AVAILED
503	8-Mar-19	HASSAN	110	HV1	HOSANGADI_110	15:10	15:59	0:49	LINE CLEAR AVAILED
504	8-Mar-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:25	13:43	3:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
505	8-Mar-19	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	18:13	18:36	0:23	LINE CLEAR AVAILED
506	8-Mar-19	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	9:15	18:47	9:32	LINE CLEAR AVAILED
507	8-Mar-19	HASSAN	66	HASSN22-CHIKAMAGLUR2	HASSAN_220	9:15	18:50	9:35	LINE CLEAR AVAILED
508	8-Mar-19	HASSAN	66	HV2	BELUR_66	19:19	19:27	0:08	TRANSFORMER FAULT
509	8-Mar-19	HASSAN	66	HASSAN	GANGUR_66	12:15	14:55	2:40	LOAD CURTAILMENT
510	8-Mar-19	HASSAN	66	HV1	GANGUR_66	12:15	14:55	2:40	LOAD CURTAILMENT
511	8-Mar-19	HASSAN	66	GORUR-ARAKALGUD	GORUR_66	11:43	18:46	7:03	LINE CLEAR AVAILED
512	8-Mar-19	HASSAN	66	GORUR-HASSAN	GORUR_66	11:43	18:42	6:59	LINE CLEAR AVAILED
513	8-Mar-19	HASSAN	66	HV1	GORUR_66	11:43	18:42	6:59	LINE CLEAR AVAILED
514	8-Mar-19	HASSAN	66	HV2	MATTNIVILE_66	9:55	11:40	1:45	LINE CLEAR AVAILED
515	8-Mar-19	HASSAN	66	HV1	MATTNIVILE_66	8:45	11:00	2:15	LINE CLEAR AVAILED
516	8-Mar-19	MYSORE	66	HV2	BASARALU_66	13:59	14:06	0:06	HAND TRIPPED
517	8-Mar-19	MYSORE	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66	15:43	23:59	8:15	LINE CLEAR AVAILED
518	8-Mar-19	MYSORE	66	HOOTAGALLI-ELAVALA	ELAVALA_66 GAVADAGERE_66	12:40	12:48	0:07	LINE FAULT
519	8-Mar-19	MYSORE	66	HUNSUR-HOOTAGALLI	HUNSUR_66 HOSURGATE_66 BANNIKUPPE_66 HANAGODU_66	12:36	12:54	0:18	LINE FAULT
520	8-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	16:57	17:06	0:09	HAND TRIPPED
521	8-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	16:57	17:06	0:09	HAND TRIPPED
522	8-Mar-19	MYSORE	66	HV1	KIADBMANDYA_66	16:55	17:04	0:09	TRANSFORMER FAULT
523	8-Mar-19	MYSORE	66	HV2	KIADBMANDYA_66	16:55	17:04	0:09	HAND TRIPPED
524	8-Mar-19	MYSORE	66	HV1	MADHUVANAHALLI_220	9:10	9:15	0:05	TRANSFORMER FAULT
525	8-Mar-19	MYSORE	66	MYSORE SOUTH-KADAKOLA	MYSORESOUTH_66	17:03	18:23	1:20	LINE CLEAR AVAILED
526	8-Mar-19	MYSORE	66	HV1	NANJANGUDU_66	12:28	12:34	0:06	TRANSFORMER FAULT
527	8-Mar-19	MYSORE	66	HV1	PGPALYA_66	16:11	16:35	0:24	LINE CLEAR AVAILED
528	8-Mar-19	MYSORE	66	HV1	RAMAPURA_MYS_66	12:08	13:30	1:21	LINE CLEAR AVAILED
529	8-Mar-19	MYSORE	66	HV2	RAMAPURA_MYS_66	13:10	14:00	0:50	LINE CLEAR AVAILED
530	8-Mar-19	MYSORE	66	HV1	RAMAPURA_MYS_66	15:58	16:30	0:31	TRANSFORMER FAULT
531	8-Mar-19	MYSORE	66	HV2	SALIGRAMA_66	16:58	17:07	0:08	TRANSFORMER FAULT
532	8-Mar-19	MYSORE	66	HV1	SANTHESARAGUR_66	12:55	13:04	0:09	TRANSFORMER FAULT
533	8-Mar-19	MYSORE	66	SHANIVARASANTHE-MALLIPATNA	SANIVARASANTHE_66	9:15	18:45	9:30	LINE CLEAR AVAILED
534	8-Mar-19	MYSORE	66	SHANIVARASANTHE-YESSLUR	SANIVARASANTHE_66	10:10	18:45	8:35	LINE CLEAR AVAILED
535	8-Mar-19	MYSORE	66	HV2	SFCSHIVA_66	12:09	23:59	11:49	LINE CLEAR AVAILED
536	8-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	10:30	12:25	1:55	LINE CLEAR AVAILED
537	8-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	19:10	22:03	2:53	LINE CLEAR AVAILED
538	8-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADICHUNCHANAGIRI_66, ADDIHALLI_66, BGNAGARA_66, BASARALU_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	0:33	0:46	0:12	LINE FAULT
539	8-Mar-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:57	15:14	3:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
540	8-Mar-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_22	12:11	16:26	4:15	LINE CLEAR AVAILED
541	8-Mar-19	TUMKUR	220	TR-2	DAVANGERE_SRS_220	11:55	12:40	0:45	LINE CLEAR AVAILED
542	8-Mar-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:57	15:15	3:18	LINE FAULT
543	8-Mar-19	TUMKUR	110	HONNAVALI 110- KADUR220	HONNAVALI_110	11:43	17:02	5:18	LINE CLEAR AVAILED
544	8-Mar-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	22:04	22:14	0:10	LINE FAULT
545	8-Mar-19	TUMKUR	110	TR-3( HV SIDE )	GUBBI_110	12:03	12:21	0:17	LINE CLEAR AVAILED
546	8-Mar-19	TUMKUR	110	TR-3( HV SIDE )	GUBBI_110	14:42	15:20	0:38	LINE CLEAR AVAILED
547	8-Mar-19	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	10:13	13:18	3:05	LINE CLEAR AVAILED
548	8-Mar-19	TUMKUR	66	TR-2	BRAHMASANDRA_66	22:03	22:13	0:09	TRANSFORMER FAULT
549	8-Mar-19	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHILI)	CHANNAGIRI_66	11:48	11:53	0:04	MAIN SUPPLY FAILURE
550	8-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	23:18	23:23	0:04	TRANSFORMER FAULT
551	8-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	2:58	3:05	0:07	LINE FAULT
552	8-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:50	13:59	0:09	LINE FAULT
553	8-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:09	15:20	0:11	LINE FAULT
554	8-Mar-19	TUMKUR	66	TR-1	KUNIGAL_66	16:48	16:55	0:07	TRANSFORMER FAULT
555	8-Mar-19	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	5:51	5:58	0:06	LINE FAULT
556	8-Mar-19	TUMKUR	66	MADHUGIRI 220kV- SIRA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	15:28	15:32	0:04	LINE CLEAR AVAILED
557	8-Mar-19	TUMKUR	66	TR-1	KADEHALLI_110	12:12	13:26	1:14	LINE CLEAR AVAILED
558	8-Mar-19	TUMKUR	66	TR-2	KADEHALLI_110	13:26	13:59	0:33	LINE CLEAR AVAILED
559	8-Mar-19	TUMKUR	66	TR-1	KBCROSS_220	13:38	15:05	1:27	LINE CLEAR AVAILED
560	9-Mar-19	BAGALKOT	110	110/33KV,HV1	BAILHONGAL_110,NEGINHAL_33,MURGOD_33	8:50	9:30	0:40	LINE CLEAR AVAILED
561	9-Mar-19	BAGALKOT	220	ADPH 2-BAGEWADI	BAGEWADI_220	10:30	12:56	2:26	LINE CLEAR AVAILED
562	9-Mar-19	BAGALKOT	220	BAGEWADI-BIJAPUR 1&2	BAGEWADI_220	10:25	11:41	1:16	LINE CLEAR AVAILED
563	9-Mar-19	BAGALKOT	220	BAGEAWADI-ATRIA 1	BAGEWADI_220	10:25	12:48	2:23	LINE CLEAR AVAILED
564	9-Mar-19	BAGALKOT	220	BAGEAWADI-FORFIVE 1&2	BAGEWADI_220	10:25	13:41	3:16	LINE CLEAR AVAILED
565	9-Mar-19	BAGALKOT	220	BAGEAWADI-RBRK	BAGEWADI_220	10:25	15:28	5:03	LINE CLEAR AVAILED
566	9-Mar-19	BAGALKOT	110	BAGEWADI-RAMPUR	NIDAGUNDI_110	10:25	11:46	1:21	LINE CLEAR AVAILED
567	9-Mar-19	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	10:25	12:01	1:36	LINE CLEAR AVAILED
568	9-Mar-19	BAGALKOT	110	BAGEWADI-ACHANUR	MUDEBIHAL_110	10:25	12:17	1:52	LINE CLEAR AVAILED
569	9-Mar-19	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	19:23	23:59	4:36	LINE FAULT
570	9-Mar-19	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	9:49	16:04	6:15	LINE CLEAR AVAILED
571	9-Mar-19	BAGALKOT	110	110/33KV,HV-2	BELGAUM-110	19:01	23:59	4:58	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
572	9-Mar-19	BAGALKOT	110	110/33KV,HV-2	BELGAUM-110	0:00	20:38	20:38	LINE CLEAR AVAILED
573	9-Mar-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	19:22	19:26	0:04	TRANSFORMER FAULT
574	9-Mar-19	BAGALKOT	110	110/33KV,HV3	TILUVALI_110,KALKERE_33KV,GUDDADMALLAPUR_33KV	15:37	18:00	2:23	LINE CLEAR AVAILED
575	9-Mar-19	BAGALKOT	110	110/33KV,HV3	MUDDEBIHAL_110, TANGADAGI_33, DHAVALGI_33	7:28	7:42	0:14	TRANSFORMER FAULT
576	9-Mar-19	BAGALKOT	110	BELGAUM SOLAR-MAMDAPUR(B)	MAMDAPUR(B)_110	12:05	12:08	0:03	LINE FAULT
577	9-Mar-19	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	7:13	15:43	8:30	LINE FAULT
578	9-Mar-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	7:17	15:51	8:34	LINE FAULT
579	9-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	0:14	0:24	0:10	LINE FAULT
580	9-Mar-19	BENGALORE	66	HV1	GOWRIBIDANUR 220	17:10	17:20	0:10	TRANSFORMER FAULT
581	9-Mar-19	BENGALORE	66	YEDUMADU - HANUMANTHNAGAR	LOAD CHANGEOVER	7:05	7:22	0:17	LOAD CHANGEOVER
582	9-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	5:43	5:52	0:09	LINE FAULT
583	9-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	5:56	6:06	0:10	LINE FAULT
584	9-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:43	18:52	0:09	LINE FAULT
585	9-Mar-19	BENGALORE	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	19:00	19:12	0:12	LINE FAULT
586	9-Mar-19	BENGALORE	66	HV2	JANGAMKOTE	18:00	18:20	0:20	TRANSFORMER FAULT
587	9-Mar-19	BENGALORE	66	HV1	KIADB DB PURA 220	11:12	12:12	1:00	TRANSFORMER FAULT
588	9-Mar-19	BENGALORE	66	BAGHMANE WTP - HAL 2	NGEF, NGEF (EHT)	12:27	14:57	2:29	LINE CLEAR AVAILED
589	9-Mar-19	BENGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:40	17:51	0:11	LINE FAULT
590	9-Mar-19	BENGALORE	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA, SAHAKARI NAGAR	17:03	18:10	1:07	LINE CLEAR AVAILED
591	9-Mar-19	BENGALORE	66	HV2	YERANDANAHALLI 220	6:02	6:34	0:32	TRANSFORMER FAULT
592	9-Mar-19	BENGALORE	66	NRS 220 - VIJAYANAGAR 1	VIJAYANAGAR	13:06	13:10	0:04	LINE FAULT
593	9-Mar-19	BENGALORE	66	HANUMANTHNAGAR - SOMANAHALLI 22	HANUMANTHNAGAR	7:05	7:20	0:15	LOAD CHANGEOVER
594	9-Mar-19	BENGALORE	66	ABBIGERE - DG 3	ABBIGERE	15:23	15:28	0:04	LOAD CHANGEOVER
595	9-Mar-19	BENGALORE	66	ABBIGERE - WELCAST	ABBIGERE	17:04	17:17	0:13	LOAD CHANGEOVER
596	9-Mar-19	BENGALORE	66	GOWRIBIDANUR 220 - DB PURA 1	THONDEBHAVI	14:45	16:50	2:05	LINE FAULT
597	9-Mar-19	BENGALORE	220	EPIP-HOODY	HOODY 220	2:51	2:52	0:01	LOAD CHANGEOVER
598	9-Mar-19	BENGALORE	66	HOODY 220 - GRAPHITE INDIA(EHT)	GRAPHITE INDIA(EHT)	0:00	1:50	1:50	MAIN SUPPLY FAILURE
599	9-Mar-19	BENGALORE	66	HOODY 220 - HAL 1 & 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	0:00	2:05	2:05	MAIN SUPPLY FAILURE
600	9-Mar-19	BENGALORE	66	HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	0:00	1:50	1:50	MAIN SUPPLY FAILURE
601	9-Mar-19	BENGALORE	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	0:00	1:50	1:50	MAIN SUPPLY FAILURE
602	9-Mar-19	BENGALORE	66	HOODY 220 - ITI	ITI, BANASWADI	0:00	1:50	1:50	MAIN SUPPLY FAILURE
603	9-Mar-19	BENGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	0:00	1:50	1:50	MAIN SUPPLY FAILURE
604	9-Mar-19	BENGALORE	66	HV2	HOODY 220	0:00	1:50	1:50	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
605	9-Mar-19	GULBARGA	220	KAPNOOR-HUMNABAD1	MAHAGOAN AND MARGUTTI_110	6:02	6:11	0:09	LINE FAULT
606	9-Mar-19	GULBARGA	220	KUSTAGI-SUZLONWIND1	SUZLONWIND1_IPP	18:09	18:36	0:27	LINE FAULT
607	9-Mar-19	GULBARGA	220	RTPS-SHAHAPUR220	SHAHPUR_220	22:10	22:40	0:30	LINE FAULT
608	9-Mar-19	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110	6:30	6:50	0:20	LINE FAULT
609	9-Mar-19	GULBARGA	66	ITTAGGI-HUVINAHADAGALI	HUVINAHADAGALI_66	12:55	13:03	0:08	LINE FAULT
610	9-Mar-19	GULBARGA	66	ITTAGGI-HUVINAHADAGALI	HUVINAHADAGALI_66	18:47	18:53	0:06	HAND TRIPPED
611	9-Mar-19	GULBARGA	66	JANAWADA-SANTAPUR	SANTAPUR_110	18:45	19:00	0:15	LINE FAULT
612	9-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	11:10	17:40	6:30	LINE CLEAR AVAILED
613	9-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	17:55	19:30	1:35	LINE CLEAR AVAILED
614	9-Mar-19	HASSAN	400	TAQLGU-NELAMANGALA#2	TALAGUPPA_400	0:00	17:04	17:04	LINE FAULT
615	9-Mar-19	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	19:43	23:57	4:14	LINE FAULT
616	9-Mar-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	9:05	9:27	0:22	LINE FAULT
617	9-Mar-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	12:12	12:32	0:20	LINE FAULT
618	9-Mar-19	HASSAN	66	HV1	DODDAKADANUR_66	13:09	13:19	0:10	TRANSFORMER FAULT
619	9-Mar-19	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	5:17	5:23	0:06	LINE FAULT
620	9-Mar-19	HASSAN	66	HV2	HNPURA_66	5:27	5:32	0:05	LOAD CURTAILMENT
621	9-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	6:55	7:30	0:35	HAND TRIPPED
622	9-Mar-19	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	6:20	6:23	0:03	LINE FAULT
623	9-Mar-19	MYSORE	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66 SUTTUR_66	6:00	6:10	0:10	LINE FAULT
624	9-Mar-19	MYSORE	66	HV1	JAKKANAHALLY_66	6:57	7:01	0:04	TRANSFORMER FAULT
625	9-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	22:05	23:59	1:54	LINE CLEAR AVAILED
626	9-Mar-19	MYSORE	66	PGL	SFCSHIVA_66	7:59	8:05	0:05	LINE FAULT
627	9-Mar-19	MYSORE	66	HV3	SFCSHIVA_66	22:20	22:40	0:20	HAND TRIPPED
628	9-Mar-19	MYSORE	66	HV4	SFCSHIVA_66	22:20	22:40	0:20	HAND TRIPPED
629	9-Mar-19	MYSORE	66	VAJAMANGALA-MEGHALAPURA	CHIDRAVALLI_66, THUMLA_66 MEGALAPURA_66	7:52	8:11	0:18	HAND TRIPPED
630	9-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:13	11:52	6:39	LINE CLEAR AVAILED
631	9-Mar-19	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	13:44	16:19	2:34	LINE FAULT
632	9-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:13	11:51	6:37	LINE CLEAR AVAILED
633	9-Mar-19	TUMKUR	110	TR-3( HV SIDE )	GUBBI_110	21:15	21:18	0:02	TRANSFORMER FAULT
634	9-Mar-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	6:50	7:08	0:17	LINE FAULT
635	9-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:30	9:44	0:13	LINE FAULT
636	9-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	21:13	21:23	0:10	LINE FAULT
637	9-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:01	12:10	0:08	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
638	9-Mar-19	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:08	18:10	0:01	MAIN SUPPLY FAILURE
639	9-Mar-19	TUMKUR	66	TR-2	KUKKAWADA_66	18:08	18:10	0:01	MAIN SUPPLY FAILURE
640	9-Mar-19	TUMKUR	66	TR-1 & TR-2	NAGASAMUDRA_66	7:52	7:57	0:05	TRANSFORMER FAULT
641	9-Mar-19	TUMKUR	66	TR-1	GUBBI_110	21:15	21:18	0:02	TRANSFORMER FAULT
642	10-Mar-19	BAGALKOT	220	220/110KV,HV&LV-2	BELGAUM_220	9:23	16:32	7:09	LINE CLEAR AVAILED
643	10-Mar-19	BAGALKOT	110	220/110KV,LV-2	BELGAUM_220	18:05	19:10	1:05	LINE CLEAR AVAILED
644	10-Mar-19	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	0:00	17:15	17:15	LINE CLEAR AVAILED
645	10-Mar-19	BAGALKOT	110	GHATAPRABHA-IDLE	HIDIKA DAM_110	10:07	10:35	0:28	LINE FAULT
646	10-Mar-19	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA	GHATAPRABHA_110	10:07	10:15	0:08	LINE FAULT
647	10-Mar-19	BAGALKOT	110	110/11KV,HV-4	GHATAPRABHA_110	15:51	15:57	0:06	TRANSFORMER FAULT
648	10-Mar-19	BAGALKOT	110	GHATAPRABHA-PG HUNASYAL	PG HUNASYAL_110	13:39	13:59	0:20	LINE FAULT
649	10-Mar-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110	6:06	6:08	0:02	TRANSFORMER FAULT
650	10-Mar-19	BAGALKOT	110	110/11KV,HV1	SATTI_110	6:16	6:22	0:06	TRANSFORMER FAULT
651	10-Mar-19	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	11:11	11:41	0:30	LINE CLEAR AVAILED
652	10-Mar-19	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	21:45	23:59	2:14	TRANSFORMER FAULT
653	10-Mar-19	BAGALKOT	110	110/11KV,HV2	RANNABELAGALI_110	14:16	15:19	1:03	LINE CLEAR AVAILED
654	10-Mar-19	BAGALKOT	110	PH HUNSYAL-NAGNUR	NAGNUR_110	6:44	6:57	0:13	LINE FAULT
655	10-Mar-19	BAGALKOT	110	110/33KV,HV3	MUDDEBIHAL_110, TANGADAGI_33, DHAVALGI_33	8:23	8:41	0:18	TRANSFORMER FAULT
656	10-Mar-19	BAGALKOT	110	GAMESHA-KULIGOD	KULIGOD_110	6:45	7:00	0:15	MAIN SUPPLY FAILURE
657	10-Mar-19	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	19:05	19:29	0:24	LINE CLEAR AVAILED
658	10-Mar-19	BENGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	15:45	15:52	0:07	LINE FAULT
659	10-Mar-19	BENGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	8:14	8:20	0:06	LINE CLEAR AVAILED
660	10-Mar-19	BENGALORE	220	GOWRIBIDANUR 220 - DB PURA	KIADB DB PURA 220	18:22	20:03	1:41	LINE FAULT
661	10-Mar-19	BENGALORE	66	KIADB DB PURA 220 - APAREL PARK	KIADB DB PURA 220	21:29	21:47	0:18	LOAD CHANGEOVER
662	10-Mar-19	BENGALORE	66	GOWRIBIDANUR 220 - AFTL (EHT)	AFTL (EHT)	18:22	18:55	0:33	LINE FAULT
663	10-Mar-19	BENGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	21:57	22:05	0:08	LINE FAULT
664	10-Mar-19	BENGALORE	66	KOLAR 220 - DALASNUR	MALLASANDRA, DRDO (EHT), DAALSNUR	9:50	9:54	0:04	LINE FAULT
665	10-Mar-19	BENGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	3:10	3:18	0:08	LINE FAULT
666	10-Mar-19	BENGALORE	66	KIADB DB PURA 220 - APAREL PARK	APAREL PARK	18:22	19:58	1:36	MAIN SUPPLY FAILURE
667	10-Mar-19	BENGALORE	66	HV1	KIADB DB PURA 220	18:22	20:09	1:47	MAIN SUPPLY FAILURE
668	10-Mar-19	BENGALORE	66	HV2	KIADB DB PURA 220	18:22	20:09	1:47	MAIN SUPPLY FAILURE
669	10-Mar-19	BENGALORE	66	HV1	KIADB DB PURA 220	21:29	21:42	0:13	MAIN SUPPLY FAILURE
670	10-Mar-19	BENGALORE	66	HV2	KIADB DB PURA 220	21:29	21:42	0:13	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
671	10-Mar-19	BENGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	10:02	10:07	0:05	LINE FAULT
672	10-Mar-19	BENGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	13:17	13:22	0:04	LINE FAULT
673	10-Mar-19	BENGALORE	66	ADUGODI - HAL 2	KORMANGALA, K & C VALLEY	13:00	13:21	0:20	LINE FAULT
674	10-Mar-19	BENGALORE	66	HV1	IISC	17:00	17:15	0:15	TRANSFORMER FAULT
675	10-Mar-19	GULBARGA	220	SINDHANOOR220-MUNIRABAD2	BTPS WATER,MUKUNDA_110,KAMPLI_110	13:07	13:24	0:17	LINE FAULT
676	10-Mar-19	GULBARGA	110	LINGASUGUR-GURGUNTA	GURGUNTA_110	22:10	22:30	0:20	LINE FAULT
677	10-Mar-19	HASSAN	220	GESOPA-TALGUPA2	gerusoppa_gen	11:50	17:11	5:21	NFBC ISSUED
678	10-Mar-19	HASSAN	220	KADUR-DABUSET	KADUR_220	12:05	17:19	5:14	LINE CLEAR AVAILED
679	10-Mar-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:50	17:11	5:21	LINE CLEAR AVAILED
680	10-Mar-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	7:55	18:47	10:52	NFBC ISSUED
681	10-Mar-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	7:55	18:46	10:51	NFBC ISSUED
682	10-Mar-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	12:52	13:00	0:08	LINE FAULT
683	10-Mar-19	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	13:00	14:30	1:30	LINE FAULT
684	10-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	8:19	8:24	0:05	TRANSFORMER FAULT
685	10-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	8:30	8:40	0:10	TRANSFORMER FAULT
686	10-Mar-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:54	18:43	10:49	LINE CLEAR AVAILED
687	10-Mar-19	HASSAN	66	MRSSHM-DVG2	MRSMG_220	12:04	12:33	0:29	LINE FAULT
688	10-Mar-19	MYSORE	66	HV1	BGNAGARA_66	15:25	16:05	0:40	LINE CLEAR AVAILED
689	10-Mar-19	MYSORE	66	HV2	BILIKERE_66	11:26	23:59	12:32	LINE CLEAR AVAILED
690	10-Mar-19	MYSORE	220	HV1	CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 KUNTHUR_66 SATHEGALA_66 YELANDUR_66 , CHIDRAVALLI_66 THAYURU_66 TNARASIPURA_66 THUMLA_66 BHARGI_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 SINDHUVALLI_66	13:17	13:56	0:38	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
691	10-Mar-19	MYSORE	220	HV2	CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 KUNTHUR_66 SATHEGALA_66 YELANDUR_66 , CHIDRAVALLI_66 THAYURU_66 TNARASIPURA_66 THUMLA_66 BHARGI_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 SINDHUVALLI_66	13:17	13:56	0:38	TRANSFORMER FAULT
692	10-Mar-19	MYSORE	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66 HEMMARGALA_66,KARYA_66 SUTTUR_66	13:17	14:18	1:01	LINE FAULT
693	10-Mar-19	MYSORE	66	HUNSUR-HOOTAGALLI	HUNSUR_66 HOSURGATE_66 BANNIKUPPE_66 HANAGODU_66	2:15	2:34	0:19	LINE FAULT
694	10-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	10:20	10:30	0:10	HAND TRIPPED
695	10-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	10:20	10:29	0:09	HAND TRIPPED
696	10-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	10:52	11:05	0:13	HAND TRIPPED
697	10-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	10:52	11:05	0:13	HAND TRIPPED
698	10-Mar-19	MYSORE	66	HV1	KIADBMANDYA_66	10:16	10:28	0:12	HAND TRIPPED
699	10-Mar-19	MYSORE	66	HV2	KIADBMANDYA_66	10:16	10:29	0:13	HAND TRIPPED
700	10-Mar-19	MYSORE	66	HV1	KIADBMANDYA_66	10:52	10:55	0:02	HAND TRIPPED
701	10-Mar-19	MYSORE	66	HV2	KIADBMANDYA_66	10:52	10:55	0:02	HAND TRIPPED
702	10-Mar-19	MYSORE	66	MADHUVANAHALLI-YELANDUR	YELANDUR_66	13:18	13:45	0:27	LINE FAULT
703	10-Mar-19	MYSORE	66	MADHUVANAHALLI-KOLLEGALA1	KOLLEGALA_66	13:17	13:45	0:27	LINE FAULT
704	10-Mar-19	MYSORE	220	HV1	MADHUVANAHALLI_220	14:32	16:07	1:35	LINE CLEAR AVAILED
705	10-Mar-19	MYSORE	66	MYSORE SOUTH-KADAKOLA	MYSORESOUTH_66	8:01	8:15	0:13	LINE FAULT
706	10-Mar-19	MYSORE	66	MYSORE SOUTH-KADAKOLA	MYSORESOUTH_66	9:09	9:27	0:18	LINE FAULT
707	10-Mar-19	MYSORE	66	MYSORE SOUTH-KADAKOLA	MYSORESOUTH_66	9:57	10:08	0:11	LINE FAULT
708	10-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:28	11:38	6:09	LINE CLEAR AVAILED
709	10-Mar-19	TUMKUR	66	TR-1 & TR-2	BELADARA_66	14:55	15:00	0:04	HAND TRIPPED
710	10-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	20:31	20:33	0:01	TRANSFORMER FAULT
711	10-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	22:17	22:20	0:03	TRANSFORMER FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
712	10-Mar-19	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:01	18:18	0:17	LINE FAULT
713	10-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:59	17:32	8:33	LINE CLEAR AVAILED
714	10-Mar-19	TUMKUR	66	HEGGERE- MALLASANDRA	MALLASANDRA_66	11:25	11:59	0:34	LINE FAULT
715	10-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	1:02	1:11	0:09	LINE FAULT
716	10-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	7:40	7:55	0:14	LINE FAULT
717	10-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	22:22	22:29	0:07	LINE FAULT
718	10-Mar-19	TUMKUR	66	TR-2	HULIYURDURGA_66	16:56	17:12	0:15	LINE CLEAR AVAILED
719	10-Mar-19	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	WELSPUN_IPP_SOLAR_66	6:52	7:24	0:31	LINE FAULT
720	10-Mar-19	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	WELSPUN_IPP_SOLAR_66	9:23	9:30	0:06	LINE FAULT
721	10-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:48	12:09	1:21	LINE FAULT
722	10-Mar-19	TUMKUR	66	SHYLAPURA-PR PURA	YNHOSKOTE_66, MANGALWADA_66,LINGDHALLI_66	9:27	9:33	0:06	LINE FAULT
723	11-Mar-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	8:02	8:10	0:08	TRANSFORMER FAULT
724	11-Mar-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	10:54	12:01	1:07	LINE CLEAR AVAILED
725	11-Mar-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	10:54	12:08	1:14	LINE CLEAR AVAILED
726	11-Mar-19	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	14:04	14:13	0:09	TRANSFORMER FAULT
727	11-Mar-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	17:42	18:12	0:30	LINE FAULT
728	11-Mar-19	BAGALKOT	220	ATRIA1-BAGEWADI	BAGEWADI_220	17:42	17:53	0:11	LINE FAULT
729	11-Mar-19	BAGALKOT	220	FORTUNE FIVE 1-BAGEWADI	BAGEWADI_220	17:42	17:57	0:15	LINE FAULT
730	11-Mar-19	BAGALKOT	220	FORTUNE FIVE 2-BAGEWADI	BAGEWADI_220	17:42	17:58	0:16	LINE FAULT
731	11-Mar-19	BAGALKOT	220	BAGEWADI-BIJAPUR1	BAGEWADI_220	17:42	17:58	0:16	LINE FAULT
732	11-Mar-19	BAGALKOT	110	BAGEWADI220-NIDAGUNDI	NIDAGUNDI_110	17:42	17:50	0:08	LINE FAULT
733	11-Mar-19	BAGALKOT	110	BAGEWADI220-MUDDEBIHAL	MUDDEBIHAL_110	17:42	17:53	0:11	LINE FAULT
734	11-Mar-19	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	6:30	17:10	10:40	LINE FAULT
735	11-Mar-19	BAGALKOT	110	BIDNAL220-HUBLI 2	BIDNAL_220	0:00	16:44	16:44	LINE CLEAR AVAILED
736	11-Mar-19	BAGALKOT	110	BIDNAL220-HUBLI 2	BIDNAL_220	18:24	23:59	5:35	LINE CLEAR AVAILED
737	11-Mar-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	0:00	18:24	18:24	LINE CLEAR AVAILED
738	11-Mar-19	BAGALKOT	110	110/11KV,HV1	GADAG_110	12:15	12:28	0:13	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
739	11-Mar-19	BAGALKOT	110	110/11KV,HV1 &HV2 110/33KV,HV3	GOKAK_110	19:27	19:35	0:08	TRANSFORMER FAULT
740	11-Mar-19	BAGALKOT	220	220/110KV,HV3,LV3	HUBLI_220	10:29	13:32	3:03	TRANSFORMER FAULT
741	11-Mar-19	BAGALKOT	110	HUBLI220-RAMANKOPPA	RAMANKOPPA_110	10:29	13:24	2:55	LINE FAULT
742	11-Mar-19	BAGALKOT	110	HUBLI220-KADANKOPPA	KADANKOPPA_110	16:25	16:33	0:08	HAND TRIPPED
743	11-Mar-19	BAGALKOT	110	HUBLI220-P H COMPOUND	P H COMPOUND_110	0:00	17:05	17:05	LINE CLEAR AVAILED
744	11-Mar-19	BAGALKOT	110	SOUDATTI110-ENERCON1	SOUDATTI_110	10:42	14:02	3:20	LINE CLEAR AVAILED
745	11-Mar-19	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	6:37	7:03	0:26	LINE FAULT
746	11-Mar-19	BAGALKOT	110	SIRSI-JOG2	SIRSI_110	13:25	17:37	4:12	LINE CLEAR AVAILED
747	11-Mar-19	BAGALKOT	110	110/11KV,HV2	SHIRGOAN_110	11:04	14:07	3:03	LINE CLEAR AVAILED
748	11-Mar-19	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	19:11	22:23	3:12	LINE FAULT
749	11-Mar-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	13:35	13:50	0:15	HAND TRIPPED
750	11-Mar-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	20:04	20:45	0:41	HAND TRIPPED
751	11-Mar-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220	13:35	22:21	8:46	LINE CLEAR AVAILED
752	11-Mar-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220	22:42	23:59	1:17	TRANSFORMER FAULT
753	11-Mar-19	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	19:23	19:25	0:02	TRANSFORMER FAULT
754	11-Mar-19	BAGALKOT	110	AMBEWADI-KADANKOPPA	KADANKOPPA_110	0:00	16:13	16:13	LINE CLEAR AVAILED
755	11-Mar-19	BAGALKOT	110	AMBEWADI-KADANKOPPA	KADANKOPPA_110	16:40	23:59	7:19	LINE CLEAR AVAILED
756	11-Mar-19	BAGALKOT	110	HUBLI220-KADANKOPPA	KADANKOPPA_110	16:13	16:40	0:27	LINE CLEAR AVAILED
757	11-Mar-19	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	15:18	15:20	0:02	HAND TRIPPED
758	11-Mar-19	BAGALKOT	110	110/33KV ,HV4	HIDIKAL_110,ALAGWADI_33KV	15:20	15:21	0:01	HAND TRIPPED
759	11-Mar-19	BAGALKOT	110	HIDIKAL-ITNAL	HIDIKAL_110	22:54	23:59	1:05	LINE CLEAR AVAILED
760	11-Mar-19	BAGALKOT	110	110/11KV,HV-1	KUDACH_220	18:04	18:43	0:39	LINE CLEAR AVAILED
761	11-Mar-19	BENGALORE	66	HV2	ANEKAL	14:24	14:50	0:26	TRANSFORMER FAULT
762	11-Mar-19	BENGALORE	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	11:18	12:20	1:01	LINE CLEAR AVAILED
763	11-Mar-19	BENGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	13:01	13:03	0:02	LOAD CHANGEOVER
764	11-Mar-19	BENGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	15:16	15:59	0:43	LOAD CHANGEOVER
765	11-Mar-19	BENGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	13:01	13:02	0:01	LOAD CHANGEOVER
766	11-Mar-19	BENGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA	15:16	15:23	0:07	LOAD CHANGEOVER
767	11-Mar-19	BENGALORE	66	HV1	MELUR	8:22	8:55	0:32	LINE CLEAR AVAILED
768	11-Mar-19	BENGALORE	66	VIJAYAPURA - MELUR	JANGAMAKOTE	13:01	13:10	0:09	LOAD CHANGEOVER
769	11-Mar-19	BENGALORE	66	MELUR - VIJAYAPURA	JANGAMAKOTE	15:37	15:47	0:09	LOAD CHANGEOVER
770	11-Mar-19	BENGALORE	66	HV2	TYAMAGONDALU	12:29	12:32	0:03	TRANSFORMER FAULT
771	11-Mar-19	BENGALORE	220	GOWRIBIDANUR 220 - DB PURA 220	KIADB DB PURA 220	12:47	15:19	2:32	LINE CLEAR AVAILED
772	11-Mar-19	BENGALORE	66	HV1	KIADB DB PURA 220	12:47	15:19	2:32	MAIN SUPPLY FAILURE
773	11-Mar-19	BENGALORE	66	HV2	KIADB DB PURA 220	12:47	15:19	2:32	MAIN SUPPLY FAILURE
774	11-Mar-19	BENGALORE	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	12:47	15:24	2:37	MAIN SUPPLY FAILURE
775	11-Mar-19	BENGALORE	66	HV1	BG ROAD	0:01	0:30	0:28	TRANSFORMER FAULT
776	11-Mar-19	BENGALORE	66	CHANDRAPPA CIRCLE - KUMBALAGODU	CHANDRAPPA CIRCLE	21:05	21:40	0:34	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
777	11-Mar-19	BENGALORE	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	11:11	11:26	0:15	MAIN SUPPLY FAILURE
778	11-Mar-19	BENGALORE	66	EDC 220 - BMTC	BMTC, NATIONAL COLLEGE	11:11	11:23	0:12	MAIN SUPPLY FAILURE
779	11-Mar-19	BENGALORE	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, PADMANABHA NAGAR	11:11	11:21	0:10	MAIN SUPPLY FAILURE
780	11-Mar-19	BENGALORE	66	NIMHANS 220 - JAYADEVA	JAYADEVA	11:11	11:22	0:11	MAIN SUPPLY FAILURE
781	11-Mar-19	BENGALORE	220	HV1	EPIP 220	11:11	11:21	0:10	MAIN SUPPLY FAILURE
782	11-Mar-19	BENGALORE	220	HV2	EPIP 220	11:11	11:21	0:10	MAIN SUPPLY FAILURE
783	11-Mar-19	BENGALORE	66	HV1	EPIP 220	11:11	11:25	0:14	MAIN SUPPLY FAILURE
784	11-Mar-19	BENGALORE	66	HV2	EPIP 220	11:11	11:26	0:15	MAIN SUPPLY FAILURE
785	11-Mar-19	BENGALORE	66	JAYADEVA - ADUGODI	ADUGODI	11:11	11:23	0:12	MAIN SUPPLY FAILURE
786	11-Mar-19	BENGALORE	220	HV1	NIMHANS 220	11:11	11:20	0:09	MAIN SUPPLY FAILURE
787	11-Mar-19	BENGALORE	220	HV2	NIMHANS 220	11:11	11:21	0:10	MAIN SUPPLY FAILURE
788	11-Mar-19	BENGALORE	66	HV2	NRS 220	23:09	23:11	0:02	LINE CLEAR AVAILED
789	11-Mar-19	BENGALORE	66	POTTERY ROAD - HOODY 220	POTTERY ROAD	14:07	14:26	0:18	LINE CLEAR AVAILED
790	11-Mar-19	BENGALORE	220	HSR LAYOUT 220 - NIMHANS 220	NIMHANS 220, HSR LAYOUT 220	11:11	11:19	0:08	LINE FAULT
791	11-Mar-19	BENGALORE	66	HV2	RMV	10:15	10:18	0:02	LINE CLEAR AVAILED
792	11-Mar-19	BENGALORE	66	APPAREL PARK - DB PURA 220	APPAREL PARK	15:15	15:25	0:10	LOAD CHANGEOVER
793	11-Mar-19	BENGALORE	66	APPAREL PARK - KIADB DB PURA 220	APPAREL PARK	12:50	13:10	0:20	LOAD CHANGEOVER
794	11-Mar-19	GULBARGA	220	LINGAPUR-BMMISPAT	LINGAPUR_220	10:06	13:52	3:46	NFBC ISSUED
795	11-Mar-19	GULBARGA	220	LINGAPUR-JVSL1	JVSWL_220	10:46	19:03	8:17	NFBC ISSUED
796	11-Mar-19	GULBARGA	220	LINGAPUR-JVSL2	JVSWL_220	13:33	15:56	2:23	LINE FAULT
797	11-Mar-19	GULBARGA	220	HV1	RAICHUR_220	11:18	11:43	0:25	LINE CLEAR AVAILED
798	11-Mar-19	GULBARGA	110	ALIPUR-MUNIRABD	TORANAGALLU_110, KUDITINI_110, KURUGOD_110, SHATAVAHANA_IPP, AGARWAL IPP,SUZLON_IPP, KAMALAPUR_110	12:51	13:07	0:16	LINE FAULT
799	11-Mar-19	GULBARGA	110	DHADESUGUR-SINDHANOOR	DHADESUGUR_110	0:00	12:10	12:10	LINE CLEAR AVAILED
800	11-Mar-19	GULBARGA	110	LINGASUGUR-GURGUNTA	GURUGUNTA_110	2:45	2:55	0:10	LINE FAULT
801	11-Mar-19	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110, BYAGWAT_110,VALKAMDINI_110	16:45	17:40	0:55	LINE CLEAR AVAILED
802	11-Mar-19	GULBARGA	110	SHAHPUR-KEMBHAVI	KEMBHAVI_110	4:09	4:15	0:06	LINE FAULT
803	11-Mar-19	HASSAN	220	HASSN22-CHIKMAGALUR	HASSAN_220	8:55	9:04	0:09	HAND TRIPPED
804	11-Mar-19	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	4:09	4:22	0:13	LOAD CURTAILMENT
805	11-Mar-19	HASSAN	110	KADUR-NGNHL	KADUR_220	15:36	15:53	0:17	LINE FAULT
806	11-Mar-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	5:12	5:53	0:41	LINE FAULT
807	11-Mar-19	HASSAN	110	SAGARA-SORABA	SAGARA_110	8:31	8:47	0:16	HAND TRIPPED
808	11-Mar-19	HASSAN	110	SAGARA-SORABA	SAGARA_110	22:34	23:59	1:25	LINE CLEAR AVAILED
809	11-Mar-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	15:13	15:20	0:07	LINE FAULT
810	11-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	17:57	18:33	0:36	LINE CLEAR AVAILED
811	11-Mar-19	HASSAN	66	BYARAPU-BAGUR	BYARAPURA_66	10:36	17:43	7:07	LOAD CURTAILMENT
812	11-Mar-19	MYSORE	66	HV1	BILIKERE_66	11:10	23:59	12:48	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
813	11-Mar-19	MYSORE	66	HOOTAGALLI-ELAVALA	GAVADAGERE_66 ELAVALA_66	12:10	12:14	0:03	LINE FAULT
814	11-Mar-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HUNSUR_66 HOSURGATE_66 HANAGODU_66	12:06	12:14	0:08	LINE FAULT
815	11-Mar-19	MYSORE	66	HV1	JAKKANAHALLY_66	8:39	15:41	7:02	LINE CLEAR AVAILED
816	11-Mar-19	MYSORE	66	HV2	JAKKANAHALLY_66	8:39	15:41	7:02	LINE CLEAR AVAILED
817	11-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	9:10	9:21	0:10	HAND TRIPPED
818	11-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	9:10	9:21	0:10	HAND TRIPPED
819	11-Mar-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 KIADBMANDYA_66 TUMBEKERE_66	9:10	9:18	0:07	LINE FAULT
820	11-Mar-19	MYSORE	66	KUSHALANAGARA 220-RAMANATHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	17:32	18:27	0:54	LINE CLEAR AVAILED
821	11-Mar-19	MYSORE	66	HV1	MYSORESOUTH_66	17:33	17:59	0:25	HAND TRIPPED
822	11-Mar-19	MYSORE	66	HV2	MYSORESOUTH_66	17:33	17:59	0:25	HAND TRIPPED
823	11-Mar-19	MYSORE	66	HV2	SALIGRAMA_66	5:09	5:13	0:04	LINE CLEAR AVAILED
824	11-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	0:15	7:12	6:57	LINE CLEAR AVAILED
825	11-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	11:47	21:01	9:13	LINE CLEAR AVAILED
826	11-Mar-19	MYSORE	66	TARIPURA-TUBINAKERE	TARIPURA_66	8:24	8:37	0:12	LINE FAULT
827	11-Mar-19	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	10:58	11:56	0:58	LINE CLEAR AVAILED
828	11-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:11	11:42	6:30	LINE CLEAR AVAILED
829	11-Mar-19	TUMKUR	220	TR-3(HV SIDE )	DAVANGERE_SRS_220	2:25	3:28	1:02	LINE CLEAR AVAILED
830	11-Mar-19	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	MRSMG_220	13:19	15:54	2:34	LINE CLEAR AVAILED
831	11-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:12	11:46	6:34	LINE CLEAR AVAILED
832	11-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	18:17	18:53	0:36	LINE FAULT
833	11-Mar-19	TUMKUR	66	TR-2	DAVANAGERE_66	18:47	18:53	0:06	TRANSFORMER FAULT
834	11-Mar-19	TUMKUR	66	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_2	2:29	3:29	1:00	LINE CLEAR AVAILED
835	11-Mar-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	2:28	3:46	1:17	LINE CLEAR AVAILED
836	11-Mar-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:26	13:17	0:51	HAND TRIPPED
837	11-Mar-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	2:28	3:50	1:21	LINE CLEAR AVAILED
838	11-Mar-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:33	15:12	2:39	LINE CLEAR AVAILED
839	11-Mar-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	2:27	15:17	12:49	LINE CLEAR AVAILED
840	11-Mar-19	TUMKUR	66	TR-1 (HV SIDE )	DAVANGERE_SRS_220	2:28	3:29	1:01	TRANSFORMER FAULT
841	11-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	2:29	3:47	1:18	LINE CLEAR AVAILED
842	11-Mar-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	2:27	3:49	1:22	LINE CLEAR AVAILED
843	11-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	2:27	3:50	1:22	LINE CLEAR AVAILED
844	11-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:26	15:37	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
845	11-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:53	17:44	8:50	LINE CLEAR AVAILED
846	11-Mar-19	TUMKUR	66	TR-2	HARIYABBE_66	19:55	20:07	0:12	TRANSFORMER FAULT
847	11-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:22	8:28	0:05	LINE FAULT
848	11-Mar-19	TUMKUR	66	MADANAYAKANAHALLI-CHITRADURGA220	MADANAYAKANAHALLI_66	18:40	18:51	0:10	LINE FAULT
849	11-Mar-19	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	6:17	6:28	0:10	LINE FAULT
850	11-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	4:05	4:39	0:33	LINE FAULT
851	11-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	16:15	16:41	0:25	LINE FAULT
852	11-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:19	11:48	1:29	LINE FAULT