

400/220/110/66 kV TRANSMISSION INTERRUPTIONS DUE TO LC, LS AND FAULTS :09.04.2020 TO 13.04.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	7-Apr-20	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	6:59	8:53	1:54	LINE CLEAR AVAILED
2	7-Apr-20	BAGALKOT	110	110/11KV,HV1	DAMBAL_110	11:28	12:10	0:42	LINE CLEAR AVAILED
3	7-Apr-20	BAGALKOT	110	110/11KV,HV2	SHIROL_110	13:12	14:01	0:49	LINE CLEAR AVAILED
4	7-Apr-20	BAGALKOT	110	110/33KV,HV2	ANKOLA_110	6:19	7:33	1:14	TRANSFORMER FAULT
5	7-Apr-20	BAGALKOT	110	110/33KV,HV2	HANAGAL_110,BOMMANALLI_33,AKKI ALUR_33,BELAGALPETE_33,LAXMIPUR_33	12:05	12:10	0:05	TRANSFORMER FAULT
6	7-Apr-20	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110	9:31	9:39	0:08	TRANSFORMER FAULT
7	7-Apr-20	BAGALKOT	110	110/33KV,HV2	LAXMESHWAR_110,MMCL_33,SSM_33	19:27	19:55	0:28	TRANSFORMER FAULT
8	7-Apr-20	BAGALKOT	110	110/33KV,HV2	VADAGOAN_110,RM1_33,FORT_33	11:05	12:20	1:15	TRANSFORMER FAULT
9	7-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DULKED_33, NEVARGI_33	6:55	7:00	0:05	TRANSFORMER FAULT
10	7-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DULKED_33, NEVARGI_33	10:51	10:56	0:05	TRANSFORMER FAULT
11	7-Apr-20	BAGALKOT	110	GADAG-DAMBAL2	DAMBAL_110	18:33	23:59	5:26	LINE FAULT
12	7-Apr-20	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	18:19	23:59	5:40	LINE FAULT
13	7-Apr-20	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	8:47	12:45	3:58	NFBC ISSUED
14	7-Apr-20	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	2:34	12:28	9:54	LINE FAULT
15	7-Apr-20	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	20:37	23:59	3:22	LINE FAULT
16	7-Apr-20	BAGALKOT	110	ITNAL-HIDIKAL	HIDIKAL_110	20:50	23:59	3:09	LINE CLEAR AVAILED
17	7-Apr-20	BAGALKOT	110	SAVANUR-RAMANAKOPPA	RAMANAKOPPA	16:53	17:16	0:23	LINE FAULT
18	7-Apr-20	BAGALKOT	220	220/110KV,HV1,LV1	NARENDRA_220	14:41	16:44	2:03	LINE CLEAR AVAILED
19	7-Apr-20	BAGALKOT	220	220/110KV,HV2,LV2	NARENDRA_220	13:01	14:36	1:35	LINE CLEAR AVAILED
20	7-Apr-20	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	20:59	23:59	3:00	LINE CLEAR AVAILED
21	7-Apr-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:00	13:15	13:15	LINE CLEAR AVAILED
22	7-Apr-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	10:38	13:35	2:57	LINE CLEAR AVAILED
23	7-Apr-20	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	0:00	13:38	13:38	LINE CLEAR AVAILED
24	7-Apr-20	BAGALKOT	220	LINGASUR1-BAGEWADI	BAGEWADI_220	16:35	17:03	0:28	LINE FAULT
25	7-Apr-20	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	17:02	17:11	0:09	LINE FAULT
26	7-Apr-20	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI, SOMNATHPURA	18:18	18:43	0:25	MAIN SUPPLY FAILURE
27	7-Apr-20	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	18:20	21:27	3:07	LINE FAULT
28	7-Apr-20	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	21:27	21:31	0:04	LINE FAULT
29	7-Apr-20	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	18:20	21:31	3:11	LINE FAULT
30	7-Apr-20	GULBARGA	66	HV1	KOTTUR_66	15:40	15:45	0:05	TRANSFORMER FAULT
31	7-Apr-20	GULBARGA	66	HV1	GUDEKOTE_110	17:25	18:50	1:25	TRANSFORMER FAULT
32	7-Apr-20	GULBARGA	66	HV1,HV2	GUDEKOTE_110	15:35	16:55	1:20	LINE CLEAR AVAILED
33	7-Apr-20	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	8:40	8:50	0:10	TRANSFORMER FAULT
34	7-Apr-20	GULBARGA	66	HV2	GUDEKOTE_110	17:30	18:50	1:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
35	7-Apr-20	GULBARGA	110	DEODURGA-GABUR	DEODURGA_110	18:50	22:25	3:35	MAIN SUPPLY FAILURE
36	7-Apr-20	GULBARGA	110	GABUR-RAICHUR	GABUR_110, DEODURGA_110	18:45	22:25	3:40	LOAD CURTAILMENT
37	7-Apr-20	GULBARGA	110	HV1	DEODURGA_110	17:30	17:50	0:20	TRANSFORMER FAULT
38	7-Apr-20	GULBARGA	110	HV1	DEODURGA_110	18:05	22:25	4:20	TRANSFORMER FAULT
39	7-Apr-20	GULBARGA	110	HV2	DEODURGA_110	6:40	6:45	0:05	TRANSFORMER FAULT
40	7-Apr-20	GULBARGA	110	HV2	HATTI_110	13:52	14:20	0:28	TRANSFORMER FAULT
41	7-Apr-20	GULBARGA	110	HV2	HATTI_110	16:55	17:20	0:25	TRANSFORMER FAULT
42	7-Apr-20	GULBARGA	110	HV2	HATTI_110	19:25	19:30	0:05	TRANSFORMER FAULT
43	7-Apr-20	GULBARGA	110	HV2	YELBURGA_110	16:45	16:55	0:10	TRANSFORMER FAULT
44	7-Apr-20	GULBARGA	110	HV3	KEMBHAVI_110	20:20	20:30	0:10	TRANSFORMER FAULT
45	7-Apr-20	GULBARGA	110	HV3	SHORAPUR_110	20:15	20:20	0:05	TRANSFORMER FAULT
46	7-Apr-20	GULBARGA	110	HV3	SHORAPUR_110	20:45	20:55	0:10	TRANSFORMER FAULT
47	7-Apr-20	GULBARGA	110	HV4	SHORAPUR_110	19:01	19:10	0:09	TRANSFORMER FAULT
48	7-Apr-20	GULBARGA	110	PDHALLI-ALIPUR	PDHALLI_110	16:55	18:27	1:32	LINE CLEAR AVAILED
49	7-Apr-20	GULBARGA	110	PDHALLI-JANAKI_IPP,CLEANSOLAR_IPP, CLEANMAX_IPP, BASAI_IPP	PDHALLI_110	18:50	19:00	0:10	LINE CLEAR AVAILED
50	7-Apr-20	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB,BTPS_WATERWORKS	14:35	15:00	0:25	LINE FAULT
51	7-Apr-20	GULBARGA	110	SINDHANOOR220-NIRLOOTI_IPP	SINDHANOOR_220	13:40	13:50	0:10	LINE FAULT
52	7-Apr-20	GULBARGA	220	MALLAT-RTPS	MALLAT_220	18:50	19:10	0:20	LINE FAULT
53	7-Apr-20	GULBARGA	400	JVSWL-GUTTUR	GUTTUR_400	16:09	23:59	7:50	LINE FAULT
54	7-Apr-20	GULBARGA	400	JVSWL-GUTTUR	GUTTUR_400	0:00	11:45	11:45	LINE FAULT
55	7-Apr-20	HASSAN	66	HV1	DODDAKADANUR_66	14:47	14:56	0:09	TRANSFORMER FAULT
56	7-Apr-20	HASSAN	66	HV1	HNPURA_66	0:58	1:02	0:04	HAND TRIPPED
57	7-Apr-20	HASSAN	66	HV1	SAKLESH PURA_66	20:47	21:01	0:14	TRANSFORMER FAULT
58	7-Apr-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	2:06	2:12	0:06	LINE FAULT
59	7-Apr-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	0:20	1:10	0:50	MAIN SUPPLY FAILURE
60	7-Apr-20	HASSAN	66	MRSSHM-DVG2	MRS MG_220	8:56	9:18	0:22	LINE FAULT
61	7-Apr-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:16	16:18	1:02	MAIN SUPPLY FAILURE
62	7-Apr-20	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	16:21	17:18	0:57	MAIN SUPPLY FAILURE
63	7-Apr-20	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	16:24	17:20	0:56	MAIN SUPPLY FAILURE
64	7-Apr-20	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	16:23	17:18	0:55	MAIN SUPPLY FAILURE
65	7-Apr-20	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	16:38	17:17	0:39	MAIN SUPPLY FAILURE
66	7-Apr-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	16:22	17:19	0:57	MAIN SUPPLY FAILURE
67	7-Apr-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	17:28	18:33	1:05	LINE FAULT
68	7-Apr-20	HASSAN	110	HV1	BANAVARA_110	0:00	3:03	3:03	LINE CLEAR AVAILED
69	7-Apr-20	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:19	10:50	0:31	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
70	7-Apr-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:16	16:18	1:02	LINE FAULT
71	7-Apr-20	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	16:21	17:16	0:55	LINE FAULT
72	7-Apr-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	16:23	16:35	0:12	LINE FAULT
73	7-Apr-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	16:23	16:59	0:36	LINE FAULT
74	7-Apr-20	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	16:24	17:34	1:10	LINE FAULT
75	7-Apr-20	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	16:24	17:32	1:08	LINE FAULT
76	7-Apr-20	HASSAN	110	LV3	KEMAR_220	12:57	13:43	0:46	TRANSFORMER FAULT
77	7-Apr-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	16:29	16:42	0:13	MAIN SUPPLY FAILURE
78	7-Apr-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	16:24	16:40	0:16	MAIN SUPPLY FAILURE
79	7-Apr-20	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	13:56	15:36	1:40	LINE FAULT
80	7-Apr-20	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	16:36	16:41	0:05	MAIN SUPPLY FAILURE
81	7-Apr-20	HASSAN	220	HV3	KEMAR_220	12:59	13:43	0:44	TRANSFORMER FAULT
82	7-Apr-20	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	15:16	17:22	2:06	LINE FAULT
83	7-Apr-20	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	15:16	17:24	2:08	LINE FAULT
84	7-Apr-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:11	17:07	1:56	LINE FAULT
85	7-Apr-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	15:11	17:11	2:00	LINE FAULT
86	7-Apr-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	13:46	15:29	1:43	LINE FAULT
87	7-Apr-20	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	15:16	17:22	2:06	LINE FAULT
88	7-Apr-20	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	15:16	17:24	2:08	LINE FAULT
89	7-Apr-20	HASSAN	220	VARAH1-KEMAR1	varahi_gen	15:11	17:08	1:57	LINE FAULT
90	7-Apr-20	HASSAN	220	VARAH1-KEMAR2	varahi_gen	15:11	17:12	2:01	LINE FAULT
91	7-Apr-20	HASSAN	220	VARAH1-KEMAR2	varahi_gen	17:21	17:54	0:33	LINE FAULT
92	7-Apr-20	HASSAN	220	VARAH1-KEMAR3	varahi_gen	16:22	16:27	0:05	LINE FAULT
93	7-Apr-20	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:46	15:29	1:43	LINE FAULT
94	7-Apr-20	MYSORE	66	HALAGUR-HONAGANALLI	HALAGUR_66	12:20	15:40	3:20	MAIN SUPPLY FAILURE
95	7-Apr-20	MYSORE	66	HV1	BANANGADI_66	14:52	16:12	1:20	LINE CLEAR AVAILED
96	7-Apr-20	MYSORE	66	HV1	CHINAKURALI_66	14:26	15:21	0:54	LINE CLEAR AVAILED
97	7-Apr-20	MYSORE	66	HV1	HDKOTE_66	14:37	15:35	0:57	LINE CLEAR AVAILED
98	7-Apr-20	MYSORE	66	HV1	K_HONNALGERE_66	14:03	14:13	0:10	MAIN SUPPLY FAILURE
99	7-Apr-20	MYSORE	66	HV1	K_HONNALGERE_66	15:58	16:16	0:17	MAIN SUPPLY FAILURE
100	7-Apr-20	MYSORE	66	HV1	K_HONNALGERE_66	22:07	23:05	0:58	MAIN SUPPLY FAILURE
101	7-Apr-20	MYSORE	66	HV1	KIADBMANDYA_66	15:40	17:04	1:23	LINE CLEAR AVAILED
102	7-Apr-20	MYSORE	66	HV2	DODDINADUVADI_66	15:00	15:50	0:49	LINE CLEAR AVAILED
103	7-Apr-20	MYSORE	66	HV2	K_HONNALGERE_66	14:03	14:13	0:10	MAIN SUPPLY FAILURE
104	7-Apr-20	MYSORE	66	HV2	K_HONNALGERE_66	15:58	16:15	0:17	MAIN SUPPLY FAILURE
105	7-Apr-20	MYSORE	66	HV2	K_HONNALGERE_66	22:07	23:05	0:58	MAIN SUPPLY FAILURE
106	7-Apr-20	MYSORE	66	HV3	KUSHALNAGARA_220	1:20	1:23	0:02	TRANSFORMER FAULT
107	7-Apr-20	MYSORE	66	KADAKOLA-RK NAGARA	MANDAKALLI_66	1:40	2:04	0:24	LINE FAULT
108	7-Apr-20	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	0:25	0:42	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
109	7-Apr-20	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	0:42	1:30	0:47	LINE FAULT
110	7-Apr-20	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	1:30	11:10	9:39	LINE FAULT
111	7-Apr-20	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	11:10	11:45	0:35	NFBC ISSUED
112	7-Apr-20	TUMKUR	66	ANTHRASANAHALI 220KV- KORA	KORA_66, THOVINAKERE_66	20:28	21:17	0:49	LINE CLEAR AVAILED
113	7-Apr-20	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	15:59	16:12	0:12	LINE FAULT
114	7-Apr-20	TUMKUR	66	BENNEHALI-KOTTUR	BENNEHALI_66	18:49	19:01	0:12	LINE FAULT
115	7-Apr-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	13:01	13:52	0:51	HAND TRIPPED
116	7-Apr-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:01	13:52	0:51	HAND TRIPPED
117	7-Apr-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:52	19:04	0:11	LINE FAULT
118	7-Apr-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:00	13:52	0:51	HAND TRIPPED
119	7-Apr-20	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	15:11	15:20	0:08	LINE FAULT
120	7-Apr-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:43	15:04	0:21	HAND TRIPPED
121	7-Apr-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:43	15:04	0:21	HAND TRIPPED
122	7-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALI	SASUVEHALI_66,CHANNAGIRI_66	14:43	15:03	0:20	HAND TRIPPED
123	7-Apr-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	8:42	9:04	0:21	LINE FAULT
124	7-Apr-20	TUMKUR	66	TR-1	BAGUR_TMK_66	22:22	22:40	0:18	TRANSFORMER FAULT
125	7-Apr-20	TUMKUR	66	TR-1	SHYLAPURA_66	20:45	20:56	0:10	TRANSFORMER FAULT
126	7-Apr-20	TUMKUR	66	TR-1	SHYLAPURA_66	21:07	21:25	0:17	TRANSFORMER FAULT
127	7-Apr-20	TUMKUR	66	TR-2	HANAGAL_66,	10:49	11:01	0:11	LINE CLEAR AVAILED
128	7-Apr-20	TUMKUR	66	TR-2	MANGALWADA_66	15:08	15:16	0:08	TRANSFORMER FAULT
129	7-Apr-20	TUMKUR	66	TR-2	MANGALWADA_66	19:27	19:36	0:08	TRANSFORMER FAULT
130	7-Apr-20	TUMKUR	66	TR-2	MANGALWADA_66	22:12	22:19	0:07	TRANSFORMER FAULT
131	7-Apr-20	TUMKUR	66	TR-2	SANIKERE_66	9:14	9:54	0:39	LINE CLEAR AVAILED
132	7-Apr-20	TUMKUR	110	DODDAGUNI- NITTUR	DODDAGUNI_110	11:21	11:58	0:37	LINE CLEAR AVAILED
133	7-Apr-20	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	11:19	11:59	0:39	LINE CLEAR AVAILED
134	7-Apr-20	TUMKUR	110	NITTUR 220kv- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	11:32	11:57	0:25	LINE CLEAR AVAILED
135	7-Apr-20	TUMKUR	220	HONNALLI 220kv- SUZLON1	SUZLON_IPP_66	14:43	15:14	0:31	LINE FAULT
136	7-Apr-20	TUMKUR	220	HONNALLI 220kv- SUZLON2	SUZLON_IPP_66	14:43	15:13	0:30	LINE FAULT
137	8-Apr-20	BAGALKOT	110	110/11KV, HV1?&HV2	DAMBAL_110	10:51	12:03	1:12	LINE CLEAR AVAILED
138	8-Apr-20	BAGALKOT	110	110/11KV,HV1	GADAG_110	10:40	10:45	0:05	TRANSFORMER FAULT
139	8-Apr-20	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	11:06	11:29	0:23	TRANSFORMER FAULT
140	8-Apr-20	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	11:39	11:54	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
141	8-Apr-20	BAGALKOT	110	110/33KV, HV1&HV2	HANAGAL_110,BOMMANALLI_33,AKKI ALUR_33,BELAGALPETE_33,LAXMIPUR_33	11:50	12:00	0:10	TRANSFORMER FAULT
142	8-Apr-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	7:31	7:34	0:03	TRANSFORMER FAULT
143	8-Apr-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	9:22	9:27	0:05	TRANSFORMER FAULT
144	8-Apr-20	BAGALKOT	110	BAGALKOT220-GULEDAGUDDA	GELUDAGUDDA_110	14:12	16:55	2:43	LINE FAULT
145	8-Apr-20	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	20:34	20:56	0:22	HAND TRIPPED
146	8-Apr-20	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	21:37	21:59	0:22	LINE FAULT
147	8-Apr-20	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	22:10	23:59	1:49	LINE CLEAR AVAILED
148	8-Apr-20	BAGALKOT	110	GADAG220-DAMBAL1	DAMBAL_110	10:59	12:01	1:02	LINE CLEAR AVAILED
149	8-Apr-20	BAGALKOT	110	GADAG220-DAMBAL2	DAMBAL_110	0:00	11:55	11:55	LINE CLEAR AVAILED
150	8-Apr-20	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	0:00	14:13	14:13	LINE CLEAR AVAILED
151	8-Apr-20	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	0:00	0:56	0:56	LINE CLEAR AVAILED
152	8-Apr-20	BAGALKOT	110	SUZLON1&2-DAMBAL	DAMBAL_110	10:39	12:12	1:33	LINE CLEAR AVAILED
153	8-Apr-20	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	12:04	17:37	5:33	LINE FAULT
154	8-Apr-20	BAGALKOT	220	BELGAUM-NARENDRA2	BELGAUM_220	13:15	17:37	4:22	LINE FAULT
155	8-Apr-20	BAGALKOT	220	HARTI1&2-GADAG	GADAG_220	11:18	14:55	3:37	LINE CLEAR AVAILED
156	8-Apr-20	BAGALKOT	220	HUBLI-NARENDRA1	HUBLI_220	18:18	21:22	3:04	LINE FAULT
157	8-Apr-20	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	14:54	19:24	4:30	LINE FAULT
158	8-Apr-20	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	12:40	12:51	0:11	HAND TRIPPED
159	8-Apr-20	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE,MATHIKERE	1:40	2:55	1:15	MAIN SUPPLY FAILURE
160	8-Apr-20	BENGALURU	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE,MATHIKERE	15:07	15:10	0:03	MAIN SUPPLY FAILURE
161	8-Apr-20	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:42	12:56	0:14	LINE CLEAR AVAILED
162	8-Apr-20	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA,SHIVANAHLLI,DASHAW ARA,SANKALGERE,BEVOOR	10:07	10:17	0:10	LINE FAULT
163	8-Apr-20	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	9:31	9:49	0:17	LINE CLEAR AVAILED
164	8-Apr-20	BENGALURU	66	HOODY 220 - GRAPHITE INDIA(EHT)	GRAPHITE INDIA(EHT)	13:34	14:41	1:07	LINE FAULT
165	8-Apr-20	BENGALURU	66	HV1	HONNIGANAHALLI	12:11	12:25	0:13	LINE CLEAR AVAILED
166	8-Apr-20	BENGALURU	66	HV1	HONNIGANAHALLI	13:05	13:15	0:10	TRANSFORMER FAULT
167	8-Apr-20	BENGALURU	66	HV1	HONNIGANAHALLI	13:20	13:25	0:05	TRANSFORMER FAULT
168	8-Apr-20	BENGALURU	66	HV1	SM MANGALA	7:51	8:13	0:22	LINE CLEAR AVAILED
169	8-Apr-20	BENGALURU	66	HV1	ST.JOHNS	17:36	17:52	0:16	TRANSFORMER FAULT
170	8-Apr-20	BENGALURU	66	HV2	CB PURA I/A	11:58	12:51	0:53	LINE CLEAR AVAILED
171	8-Apr-20	BENGALURU	66	HV2	DODDALAHALLI	8:01	8:17	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
172	8-Apr-20	BENGALURU	66	HV2	HONNIGANAHALLI	12:11	12:25	0:13	LINE CLEAR AVAILED
173	8-Apr-20	BENGALURU	66	HV2	ADUGODI	16:45	16:50	0:05	LINE CLEAR AVAILED
174	8-Apr-20	BENGALURU	66	HV2	PADMANABHANAGARA	9:36	9:40	0:04	LINE CLEAR AVAILED
175	8-Apr-20	BENGALURU	66	HV2	ST.JOHNS	17:37	17:40	0:03	LINE CLEAR AVAILED
176	8-Apr-20	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	19:12	19:20	0:08	LINE FAULT
177	8-Apr-20	BENGALURU	66	NANGALI - KEMPANAHALLI	NANGALI	16:58	17:53	0:54	LINE FAULT
178	8-Apr-20	GULBARGA	110	HALBURGA-KOLHAR1,2	KOLHAR_110, JANAWADA_110, NSSK_SUGARS	17:37	22:00	4:23	LINE CLEAR AVAILED
179	8-Apr-20	GULBARGA	110	HV2	DEODURGA_110	10:20	10:30	0:10	TRANSFORMER FAULT
180	8-Apr-20	GULBARGA	110	HV2	SINDHANOOR_220	11:10	12:20	1:10	LINE CLEAR AVAILED
181	8-Apr-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110	22:17	22:23	0:06	LINE FAULT
182	8-Apr-20	GULBARGA	220	HV1, HV2	HALBURGA_220	10:38	10:46	0:08	TRANSFORMER FAULT
183	8-Apr-20	GULBARGA	400	YTPS-BPS1	BPS_400	19:05	23:59	4:54	LINE FAULT
184	8-Apr-20	GULBARGA	400	YTPS-BPS1	BPS_400	0:00	8:14	8:14	LINE FAULT
185	8-Apr-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:38	9:45	0:07	LINE FAULT
186	8-Apr-20	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:07	10:13	0:06	HAND TRIPPED
187	8-Apr-20	HASSAN	66	BYACHAN-HV1	BYCHANAHALLY_66	11:06	11:37	0:31	LINE CLEAR AVAILED
188	8-Apr-20	HASSAN	66	HASSN22-HSN66	HASSAN_220	17:04	19:27	2:23	LINE FAULT
189	8-Apr-20	HASSAN	66	HV1	SAKLESH PURA_66	16:15	16:25	0:10	TRANSFORMER FAULT
190	8-Apr-20	HASSAN	66	HV2	UDAYAPURA_66	9:06	9:09	0:03	TRANSFORMER FAULT
191	8-Apr-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:21	11:07	0:46	LINE CLEAR AVAILED
192	8-Apr-20	HASSAN	66	MRSSHM-BD-2	MRS MG_220	10:06	10:13	0:07	HAND TRIPPED
193	8-Apr-20	HASSAN	66	MRSSHM-DVG2	MRS MG_220	10:32	10:53	0:21	LINE FAULT
194	8-Apr-20	HASSAN	66	UDDURKO-UDDUR	UDDURKOPLU_66	17:04	17:37	0:33	LINE FAULT
195	8-Apr-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	9:17	13:40	4:23	NFBC ISSUED
196	8-Apr-20	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	9:33	9:54	0:21	LINE FAULT
197	8-Apr-20	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	9:33	9:55	0:22	LINE FAULT
198	8-Apr-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	9:35	9:56	0:21	LINE FAULT
199	8-Apr-20	HASSAN	110	HV1	BANAVARA_110	12:43	13:14	0:31	LINE CLEAR AVAILED
200	8-Apr-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	9:17	13:40	4:23	LINE CLEAR AVAILED
201	8-Apr-20	HASSAN	110	MRSSHM-BADRAVATY1	MRS MG_220	19:31	21:36	2:05	LINE FAULT
202	8-Apr-20	HASSAN	110	MRSSHM-BADRAVATY2	MRS MG_220	19:31	21:36	2:05	LINE FAULT
203	8-Apr-20	HASSAN	110	MRSSHM-GAJNUR	MRS MG_220	19:19	20:37	1:18	LINE FAULT
204	8-Apr-20	HASSAN	110	SHIVAPU-BIRUR	SHIVAPURA_110	19:34	19:52	0:18	LINE FAULT
205	8-Apr-20	HASSAN	220	MRSSHM-KBCRS	MRS MG_220	16:15	17:59	1:44	LINE FAULT
206	8-Apr-20	MYSORE	66	HV1	HDKOTE_66	8:14	8:38	0:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
207	8-Apr-20	MYSORE	66	HV1	HONNALLY_MYS_66	12:50	12:59	0:09	TRANSFORMER FAULT
208	8-Apr-20	MYSORE	66	HV2	DODDINADUVADI_66	11:48	15:10	3:22	LINE CLEAR AVAILED
209	8-Apr-20	MYSORE	66	HV2	HDKOTE_66	8:38	8:47	0:08	TRANSFORMER FAULT
210	8-Apr-20	MYSORE	66	HV4	SFCSHIVA_66	14:32	15:39	1:07	LINE CLEAR AVAILED
211	8-Apr-20	MYSORE	66	HV4	SFCSHIVA_66	15:49	15:51	0:01	TRANSFORMER FAULT
212	8-Apr-20	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66,TARIPURA_66 ,GAMANAH ALLY_66	16:08	16:20	0:12	LINE FAULT
213	8-Apr-20	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	14:11	14:20	0:09	LINE FAULT
214	8-Apr-20	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	16:37	17:00	0:22	LINE FAULT
215	8-Apr-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	10:53	11:03	0:10	LINE FAULT
216	8-Apr-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:35	10:56	0:21	LINE FAULT
217	8-Apr-20	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	9:47	9:55	0:08	LINE FAULT
218	8-Apr-20	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66	12:19	12:28	0:08	LINE CLEAR AVAILED
219	8-Apr-20	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	14:57	15:03	0:06	HAND TRIPPED
220	8-Apr-20	TUMKUR	66	MATHOD- ENERCON1_IPP_66 1	ENERCON1_IPP_66	5:42	5:59	0:16	LINE FAULT
221	8-Apr-20	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	18:48	18:58	0:10	LINE FAULT
222	8-Apr-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	7:48	7:53	0:05	LINE FAULT
223	8-Apr-20	TUMKUR	66	TR-1	CHALLAKERE_66	17:51	17:55	0:03	TRANSFORMER FAULT
224	8-Apr-20	TUMKUR	66	TR-1	LINGADAHALLI_TMK2_66	15:32	15:37	0:05	TRANSFORMER FAULT
225	8-Apr-20	TUMKUR	66	TR-2	CHANNAGIRI_66	12:21	12:26	0:05	TRANSFORMER FAULT
226	8-Apr-20	TUMKUR	66	TR-2	MATHOD_66	7:39	7:45	0:06	TRANSFORMER FAULT
227	8-Apr-20	TUMKUR	66	TR-2	MATHOD_66	12:09	12:14	0:05	TRANSFORMER FAULT
228	8-Apr-20	TUMKUR	66	TR-2	TAVAREKERE(H)_66	9:58	10:11	0:13	TRANSFORMER FAULT
229	8-Apr-20	TUMKUR	110	GUNGURMALE110-KB CROSS220	GUNGURMALE_110	12:06	14:16	2:09	LINE CLEAR AVAILED
230	8-Apr-20	TUMKUR	110	TR-1	GUNGURMALE_110	12:06	14:16	2:09	LINE CLEAR AVAILED
231	8-Apr-20	TUMKUR	110	TR-2	SAMPIGE_110	6:16	6:36	0:19	TRANSFORMER FAULT
232	9-Apr-20	BAGALKOT	110	110/11KV,HV1	THORVI_110	9:30	10:20	0:50	LINE CLEAR AVAILED
233	9-Apr-20	BAGALKOT	110	110/11KV,HV1&2	RATTIHALI_110	17:50	17:57	0:07	HAND TRIPPED
234	9-Apr-20	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	10:30	10:45	0:15	TRANSFORMER FAULT
235	9-Apr-20	BAGALKOT	110	110/11KV,HV2&3	GULEDAGUDDA_110	14:37	15:00	0:23	LINE CLEAR AVAILED
236	9-Apr-20	BAGALKOT	110	110/11KV,HV3	TIKOTA_110	10:35	10:46	0:11	TRANSFORMER FAULT
237	9-Apr-20	BAGALKOT	110	110/33KV,HV1	GULEDAGUDDA_110,ACME SOLAR_33,KAMATAGI_33,SHIRUR_33	14:37	15:00	0:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
238	9-Apr-20	BAGALKOT	110	110/33KV,HV2&HV3	HANAGAL_110,BOMMANALLI_33,AKKIALUR_33,BELAGALPET_33,LAXMIPUR	8:05	8:13	0:08	TRANSFORMER FAULT
239	9-Apr-20	BAGALKOT	110	110/33KV,HV2&HV3	HANAGAL_110,BOMMANALLI_33,AKKIALUR_33,BELAGALPET_33,LAXMIPUR	9:58	10:05	0:07	TRANSFORMER FAULT
240	9-Apr-20	BAGALKOT	110	110/33KV,HV2&HV3	HANAGAL_110,BOMMANALLI_33,AKKIALUR_33,BELAGALPET_33,LAXMIPUR	12:35	12:45	0:10	TRANSFORMER FAULT
241	9-Apr-20	BAGALKOT	110	110/33KV,HV3	RATTIHALI_110,HALLUR_33,MASUR_33	17:50	17:57	0:07	HAND TRIPPED
242	9-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,DULKHED_33,HALSANGI_33,NEVARGI_33	7:20	7:31	0:11	TRANSFORMER FAULT
243	9-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,DULKHED_33,HALSANGI_33,NEVARGI_33	9:11	9:15	0:04	TRANSFORMER FAULT
244	9-Apr-20	BAGALKOT	110	BAGALKOT220-GULEDAGUDDA	GULEDAGUDDA_110	13:36	13:50	0:14	LINE CLEAR AVAILED
245	9-Apr-20	BAGALKOT	110	BAGALKOT220-GULEDAGUDDA	GULEDAGUDDA_110	14:37	15:00	0:23	LINE CLEAR AVAILED
246	9-Apr-20	BAGALKOT	110	BAGALKOT220-GULEDAGUDDA	GULEDAGUDDA_110	12:45	13:00	0:15	LINE FAULT
247	9-Apr-20	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	0:00	2:46	2:46	LINE CLEAR AVAILED
248	9-Apr-20	BAGALKOT	110	GAJENDRAGAD1-RON	RON_110	5:23	8:20	2:57	LINE FAULT
249	9-Apr-20	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	15:51	17:50	1:59	LINE CLEAR AVAILED
250	9-Apr-20	BAGALKOT	110	HUBLI-RAMANAKOPPA	RAMANAKOPPA_110	13:31	20:42	7:11	LINE FAULT
251	9-Apr-20	BAGALKOT	110	KUDUCHI220-AINAPUR(KUDUCHI110)	KUDUCHI_110	15:07	16:21	1:14	LINE FAULT
252	9-Apr-20	BAGALKOT	220	220/110KV,HV1	HAVERI_220	15:01	16:01	1:00	LINE CLEAR AVAILED
253	9-Apr-20	BAGALKOT	220	220/110KV,HV2,LV2	RANEBENNUR_220,HIREKERUR_110,GUTTAL_110,HONNATTI_110,TUMMINAKATTI_110,BYADAGI_110	17:30	18:16	0:46	TRANSFORMER FAULT
254	9-Apr-20	BAGALKOT	220	HARTI1&2-GADAG	GADAG_220	10:56	23:59	13:03	LINE CLEAR AVAILED
255	9-Apr-20	BAGALKOT	220	HARTI1-BIDNAL	BIDNAL_220	11:39	23:59	12:20	LINE CLEAR AVAILED
256	9-Apr-20	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	13:22	16:44	3:22	LINE FAULT
257	9-Apr-20	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	13:07	15:01	1:54	LINE FAULT
258	9-Apr-20	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	21:25	21:30	0:05	LOAD CHANGE OVER
259	9-Apr-20	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	18:36	19:12	0:36	MAIN SUPPLY FAILURE
260	9-Apr-20	BENGALURU	66	CHELUR - CHINTAMANI 220	CHELUR	10:10	10:15	0:05	LINE CLEAR AVAILED
261	9-Apr-20	BENGALURU	66	CHINTAMANI 66 - CHINTAMANI 220	CHINTAMANI 66	15:49	15:50	0:01	LINE CLEAR AVAILED
262	9-Apr-20	BENGALURU	66	HOSKOTE 220 - DG4	GRINDWELL(EHT)	19:39	19:50	0:11	LINE FAULT
263	9-Apr-20	BENGALURU	66	HOSKOTE 220 - DG4	GRINDWELL(EHT)	20:41	23:14	2:33	LINE FAULT
264	9-Apr-20	BENGALURU	66	HOSKOTE 220 - HBR LAYOUT	HBR LAYOUT	22:40	23:08	0:28	LINE CLEAR AVAILED
265	9-Apr-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO,NANDAGUDI	17:49	18:09	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
266	9-Apr-20	BENGALURU	66	HV1	VOLVO	19:44	19:54	0:10	TRANSFORMER FAULT
267	9-Apr-20	BENGALURU	66	HV1	TK HALLI 220	20:48	20:53	0:05	TRANSFORMER FAULT
268	9-Apr-20	BENGALURU	66	HV1	RR NAGAR	20:10	20:16	0:05	LOAD CHANGE OVER
269	9-Apr-20	BENGALURU	66	HV1	MALLASANDRA	10:40	11:18	0:38	LINE CLEAR AVAILED
270	9-Apr-20	BENGALURU	66	HV1	CHAKKAVELU	15:35	15:56	0:21	TRANSFORMER FAULT
271	9-Apr-20	BENGALURU	66	HV1	CHELUR	10:06	10:16	0:10	TRANSFORMER FAULT
272	9-Apr-20	BENGALURU	66	HV1	ISRO LAYOUT	14:40	16:40	2:00	LINE CLEAR AVAILED
273	9-Apr-20	BENGALURU	66	HV1	ISRO LAYOUT	20:39	20:53	0:14	HAND TRIPPED
274	9-Apr-20	BENGALURU	66	HV2	MALLASANDRA	10:40	10:57	0:17	LINE CLEAR AVAILED
275	9-Apr-20	BENGALURU	66	HV2	HONNIGANAHALLI	20:04	20:40	0:36	TRANSFORMER FAULT
276	9-Apr-20	BENGALURU	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	18:36	19:36	1:00	MAIN SUPPLY FAILURE
277	9-Apr-20	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	18:36	18:57	0:21	LINE CLEAR AVAILED
278	9-Apr-20	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	18:36	18:51	0:15	LINE CLEAR AVAILED
279	9-Apr-20	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	18:53	18:59	0:06	LINE CLEAR AVAILED
280	9-Apr-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:29	15:38	0:09	LINE FAULT
281	9-Apr-20	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY PH-2 SEC- 2	ELECTRONIC CITY PH-2 SEC-2, BIOCON	18:14	19:05	0:51	LINE FAULT
282	9-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	18:36	19:44	1:08	MAIN SUPPLY FAILURE
283	9-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	10:28	10:36	0:07	LOAD CHANGE OVER
284	9-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	18:36	19:00	0:23	MAIN SUPPLY FAILURE
285	9-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	18:36	19:30	0:53	MAIN SUPPLY FAILURE
286	9-Apr-20	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:54	6:10	0:16	LINE FAULT
287	9-Apr-20	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:52	20:24	0:31	LINE FAULT
288	9-Apr-20	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:35	20:56	0:20	LINE FAULT
289	9-Apr-20	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	22:32	23:06	0:34	LINE FAULT
290	9-Apr-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:52	20:35	0:42	LINE FAULT
291	9-Apr-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:35	23:59	3:23	LINE FAULT
292	9-Apr-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	5:53	6:10	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
293	9-Apr-20	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	2:52	3:01	0:09	LINE FAULT
294	9-Apr-20	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	21:56	22:18	0:21	MAIN SUPPLY FAILURE
295	9-Apr-20	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY	ELECTRONIC CITY, INFOSYS	18:02	19:18	1:16	LINE CLEAR AVAILED
296	9-Apr-20	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	8:30	10:47	2:17	LINE FAULT
297	9-Apr-20	BENGALURU	220	HV1	VRISHBHAVATHI 220	21:56	22:25	0:28	TRANSFORMER FAULT
298	9-Apr-20	BENGALURU	220	HV1	VRISHBHAVATHI 220	21:56	22:25	0:28	TRANSFORMER FAULT
299	9-Apr-20	BENGALURU	220	HV1	YARANDANAHALLI 220	18:02	23:59	5:57	TRANSFORMER FAULT
300	9-Apr-20	BENGALURU	220	HV2	SUBRAMANYAPURA 220	18:36	19:32	0:55	MAIN SUPPLY FAILURE
301	9-Apr-20	BENGALURU	220	HV3	SUBRAMANYAPURA 220	18:36	19:38	1:01	MAIN SUPPLY FAILURE
302	9-Apr-20	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220, SUBRAMANYAPURA 220	18:36	18:46	0:10	LINE FAULT
303	9-Apr-20	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220, SUBRAMANYAPURA 220	18:54	18:57	0:03	LINE CLEAR AVAILED
304	9-Apr-20	BENGALURU	220	KHODAYS 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	18:36	18:46	0:10	LINE FAULT
305	9-Apr-20	BENGALURU	220	SUBRAMANYAPURA 220 - SOMANAHALLI 220	SUBRAMANYAPURA 220	18:36	18:54	0:17	LINE FAULT
306	9-Apr-20	BENGALURU	220	SUBRAMANYAPURA 220 - SOMANAHALLI 220	SUBRAMANYAPURA 220	18:54	19:30	0:36	LINE FAULT
307	9-Apr-20	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	20:20	20:25	0:05	TRANSFORMER FAULT
308	9-Apr-20	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110	21:23	21:36	0:13	LINE FAULT
309	9-Apr-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	22:13	22:20	0:07	LINE FAULT
310	9-Apr-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110	9:55	10:08	0:13	LINE FAULT
311	9-Apr-20	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARTAGI_110,SREERAMNAGAR_110, GANGAVATHI_110,VENKATGIRI_110	15:40	15:55	0:15	LINE FAULT
312	9-Apr-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	21:45	21:55	0:10	LINE FAULT
313	9-Apr-20	GULBARGA	220	SHAHPUR-SEDAM	SHAHPUR_110	12:50	13:42	0:52	LINE FAULT
314	9-Apr-20	GULBARGA	220	SHAHPUR-SEDAM	SHAHPUR_110	14:00	17:46	3:46	LINE FAULT
315	9-Apr-20	GULBARGA	400	YTPS-BPS1	BPS_400	8:20	14:26	6:06	NFBC ISSUED
316	9-Apr-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	9:39	12:55	3:16	NFBC ISSUED
317	9-Apr-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	9:33	12:55	3:22	MAIN SUPPLY FAILURE
318	9-Apr-20	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	9:32	15:53	6:21	LINE CLEAR AVAILED
319	9-Apr-20	HASSAN	110	JOG110-MGHE	JOG_110	9:00	15:53	6:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
320	9-Apr-20	HASSAN	110	JOG-JLT3	gen_mghe	8:58	15:53	6:55	LINE CLEAR AVAILED
321	9-Apr-20	HASSAN	110	JOG-JST1	gen_mghe	8:58	15:53	6:55	LINE CLEAR AVAILED
322	9-Apr-20	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	15:31	15:33	0:02	HAND TRIPPED
323	9-Apr-20	HASSAN	110	SAGARA-JST1	SAGARA_110	8:58	13:39	4:41	LINE CLEAR AVAILED
324	9-Apr-20	MYSORE	66	220kV TKHALLI-MANDYA M1 LINE	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	5:53	6:11	0:18	LINE FAULT
325	9-Apr-20	MYSORE	66	220kV TKHALLI-MANDYA M1 LINE	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	5:53	6:11	0:18	LINE FAULT
326	9-Apr-20	MYSORE	66	220kV TKHALLI-MANDYA M1 LINE	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	19:50	20:48	0:58	LINE FAULT
327	9-Apr-20	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	23:27	23:37	0:09	LINE FAULT
328	9-Apr-20	MYSORE	66	HV1	JAKKANAHALLY_66	13:40	14:00	0:20	HAND TRIPPED
329	9-Apr-20	MYSORE	66	HV1	KRPET_220	14:10	14:25	0:15	TRANSFORMER FAULT
330	9-Apr-20	MYSORE	66	HV2	HUNSUR_66	9:02	15:06	6:03	LINE CLEAR AVAILED
331	9-Apr-20	MYSORE	66	HV2	KMDODDI_66	19:44	20:30	0:46	TRANSFORMER FAULT
332	9-Apr-20	MYSORE	66	HV3	KUSHALANAGARA_66	10:31	11:21	0:49	LINE CLEAR AVAILED
333	9-Apr-20	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66	20:18	22:15	1:57	LINE FAULT
334	9-Apr-20	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66	22:15	0:00	1:45	NFBC ISSUED
335	9-Apr-20	MYSORE	66	KUSHALNAGARA-SOMWARPETE	SOMWARPETE_33	11:45	11:49	0:04	LINE FAULT
336	9-Apr-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	7:17	7:32	0:15	LINE FAULT
337	9-Apr-20	MYSORE	66	VAJMANGALA-KADKOLA 1	AYRALLI_66 MARADIHUNDI_66	18:52	19:04	0:12	LINE FAULT
338	9-Apr-20	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	17:52	17:56	0:04	HAND TRIPPED
339	9-Apr-20	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	10:13	10:28	0:15	LINE FAULT
340	9-Apr-20	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	5:15	5:48	0:32	HAND TRIPPED
341	9-Apr-20	TUMKUR	66	TR-1	LINGADAHALLI_66 SHIMOGA	10:05	10:15	0:10	TRANSFORMER FAULT
342	9-Apr-20	TUMKUR	110	TR-1	TIMMANAHALLI_110	11:59	13:31	1:32	LINE CLEAR AVAILED
343	10-Apr-20	BAGALKOT	110	110/11KV,HV3	HANGAL_110	15:53	15:57	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
344	10-Apr-20	BAGALKOT	110	GAJENDRAGAD-RON 1	GAJENDRAGAD_110	0:00	18:26	18:26	LINE CLEAR AVAILED
345	10-Apr-20	BAGALKOT	110	GAJENDRAGAD-RON 2	GAJENDRAGAD_110	0:00	18:26	18:26	LINE CLEAR AVAILED
346	10-Apr-20	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	15:44	15:53	0:09	LINE FAULT
347	10-Apr-20	BAGALKOT	110	MK HUBLI220-MK HUBLI	MKHUBLI_110	17:21	17:35	0:14	LINE FAULT
348	10-Apr-20	BAGALKOT	220	220/110KV, HV2&LV2	RANEENNUR_220	15:05	17:40	2:35	LINE CLEAR AVAILED
349	10-Apr-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_110	8:21	23:59	15:38	LINE CLEAR AVAILED
350	10-Apr-20	BAGALKOT	220	HARTI1-BIDNAL	BIDNAL_220	0:00	15:13	15:13	LINE CLEAR AVAILED
351	10-Apr-20	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	18:21	22:37	4:16	LINE FAULT
352	10-Apr-20	BENGALURU	66	A STATION 220 - A STATION	A STATION	2:30	2:35	0:05	LOAD CHANGE OVER
353	10-Apr-20	BENGALURU	66	DABUSPETE 220 - TYAMAGONDLU	TYAMAGONDLU	14:37	14:50	0:13	LINE FAULT
354	10-Apr-20	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY,INFOSYS	8:25	8:31	0:06	LOAD CHANGE OVER
355	10-Apr-20	BENGALURU	66	GOKULA - BEL	BEL(EHT)	11:26	13:55	2:29	LINE CLEAR AVAILED
356	10-Apr-20	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	0:12	0:40	0:28	LINE FAULT
357	10-Apr-20	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	3:25	3:35	0:10	LINE FAULT
358	10-Apr-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO,NANDAGUDI	8:15	8:25	0:10	LINE FAULT
359	10-Apr-20	BENGALURU	66	HV1	BAGHMANE WORLD TECH PARK	12:39	12:45	0:06	LINE CLEAR AVAILED
360	10-Apr-20	BENGALURU	66	HV1	TK HALLI 220	15:26	15:31	0:04	TRANSFORMER FAULT
361	10-Apr-20	BENGALURU	66	HV1	THAYALUR	17:32	18:33	1:01	LINE CLEAR AVAILED
362	10-Apr-20	BENGALURU	66	HV1	RANGANDODDI	11:54	12:05	0:10	LINE CLEAR AVAILED
363	10-Apr-20	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	13:28	13:29	0:01	LINE CLEAR AVAILED
364	10-Apr-20	BENGALURU	66	HV2	B G ROAD	10:40	10:45	0:05	LINE CLEAR AVAILED
365	10-Apr-20	BENGALURU	66	HV2	TEMAGONDALU	15:04	15:50	0:45	LINE CLEAR AVAILED
366	10-Apr-20	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	RAMANAGARA,MELLEHALLI,JALAMANG ALA,CHIKKAGANGANAWADI,KUTAGALL U	13:27	13:37	0:10	LINE FAULT
367	10-Apr-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	9:07	9:21	0:13	LINE CLEAR AVAILED
368	10-Apr-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:31	11:52	0:21	LINE CLEAR AVAILED
369	10-Apr-20	BENGALURU	66	VIDYANAGAR - BIAL 220	VIDYANAGAR, HENNUR CROSS	12:00	12:10	0:10	LINE CLEAR AVAILED
370	10-Apr-20	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	20:53	21:02	0:09	LINE FAULT
371	10-Apr-20	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	21:52	21:59	0:07	LINE FAULT
372	10-Apr-20	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	23:48	23:58	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
373	10-Apr-20	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	23:30	23:35	0:05	LINE FAULT
374	10-Apr-20	GULBARGA	110	KAPNOOR-HUMNNABAD2	ALAND_110, KADAGANCHI_110	19:03	19:13	0:10	LINE FAULT
375	10-Apr-20	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110, HIREGONNAGAR_110, HANUMANAL_110	18:14	18:58	0:44	LINE CLEAR AVAILED
376	10-Apr-20	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	10:55	11:03	0:08	LINE FAULT
377	10-Apr-20	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARTAGI_110,SREERAMNAGAR_110, GANGAVATHI_110,VENKATGIRI_110	13:28	13:38	0:10	LINE FAULT
378	10-Apr-20	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARTAGI_110,SREERAMNAGAR_110, GANGAVATHI_110,VENKATGIRI_110	13:38	20:20	6:42	LINE CLEAR AVAILED
379	10-Apr-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB,BTPS_WATERWORKS	17:35	20:30	2:55	LINE CLEAR AVAILED
380	10-Apr-20	GULBARGA	220	HV1,HV2	ITTAGI_220	13:22	14:42	1:20	TRANSFORMER FAULT
381	10-Apr-20	GULBARGA	220	ITTAGI-NEELGUNDA	NEELGUNDA_220	13:22	14:01	0:39	LINE FAULT
382	10-Apr-20	GULBARGA	400	YTPS-BPS2	BPS_400	9:30	13:50	4:20	NFBC ISSUED
383	10-Apr-20	HASSAN	66	HV1	BYACHANAHALLI_66	13:00	0:00	11:00	TRANSFORMER FAULT
384	10-Apr-20	HASSAN	66	HV2	HALEBEEDU_66	9:10	9:40	0:30	LINE CLEAR AVAILED
385	10-Apr-20	HASSAN	66	HV2	HALEBEEDU_66	9:43	10:44	1:01	LINE CLEAR AVAILED
386	10-Apr-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	16:28	16:40	0:12	LINE FAULT
387	10-Apr-20	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	13:07	13:35	0:28	LINE FAULT
388	10-Apr-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:19	13:15	2:56	LINE CLEAR AVAILED
389	10-Apr-20	HASSAN	110	HV1	KULASHEKARA_110	14:01	15:58	1:57	LINE CLEAR AVAILED
390	10-Apr-20	HASSAN	110	HV2	AJJAMPURA_110	13:32	14:03	0:31	LINE CLEAR AVAILED
391	10-Apr-20	HASSAN	110	HV2	ANAVATTI_110	16:30	16:35	0:05	TRANSFORMER FAULT
392	10-Apr-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:19	13:15	2:56	LINE CLEAR AVAILED
393	10-Apr-20	HASSAN	110	SAGARA-SAGARA	SAGARA_110	10:15	14:20	4:05	LINE CLEAR AVAILED
394	10-Apr-20	HASSAN	110	SAGARA-SAGARA	SAGARA_110	17:25	23:59	6:34	LINE CLEAR AVAILED
395	10-Apr-20	HASSAN	220	ARK2-SHMG	ARASIKERE_220	10:29	13:32	3:03	NFBC ISSUED
396	10-Apr-20	HASSAN	220	MRSSHM-HASSAN	MRSMG_220	10:29	13:31	3:02	LINE CLEAR AVAILED
397	10-Apr-20	MYSORE	66	HV1	BANANGADI_66	8:40	11:02	2:22	LINE CLEAR AVAILED
398	10-Apr-20	MYSORE	66	HV2	AKKIHEBBAL_66,	16:30	16:34	0:04	TRANSFORMER FAULT
399	10-Apr-20	MYSORE	66	HV3	KRPET_66	10:34	11:00	0:26	LINE CLEAR AVAILED
400	10-Apr-20	MYSORE	66	HV3	KRPET_66	12:16	13:27	1:11	LINE CLEAR AVAILED
401	10-Apr-20	MYSORE	66	HV3	KUSHALANAGARA_66	20:44	21:17	0:32	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
402	10-Apr-20	MYSORE	66	KIADB Mandya- TK Halli-KIADB Incoming Line	KOLKARANADODDI_66	0:00	3:07	3:07	NFBC ISSUED
403	10-Apr-20	MYSORE	66	KIADB Mandya- TK Halli-KIADB Incoming Line	KOLKARANADODDI_66	13:27	14:43	1:16	NFBC ISSUED
404	10-Apr-20	MYSORE	66	KM Doddi-MANDYA	KOLKARANADODDI_66	0:00	14:40	14:40	NFBC ISSUED
405	10-Apr-20	MYSORE	66	Mandya -M-3	BASARALU_66,BESAGARAHALLI_66, KOPPA_66, CHIKKA_MANDYA_66 HAMPAPURA_66	14:06	14:18	0:12	LINE FAULT
406	10-Apr-20	MYSORE	66	TUBINKERE-MC-2	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	12:09	12:19	0:10	LINE FAULT
407	10-Apr-20	MYSORE	66	TUBINKERE-MC-4	BASARALU_66, BESAGARAHALLI_66, KOPPA_66, 6 MANDYA_66 MALAVALLI_66 HADLI_66 CHIKKA_MANDYA_66 HAMPAPURA_66 KADKOTHANAHALLI_66	12:09	12:19	0:10	LINE FAULT
408	10-Apr-20	MYSORE	66	VAJMANGALA-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 MEGALAPURA_66 THUMBLA_66 TNARASIPURA_66 VYASRAJPURA_66	0:59	1:12	0:12	LINE FAULT
409	10-Apr-20	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	22:49	23:01	0:11	LINE FAULT
410	10-Apr-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:10	14:20	0:10	LINE FAULT
411	10-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	13:34	14:42	1:07	LINE CLEAR AVAILED
412	10-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	13:34	14:41	1:07	LINE CLEAR AVAILED
413	10-Apr-20	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	20:37	20:47	0:10	LINE FAULT
414	10-Apr-20	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	18:53	19:12	0:19	LINE FAULT
415	10-Apr-20	TUMKUR	66	TR-1	HIRIYUR_66	16:27	16:33	0:06	TRANSFORMER FAULT
416	10-Apr-20	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	18:53	19:08	0:14	TRANSFORMER FAULT
417	10-Apr-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	13:38	14:51	1:12	LINE CLEAR AVAILED
418	10-Apr-20	TUMKUR	110	TR-1	SHETYKERE_110	14:31	17:12	2:41	LINE CLEAR AVAILED
419	10-Apr-20	TUMKUR	110	TR-2	SAMPIGE_110	16:35	16:55	0:19	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
420	10-Apr-20	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	13:39	13:56	0:16	LINE FAULT
421	11-Apr-20	BAGALKOT	110	110/11KV,HV2	HUNAGUND_110AMINAGAD_33,KARADI_33,MYTRA_33	7:45	7:49	0:04	TRANSFORMER FAULT
422	11-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DULKED_33,NEVARGI_33	6:27	6:48	0:21	TRANSFORMER FAULT
423	11-Apr-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,DULKED_33,NEVARGI_33	9:11	9:17	0:06	TRANSFORMER FAULT
424	11-Apr-20	BAGALKOT	110	CHIKKODI2-RAIBAG	RAIBAG_110	4:44	10:35	5:51	LINE FAULT
425	11-Apr-20	BAGALKOT	110	GHATAPRABHA-BELGAUM	BELGAUM_110	1:41	2:01	0:20	LINE FAULT
426	11-Apr-20	BAGALKOT	110	RANEENNUR-HIREKERUR,GUTTAL,HONNATTI,TUMMINAKATTI	HIREKERUR_110,GUTTAL_110,HONNATTI_110,TUMMINAKATTI_110	4:00	4:21	0:21	HAND TRIPPED
427	11-Apr-20	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	0:00	11:23	11:23	LINE CLEAR AVAILED
428	11-Apr-20	BAGALKOT	220	BALLIGAVI(SHIROLKOPPA)-RANEENNUR	RANEENNUR_220	0:00	4:21	4:21	LINE CLEAR AVAILED
429	11-Apr-20	BAGALKOT	220	BALLIGAVI(SHIROLKOPPA)-RANEENNUR	RANEENNUR_220	11:04	14:16	3:12	LINE CLEAR AVAILED
430	11-Apr-20	BAGALKOT	220	BALLIGAVI(SHIROLKOPPA)-RANEENNUR	RANEENNUR_220	18:12	23:59	5:47	LINE CLEAR AVAILED
431	11-Apr-20	BAGALKOT	220	GUTTUR-RANEENNUR	RANEENNUR_220	4:00	11:04	7:04	LINE FAULT
432	11-Apr-20	BAGALKOT	220	SIRSI-HUBLI1&2	SIRSI_220	0:00	11:25	11:25	LINE CLEAR AVAILED
433	11-Apr-20	BAGALKOT	220	SIRSI-HUBLI1&2	SIRSI_220	15:02	23:59	8:57	LINE CLEAR AVAILED
434	11-Apr-20	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY PH-2 SEC-2	ELECTRONIC CITY, INFOSYS	17:07	17:14	0:07	LOAD CHANGE OVER
435	11-Apr-20	BENGALURU	66	HOSKOTE 220 - DG4	GRINDWELL(EHT)	4:43	4:52	0:09	LINE FAULT
436	11-Apr-20	BENGALURU	66	HV1	KEMPANAHALLI	3:18	3:28	0:10	TRANSFORMER FAULT
437	11-Apr-20	BENGALURU	66	HV1	ATTUR YELAHANKA	3:29	4:52	1:23	TRANSFORMER FAULT
438	11-Apr-20	BENGALURU	66	HV3	ADUGODI	6:11	6:14	0:03	LOAD CHANGE OVER
439	11-Apr-20	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	1:41	2:56	1:15	LINE FAULT
440	11-Apr-20	BENGALURU	66	VR DODDI - SOMANAHALLI 220	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	4:02	11:45	7:43	LINE FAULT
441	11-Apr-20	BENGALURU	220	HV1	HOODY 220	9:04	9:14	0:10	LOAD CHANGE OVER
442	11-Apr-20	BENGALURU	220	HV1	HOODY 220	14:29	14:48	0:19	LOAD CHANGE OVER
443	11-Apr-20	BENGALURU	220	HV3	HOODY 220	8:52	9:02	0:10	LOAD CHANGE OVER
444	11-Apr-20	BENGALURU	220	HV3	HOODY 220	13:57	14:02	0:05	LOAD CHANGE OVER
445	11-Apr-20	BENGALURU	220	HV4	HOODY 220	8:54	9:02	0:08	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
446	11-Apr-20	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	8:45	9:30	0:45	TRANSFORMER FAULT
447	11-Apr-20	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	13:10	13:40	0:30	LINE CLEAR AVAILED
448	11-Apr-20	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	5:00	5:50	0:50	LINE FAULT
449	11-Apr-20	GULBARGA	110	HV2	DEODURGA_110	16:20	17:00	0:40	TRANSFORMER FAULT
450	11-Apr-20	GULBARGA	110	KAPNOOR-HUMNNABAD2	ALAND_110, KADAGANCHI_110	13:55	14:00	0:05	LINE FAULT
451	11-Apr-20	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	13:00	13:13	0:13	LINE FAULT
452	11-Apr-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB,BTPS_WATERWORKS	5:50	6:00	0:10	LINE FAULT
453	11-Apr-20	GULBARGA	110	YELBURGA-KUSTAGI	YELBURGA_110	12:58	13:13	0:15	MAIN SUPPLY FAILURE
454	11-Apr-20	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	12:17	23:59	11:42	LINE CLEAR AVAILED
455	11-Apr-20	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	0:00	0:26	0:26	LINE CLEAR AVAILED
456	11-Apr-20	HASSAN	110	HV2	ANANDAPURA_110	8:26	8:48	0:22	LINE CLEAR AVAILED
457	11-Apr-20	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	8:59	10:52	1:53	LINE CLEAR AVAILED
458	11-Apr-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	6:10	10:06	3:56	LINE CLEAR AVAILED
459	11-Apr-20	HASSAN	220	SHRAVITY-TALAGUPPA3	sharavathy_gen	6:03	12:32	6:29	LINE FAULT
460	11-Apr-20	HASSAN	220	TALAGU-STRP3	TALAGUPPA_400	6:03	10:06	4:03	LINE FAULT
461	11-Apr-20	MYSORE	66	220kV KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	22:34	22:40	0:06	LINE FAULT
462	11-Apr-20	MYSORE	66	HV1	BETTADHAPURA_66	12:03	13:32	1:29	LINE CLEAR AVAILED
463	11-Apr-20	MYSORE	66	HV1	SHIVALLY_66	8:21	9:33	1:12	LINE CLEAR AVAILED
464	11-Apr-20	MYSORE	66	HV2	COWDALLI_66	9:58	10:08	0:09	TRANSFORMER FAULT
465	11-Apr-20	MYSORE	66	HV2	HAMPAPURA_66	11:58	12:19	0:20	TRANSFORMER FAULT
466	11-Apr-20	TUMKUR	66	DAVANGERE66-DAVANGERE SRS	DAVANAGERE_66	11:42	12:15	0:32	HAND TRIPPED
467	11-Apr-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	21:17	23:34	2:17	LINE CLEAR AVAILED
468	11-Apr-20	TUMKUR	66	CHELLUR-ANTHRASANAHALLI	CHELURU_66	21:04	23:38	2:33	LINE FAULT
469	11-Apr-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	DAVANGERE_SRS_220	11:42	12:15	0:32	HAND TRIPPED
470	11-Apr-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:42	12:21	0:39	HAND TRIPPED
471	11-Apr-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:42	12:15	0:32	HAND TRIPPED
472	11-Apr-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:38	6:47	0:08	HAND TRIPPED
473	11-Apr-20	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	11:42	12:20	0:37	HAND TRIPPED
474	11-Apr-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66	12:04	12:10	0:05	LINE FAULT
475	11-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:49	12:55	0:05	LINE FAULT
476	11-Apr-20	TUMKUR	66	TR-1	PAVAGADA_66	7:09	7:30	0:20	TRANSFORMER FAULT
477	11-Apr-20	TUMKUR	66	TR-2	CHELURU_66	21:04	23:38	2:33	TRANSFORMER FAULT
478	11-Apr-20	TUMKUR	66	TR-2	KUNIGAL_66	16:04	17:17	1:13	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
479	11-Apr-20	TUMKUR	66	TR-3	HARIYABBE_66	12:01	12:06	0:05	TRANSFORMER FAULT
480	11-Apr-20	TUMKUR	110	TR-2	SAMPIGE_110	0:06	0:20	0:13	TRANSFORMER FAULT
481	11-Apr-20	TUMKUR	110	TR-2	SAMPIGE_110	12:02	12:35	0:33	TRANSFORMER FAULT
482	12-Apr-20	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	17:01	18:17	1:16	LINE CLEAR AVAILED
483	12-Apr-20	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	9:48	9:50	0:02	TRANSFORMER FAULT
484	12-Apr-20	BAGALKOT	110	110/11KV, HV2	PG HUNSHYAL_110	10:57	11:22	0:25	HAND TRIPPED
485	12-Apr-20	BAGALKOT	110	CHIKKODI220-RAIBAG	RAIBAG_110	3:45	3:56	0:11	LINE FAULT
486	12-Apr-20	BAGALKOT	110	HUBLI220-KALGHATAGI	KALGHATAGI_110	15:38	16:06	0:28	LINE FAULT
487	12-Apr-20	BAGALKOT	110	INDI-HIREBEVNUR	HIREBEVNUR_110, RODAGI_110	13:30	13:58	0:28	LINE CLEAR AVAILED
488	12-Apr-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	15:57	23:59	8:02	LINE CLEAR AVAILED
489	12-Apr-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	15:56	15:56	LINE CLEAR AVAILED
490	12-Apr-20	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY, INFOSYS	7:25	7:30	0:05	LOAD CHANGE OVER
491	12-Apr-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	7:21	7:31	0:10	LINE FAULT
492	12-Apr-20	BENGALURU	66	HV1	HULLENAHALLI	14:07	14:14	0:07	TRANSFORMER FAULT
493	12-Apr-20	BENGALURU	66	HV1	VOLVO	14:39	15:03	0:24	TRANSFORMER FAULT
494	12-Apr-20	BENGALURU	66	HV2	BTM 4TH PHASE	6:55	7:14	0:19	TRANSFORMER FAULT
495	12-Apr-20	BENGALURU	66	HV2	BYADRAHALLI	10:35	10:40	0:05	LINE CLEAR AVAILED
496	12-Apr-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	11:00	14:21	3:20	LINE CLEAR AVAILED
497	12-Apr-20	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	9:44	9:50	0:05	LOAD CHANGE OVER
498	12-Apr-20	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	8:22	9:39	1:16	LINE FAULT
499	12-Apr-20	GULBARGA	110	HV2	DEODURGA_110	14:20	14:38	0:18	TRANSFORMER FAULT
500	12-Apr-20	GULBARGA	220	ALIPUR-RAGALPADU	ALIPUR_220	7:17	7:40	0:23	LINE FAULT
501	12-Apr-20	GULBARGA	220	HUMMNABAD-SEDAM1,2	HUMNABAD_220	7:03	7:17	0:14	LINE FAULT
502	12-Apr-20	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	13:41	14:06	0:25	LINE CLEAR AVAILED
503	12-Apr-20	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	14:19	14:48	0:29	LINE FAULT
504	12-Apr-20	GULBARGA	220	SEDAM-ORIENT	ORIENT CEMENTS_IPP	7:05	7:45	0:40	LINE FAULT
505	12-Apr-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	14:51	14:56	0:05	LINE FAULT
506	12-Apr-20	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	15:04	16:21	1:17	MAIN SUPPLY FAILURE
507	12-Apr-20	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	15:00	16:19	1:19	MAIN SUPPLY FAILURE
508	12-Apr-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	15:04	16:30	1:26	MAIN SUPPLY FAILURE
509	12-Apr-20	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	14:59	16:18	1:19	LINE FAULT
510	12-Apr-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	15:48	16:30	0:42	LINE FAULT
511	12-Apr-20	HASSAN	110	MANIPALHIRIYADKA	MANIPAL_110	19:03	19:21	0:18	HAND TRIPPED
512	12-Apr-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	15:48	16:31	0:43	LINE FAULT
513	12-Apr-20	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	15:20	16:03	0:43	LINE FAULT
514	12-Apr-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	14:59	16:20	1:21	LINE FAULT
515	12-Apr-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:17	15:29	0:12	LINE FAULT
516	12-Apr-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	14:59	16:19	1:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
517	12-Apr-20	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	18:42	18:48	0:05	LINE FAULT
518	12-Apr-20	MYSORE	66	HV1	BANANGADI_66	9:10	10:10	1:00	TRANSFORMER FAULT
519	12-Apr-20	MYSORE	66	HV1	MANDYA_66	10:00	10:10	0:10	TRANSFORMER FAULT
520	12-Apr-20	MYSORE	66	HV2	BANANGADI_66	9:10	10:10	1:00	TRANSFORMER FAULT
521	12-Apr-20	MYSORE	66	HV3	KUSHALANAGARA_66	11:00	11:17	0:17	LINE CLEAR AVAILED
522	12-Apr-20	MYSORE	66	MANDYA-MC-3	BASARALU_66,BESAGARAHALLI_66, KOPPA_66, CHIKKA_MANDYA_66 HAMPAPURA_66	8:26	8:33	0:07	LINE FAULT
523	12-Apr-20	MYSORE	66	MEGHALAPURA -SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 TNARASIPURA_66 VYASRAJPURA_66	13:57	14:06	0:09	LINE FAULT
524	12-Apr-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	14:01	14:33	0:32	MAIN SUPPLY FAILURE
525	12-Apr-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	14:26	14:31	0:04	MAIN SUPPLY FAILURE
526	12-Apr-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:09	12:11	0:01	HAND TRIPPED
527	12-Apr-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:58	13:02	0:03	HAND TRIPPED
528	12-Apr-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66	12:09	12:11	0:01	HAND TRIPPED
529	12-Apr-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66	12:58	13:01	0:03	HAND TRIPPED
530	12-Apr-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	12:58	13:02	0:04	HAND TRIPPED
531	12-Apr-20	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	7:22	7:32	0:10	HAND TRIPPED
532	12-Apr-20	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	7:22	7:31	0:08	HAND TRIPPED
533	12-Apr-20	TUMKUR	66	MADHUGIRI 220kv- MEDIGESHI	MADHUGIRI_220	7:22	7:33	0:10	HAND TRIPPED
534	12-Apr-20	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	7:22	7:36	0:14	HAND TRIPPED
535	12-Apr-20	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	SIRA_66,GULIGENAHALLI_66,	7:22	7:25	0:03	HAND TRIPPED
536	12-Apr-20	TUMKUR	220	HONNALLI 220kv- SUZLON1	SUZLON_IPP_66	12:09	13:49	1:39	LINE FAULT
537	12-Apr-20	TUMKUR	220	HONNALLI 220kv- SUZLON1	SUZLON_IPP_66	13:50	14:51	1:01	LINE CLEAR AVAILED
538	12-Apr-20	TUMKUR	220	HONNALLI 220kv- SUZLON2	SUZLON_IPP_66	12:09	14:37	2:27	LINE FAULT
539	12-Apr-20	TUMKUR	220	HONNALLI 220kv- SUZLON2	SUZLON_IPP_66	13:50	14:51	1:01	LINE CLEAR AVAILED
540	12-Apr-20	TUMKUR	220	TR-2	MADHUGIRI_220	6:30	7:22	0:51	TRANSFORMER FAULT
541	13-Apr-20	BAGALKOT	110	110/11KV,HV1	ZALKI_110	20:06	21:00	0:54	HAND TRIPPED
542	13-Apr-20	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	11:18	11:47	0:29	LINE CLEAR AVAILED
543	13-Apr-20	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	14:55	15:04	0:09	TRANSFORMER FAULT
544	13-Apr-20	BAGALKOT	110	110/11KV,HV2	TIKOTA_110	21:37	21:42	0:05	TRANSFORMER FAULT
545	13-Apr-20	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	16:23	16:40	0:17	TRANSFORMER FAULT
546	13-Apr-20	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110,KEROSHI_33,KERUR_33	13:58	14:19	0:21	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
547	13-Apr-20	BAGALKOT	110	ITNAL-HIDIKAL	HIDIKAL_110	0:00	19:37	19:37	LINE CLEAR AVAILED
548	13-Apr-20	BAGALKOT	110	ITNAL-HIDIKAL	HIDIKAL_110	20:31	20:37	0:06	HAND TRIPPED
549	13-Apr-20	BAGALKOT	110	SHIVAKUMAR SUGARS-HIREBEVANUR	HIREBEVANUR_110	8:48	12:35	3:47	LINE CLEAR AVAILED
550	13-Apr-20	BAGALKOT	220	SHARAVATHI 1&2	SIRSI_220	12:35	23:59	11:24	LINE CLEAR AVAILED
551	13-Apr-20	BAGALKOT	220	SIRSI-HUBLI1&2	SIRSI_220	0:00	12:37	12:37	LINE CLEAR AVAILED
552	13-Apr-20	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	6:38	6:41	0:03	LINE FAULT
553	13-Apr-20	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	11:07	11:12	0:05	LOAD CHANGE OVER
554	13-Apr-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	12:03	12:52	0:49	LINE CLEAR AVAILED
555	13-Apr-20	BENGALURU	66	HV1	THAYALUR	11:38	12:42	1:03	LINE CLEAR AVAILED
556	13-Apr-20	BENGALURU	66	HV1	HOSPALYA CIRCLE	14:48	15:01	0:12	TRANSFORMER FAULT
557	13-Apr-20	BENGALURU	66	HV2	MULABAGALU	23:41	23:59	0:18	TRANSFORMER FAULT
558	13-Apr-20	BENGALURU	66	HV2	BANASHANKARI	10:56	11:00	0:04	LINE CLEAR AVAILED
559	13-Apr-20	BENGALURU	66	HV2	JAYADEVA	15:08	15:32	0:24	LINE CLEAR AVAILED
560	13-Apr-20	BENGALURU	66	HV2	REMCO	12:00	12:04	0:04	LINE CLEAR AVAILED
561	13-Apr-20	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	11:38	12:09	0:30	LINE FAULT
562	13-Apr-20	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU,CHANDRAPPA CIRCLE	11:40	11:45	0:05	LOAD CHANGE OVER
563	13-Apr-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	9:50	10:06	0:15	LINE FAULT
564	13-Apr-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	12:12	12:22	0:10	LINE CLEAR AVAILED
565	13-Apr-20	GULBARGA	110	HALBURGA-HALLIKHED	HALLIKHED_110	19:10	19:30	0:20	LINE FAULT
566	13-Apr-20	GULBARGA	110	HV1	CHINCHOLI_110	19:15	19:23	0:08	LOAD CURTAILMENT
567	13-Apr-20	GULBARGA	110	HV1, HV2	YELBURGA_110	14:20	15:30	1:10	LINE CLEAR AVAILED
568	13-Apr-20	GULBARGA	110	HV2	ALAND_110	19:25	19:35	0:10	LOAD CURTAILMENT
569	13-Apr-20	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110, HIREGONNAGAR_110, HANUMANAL_110	15:45	15:56	0:11	LINE FAULT
570	13-Apr-20	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110, MANVI_110	1:45	1:55	0:10	LINE FAULT
571	13-Apr-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:56	22:07	0:11	LINE FAULT
572	13-Apr-20	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPUR_110	18:35	18:45	0:10	LINE FAULT
573	13-Apr-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB,BTPS_WATERWORKS	2:35	2:45	0:10	LINE FAULT
574	13-Apr-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	1:00	1:15	0:15	LINE FAULT
575	13-Apr-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	20:35	20:45	0:10	LINE FAULT
576	13-Apr-20	GULBARGA	110	SINDHANOOR-RAICHUR2	KURDICROSS_110	21:00	21:10	0:10	LINE FAULT
577	13-Apr-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	0:33	0:46	0:13	LINE FAULT
578	13-Apr-20	GULBARGA	220	HV1	HALBURGA_220	19:10	19:30	0:20	TRANSFORMER FAULT
579	13-Apr-20	GULBARGA	220	HV2	KUSTAGI_220	16:00	20:35	4:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
580	13-Apr-20	HASSAN	66	HV1	K_BYRAPURA_66	12:05	14:04	1:59	LINE CLEAR AVAILED
581	13-Apr-20	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	12:25	13:32	1:07	LINE CLEAR AVAILED
582	13-Apr-20	HASSAN	66	HV1	DODDAKADANUR_66	9:35	9:55	0:20	TRANSFORMER FAULT
583	13-Apr-20	HASSAN	66	HV1	HANGARANAHALLY_66	14:01	14:51	0:50	LINE CLEAR AVAILED
584	13-Apr-20	HASSAN	66	HV2	MAGGE_66	11:12	13:05	1:53	LINE CLEAR AVAILED
585	13-Apr-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:20	12:30	2:10	NFBC ISSUED
586	13-Apr-20	HASSAN	110	HV1	ARASIKERE_110	9:15	10:07	0:52	LINE CLEAR AVAILED
587	13-Apr-20	HASSAN	110	HV1	ARASIKERE_110	14:30	15:15	0:45	LINE CLEAR AVAILED
588	13-Apr-20	HASSAN	110	HV2	AJJAMPURA_110	9:19	10:17	0:58	LINE CLEAR AVAILED
589	13-Apr-20	HASSAN	110	HV2	KARAYA_110	21:12	21:30	0:18	TRANSFORMER FAULT
590	13-Apr-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:20	12:26	2:06	LINE CLEAR AVAILED
591	13-Apr-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:22	11:47	1:25	LINE CLEAR AVAILED
592	13-Apr-20	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:25	16:25	2:00	LINE FAULT
593	13-Apr-20	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	22:14	23:59	1:45	LINE FAULT
594	13-Apr-20	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	22:14	23:59	1:45	LINE FAULT
595	13-Apr-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:21	11:48	1:27	LINE CLEAR AVAILED
596	13-Apr-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	11:39	17:32	5:53	LINE CLEAR AVAILED
597	13-Apr-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:07	23:59	5:52	LINE CLEAR AVAILED
598	13-Apr-20	MYSORE	66	HV1	DODDABYADARAHALLI_66	11:23	12:16	0:52	LINE CLEAR AVAILED
599	13-Apr-20	MYSORE	66	HV1	VAJAMANGALA_220	10:04	11:11	1:07	LINE CLEAR AVAILED
600	13-Apr-20	MYSORE	66	HV2	BOGADHI_66	6:27	8:32	2:05	TRANSFORMER FAULT
601	13-Apr-20	MYSORE	66	KUSHALANAGARA220-MYSORE-2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	8:21	8:31	0:09	LINE FAULT
602	13-Apr-20	MYSORE	66	Mandya-O/G MC3	CHIKKA_MANDYA_66	6:24	7:54	1:30	LINE CLEAR AVAILED
603	13-Apr-20	MYSORE	66	MEGALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	18:59	19:13	0:14	LINE FAULT
604	13-Apr-20	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	9:44	9:57	0:12	LINE FAULT
605	13-Apr-20	TUMKUR	66	BHAKTHARA HALLI -ANCHEPALYA	BHAKTHARAHALLI_66	8:37	9:01	0:23	HAND TRIPPED
606	13-Apr-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	13:28	13:34	0:05	HAND TRIPPED
607	13-Apr-20	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	19:03	20:56	1:52	LINE FAULT
608	13-Apr-20	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	19:03	20:56	1:52	LINE FAULT
609	13-Apr-20	TUMKUR	66	THOVINAKERE-ANTHRASANAHALLI	THOVINAKERE_66	15:09	15:21	0:11	HAND TRIPPED
610	13-Apr-20	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	8:39	9:01	0:21	HAND TRIPPED
611	13-Apr-20	TUMKUR	66	TR-2	AVAREGERE_66	14:52	15:07	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
612	13-Apr-20	TUMKUR	66	TR-2	BENKIKERE_66	13:35	13:43	0:08	LINE CLEAR AVAILED
613	13-Apr-20	TUMKUR	66	TR-2	HONNUDIKE_66	13:41	16:35	2:54	LINE CLEAR AVAILED
614	13-Apr-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	15:26	17:28	2:02	LINE CLEAR AVAILED
615	13-Apr-20	TUMKUR	110	TR-2	SAMPIGE_110	13:10	13:43	0:32	LINE CLEAR AVAILED
616	13-Apr-20	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	HONNALLI_220	12:01	13:23	1:21	LINE CLEAR AVAILED
617	13-Apr-20	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	12:01	13:23	1:21	LINE CLEAR AVAILED