

400/220/110/66 kV TRANSMISSION OUTAGES FROM 26.04.22 TO 02.05.22

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	26-Apr-22	BAGALKOT	110	110/110KV,HV1	KUDUCHI_220	20:46	20:51	0:05	TRANSFORMER FAULT
2	26-Apr-22	BAGALKOT	110	110/110KV,HV2	KUD DHARWAD_110	8:35 (26.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
3	26-Apr-22	BAGALKOT	110	110/110KV,HV2	MAMADAPUR(B)_110	22:51	23:03	0:12	TRANSFORMER FAULT
4	26-Apr-22	BAGALKOT	110	110/110KV,HV2	SANKESHWAR_110	21:38	21:47	0:09	LINE CLEAR AVAILED
5	26-Apr-22	BAGALKOT	110	110/110KV,HV2	YELLAMANAWADI_110	10:34	12:12	1:38	LINE CLEAR AVAILED
6	26-Apr-22	BAGALKOT	110	110/110KV,HV2	YELPARHATTI_110	16:38	17:27	0:49	LINE CLEAR AVAILED
7	26-Apr-22	BAGALKOT	110	110/110KV,HV3(HV4)	ARALIMATI_33,TIGADI_33, KULIGOD_110	21:48	22:05	0:17	TRANSFORMER FAULT
8	26-Apr-22	BAGALKOT	110	110/11KV, HV1	GHATAPRABHA_220	13:25	13:47	0:22	LINE CLEAR AVAILED
9	26-Apr-22	BAGALKOT	110	110/11KV, HV2	ANKALI_110	21:35	21:45	0:10	TRANSFORMER FAULT
10	26-Apr-22	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	21:40	21:55	0:15	TRANSFORMER FAULT
11	26-Apr-22	BAGALKOT	110	110/11KV, HV3	NIPPANI_110	21:40	21:55	0:15	TRANSFORMER FAULT
12	26-Apr-22	BAGALKOT	110	110/11KV, HV4	ANKALI_110	21:35	21:45	0:10	TRANSFORMER FAULT
13	26-Apr-22	BAGALKOT	110	110/11KV, HV4	ANKALI_110	2:45	3:05	0:20	TRANSFORMER FAULT
14	26-Apr-22	BAGALKOT	110	110/11KV,HV1	AIGALI_110	16:35 (25.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
15	26-Apr-22	BAGALKOT	110	110/11KV,HV1	DADDI_110	12:26	14:17	1:51	LINE CLEAR AVAILED
16	26-Apr-22	BAGALKOT	110	110/11KV,HV1	GADAG_110	18:11	18:25	0:14	TRANSFORMER FAULT
17	26-Apr-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BABALESHWAR_110	18:04 (16.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
18	26-Apr-22	BAGALKOT	110	110/11KV,HV2	ANKALI_110	21:37	21:46	0:09	TRANSFORMER FAULT
19	26-Apr-22	BAGALKOT	110	110/11KV,HV3	SADALAGA_110	10:42	12:46	2:04	LINE CLEAR AVAILED
20	26-Apr-22	BAGALKOT	110	110/11KV,HV3	TIKOTA_110	14:14	18:05	3:51	LINE CLEAR AVAILED
21	26-Apr-22	BAGALKOT	110	110/11KV,HV4	BAILHONGAL_110	23:02 (25.04.2022)	18:02 (26.04.2022)	19:00	TRANSFORMER CHARGED
22	26-Apr-22	BAGALKOT	110	AMBEWADI- NK2 (KAWAWADA)	AMBEWADI_220	6:37	6:42	0:05	LOAD CHANGE OVER
23	26-Apr-22	BAGALKOT	110	AMBEWADI- NK2 (KAWAWADA)	AMBEWADI_220	18:09	18:11	0:02	LOAD CHANGE OVER
24	26-Apr-22	BAGALKOT	110	AMBEWADI-KIRUVATTI (STATION NOT AFFECTED)	KIRUVATTI_110	6:37	17:59	11:22	LINE CLEAR AVAILED
25	26-Apr-22	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	12:24	12:51	0:27	LINE FAULT
26	26-Apr-22	BAGALKOT	110	BELGAUM220- HONAGA	HONAGA_110	21:01	21:10	0:09	LINE FAULT
27	26-Apr-22	BAGALKOT	110	BIDNAL-GADAG (STATION NOT AFFECTED)	GADAG_110	9:35	19:52	10:17	LINE FAULT
28	26-Apr-22	BAGALKOT	110	BIDNAL-NAVALGUND (STATION NOT AFFECTED)	NAVALGUND_110	18:16 (25.04.2022)			LINE OPEN:LINE FAULT
29	26-Apr-22	BAGALKOT	110	CHIKKODI220- CHIKKODI	CHIKKODI_110	15:20	20:01	4:41	LINE CLEAR AVAILED
30	26-Apr-22	BAGALKOT	110	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	1:39	1:50	0:11	LINE FAULT
31	26-Apr-22	BAGALKOT	110	GHATAPRABHA220- SHIRGOAN	GHATAPRABHA_220	20:46	21:12	0:26	LINE FAULT
32	26-Apr-22	BAGALKOT	110	GOPANAKOPPA-GADAG ROAD	GADAG ROAD_110	10:03	10:22	0:19	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
33	26-Apr-22	BAGALKOT	110	GOPPANAKOPPA-MR NAGAR	MR NAGAR_110	9:45	10:06	0:21	LOAD CHANGE OVER
34	26-Apr-22	BAGALKOT	110	INDI-LACHYAN-HIREBEVANUR	HIREBEVANUR_110	4:13	4:34	0:21	LINE FAULT
35	26-Apr-22	BAGALKOT	110	MAHALINGAPUR-GSML2	STATION NOT AFFECTED MAHALINGAPUR_220	21:42 (24.04.2022)			LINE OPEN:LINE FAULT
36	26-Apr-22	BAGALKOT	110	MAMADAPUR-BABLESHWAR	MAMADAPUR(B)_110	13:00	13:06	0:06	HAND TRIPPED
37	26-Apr-22	BAGALKOT	110	MAMADAPUR-SHIRBUR	MAMADAPUR(B)_110	13:00	13:07	0:07	HAND TRIPPED
38	26-Apr-22	BAGALKOT	110	MKHUBLI220-KHANAPUR	MK HUBLI_220	8:20	12:10	3:50	LINE CLEAR AVAILED
39	26-Apr-22	BAGALKOT	110	NARAGUND-BPCL	NARUND_110	1:01	1:10	0:09	LINE FAULT
40	26-Apr-22	BAGALKOT	110	NARAGUND-BPCL	NARUND_110	8:07	16:06	7:59	LINE FAULT
41	26-Apr-22	BAGALKOT	110	NARENDRA- BELUR1	NARENDRA_220	21:08 (25.04.2022)	10:39 (26.04.2022)	13:31	LINE CHARGED
42	26-Apr-22	BAGALKOT	110	NARENDRA- BELUR2	NARENDRA_220	21:08 (25.04.2022)	18:13 (26.04.2022)	17:41	LINE CHARGED
43	26-Apr-22	BAGALKOT	110	NARENDRA1-MR NAGAR	STATION NOT AFFECTED MR NAGAR_110	20:55 (25.04.2022)	9:45 (26.04.2022)	12:50	LINE CHARGED
44	26-Apr-22	BAGALKOT	110	NARENDRA2-MR NAGAR	STATION NOT AFFECTED MR NAGAR_110	20:55 (25.04.2022)	10:04 (26.04.2022)	13:09	LINE CHARGED
45	26-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
46	26-Apr-22	BAGALKOT	110	RANEBENNUR-BYADAGI	BYADAGI_110 (STATION NOT AFFECTED)	11:34	16:11	4:37	NFBC ISSUED
47	26-Apr-22	BAGALKOT	110	RANEBENNUR-GUTTAL	GUTTAL_110	12:36	13:15	0:39	MAIN SUPPLY FAILURE
48	26-Apr-22	BAGALKOT	110	RANEBENNUR-HIREKERUR	HIREKERUR_110	12:36	13:15	0:39	MAIN SUPPLY FAILURE
49	26-Apr-22	BAGALKOT	110	RANEBENNUR-HONNATTI	HONNATTI_110	12:36	13:15	0:39	MAIN SUPPLY FAILURE
50	26-Apr-22	BAGALKOT	110	RANEBENNUR-TUMMINKATTE	TUMMINKATTE_110	12:36	13:15	0:39	MAIN SUPPLY FAILURE
51	26-Apr-22	BAGALKOT	110	RON-HIREHAL	STATION NOT AFFECTED RON_110	23:05	23:10	0:05	LOAD CHANGE OVER
52	26-Apr-22	BAGALKOT	110	SAVALAGI-AIGALI(YELLAMANAWADI)	STATION NOT AFFECTED SAVALAGI_110	7:59	19:14	11:15	NFBC ISSUED
53	26-Apr-22	BAGALKOT	110	SIRAGUPPI-BILAGI	BILAGI_110,GIRISAGAR_110, TOLAMATTI_110&BISNAL_110	5:34	5:41	0:07	MAIN SUPPLY FAILURE
54	26-Apr-22	BAGALKOT	110	SIRAGUPPI-BILAGI	BILAGI_110,GIRISAGAR_110, TOLAMATTI_110&BISNAL_110	5:59	6:04	0:05	MAIN SUPPLY FAILURE
55	26-Apr-22	BAGALKOT	110	TIKOTA-BHUTNAL(TAKKALAKI)	STATION NOT AFFECTED TIKOTA_110	8:35	14:14	5:39	NFBC ISSUED
56	26-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)			LINE OPEN:LINE CLEAR AVAILED
57	26-Apr-22	BAGALKOT	110	VAJRAMATTI220-KATARKI	VAJRAMATTI_220	5:34	5:41	0:07	LINE FAULT
58	26-Apr-22	BAGALKOT	110	VAJRAMATTI220-SHIRAGUPPI	VAJRAMATTI_220	5:34	5:41	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
59	26-Apr-22	BAGALKOT	110	VAJRAMATTI220-SHIRAGUPPI	VAJRAMATTI_220	5:59	6:04	0:05	LINE FAULT
60	26-Apr-22	BAGALKOT	110	YELLAMANAWADI-SAVALAGI	STATION NOT AFFECTED YELLAMANAWADI_110	7:55	19:08	11:13	LINE CLEAR AVOIDED
61	26-Apr-22	BAGALKOT	220	220/110KV, HV1	CHIKKODI_220	21:37	22:21	0:44	TRANSFORMER FAULT
62	26-Apr-22	BAGALKOT	220	220/110KV, HV1	RANEBENNUR_220	13:13	14:10	0:57	TRANSFORMER FAULT
63	26-Apr-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
64	26-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVOIDED
65	26-Apr-22	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA_220	13:08	13:29	0:21	LINE FAULT
66	26-Apr-22	BAGALKOT	220	RANEBENNUR- GUTTUR	RANEBENNUR_220	12:36	13:13	0:37	LINE FAULT
67	26-Apr-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:33 (22.04.2022)			LINE OPEN:LINE CLEAR AVOIDED
68	26-Apr-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:33 (22.04.2022)			LINE OPEN:LINE CLEAR AVOIDED
69	26-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	15:31	16:19	0:48	LOAD CHANGE OVER
70	26-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	16:32	17:01	0:29	HAND TRIPPED
71	26-Apr-22	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	16:23	16:26	0:03	LOAD CHANGE OVER
72	26-Apr-22	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), JAKKASANDRA	9:19	9:29	0:10	LINE CLEAR AVOIDED
73	26-Apr-22	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT), JAKKASANDRA, ST JOHN WOOD	9:55	10:01	0:06	MAIN SUPPLY FAILURE
74	26-Apr-22	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	14:28	14:43	0:15	LINE FAULT
75	26-Apr-22	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	20:15(18-4-2022)			LINE OPEN:LINE FAULT
76	26-Apr-22	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR	15:05	15:15	2:31	LINE CLEAR AVOIDED
77	26-Apr-22	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	16:54	17:03	0:09	LINE FAULT
78	26-Apr-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	17:06	17:15	0:08	LINE FAULT
79	26-Apr-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	22:41(26-4-2022)			LINE OPEN:LINE FAULT
80	26-Apr-22	BENGALURU	66	CHNADAPURA - YERANDANAHALLI 220	CHANDAPURA	18:27	18:32	0:05	LOAD CHANGE OVER
81	26-Apr-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	9:23	9:38	0:15	LINE FAULT
82	26-Apr-22	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	18:14	18:48	0:34	MAIN SUPPLY FAILURE
83	26-Apr-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	18:14	20:35	2:21	LINE FAULT
84	26-Apr-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	18:14	19:00	0:46	MAIN SUPPLY FAILURE
85	26-Apr-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	18:14	18:45	0:31	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
86	26-Apr-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:51	18:01	0:09	LINE FAULT
87	26-Apr-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	18:14	18:53	0:39	MAIN SUPPLY FAILURE
88	26-Apr-22	BENGALURU	66	GLOBAL TECH PARK - HSR LAYOUT 220	GLOBAL TECH PARK	7:24	9:54	2:30	MAIN SUPPLY FAILURE
89	26-Apr-22	BENGALURU	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK	10:54	11:00	0:06	LOAD CHANGE OVER
90	26-Apr-22	BENGALURU	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK	11:05	11:32	0:27	MAIN SUPPLY FAILURE
91	26-Apr-22	BENGALURU	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK	15:42	15:44	0:02	MAIN SUPPLY FAILURE
92	26-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	19:06	19:36	0:30	LOAD CURTAILMENT
93	26-Apr-22	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	12:47	13:07	0:20	LOAD CURTAILMENT
94	26-Apr-22	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	12:40	13:07	0:27	LOAD CURTAILMENT
95	26-Apr-22	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	14:30	14:35	0:05	LOAD CHANGE OVER
96	26-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	14:53	15:03	0:09	LINE CLEAR AVAILED
97	26-Apr-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	14:40	14:53	0:13	LINE FAULT
98	26-Apr-22	BENGALURU	66	HV1	BAGEPALLI	12:05	12:36	0:31	LINE CLEAR AVAILED
99	26-Apr-22	BENGALURU	66	HV1	DALASNUR	16:10	16:30	0:20	LINE CLEAR AVAILED
100	26-Apr-22	BENGALURU	66	HV1	HOODY 220	9:21	9:28	0:07	LOAD CHANGE OVER
101	26-Apr-22	BENGALURU	66	HV1	HUKUNDA	12:45	12:50	0:04	LINE CLEAR AVAILED
102	26-Apr-22	BENGALURU	66	HV1	JAYADEVA	16:17	16:35	0:18	LINE CLEAR AVAILED
103	26-Apr-22	BENGALURU	66	HV1	NAGANATHPURA 220	12:41	12:46	0:05	LINE CLEAR AVAILED
104	26-Apr-22	BENGALURU	66	HV2	HOODY 220	12:40	13:14	0:34	LOAD CURTAILMENT
105	26-Apr-22	BENGALURU	66	HV2	HUKUNDA	13:38	14:05	0:26	LINE CLEAR AVAILED
106	26-Apr-22	BENGALURU	66	HV2	HULLENAHALLI	15:37	15:57	0:20	TRANSFORMER FAULT
107	26-Apr-22	BENGALURU	66	HV2	KONDASPURA	15:48	15:53	0:05	TRANSFORMER FAULT
108	26-Apr-22	BENGALURU	66	HV2	NAGANATHPURA 220	12:41	12:46	0:05	LINE CLEAR AVAILED
109	26-Apr-22	BENGALURU	66	HV2	NRS 220	13:17	13:28	0:11	LOAD CHANGE OVER
110	26-Apr-22	BENGALURU	66	HV2	NRS 220	15:17	15:22	0:05	LOAD CHANGE OVER
111	26-Apr-22	BENGALURU	66	HV3	NAGANATHPURA 220	12:41	12:46	0:05	LINE CLEAR AVAILED
112	26-Apr-22	BENGALURU	66	HV3	YARANDANAHALLI 220	9:12	9:21	0:09	TRANSFORMER FAULT
113	26-Apr-22	BENGALURU	66	IISc - HEBBALA 220	IISc	19:34	19:39	0:05	LOAD CHANGE OVER
114	26-Apr-22	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	16:26	16:31	0:05	LOAD CHANGE OVER
115	26-Apr-22	BENGALURU	66	KOLAR 220 - MULBAGLU	NO STATION AFFECTED	19:20:00(14-04-2022)			LINE OPEN:LINE FAULT
116	26-Apr-22	BENGALURU	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	11:57	12:06	0:09	LINE CLEAR AVAILED
117	26-Apr-22	BENGALURU	66	LR BANDE - HBR LAYOUT 220	LR BANDE	12:55	13:05	0:10	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
118	26-Apr-22	BENGALURU	66	MALLASANDRA - DRDO(EHT)	MALLASANDRA/TD HALLI, DALSNUR	19:20	19:50	0:30	LOAD CURTAILMENT
119	26-Apr-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, ELECTRONIC CITY P2 S1, INFOSYS(EHT), HULIMANGALA	12:41	12:46	0:05	LINE CLEAR AVAILED
120	26-Apr-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), HUSKUR	12:41	12:46	0:05	LINE CLEAR AVAILED
121	26-Apr-22	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), JAKKASANDRA, ST JOHN WOOD	9:55	10:01	0:06	LINE FAULT
122	26-Apr-22	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	13:23	13:28	0:05	LOAD CHANGE OVER
123	26-Apr-22	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	16:26	16:31	0:05	LOAD CHANGE OVER
124	26-Apr-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	7:25	8:17	0:52	MAIN SUPPLY FAILURE
125	26-Apr-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	11:36	11:46	0:10	MAIN SUPPLY FAILURE
126	26-Apr-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	15:43	15:47	0:04	MAIN SUPPLY FAILURE
127	26-Apr-22	BENGALURU	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	7:25	9:55	2:30	MAIN SUPPLY FAILURE
128	26-Apr-22	BENGALURU	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	10:41	10:55	0:14	MAIN SUPPLY FAILURE
129	26-Apr-22	BENGALURU	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	11:05	11:23	0:18	MAIN SUPPLY FAILURE
130	26-Apr-22	BENGALURU	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	15:42	15:45	0:03	MAIN SUPPLY FAILURE
131	26-Apr-22	BENGALURU	66	ST JOHN WOOD - ADUGODI	ST JOHN WOOD	10:56	11:02	0:06	LOAD CHANGE OVER
132	26-Apr-22	BENGALURU	66	ST JOHN WOOD - HSR LAYOUT 220	ST JOHN WOOD	7:25	9:15	1:50	MAIN SUPPLY FAILURE
133	26-Apr-22	BENGALURU	66	ST JOHN WOOD - HSR LAYOUT 220	ST JOHN WOOD	11:05	11:23	0:18	MAIN SUPPLY FAILURE
134	26-Apr-22	BENGALURU	66	ST JOHN WOOD - HSR LAYOUT 220	ST JOHN WOOD	15:42	15:45	0:03	MAIN SUPPLY FAILURE
135	26-Apr-22	BENGALURU	66	TUBGERE - CHIKKABALLPURA 1	NO STATION AFFECTED	9:23	9:50	0:27	LINE FAULT
136	26-Apr-22	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	12:43	12:50	0:07	LOAD CHANGE OVER
137	26-Apr-22	BENGALURU	66	VICTORIA - NRS 220	VICTORIA	14:09	14:12	0:03	LOAD CHANGE OVER
138	26-Apr-22	BENGALURU	66	VIDYANAGAR - HOSKOTE 220	VIDYANAGAR	17:30	17:43	0:13	LOAD CHANGE OVER
139	26-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	15:29	15:43	0:14	LOAD CHANGE OVER
140	26-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	15:29	15:43	0:14	LOAD CHANGE OVER
141	26-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	16:40	16:45	0:05	LOAD CHANGE OVER
142	26-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	16:40	16:45	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
143	26-Apr-22	BENGALURU	220	BEGUR 220 - HOODY 220	NO STATION AFFECTED	12:37	13:37	0:59	LINE FAULT
144	26-Apr-22	BENGALURU	220	HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	12:36	13:36	1:00	LINE FAULT
145	26-Apr-22	BENGALURU	220	HSR LAYOUT 220 - MYLASANDRA 220	HSR LAYOUT 220	7:24	7:33	0:09	LINE FAULT
146	26-Apr-22	BENGALURU	220	HSR LAYOUT 220 - MYLASANDRA 220	NO STATION AFFECTED	7:33	10:00	2:27	LINE FAULT
147	26-Apr-22	BENGALURU	220	HSR LAYOUT 220 - MYLASANDRA 220	NO STATION AFFECTED	11:07	13:47	2:40	LINE FAULT
148	26-Apr-22	BENGALURU	220	HSR LAYOUT 220 - MYLASANDRA 220	NO STATION AFFECTED	14:15	15:00	0:45	LINE CLEAR AVAILED
149	26-Apr-22	BENGALURU	220	HV1	DB PURA 220	18:14	18:44	0:30	TRANSFORMER FAULT
150	26-Apr-22	BENGALURU	220	HV1	HSR LAYOUT 220	7:24	7:33	0:09	TRANSFORMER FAULT
151	26-Apr-22	BENGALURU	220	HV1	HSR LAYOUT 220	11:09	11:20	0:11	LINE CLEAR AVAILED
152	26-Apr-22	BENGALURU	220	HV1	HSR LAYOUT 220	15:47	15:54	0:07	LOAD CHANGE OVER
153	26-Apr-22	BENGALURU	220	HV1	NAGANATHPURA 220	12:41	12:45	0:04	TRANSFORMER FAULT
154	26-Apr-22	BENGALURU	220	HV1	YARANDANAHALLI 220	15:29	15:43	0:14	LOAD CHANGE OVER
155	26-Apr-22	BENGALURU	220	HV1	YARANDANAHALLI 220	16:40	16:45	0:05	LOAD CHANGE OVER
156	26-Apr-22	BENGALURU	220	HV2	HSR LAYOUT 220	8:48	8:50	0:02	LOAD CHANGE OVER
157	26-Apr-22	BENGALURU	220	HV2	NAGANATHPURA 220	12:41	12:45	0:04	TRANSFORMER FAULT
158	26-Apr-22	BENGALURU	220	HV3	HSR LAYOUT 220	7:24	8:07	0:43	TRANSFORMER FAULT
159	26-Apr-22	BENGALURU	220	HV3	HSR LAYOUT 220	8:26	15:40	7:14	LINE CLEAR AVAILED
160	26-Apr-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALLI_66	0:05	0:10	0:05	LINE FAULT
161	26-Apr-22	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	15:45	16:00	0:15	LINE FAULT
162	26-Apr-22	GULBARGA	110	DUBALGUNDI-HUMNABAD	DUBALGUNDI_110	9:25	9:35	0:10	MAIN SUPPLY FAILURE
163	26-Apr-22	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	3:10	6:00	2:50	LINE FAULT
164	26-Apr-22	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	21:50	22:05	0:15	LINE FAULT
165	26-Apr-22	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBALGUNDI_110	9:26	9:35	0:09	LINE FAULT
166	26-Apr-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
167	26-Apr-22	GULBARGA	110	HUMNABAD-MANEIKHELLI	MANAIKHELLI_110	8:48	11:44	2:56	LINE CLEAR AVAILED
168	26-Apr-22	GULBARGA	110	HV1	CHINCHOLI_110	16:51	17:05	0:14	TRANSFORMER FAULT
169	26-Apr-22	GULBARGA	110	HV1	MATAMARI_110	17:50	18:20	0:30	TRANSFORMER FAULT
170	26-Apr-22	GULBARGA	110	HV2	MATAMARI_110	1:40	1:45	0:05	TRANSFORMER FAULT
171	26-Apr-22	GULBARGA	110	HV2	VAJRABANDI_110	14:50	15:05	0:15	LINE CLEAR AVAILED
172	26-Apr-22	GULBARGA	110	HV3	TEKKALKOTE_110	9:30	14:08	4:38	LINE CLEAR AVAILED
173	26-Apr-22	GULBARGA	110	HV3	YELBURGA_110	13:04	13:58	0:54	LINE CLEAR AVAILED
174	26-Apr-22	GULBARGA	110	KAVITAL-MALLAT	KAVITAL_110	23:40	23:45	0:05	MAIN SUPPLY FAILURE
175	26-Apr-22	GULBARGA	110	KAVITAL-SINDHANOOR	KAVITAL_110	0:50	0:55	0:05	MAIN SUPPLY FAILURE
176	26-Apr-22	GULBARGA	110	KUSTAGI-VAJRABANDI	VAJRABANDI_110,YELBURAG_110,KUKNOOR_110	17:20 (26.04.2022)			LINE OPEN:LINE FAULT
177	26-Apr-22	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	3:05	3:12	0:07	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
178	26-Apr-22	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	6:06	6:18	0:12	MAIN SUPPLY FAILURE
179	26-Apr-22	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	7:30	10:42	3:12	LINE CLEAR AVAIED
180	26-Apr-22	GULBARGA	110	PDHALLI-CLN MAX,CLN SLR,BASAI STEELS	PD_HALLI_110	7:30	10:45	3:15	LINE CLEAR AVAIED
181	26-Apr-22	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	3:10	3:16	0:06	LINE FAULT
182	26-Apr-22	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	21:49	21:59	0:10	LINE FAULT
183	26-Apr-22	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	3:45	3:57	0:12	LINE FAULT
184	26-Apr-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	21:44 (25.04.2022)	12:05 (26.04.2022)	14:21HRS	LINE CHARGED
185	26-Apr-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,A FZALPUR_110,KARAJAGI_110	19:25	20:35	1:10	LINE CLEAR AVAIED
186	26-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAIED
187	26-Apr-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_100	5:06	5:13	0:07	LINE FAULT
188	26-Apr-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	22:11	22:17	0:06	LINE FAULT
189	26-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAIED
190	26-Apr-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	14:44	14:52	0:08	LINE FAULT
191	26-Apr-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	14:44	14:52	0:08	LINE FAULT
192	26-Apr-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:11	22:17	0:06	LINE FAULT
193	26-Apr-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,WADAGERA_110, KHANAPUR_110	3:52	3:58	0:06	LINE FAULT
194	26-Apr-22	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAPUR_110,MASKI_110,VALAKAMADINNI_110	6:04	6:14	0:10	LINE FAULT
195	26-Apr-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	17:58	18:07	0:09	LINE FAULT
196	26-Apr-22	GULBARGA	110	TEKKALKOTE-SHAHI SLR	TEKKALKOTE_110	21:08	21:33	0:25	LINE CLEAR AVAIED
197	26-Apr-22	GULBARGA	110	VAJRABANDI-KUSHTAGI	VAJRABANDI_110	0:45	2:40	1:55	MAIN SUPPLY FAILURE
198	26-Apr-22	GULBARGA	220	HV1	KUSTAGI_220	14:10	14:17	0:07	TRANSFORMER FAULT
199	26-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
200	26-Apr-22	GULBARGA	220	HV2, LV2	KAPNOOR_220	0:28(22.04.2022)	16:16(26.04.2022)	111:48HRS	TRANSFORMER CHARGED
201	26-Apr-22	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	10:12	13:44	3:32	NFBC ISSUED
202	26-Apr-22	HASSAN	66	GORUR-ARAKALGUD	GORUR_66	10:39	12:35	1:56	MAIN SUPPLY FAILURE
203	26-Apr-22	HASSAN	66	GORUR-HASSAN	GORUR_66	10:39	12:35	1:56	MAIN SUPPLY FAILURE
204	26-Apr-22	HASSAN	66	HASSN220-BELUR	HASSAN_220	10:54	18:21	7:27	LINE CLEAR AVAIED
205	26-Apr-22	HASSAN	66	HASSN220-SUZLON	HASSAN_220	10:54	18:21	7:27	LINE CLEAR AVAIED
206	26-Apr-22	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	10:54	18:21	7:27	LINE CLEAR AVAIED
207	26-Apr-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_66	19:01	19:06	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
208	26-Apr-22	HASSAN	66	HV1	BALEHONNUR_66	12:38	13:43	1:05	LINE CLEAR AVAIED
209	26-Apr-22	HASSAN	66	HV1	CHIKMAGALUR_66	10:41	10:50	0:09	HAND TRIPPED
210	26-Apr-22	HASSAN	66	HV1	GORUR_66	10:39	12:35	1:56	MAIN SUPPLY FAILURE
211	26-Apr-22	HASSAN	66	HV1	HOLEHONNUR_66	10:55 (26.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAIED
212	26-Apr-22	HASSAN	66	HV1	SAKALESHPUA_66	9:10	10:30	1:20	LINE CLEAR AVAIED
213	26-Apr-22	HASSAN	66	HV2	HOLEHONNUR_66	10:55	11:05	0:10	LINE CLEAR AVAIED
214	26-Apr-22	HASSAN	66	HV2	SAKALESHPUA_66	9:10	10:30	1:20	LINE CLEAR AVAIED
215	26-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPUA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAIED
216	26-Apr-22	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAMME_66	10:30	10:50	0:20	MAIN SUPPLY FAILURE
217	26-Apr-22	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPPLU_66	10:40	18:20	7:40	NFBC ISSUED
218	26-Apr-22	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPPLU_66	10:40	18:20	7:40	NFBC ISSUED
219	26-Apr-22	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	10:01	15:08	5:07	LINE CLEAR AVAIED
220	26-Apr-22	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	11:43	14:52	3:09	LINE CLEAR AVAIED
221	26-Apr-22	HASSAN	110	HV1	MADHUVANA_110	11:52	17:20	5:28	LINE CLEAR AVAIED
222	26-Apr-22	HASSAN	110	HV1	MANIPAL_110	9:42	11:02	1:20	LINE CLEAR AVAIED
223	26-Apr-22	HASSAN	110	HV2	ANAVATTI_110	15:08	15:19	0:11	TRANSFORMER FAULT
224	26-Apr-22	HASSAN	110	HV2	KEMAR_220	14:57	15:14	0:17	TRANSFORMER FAULT
225	26-Apr-22	HASSAN	110	HV2	MANIPAL_110	9:42	11:02	1:20	LINE CLEAR AVAIED
226	26-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAIED
227	26-Apr-22	HASSAN	110	HV4	SHIRALKOPPA_110	15:20	17:30	2:10	LINE CLEAR AVAIED
228	26-Apr-22	HASSAN	110	HV5	KAVOOR_220	8:45 (26.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAIED
229	26-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAIED
230	26-Apr-22	HASSAN	110	KAVOOR-AMR	KAVOOR_220	10:28	10:30	0:02	HAND TRIPPED
231	26-Apr-22	HASSAN	110	KAVOOR-AMR	KAVOOR_220	17:04	17:30	0:26	LINE FAULT
232	26-Apr-22	HASSAN	110	KEMAR-BELMAN	KEMAR_220	11:54	12:27	0:33	NFBC ISSUED
233	26-Apr-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:37	13:31	0:54	MAIN SUPPLY FAILURE
234	26-Apr-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	14:27	14:44	0:17	LINE FAULT
235	26-Apr-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:37	13:55	1:18	MAIN SUPPLY FAILURE
236	26-Apr-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	14:30	14:45	0:15	LINE FAULT
237	26-Apr-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:37	13:30	0:53	MAIN SUPPLY FAILURE
238	26-Apr-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:37	13:32	0:55	MAIN SUPPLY FAILURE
239	26-Apr-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:37	13:31	0:54	MAIN SUPPLY FAILURE
240	26-Apr-22	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	15:51	16:10	0:19	LINE FAULT
241	26-Apr-22	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	10:27	13:30	3:03	LINE CLEAR AVAIED
242	26-Apr-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	16:00(25.04.2022)	12:22(26.04.2022)	20:21 hrs	LINE CHARGED
243	26-Apr-22	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	12:51(25.04.2022)			LINE OPEN:LINE FAULT
244	26-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	12:38	12:56	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
245	26-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:21	17:11	4:50	LINE FAULT
246	26-Apr-22	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	10:27	13:30	3:03	NFBC ISSUED
247	26-Apr-22	HASSAN	220	SHRAVITY-SHIMOGA1	gen_sharavathy	12:39	17:14	4:35	LINE FAULT
248	26-Apr-22	HASSAN	220	SHRAVITY-SHIMOGA3	gen_sharavathy	12:21	17:24	5:03	LINE FAULT
249	26-Apr-22	HASSAN	220	SHRAVITY-SHIRALKOPPA	gen_sharavathy	16:17(25.04.2022)	16:24 (26.04.2022)	24:6 hrs	LINE CHARGED
250	26-Apr-22	HASSAN	220	SHRAVITY-SIRISI 1	gen_sharavathy	15:31	16:26	0:55	HAND TRIPPED
251	26-Apr-22	HASSAN	220	SHRAVITY-SIRISI 1	gen_sharavathy	16:33	17:00	0:27	HAND TRIPPED
252	26-Apr-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	16:17(25.04.2022)	13:29 (26.04.2022)	21:11 hrs	LINE CHARGED
253	26-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
254	26-Apr-22	MYSURU	66	BOGADHI-HOOTAGALLI	BOGADHI_66	12:05	12:18	0:13	LINE FAULT
255	26-Apr-22	MYSURU	66	CR NAGARA-HONNAHALLI	ATTIGULIPURA_66 ARAKALWADI_66 HONNALLY_MYS_66	16:26	17:01	0:35	LINE CLEAR AVAILED
256	26-Apr-22	MYSURU	66	DEVANURNANJANAGUDU-SUTTUR	SUTTUR_66	12:56	14:57	2:01	LINE CLEAR AVAILED
257	26-Apr-22	MYSURU	66	GUNDLUPETE-KABBALI	NO STATIONS EFFECTED	7:05	9:10	2:05	LINE CLEAR AVAILED
258	26-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
259	26-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
260	26-Apr-22	MYSURU	66	HV1	SANIVARASANTHE_66	15:29:47 (11.04.2022)	18:09:00 (26.04.2022)	338:39 hrs	TRANSFORMER CHARGED
261	26-Apr-22	MYSURU	66	HV1	THUMBLA_66	10:53	11:00	0:07	TRANSFORMER FAULT
262	26-Apr-22	MYSURU	66	HV2	CHANDAKAVADI_66	16:50	17:10	0:19	LINE CLEAR AVAILED
263	26-Apr-22	MYSURU	66	KUSHALNAGARA-MYSORE-1	BILIKERE_66 GVGUDI_66 KRNAGARA_66 MIRLE_66	9:23	9:32	0:09	LINE FAULT
264	26-Apr-22	MYSURU	66	KUSHALNAGARA-MYSORE-1	NO STATIONS EFFECTED	10:42	11:06	0:24	LINE FAULT
265	26-Apr-22	MYSURU	66	KUSHALNAGARA-MYSORE-2	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	9:23	9:32	0:09	LINE FAULT
266	26-Apr-22	MYSURU	66	MADHUVANAHALLI-HANNUR-2	NO STATIONS EFFECTED	14:07	14:12	0:05	LINE FAULT
267	26-Apr-22	MYSURU	66	MADHUVANAHALLI-HANNUR-2	NO STATIONS EFFECTED	18:44	18:49	0:05	LINE FAULT
268	26-Apr-22	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	16:04	16:49	0:45	LINE FAULT
269	26-Apr-22	MYSURU	66	SFC SHIVA-10 MW	NO STATIONS EFFECTED	20:45	21:04	0:19	LINE FAULT
270	26-Apr-22	MYSURU	66	SFC SHIVA-10 MW	NO STATIONS EFFECTED	10:15:00 PM (26.04.2022)			LINE OPEN:LINE FAULT
271	26-Apr-22	MYSURU	66	TUBINKAKERE-NAGAMANGALA 2	BASARALU_66 HARADANAHALLI_66 KESLAGERE_66 SHIVALLY_66	21:19	21:23	0:04	LINE FAULT
272	26-Apr-22	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	14:36	14:50	0:14	LINE FAULT
273	26-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
274	26-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
275	26-Apr-22	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATIONS EFFECTED	10:01	10:58	0:57	HAND TRIPPED
276	26-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	19:11	19:23	0:11	LOAD CURTAILMENT
277	26-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	22:20	23:23	1:02	LOAD CURTAILMENT
278	26-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	7:01	7:18	0:17	LINE FAULT
279	26-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220kv KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	22:21	23:24	1:02	LOAD CURTAILMENT
280	26-Apr-22	TUMKUR	66	CHITRADURGA 220kv- SUZLON 2	SUZLON2_IPP_66	17:07	18:17	1:09	LINE CLEAR AVAILED
281	26-Apr-22	TUMKUR	66	CHITRADURGA 220kv- CHITRADURGA 1	CHITRADURGA_220	5:40	6:26	0:46	HAND TRIPPED
282	26-Apr-22	TUMKUR	66	CHITRADURGA 220kv- CHITRADURGA 4	CHITRADURGA_220	5:39	6:26	0:47	HAND TRIPPED
283	26-Apr-22	TUMKUR	66	CHITRADURGA 220kv- CHITRADURGA2	CHITRADURGA_220	5:40	6:27	0:46	HAND TRIPPED
284	26-Apr-22	TUMKUR	66	CHITRADURGA 66kv- CHITRADURGA 2	CHITRADURGA_66	5:20	9:16	3:56	LINE CLEAR AVAILED
285	26-Apr-22	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66	5:20	6:48	1:28	MAIN SUPPLY FAILURE
286	26-Apr-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:39	6:00	0:20	LINE FAULT
287	26-Apr-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:50	19:05	0:15	MAIN SUPPLY FAILURE
288	26-Apr-22	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_6 6,SASALUHALLA_66	16:13	17:20	1:06	LINE FAULT
289	26-Apr-22	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	6:05	6:15	0:10	MAIN SUPPLY FAILURE
290	26-Apr-22	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	7:25	8:10	0:45	MAIN SUPPLY FAILURE
291	26-Apr-22	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	8:15	8:30	0:15	MAIN SUPPLY FAILURE
292	26-Apr-22	TUMKUR	66	LOKIKERE-TYAVANAGI	LOKIKERE_66	1:22	1:39	0:16	MAIN SUPPLY FAILURE
293	26-Apr-22	TUMKUR	66	MADHUGIRI 220kv- BADAVANAHALLI	MADHUGIRI_66, BADAVANAHALLI_66	22:20	22:30	0:10	LOAD CURTAILMENT
294	26-Apr-22	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE	NAYAKANAHATTI_66	0:20	0:46	0:25	LINE FAULT
295	26-Apr-22	TUMKUR	66	THIPPUR- ANCHEPALYA220	THIPPUR_66	20:53	21:08	0:15	LINE FAULT
296	26-Apr-22	TUMKUR	66	THIPPUR-YADIYUR	YADIYUR_66	20:53	21:13	0:19	LINE FAULT
297	26-Apr-22	TUMKUR	66	TMTP66-THOVINAKERE	THOVINAKERE_66	7:35	7:49	0:14	MAIN SUPPLY FAILURE
298	26-Apr-22	TUMKUR	66	TR-1	PAVAGADA_220	14:56	15:00	0:03	TRANSFORMER FAULT
299	26-Apr-22	TUMKUR	66	TR-1	THIPPUR_66	21:08	22:08	0:59	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
300	26-Apr-22	TUMKUR	66	TR-1	TMTP_66	7:35	7:49	0:14	MAIN SUPPLY FAILURE
301	26-Apr-22	TUMKUR	66	TR-1(LV-1)	THALLAK_220	15:30	17:19	1:49	LINE CLEAR AVAILED
302	26-Apr-22	TUMKUR	66	TR-2	GARAGA_66	7:57	8:43	0:46	LINE CLEAR AVAILED
303	26-Apr-22	TUMKUR	66	TR-2	KADAJI_66	12:44	12:50	0:05	TRANSFORMER FAULT
304	26-Apr-22	TUMKUR	66	TR-2	PAVAGADA_66	15:19	15:23	0:04	TRANSFORMER FAULT
305	26-Apr-22	TUMKUR	66	TR-2	THOVINAKERE_66	10:10	11:23	1:13	LINE CLEAR AVAILED
306	26-Apr-22	TUMKUR	66	TR-2	TMTP_66	7:35	7:49	0:14	MAIN SUPPLY FAILURE
307	26-Apr-22	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	19:08(26.4.22)	0:25(27.4.22)	5:25	LOAD CURTAILMENT
308	26-Apr-22	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDR A_110,SAMPIGE_110	14:15	16:35	2:20	MAIN SUPPLY FAILURE
309	26-Apr-22	TUMKUR	110	TR-1	KALLUR_110	18:58	19:09	0:11	LOAD CURTAILMENT
310	26-Apr-22	TUMKUR	110	TR-1	SAMPIGE_110	14:15	16:35	2:20	MAIN SUPPLY FAILURE
311	26-Apr-22	TUMKUR	110	TR-1	SHETTYKERE_110	16:02	16:33	0:31	LINE CLEAR AVAILED
312	26-Apr-22	TUMKUR	110	TR-2	SAMPIGE_110	14:15	16:34	2:19	MAIN SUPPLY FAILURE
313	26-Apr-22	TUMKUR	220	TR-1	THALLAK_220	15:30	17:18	1:48	LINE CLEAR AVAILED
314	27-Apr-22	BAGALKOT	110	110/110KV,HV2	KUD DHARWAD_110	8:35 (26.04.2022)	17:11 (27.04.2022)	32:36 hrs	TRANSFORMER CHARGED
315	27-Apr-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED UTTUR_110	5:47	6:36	0:49	TRANSFORMER FAULT
316	27-Apr-22	BAGALKOT	110	110/11KV,HV1	AIGALI_110	16:35 (25.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
317	27-Apr-22	BAGALKOT	110	110/11KV,HV1	HALAKI_110	7:17	7:34	0:17	TRANSFORMER FAULT
318	27-Apr-22	BAGALKOT	110	110/11KV,HV1	INDI_220	9:28	12:08	2:40	TRANSFORMER FAULT
319	27-Apr-22	BAGALKOT	110	110/11KV,HV1	SHIRAGUPPI_110	16:45	18:20	1:35	HAND TRIPPED
320	27-Apr-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BABALESHWAR_110	18:04 (16.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
321	27-Apr-22	BAGALKOT	110	110/11KV,HV1	TOLAMATTI_110	16:35	16:55	0:20	LINE CLEAR AVAILED
322	27-Apr-22	BAGALKOT	110	110/11KV,HV1	TOLAMATTI_110	17:10	18:05	0:55	LINE CLEAR AVAILED
323	27-Apr-22	BAGALKOT	110	110/11KV,HV1	TOLMATTI_110	16:34	16:54	0:20	LINE CLEAR AVAILED
324	27-Apr-22	BAGALKOT	110	110/11KV,HV1	TOLMATTI_110	17:09	18:05	0:56	LINE CLEAR AVAILED
325	27-Apr-22	BAGALKOT	110	110/11KV,HV1	UDAKERI_110	12:55	13:50	0:55	LINE CLEAR AVAILED
326	27-Apr-22	BAGALKOT	110	110/11KV,HV1&HV2	SULTANPUR_110	16:00	16:55	0:55	LINE CLEAR AVAILED
327	27-Apr-22	BAGALKOT	110	110/11KV,HV2	LAXMESHWAR_110	11:59	13:35	1:36	TRANSFORMER FAULT
328	27-Apr-22	BAGALKOT	110	110/11KV,HV2	MALGHAN(S)_110	11:51	14:18	2:27	LINE CLEAR AVAILED
329	27-Apr-22	BAGALKOT	110	110/11KV,HV2	NANADI_110	18:10	18:44	0:34	LINE CLEAR AVAILED
330	27-Apr-22	BAGALKOT	110	110/11KV,HV2	SULTANPUR_110	12:45	14:08	1:23	LINE CLEAR AVAILED
331	27-Apr-22	BAGALKOT	110	110/11KV,HV2	SULTANPUR_110	14:14	14:24	0:10	HAND TRIPPED
332	27-Apr-22	BAGALKOT	110	110/11KV,HV2	SULTANPUR_110	14:25	14:38	0:13	HAND TRIPPED
333	27-Apr-22	BAGALKOT	110	110/11KV,HV2	UGARKHUD_110	11:14	12:35	1:21	LINE CLEAR AVAILED
334	27-Apr-22	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110 (STATION NOT AFFECTED)	6:25	17:24	10:59	LINE CLEAR AVAILED
335	27-Apr-22	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	KAVALWADA_110	6:48	6:51	0:03	LINE CLEAR AVAILED
336	27-Apr-22	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110 (STATION NOT AFFECTED)	18:16 (25.04.2022)	13:34 (27.04.2022)	43:18 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
337	27-Apr-22	BAGALKOT	110	GAJENDRAGAD-RON2	GAJENDRAGAD_110 (STATION NOT AFFECTED)	10:33	13:17	2:44	LINE FAULT
338	27-Apr-22	BAGALKOT	110	GHATAPRABHA-KABBUR	GHATAPRABHA_220	18:40	19:12	0:32	LINE FAULT
339	27-Apr-22	BAGALKOT	110	GOPANAKOPPA-GADAG ROAD	GADAG ROAD_110	10:54	13:43	2:49	NFBC ISSUED
340	27-Apr-22	BAGALKOT	110	HIREBEVANUR-RODAGI	RODAGI_110	17:51	18:03	0:12	LINE FAULT
341	27-Apr-22	BAGALKOT	110	HUNGUND-KUDAL SANGAM	KUDAL SANGAM_110	13:01	15:50	2:49	LINE CLEAR AVAILED
342	27-Apr-22	BAGALKOT	110	INDI-DEVAR HIPPARAGI	INDI_220,DEVARA HIPPARAGI_110,ATHARGA_110,HIREMASALI_110	21:00	21:40	0:40	LINE FAULT
343	27-Apr-22	BAGALKOT	110	KUDALASANGUM-HUNAGUND	KUDAL SANGAM_110	12:39	18:04	5:25	LINE CLEAR AVAILED
344	27-Apr-22	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110 (STATION NOT AFFECTED)	10:33	21:17	10:44	LINE FAULT
345	27-Apr-22	BAGALKOT	110	LAXMESHWAR-SHIRAHATTI	LAXMESHWAR_110	16:49	18:09	1:20	LINE FAULT
346	27-Apr-22	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	MAHALINGAPUR_220	5:47	7:11	1:24	HAND TRIPPED
347	27-Apr-22	BAGALKOT	110	MAHALINGAPUR220-TERDAL	MAHALINGAPUR_220	5:56	7:26	1:30	HAND TRIPPED
348	27-Apr-22	BAGALKOT	110	MAHALINGAPUR-GSML2	STATION NOT AFFECTED MAHALINGAPUR_220	21:42 (24.04.2022)			LINE OPEN:LINE FAULT
349	27-Apr-22	BAGALKOT	110	MAMADAPUR(B)-BELGAUM SOLAR	MAMADAPUR(B)_110	16:43	16:49	0:06	LINE FAULT
350	27-Apr-22	BAGALKOT	110	MUGALKHOD-SULTANPUR	STATION NOT AFFECTED SULTANPUR_110	16:06	16:50	0:44	HAND TRIPPED
351	27-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
352	27-Apr-22	BAGALKOT	110	SAVALAGI- AIGALI	STATION NOT AFFECTED SAVALAGI_110	8:46	19:11	10:25	LINE CLEAR AVAILED
353	27-Apr-22	BAGALKOT	110	SHIRAHATTI-BPCL1	STATION NOT AFFECTED SHIRAHATTI_110	16:50	22:35	5:45	LINE FAULT
354	27-Apr-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
355	27-Apr-22	BAGALKOT	110	SOUDATTI-MUNAVALLI	STATION NOT AFFECTED MUNAVALLI_110	14:40	15:04	0:24	LINE FAULT
356	27-Apr-22	BAGALKOT	110	SULTANPUR- F2(KABBUR)	SULTANPUR_110	16:00	16:50	0:50	LINE CLEAR AVAILED
357	27-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)			LINE OPEN:LINE CLEAR AVAILED
358	27-Apr-22	BAGALKOT	110	VAJRAMATTI-MUDHOL	STATION NOT AFFECTED MUDHOL_110	5:48	6:30	0:42	LOAD CHANGE OVER
359	27-Apr-22	BAGALKOT	110	YALLAMMANAWADI-SAVALAGI	STATION NOT AFFECTED YALLAMMANAWADI_110	8:10	19:06	10:56	LINE CLEAR AVAILED
360	27-Apr-22	BAGALKOT	220	220/110KV, HV1&LV1	MAHALINGAPUR_220	5:48	6:23	0:35	HAND TRIPPED
361	27-Apr-22	BAGALKOT	220	220/110KV, HV2&LV2	MAHALINGAPUR_220	5:48	7:24	1:36	HAND TRIPPED
362	27-Apr-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
363	27-Apr-22	BAGALKOT	220	AMBEWADI-NAGJHARI2	AMBEWADI_220	18:27	18:45	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
364	27-Apr-22	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	13:13	15:05	1:52	LINE CLEAR AVAILED
365	27-Apr-22	BAGALKOT	220	BIDNAL-HUBLI 3	BIDNAL_220	11:23	18:41	7:18	NFBC ISSUED
366	27-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
367	27-Apr-22	BAGALKOT	220	HUBLI_BIDNAL2	STATION NOT AFFECTED HUBLI_220	13:20	18:41	5:21	LINE FAULT
368	27-Apr-22	BAGALKOT	220	HUBLI_NARENDRA 1	STATION NOT AFFECTED HUBLI_220	16:01	18:36	2:35	LINE FAULT
369	27-Apr-22	BAGALKOT	220	HUBLI_SIRSI2	STATION NOT AFFECTED HUBLI_220	13:49	13:50	0:01	LINE FAULT
370	27-Apr-22	BAGALKOT	220	HUBLI_SIRSI2	STATION NOT AFFECTED HUBLI_220	19:08	22:25	3:17	LINE FAULT
371	27-Apr-22	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	18:28 (27.04.2022)			LINE OPEN:LINE FAULT
372	27-Apr-22	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	13:13	15:04	1:51	LINE CLEAR AVAILED
373	27-Apr-22	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	16:01	18:36	2:35	LINE FAULT
374	27-Apr-22	BAGALKOT	220	RANEBENNUR-BALLIGAVI	STATION NOT AFFECTED RANEBENNUR_220	14:45 (27.04.2022)			LINE OPEN:LINE CLEAR AVAILED
375	27-Apr-22	BAGALKOT	220	RANEBENNUR-GUTTUR	STATION NOT AFFECTED RANEBENNUR_220	10:15	20:35	10:20	NFBC ISSUED
376	27-Apr-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:33 (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
377	27-Apr-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:33 (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
378	27-Apr-22	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	14:14	14:30	0:16	LINE FAULT
379	27-Apr-22	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	20:15(18-4-2022)			LINE OPEN:LINE FAULT
380	27-Apr-22	BENGALURU	66	BIAL BEGUR 220 - VIDYANAGARA	VIDYANAGARA	19:27	21:12	1:45	LINE FAULT
381	27-Apr-22	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	13:54	13:57	0:03	LOAD CHANGE OVER
382	27-Apr-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	22:41(26-4-2022)	2:00(27-4-2022)	3:18 hrs	LINE CHARGED
383	27-Apr-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	14:02	14:15	0:13	LINE FAULT
384	27-Apr-22	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	13:31	13:36	0:05	LOAD CHANGE OVER
385	27-Apr-22	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	11:32	11:37	0:05	LOAD CHANGE OVER
386	27-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	8:44	8:58	0:14	LINE FAULT
387	27-Apr-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	14:37	14:48	0:10	LINE FAULT
388	27-Apr-22	BENGALURU	66	HV1	DEVANAHALLI	16:02	16:06	0:03	LINE CLEAR AVAILED
389	27-Apr-22	BENGALURU	66	HV1	DOMMASANDRA	17:45	18:05	0:20	TRANSFORMER FAULT
390	27-Apr-22	BENGALURU	66	HV1	DOMMASANDRA	21:04	21:20	0:15	TRANSFORMER FAULT
391	27-Apr-22	BENGALURU	66	HV1	DOMMASANDRA	21:28(27-4-2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
392	27-Apr-22	BENGALURU	66	HV1	HSR LAYOUT 220	14:08	14:16	0:08	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
393	27-Apr-22	BENGALURU	66	HV1	HUKUNDA	14:14	14:20	0:05	LINE CLEAR AVAILED
394	27-Apr-22	BENGALURU	66	HV1	HUKUNDA	15:40	16:02	0:22	LINE CLEAR AVAILED
395	27-Apr-22	BENGALURU	66	HV1	LR BANDE	6:35	6:50	0:15	TRANSFORMER FAULT
396	27-Apr-22	BENGALURU	66	HV1	PALLICHERLU	23:08(24-4-2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
397	27-Apr-22	BENGALURU	66	HV1	VIDYANAGAR	19:25	21:13	1:48	TRANSFORMER FAULT
398	27-Apr-22	BENGALURU	66	HV1	VIJAYANAGARA	17:46	18:01	0:15	MAIN SUPPLY FAILURE
399	27-Apr-22	BENGALURU	66	HV1	VIJAYANAGARA	18:46	18:50	0:04	LOAD CHANGE OVER
400	27-Apr-22	BENGALURU	66	HV2	HSR LAYOUT 220	14:08	14:16	0:08	LOAD CHANGE OVER
401	27-Apr-22	BENGALURU	66	HV2	KONDASPURA	13:32	13:44	0:12	LINE CLEAR AVAILED
402	27-Apr-22	BENGALURU	66	HV3	HSR LAYOUT 220	14:08	14:16	0:08	LOAD CHANGE OVER
403	27-Apr-22	BENGALURU	66	IISc - NRS 220	IISc	17:00	17:03	0:03	LOAD CHANGE OVER
404	27-Apr-22	BENGALURU	66	JIGANI 66 - YERANDANAHALLI 220	JIGANI 66	13:54	14:37	0:43	MAIN SUPPLY FAILURE
405	27-Apr-22	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	12:50	14:10	1:20	LINE CLEAR AVAILED
406	27-Apr-22	BENGALURU	66	KOLAR 220 - MULBAGLU	NO STATION AFFECTED	19:20(14-04-2022)			LINE OPEN:LINE FAULT
407	27-Apr-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	19:07	19:30	0:23	LOAD CURTAILMENT
408	27-Apr-22	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	15:04	15:07	0:03	LOAD CHANGE OVER
409	27-Apr-22	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	15:14	15:17	0:03	MAIN SUPPLY FAILURE
410	27-Apr-22	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	16:36	16:41	0:04	LOAD CHANGE OVER
411	27-Apr-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI	16:36	16:41	0:05	LOAD CHANGE OVER
412	27-Apr-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI	15:14	15:17	0:03	MAIN SUPPLY FAILURE
413	27-Apr-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	15:15	15:21	0:05	MAIN SUPPLY FAILURE
414	27-Apr-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	15:21	15:25	0:03	LINE FAULT
415	27-Apr-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	15:25	15:39	0:14	LINE FAULT
416	27-Apr-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	16:36	16:41	0:04	LOAD CHANGE OVER
417	27-Apr-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1, INFOSYS(EHT), HULIMANGALA	13:21	14:06	0:45	LINE CLEAR AVAILED
418	27-Apr-22	BENGALURU	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA, HUSKUR	13:21	14:06	0:45	LINE CLEAR AVAILED
419	27-Apr-22	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	17:46	18:01	0:15	LINE FAULT
420	27-Apr-22	BENGALURU	66	TALAGAWARA - KOLAR 220	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	1:55	2:00	0:05	LOAD CHANGE OVER
421	27-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	13:40	14:44	1:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
422	27-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	14:45	14:50	0:05	LINE FAULT
423	27-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	13:40	14:31	0:51	LINE CLEAR AVAILED
424	27-Apr-22	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	NO STATION AFFECTED	13:10	13:52	0:42	LINE FAULT
425	27-Apr-22	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	NO STATION AFFECTED	13:10	13:59	0:49	LINE FAULT
426	27-Apr-22	BENGALURU	220	HV1	YARANDANAHALLI 220	13:40	14:28	0:48	MAIN SUPPLY FAILURE
427	27-Apr-22	BENGALURU	220	HV2	HSR LAYOUT 220	14:08	14:16	0:08	LOAD CHANGE OVER
428	27-Apr-22	BENGALURU	220	NAGANATHPURA 220 - SOMANAHALLI 220	NAGANATHPURA 220	13:21	14:01	0:40	MAIN SUPPLY FAILURE
429	27-Apr-22	BENGALURU	220	SOMANAHALLI 220 - NAGANATHPURA 220	NAGANATHPURA 220	13:21	13:42	0:21	LINE FAULT
430	27-Apr-22	BENGALURU	220	SOMANAHALLI 220 - NAGANATHPURA 220	NO STATION AFFECTED	13:42	15:41	1:59	LINE FAULT
431	27-Apr-22	BENGALURU	220	YARANDANAHALLI 220 - HOSUR 220	YARANDANAHALLI 220	13:40	14:28	0:48	MAIN SUPPLY FAILURE
432	27-Apr-22	GULBARGA	66	HOSAHALLI-SML_WND	HOASAHALLI_66	18:50	19:05	0:15	LINE FAULT
433	27-Apr-22	GULBARGA	66	HV1	TAMBRAHALLI_66	15:05	15:25	0:20	LINE CLEAR AVAILED
434	27-Apr-22	GULBARGA	66	HV2	HALVAGALU_66	17:10	17:15	0:05	TRANSFORMER FAULT
435	27-Apr-22	GULBARGA	66	HV2	HALVAGALU_66	15:40	15:45	0:05	TRANSFORMER FAULT
436	27-Apr-22	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	15:27	15:42	0:15	LINE FAULT
437	27-Apr-22	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	18:30	18:41	0:11	LINE FAULT
438	27-Apr-22	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	12:10	12:55	0:45	LINE CLEAR AVAILED
439	27-Apr-22	GULBARGA	66	UCCHANGIDURGA-BILCHOD	BILCHOD_66	2:35	2:40	0:05	LINE FAULT
440	27-Apr-22	GULBARGA	66	UCCHANGIDURGA-BILCHOD	BILCHOD_66	2:35	2:40	0:05	LINE FAULT
441	27-Apr-22	GULBARGA	110	AURAD-SANTHPUR	AURAD_110	5:35	5:40	0:05	MAIN SUPPLY FAILURE
442	27-Apr-22	GULBARGA	110	CHINCHOLI-MANEKHALI	MANEKHALI_110,CHEETINAD_IPP ,EKLAID_IPP	12:42	13:08	0:26	LINE FAULT
443	27-Apr-22	GULBARGA	110	HV1	MATAMARI_110	19:20	20:05	0:45	LINE CLEAR AVAILED
444	27-Apr-22	GULBARGA	110	HV1	KOLHAR_110	13:25	14:45	1:20	LINE CLEAR AVAILED
445	27-Apr-22	GULBARGA	110	HV2	DEODURGA_110	14:35	14:50	0:15	TRANSFORMER FAULT
446	27-Apr-22	GULBARGA	110	HV2	DUBALGUNDI_110	14:05	14:10	0:05	TRANSFORMER FAULT
447	27-Apr-22	GULBARGA	110	HV3	VALKAMDINNI_110	5:10	5:15	0:05	TRANSFORMER FAULT
448	27-Apr-22	GULBARGA	110	HV3	CHINCHOLI_110	12:42	13:00	0:18	TRANSFORMER FAULT
449	27-Apr-22	GULBARGA	110	HV3,HV4,HV2	YELBURGA_110	10:38	16:43	6:05	LINE CLEAR AVAILED
450	27-Apr-22	GULBARGA	110	KAVITAL-MANTHAL	KAVITAL_110	0:50	0:55	0:05	MAIN SUPPLY FAILURE
451	27-Apr-22	GULBARGA	110	KUSTAGI-VAJRABANDI	VAJRABANDI_110,YELBURAG_110,KUKNOOR_110	17:20 (26.04.2022)	00:25 (27.04.2022)	7:05 HRS	LINE CHARGED
452	27-Apr-22	GULBARGA	110	KUSTAGI-VAJRABANDI	VAJRABANDI_110,YELBURAG_110,KUKNOOR_110	11:09	16:28	5:19	LINE CLEAR AVAILED
453	27-Apr-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	20:10	21:07	0:57	LINE FAULT
454	27-Apr-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	21:01	21:07	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
455	27-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	21:13	21:15	0:02	LINE FAULT
456	27-Apr-22	GULBARGA	110	MUDDAPURA-SINDHANOOR	MUDDAPUR_110	0:52	1:05	0:13	MAIN SUPPLY FAILURE
457	27-Apr-22	GULBARGA	110	MUDDAPURA-SINDHANOOR	MUDDAPUR_110	1:06	1:15	0:09	MAIN SUPPLY FAILURE
458	27-Apr-22	GULBARGA	110	MUDDAPURA-SINDHANOOR	MUDDAPUR_110	0:52	1:05	0:13	LINE FAULT
459	27-Apr-22	GULBARGA	110	NEELGUNDA-HARAPANAHALLI	HARAPANAHALLI_110	6:11	6:17	0:06	LINE FAULT
460	27-Apr-22	GULBARGA	110	SANKLAPUR-TORANGALU	TORANGALU_110	18:28	18:40	0:12	LINE FAULT
461	27-Apr-22	GULBARGA	110	SEDAM-ULTRATECH_IPP	SEDAM_220	5:20	5:25	0:05	LINE FAULT
462	27-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
463	27-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
464	27-Apr-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YER DONA_110,SRNAGAR_110,MALL APURA_110	5:02	5:12	0:10	LINE FAULT
465	27-Apr-22	GULBARGA	110	YELBURGA-KUKUNOOR,TALAKUTAI	YELBURGA_110	10:33	16:39	6:06	LINE CLEAR AVAILED
466	27-Apr-22	GULBARGA	110	YELBURGA-PARAM PUJYA	YELBURGA_110	10:28	16:58	6:30	LINE FAULT
467	27-Apr-22	GULBARGA	110	YELBURGA-WAJRABANDI	YELBURGA_110	10:40	16:36	5:56	LINE CLEAR AVAILED
468	27-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
469	27-Apr-22	GULBARGA	220	HV2	NEELGUNDA_220	15:20	15:40	0:20	TRANSFORMER FAULT
470	27-Apr-22	GULBARGA	220	ITTAGI-NEELAGUNDA	NEELGUNDA_220	14:57	15:37	0:40	LINE FAULT
471	27-Apr-22	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	22:52	23:16	0:24	LINE FAULT
472	27-Apr-22	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	9:50	19:02	9:12	LINE CLEAR AVAILED
473	27-Apr-22	GULBARGA	400	JSWL-RE LIN2	JSWL_400	17:29	21:45	4:16	LINE CLEAR AVAILED
474	27-Apr-22	GULBARGA	400	RTPS-BTPS	RTPS_400	17:37	21:50	4:13	LINE FAULT
475	27-Apr-22	HASSAN	66	BHADRA-LINGADAHALLI	gen_bhadra	13:20	13:35	0:15	MAIN SUPPLY FAILURE
476	27-Apr-22	HASSAN	66	BHADRA-SHMGA 1	gen_bhadra	13:20	13:36	0:16	MAIN SUPPLY FAILURE
477	27-Apr-22	HASSAN	66	BHADRA-SHMGA 2	gen_bhadra	13:20	13:37	0:17	MAIN SUPPLY FAILURE
478	27-Apr-22	HASSAN	66	CRPATNA-HNPURA	CHANNARAYAPATNA_220	13:41	13:45	0:04	MAIN SUPPLY FAILURE
479	27-Apr-22	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_220	13:41	14:46	1:05	MAIN SUPPLY FAILURE
480	27-Apr-22	HASSAN	66	CRPATNA-SBELAGOLA1	CHANNARAYAPATNA_220	13:41	14:46	1:05	MAIN SUPPLY FAILURE
481	27-Apr-22	HASSAN	66	CRPATNA-SBELAGOLA2	CHANNARAYAPATNA_220	13:41	14:46	1:05	MAIN SUPPLY FAILURE
482	27-Apr-22	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLI_66	8:40	8:51	0:11	LOAD CHANGE OVER
483	27-Apr-22	HASSAN	66	HV1	HOLEHONNUR_66	10:55 (26.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
484	27-Apr-22	HASSAN	66	HV1	MALALI_66	16:26	17:10	0:44	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
485	27-Apr-22	HASSAN	66	HV1	SHRAVANABELAGOLA_66	13:35	13:45	0:10	MAIN SUPPLY FAILURE
486	27-Apr-22	HASSAN	66	HV1	SHRAVANABELAGOLA_66	14:30	14:45	0:15	MAIN SUPPLY FAILURE
487	27-Apr-22	HASSAN	66	HV1	SHRAVANABELAGOLA_66	19:02	19:15	0:13	TRANSFORMER FAULT
488	27-Apr-22	HASSAN	66	HV2	BELUR_66	9:35	9:45	0:10	TRANSFORMER FAULT
489	27-Apr-22	HASSAN	66	HV2	DIDIGA_66	13:40	13:50	0:10	LINE CLEAR AVAILED
490	27-Apr-22	HASSAN	66	HV2	DIDIGA_66	14:30	15:00	0:30	MAIN SUPPLY FAILURE
491	27-Apr-22	HASSAN	66	HV2	SALAGAME_66	19:00	19:10	0:10	TRANSFORMER FAULT
492	27-Apr-22	HASSAN	66	HV2	SINGAPURA_66	19:05	19:22	0:17	TRANSFORMER FAULT
493	27-Apr-22	HASSAN	66	LV1	CHANNARAYAPATNA_220	13:52	14:16	0:24	TRANSFORMER FAULT
494	27-Apr-22	HASSAN	66	LV1	CHANNARAYAPATNA_220	14:19	14:35	0:16	TRANSFORMER FAULT
495	27-Apr-22	HASSAN	66	LV2	CHANNARAYAPATNA_220	13:36	13:42	0:06	TRANSFORMER FAULT
496	27-Apr-22	HASSAN	66	MRSSHM-BD-1	MRSMG_220	13:13	13:35	0:22	HAND TRIPPED
497	27-Apr-22	HASSAN	66	MRSSHM-BD-2	MRSMG_220	13:13	13:35	0:22	HAND TRIPPED
498	27-Apr-22	HASSAN	66	MRSSHM-DVG2	MRSMG_220	13:13	13:36	0:23	HAND TRIPPED
499	27-Apr-22	HASSAN	66	MRSSHM-DVG2	MRSMG_220	14:31	14:40	0:09	LINE FAULT
500	27-Apr-22	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	13:13	13:36	0:23	HAND TRIPPED
501	27-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
502	27-Apr-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	14:35	14:55	0:20	HAND TRIPPED
503	27-Apr-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	13:10	13:35	0:25	MAIN SUPPLY FAILURE
504	27-Apr-22	HASSAN	66	SOMNHL-GDNEHALI	SOMANAHALLI_66	12:20	14:46	2:26	LINE CLEAR AVAILED
505	27-Apr-22	HASSAN	66	SOMNHL-HN PURA	SOMANAHALLI_66	12:20	14:48	2:28	LINE CLEAR AVAILED
506	27-Apr-22	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPPLU_66	9:00	12:05	3:05	LINE FAULT
507	27-Apr-22	HASSAN	110	HV1	NITTUR_110	19:50	20:58	1:08	TRANSFORMER FAULT
508	27-Apr-22	HASSAN	110	HV1	VITTAL_110	9:40	13:22	3:42	LINE CLEAR AVAILED
509	27-Apr-22	HASSAN	110	HV2	VITTAL_110	13:27	15:35	2:08	LINE CLEAR AVAILED
510	27-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
511	27-Apr-22	HASSAN	110	HV3	SAGARA_110	11:00	16:45	5:45	LINE CLEAR AVAILED
512	27-Apr-22	HASSAN	110	HV5	KAVOOR_220	8:45 (26.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
513	27-Apr-22	HASSAN	110	HV5	MRSMG_220	13:13	13:40	0:27	HAND TRIPPED
514	27-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
515	27-Apr-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	14:30	18:52	4:22	LINE FAULT
516	27-Apr-22	HASSAN	110	LPH-LST3	gen_lph	11:19	11:46	0:27	LINE FAULT
517	27-Apr-22	HASSAN	110	LPH-LST4	gen_lph	11:18	11:46	0:28	LINE FAULT
518	27-Apr-22	HASSAN	110	LV1	MRSMG_220	13:13	13:48	0:35	HAND TRIPPED
519	27-Apr-22	HASSAN	110	LV2	MRSMG_220	13:13	13:40	0:27	HAND TRIPPED
520	27-Apr-22	HASSAN	110	LV3	MRSMG_220	13:13	13:33	0:20	HAND TRIPPED
521	27-Apr-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	13:13	13:51	0:38	HAND TRIPPED
522	27-Apr-22	HASSAN	110	MRSSHM-BADRAVATY2	MRSMG_220	13:13	13:52	0:39	HAND TRIPPED
523	27-Apr-22	HASSAN	110	MRSSHM-BADRAVATY3	MRSMG_220	13:13	13:42	0:29	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
524	27-Apr-22	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	13:13	13:49	0:36	HAND TRIPPED
525	27-Apr-22	HASSAN	110	MRSSHM-MPM	MRSMSG_220	13:13	13:51	0:38	HAND TRIPPED
526	27-Apr-22	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	13:13	13:45	0:32	HAND TRIPPED
527	27-Apr-22	HASSAN	110	MRSSHM-SS1	MRSMSG_220	13:13	13:49	0:36	HAND TRIPPED
528	27-Apr-22	HASSAN	110	MRSSHM-SS2	MRSMSG_220	13:13	13:50	0:37	HAND TRIPPED
529	27-Apr-22	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	14:31	15:08	0:37	LINE FAULT
530	27-Apr-22	HASSAN	110	SAGARA-ALKLA	SAGARA_110	13:50	14:05	0:15	MAIN SUPPLY FAILURE
531	27-Apr-22	HASSAN	110	SAGARA-SS1	SAGARA_110	11:20	12:00	0:40	LINE FAULT
532	27-Apr-22	HASSAN	110	SAGARA-SS1	SAGARA_110	13:50	14:05	0:15	HAND TRIPPED
533	27-Apr-22	HASSAN	110	SHRLKP-BARANGI	SHIRALKOPPA_220	21:32	21:37	0:05	LINE FAULT
534	27-Apr-22	HASSAN	110	SORABA-MAVUNI	SORABA_110	14:30	14:55	0:25	MAIN SUPPLY FAILURE
535	27-Apr-22	HASSAN	110	SORABA-SHR220	SORABA_110	13:50	14:01	0:11	MAIN SUPPLY FAILURE
536	27-Apr-22	HASSAN	220	HV1	CHANNARAYAPATNA_220	13:52	14:16	0:24	TRANSFORMER FAULT
537	27-Apr-22	HASSAN	220	HV1	CHANNARAYAPATNA_220	14:19	14:35	0:16	TRANSFORMER FAULT
538	27-Apr-22	HASSAN	220	HV1	MRSMSG_220	13:13	13:48	0:35	HAND TRIPPED
539	27-Apr-22	HASSAN	220	HV2	CHANNARAYAPATNA_220	13:36	13:42	0:06	TRANSFORMER FAULT
540	27-Apr-22	HASSAN	220	HV2	MRSMSG_220	13:13	13:40	0:27	HAND TRIPPED
541	27-Apr-22	HASSAN	220	HV3	MRSMSG_220	13:13	13:33	0:20	HAND TRIPPED
542	27-Apr-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	13:13	13:24	0:11	LINE FAULT
543	27-Apr-22	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	13:13	13:42	0:29	HAND TRIPPED
544	27-Apr-22	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	13:13	13:42	0:29	HAND TRIPPED
545	27-Apr-22	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	12:51(25.04.2022)	14:17(27.04.2022)	49:25 hrs	LINE CHARGED
546	27-Apr-22	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	13:13	13:58	0:45	HAND TRIPPED
547	27-Apr-22	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	13:13	13:34	0:21	HAND TRIPPED
548	27-Apr-22	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	13:13	13:34	0:21	HAND TRIPPED
549	27-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:13	13:50	0:37	HAND TRIPPED
550	27-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	13:13	13:32	0:19	HAND TRIPPED
551	27-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	13:13	13:31	0:18	HAND TRIPPED
552	27-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:13	13:31	0:18	HAND TRIPPED
553	27-Apr-22	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	13:13	13:41	0:28	HAND TRIPPED
554	27-Apr-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:13	13:41	0:28	HAND TRIPPED
555	27-Apr-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	16:19	16:24	0:05	LINE CLEAR AVAILED
556	27-Apr-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	16:45	16:46	0:01	HAND TRIPPED
557	27-Apr-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	16:47	16:49	0:02	HAND TRIPPED
558	27-Apr-22	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	13:13	13:42	0:29	HAND TRIPPED
559	27-Apr-22	HASSAN	220	SHRAVITY-SHIMOGA 2	gen_sharavthy	13:13	13:32	0:19	HAND TRIPPED
560	27-Apr-22	HASSAN	220	SHRAVITY-SHIMOGA1	gen_sharavthy	13:13	13:32	0:19	HAND TRIPPED
561	27-Apr-22	HASSAN	220	SHRAVITY-SHIMOGA3	gen_sharavthy	13:13	13:32	0:19	HAND TRIPPED
562	27-Apr-22	HASSAN	220	SHRAVITY-SHIMOGA4	gen_sharavthy	13:13	13:32	0:19	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
563	27-Apr-22	HASSAN	220	SHRAVITY-SHIRALKOPPA	gen_sharavthy	13:04	13:40	0:36	LINE FAULT
564	27-Apr-22	HASSAN	220	SHRAVITY-SHIRALKOPPA	gen_sharavthy	14:31	14:49	0:18	LINE FAULT
565	27-Apr-22	HASSAN	220	SHRLKP-SHRAVITY	SHIRALKOPPA_220	13:04	13:40	0:36	LINE FAULT
566	27-Apr-22	HASSAN	220	SHRLKP-SHRAVITY	SHIRALKOPPA_220	14:31	14:49	0:18	LINE FAULT
567	27-Apr-22	HASSAN	220	TALAGU-STRP3	TALAGUPPA_400	9:10	12:45	3:35	HAND TRIPPED
568	27-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
569	27-Apr-22	MYSURU	66	CHUNCHANAKATTE-RAVANDUR	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	5:35	5:45	0:09	LINE FAULT
570	27-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
571	27-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
572	27-Apr-22	MYSURU	66	HOOTAGALLI-BARC-2	NO STATIONS EFFECTED	10:25	12:12	1:47	LINE CLEAR AVAILED
573	27-Apr-22	MYSURU	66	HOOTAGALLI-BELAGOLA	NO STATIONS EFFECTED	10:55	11:18	0:23	LINE CLEAR AVAILED
574	27-Apr-22	MYSURU	66	HV1	NAGAMANGALA_66	19:02	19:06	0:04	LINE CLEAR AVAILED
575	27-Apr-22	MYSURU	66	HV1	SALIGRAMA_66	19:02	19:08	0:05	LINE CLEAR AVAILED
576	27-Apr-22	MYSURU	66	HV1	SATHEGALA_66	19:02	19:08	0:05	LINE CLEAR AVAILED
577	27-Apr-22	MYSURU	66	HV2	DATTAGALLY_66	11:25	13:41	2:16	LINE CLEAR AVAILED
578	27-Apr-22	MYSURU	66	HV2	MALAVALLI_66	11:48	11:54	0:05	TRANSFORMER FAULT
579	27-Apr-22	MYSURU	66	HV2	SANTHEMARAHALLI_66	19:02	19:14	0:11	LINE CLEAR AVAILED
580	27-Apr-22	MYSURU	66	HV2	SANTHESARAGUR_66	19:02	19:10	0:08	LINE CLEAR AVAILED
581	27-Apr-22	MYSURU	66	HV2	THANDYA_66	0:59	1:25	0:26	TRANSFORMER FAULT
582	27-Apr-22	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	11:06	13:20	2:14	LINE CLEAR AVAILED
583	27-Apr-22	MYSURU	66	KUSHALNAGARA-MYSORE-1	MIRLE_66	20:27	20:36	0:08	LINE FAULT
584	27-Apr-22	MYSURU	66	SFC SHIVA-10 MW	NO STATIONS EFFECTED	10:15:00 PM (26.04.2022)	6:18:00 (27.04.2022)	8:03 hrs	LINE CHARGED
585	27-Apr-22	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66PANDA VAPURA_66BELAGOLA_66BANAN GADI_66	5:48	5:53	0:05	LINE FAULT
586	27-Apr-22	MYSURU	66	VAJMANGALA-BANNUR	BANNUR_66	22:30	22:38	0:08	LINE FAULT
587	27-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
588	27-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
589	27-Apr-22	TUMKUR	66	ANCHEPALYA 220kv-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	18:43	18:53	0:10	LINE FAULT
590	27-Apr-22	TUMKUR	66	ANCHEPALYA 220kv-VIJAYA STEEL	VIJAYA STEEL	7:03	8:24	1:21	LINE FAULT
591	27-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	18:58	19:34	0:36	LOAD CURTAILMENT
592	27-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	23:21(27.4.22)	0:05(27.4.22)	0:44	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
593	27-Apr-22	TUMKUR	66	BADAVANAHALLI-MADHUGIRI	BADAVANAHALLI_66	23:28	23:45	0:16	LINE FAULT
594	27-Apr-22	TUMKUR	66	BILCHODU-UCHANGIDURGA	BILCHODU_66	2:32	2:38	0:06	LINE FAULT
595	27-Apr-22	TUMKUR	66	CHITRADURGA 220kV-HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	10:26	10:42	0:16	LINE FAULT
596	27-Apr-22	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:32	6:41	0:08	LINE FAULT
597	27-Apr-22	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	3:36	3:50	0:14	LINE FAULT
598	27-Apr-22	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	4:42	4:52	0:10	LINE FAULT
599	27-Apr-22	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	5:20	5:30	0:09	LINE FAULT
600	27-Apr-22	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	19:06	19:18	0:12	LINE FAULT
601	27-Apr-22	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	19:05	19:16	0:10	HAND TRIPPED
602	27-Apr-22	TUMKUR	66	MADHUGIRI 220kV-KORATAGERE 1	KORATAGERE_66	16:56	17:17	0:20	HAND TRIPPED
603	27-Apr-22	TUMKUR	66	MADHUGIRI 220kV-NITRAHALLI	NITRAHALLI_66	16:56	17:16	0:20	HAND TRIPPED
604	27-Apr-22	TUMKUR	66	NAGASAMUDRA-RAMPUR	NAGASAMUDRA_66, RAMPURA_66	6:20	6:23	0:02	MAIN SUPPLY FAILURE
605	27-Apr-22	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	18:53	19:03	0:10	LINE CLEAR AVAILED
606	27-Apr-22	TUMKUR	66	SIRA220-PATNAYAKANAHALLI 1	PATNAYAKANAHALLI 1	5:32	5:47	0:14	LINE FAULT
607	27-Apr-22	TUMKUR	66	TR-1	CHITRADURGA_66	16:07	16:47	0:40	LINE CLEAR AVAILED
608	27-Apr-22	TUMKUR	66	TR-1	NIDASALE_66	10:36	10:55	0:18	TRANSFORMER FAULT
609	27-Apr-22	TUMKUR	66	TR-2	BALENAHALLI_66	9:06	9:36	0:29	LINE CLEAR AVAILED
610	27-Apr-22	TUMKUR	66	TR-2	GUTTUR_66	15:09	16:05	0:56	LINE CLEAR AVAILED
611	27-Apr-22	TUMKUR	66	TR-2(LV2)	MADHUGIRI_220	16:15	17:11	0:56	HAND TRIPPED
612	27-Apr-22	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	0:10	0:27	0:17	LOAD CURTAILMENT
613	27-Apr-22	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	13:37	13:50	0:12	MAIN SUPPLY FAILURE
614	27-Apr-22	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	13:52	14:19	0:27	HAND TRIPPED
615	27-Apr-22	TUMKUR	110	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	14:36	14:45	0:09	MAIN SUPPLY FAILURE
616	27-Apr-22	TUMKUR	110	TR-1	HUNASEGHATTA_110	12:20	14:20	2:00	LINE CLEAR AVAILED
617	27-Apr-22	TUMKUR	110	TR-1	KALLUR_110	19:02	19:11	0:09	TRANSFORMER FAULT
618	27-Apr-22	TUMKUR	110	TR-1	THIMMANAHALLI_110	13:15	14:10	0:55	MAIN SUPPLY FAILURE
619	27-Apr-22	TUMKUR	110	TR-2	HUNASEGHATTA_110	12:20	14:20	2:00	LINE CLEAR AVAILED
620	27-Apr-22	TUMKUR	110	TR-2	THIMMANAHALLI_110	13:15	14:10	0:55	MAIN SUPPLY FAILURE
621	27-Apr-22	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	13:31	18:38	5:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
622	27-Apr-22	TUMKUR	220	THALLAK 220KV -HIRIYUR	SANEKERE_66, THALLAKK_220	15:33	18:48	3:15	LINE CLEAR AVAILED
623	27-Apr-22	TUMKUR	220	TR-2	MADHUGIRI_220	16:15	17:05	0:50	TRANSFORMER FAULT
624	28-Apr-22	BAGALKOT	66	66/11KV, HV2	HARIHAR HOSPET_66	11:11	11:30	0:19	LINE CLEAR AVAILED
625	28-Apr-22	BAGALKOT	66	66/11KV,HV2	HARIHAR HOSPET_110	11:10	11:30	0:20	LINE CLEAR AVAILED
626	28-Apr-22	BAGALKOT	110	(AMBEWADI)SIRSI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	6:25	19:05	12:40	LINE CLEAR AVAILED
627	28-Apr-22	BAGALKOT	110	(AMBEWADI)SIRSI-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	21:16	21:45	0:29	LOAD CHANGE OVER
628	28-Apr-22	BAGALKOT	110	110/11KV, HV1	MK HUBLI_220	19:15	19:35	0:20	TRANSFORMER FAULT
629	28-Apr-22	BAGALKOT	110	110/11KV, HV1	MK HUBLI_220	19:15	19:35	0:20	TRANSFORMER FAULT
630	28-Apr-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED RAIBAG_110	19:18	19:45	0:27	TRANSFORMER FAULT
631	28-Apr-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIRSI_110	20:03	20:39	0:36	TRANSFORMER FAULT
632	28-Apr-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED VAJJRAMATTI_110	7:52	8:06	0:14	TRANSFORMER FAULT
633	28-Apr-22	BAGALKOT	110	110/11KV, HV1	TOLAMATTI_110	15:00	15:03	0:03	TRANSFORMER FAULT
634	28-Apr-22	BAGALKOT	110	110/11KV, HV1	UKKALI_110	18:47	20:10	1:23	TRANSFORMER FAULT
635	28-Apr-22	BAGALKOT	110	110/11KV, HV1	UKKALI_110	15:18	18:46	3:28	TRANSFORMER FAULT
636	28-Apr-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RON_110	17:39	18:10	0:31	TRANSFORMER FAULT
637	28-Apr-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SANKESHWER_110	19:18	19:26	0:08	TRANSFORMER FAULT
638	28-Apr-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_110	20:03	20:35	0:32	TRANSFORMER FAULT
639	28-Apr-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YELPARATTI_110	16:22	18:49	2:27	TRANSFORMER FAULT
640	28-Apr-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YELPARATTI_110	8:29	15:41	7:12	TRANSFORMER FAULT
641	28-Apr-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED RAIBAG_110	19:18	19:45	0:27	TRANSFORMER FAULT
642	28-Apr-22	BAGALKOT	110	110/11KV,HV1	BJCTY_110(TORVI_110)	14:30	16:38	2:08	HAND TRIPPED
643	28-Apr-22	BAGALKOT	110	110/11KV,HV1	JAMAKHANDI_110	23:43 (28.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
644	28-Apr-22	BAGALKOT	110	110/11KV,HV1	KUDUCHI_220	19:17	19:21	0:04	TRANSFORMER FAULT
645	28-Apr-22	BAGALKOT	110	110/11KV,HV1	MALGHAN_110	20:11	20:24	0:13	TRANSFORMER FAULT
646	28-Apr-22	BAGALKOT	110	110/11KV,HV1	MUDDEBIHAL_110	18:58	19:11	0:13	TRANSFORMER FAULT
647	28-Apr-22	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	15:56	16:26	0:30	TRANSFORMER FAULT
648	28-Apr-22	BAGALKOT	110	110/11KV,HV1	NAVALAGI_110	19:17	20:11	0:54	TRANSFORMER FAULT
649	28-Apr-22	BAGALKOT	110	110/11KV,HV1	NAVALGUND_110	10:26	13:20	2:54	LINE CLEAR AVAILED
650	28-Apr-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED AIGALI_110	16:35 (25.04.2022)	14:19 (28.04.2022)	69:44 hrs	TRANSFORMER CHARGED
651	28-Apr-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BBALESHWAR_110	18:04 (16.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
652	28-Apr-22	BAGALKOT	110	110/11KV,HV2	ANKALI_110	19:18	19:28	0:10	TRANSFORMER FAULT
653	28-Apr-22	BAGALKOT	110	110/11KV,HV2	BEDI_110	14:17	14:25	0:08	LINE CLEAR AVAILED
654	28-Apr-22	BAGALKOT	110	110/11KV,HV2	BJCTY_110(TORVI_110)	16:27	16:38	0:11	HAND TRIPPED
655	28-Apr-22	BAGALKOT	110	110/11KV,HV2	DAVALESHWAR_110	16:33	16:45	0:12	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
656	28-Apr-22	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	20:07	21:54	1:47	TRANSFORMER FAULT
657	28-Apr-22	BAGALKOT	110	110/11KV,HV2	NAVALAGI_110	19:17	20:11	0:54	TRANSFORMER FAULT
658	28-Apr-22	BAGALKOT	110	110/11KV,HV2	NIPPANI_110	19:18	19:22	0:04	TRANSFORMER FAULT
659	28-Apr-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHVAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
660	28-Apr-22	BAGALKOT	110	110/11KV,HV3	STATION NOT AFFECTED TIKOTA_110	10:28	10:50	0:22	LINE CLEAR AVAILED
661	28-Apr-22	BAGALKOT	110	110/11KV,HV4	KERUR_110	17:31	19:46	2:15	TRANSFORMER FAULT
662	28-Apr-22	BAGALKOT	110	110/11KV,HV4	KERUR_110	7:25	8:29	1:04	LINE CLEAR AVAILED
663	28-Apr-22	BAGALKOT	110	110/33, HV3	SHIGGAON_33, AMBUJA_33, KPCL SOLAR_33 STATION NOT AFFECTED SHIGGAON_110	18:30	18:58	0:28	TRANSFORMER FAULT
664	28-Apr-22	BAGALKOT	110	110/33KV, HV1	BAGALKOT_220, KATAGERI_33, GADDANKERI_33	16:31	16:50	0:19	TRANSFORMER FAULT
665	28-Apr-22	BAGALKOT	110	110/33KV, HV1	BAGALKOT_220, KATAGERI_33, GADDANKERI_33	18:36	20:05	1:29	TRANSFORMER FAULT
666	28-Apr-22	BAGALKOT	110	110/33KV, HV1	BAGALKOT_220, KATAGERI_33, GADDANKERI_33	23:08	23:12	0:04	TRANSFORMER FAULT
667	28-Apr-22	BAGALKOT	110	110/33KV, HV3	MUSHIGERI_33 STATION NOT AFFECTED RON_110	17:39	18:10	0:31	TRANSFORMER FAULT
668	28-Apr-22	BAGALKOT	110	110/33KV,HV2	AMINAGAD_33,KARADI_33,MYTR A_33, HUNGUND_110	16:32	16:40	0:08	TRANSFORMER FAULT
669	28-Apr-22	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110, KAROSHI_33,KERUR_33	18:13	18:40	0:27	TRANSFORMER FAULT
670	28-Apr-22	BAGALKOT	110	110/33KV,HV2	CHIKKODI_110, KAROSHI_33,KERUR_33	19:16	19:25	0:09	TRANSFORMER FAULT
671	28-Apr-22	BAGALKOT	110	110/33KV,HV2	TEGGI_33, STATION NOT AFFECTED BISNAL_110	8:05	8:14	0:09	TRANSFORMER FAULT
672	28-Apr-22	BAGALKOT	110	110/33KV,HV3	BENADI_33,JATRAT_33,MAGNU M TUFF_33 NIPPANI_110	19:18	19:22	0:04	TRANSFORMER FAULT
673	28-Apr-22	BAGALKOT	110	110/33KV,HV4	KOTWADI_33,KALLOLI LI,S,SHIRAGUPPI_33,STATION NOT AFFECTED ANKOLA_110,	19:18	19:28	0:10	TRANSFORMER FAULT
674	28-Apr-22	BAGALKOT	110	ANKOLA-KUMATA(L2)	KUMATA_110	20:42 (28.04.2022)			LINE OPEN:LINE FAULT
675	28-Apr-22	BAGALKOT	110	BAGALKOT220- GULEDAGUDDA	BAGALKOT_220	17:16	17:35	0:19	LINE FAULT
676	28-Apr-22	BAGALKOT	110	BAGALKOT220- GULEDAGUDDA	BAGALKOT_220	19:16	19:33	0:17	LINE FAULT
677	28-Apr-22	BAGALKOT	110	BAGALKOT220- KATARAKI (NEERBUDIHAL)	BAGALKOT_220	17:02	17:31	0:29	LINE FAULT
678	28-Apr-22	BAGALKOT	110	BAGALKOT220- KERUR	BAGALKOT_220	19:18	19:32	0:14	LINE FAULT
679	28-Apr-22	BAGALKOT	110	BAGALKOT220- LOKAPUR	BAGALKOT_220	17:02	17:40	0:38	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
680	28-Apr-22	BAGALKOT	110	BAGEWADI220-UKKALI	UKKALI_110	16:43	18:41	1:58	NFBC ISSUED
681	28-Apr-22	BAGALKOT	110	BAGEWADI-CHIMMALAGI LIS	STATION NOT AFFECTED BAGEWADI_220	17:39	18:06	0:27	LINE CLEAR AVAILED
682	28-Apr-22	BAGALKOT	110	BAGEWADI- MAMADAPUR1&2	STATION NOT AFFECTED BAGEWADI_220	17:39	18:06	0:27	LINE CLEAR AVAILED
683	28-Apr-22	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	STATION NOT AFFECTED BAGEWADI_220	17:39	18:06	0:27	LINE CLEAR AVAILED
684	28-Apr-22	BAGALKOT	110	BIDNAL220- ANNIGERI	BIDNAL_220	17:38	20:44	3:06	HAND TRIPPED
685	28-Apr-22	BAGALKOT	110	BIDNAL220- PH COMPOUND	BIDNAL_220	18:22	19:34	1:12	HAND TRIPPED
686	28-Apr-22	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	18:44 (28.04.2022)			LINE OPEN:LINE FAULT
687	28-Apr-22	BAGALKOT	110	GADAG220- SHIRAHATTI	GADAG_220	20:06 (28.04.2022)			LINE OPEN:LINE FAULT
688	28-Apr-22	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA	GHATAPRABHA_220	19:17	19:45	0:27	LINE FAULT
689	28-Apr-22	BAGALKOT	110	GHATAPRABHA220- SHIRGOAN	GHATAPRABHA_220	19:17	19:37	0:20	LINE FAULT
690	28-Apr-22	BAGALKOT	110	GOPPANAKOPPA-GADAG ROAD	GOPPANAKOPPA_110	18:02	18:24	0:22	LOAD CHANGE OVER
691	28-Apr-22	BAGALKOT	110	HUBLI- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	19:17	20:42	1:25	LINE FAULT
692	28-Apr-22	BAGALKOT	110	HUBLI- RAMANKOPPA	STATION NOT AFFECTED HUBLI_220	19:17	19:46	0:29	LINE FAULT
693	28-Apr-22	BAGALKOT	110	HUBLI220- RAMANAKOPPA	STATION NOT AFFECTED RAMANAKOPPA_110	19:42	19:59	0:17	LOAD CHANGE OVER
694	28-Apr-22	BAGALKOT	110	HUBLI-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	19:49	21:23	1:34	HAND TRIPPED
695	28-Apr-22	BAGALKOT	110	HUNGUND-JINDAL	STATION NOT AFFECTED HUNGUND_110	16:35 (28.04.2022)			LINE OPEN:LINE FAULT
696	28-Apr-22	BAGALKOT	110	KARWAR- ARG(KUMATA)	KARWAR_220	15:55	16:00	0:05	LINE FAULT
697	28-Apr-22	BAGALKOT	110	KARWAR- ARG(KUMATA)	KARWAR_220	16:32	16:37	0:05	LINE FAULT
698	28-Apr-22	BAGALKOT	110	KUDUCHI220- TEDAL(MORAB)	MORAB_110	19:16	19:24	0:08	LINE FAULT
699	28-Apr-22	BAGALKOT	110	LAXMESHVAR- SHIRAHATTI	STATION NOT AFFECTED LAXMESHVAR_110	20:06	21:01	0:55	LINE FAULT
700	28-Apr-22	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	17:00	18:20	1:20	LINE FAULT
701	28-Apr-22	BAGALKOT	110	MAHALINGAPUR-GSML2	STATION NOT AFFECTED MAHALINGAPUR_220	21:42 (24.04.2022)			LINE OPEN:LINE FAULT
702	28-Apr-22	BAGALKOT	110	MK HUBLI220-BEDI	MK HUBLI_220	19:15	19:38	0:23	LINE FAULT
703	28-Apr-22	BAGALKOT	110	MK HUBLI220-MK HUBLI2	MK HUBLI_220	19:15	19:40	0:25	LINE FAULT
704	28-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
705	28-Apr-22	BAGALKOT	110	RANEENNUR-BYADAGI	STATION NOT AFFECTED BYADAGI_110	17:59	18:54	0:55	LOAD CHANGE OVER
706	28-Apr-22	BAGALKOT	110	SAMBAPUR ROAD-RLY (RAILWAY)	RAILWAY_110 STATION NOT AFFECTED SAMBAPUR_110	18:49	19:25	0:36	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
707	28-Apr-22	BAGALKOT	110	SAVALAGI-AIGALI	STATION NOT AFFECTED SAVALAGI_110	9:11	18:48	9:37	LINE CLEAR AVAILED
708	28-Apr-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	18:16	19:27	1:11	LINE FAULT
709	28-Apr-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	17:53	18:04	0:11	LINE FAULT
710	28-Apr-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	17:47	17:53	0:06	LINE FAULT
711	28-Apr-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	17:36	17:42	0:06	LINE FAULT
712	28-Apr-22	BAGALKOT	110	SHIRAGUPPI-BISNAL	BISNAL_1110	8:15	8:24	0:09	MAIN SUPPLY FAILURE
713	28-Apr-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
714	28-Apr-22	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	21:21	21:34	0:13	LOAD CHANGE OVER
715	28-Apr-22	BAGALKOT	110	SOUDATTI220-MMCL	STATION NOT AFFECTED SOUDATTI_220	19:29	19:34	0:05	LINE FAULT
716	28-Apr-22	BAGALKOT	110	SOUDATTI220-MUNAVALLI	STATION NOT AFFECTED SOUDATTI_220	15:46	16:11	0:25	LINE FAULT
717	28-Apr-22	BAGALKOT	110	SOUDATTI220-MUNAVALLI	STATION NOT AFFECTED SOUDATTI_220	19:11	19:39	0:28	LINE FAULT
718	28-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)	13:37 (28.04.2022)	435:27 hrs	LINE CHARGED
719	28-Apr-22	BAGALKOT	110	UMACHAGI-KIRUVATTI	KIRUVATTI_110	19:39	20:29	0:50	LINE FAULT
720	28-Apr-22	BAGALKOT	110	YELLAMMANAWADI-SAVALAGI	STATION NOT AFFECTED YELLAMMANAWADI_110	9:08	18:42	9:34	LINE FAULT
721	28-Apr-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
722	28-Apr-22	BAGALKOT	220	BAGALKOT- ALAMATTI2 (ALAMATTI1)	STATION NOT AFFECTED BAGALKOT_220	17:32 (28.04.2022)		6:28	LINE FAULT
723	28-Apr-22	BAGALKOT	220	BAGALKOT- ALAMATTI2 (ALAMATTI1)	STATION NOT AFFECTED BAGALKOT_220	16:02	16:22	0:20	LINE FAULT
724	28-Apr-22	BAGALKOT	220	BAGEWADI-ADPH1	STATION NOT AFFECTED BAGEWADI_220	16:37	17:19	0:42	LINE FAULT
725	28-Apr-22	BAGALKOT	220	BAGEWADI-LINGASUR2	STATION NOT AFFECTED BAGEWADI_220	15:40	16:51	1:11	LINE FAULT
726	28-Apr-22	BAGALKOT	220	BAGEWADI-RBRK	STATION NOT AFFECTED BAGEWADI_220	15:31	16:06	0:35	LINE FAULT
727	28-Apr-22	BAGALKOT	220	BELGAUM- KANABARGI1 (NARENDRA1)	STATION NOT AFFECTED BELGAUM_220	19:18	20:03	0:45	LINE FAULT
728	28-Apr-22	BAGALKOT	220	BELGAUM- KANABARGI2 (NARENDRA2)	STATION NOT AFFECTED BELGAUM_220	19:17	20:02	0:45	LINE FAULT
729	28-Apr-22	BAGALKOT	220	BIDNAL- HARTI1	BIDNAL_220	17:38	18:49	1:11	HAND TRIPPED
730	28-Apr-22	BAGALKOT	220	BIDNAL- HARTI2	BIDNAL_220	17:38	18:50	1:12	HAND TRIPPED
731	28-Apr-22	BAGALKOT	220	BIDNAL- HAVERI	BIDNAL_220	17:38	23:24	5:46	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
732	28-Apr-22	BAGALKOT	220	BIDNAL- HUBLI1	BIDNAL_220	14:13	17:26	3:13	LINE CLEAR AVAILED
733	28-Apr-22	BAGALKOT	220	BIDNAL- HUBLI1	BIDNAL_220	17:38	19:04	1:26	HAND TRIPPED
734	28-Apr-22	BAGALKOT	220	BIDNAL- HUBLI3	BIDNAL_220	17:59	23:21	5:22	HAND TRIPPED
735	28-Apr-22	BAGALKOT	220	BIDNAL- NARENDRA	BIDNAL_220	17:44	17:46	0:02	HAND TRIPPED
736	28-Apr-22	BAGALKOT	220	BIDNAL- SOUDATTI	BIDNAL_220	17:16	23:20	6:04	LINE FAULT
737	28-Apr-22	BAGALKOT	220	BIDNAL- TADAS1 (HIREBENDIGERI1)	BIDNAL_220	17:39 (28.04.2022)			LINE OPEN:LINE FAULT
738	28-Apr-22	BAGALKOT	220	BIDNAL- TADAS2 (HIREBENDIGERI2)	BIDNAL_220	17:38	19:22	1:44	LINE FAULT
739	28-Apr-22	BAGALKOT	220	CHIKKODI-AEQUS	AEQUS_220	12:53	18:17	5:24	HAND TRIPPED
740	28-Apr-22	BAGALKOT	220	DHONI- GADAG1	STATION NOT AFFECTED DHONI_400	20:10 (28.04.2022)			LINE OPEN:LINE FAULT
741	28-Apr-22	BAGALKOT	220	DHONI- GADAG2	STATION NOT AFFECTED DHONI_400	20:10 (28.04.2022)			LINE OPEN:LINE FAULT
742	28-Apr-22	BAGALKOT	220	GADAG- LINGAPUR1(DHONI1)	STATION NOT AFFECTED GADAG_220	20:10 (28.04.2022)			LINE OPEN:LINE FAULT
743	28-Apr-22	BAGALKOT	220	GADAG- LINGAPUR2(DHONI2)	STATION NOT AFFECTED GADAG_220	20:10	21:31	1:21	LINE FAULT
744	28-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
745	28-Apr-22	BAGALKOT	220	HUBLI- BIDNAL1	STATION NOT AFFECTED HUBLI_220	14:12	17:26	3:14	LINE CLEAR AVAILED
746	28-Apr-22	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	19:04 (28.04.2022)			LINE OPEN:LINE FAULT
747	28-Apr-22	BAGALKOT	220	NAGJHARI2-BIDNAL	STATION NOT AFFECTED BIDNAL_220	18:28 (27.04.2022)			LINE OPEN:LINE FAULT
748	28-Apr-22	BAGALKOT	220	RANEBENNUR-BALLIGAVI	STATION NOT AFFECTED RANEBENNUR_220	14:45 (27.04.2022)	6:50 (28.04.2022)	16:05 hrs	MAIN SUPPLY FAILURE
749	28-Apr-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	15:33 (22.04.2022)	20:25 (28.04.2022)	148:52 hrs	LINE CHARGED
750	28-Apr-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:33 (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
751	28-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	20:03 (28.04.2022)			LINE OPEN:LINE FAULT
752	28-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	19:43 (28.04.2022)			LINE OPEN:LINE FAULT
753	28-Apr-22	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	17:13	23:17	6:04	LINE FAULT
754	28-Apr-22	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	20:22	20:37	0:15	LINE FAULT
755	28-Apr-22	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	20:15(18-4-2022)			LINE OPEN:LINE FAULT
756	28-Apr-22	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR	17:26	17:54	0:28	LINE FAULT
757	28-Apr-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI	0:19	0:42	0:23	LOAD CURTAILMENT
758	28-Apr-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI	17:36	17:57	0:20	LINE CLEAR AVAILED
759	28-Apr-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	NO STATION AFFECTED	15:09	16:45	1:36	LINE CLEAR AVAILED
760	28-Apr-22	BENGALURU	66	DODALHALLI - GRT SOLAR (IPP)	GRT SOLAR (IPP)	18:07	19:41	1:33	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
761	28-Apr-22	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, KONDASPURA, ARMY WELAFARE ORGANISATION	13:51	17:16	3:25	LINE FAULT
762	28-Apr-22	BENGALURU	66	EXORA - HAL 220	EXORA	13:32	13:36	0:04	LOAD CHANGE OVER
763	28-Apr-22	BENGALURU	66	EXORA - VIKAS TECH PARK 220	EXORA	12:45	13:00	0:15	MAIN SUPPLY FAILURE
764	28-Apr-22	BENGALURU	66	HENNUR CROSS - HBR LAYOUT 220	HENNUR CROSS	14:20	14:23	0:03	LOAD CHANGE OVER
765	28-Apr-22	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	17:08	17:11	0:03	LOAD CHANGE OVER
766	28-Apr-22	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SIRIGIRIPURA	18:08	18:40	0:32	MAIN SUPPLY FAILURE
767	28-Apr-22	BENGALURU	66	HV1	CB PURA I/A	14:55	15:00	0:05	LINE CLEAR AVAILED
768	28-Apr-22	BENGALURU	66	HV1	CHINTAMANI 66	12:19	12:24	0:05	TRANSFORMER FAULT
769	28-Apr-22	BENGALURU	66	HV1	DOMMASANDRA	21:28(27-4-2022)	11:40(28-4-2022)	14:11 hrs	TRANSFORMER CHARGED
770	28-Apr-22	BENGALURU	66	HV1	GUDEMARANAHALLI	9:50	10:59	1:08	LINE CLEAR AVAILED
771	28-Apr-22	BENGALURU	66	HV1	HULLENAHALLI	18:08	18:40	0:32	TRANSFORMER FAULT
772	28-Apr-22	BENGALURU	66	HV1	K&C VALLEY	2:40	2:45	0:05	TRANSFORMER FAULT
773	28-Apr-22	BENGALURU	66	HV1	PALLICHERLU	23:08(24-4-2022)	3:21(28-4-2022)	4:12 hrs	TRANSFORMER CHARGED
774	28-Apr-22	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	22:00	22:30	0:30	TRANSFORMER FAULT
775	28-Apr-22	BENGALURU	66	HV1	SRIGANDA KAVALU	15:12	15:15	0:03	LINE CLEAR AVAILED
776	28-Apr-22	BENGALURU	66	HV2	BANASHANKARI	20:22	20:51	0:29	TRANSFORMER FAULT
777	28-Apr-22	BENGALURU	66	HV2	KEMBODI	12:29	14:16	1:46	LINE CLEAR AVAILED
778	28-Apr-22	BENGALURU	66	HV2	KEMBODI	15:20	15:47	0:27	LINE CLEAR AVAILED
779	28-Apr-22	BENGALURU	66	HV2	KONDASPURA	12:50	12:56	0:06	TRANSFORMER FAULT
780	28-Apr-22	BENGALURU	66	HV2	MAASTI	11:05	11:12	0:07	TRANSFORMER FAULT
781	28-Apr-22	BENGALURU	66	HV2	VIDYANAGAR	17:20	19:00	1:40	TRANSFORMER FAULT
782	28-Apr-22	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	7:35	7:39	0:04	LOAD CHANGE OVER
783	28-Apr-22	BENGALURU	66	JIGANI LINK ROAD - JIGANI 220	JIGANI LINK ROAD	15:25	15:37	0:12	LOAD CHANGE OVER
784	28-Apr-22	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI	13:51	17:20	3:29	LINE FAULT
785	28-Apr-22	BENGALURU	66	KOLAR 220 - MULBAGLU	NO STATION AFFECTED	19:20(14-04-2022)			LINE OPEN:LINE FAULT
786	28-Apr-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	9:19	9:25	0:05	LINE FAULT
787	28-Apr-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	12:00	12:06	0:05	LINE FAULT
788	28-Apr-22	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA, ARMY WELAFARE ORGANISATION, BELL CERAMIC(EHT)	18:00	18:25	0:25	LOAD CHANGE OVER
789	28-Apr-22	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	14:31	14:34	0:03	LINE FAULT
790	28-Apr-22	BENGALURU	66	MALUR 220 - HOODY 220	SARJAPURA 220, VIKAS TECH PARK 220	12:45	13:25	0:40	LINE FAULT
791	28-Apr-22	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	15:09	15:14	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
792	28-Apr-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:46	13:25	0:39	MAIN SUPPLY FAILURE
793	28-Apr-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:46	13:25	0:39	MAIN SUPPLY FAILURE
794	28-Apr-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:46	13:25	0:39	MAIN SUPPLY FAILURE
795	28-Apr-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	15:48	15:59	0:11	LINE FAULT
796	28-Apr-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	15:48	15:59	0:11	LINE FAULT
797	28-Apr-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	18:52	19:11	0:19	LINE FAULT
798	28-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	12:45	13:35	0:50	LINE CLEAR AVAILED
799	28-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	12:45	13:35	0:50	LINE CLEAR AVAILED
800	28-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	12:45	13:35	0:50	LINE CLEAR AVAILED
801	28-Apr-22	BENGALURU	220	HOODY 220 - MALUR 220	VIKAS TECH PARK 220, SARJAPURA 220	12:45	13:25	0:40	LINE FAULT
802	28-Apr-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	12:45	13:32	0:47	MAIN SUPPLY FAILURE
803	28-Apr-22	GULBARGA	66	HV2	HALAVAGALU_66	7:25	7:30	0:05	TRANSFORMER FAULT
804	28-Apr-22	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	17:13	18:20	1:07	LINE FAULT
805	28-Apr-22	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	19:05	19:12	0:07	LINE FAULT
806	28-Apr-22	GULBARGA	66	MUNIRABAD-MHD	VENKATAPUR_66,UPANAYAKANA HALLI_66,HAGARIBOMMANAHALLI_66,RR STEELS_IPP	16:10	16:38	0:28	LINE FAULT
807	28-Apr-22	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	19:20	21:39	2:19	LINE FAULT
808	28-Apr-22	GULBARGA	66	NEELGUNDA-TELIGI	TELIGI_66,KURBHAHALLI_66,YEREGUNTA_66	20:49	21:41	0:52	LINE FAULT
809	28-Apr-22	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	12:10	13:00	0:50	MAIN SUPPLY FAILURE
810	28-Apr-22	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	13:00	14:40	1:40	MAIN SUPPLY FAILURE
811	28-Apr-22	GULBARGA	110	DEODURGA-SHAHPUR	DEODURGA_110	18:20	19:20	1:00	MAIN SUPPLY FAILURE
812	28-Apr-22	GULBARGA	110	GHATTARGA-AFZALPUR	GHATTARGA_110	21:15	21:28	0:13	LINE FAULT
813	28-Apr-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	5:36	5:46	0:10	LINE FAULT
814	28-Apr-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
815	28-Apr-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	18:25	18:35	0:10	MAIN SUPPLY FAILURE
816	28-Apr-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	19:00	19:20	0:20	MAIN SUPPLY FAILURE
817	28-Apr-22	GULBARGA	110	HV1	KEREHALLI_110	21:05	21:20	0:15	LINE CLEAR AVAILED
818	28-Apr-22	GULBARGA	110	HV1	MYLAR_110	0:55	0:59	0:04	TRANSFORMER FAULT
819	28-Apr-22	GULBARGA	110	HV1	MYLAR_110	23:01	23:06	0:05	TRANSFORMER FAULT
820	28-Apr-22	GULBARGA	110	HV2	DEODURGA_110	19:30	20:45	1:15	TRANSFORMER FAULT
821	28-Apr-22	GULBARGA	110	HV2	NIRNA_110	15:35	15:40	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
822	28-Apr-22	GULBARGA	110	HV2	YELBURGA_110	18:10	18:34	0:24	LINE CLEAR AVAILED
823	28-Apr-22	GULBARGA	110	HV2	YELBURGA_110	18:54	19:24	0:30	LINE CLEAR AVAILED
824	28-Apr-22	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	JAWALGERA_110	17:05	17:10	0:05	MAIN SUPPLY FAILURE
825	28-Apr-22	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	12:45	18:30	5:45	NFBC ISSUED
826	28-Apr-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS	12:26	14:34	2:08	LINE CLEAR AVAILED
827	28-Apr-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS	21:19	21:32	0:13	LINE FAULT
828	28-Apr-22	GULBARGA	110	KUKUNOOR-YELBURGA	KUKUNOOR_110	17:04	18:04	1:00	MAIN SUPPLY FAILURE
829	28-Apr-22	GULBARGA	110	KUSTAGI-ILKAL2	ILKAL_110	16:54	22:12	5:18	LINE FAULT
830	28-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	2:30	2:35	0:05	LINE FAULT
831	28-Apr-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	18:55	19:15	0:20	LINE FAULT
832	28-Apr-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAON_110,RENUKA_IPP,A FZALPUR_110,KARAJAGI_110	20:50	21:52	1:02	LINE CLEAR AVAILED
833	28-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
834	28-Apr-22	GULBARGA	110	SHAHABAD-FAHARTABAD	FAHARTABAD_110	19:20	21:53	2:33	LINE CLEAR AVAILED
835	28-Apr-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	19:13	19:20	0:07	LINE FAULT
836	28-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
837	28-Apr-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	18:10	19:10	1:00	LINE FAULT
838	28-Apr-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	18:10 (28.04.2022)			LINE OPEN:LINE FAULT
839	28-Apr-22	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:13	19:20	0:07	LINE FAULT
840	28-Apr-22	GULBARGA	110	SINDHANOOR-ADAVI AMARESHWAR	MANVI_110,MADLAPUR_110,KU RDICROSS_110,ADAVI AMARESHWAR_110	12:40	18:20	5:40	LINE CLEAR AVAILED
841	28-Apr-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	1:11	1:20	0:09	LINE FAULT
842	28-Apr-22	GULBARGA	220	HV1	ITTAGI_220	17:13	17:33	0:20	TRANSFORMER FAULT
843	28-Apr-22	GULBARGA	220	HV1,HV2,LV1,LV2	SHAHAPUR_220	18:10	18:25	0:15	TRANSFORMER FAULT
844	28-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
845	28-Apr-22	GULBARGA	220	HV2	RAICHUR_220	16:40	18:55	2:15	LINE CLEAR AVAILED
846	28-Apr-22	GULBARGA	220	KUSATGI-SULEKAL	KUSTAGI_220	17:01	17:51	0:50	LINE FAULT
847	28-Apr-22	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	17:01	17:47	0:46	LINE FAULT
848	28-Apr-22	GULBARGA	220	KUSTAGI-SUZLON_1_IPP	KUSTAGI_220	16:51	19:43	2:52	LINE FAULT
849	28-Apr-22	GULBARGA	220	KUSTAGI-SUZLON_2_IPP	KUSTAGI_220	16:51	19:43	2:52	LINE FAULT
850	28-Apr-22	GULBARGA	220	LINGAPUR-BMMIS	LINGAPUR_220	8:39	14:03	5:24	LINE CLEAR AVAILED
851	28-Apr-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	18:53	19:05	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
852	28-Apr-22	HASSAN	66	BD-1	MRSMG_220	17:16	19:35	2:19	LINE FAULT
853	28-Apr-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_220	15:50	16:05	0:15	MAIN SUPPLY FAILURE
854	28-Apr-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_220	15:50	16:05	0:15	MAIN SUPPLY FAILURE
855	28-Apr-22	HASSAN	66	CRPATNA-CRPTNA1	CHANNARAYAPATNA_220	15:49	16:04	0:15	LINE FAULT
856	28-Apr-22	HASSAN	66	CRPATNA-CRPTNA2	CHANNARAYAPATNA_220	15:49	16:04	0:15	LINE FAULT
857	28-Apr-22	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_220	15:49	16:04	0:15	LINE FAULT
858	28-Apr-22	HASSAN	66	CRPATNA-SBELAGOLA	CHANNARAYAPATNA_220	15:49	15:54	0:05	LINE FAULT
859	28-Apr-22	HASSAN	66	GENDEH-MUDIGERE	GENDEHALLY_66	10:59	13:39	2:40	LINE CLEAR AVAILED
860	28-Apr-22	HASSAN	66	HV1	HOLEHONNUR_66	10:55 (26.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
861	28-Apr-22	HASSAN	66	HV1	SAKALESH PURA_66	10:59(28.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
862	28-Apr-22	HASSAN	66	HV2	BELUR_66	8:11	8:22	0:11	TRANSFORMER FAULT
863	28-Apr-22	HASSAN	66	HV2	HOLEHONNUR_66	18:30	19:15	0:45	NFBC ISSUED
864	28-Apr-22	HASSAN	66	HV2	SAKALESH PURA_66	23:54 (28.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
865	28-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATH PURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
866	28-Apr-22	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	10:03	15:12	5:09	LINE CLEAR AVAILED
867	28-Apr-22	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	10:03	15:12	5:09	LINE CLEAR AVAILED
868	28-Apr-22	HASSAN	66	SHMGA 1	gen_bhadr	17:20	19:35	2:15	LINE FAULT
869	28-Apr-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGi_66	23:40(28.04.2022)			LINE OPEN:LINE CLEAR AVAILED
870	28-Apr-22	HASSAN	66	TAVAREC-HONNALLI	TAVARECHETTANAHALLY_66	16:55	22:07	5:12	MAIN SUPPLY FAILURE
871	28-Apr-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	16:05	16:10	0:05	MAIN SUPPLY FAILURE
872	28-Apr-22	HASSAN	110	BADRAVATY1	MRSMG_220	17:11	20:04	2:53	LINE FAULT
873	28-Apr-22	HASSAN	110	BADRAVATY2	MRSMG_220	17:11	20:04	2:53	LINE FAULT
874	28-Apr-22	HASSAN	110	Guruvykere1	KEMAR_220	16:36	17:03	0:27	LINE CLEAR AVAILED
875	28-Apr-22	HASSAN	110	Guruvykere1	KEMAR_220	15:39	16:34	0:55	LINE FAULT
876	28-Apr-22	HASSAN	110	Guruvykere2	KEMAR_220	15:49	17:05	1:16	LINE FAULT
877	28-Apr-22	HASSAN	110	HIRENAL-AMR	KAVOOR_220	10:33	13:01	2:28	LINE CLEAR AVAILED
878	28-Apr-22	HASSAN	110	HIRENAL-GURUPURA	KAVOOR_220	10:21	13:28	3:07	LINE CLEAR AVAILED
879	28-Apr-22	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	12:05	12:20	0:15	LINE CLEAR AVAILED
880	28-Apr-22	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	14:55	15:05	0:10	HAND TRIPPED
881	28-Apr-22	HASSAN	110	HV1	BHADRAVATY_110	17:10	18:30	1:20	TRANSFORMER FAULT
882	28-Apr-22	HASSAN	110	HV2	BHADRAVATY_110	18:16	18:26	0:10	HAND TRIPPED
883	28-Apr-22	HASSAN	110	HV3	BHADRAVATY_110	18:16	21:12	2:56	HAND TRIPPED
884	28-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
885	28-Apr-22	HASSAN	110	HV4	MANIPAL_110	7:55	12:25	4:30	LINE CLEAR AVAILED
886	28-Apr-22	HASSAN	110	HV5	KAVOOR_220	8:45 (26.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
887	28-Apr-22	HASSAN	110	IPP IC LINE	GAJNUR_110	17:45	18:15	0:30	LINE FAULT
888	28-Apr-22	HASSAN	110	JOG-JLT4	gen_mghe	21:28(28.04.2022)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
889	28-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
890	28-Apr-22	HASSAN	110	KEMAR1	GURUVYANKERE_110	15:49	17:14	1:25	MAIN SUPPLY FAILURE
891	28-Apr-22	HASSAN	110	KEMAR2	GURUVYANKERE_110	15:45	17:05	1:20	MAIN SUPPLY FAILURE
892	28-Apr-22	HASSAN	110	LPH-MGHE 2	gen_lph	21:28(28.04.2022)			LINE OPEN:LINE FAULT
893	28-Apr-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	19:10	19:33	0:23	LINE FAULT
894	28-Apr-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	19:10	19:34	0:24	LINE FAULT
895	28-Apr-22	HASSAN	110	SLVPWR	GURUVYANKERE_110	15:45	17:05	1:20	MAIN SUPPLY FAILURE
896	28-Apr-22	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	17:11 (28.04.2022)			LINE OPEN:LINE FAULT
897	28-Apr-22	HASSAN	220	HV2	PUTTUR_220	10:01	12:21	2:20	LINE CLEAR AVAILED
898	28-Apr-22	HASSAN	220	KEMAR	PUTTUR_220	10:33	16:33	6:00	NFBC ISSUED
899	28-Apr-22	HASSAN	220	MRSSHM--ANTRSNH	MRSMSG_220	17:45(28.04.2022)			LINE OPEN:LINE FAULT
900	28-Apr-22	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	17:11(28.04.2022)			LINE OPEN:LINE FAULT
901	28-Apr-22	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	16:52(28.04.2022)			LINE OPEN:LINE FAULT
902	28-Apr-22	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	18:20 (28.04.2022)			LINE OPEN:LINE CLEAR AVAILED
903	28-Apr-22	HASSAN	220	PUTUR1	KEMAR_220	10:33	16:35	6:02	LINE CLEAR AVAILED
904	28-Apr-22	HASSAN	220	SHARAVATHY3	MRSMSG_220	12:48	13:31	0:43	HAND TRIPPED
905	28-Apr-22	HASSAN	220	SHIMOGA	KADUR_220	18:30 (28.04.2022)			LINE OPEN:LINE CLEAR AVAILED
906	28-Apr-22	HASSAN	220	SHIMOGA2	gen_varahi	9:20	15:07	5:47	NFBC ISSUED
907	28-Apr-22	HASSAN	220	SHIMOGA3	gen_sharavaty	12:48	13:33	0:45	HAND TRIPPED
908	28-Apr-22	HASSAN	220	SHRAVITY-SIRISI 1	gen_sharavaty	20:03(28.04.2022)			LINE OPEN:LINE CLEAR AVAILED
909	28-Apr-22	HASSAN	220	SHRAVITY-SIRISI 2	gen_sharavaty	19:42 (28.02.2022)			LINE OPEN:LINE CLEAR AVAILED
910	28-Apr-22	HASSAN	220	VARAH12	MRSMSG_220	15:07	19:23	4:16	NFBC ISSUED
911	28-Apr-22	HASSAN	220	VARAH1-SHMG3	gen_varahi	17:44(28.04.2022)			LINE OPEN:LINE FAULT
912	28-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
913	28-Apr-22	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	12:15	12:38	0:23	LINE FAULT
914	28-Apr-22	MYSURU	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	7:19	7:23	0:04	LINE FAULT
915	28-Apr-22	MYSURU	66	HANAGODU-HUNSURU	NO STATIONS EFFECTED	16:59	17:06	0:06	HAND TRIPPED
916	28-Apr-22	MYSURU	66	HEBBANI-MADHUVANALLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
917	28-Apr-22	MYSURU	66	HEBBANI-MEGALAPURA	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	0:09	0:15	0:06	LINE FAULT
918	28-Apr-22	MYSURU	66	HEBBANI-SHIMSHA	HADLI_66 MALAVALLI_66	18:52	19:10	0:18	LINE FAULT
919	28-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
920	28-Apr-22	MYSURU	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	8:54	11:19	2:25	LINE CLEAR AVAILED
921	28-Apr-22	MYSURU	66	HOOTAGALLI-FTS-1	NO STATIONS EFFECTED	9:55	11:58	2:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
922	28-Apr-22	MYSURU	66	HOOTAGALLI-FTS-1	NO STATIONS EFFECTED	18:35	18:55	0:20	LINE FAULT
923	28-Apr-22	MYSURU	66	HV1	HOOTAGALLY_220	13:04	13:27	0:23	TRANSFORMER FAULT
924	28-Apr-22	MYSURU	66	HV2	GUNDULPET_66	6:35	8:15	1:40	HAND TRIPPED
925	28-Apr-22	MYSURU	66	HV2	SANTHESARAGUR_66	10:37	10:44	0:06	TRANSFORMER FAULT
926	28-Apr-22	MYSURU	66	HV2	TUBINAKERE_220	17:45	17:55	0:10	HAND TRIPPED
927	28-Apr-22	MYSURU	66	KR PETE 220KV- MAHADESHWARAPURA	G MALLIGERE_66 JAKKANAHALLY_66 MADESWARAPURA_66	17:38	17:51	0:13	LINE FAULT
928	28-Apr-22	MYSURU	66	KUNTHUR-D R PETE	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66	5:58	6:07	0:09	LINE FAULT
929	28-Apr-22	MYSURU	66	KUSHALNAGARA- MERCERA-1	MADIKERI_66	16:32	16:42	0:10	LINE FAULT
930	28-Apr-22	MYSURU	66	MADHUVANAHALLI- MAMBALLI	NO STATIONS EFFECTED	18:52	18:57	0:05	LINE FAULT
931	28-Apr-22	MYSURU	66	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	16:29	16:41	0:11	LINE FAULT
932	28-Apr-22	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	18:54	18:58	0:04	LINE FAULT
933	28-Apr-22	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	10:38	10:40	0:02	HAND TRIPPED
934	28-Apr-22	MYSURU	66	TUBINAKERE- PANDAVAPURA	BELAGOLA_66 BANANGADI_66 DODDABYADARAHALLI_66 PANDAVAPURA_66	14:30	14:35	0:05	LINE FAULT
935	28-Apr-22	MYSURU	66	TUBINAKERE-S R PATNA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	15:50	16:00	0:10	LINE FAULT
936	28-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
937	28-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
938	28-Apr-22	MYSURU	220	HV1	KADAKOLA_220	9:25:00 PM (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
939	28-Apr-22	MYSURU	220	HV2	KADAKOLA_220	21:25	22:10	0:45	TRANSFORMER FAULT
940	28-Apr-22	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2(KUDUR)	KUDUR_66, HULLENAHALLI_66	18:07	18:36	0:29	LINE FAULT
941	28-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- BELLAVI	BELLAVI_66	1:01	1:15	0:13	LOAD CURTAILMENT
942	28-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	1:28	1:37	0:08	LOAD CURTAILMENT
943	28-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220kv KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	15:48	16:05	0:16	LINE FAULT
944	28-Apr-22	TUMKUR	66	BADAVANAHALLI- MADHUGIRI	BADAVANAHALLI_66	11:47	14:30	2:43	LINE CLEAR AVAILED
945	28-Apr-22	TUMKUR	66	BADAVANAHALLI- MADHUGIRI	BADAVANAHALLI_66	15:20	18:33	3:12	LINE CLEAR AVAILED
946	28-Apr-22	TUMKUR	66	BADAVANAHALLI- MADHUGIRI	BADAVANAHALLI_66	20:31	20:34	0:02	HAND TRIPPED
947	28-Apr-22	TUMKUR	66	BENKIKERE 220kv- GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	16:01	17:14	1:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
948	28-Apr-22	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	19:07	19:14	0:07	HAND TRIPPED
949	28-Apr-22	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	6:00	9:14	3:14	LINE FAULT
950	28-Apr-22	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	19:36	19:48	0:11	HAND TRIPPED
951	28-Apr-22	TUMKUR	66	CHITRADURGA 220kv- CHITRADURGA 4	CHITRADURGA_220	6:00	6:36	0:36	LINE CLEAR AVAILED
952	28-Apr-22	TUMKUR	66	CHITRADURGA 220kv- CHITRADURGA2	CHITRADURGA_220	6:00	6:33	0:32	LINE FAULT
953	28-Apr-22	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	PANDARAHALLI_66	6:00	6:47	0:46	LINE FAULT
954	28-Apr-22	TUMKUR	66	MADANAYAKANAHALLI- TURUVANUR	MADANAYAKANAHALLI_66,	19:34	19:53	0:19	LOAD CURTAILMENT
955	28-Apr-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66, HDPURA_66,	6:00	19:07	13:06	LINE CLEAR AVAILED
956	28-Apr-22	TUMKUR	66	PAVAGADA 220kv- SHYLAPURA	SHYLAPURA_66	21:57	22:05	0:08	LINE FAULT
957	28-Apr-22	TUMKUR	66	PAVAGADA 220kv- SHYLAPURA	SHYLAPURA_66	22:05	22:10	0:05	LINE FAULT
958	28-Apr-22	TUMKUR	66	PAVAGADA 220kv- SHYLAPURA	SHYLAPURA_66	22:30	22:40	0:10	LINE FAULT
959	28-Apr-22	TUMKUR	66	SHYLAPURA-PR PURA	P R PURA_66	22:52	22:57	0:05	MAIN SUPPLY FAILURE
960	28-Apr-22	TUMKUR	66	SIRA- MADHUGIRI 1	BUKKAPATNA_66, KALLAMBELLA_66	10:28	10:44	0:15	HAND TRIPPED
961	28-Apr-22	TUMKUR	66	SIRA220-SIRA 3(KALAMBELLA)	SIRA_66	13:33	13:49	0:15	LINE FAULT
962	28-Apr-22	TUMKUR	66	TR-1	BADAVANAHALLI_66	18:46	20:38	1:51	LINE CLEAR AVAILED
963	28-Apr-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	22:36	22:38	0:02	TRANSFORMER FAULT
964	28-Apr-22	TUMKUR	66	TR-1	CHITRADURGA_66	15:18	16:36	1:17	LOAD CHANGE OVER
965	28-Apr-22	TUMKUR	66	TR-1	MADHUGIRI_220	22:03	22:16	0:13	TRANSFORMER FAULT
966	28-Apr-22	TUMKUR	66	TR-1	PAVAGADA_66	11:20	11:25	0:04	TRANSFORMER FAULT
967	28-Apr-22	TUMKUR	66	TR-1(LV-1)	CHITRADURGA_220	18:39	19:14	0:34	TRANSFORMER FAULT
968	28-Apr-22	TUMKUR	66	TR-2	BADAVANAHALLI_66	11:47	14:30	2:43	LINE CLEAR AVAILED
969	28-Apr-22	TUMKUR	66	TR-2	BADAVANAHALLI_66	15:20	18:33	3:12	LINE CLEAR AVAILED
970	28-Apr-22	TUMKUR	66	TR-2	GUTTUR_66	12:38	15:34	2:56	LINE CLEAR AVAILED
971	28-Apr-22	TUMKUR	66	TR-2	PAVAGADA_66	21:55	21:57	0:01	TRANSFORMER FAULT
972	28-Apr-22	TUMKUR	66	TURUVANUR66- CHITRADURGA	TURUVANUR_66	19:36	19:56	0:19	HAND TRIPPED
973	28-Apr-22	TUMKUR	110	KATRIKEHAL- THIMMANAHALLI	KATRIKEHAL_110	13:00	13:38	0:37	HAND TRIPPED
974	28-Apr-22	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, KADEHALLI_1 10	15:48	15:54	0:05	LINE FAULT
975	28-Apr-22	TUMKUR	110	NITTUR 220kv- SOMALAPURA	SOMALAPURA_66	15:48	16:05	0:17	LINE FAULT
976	28-Apr-22	TUMKUR	110	TR-1	KATRIKIHALL_110	13:37	13:40	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
977	28-Apr-22	TUMKUR	110	TR-2	NITTUR_110	15:48	16:03	0:14	TRANSFORMER FAULT
978	28-Apr-22	TUMKUR	110	TR-3(HV-3)	AMMASANDRA_110	3:42	3:57	0:14	TRANSFORMER FAULT
979	28-Apr-22	TUMKUR	220	ANTHRASANAHALLI 220kv SHIMOGA	ANTHRASANAHALLI_220	17:45	21:36	3:51	LINE FAULT
980	28-Apr-22	TUMKUR	220	DAVANGERE SRS-GUTTUR-3	DAVANGERE_SRS_220	11:07	11:26	0:18	HAND TRIPPED
981	28-Apr-22	TUMKUR	220	ICT-1	JAGALURU_400	11:17	14:46	3:28	LINE CLEAR AVAIED
982	28-Apr-22	TUMKUR	220	TR-1	DAVANGERE_SRS_220	11:33	12:15	0:42	TRANSFORMER FAULT
983	28-Apr-22	TUMKUR	220	TR-2	DAVANGERE_SRS_220	11:33	11:45	0:12	TRANSFORMER FAULT
984	28-Apr-22	TUMKUR	400	ICT-1	JAGALURU_400	11:18	14:45	3:27	LINE CLEAR AVAIED
985	29-Apr-22	BAGALKOT	110	110/11,HV1	STATION NOT AFFECTED TODALABAGI_110	6:05	7:07	1:02	TRANSFORMER FAULT
986	29-Apr-22	BAGALKOT	110	110/11KV, HV1	HIREMASALI_110	9:11	9:14	0:03	TRANSFORMER FAULT
987	29-Apr-22	BAGALKOT	110	110/11KV, HV1	RANEENNUR_220	16:25	17:50	1:25	LINE CLEAR AVAIED
988	29-Apr-22	BAGALKOT	110	110/11KV, HV1	RANEENNUR_220	19:02	19:07	0:05	TRANSFORMER FAULT
989	29-Apr-22	BAGALKOT	110	110/11KV, HV2	KANABARGI LAYOUT_110	11:04	11:35	0:31	HAND TRIPPED
990	29-Apr-22	BAGALKOT	110	110/11KV, HV2	RANEENNUR_220	0:45	0:56	0:11	TRANSFORMER FAULT
991	29-Apr-22	BAGALKOT	110	110/11KV, HV2	RANEENNUR_220	15:50	16:00	0:10	TRANSFORMER FAULT
992	29-Apr-22	BAGALKOT	110	110/11KV, HV2	SHIROL_110	7:00	9:05	2:05	LINE CLEAR AVAIED
993	29-Apr-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NAVALAGUND_110	11:14	13:24	2:10	LINE CLEAR AVAIED
994	29-Apr-22	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	13:14	13:55	0:41	LINE CLEAR AVAIED
995	29-Apr-22	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	17:54	18:56	1:02	LINE CLEAR AVAIED
996	29-Apr-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BABALESHWAR_110	18:04 (16.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
997	29-Apr-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED JAMAKHANDI_110	23:43 (28.04.2022)	00:09 (29.04.2022)	0:26	TRANSFORMER CHARGED
998	29-Apr-22	BAGALKOT	110	110/11KV,HV1 (HV2)	STATION NOT AFFECTED UGARKHUD_110	14:45	15:33	0:48	TRANSFORMER FAULT
999	29-Apr-22	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	12:15	12:27	0:12	TRANSFORMER FAULT
1000	29-Apr-22	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	15:33	15:54	0:21	TRANSFORMER FAULT
1001	29-Apr-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1002	29-Apr-22	BAGALKOT	110	220/110KV, LV1	KARWAR_220	12:31	12:42	0:11	HAND TRIPPED
1003	29-Apr-22	BAGALKOT	110	ANKOLA-KUMATA(L2)	STATION NOT AFFECTED KUMATA_110	20:42 (28.04.2022)	9:24 (29.04.2022)	12:42	LINE CHARGED
1004	29-Apr-22	BAGALKOT	110	ATHANI220-SATTI	ATHANI_220	16:52	16:59	0:07	HAND TRIPPED
1005	29-Apr-22	BAGALKOT	110	BAGEWADI-MAMADAPUR 1	MAMADAPUR_110	17:38	17:58	0:20	HAND TRIPPED
1006	29-Apr-22	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND_110	18:44 (28.04.2022)	16:33 (29.04.2022)	21:49	LINE CHARGED
1007	29-Apr-22	BAGALKOT	110	BYADAGI-SUZLON	BYADAGI_110	17:05	18:02	0:57	HAND TRIPPED
1008	29-Apr-22	BAGALKOT	110	GADAG220- SHIRAHATTI	STATION NOT AFFECTED GADAG_220	20:06 (28.04.2022)	10:59 (29.04.2022)	14:53	LINE CHARGED
1009	29-Apr-22	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA1	GHATAPRABHA_220	10:05	11:09	1:04	LINE FAULT
1010	29-Apr-22	BAGALKOT	110	HAVERI- BYADAGI	STATION NOT AFFECTED HAVERI_220	16:41 (29.04.2022)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1011	29-Apr-22	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	16:41	17:05	0:24	LOAD CHANGE OVER
1012	29-Apr-22	BAGALKOT	110	HUNGUND-JINDAL	STATION NOT AFFECTED HUNGUND_110	16:35 (28.04.2022)	14:55 (29.04.2022)	22:20	LINE CHARGED
1013	29-Apr-22	BAGALKOT	110	KAMBAGI-F2(TODALBAGI)	KAMBAGI_110	13:28	13:55	0:27	HAND TRIPPED
1014	29-Apr-22	BAGALKOT	110	KARWAR220-ARGA(KUMATA)	KARWAR_220	12:28	12:43	0:15	LINE FAULT
1015	29-Apr-22	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	6:15	13:16	7:01	LINE CLEAR AVAILED
1016	29-Apr-22	BAGALKOT	110	MAHALINGAPUR-DHAVALESHWAR	DHAVALESHWAR_110	6:23	13:11	6:48	LINE CLEAR AVAILED
1017	29-Apr-22	BAGALKOT	110	MAHALINGAPUR-GSML2	STATION NOT AFFECTED MAHALINGAPUR_220	21:42 (24.04.2022)			LINE OPEN:LINE FAULT
1018	29-Apr-22	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	7:11	19:06	11:55	LINE CLEAR AVAILED
1019	29-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1020	29-Apr-22	BAGALKOT	110	RANEBENNUR-RATTIHALLI (TUMMINKATTE)	RANEBENNUR_220	16:41	17:53	1:12	LOAD CHANGE OVER
1021	29-Apr-22	BAGALKOT	110	RANEBENNUR-BYADAGI	BYADAGI_110	17:03	17:30	0:27	HAND TRIPPED
1022	29-Apr-22	BAGALKOT	110	SALAHALLI-GMNAVAR	GM NAVAT_110 SALAHALLI_110	13:23	13:45	0:22	HAND TRIPPED
1023	29-Apr-22	BAGALKOT	110	SAMBAPUR ROAD-RLY (RAILWAY)	RAILWAY_110 STATION NOT AFFECTED SAMBAPUR ROAD_110	20:17	20:23	0:06	LINE FAULT
1024	29-Apr-22	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	6:22	6:25	0:03	LOAD CHANGE OVER
1025	29-Apr-22	BAGALKOT	110	SAVALAGI-AIGALI	STATION NOT AFFECTED SAVALAGI_110	14:09	19:12	5:03	LINE CLEAR AVAILED
1026	29-Apr-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	19:28	19:36	0:08	LINE FAULT
1027	29-Apr-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	17:43	17:58	0:15	LINE FAULT
1028	29-Apr-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	17:11	17:21	0:10	LINE FAULT
1029	29-Apr-22	BAGALKOT	110	SAVANUR-ASIAN FEBTECH	ASIAN FEBTECH_110 STATION NOT AFFECTED SAVANUR_110	16:52	17:03	0:11	LINE FAULT
1030	29-Apr-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
1031	29-Apr-22	BAGALKOT	110	TAKKALAKI-TIKOTA	STATION NOT AFFECTED TAKKALAKI_110	5:32	11:37	6:05	LINE CLEAR AVAILED
1032	29-Apr-22	BAGALKOT	110	TIKOTA-BHITANAL	STATION NOT AFFECTED TIKOTA_110	5:34	11:30	5:56	LINE CLEAR AVAILED
1033	29-Apr-22	BAGALKOT	110	UGARKHUD-KAGAWAD	KAGAWAD_110	14:45	15:11	0:26	LINE FAULT
1034	29-Apr-22	BAGALKOT	110	YELLAMMANAWADI-SAVALAGI	STATION NOT AFFECTED YELLAMMANAWADI_110	14:03	19:07	5:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1035	29-Apr-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
1036	29-Apr-22	BAGALKOT	220	BAGALKOT- ALAMATTI2 (ALAMATTI1)	STATION NOT AFFECTED BAGALKOT_220	17:32 (28.04.2022)	9:52 (29.04.2022)	16:20	LINE CHARGED
1037	29-Apr-22	BAGALKOT	220	BIDNAL- TADAS1 (HIREBENDIGERI1)	STATION NOT AFFECTED BIDNAL_220	17:39 (28.04.2022)	12:55 (29.04.2022)	19:16	LINE CHARGED
1038	29-Apr-22	BAGALKOT	220	DHONI- GADAG1	STATION NOT AFFECTED DHONI_400	20:10 (28.04.2022)			LINE OPEN:LINE FAULT
1039	29-Apr-22	BAGALKOT	220	DHONI- GADAG2	STATION NOT AFFECTED DHONI_400	20:10 (28.04.2022)	19:06 (29.04.2022)	22:56	LINE CHARGED
1040	29-Apr-22	BAGALKOT	220	GADAG- LINGAPUR1(DHONI1)	STATION NOT AFFECTED GADAG_220	20:10 (28.04.2022)			LINE OPEN:LINE FAULT
1041	29-Apr-22	BAGALKOT	220	GADAG- LINGAPUR2 (DHONI2)	STATION NOT AFFECTED GADAG_220	12:13	19:42	7:29	LINE CLEAR AVAILED
1042	29-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1043	29-Apr-22	BAGALKOT	220	HUBLI- NAGJHARI3	STATION NOT AFFECTED HUBLI_220	11:01	14:05	3:04	LINE CLEAR AVAILED
1044	29-Apr-22	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	19:04 (28.04.2022)	18:22 (29.04.2022)	23:18	LINE CHARGED
1045	29-Apr-22	BAGALKOT	220	NAGJHARI2-BIDNAL	STATION NOT AFFECTED BIDNAL_220	18:28 (27.04.2022)	14:42 (29.04.2022)	44:14:00	LINE CHARGED
1046	29-Apr-22	BAGALKOT	220	RANEBENNUR- BALLIGAVI	RANEBENNUR_220	16:27	17:47	1:20	HAND TRIPPED
1047	29-Apr-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	16:54 (29.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1048	29-Apr-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:33 (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1049	29-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	20:03 (28.04.2022)	16:45 (29.04.2022)	20:42	LINE CHARGED
1050	29-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	19:43 (28.04.2022)	16:44 (29.04.2022)	21:01	LINE CHARGED
1051	29-Apr-22	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	19:06	19:10	0:04	LOAD CHANGE OVER
1052	29-Apr-22	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	17:27	17:41	0:14	MAIN SUPPLY FAILURE
1053	29-Apr-22	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA, PLATINUM CITY, SAHAKARINAGAR	18:26	18:36	0:10	LINE FAULT
1054	29-Apr-22	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	16:13	16:25	0:12	LOAD CHANGE OVER
1055	29-Apr-22	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	14:45	14:52	0:07	LOAD CHANGE OVER
1056	29-Apr-22	BENGALURU	66	CHANDRAPPA CIRCLE - KENGARI SATELLITE TOWN	CHANDRAPPA CIRCLE	15:00	15:10	0:10	LOAD CHANGE OVER
1057	29-Apr-22	BENGALURU	66	CHANDRAPPA CIRCLE - KUMBALAGODU	CHANDRAPPA CIRCLE	15:35	15:40	0:05	LOAD CHANGE OVER
1058	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	17:37	19:54	2:17	LOAD CURTAILMENT
1059	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	17:37	19:54	2:17	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1060	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI	17:37	18:52	1:15	LOAD CURTAILMENT
1061	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI	20:10	20:44	0:34	LOAD CURTAILMENT
1062	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU CROSS, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	17:37	19:57	2:20	LOAD CURTAILMENT
1063	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	17:37	19:15	1:38	LOAD CURTAILMENT
1064	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	19:28	20:03	0:35	LINE FAULT
1065	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:37	18:56	1:19	LOAD CURTAILMENT
1066	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	17:04	17:11	0:07	LOAD CURTAILMENT
1067	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	16:37	16:44	0:06	LOAD CURTAILMENT
1068	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	17:37	18:59	1:22	LOAD CURTAILMENT
1069	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	17:04	17:30	0:26	LOAD CURTAILMENT
1070	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	9:01	9:08	0:07	LINE FAULT
1071	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	16:38	16:44	0:05	LOAD CURTAILMENT
1072	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	17:37	18:27	0:50	LOAD CURTAILMENT
1073	29-Apr-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLI CROSS, YENIGADALE	17:37	19:23	1:46	LOAD CURTAILMENT
1074	29-Apr-22	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	10:28	11:48	1:20	MAIN SUPPLY FAILURE
1075	29-Apr-22	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	10:28	12:16	1:48	MAIN SUPPLY FAILURE
1076	29-Apr-22	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	10:28	11:48	1:20	MAIN SUPPLY FAILURE
1077	29-Apr-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	10:28	11:47	1:19	MAIN SUPPLY FAILURE
1078	29-Apr-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	17:47	17:55	0:08	LOAD CURTAILMENT
1079	29-Apr-22	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	10:28	11:47	1:19	MAIN SUPPLY FAILURE
1080	29-Apr-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	10:28	11:47	1:19	MAIN SUPPLY FAILURE
1081	29-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR	19:26	20:25	0:59	LOAD CURTAILMENT
1082	29-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	THONDEBHAVI	14:45	15:30	0:45	LOAD CURTAILMENT
1083	29-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA, NITRALLI	14:45	15:30	0:45	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1084	29-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL	18:16	19:01	0:45	LOAD CURTAILMENT
1085	29-Apr-22	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SIRIGIRIPURA	13:30	13:52	0:22	LINE CLEAR AVAIED
1086	29-Apr-22	BENGALURU	66	HV1	BRIGADE MEADOWS	21:23	21:25	0:02	LINE CLEAR AVAIED
1087	29-Apr-22	BENGALURU	66	HV1	BURUDAGUNTE	12:20	13:36	1:16	LINE CLEAR AVAIED
1088	29-Apr-22	BENGALURU	66	HV1	CHIKKENAHALLI	18:15	18:40	0:25	LOAD CURTAILMENT
1089	29-Apr-22	BENGALURU	66	HV1	CHINTAMANI 66	16:52	18:31	1:39	LINE CLEAR AVAIED
1090	29-Apr-22	BENGALURU	66	HV1	KODIGEHALI	18:52	19:08	0:16	TRANSFORMER FAULT
1091	29-Apr-22	BENGALURU	66	HV1	MULABAGALU	12:01	12:20	0:18	TRANSFORMER FAULT
1092	29-Apr-22	BENGALURU	66	HV1	NANDIGANAHALLI	19:25	20:10	0:45	TRANSFORMER FAULT
1093	29-Apr-22	BENGALURU	66	HV1	NGEF	16:00	16:16	0:16	LINE CLEAR AVAIED
1094	29-Apr-22	BENGALURU	66	HV1	YARANDANAHALLI 220	21:30	21:45	0:15	TRANSFORMER FAULT
1095	29-Apr-22	BENGALURU	66	HV2	BANASHANAKARI	6:18	6:20	0:02	LOAD CHANGE OVER
1096	29-Apr-22	BENGALURU	66	HV2	CHIKKENAHALLI	18:15	18:40	0:25	LOAD CURTAILMENT
1097	29-Apr-22	BENGALURU	66	HV2	CHINTAMANI 66	16:33	16:45	0:12	LINE CLEAR AVAIED
1098	29-Apr-22	BENGALURU	66	HV2	GOWRIBIDANUR 220	8:27	8:32	0:05	LINE CLEAR AVAIED
1099	29-Apr-22	BENGALURU	66	HV2	GOWRIBIDANUR 220	11:45	12:35	0:50	LINE CLEAR AVAIED
1100	29-Apr-22	BENGALURU	66	HV2	HULLENAHALLI	13:30	14:25	0:55	LINE CLEAR AVAIED
1101	29-Apr-22	BENGALURU	66	HV2	NGEF	14:30	14:40	0:10	LINE CLEAR AVAIED
1102	29-Apr-22	BENGALURU	66	HV2	YEDUMADU	0:31	0:45	0:14	TRANSFORMER FAULT
1103	29-Apr-22	BENGALURU	66	HV2	YEDUMADU	3:03	3:06	0:03	TRANSFORMER FAULT
1104	29-Apr-22	BENGALURU	66	KEMPANAHALLI - AGALKOTE	AGALKOTE, MATHIKERE(NELAMANGALA)	14:15	14:18	0:03	LINE FAULT
1105	29-Apr-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	17:31	19:02	1:31	LOAD CURTAILMENT
1106	29-Apr-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	17:33	20:10	2:37	LOAD CURTAILMENT
1107	29-Apr-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	17:33	20:10	2:37	LOAD CURTAILMENT
1108	29-Apr-22	BENGALURU	66	KOLAR 220 - PGCIL AUX	PGCIL AUX, SUGUTUR	17:36	18:00	0:24	LOAD CURTAILMENT
1109	29-Apr-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR	16:41	16:45	0:04	LOAD CURTAILMENT
1110	29-Apr-22	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	17:31	19:07	1:36	LOAD CURTAILMENT
1111	29-Apr-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	17:31	20:01	2:30	LOAD CURTAILMENT
1112	29-Apr-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:36	20:06	2:30	LOAD CURTAILMENT
1113	29-Apr-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	17:43	20:01	2:18	LOAD CURTAILMENT
1114	29-Apr-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	16:48	17:17	0:29	LOAD CURTAILMENT
1115	29-Apr-22	BENGALURU	66	MALUR 220 - KGF 2	BANGARPETE	17:43	20:02	2:19	LOAD CURTAILMENT
1116	29-Apr-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	17:43	19:36	1:53	LOAD CURTAILMENT
1117	29-Apr-22	BENGALURU	66	MANDIKAL - MITTERMARI	MANDIKAL	20:00	20:05	0:05	LOAD CHANGE OVER
1118	29-Apr-22	BENGALURU	66	NANDIGANAHALLI - CHINTAMANI 220	NANDIGANAHALLI	19:25	20:05	0:40	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1119	29-Apr-22	BENGALURU	66	PLATINUM CITY - ATTUR YELAHANKA	PLATINUM CITY	18:28	18:39	0:11	MAIN SUPPLY FAILURE
1120	29-Apr-22	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	21:58	22:05	0:07	LOAD CHANGE OVER
1121	29-Apr-22	BENGALURU	66	SAHAKARINAGAR - MANYATHA TECH PARK 220	SAHAKARINAGAR	23:00	23:05	0:05	LOAD CHANGE OVER
1122	29-Apr-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	10:48	11:14	0:26	MAIN SUPPLY FAILURE
1123	29-Apr-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:45	15:02	0:17	MAIN SUPPLY FAILURE
1124	29-Apr-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:48	11:14	0:26	MAIN SUPPLY FAILURE
1125	29-Apr-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:45	15:02	0:17	MAIN SUPPLY FAILURE
1126	29-Apr-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:48	11:13	0:25	MAIN SUPPLY FAILURE
1127	29-Apr-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:45	15:01	0:16	MAIN SUPPLY FAILURE
1128	29-Apr-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	17:27	17:41	0:14	LINE FAULT
1129	29-Apr-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	17:55	18:08	0:13	LINE FAULT
1130	29-Apr-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR, K HONALGERE, YATHAMBADI	18:41	18:51	0:10	LINE FAULT
1131	29-Apr-22	BENGALURU	66	VIDYANAGAR - BEGUR 220	VIDYANAGAR	0:52	2:32	1:40	LINE CLEAR AVAILED
1132	29-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	10:48	11:15	0:27	LINE CLEAR AVAILED
1133	29-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	14:45	15:01	0:16	LINE CLEAR AVAILED
1134	29-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	10:48	11:15	0:27	LINE CLEAR AVAILED
1135	29-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	14:45	15:01	0:16	LINE CLEAR AVAILED
1136	29-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	10:48	11:15	0:27	LINE CLEAR AVAILED
1137	29-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	14:45	15:01	0:16	LINE CLEAR AVAILED
1138	29-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	10:48	11:15	0:27	LINE CLEAR AVAILED
1139	29-Apr-22	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	14:45	15:01	0:16	LINE CLEAR AVAILED
1140	29-Apr-22	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:02	6:13	0:11	LINE FAULT
1141	29-Apr-22	BENGALURU	220	DABUSPETE 220 - KADUR 220	KUDUR 220	10:27	12:01	1:33	MAIN SUPPLY FAILURE
1142	29-Apr-22	BENGALURU	220	HOODY 220 - MALUR 220	VIKAS TECH PARK 220, SARJAPURA 220	10:48	11:04	0:16	LINE FAULT
1143	29-Apr-22	BENGALURU	220	HOODY 220 - MALUR 220	VIKAS TECH PARK 220, SARJAPURA 220	14:44	14:52	0:08	LINE CLEAR AVAILED
1144	29-Apr-22	BENGALURU	220	MALUR 220 - HOODY 220	SARJAPURA 220, VIKAS TECH PARK 220	10:48	11:10	0:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1145	29-Apr-22	BENGALURU	220	MALUR 220 - HOODY 220	SARJAPURA 220, VIKAS TECH PARK 220	14:44	14:55	0:10	LINE CLEAR AVAILED
1146	29-Apr-22	BENGALURU	220	NELMANGALA 400 - DABUSPETE 220	DABUSPETE 220	10:27	11:45	1:17	LINE FAULT
1147	29-Apr-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	10:48	11:15	0:27	MAIN SUPPLY FAILURE
1148	29-Apr-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	14:44	15:01	0:17	MAIN SUPPLY FAILURE
1149	29-Apr-22	GULBARGA	66	HV1	HALAVAGALU_66	18:25(29.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
1150	29-Apr-22	GULBARGA	66	HV1	HALAVAGALU_66	17:15	18:00	0:45	LINE CLEAR AVAILED
1151	29-Apr-22	GULBARGA	66	HV1	TELAGI_66	6:00	6:10	0:10	TRANSFORMER FAULT
1152	29-Apr-22	GULBARGA	66	HV2	HALAVAGALU_66	9:35	9:40	0:05	TRANSFORMER FAULT
1153	29-Apr-22	GULBARGA	66	HV2	HALAVAGALU_66	18:25	19:15	0:50	LINE CLEAR AVAILED
1154	29-Apr-22	GULBARGA	66	HV2	HALAVAGALU_66	19:20	19:30	0:10	TRANSFORMER FAULT
1155	29-Apr-22	GULBARGA	66	ITTAGI-HUVINAHADAGALI_66	HUVINAHADGALI_66,HOLAGUNDI_66	11:20	17:35	6:15	LINE CLEAR AVAILED
1156	29-Apr-22	GULBARGA	110	ADVIMARESHWARA-MALLAT	ADAVIAMARESHWARA_110	22:35	22:41	0:06	MAIN SUPPLY FAILURE
1157	29-Apr-22	GULBARGA	110	DEODURGA-SHAHPUR	DEODURGA_110	9:10	9:45	0:35	MAIN SUPPLY FAILURE
1158	29-Apr-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1159	29-Apr-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1160	29-Apr-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	0:10	0:15	0:05	MAIN SUPPLY FAILURE
1161	29-Apr-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	0:20	0:25	0:05	MAIN SUPPLY FAILURE
1162	29-Apr-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	5:30	5:35	0:05	MAIN SUPPLY FAILURE
1163	29-Apr-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	9:20	9:30	0:10	MAIN SUPPLY FAILURE
1164	29-Apr-22	GULBARGA	110	HV	GANGAVATI_220	9:55	15:55	6:00	LINE CLEAR AVAILED
1165	29-Apr-22	GULBARGA	110	HV1	GOOGLE_110	9:35	9:45	0:10	TRANSFORMER FAULT
1166	29-Apr-22	GULBARGA	110	HV1	GOOGLE_110	15:05	15:15	0:10	TRANSFORMER FAULT
1167	29-Apr-22	GULBARGA	110	HV1	YAKATPUR_110	11:30	14:25	2:55	LINE CLEAR AVAILED
1168	29-Apr-22	GULBARGA	110	HV2	CHINCHOLI_110	14:50	15:05	0:15	LOAD CURTAILMENT
1169	29-Apr-22	GULBARGA	110	HV2	CHINCHOLI_110	17:31	18:04	0:33	LOAD CURTAILMENT
1170	29-Apr-22	GULBARGA	110	HV2	DEODURGA_110	16:20	16:30	0:10	TRANSFORMER FAULT
1171	29-Apr-22	GULBARGA	110	HV2	KUSTAGI_220	10:47	10:55	0:08	TRANSFORMER FAULT
1172	29-Apr-22	GULBARGA	110	LADHA-RENEWSOALR_IPP	LADHA_110	19:05	22:30	3:25	LINE CLEAR AVAILED
1173	29-Apr-22	GULBARGA	110	LV1, LV2	SHAHAPUR_220	9:18	9:26	0:08	LINE CLEAR AVAILED
1174	29-Apr-22	GULBARGA	110	LV2	SHAHAPUR_220	11:53	13:54	2:01	LINE CLEAR AVAILED
1175	29-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	2:30	2:35	0:05	LINE FAULT
1176	29-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	22:26	22:36	0:10	LINE FAULT
1177	29-Apr-22	GULBARGA	110	NALWAR-SHAHAAPUR	NALWAR_110	9:15	9:35	0:20	MAIN SUPPLY FAILURE
1178	29-Apr-22	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	21:00	21:20	0:20	MAIN SUPPLY FAILURE
1179	29-Apr-22	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	23:33	23:38	0:05	LINE FAULT
1180	29-Apr-22	GULBARGA	110	SAHHAPUR-SHAHAPUR1	SHAHAPUR_110	5:28	5:36	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1181	29-Apr-22	GULBARGA	110	SAHHAPUR-WARDA SLOAR_IPP	SHAHAPUR_220	11:52	13:33	1:41	LINE FAULT
1182	29-Apr-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	11:18	11:21	0:03	LINE FAULT
1183	29-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)	18:08(29.04.2022)	6939:13HRS	LINE CHARGED
1184	29-Apr-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	9:08	13:36	4:28	LINE CLEAR AVAILED
1185	29-Apr-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI_110	0:16	0:20	0:04	LINE FAULT
1186	29-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1187	29-Apr-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	9:08	9:30	0:22	LINE CLEAR AVAILED
1188	29-Apr-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	13:26	13:30	0:04	LINE CLEAR AVAILED
1189	29-Apr-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	18:10 (28.04.2022)	13:26 (29.04.2022)	19:16 HRS	LINE CHARGED
1190	29-Apr-22	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110,SHORAPUR_110, KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI_110	9:08	9:28	0:20	LINE CLEAR AVAILED
1191	29-Apr-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	NALWAR_110	9:08	9:50	0:42	LINE CLEAR AVAILED
1192	29-Apr-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,WA DGERA_110, KHANAPUR_110	9:08	13:44	4:36	LINE CLEAR AVAILED
1193	29-Apr-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,WA DGERA_110, KHANAPUR_110	18:42	18:58	0:16	LINE FAULT
1194	29-Apr-22	GULBARGA	110	STAR METTALLIC-MUNIRABAD	STAR METTALLIC_IPP	22:58	23:04	0:06	LINE FAULT
1195	29-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1196	29-Apr-22	GULBARGA	220	HV2	RAICHUR_220	10:15	17:30	7:15	LINE CLEAR AVAILED
1197	29-Apr-22	GULBARGA	220	KUDLIGI-HIREMALLANHOLE	KUDLIGI_220	11:50	12:35	0:45	LINE FAULT
1198	29-Apr-22	GULBARGA	220	NEELGUNDA-GUTTUR	NEELGUNDA_220	15:54	17:00	1:06	NFBC ISSUED
1199	29-Apr-22	GULBARGA	400	BPS-PAVAGADA1,2	PAVAGADA_400	11:47(29.4.22)			LINE OPEN:LINE CLEAR AVAILED
1200	29-Apr-22	GULBARGA	400	RTPS-BTPS	RTPS_400	21:19(29.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1201	29-Apr-22	GULBARGA	400	RTPS-BTPS	RTPS_400	13:07	13:46	0:39	LINE CLEAR AVAILED
1202	29-Apr-22	HASSAN	66	BANDISHET-RAMNATHPURA	BANDISHETTIHALLY_66	14:20(29.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1203	29-Apr-22	HASSAN	66	HV1	DODDAHALLY_66	19:15	20:45	1:30	MAIN SUPPLY FAILURE
1204	29-Apr-22	HASSAN	66	HV1	HALEBEEDU_66	16:10	16:40	0:30	LINE CLEAR AVAILED
1205	29-Apr-22	HASSAN	66	HV1	HALLIMYSORE_66	17:17	17:30	0:13	LOAD CURTAILMENT
1206	29-Apr-22	HASSAN	66	HV1	HANGARAHALLY_66	17:15	17:25	0:10	LOAD CURTAILMENT
1207	29-Apr-22	HASSAN	66	HV1	HNPURA_66	19:18	20:45	1:27	MAIN SUPPLY FAILURE
1208	29-Apr-22	HASSAN	66	HV1	HOLEHONNUR_66	10:55 (26.04.2022)	13:55(29.04.2022)	75:00HRS	TRANSFORMER CHARGED
1209	29-Apr-22	HASSAN	66	HV1	HOLEHONNUR_66	16:55	17:05	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1210	29-Apr-22	HASSAN	66	HV1	RAMPURA_66	19:15	20:40	1:25	MAIN SUPPLY FAILURE
1211	29-Apr-22	HASSAN	66	HV1	SAKALESH PURA_66	10:59(28.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1212	29-Apr-22	HASSAN	66	HV1	SIGEBAGI_66	19:15	19:50	0:35	LINE CLEAR AVAILED
1213	29-Apr-22	HASSAN	66	HV2	BASAVAGATTA_66	14:51	15:03	0:12	LOAD CURTAILMENT
1214	29-Apr-22	HASSAN	66	HV2	HNPURA_66	19:18	20:45	1:27	MAIN SUPPLY FAILURE
1215	29-Apr-22	HASSAN	66	HV2	RAMNATH PURA_66	19:15	20:40	1:25	MAIN SUPPLY FAILURE
1216	29-Apr-22	HASSAN	66	HV2	SAKALESH PURA_66	23:54 (28.04.2022)	00:02(29.04.2022)	00:08HRS	TRANSFORMER CHARGED
1217	29-Apr-22	HASSAN	66	HV2	SAKALESH PURA_66	19:04	19:10	0:06	TRANSFORMER FAULT
1218	29-Apr-22	HASSAN	66	HV2	SINGAPURA_66	17:37	17:46	0:09	LOAD CURTAILMENT
1219	29-Apr-22	HASSAN	66	HV2	UDAYAPURA_66	14:15	14:25	0:10	HAND TRIPPED
1220	29-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATH PURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1221	29-Apr-22	HASSAN	66	SALGME-HIREMANGLUR	SALAGAME_66	21:15	22:17	1:02	LINE FAULT
1222	29-Apr-22	HASSAN	66	SIGEBAGI-KDLGRE	SIGEBAGI_66	23:54 (28.04.2022)	00:10(29.04.2022)	00:16HRS	LINE CHARGED
1223	29-Apr-22	HASSAN	110	GURUPURA-KAVOOR	GURUPURA_110	10:46	14:57	4:11	HAND TRIPPED
1224	29-Apr-22	HASSAN	110	HV1	JAVAGAL_110	17:30	17:45	0:15	LOAD CURTAILMENT
1225	29-Apr-22	HASSAN	110	HV1	KADUR_220	10:25	12:01	1:36	MAIN SUPPLY FAILURE
1226	29-Apr-22	HASSAN	110	HV2	BADRAVATY_110	16:30	17:35	1:05	LINE CLEAR AVAILED
1227	29-Apr-22	HASSAN	110	HV2	GANDASI_110	17:30	17:45	0:15	LOAD CURTAILMENT
1228	29-Apr-22	HASSAN	110	HV2	GERUMARA_110	17:15	17:30	0:15	LOAD CURTAILMENT
1229	29-Apr-22	HASSAN	110	HV2	HIRENALLUR_110	10:30	14:30	4:00	LINE CLEAR AVAILED
1230	29-Apr-22	HASSAN	110	HV2	KADUR_220	10:25	12:01	1:36	MAIN SUPPLY FAILURE
1231	29-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1232	29-Apr-22	HASSAN	110	HV4	BAIKAMPADY_110	12:30	16:03	3:33	LINE CLEAR AVAILED
1233	29-Apr-22	HASSAN	110	HV5	KAVOOR_220	8:45 (26.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1234	29-Apr-22	HASSAN	110	JOG-JLT4	gen_mghe	21:28(28.04.2022)			LINE OPEN:LINE FAULT
1235	29-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1236	29-Apr-22	HASSAN	110	KADUR	HIRENALLUR_110	9:45	12:30	2:45	MAIN SUPPLY FAILURE
1237	29-Apr-22	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:25	12:03	1:38	MAIN SUPPLY FAILURE
1238	29-Apr-22	HASSAN	110	KADUR-TNGL	KADUR_220	15:00	15:25	0:25	HAND TRIPPED
1239	29-Apr-22	HASSAN	110	KADUR-TNGL	KADUR_220	10:25	12:02	1:37	MAIN SUPPLY FAILURE
1240	29-Apr-22	HASSAN	110	KADUR-YGTI	KADUR_220	10:25	12:01	1:36	MAIN SUPPLY FAILURE
1241	29-Apr-22	HASSAN	110	LPH-MGHE 2	gen_lph	21:28(28.04.2022)			LINE OPEN:LINE FAULT
1242	29-Apr-22	HASSAN	110	LV1	KADUR_220	10:25	12:01	1:36	MAIN SUPPLY FAILURE
1243	29-Apr-22	HASSAN	110	LV2	KADUR_220	10:25	12:01	1:36	MAIN SUPPLY FAILURE
1244	29-Apr-22	HASSAN	110	MOBDRE-KEMAR	MOODABIDRE_110	10:47	14:55	4:08	LOAD CHANGE OVER
1245	29-Apr-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	16:45	17:39	0:54	MAIN SUPPLY FAILURE
1246	29-Apr-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	16:45	17:39	0:54	MAIN SUPPLY FAILURE
1247	29-Apr-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	16:45	17:39	0:54	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1248	29-Apr-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	16:45	17:39	0:54	MAIN SUPPLY FAILURE
1249	29-Apr-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	16:45	17:39	0:54	MAIN SUPPLY FAILURE
1250	29-Apr-22	HASSAN	220	ARSIK2-SHMG	ARSIKERE_220	17:11(28.04.2022)	12:35(29.04.2022)	6:49HRS	LINE CHARGED
1251	29-Apr-22	HASSAN	220	GOPALA--BASTIPURA	GOPALAPURA_220	19:15	20:40	1:25	LINE FAULT
1252	29-Apr-22	HASSAN	220	KADUR-DABUSET	KADUR_220	10:25	12:01	1:36	MAIN SUPPLY FAILURE
1253	29-Apr-22	HASSAN	220	KADUR-SHIMOGA	KADUR_220	18:30(28.04.2022)	12:26(29.04.20.22)	18:56HRS	LINE CHARGED
1254	29-Apr-22	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	11:41	13:25	1:44	LINE CLEAR AVAILED
1255	29-Apr-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	17:45(28.04.2022)	12:05(29.04.2022)	29:50HRS	LINE CHARGED
1256	29-Apr-22	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	17:11(28.04.2022)	12:35(29.04.2022)	29:46HRS	LINE CHARGED
1257	29-Apr-22	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	16:52(28.04.2022)			LINE OPEN:LINE FAULT
1258	29-Apr-22	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	18:20 (28.04.2022)	12:25(29.04.2022)	30:45HRS	LINE CHARGED
1259	29-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:47	12:53	0:06	LINE FAULT
1260	29-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	15:17	18:49	3:32	LINE FAULT
1261	29-Apr-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	11:17	12:42	1:25	LINE CLEAR AVAILED
1262	29-Apr-22	HASSAN	220	SHRAVTY-SHIMOGA1	gen_sharavthy	12:47	12:53	0:06	LINE FAULT
1263	29-Apr-22	HASSAN	220	SHRAVTY-SHIMOGA4	gen_sharavthy	15:17	18:49	3:32	LINE FAULT
1264	29-Apr-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	gen_sharavthy	16:49	17:39	0:50	LINE CLEAR AVAILED
1265	29-Apr-22	HASSAN	220	SHRAVTY-SIRISI 1	gen_sharavthy	20:03 (28.04.2022)	16:45(29.04.2022)	20:17HRS	LINE CHARGED
1266	29-Apr-22	HASSAN	220	SHRAVTY-SIRISI 2	gen_sharavthy	19:42 (28.02.2022)	16:45(29.04.2022)	20:17HRS	LINE CHARGED
1267	29-Apr-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	16:49	17:39	0:50	LINE CLEAR AVAILED
1268	29-Apr-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	16:44	17:43	0:59	LINE CLEAR AVAILED
1269	29-Apr-22	HASSAN	220	VARAH1-SHIMOGA2	gen_varahi	11:17	12:42	1:25	LINE CLEAR AVAILED
1270	29-Apr-22	HASSAN	220	VARAH1-SHMG3	gen_varahi	17:44(28.04.2022)	7:28(29.04.2022)	13:44HRS	LINE CHARGED
1271	29-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1272	29-Apr-22	MYSURU	66	AKIHEBBAL-K R PETE 1	NO STATIONS EFFECTED	3:40	3:45	0:05	LINE FAULT
1273	29-Apr-22	MYSURU	66	AKIHEBBAL-KAVERI HYDRO	NO STATIONS EFFECTED	3:40	3:45	0:05	LINE FAULT
1274	29-Apr-22	MYSURU	66	BEGUR 220-SARGUR	ANTHARSANTHE_66 HDKOTE_66 SANTHESARAGUR_66 CHANDRAVADI_66 YARAHALLI HANDPOST_66	19:39	19:55	0:16	LINE FAULT
1275	29-Apr-22	MYSURU	66	BEGUR 66-B MATTGERE	NO STATIONS EFFECTED	7:41:00 PM (29.04.2022)			LINE OPEN:LINE FAULT
1276	29-Apr-22	MYSURU	66	BEGUR 66-NANJANGUDU	NO STATIONS EFFECTED	19:45	20:50	1:05	LINE FAULT
1277	29-Apr-22	MYSURU	66	DEVANUR NANJANGUDU-HEMMARAGALA	DEVANOORNGUDU_66 SUTTUR_66	3:32	3:50	0:18	LINE FAULT
1278	29-Apr-22	MYSURU	66	DEVANUR NANJANGUDU-HEMMARAGALA	DEVANOORNGUDU_66 SUTTUR_66	13:00	13:10	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1279	29-Apr-22	MYSURU	66	DEVANUR NANJANGUDU-KADAKOLA	DEVANOORNGUDU_66 SUTTUR_66	14:29	14:45	0:16	LINE FAULT
1280	29-Apr-22	MYSURU	66	DODDINDUVADI-KOTHANURU	NO STATIONS EFFECTED	0:55	1:00	0:05	LINE FAULT
1281	29-Apr-22	MYSURU	66	HARVEYTHAMADALLI LIS	NO STATIONS EFFECTED	17:00	19:35	2:35	LINE FAULT
1282	29-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1283	29-Apr-22	MYSURU	66	HEBBANI-MEGALAPURA	BGPURA_66 CHIDRAVALI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	20:59	21:10	0:11	LINE FAULT
1284	29-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1285	29-Apr-22	MYSURU	66	HONNAHALLI-HV2	HONNALY_MYS_66	11:40	14:20	2:40	LINE CLEAR AVAILED
1286	29-Apr-22	MYSURU	66	HOOTAGALLI-BARC2	NO STATIONS EFFECTED	20:50	21:40	0:50	LINE FAULT
1287	29-Apr-22	MYSURU	66	HOOTAGALLI-BOGADHI	BOGADHI_66	20:50	22:09	1:19	LINE FAULT
1288	29-Apr-22	MYSURU	66	HOOTAGALLI-FTS-1	NO STATIONS EFFECTED	9:26	9:37	0:11	LINE FAULT
1289	29-Apr-22	MYSURU	66	HOOTAGALLI-FTS-1	NO STATIONS EFFECTED	13:25	16:35	3:10	LINE CLEAR AVAILED
1290	29-Apr-22	MYSURU	66	HOOTAGALLI-FTS-2	NO STATIONS EFFECTED	10:43	12:00	1:17	LINE CLEAR AVAILED
1291	29-Apr-22	MYSURU	66	HOOTAGALLI-FTS-2	NO STATIONS EFFECTED	13:25	16:35	3:10	LINE CLEAR AVAILED
1292	29-Apr-22	MYSURU	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HOSURGATE_66	19:45	20:10	0:25	LINE FAULT
1293	29-Apr-22	MYSURU	66	HV 2	AKKIHEBBAL_66	14:52	15:02	0:10	LOAD CURTAILMENT
1294	29-Apr-22	MYSURU	66	HV1	BGNAGARA_66	14:55	15:00	0:05	LOAD CURTAILMENT
1295	29-Apr-22	MYSURU	66	HV1	BGPURA_66	14:50	15:00	0:10	LOAD CURTAILMENT
1296	29-Apr-22	MYSURU	66	HV1	KIADBMANDYA_66	13:30	15:12	1:42	LINE CLEAR AVAILED
1297	29-Apr-22	MYSURU	66	HV1	NAGAMANGALA_66	17:35	17:40	0:05	LOAD CURTAILMENT
1298	29-Apr-22	MYSURU	66	HV1	SATHEGALA_66	17:30	17:40	0:10	LOAD CURTAILMENT
1299	29-Apr-22	MYSURU	66	HV-1	KUSHALNAGARA-	15:01	15:12	0:11	TRANSFORMER FAULT
1300	29-Apr-22	MYSURU	66	HV2	BOOKANAKERE_66	14:50	15:00	0:10	LOAD CURTAILMENT
1301	29-Apr-22	MYSURU	66	HV2	HANNUR_66	17:31	17:35	0:03	LOAD CURTAILMENT
1302	29-Apr-22	MYSURU	66	HV2	HDKOTE_66	17:15	17:25	0:10	LOAD CURTAILMENT
1303	29-Apr-22	MYSURU	66	HV2	HEBBAL_66	11:23	18:32	7:09	TRANSFORMER FAULT
1304	29-Apr-22	MYSURU	66	HV2	KIRUGAVALU_66	17:35	18:07	0:32	LOAD CURTAILMENT
1305	29-Apr-22	MYSURU	66	HV2	KMDODDI_66	17:10	17:40	0:30	LOAD CURTAILMENT
1306	29-Apr-22	MYSURU	66	HV2	KOLLEGALA_66	17:17	17:22	0:04	LOAD CURTAILMENT
1307	29-Apr-22	MYSURU	66	HV2	MALAVALLI_66	17:33	17:36	0:03	LOAD CURTAILMENT
1308	29-Apr-22	MYSURU	66	HV2	SANTHEMARAHALI_66	17:35	17:40	0:05	LOAD CURTAILMENT
1309	29-Apr-22	MYSURU	66	HV2	SANTHESARAGUR_66	17:40	17:50	0:10	LOAD CURTAILMENT
1310	29-Apr-22	MYSURU	66	HV2	SATHEGALA_66	12:43	13:17	0:33	LINE CLEAR AVAILED
1311	29-Apr-22	MYSURU	66	K R PETE 220-K R PETE 1	AKKIHEBBAL_66 KRPET_66 KIKKERI_66	19:09	19:26	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1312	29-Apr-22	MYSURU	66	K R PETE 220-K R PETE 2	NO STATIONS EFFECTED	19:09	19:28	0:19	LINE FAULT
1313	29-Apr-22	MYSURU	66	KADAKOLA-SARGUR 1	HAMPAPURA(K)_66 JAIPUR_66	3:39	3:46	0:07	LINE FAULT
1314	29-Apr-22	MYSURU	66	KADAKOLA-SARGUR 2	HULLAHALLI_66 HURA_66 DOORA_66	3:39	3:46	0:07	LINE FAULT
1315	29-Apr-22	MYSURU	66	KADAKOLA-THANDYA	NO STATIONS EFFECTED	9:46	19:47	10:01	HAND TRIPPED
1316	29-Apr-22	MYSURU	66	KUSHALNAGARA-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 MIRLE_66 RAVANDUR_66 CHUNCHUNKATTE_66 KRNAGARA_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	14:10	14:20	0:10	LINE FAULT
1317	29-Apr-22	MYSURU	66	KUSHALNAGARA-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 MIRLE_66 RAVANDUR_66 CHUNCHUNKATTE_66 KRNAGARA_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	14:36	15:01	0:25	LINE FAULT
1318	29-Apr-22	MYSURU	66	KUSHALNAGARA-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 MIRLE_66 RAVANDUR_66 CHUNCHUNKATTE_66 KRNAGARA_66 BILIKERE_66 GVGUDI_66 DMG_HALLI_66	20:30	21:32	1:02	LINE FAULT
1319	29-Apr-22	MYSURU	66	KUSHALNAGARA-MYSORE-1	MIRLE_66	18:25	18:33	0:08	LINE FAULT
1320	29-Apr-22	MYSURU	66	KUSHALNAGARA-MYSORE-1	NO STATIONS EFFECTED	14:10	14:20	0:10	LINE FAULT
1321	29-Apr-22	MYSURU	66	KUSHALNAGARA-MYSORE-1	NO STATIONS EFFECTED	14:36	15:01	0:25	LINE FAULT
1322	29-Apr-22	MYSURU	66	KUSHALNAGARA-MYSORE-1	NO STATIONS EFFECTED	20:30	21:34	1:04	LINE FAULT
1323	29-Apr-22	MYSURU	66	KUSHALNAGARA-PERİYAPATNA-1	NO STATIONS EFFECTED	7:12	7:17	0:05	LINE FAULT
1324	29-Apr-22	MYSURU	66	KUSHALNAGARA-SOMWARPETE	SOMWARPETE_33	18:15	18:25	0:10	LINE FAULT
1325	29-Apr-22	MYSURU	66	KUSHALNAGARA-SOMWARPETE	SOMWARPETE_33	22:05	22:15	0:10	LINE FAULT
1326	29-Apr-22	MYSURU	66	KUSHALNAGARA-SOMWARPETE	SOMWARPETE_33	22:50	23:01	0:11	LINE FAULT
1327	29-Apr-22	MYSURU	66	KUSHALNAGARA-SOMWARPETE	SOMWARPETE_33	23:12	23:19	0:07	LINE FAULT
1328	29-Apr-22	MYSURU	66	MADHUVANAHALLY-KOLLEGALA	NO STATIONS EFFECTED	22:00	22:07	0:07	LINE FAULT
1329	29-Apr-22	MYSURU	66	MADHUVANAHALLY-KUNTHUR	THAYURU_66 TNARASIPURA_66 MUGUR_66 KUNTHUR_66 JANNUR_66	22:10	22:16	0:06	LINE FAULT
1330	29-Apr-22	MYSURU	66	MADHUVANAHALLY-MAMBALLI	NO STATIONS EFFECTED	22:00	22:06	0:06	LINE FAULT
1331	29-Apr-22	MYSURU	66	NAGAMANGALA 220 KV-GUDDENAHALLI	BOGADHI MANDYA_66 GUDDENAHALLI_66	18:02	18:45	0:43	LINE FAULT
1332	29-Apr-22	MYSURU	66	PERIAPATNA-KAMPLAPURA	KAMPLAPURA_66	19:34	19:41	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1333	29-Apr-22	MYSURU	66	SATHEGALA -HV-2	SATHEGALA_66	12:45	13:20	0:35	LINE CLEAR AVAILED
1334	29-Apr-22	MYSURU	66	SFCSIVA-10 MW	NO STATIONS EFFECTED	21:00	21:30	0:30	LINE FAULT
1335	29-Apr-22	MYSURU	66	SFCSIVA-5 MW	NO STATIONS EFFECTED	9:00:00 PM (29.04.2022)			LINE OPEN:LINE FAULT
1336	29-Apr-22	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	21:00	21:16	0:16	LINE FAULT
1337	29-Apr-22	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	19:11:00 (4/5/2022)	0:59:00 (5/5/2022)	5:48:00	LINE CHARGED
1338	29-Apr-22	MYSURU	66	TUBINAKERE-BASTHIPURA	NO STATIONS EFFECTED	19:14	20:50	1:36	LINE FAULT
1339	29-Apr-22	MYSURU	66	TUBINAKERE- NAGAMANGALA 1	HARADANAHALLI(JAK)_66 SHIVALLY_66	6:00	14:30	8:30	LINE CLEAR AVAILED
1340	29-Apr-22	MYSURU	66	TUBINAKERE- NAGAMANGALA 2	NO STATIONS EFFECTED	6:00	14:30	8:30	LINE CLEAR AVAILED
1341	29-Apr-22	MYSURU	66	TUBINAKERE- NAGAMANGALA 2	SHIVALLY_66 KESLAGERE_66 HARADANAHALLI(JAK)_66 BASARALU_66	17:55	18:00	0:05	LINE FAULT
1342	29-Apr-22	MYSURU	66	TUBINAKERE-S R PATNA	SRIRANGAPATNA_66 GARUDANAUKADDA_66	21:02	21:24	0:22	LINE FAULT
1343	29-Apr-22	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	2:54	3:04	0:10	LINE FAULT
1344	29-Apr-22	MYSURU	66	VAJAMANGALA- KADAKOLA 1	MARADIHUNDI_66 AYRALLI_66	19:46	19:56	0:10	LINE FAULT
1345	29-Apr-22	MYSURU	66	VAJAMANGALA- KADAKOLA 2	NO STATIONS EFFECTED	6:07	6:14	0:07	LINE FAULT
1346	29-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1347	29-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1348	29-Apr-22	MYSURU	220	HV1	KADAKOLA_220	9:25:00 PM (28.04.2022)	8:06:00 PM (29.04.2022)	22:41 hrs	TRANSFORMER CHARGED
1349	29-Apr-22	MYSURU	220	HV-1	NAGAMANGALA_220	18:02	18:50	0:48	TRANSFORMER FAULT
1350	29-Apr-22	MYSURU	220	HV2	HOOTAGALLY_220	20:50	21:49	0:59	TRANSFORMER FAULT
1351	29-Apr-22	TUMKUR	66	ANCHEPALYA 220- HEBBUR	HEBBUR_66	16:33	16:49	0:15	LOAD CURTAILMENT
1352	29-Apr-22	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	16:53	17:04	0:10	LINE FAULT
1353	29-Apr-22	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	17:20(29.4.22)	8:46(30.4.22)	1DAY,3:26	LINE CHARGED
1354	29-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	17:42	19:10	1:27	LOAD CURTAILMENT
1355	29-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	17:42	19:10	1:27	LOAD CURTAILMENT
1356	29-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220kV KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	19:22	20:32	1:10	LOAD CURTAILMENT
1357	29-Apr-22	TUMKUR	66	BENKIKERE 220kV- GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	10:03	16:29	6:25	LINE CLEAR AVAILED
1358	29-Apr-22	TUMKUR	66	BHARAMAGIRI- HIRIYUR220	BHARAMAGIRI_66	17:20	17:30	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1359	29-Apr-22	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:43	12:53	0:09	LINE FAULT
1360	29-Apr-22	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:54	18:02	0:08	LOAD CURTAILMENT
1361	29-Apr-22	TUMKUR	66	DAVANGERE SRS-YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJHALLI_66	17:53	19:03	1:09	LOAD CURTAILMENT
1362	29-Apr-22	TUMKUR	66	HIREHALLI - BADDIHALLI(MELEKOTE)	MELEKOTE_66, BADDIHALLI_66	10:28	12:26	1:58	MAIN SUPPLY FAILURE
1363	29-Apr-22	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	9:05	9:20	0:15	MAIN SUPPLY FAILURE
1364	29-Apr-22	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	9:45	9:55	0:10	MAIN SUPPLY FAILURE
1365	29-Apr-22	TUMKUR	66	HOLALKERE-PANDRAHALLI	PANDRAHALLI	6:30	17:03	10:33	LINE CLEAR AVAILED
1366	29-Apr-22	TUMKUR	66	KUKKAWADA -HONNALLI	KUKKAWADA_66	18:04	19:07	1:02	MAIN SUPPLY FAILURE
1367	29-Apr-22	TUMKUR	66	MADHUGIRI 220kV-KORATAGERE	KORATAGERE_66	16:37	17:25	0:47	LOAD CURTAILMENT
1368	29-Apr-22	TUMKUR	66	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	19:09	20:03	0:53	LINE FAULT
1369	29-Apr-22	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	11:51	12:01	0:10	LINE FAULT
1370	29-Apr-22	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	15:02	15:16	0:14	LINE FAULT
1371	29-Apr-22	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	17:22	17:28	0:05	HAND TRIPPED
1372	29-Apr-22	TUMKUR	66	PKOTE-AZURE SOLAR	AZURE SOLAR_66	18:14	18:46	0:31	MAIN SUPPLY FAILURE
1373	29-Apr-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	18:14	18:45	0:31	MAIN SUPPLY FAILURE
1374	29-Apr-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	18:14	18:45	0:31	MAIN SUPPLY FAILURE
1375	29-Apr-22	TUMKUR	66	SIRA- MADHUGIRI 1	BUKKAPATNA_66, KALLAMBELLA_66	1:23	1:31	0:07	LOAD CURTAILMENT
1376	29-Apr-22	TUMKUR	66	SIRA220-PATNAYAKANAHALLI	PATNAYAKANAHALLI	18:13	18:22	0:09	LOAD CURTAILMENT
1377	29-Apr-22	TUMKUR	66	SIRA220-TAVAREKERE	TAVAREKERE_66	1:10	1:26	0:16	LOAD CURTAILMENT
1378	29-Apr-22	TUMKUR	66	THALLAK 220kV-CHALLAKERE-2	CHALLAKERE_66	11:55	12:03	0:07	HAND TRIPPED
1379	29-Apr-22	TUMKUR	66	THALLAK 220kV-GOWRASAMUDRA	CHALLAKERE_66, SANIKERE_66	11:55	12:00	0:05	HAND TRIPPED
1380	29-Apr-22	TUMKUR	66	TR-1	HIRIHALLI_66	10:28	12:26	1:58	MAIN SUPPLY FAILURE
1381	29-Apr-22	TUMKUR	66	TR-1	KUNIGAL_66	9:45	10:26	0:41	TRANSFORMER FAULT
1382	29-Apr-22	TUMKUR	66	TR-1	KUNIGAL_66	11:55	12:50	0:55	LINE CLEAR AVAILED
1383	29-Apr-22	TUMKUR	66	TR-1	PURUVARA_66	10:11	10:24	0:12	TRANSFORMER FAULT
1384	29-Apr-22	TUMKUR	66	TR-1	SHYLAPURA_66	7:14	11:14	3:59	LINE CLEAR AVAILED
1385	29-Apr-22	TUMKUR	66	TR-1	VENKATAPURA_66	7:00	8:02	1:02	LINE CLEAR AVAILED
1386	29-Apr-22	TUMKUR	66	TR-2	HIRIHALLI_66	10:28	12:26	1:58	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1387	29-Apr-22	TUMKUR	66	TR-2	KUNIGAL_66	11:20	12:50	1:30	LINE CLEAR AVAIED
1388	29-Apr-22	TUMKUR	66	TR-2	THALLAK_220	11:54	11:56	0:01	HAND TRIPPED
1389	29-Apr-22	TUMKUR	110	NITTUR 220kV-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	16:39	16:51	0:11	LOAD CURTAILMENT
1390	29-Apr-22	TUMKUR	110	NITTUR 220kV-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	17:44	18:05	0:21	LOAD CURTAILMENT
1391	29-Apr-22	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	15:28	15:35	0:07	LOAD CURTAILMENT
1392	29-Apr-22	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	19:24	19:36	0:12	LOAD CURTAILMENT
1393	29-Apr-22	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	17:44	18:04	0:20	LOAD CURTAILMENT
1394	29-Apr-22	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	19:24	19:33	0:08	LOAD CURTAILMENT
1395	29-Apr-22	TUMKUR	110	NITTUR 220kV-SOMALAPURA	SOMALAPURA_66	18:55(29.4.22)	7:42(30.4.22)	12:40	LINE CHARGED
1396	29-Apr-22	TUMKUR	110	TR-1(LV1)	NITTUR_110	18:56	19:25	0:28	LOAD CURTAILMENT
1397	29-Apr-22	TUMKUR	110	TR-2(LV2)	NITTUR_110	18:56	19:35	0:38	LOAD CURTAILMENT
1398	29-Apr-22	TUMKUR	220	GUTTUR 400-CHITRADURGA 220	CHITRADURGA_220	13:50	14:01	0:10	LINE CLEAR AVAIED
1399	29-Apr-22	TUMKUR	220	THALLAK 220kV-HIREMALLANAHOLE 1	HIREMALLANAHOLE 1	12:00	12:36	0:35	LOAD CURTAILMENT
1400	29-Apr-22	TUMKUR	220	TR-1	NITTUR_220	18:56	19:24	0:27	TRANSFORMER FAULT
1401	29-Apr-22	TUMKUR	220	TR-2	NITTUR_220	18:56	19:29	0:33	TRANSFORMER FAULT
1402	30-Apr-22	BAGALKOT	110	110/11KV, HV1	HALAKI_110	06:00	6:10	0:10	TRANSFORMER FAULT
1403	30-Apr-22	BAGALKOT	110	110/11KV, HV1	KUDALA SANGAM_110	12:15	12:31	0:16	LINE CLEAR AVAIED
1404	30-Apr-22	BAGALKOT	110	110/11KV, HV1	MAREGUDDI_110	14:10	14:25	0:15	LINE CLEAR AVAIED
1405	30-Apr-22	BAGALKOT	110	110/11KV, HV1	MUNDAGNUR_110	05:55	06:05	0:10	TRANSFORMER FAULT
1406	30-Apr-22	BAGALKOT	110	110/11KV, HV1 (HV2)	STATION NOT AFFECTED ZALKI_110	13:37	13:42	0:05	HAND TRIPPED
1407	30-Apr-22	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	13:14 (30.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAIED
1408	30-Apr-22	BAGALKOT	110	110/11KV, HV2	MUKARTHAL_110	12:00	15:02	3:02	LINE CLEAR AVAIED
1409	30-Apr-22	BAGALKOT	110	110/11KV, HV2	SHIROL_110	11:46	11:55	0:09	TRANSFORMER FAULT
1410	30-Apr-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BABALESHWAR_110	18:04 (16.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1411	30-Apr-22	BAGALKOT	110	110/11KV,HV1	TOLAMATTI_110	12:03	12:10	0:07	TRANSFORMER FAULT
1412	30-Apr-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	12:24	12:30	0:06	LINE CLEAR AVAIED
1413	30-Apr-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED LAXMESHWAR_110	17:55 (28.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1414	30-Apr-22	BAGALKOT	110	110/11V,HV2	RANNABELAGALI_110	16:30	18:40	2:10	LINE CLEAR AVAIED
1415	30-Apr-22	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	4:45	4:52	0:07	LINE FAULT
1416	30-Apr-22	BAGALKOT	110	AMBEWADI(SIRSI)-KIRVATTI	KIRUVATTI_110	6:31	18:42	12:11	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1417	30-Apr-22	BAGALKOT	110	ATHANI220- AIGALI	AIGALI_110, KAKAMARI_110, ALBAL_110, YALLAMANAWADI_110, SAVALAGI_110, TODALBAGI_110	00:39	0:51	0:12	LINE FAULT
1418	30-Apr-22	BAGALKOT	110	ATHANI220- AIGALI	AIGALI_110, KAKAMARI_110, ALBAL_110, YALLAMANAWADI_110, SAVALAGI_110, TODALBAGI_110	05:39	5:47	0:08	LINE FAULT
1419	30-Apr-22	BAGALKOT	110	ATHANI220- AIGALI	AIGALI_110, KAKAMARI_110, ALBAL_110, YALLAMANAWADI_110, SAVALAGI_110, TODALBAGI_110	06:15	6:36	0:21	LINE FAULT
1420	30-Apr-22	BAGALKOT	110	BELGAUM220- MACHE	MACHE_110	10:30	11:07	0:37	LINE FAULT
1421	30-Apr-22	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	13:50	14:46	0:56	LINE CLEAR AVAILED
1422	30-Apr-22	BAGALKOT	110	HAVERI- BYADAGI	STATION NOT AFFECTED HAVERI_220	16:41 (29.04.2022)	12:37 (30.04.2022)	19:56	LINE CHARGED
1423	30-Apr-22	BAGALKOT	110	KARWAR220- ARGA(KUMATA)	KARWAR_220	15:47	15:52	0:05	LINE FAULT
1424	30-Apr-22	BAGALKOT	110	KARWAR220- ARGA(KUMATA)	KARWAR_220	20:05	20:10	0:05	LINE FAULT
1425	30-Apr-22	BAGALKOT	110	MAHALINGAPUR-GSML2	STATION NOT AFFECTED MAHALINGAPUR_220	21:42 (24.04.2022)	10:0 (01.05.2022)	156:18:00	LINE CHARGED
1426	30-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1427	30-Apr-22	BAGALKOT	110	SAVANUR-AFB	SAVANUR_110	13:33	13:43	0:10	LINE FAULT
1428	30-Apr-22	BAGALKOT	110	SHIRAHATTI-BPCL2	STATION NOT AFFECTED SHIRAHATTI_110	16:40 (27.04.2022)			LINE OPEN:LINE FAULT
1429	30-Apr-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BELGAUM_220	10:34 (24.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1430	30-Apr-22	BAGALKOT	220	BIDNAL-HUBLI1	BIDNAL_220	10:11	15:48	5:37	LINE CLEAR AVAILED
1431	30-Apr-22	BAGALKOT	220	DHONI- GADAG1	STATION NOT AFFECTED DHONI_400	20:10 (28.04.2022)	14:40 (30.04.2022)	42:30:00	LINE CHARGED
1432	30-Apr-22	BAGALKOT	220	DHONI- GADAG2	DHONI_400	10:57	14:41	3:44	LINE CLEAR AVAILED
1433	30-Apr-22	BAGALKOT	220	GADAG- DHONI2	GADAG_220	10:57	14:41	3:44	LINE CLEAR AVAILED
1434	30-Apr-22	BAGALKOT	220	GADAG- LINGAPUR1(DHONI1)	STATION NOT AFFECTED GADAG_220	20:10 (28.04.2022)	14:39 (30.04.2022)	42:29:00	LINE CHARGED
1435	30-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1436	30-Apr-22	BAGALKOT	220	HUBLI- BIDNAL1	HUBLI_220	10:11	13:34	3:23	NFBC ISSUED
1437	30-Apr-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	16:54 (29.04.2022)	18:06 (01.05.2022)	59 :14 hrs	LINE CHARGED
1438	30-Apr-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	15:33 (22.04.2022)	18:06 (01.05.2022)	225:93 hrs	LINE CHARGED
1439	30-Apr-22	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	23:23	23:39	0:16	LOAD CHANGE OVER
1440	30-Apr-22	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA, ABBIGERE, WELCASTE	22:35	22:48	0:13	LINE FAULT
1441	30-Apr-22	BENGALURU	66	BYDRAHALLI - KODIGEHALLI	KODIGEHALLI, SRIGANDA KAVALU	12:21	13:16	0:55	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1442	30-Apr-22	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	20:52	20:59	0:06	LINE FAULT
1443	30-Apr-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI	14:50	15:01	0:10	LOAD CURTAILMENT
1444	30-Apr-22	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	14:50	15:09	0:19	LOAD CURTAILMENT
1445	30-Apr-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	14:50	15:09	0:18	LOAD CURTAILMENT
1446	30-Apr-22	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	14:50	15:03	0:13	LOAD CURTAILMENT
1447	30-Apr-22	BENGALURU	66	ELECTRONIC CITY P2 S2 - NAGANATHPURA 220	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), HUSKUR	21:59	22:25	0:26	LINE FAULT
1448	30-Apr-22	BENGALURU	66	HV1	ATTIBELE	22:10	22:15	0:05	LOAD CHANGE OVER
1449	30-Apr-22	BENGALURU	66	HV1	MULABAGALU	9:52	10:06	0:13	TRANSFORMER FAULT
1450	30-Apr-22	BENGALURU	66	HV1	PILLAGUMPA	5:35	6:15	0:40	TRANSFORMER FAULT
1451	30-Apr-22	BENGALURU	66	HV1	TK HALLI 220	16:18	16:20	0:02	TRANSFORMER FAULT
1452	30-Apr-22	BENGALURU	66	HV2	CHATRA	12:41	13:08	0:27	LINE CLEAR AVAILED
1453	30-Apr-22	BENGALURU	66	HV2	HUKUNDA	19:25	19:30	0:05	TRANSFORMER FAULT
1454	30-Apr-22	BENGALURU	66	HV2	HUKUNDA	21:27	22:23	0:56	TRANSFORMER FAULT
1455	30-Apr-22	BENGALURU	66	HV2	HUKUNDA	22:25	22:30	0:05	TRANSFORMER FAULT
1456	30-Apr-22	BENGALURU	66	HV2	THAYALUR	12:33	12:50	0:16	TRANSFORMER FAULT
1457	30-Apr-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	8:05	8:09	0:04	LINE FAULT
1458	30-Apr-22	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	20:40	21:25	0:44	LINE FAULT
1459	30-Apr-22	BENGALURU	66	KOLAR 220 - BANGARPET 2	NO STATION AFFECTED	20:40	21:25	0:44	LINE FAULT
1460	30-Apr-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	14:49	14:57	0:08	LOAD CURTAILMENT
1461	30-Apr-22	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	20:34	20:58	0:24	LINE FAULT
1462	30-Apr-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	8:07	8:20	0:12	LINE FAULT
1463	30-Apr-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	20:51	21:42	0:51	LINE FAULT
1464	30-Apr-22	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	21:11	21:41	0:30	LINE FAULT
1465	30-Apr-22	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI, BANGARPETE	20:54	21:39	0:45	LINE FAULT
1466	30-Apr-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADAHOSAHALLI	7:21	7:27	0:06	LINE FAULT
1467	30-Apr-22	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), HUSKUR	21:59	22:25	0:26	LINE FAULT
1468	30-Apr-22	BENGALURU	66	SANKALGERE - CHANNAPATNA 220	SANKALGERE(BAIRPATNA)	21:01	21:28	0:27	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1469	30-Apr-22	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, KODIGEHALI, SRIGANDA KAVALU	12:21	12:43	0:22	LINE FAULT
1470	30-Apr-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	13:28	13:42	0:14	LINE FAULT
1471	30-Apr-22	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	NO STATION AFFECTED	15:37	17:15	1:38	LINE FAULT
1472	30-Apr-22	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	23:29	23:32	0:03	LOAD CHANGE OVER
1473	30-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	22:06	22:46	0:40	LINE FAULT
1474	30-Apr-22	BENGALURU	220	KOLAR 220 - MALUR 3	NO STATION AFFECTED	20:30	21:18	0:48	LINE FAULT
1475	30-Apr-22	GULBARGA	66	HV1	HALAVAGALU_66	18:25(29.04.2022)	9:20(30.04.2022)	14:55:00	TRANSFORMER CHARGED
1476	30-Apr-22	GULBARGA	66	HV1,HV2	HALVAGALU_66	14:50	15:00	0:10	LINE CLEAR AVAILED
1477	30-Apr-22	GULBARGA	66	MUNIRABAD-MHDLIN	VENKATAPUR_66,UPANAYAKANA HALLI_66,HAGARIBOMMANAHALLI_66,RR STEELS_IPP	12:57	14:54	1:57	LINE FAULT
1478	30-Apr-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:06(26/04/2022)			LINE OPEN:LINE CLEAR AVAILED
1479	30-Apr-22	GULBARGA	110	HV1	KURKUNTA_110	0:00	0:15	0:15	TRANSFORMER FAULT
1480	30-Apr-22	GULBARGA	110	HV1,	DEODURGA_110	15:15	15:25	0:10	TRANSFORMER FAULT
1481	30-Apr-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	5:00	5:10	0:10	LINE FAULT
1482	30-Apr-22	GULBARGA	110	MASKI-RNWSLR	MASKI_110	19:07(30.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1483	30-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
1484	30-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	13:55	18:05	4:10	LINE CLEAR AVAILED
1485	30-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1486	30-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1487	30-Apr-22	GULBARGA	400	BPS-PAVAGADA1,2	PAVAGADA_400	11:47(30.4.22)			LINE OPEN:LINE CLEAR AVAILED
1488	30-Apr-22	GULBARGA	400	RTPS-BTPS	RTPS_400	21:19(29.04.2022)	00:21(30.04.2022)	03:02HRS	LINE CHARGED
1489	30-Apr-22	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALY_66	14:20(29.04.2022)	14:40(30.04.2022)	24:20HRS	LINE CHARGED
1490	30-Apr-22	HASSAN	66	DODDAK-KRNAGARA	DODDAKADNUR_66	11:00	11:40	0:40	NFBC ISSUED
1491	30-Apr-22	HASSAN	66	HOLEHA-BNDSTHL	RAMNATHPURA_66	14:25(30.05.202)			LINE OPEN:LINE CLEAR AVAILED
1492	30-Apr-22	HASSAN	66	HV1	HOLALUR_66	17:40	18:20	0:40	TRANSFORMER FAULT
1493	30-Apr-22	HASSAN	66	HV1	HOLEHONNUR_66	13:50	13:55	0:05	TRANSFORMER FAULT
1494	30-Apr-22	HASSAN	66	HV1	SAKALESHPUA_66	10:59(28.04.2022)	16:35(01.05.2022)	53:35HRS	TRANSFORMER CHARGED
1495	30-Apr-22	HASSAN	66	HV2	HALLYMYSORE_66	16:25	16:45	0:20	LINE CLEAR AVAILED
1496	30-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1497	30-Apr-22	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	10:07	10:12	0:05	HAND TRIPPED
1498	30-Apr-22	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	10:44	10:47	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1499	30-Apr-22	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	10:50	10:55	0:05	HAND TRIPPED
1500	30-Apr-22	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	15:23	15:24	0:01	HAND TRIPPED
1501	30-Apr-22	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	13:00	20:21	7:21	HAND TRIPPED
1502	30-Apr-22	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	12:30	12:40	0:10	HAND TRIPPED
1503	30-Apr-22	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	16:07	16:16	0:09	HAND TRIPPED
1504	30-Apr-22	HASSAN	110	HV1	JOG_110	11:10	12:10	1:00	LINE CLEAR AVAILED
1505	30-Apr-22	HASSAN	110	HV1	KONAJE_110	22:34	22:40	0:06	HAND TRIPPED
1506	30-Apr-22	HASSAN	110	HV1	KULASHEKARA_110	11:52	12:01	0:09	TRANSFORMER FAULT
1507	30-Apr-22	HASSAN	110	HV1	KULASHEKARA_110	11:52	12:01	0:09	TRANSFORMER FAULT
1508	30-Apr-22	HASSAN	110	HV2	BAIKAMPADY_110	9:08	15:08	6:00	LINE CLEAR AVAILED
1509	30-Apr-22	HASSAN	110	HV2	JOG_110	9:30	12:25	2:55	LINE CLEAR AVAILED
1510	30-Apr-22	HASSAN	110	HV2	KONAJE_110	22:34	22:38	0:04	HAND TRIPPED
1511	30-Apr-22	HASSAN	110	HV2	KONAJE_110	12:57	13:02	0:05	HAND TRIPPED
1512	30-Apr-22	HASSAN	110	HV2	KULASHEKARA_110	11:52	12:01	0:09	TRANSFORMER FAULT
1513	30-Apr-22	HASSAN	110	HV3	GURUVAYANKERE_110	9:50	13:55	4:05	LINE CLEAR AVAILED
1514	30-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
1515	30-Apr-22	HASSAN	110	HV3	KULASHEKARA_110	11:52	12:01	0:09	TRANSFORMER FAULT
1516	30-Apr-22	HASSAN	110	HV4	KULASHEKARA_110	11:52	12:01	0:09	TRANSFORMER FAULT
1517	30-Apr-22	HASSAN	110	HV4	KULASHEKARA_110	11:52	12:01	0:09	TRANSFORMER FAULT
1518	30-Apr-22	HASSAN	110	HV5	KAVOOR_220	8:45 (26.04.2022)			TRANSFORME OPEN:LINE CLEAR AVAILED
1519	30-Apr-22	HASSAN	110	JOG110-NERELEKERE	KADUR_220	11:25	11:30	0:05	HAND TRIPPED
1520	30-Apr-22	HASSAN	110	JOG-JLT4	gen_mghe	21:28(28.04.2022)	13:38(30.05.2022)	16:13HRS	LINE CHARGED
1521	30-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1522	30-Apr-22	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	19:55	20:08	0:13	HAND TRIPPED
1523	30-Apr-22	HASSAN	110	KULASH-KERKNJ	KULASHEKARA_110	11:52	12:01	0:09	LINE FAULT
1524	30-Apr-22	HASSAN	110	KUSHAL-KAVOOR 1	KULASHEKARA_110	11:52	12:01	0:09	LINE FAULT
1525	30-Apr-22	HASSAN	110	LPH-MGHE 2	gen_lph	21:28(28.04.2022)	13:40(30.04.2022)	16:15HRS	LINE CHARGED
1526	30-Apr-22	HASSAN	110	LV1	KAVOOR_220	10:31	12:25	1:54	LINE CLEAR AVAILED
1527	30-Apr-22	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	15:40	16:10	0:30	LINE CLEAR AVAILED
1528	30-Apr-22	HASSAN	220	GOPALA-BASTIPURA	GOPALAPURA_220	16:54	18:57	2:03	LINE CLEAR AVAILED
1529	30-Apr-22	HASSAN	220	HV1	KAVOOR_220	10:31	12:25	1:54	LINE CLEAR AVAILED
1530	30-Apr-22	HASSAN	220	HV3	KAVOOR_220	19:55(30.05.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
1531	30-Apr-22	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	11:18	12:42	1:24	LINE CLEAR AVAILED
1532	30-Apr-22	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	16:52(28.04.2022)			LINE OPEN:LINE FAULT
1533	30-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1534	30-Apr-22	MYSURU	66	AKKIHEBBAL-KR PETE 2	NO STATIONS EFFECTED	12:22	12:26	0:04	LINE FAULT
1535	30-Apr-22	MYSURU	66	BEGUR 66-B MATTGERE	NO STATIONS EFFECTED	7:41:00 PM (29.04.2022)			LINE OPEN:LINE FAULT
1536	30-Apr-22	MYSURU	66	BESAGARAHALLI-DUNDANAHALLY	DUNDANAHALLI_66	8:19	8:33	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1537	30-Apr-22	MYSURU	66	BOGADHI-HOOTAGALLI	NO STATIONS EFFECTED	23:18 (30.4.22)			LINE OPEN:LINE CLEAR AVAILED
1538	30-Apr-22	MYSURU	66	DR PETE-KUNTHUR	NO STATIONS EFFECTED	21:02	21:13	0:11	LINE FAULT
1539	30-Apr-22	MYSURU	66	DR PETE-KUNTHUR	NO STATIONS EFFECTED	21:13	22:22	1:08	LINE FAULT
1540	30-Apr-22	MYSURU	66	DUNDANAHALLY-HULIYURDURGA	NO STATIONS EFFECTED	8:36 (30.4.22)			LINE OPEN:LINE CLEAR AVAILED
1541	30-Apr-22	MYSURU	66	ELAVALA-HUNSUR	GAVADAGERE_66, HUNSUR_66	22:50	23:00	0:10	LINE FAULT
1542	30-Apr-22	MYSURU	66	ELAVALA-HUNSUR	GAVADAGERE_66, HUNSUR_66	23:10	23:25	0:15	LINE FAULT
1543	30-Apr-22	MYSURU	66	HANNUR-KOTHANURU	NO STATIONS EFFECTED	21:02	21:07	0:05	LINE FAULT
1544	30-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN:LINE CLEAR AVAILED
1545	30-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22.04.2022)			LINE OPEN:LINE CLEAR AVAILED
1546	30-Apr-22	MYSURU	66	HUNSUR-BANNIKUPPE	NO STATIONS EFFECTED	22:49 (30.4.22)			LINE OPEN:LINE FAULT
1547	30-Apr-22	MYSURU	66	HV1	GUNDULPET_66	22:42	23:06	0:24	TRANSFORMER FAULT
1548	30-Apr-22	MYSURU	66	HV1	KMDODDI_66	13:26	13:41	0:15	MAIN SUPPLY FAILURE
1549	30-Apr-22	MYSURU	66	HV1	TERAKANAMBE_66	10:37	15:27	4:50	LINE CLEAR AVAILED
1550	30-Apr-22	MYSURU	66	HV2	BANNIMANTAP_66	13:41	14:27	0:45	LINE CLEAR AVAILED
1551	30-Apr-22	MYSURU	66	HV2	BETTADHAPURA_66	4:15	4:57	0:42	LINE CLEAR AVAILED
1552	30-Apr-22	MYSURU	66	HV2	KADAKOLA_220	12:29	13:03	0:34	LINE CLEAR AVAILED
1553	30-Apr-22	MYSURU	66	HV2	KMDODDI_66	13:26	13:41	0:15	MAIN SUPPLY FAILURE
1554	30-Apr-22	MYSURU	66	K HONNALAGERE-MADDUR	MADDUR_66, SOMANAHALLI_66	13:42	13:49	0:07	HAND TRIPPED
1555	30-Apr-22	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66, SUTTUR_66	22:36 (30.4.22)			LINE OPEN:LINE FAULT
1556	30-Apr-22	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66, SOMANAHALLI_66, K_HONNALGERE_66	13:39	14:06	0:27	MAIN SUPPLY FAILURE
1557	30-Apr-22	MYSURU	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66	13:26	16:22	2:56	LINE FAULT
1558	30-Apr-22	MYSURU	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	13:39	14:12	0:33	MAIN SUPPLY FAILURE
1559	30-Apr-22	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66	13:37	16:20	2:43	NFBC ISSUED
1560	30-Apr-22	MYSURU	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66, PARINAMIPURA_66 , THALAKADU_66	18:26	18:31	0:05	LINE FAULT
1561	30-Apr-22	MYSURU	66	KR NAGARA-BHERYA	BHERYA_66	19:00	19:10	0:10	LINE FAULT
1562	30-Apr-22	MYSURU	66	KR NAGARA-BILIKERE	BILIKERE_66 DMG_HALLI_66 GVGUDI_66	22:40	22:59	0:18	LINE FAULT
1563	30-Apr-22	MYSURU	66	KUNTHUR-DR PETE	NO STATIONS EFFECTED	5:25	5:30	0:05	LINE FAULT
1564	30-Apr-22	MYSURU	66	KUSHALANAGARA 220-MYSORE 1	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66 BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	3:56	4:11	0:15	LINE FAULT
1565	30-Apr-22	MYSURU	66	MANDYA-KK HALLI	KADKOTHANAHALLI_66	21:24	22:10	0:45	LINE FAULT
1566	30-Apr-22	MYSURU	66	MANDYA-KK HALLI	KADKOTHANAHALLI_66	22:10	22:19	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1567	30-Apr-22	MYSURU	66	MANDYA-KK HALLI	KADKOTHANAHALLI_66	22:19 (30.4.22)			LINE OPEN:LINE FAULT
1568	30-Apr-22	MYSURU	66	PERIYAPATNA-HANAGODU	PONNAMPET_66, VIRAJPET_66	23:29	23:47	0:17	LINE FAULT
1569	30-Apr-22	MYSURU	66	SANTHE SARAGURU-MARUTI	NO STATIONS EFFECTED	10:39	10:54	0:14	LINE FAULT
1570	30-Apr-22	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	20:10	20:44	0:33	LINE FAULT
1571	30-Apr-22	MYSURU	66	SFCSIVA-5 MW	NO STATIONS EFFECTED	9:00:00 PM (29.04.2022)			LINE OPEN:LINE FAULT
1572	30-Apr-22	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	20:36	20:45	0:09	LINE FAULT
1573	30-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1574	30-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN:LINE CLEAR AVAILED
1575	30-Apr-22	MYSURU	220	MADHUVANAHALLI-HEBBANI 2	NO STATIONS EFFECTED	20:08	20:40	0:31	LINE FAULT
1576	30-Apr-22	TUMKUR	66	ANCHEPALYA 220kv-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	7:06	8:00	0:54	LINE FAULT
1577	30-Apr-22	TUMKUR	66	ANCHEPALYA 220kv-KORA	KORA_66	6:15	6:45	0:30	LINE FAULT
1578	30-Apr-22	TUMKUR	66	ANCHEPALYA 220kv-YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	10:07	11:45	1:38	LINE CLEAR AVAILED
1579	30-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	18:33	19:06	0:33	LINE FAULT
1580	30-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	19:19	19:50	0:31	LINE FAULT
1581	30-Apr-22	TUMKUR	66	MADHUGIRI 220kv-PULLAMAGATTA	PULLAMGATTA_66	1:49	2:06	0:17	LINE FAULT
1582	30-Apr-22	TUMKUR	66	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	6:34	19:15	12:40	LINE CLEAR AVAILED
1583	30-Apr-22	TUMKUR	66	PAVAGADA 220kv-SHYLAPURA	SHYLAPURA_66	5:55	6:00	0:05	LINE FAULT
1584	30-Apr-22	TUMKUR	66	PDKOTE-AZURE SOLAR	AZURE SOLAR_66	12:25	14:45	2:20	MAIN SUPPLY FAILURE
1585	30-Apr-22	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	12:00	12:25	0:25	LINE FAULT
1586	30-Apr-22	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	12:25	14:46	2:21	MAIN SUPPLY FAILURE
1587	30-Apr-22	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	12:20	14:46	2:26	MAIN SUPPLY FAILURE
1588	30-Apr-22	TUMKUR	66	TR-1	JIDDIGERE_66	10:20	11:45	1:25	LINE CLEAR AVAILED
1589	30-Apr-22	TUMKUR	66	TR-1	THALLAK_220	9:02	9:08	0:06	LINE CLEAR AVAILED
1590	30-Apr-22	TUMKUR	66	TR-2	JIDDIGERE_66	10:20	11:45	1:25	LINE CLEAR AVAILED
1591	30-Apr-22	TUMKUR	66	TR-2	SANEKERE_66	19:15	19:43	0:28	TRANSFORMER FAULT
1592	30-Apr-22	TUMKUR	66	TR-2	THALLAK_220	9:02	9:08	0:06	LINE CLEAR AVAILED
1593	30-Apr-22	TUMKUR	66	TR-3	THALLAK_220	9:02	9:08	0:06	LINE CLEAR AVAILED
1594	30-Apr-22	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110,SAMPIGE_110	19:20	20:15	0:55	MAIN SUPPLY FAILURE
1595	30-Apr-22	TUMKUR	110	TR-1	NITTUR_110	9:45	10:25	0:40	TRANSFORMER FAULT
1596	30-Apr-22	TUMKUR	220	TR-1, TR-2 & TR-3	ANTHRASANAHALLI_220	13:38	13:39	0:01	TRANSFORMER FAULT
1597	30-Apr-22	TUMKUR	220	TR-2	ANCHEPALYA	7:46	8:50	1:04	LINE CLEAR AVAILED
1598	30-Apr-22	TUMKUR	220	TR-2	PAVAGADA_220	5:55	6:00	0:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1599	1-May-22	BENGALURU	66	ADUGODI - HSR LAYOUT 2	ADUGODI	8:24	8:30	0:06	LOAD CHANGE OVER
1600	1-May-22	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	17:31	17:46	0:15	MAIN SUPPLY FAILURE
1601	1-May-22	BENGALURU	66	BOMMASANDRA - YARANDANAHALLI 220 1	BOMMASANDRA	10:15	10:20	0:05	LOAD CHANGE OVER
1602	1-May-22	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI	10:10	10:32	0:22	MAIN SUPPLY FAILURE
1603	1-May-22	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI	16:30	16:35	0:05	LOAD CHANGE OVER
1604	1-May-22	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI	17:32	17:48	0:16	LOAD CHANGE OVER
1605	1-May-22	BENGALURU	66	DEVARABISANAHALLI - VIKAS TECH PARK 220	DEVARABISANAHALLI	18:02	18:10	0:08	MAIN SUPPLY FAILURE
1606	1-May-22	BENGALURU	66	ELECTRONIC CITY - ELETRONIC CITY P2 S1	ELECTRONIC CITY	10:39	10:50	0:11	LOAD CHANGE OVER
1607	1-May-22	BENGALURU	66	ELECTRONIC CITY P2 S2 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S2,BIOCON(EHT), TECH MAHINDRA(EHT), HUSKUR	1:35	1:50	0:15	LOAD CHANGE OVER
1608	1-May-22	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGANATHPURA 220	ELECTRONIC CITY P2 S1	10:42	10:49	0:07	LOAD CHANGE OVER
1609	1-May-22	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	15:14	15:24	0:10	LOAD CHANGE OVER
1610	1-May-22	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	NO STATION AFFECTED	14:57	15:08	0:11	LINE FAULT
1611	1-May-22	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	NO STATION AFFECTED	15:08	15:59	0:51	LINE FAULT
1612	1-May-22	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	NO STATION AFFECTED	15:59	20:52	4:53	LINE CLEAR AVAILED
1613	1-May-22	BENGALURU	66	GLOBAL TECH PARK - HSR LAYOUT 220	GLOBAL TECH PARK	10:09	10:33	0:24	MAIN SUPPLY FAILURE
1614	1-May-22	BENGALURU	66	GLOBAL TECH PARK - HSR LAYOUT 220	GLOBAL TECH PARK	14:57	15:32	0:35	MAIN SUPPLY FAILURE
1615	1-May-22	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	NO STATION AFFECTED	14:39	15:49	1:10	LINE FAULT
1616	1-May-22	BENGALURU	66	K&C VALLEY - NAL(EHT)	NAL(EHT)	12:25	13:05	0:40	LINE FAULT
1617	1-May-22	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	10:09	10:32	0:23	LOAD CHANGE OVER
1618	1-May-22	BENGALURU	66	HULIMANGALA - NAGANATHPURA 220	HULIMANGALA	10:38	10:50	0:12	LOAD CHANGE OVER
1619	1-May-22	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	16:35	18:13	1:38	LINE FAULT
1620	1-May-22	BENGALURU	66	JAYADEVA - SARAKKI 1	NO STATION AFFECTED	8:25	10:39	2:14	LINE FAULT
1621	1-May-22	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	7:42	7:44	0:02	LOAD CHANGE OVER
1622	1-May-22	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	14:57	16:12	1:15	MAIN SUPPLY FAILURE
1623	1-May-22	BENGALURU	66	HV2	KADUGODI	18:23	18:29	0:06	TRANSFORMER FAULT
1624	1-May-22	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	15:29	16:44	1:15	LINE FAULT
1625	1-May-22	BENGALURU	66	HV2	CESSNA	16:20	16:50	0:30	TRANSFORMER FAULT
1626	1-May-22	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU	9:15	17:30	8:15	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1627	1-May-22	BENGALURU	66	HV1	KUMBALAGODU	17:52	17:55	0:03	LINE CLEAR AVAILED
1628	1-May-22	BENGALURU	220	MANYATHA TECH PARK 220 - ITI 220	NO STATION AFFECTED	16:14	17:21	1:07	LINE FAULT
1629	1-May-22	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	14:42	14:46	0:04	LOAD CHANGE OVER
1630	1-May-22	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	15:51	15:55	0:04	LOAD CHANGE OVER
1631	1-May-22	BENGALURU	220	NAGANATHPURA 220 - HSR LAYOUT 220	NAGANATHPURA 220	14:40	15:34	0:54	MAIN SUPPLY FAILURE
1632	1-May-22	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA, HUSKUR	14:40	16:30	1:50	LINE CLEAR AVAILED
1633	1-May-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	13:41	13:49	0:08	LOAD CHANGE OVER
1634	1-May-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	15:50	15:55	0:05	LOAD CHANGE OVER
1635	1-May-22	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE	8:25	8:31	0:06	LINE FAULT
1636	1-May-22	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	15:15	15:25	0:10	MAIN SUPPLY FAILURE
1637	1-May-22	BENGALURU	66	HV2	REMCO	7:32	7:37	0:05	LOAD CHANGE OVER
1638	1-May-22	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	13:45	13:47	0:02	LOAD CHANGE OVER
1639	1-May-22	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	15:57	16:02	0:05	LOAD CHANGE OVER
1640	1-May-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	10:10	10:35	0:25	MAIN SUPPLY FAILURE
1641	1-May-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	14:58	15:32	0:34	MAIN SUPPLY FAILURE
1642	1-May-22	BENGALURU	66	BRIGADE MEADOWS - SHOBHA FOREST	SHOBHA FOREST	18:05	18:20	0:15	LINE FAULT
1643	1-May-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY	15:17	15:25	0:08	LINE FAULT
1644	1-May-22	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD, KIRLOSKAR(EHT)	15:17	15:48	0:31	LINE FAULT
1645	1-May-22	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	15:17	15:26	0:09	MAIN SUPPLY FAILURE
1646	1-May-22	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 220 2	NO STATION AFFECTED	11:48	15:40	3:52	LINE FAULT
1647	1-May-22	BENGALURU	66	ST JOHN WOOD - HSR LAYOUT 220	ST JOHN WOOD	10:09	10:30	0:21	MAIN SUPPLY FAILURE
1648	1-May-22	BENGALURU	66	ST JOHN WOOD - HSR LAYOUT 220	ST JOHN WOOD	14:57	15:15	0:18	MAIN SUPPLY FAILURE
1649	1-May-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	17:31	17:46	0:15	LINE FAULT
1650	1-May-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:40	17:24	0:44	LINE FAULT
1651	1-May-22	BENGALURU	66	HV1	TK HALLI 220	22:30	22:33	0:03	TRANSFORMER FAULT
1652	1-May-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	11:01	12:50	1:49	LINE FAULT
1653	1-May-22	BENGALURU	66	VR DODDI - ORCHID LAMINATE 2	VR DODDI	17:14	17:45	0:31	MAIN SUPPLY FAILURE
1654	1-May-22	BENGALURU	220	HV2	YARANDANAHALLI 220	6:15	6:38	0:23	LOAD CHANGE OVER
1655	1-May-22	BENGALURU	220	HV3	YARANDANAHALLI 220	6:15	6:38	0:23	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1656	1-May-22	BENGALURU	220	YARANDANAHALLI 220 - JIGANI 220	JIGANI 220	6:12	6:36	0:24	LOAD CHANGE OVER
1657	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	6:00	6:38	0:38	LOAD CHANGE OVER
1658	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	6:00	6:45	0:45	LOAD CHANGE OVER
1659	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	6:00	6:38	0:38	LOAD CHANGE OVER
1660	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	6:00	6:45	0:45	LOAD CHANGE OVER
1661	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 66	7:00	7:06	0:06	LOAD CHANGE OVER
1662	1-May-22	BENGALURU	66	HV1	YARANDANAHALLI 220	6:00	7:12	1:12	LOAD CHANGE OVER
1663	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	9:40	10:10	0:30	LOAD CHANGE OVER
1664	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	9:40	10:10	0:30	LOAD CHANGE OVER
1665	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	9:40	10:10	0:30	LOAD CHANGE OVER
1666	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	9:40	10:10	0:30	LOAD CHANGE OVER
1667	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 66	9:40	10:10	0:30	LOAD CHANGE OVER
1668	1-May-22	BENGALURU	66	HV1	YARANDANAHALLI 220	9:40	10:10	0:30	LOAD CHANGE OVER
1669	1-May-22	BENGALURU	66	HV2	YARANDANAHALLI 220	9:40	10:10	0:30	LOAD CHANGE OVER
1670	1-May-22	BENGALURU	66	HV3	YARANDANAHALLI 220	9:40	10:10	0:30	LOAD CHANGE OVER
1671	1-May-22	BENGALURU	220	YARANDANAHALLI 220 - JIGANI 220	JIGANI 220	12:12	12:14	0:02	LOAD CHANGE OVER
1672	1-May-22	BENGALURU	220	YARANDANAHALLI 220 - HOUSR 220	YARANDANAHALLI 220	21:14	22:09	0:55	LINE FAULT
1673	1-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	21:14	22:12	0:58	LINE CLEAR AVAILED
1674	1-May-22	BENGALURU	66	HV1	ANDERSONPETE	15:10	15:50	0:40	TRANSFORMER FAULT
1675	1-May-22	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	14:45	15:54	1:09	MAIN SUPPLY FAILURE
1676	1-May-22	BENGALURU	66	CHIKKABALLAPURA IND AREA - NALLIMARADANAHALLI	NALLIMARADANAHALLI	16:37	16:46	0:09	LINE FAULT
1677	1-May-22	BENGALURU	66	HV2	DODDABELAVANGALA	17:23	17:30	0:07	TRANSFORMER FAULT
1678	1-May-22	BENGALURU	66	HV2	HUKUNDA	9:15	9:20	0:05	TRANSFORMER FAULT
1679	1-May-22	BENGALURU	66	HV2	HUKUNDA	10:05	10:10	0:05	TRANSFORMER FAULT
1680	1-May-22	BENGALURU	66	HV1	HUKUNDA	15:55	16:00	0:05	TRANSFORMER FAULT
1681	1-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	14:13	15:06	0:53	LINE FAULT
1682	1-May-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	17:58	18:17	0:19	LINE FAULT
1683	1-May-22	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 220 1	NO STATION AFFECTED	11:44	11:55	0:11	LINE FAULT
1684	1-May-22	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 220 1	NO STATION AFFECTED	13:21	13:23	0:02	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1685	1-May-22	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 220 2	NO STATION AFFECTED	11:44	13:21	1:37	LINE FAULT
1686	1-May-22	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 220 2	NO STATION AFFECTED	13:21	15:40	2:19	LINE FAULT
1687	1-May-22	BENGALURU	66	SOMAYAJANAHALLI - TATA SOLAR(EHT)	TATA SOLAR(EHT)	17:10	17:35	0:25	LINE FAULT
1688	1-May-22	BENGALURU	66	SOMAYAJANAHALLI - TATA SOLAR(EHT)	TATA SOLAR(EHT)	18:50	19:40	0:50	LINE FAULT
1689	1-May-22	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	18:10	18:35	0:25	LINE FAULT
1690	1-May-22	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	16:40	16:45	0:05	LINE CLEAR AVAILED
1691	1-May-22	BENGALURU	66	ANEKAL - YERANDANAHALLI 220	ANEKAL	18:27	19:11	0:43	LINE FAULT
1692	1-May-22	BENGALURU	66	BANGARPETE - MALUR 220	BANGARPET	9:00	9:15	0:15	LOAD CHANGE OVER
1693	1-May-22	BENGALURU	66	BANGARPETE - KOLAR 220	BANGARPET	13:00	13:10	0:10	LOAD CHANGE OVER
1694	1-May-22	BENGALURU	66	SANKALGERE - CHANNAPATNA 220	SANKALGERE(BAIRPATNA)	15:30	16:45	1:15	MAIN SUPPLY FAILURE
1695	1-May-22	BENGALURU	66	TADIGOL CROSS - LAKSHMIPURA	LAKHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	17:10	17:35	0:25	LINE FAULT
1696	1-May-22	BENGALURU	66	TADIGOL CROSS - LAKSHMIPURA	LAKHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	18:50	19:30	0:40	LINE FAULT
1697	1-May-22	BENGALURU	66	T G HALLI - MAGADI 220	V G DODDI, T G HALLI, TAVARAKERE	14:10	15:20	1:10	LINE FAULT
1698	1-May-22	BENGALURU	66	T G HALLI - TAVARAKERE	V G DODDI, TAVARAKERE	14:10	15:21	1:11	LINE FAULT
1699	1-May-22	BENGALURU	66	HV2	LAKSMIPURA	19:50	19:55	0:05	LINE CLEAR AVAILED
1700	1-May-22	BENGALURU	66	HV1	LAKSMIPURA	19:50	19:55	0:05	LINE CLEAR AVAILED
1701	1-May-22	BENGALURU	66	HV1	BANGARPET	15:15	15:23	0:08	TRANSFORMER FAULT
1702	1-May-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	NO STATION AFFECTED	14:44	16:12	1:28	LINE FAULT
1703	1-May-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	14:10	14:44	0:33	LINE FAULT
1704	1-May-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	14:44	15:14	0:29	LINE FAULT
1705	1-May-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	14:00	14:10	0:10	LINE FAULT
1706	1-May-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	14:13	14:20	0:07	LINE FAULT
1707	1-May-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	17:07	17:46	0:38	LINE FAULT
1708	1-May-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	14:35	14:46	0:11	LINE FAULT
1709	1-May-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:34	6:48	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1710	1-May-22	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	18:20	18:31	0:11	LINE FAULT
1711	1-May-22	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	18:48	18:54	0:06	LINE FAULT
1712	1-May-22	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	15:40	16:31	0:51	LINE FAULT
1713	1-May-22	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	18:19	18:48	0:28	LINE FAULT
1714	1-May-22	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	22:23	22:39	0:15	LINE FAULT
1715	1-May-22	BENGALURU	66	SANKALGERE(BAIRPATNA) - ADANSUN SOLAR(IPP)	NO STATION AFFECTED	16:51	17:00	0:09	LINE FAULT
1716	1-May-22	BENGALURU	66	HV1	PERESANDRA	7:15	7:20	0:05	LINE CLEAR AVAILED
1717	2-May-22	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	13:32	13:40	0:08	LOAD CHANGE OVER
1718	2-May-22	BENGALURU	66	HV2	APPAREL PARK	17:03	17:05	0:02	TRANSFORMER FAULT
1719	2-May-22	BENGALURU	66	HV2	APPAREL PARK	17:47	17:54	0:07	TRANSFORMER FAULT
1720	2-May-22	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	17:48	17:50	0:02	LOAD CHANGE OVER
1721	2-May-22	BENGALURU	66	HV1	BANASAWADI	16:04	16:17	0:13	LOAD CHANGE OVER
1722	2-May-22	BENGALURU	66	HV3	BANASAWADI	16:04	16:17	0:13	LOAD CHANGE OVER
1723	2-May-22	BENGALURU	66	HV1	BIDADI 220	10:44	11:10	0:26	TRANSFORMER FAULT
1724	2-May-22	BENGALURU	66	HV1	BIDADI 220	16:01	16:12	0:11	TRANSFORMER FAULT
1725	2-May-22	BENGALURU	66	HV1	BIDADI 220	20:50	20:59	0:09	TRANSFORMER FAULT
1726	2-May-22	BENGALURU	220	HV2	BIDADI 220	16:01	16:11	0:10	TRANSFORMER FAULT
1727	2-May-22	BENGALURU	220	HV2	BIDADI 220	20:37	20:57	0:20	TRANSFORMER FAULT
1728	2-May-22	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	16:01	16:18	0:17	LINE CLEAR AVAILED
1729	2-May-22	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	20:37	20:59	0:22	LINE CLEAR AVAILED
1730	2-May-22	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI	8:10	8:16	0:06	MAIN SUPPLY FAILURE
1731	2-May-22	BENGALURU	66	DEVARABISANAHALLI - VIKAS TECH PARK 220	DEVARABISANAHALLI	12:09	12:14	0:05	LOAD CHANGE OVER
1732	2-May-22	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY	17:33	17:41	0:08	LOAD CHANGE OVER
1733	2-May-22	BENGALURU	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK	6:49	6:52	0:03	LOAD CHANGE OVER
1734	2-May-22	BENGALURU	66	GLOBAL TECH PARK - HSR LAYOUT 220	GLOBAL TECH PARK	8:11	8:18	0:07	MAIN SUPPLY FAILURE
1735	2-May-22	BENGALURU	66	GLOBAL TECH PARK - HSR LAYOUT 220	GLOBAL TECH PARK	8:49	8:54	0:05	MAIN SUPPLY FAILURE
1736	2-May-22	BENGALURU	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK	12:15	12:23	0:08	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1737	2-May-22	BENGALURU	66	HULIMANGALA - YARANDANAHALLI 220	HULIMANGALA	8:32	9:05	0:33	MAIN SUPPLY FAILURE
1738	2-May-22	BENGALURU	66	HULIMANGALA - YARANDANAHALLI 220	HULIMANGALA	16:33	16:42	0:09	LOAD CHANGE OVER
1739	2-May-22	BENGALURU	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	12:12	12:16	0:04	LOAD CHANGE OVER
1740	2-May-22	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	15:38	15:52	0:14	LINE FAULT
1741	2-May-22	BENGALURU	66	POTTER ROAD - HEBBALA 220	POTTERY ROAD	16:15	16:19	0:04	LOAD CHANGE OVER
1742	2-May-22	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	15:39	15:44	0:05	LOAD CHANGE OVER
1743	2-May-22	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	8:36	8:39	0:03	LOAD CHANGE OVER
1744	2-May-22	BENGALURU	66	HV2	KADUGODI	0:12	0:15	0:03	LOAD CHANGE OVER
1745	2-May-22	BENGALURU	66	HV2	KUMBALAGODU	8:24	8:29	0:05	LINE CLEAR AVAILED
1746	2-May-22	BENGALURU	66	HV1	RR NAGAR	11:13	11:17	0:04	TRANSFORMER FAULT
1747	2-May-22	BENGALURU	66	HV1	RR NAGAR	10:28	11:05	0:37	TRANSFORMER FAULT
1748	2-May-22	BENGALURU	66	HV2	RR NAGAR	10:28	11:18	0:50	TRANSFORMER FAULT
1749	2-May-22	BENGALURU	66	HV1	RR NAGAR	11:05	11:12	0:07	TRANSFORMER FAULT
1750	2-May-22	BENGALURU	66	HV1	RR NAGAR	11:30	11:40	0:10	TRANSFORMER FAULT
1751	2-May-22	BENGALURU	66	HV2	RR NAGAR	11:30	11:34	0:04	TRANSFORMER FAULT
1752	2-May-22	BENGALURU	66	RBI - KHODAYS 220	RBI	5:48	5:54	0:06	LOAD CHANGE OVER
1753	2-May-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	6:54	7:02	0:08	MAIN SUPPLY FAILURE
1754	2-May-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	8:12	8:22	0:10	MAIN SUPPLY FAILURE
1755	2-May-22	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	6:20	6:27	0:07	LOAD CHANGE OVER
1756	2-May-22	BENGALURU	66	ST JOHN WOOD - ADUGODI	ST JOHN WOOD	12:35	12:40	0:05	LOAD CHANGE OVER
1757	2-May-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:20	18:29	0:09	LINE FAULT
1758	2-May-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	19:00	19:21	0:21	LINE FAULT
1759	2-May-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:29	20:30	1:01	LINE FAULT
1760	2-May-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	20:30	22:10	1:40	LINE FAULT
1761	2-May-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	22:10	23:05	0:55	LINE CLEAR AVAILED
1762	2-May-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	23:54	23:59	0:05	LINE CLEAR AVAILED
1763	2-May-22	BENGALURU	66	HV1	TK HALLI 220	15:13	15:20	0:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1764	2-May-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	8:32	9:02	0:30	LINE FAULT
1765	2-May-22	BENGALURU	66	HV2	YARANDANAHALLI 220	14:01	14:05	0:04	TRANSFORMER FAULT
1766	2-May-22	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	8:00	8:10	0:10	LOAD CHANGE OVER
1767	2-May-22	BENGALURU	66	HAROBEL - KANAKAPURA 220	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBEL, BIJJALALLI	23:17	23:27	0:10	LINE FAULT
1768	2-May-22	BENGALURU	66	HAROBEL - KANAKAPURA 220	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBEL, BIJJALALLI	23:28	23:48	0:20	LINE FAULT
1769	2-May-22	BENGALURU	66	HV2	MAASTHI	7:32	9:01	1:29	LINE CLEAR AVAILED
1770	2-May-22	BENGALURU	220	HV2	DB PURA 220	15:15	16:59	1:44	LINE CLEAR AVAILED
1771	2-May-22	BENGALURU	66	HV1	GOWRIBIDANUR 220	15:19	15:25	0:06	TRANSFORMER FAULT
1772	2-May-22	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:12	6:22	0:09	LINE FAULT
1773	2-May-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	15:10	15:19	0:08	LOAD CHANGE OVER
1774	2-May-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	17:01	17:09	0:08	LOAD CHANGE OVER
1775	2-May-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	15:11	15:19	0:08	LOAD CHANGE OVER
1776	2-May-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	17:01	17:09	0:07	LOAD CHANGE OVER
1777	2-May-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:11	15:19	0:08	LOAD CHANGE OVER
1778	2-May-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	17:01	17:09	0:07	LOAD CHANGE OVER
1779	2-May-22	BENGALURU	66	ANEKAL - ATTIBELE	NO STATION AFFECTED	9:50	10:37	0:47	LINE CLEAR AVAILED
1780	2-May-22	BENGALURU	66	ANEKAL - ATTIBELE	NO STATION AFFECTED	12:39	17:15	4:36	LINE CLEAR AVAILED