

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM: 04.05.2021 TO 10.05.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	4-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVALIED
2	4-May-2021	BAGALKOT	110	110/11KV, HV1	HOSAHONNATTI_110	21:37	21:53	0:16	TRANSFORMER FAULT
3	4-May-2021	BAGALKOT	110	110/11KV, HV1	GUTTAL_110	20:12	23:05	2:53	TRANSFORMER FAULT
4	4-May-2021	BAGALKOT	110	110/11KV, HV1	GULEDAGUDDA_110	21:19	22:00	0:41	TRANSFORMER FAULT
5	4-May-2021	BAGALKOT	110	110/11KV, HV2	SIRSI_110	13:23	13:52	0:29	LINE CLEAR AVALIED
6	4-May-2021	BAGALKOT	110	110/11KV, HV2	SHIROL_110	4:51	4:55	0:04	TRANSFORMER FAULT
7	4-May-2021	BAGALKOT	110	110/11KV, HV2	SHIROL_110	6:33	6:35	0:02	TRANSFORMER FAULT
8	4-May-2021	BAGALKOT	110	110/11KV,HV1	AKSHAY COLONY_110	15:34	17:30	1:56	TRANSFORMER FAULT
9	4-May-2021	BAGALKOT	110	110/11KV,HV1	AREMALLAPUR_110	10:21	10:45	0:24	HAND TRIPPED
10	4-May-2021	BAGALKOT	110	110/11KV,HV2	AIGALI_110	10:14	10:30	0:16	TRANSFORMER FAULT
11	4-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19(20.04.2021)			LINE OPEN, LINE CLEAR AVALIED
12	4-May-2021	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	20:47	21:32	0:45	HAND TRIPPED
13	4-May-2021	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	20:47	21:32	0:45	HAND TRIPPED
14	4-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39(06.04.2021)			LINE OPEN, LINE CLEAR AVALIED
15	4-May-2021	BAGALKOT	110	BPCL1- SHIRAHATTI	SHIRAHATTI_110	16:10	17:10	1:00	HAND TRIPPED
16	4-May-2021	BAGALKOT	110	BPCL1- SHIRAHATTI	SHIRAHATTI_110	20:45	22:05	1:20	HAND TRIPPED
17	4-May-2021	BAGALKOT	110	BPCL2- SHIRAHATTI	SHIRAHATTI_110	16:10	17:22	1:12	HAND TRIPPED
18	4-May-2021	BAGALKOT	110	BPCL2- SHIRAHATTI	SHIRAHATTI_110	20:45	21:50	1:05	HAND TRIPPED
19	4-May-2021	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	11:41	14:12	2:31	HAND TRIPPED
20	4-May-2021	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	22:30	22:48	0:18	HAND TRIPPED
21	4-May-2021	BAGALKOT	110	DAMBAL-SUZLON1(L3)	DAMBAL_110	11:41	14:12	2:31	HAND TRIPPED
22	4-May-2021	BAGALKOT	110	DAMBAL-SUZLON1(L3)	DAMBAL_110	22:30	22:47	0:17	HAND TRIPPED
23	4-May-2021	BAGALKOT	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	11:41	14:12	2:31	HAND TRIPPED
24	4-May-2021	BAGALKOT	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	22:30	22:47	0:17	HAND TRIPPED
25	4-May-2021	BAGALKOT	110	GADAG-DAMBAL2	DAMBAL_110	5:47	13:55	8:08	LINE FAULT
26	4-May-2021	BAGALKOT	110	GADAG-LAXMESHWAR2	LAXMESHWAR_110	21:03	21:20	0:17	HAND TRIPPED
27	4-May-2021	BAGALKOT	110	GADAG-SHIRAHATTI	SHIRAHATTI_110	16:04	17:05	1:01	LINE FAULT
28	4-May-2021	BAGALKOT	110	GADAG-SHIRAHATTI	SHIRAHATTI_110	21:03	21:31	0:28	HAND TRIPPED
29	4-May-2021	BAGALKOT	110	HUNGUND- ILKAL2	HUNGUND_110	15:40	15:45	0:05	LINE FAULT
30	4-May-2021	BAGALKOT	110	HUNGUND- JINDAL (EHT)	HUNGUND_110	15:23	23:29	8:06	LINE FAULT
31	4-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
32	4-May-2021	BAGALKOT	110	LAXMESHWAR- SHIRAHATTI	LAXMESHWAR_110	16:04	16:56	0:52	LINE FAULT
33	4-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
34	4-May-2021	BAGALKOT	110	SAMBAPUR ROAD- DAMBAL	DAMBAL_110	11:20	14:12	17:08	LINE CLEAR AVALIED
35	4-May-2021	BAGALKOT	110	SOUDATTI110- ENERCON1&2	SOUDATTI_220	11:25	14:19	2:54	LINE CLEAR AVALIED
36	4-May-2021	BAGALKOT	110	VIJAYANAGAR SUGARS- MUNDARGI	MUNDARGI_110	5:47	6:25	0:38	LINE FAULT
37	4-May-2021	BAGALKOT	220	220/110KV,HV4 &LV4	GADAG_220	20:46	21:09	0:23	HAND TRIPPED
38	4-May-2021	BAGALKOT	220	220/110KV,HV2 &LV2	CHIKKODI_220	10:41	12:30	1:49	HAND TRIPPED
39	4-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)			LINE OPEN, LINE CLEAR AVALIED
40	4-May-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN, LINE CLEAR AVALIED
41	4-May-2021	BAGALKOT	220	DHONI-GADAG 2	DHONI_220	20:45 (4.5.2021)			LINE OPEN,LINE FAULT
42	4-May-2021	BAGALKOT	220	DHONI-HALVARTI	DHONI_220	18:18	20:31	2:13	LINE FAULT
43	4-May-2021	BAGALKOT	220	GADAG -DHONI	GADAG_220	20:46 (4.5.2021)			LINE OPEN,LINE FAULT
44	4-May-2021	BAGALKOT	220	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	18:15	19:51	1:36	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
45	4-May-2021	BAGALKOT	220	GHATAPRABHA-NARENDRA2	GHATAPRABHA_220	18:15 (4.5.2021)			LINE OPEN,LINE FAULT
46	4-May-2021	BAGALKOT	220	GUTTUR2- HAVERI	HAVERI_220	12:39	14:41	2:02	HAND TRIPPED
47	4-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
48	4-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
49	4-May-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	12:33	15:42	3:09	LINE CLEAR AVOIDED
50	4-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)	14:14 (04.05.2021)	117:14 hrs	LINE CHARGED
51	4-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:15 (04.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
52	4-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:06 (03.05.2021)	14:15 (04.05.2021)	2409 hrs	LINE CHARGED
53	4-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:16 (04.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
54	4-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
55	4-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
56	4-May-2021	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	15:19(01/05/2021)			LINE OPEN,LINE FAULT
57	4-May-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN,LINE FAULT
58	4-May-2021	BENGALURU	66	HV1	TEKAL	15:45	16:48	1:03	LINE CLEAR AVOIDED
59	4-May-2021	BENGALURU	66	HV1	GUDIBANDE	10:37	10:40	0:02	LINE CLEAR AVOIDED
60	4-May-2021	BENGALURU	66	HV1	GOKULA	12:10	12:12	0:02	LINE CLEAR AVOIDED
61	4-May-2021	BENGALURU	66	HV1	VIJAYANAGARA	16:30	16:37	0:07	LINE CLEAR AVOIDED
62	4-May-2021	BENGALURU	66	HV1	VIJAYANAGARA	17:38	17:41	0:03	LOAD CHANGE OVER
63	4-May-2021	BENGALURU	66	HV2	GOKULA	10:48	10:53	0:05	LINE CLEAR AVOIDED
64	4-May-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	13:30	13:36	0:06	LOAD CHANGE OVER
65	4-May-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	18:25	18:32	0:06	LINE FAULT
66	4-May-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	9:08	9:15	0:06	LINE FAULT
67	4-May-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:54	13:06	0:12	LINE FAULT
68	4-May-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	9:08	9:15	0:06	LINE FAULT
69	4-May-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	12:54	13:07	0:13	LINE FAULT
70	4-May-2021	BENGALURU	66	REMCO - NRS	NO STATION AFFECTED	16:30	17:38	1:08	LINE FAULT
71	4-May-2021	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	13:28	13:33	0:05	LOAD CHANGE OVER
72	4-May-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN,LINE FAULT
73	4-May-2021	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	SRS PEENYA 220	13:11	13:53	0:42	LINE FAULT
74	4-May-2021	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	NO STATION AFFECTED	13:15	13:59	0:44	LINE FAULT
75	4-May-2021	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66,KOTTUR_66,UJJ AINI_66	20:32	20:39	0:07	LINE FAULT
76	4-May-2021	GULBARGA	66	ITTAGI-HIREHADAGALI1&2	HIREHADAGALI_66,GIRIYAPUR_6 6,MAGALA_66,SOVENHALLI_66,T UNGA BHADRA IPP	20:20	20:33	0:13	LINE FAULT
77	4-May-2021	GULBARGA	66	KOTTUR-BENNEHALLI	KOTTUR_66	20:31	20:40	0:09	MAIN SUPPLY FAILURE
78	4-May-2021	GULBARGA	66	KOTTUR-UJJANI	UJJANI_66	20:31	20:45	0:14	LINE FAULT
79	4-May-2021	GULBARGA	110	HV1	NIRNA_110	18:10	18:15	0:05	TRANSFORMER FAULT
80	4-May-2021	GULBARGA	110	HV1	NIRNA_110	18:50	19:09	0:19	TRANSFORMER FAULT
81	4-May-2021	GULBARGA	110	HV2	HATTI_110	19:05	19:13	0:08	TRANSFORMER FAULT
82	4-May-2021	GULBARGA	110	HV2	SHAHAPUR_220	16:20	16:39	0:19	TRANSFORMER FAULT
83	4-May-2021	GULBARGA	110	HV2	SINDHANNOOR_110	17:54	18:03	0:09	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
84	4-May-2021	GULBARGA	110	HV2	BISIHALLI_110	11:46	11:51	0:19	TRANSFORMER FAULT
85	4-May-2021	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	0:46	1:00	0:14	LINE FAULT
86	4-May-2021	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	1:37	1:44	0:07	LINE FAULT
87	4-May-2021	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	11:28	11:41	0:13	LINE FAULT
88	4-May-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	7:05	7:10	0:05	MAIN SUPPLY FAILURE
89	4-May-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	13:15	13:30	0:15	MAIN SUPPLY FAILURE
90	4-May-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	17:50	18:15	0:25	LINE FAULT
91	4-May-2021	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGA WATH_110,VALKAMDINNI_110(I DLE)	13:44	13:49	0:05	LINE FAULT
92	4-May-2021	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGA WATH_110,VALKAMDINNI_110(I DLE)	23:04	23:40	0:36	LINE FAULT
93	4-May-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	13:40	13:46	0:06	LINE FAULT
94	4-May-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	3:51	6:41	2:50	LINE FAULT
95	4-May-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	4:23	9:49	5:26	LINE FAULT
96	4-May-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	10:09	11:35	1:26	LINE CLEAR AVAILED
97	4-May-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	16:17	16:41	0:24	LINE CLEAR AVAILED
98	4-May-2021	GULBARGA	220	HV1	LINGASUGUR_220	10:29	10:48	0:19	TRANSFORMER FAULT
99	4-May-2021	GULBARGA	220	HV1	HALBARGA_220	8:13	8:22	0:09	TRANSFORMER FAULT
100	4-May-2021	GULBARGA	220	HV1	HALBARGA_220	16:05	16:15	0:10	TRANSFORMER FAULT
101	4-May-2021	GULBARGA	220	HV2	LINGASUGUR_220	10:29	11:03	0:34	TRANSFORMER FAULT
102	4-May-2021	GULBARGA	220	KAPNOOR-HUMNABAD2	KAPNOOR_220	16:22	16:45	0:23	LINE FAULT
103	4-May-2021	GULBARGA	220	LINGASUGUR-BAGEWADI1	BAGEWADI_220	10:29	10:59	0:30	LINE FAULT
104	4-May-2021	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI_220	10:29	11:02	0:33	LINE FAULT
105	4-May-2021	GULBARGA	220	LINGASUGUR-KUSTAGI	LINGASUGUR_220	10:29	10:52	0:23	LINE FAULT
106	4-May-2021	GULBARGA	220	LINGASUGUR-MALLAT	LINGASUGUR_220	10:29	10:44	0:15	LINE FAULT
107	4-May-2021	GULBARGA	220	LINGASUGUR-RTPS1,2	LINGASUGUR_220	10:29	10:47	0:18	LINE FAULT
108	4-May-2021	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	10:29	10:45	0:16	LINE FAULT
109	4-May-2021	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	14:35	15:01	0:26	LINE FAULT
110	4-May-2021	GULBARGA	220	LINGASUGUR-SINDHANOOR	SINDHANOOR_220	10:29	10:53	0:24	LINE FAULT
111	4-May-2021	GULBARGA	220	RAICHUR-JURALA1	RAICHUR_220	14:36(03.042021)	17:08(04.05.2021)	26:32HRS	LINE CHARGED
112	4-May-2021	GULBARGA	220	RAICHUR-JURALA1	RAICHUR_220	13:50	17:08	3:18	LINE CLEAR AVAILED
113	4-May-2021	GULBARGA	220	RAICHUR-JURALA2	RAICHUR_220	13:50	17:08	3:18	LINE CLEAR AVAILED
114	4-May-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	14:22	15:00	0:38	LINE FAULT
115	4-May-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:23	10:50	0:27	HAND TRIPPED
116	4-May-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:58	13:21	0:23	HAND TRIPPED
117	4-May-2021	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	10:21	13:17	2:56	LINE CLEAR AVAILED
118	4-May-2021	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:22	13:18	2:56	LINE CLEAR AVAILED
119	4-May-2021	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	12:28	13:01	0:33	LINE CLEAR AVAILED
120	4-May-2021	HASSAN	66	HV1	BYACHANAHALLI_66	12:28	13:01	0:33	LINE CLEAR AVAILED
121	4-May-2021	HASSAN	66	HV1	DUDDA_66	13:29	13:56	0:27	LINE CLEAR AVAILED
122	4-May-2021	HASSAN	66	HV1	MALLIPATNA_66	15:21	16:03	0:42	LINE CLEAR AVAILED
123	4-May-2021	HASSAN	66	HV1	MALLIPATNA_66	16:49	17:30	0:41	LINE CLEAR AVAILED
124	4-May-2021	HASSAN	66	HV2	RAMNATHPURA_66	11:05	17:00	5:55	LINE CLEAR AVAILED
125	4-May-2021	HASSAN	66	HV2	TAVARECHATNAHALLI_66	0:10	0:35	0:25	TRANSFORMER FAULT
126	4-May-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	7:20	7:35	0:15	LINE FAULT
127	4-May-2021	HASSAN	66	MRSSHM-BD-1	MRSMG_220	10:20	13:18	2:58	LINE CLEAR AVAILED
128	4-May-2021	HASSAN	66	MRSSHM-BD-2	MRSMG_220	10:21	13:18	2:57	LINE CLEAR AVAILED
129	4-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	8:50(12.4.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
130	4-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	8:55	19:24	10:29	LINE CLEAR AVAILED
131	4-May-2021	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	20:31	20:49	0:18	LINE FAULT
132	4-May-2021	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	20:31	21:40	1:09	LINE FAULT
133	4-May-2021	HASSAN	110	HV4	PUTTUR_110	9:47	12:33	2:46	LINE CLEAR AVAILED
134	4-May-2021	HASSAN	110	JOG-JLT3	JOG_110	20:31	21:02	0:31	MAIN SUPPLY FAILURE
135	4-May-2021	HASSAN	110	JOG-JLT4	JOG_110	15:08	18:20	3:12	MAIN SUPPLY FAILURE
136	4-May-2021	HASSAN	110	JOG-JLT4	JOG_110	20:31	21:03	0:32	MAIN SUPPLY FAILURE
137	4-May-2021	HASSAN	110	JOG-JST1	JOG_110	20:31	21:03	0:32	MAIN SUPPLY FAILURE
138	4-May-2021	HASSAN	110	JOG-JST2	JOG_110	20:31	21:03	0:32	MAIN SUPPLY FAILURE
139	4-May-2021	HASSAN	110	LPH-MGHE 2	lph_gen	15:08	18:36	3:28	MAIN SUPPLY FAILURE
140	4-May-2021	HASSAN	110	LPH-MGHE 2	lph_gen	21:00	21:05	0:05	HAND TRIPPED
141	4-May-2021	HASSAN	110	SAGARA-ALKLA	SAGARA_110	20:31	20:47	0:16	LINE FAULT
142	4-May-2021	HASSAN	110	SAGARA-SORABA	SAGARA_110	20:31	21:54	1:23	LINE FAULT
143	4-May-2021	HASSAN	110	SHRLKP-SHIKARI PURA	SHIRALKOPPA_220	19:07	20:30	1:23	LINE FAULT
144	4-May-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	19:03	20:19	1:16	LINE FAULT
145	4-May-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRS MG_220	13:09	13:47	0:38	LINE FAULT
146	4-May-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRS MG_220	9:29	13:46	4:17	LINE CLEAR AVAILED
147	4-May-2021	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	13:09	13:47	0:38	LINE FAULT
148	4-May-2021	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	9:29	13:46	4:17	NFBC ISSUED
149	4-May-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:49	16:46	2:57	LINE FAULT
150	4-May-2021	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66,	18:47	19:00	0:12	LINE FAULT
151	4-May-2021	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	18:47	19:09	0:22	LINE FAULT
152	4-May-2021	MYSURU	66	HV1	DATTAGALLY_66	11:28	14:05	2:36	LINE CLEAR AVAILED
153	4-May-2021	MYSURU	66	HV1	KIADBMANDYA_66	17:00	17:06	0:05	TRANSFORMER FAULT
154	4-May-2021	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
155	4-May-2021	MYSURU	66	HV2	HEBBAL_66	10:35	14:33	3:58	LINE CLEAR AVAILED
156	4-May-2021	MYSURU	66	HV2	HEBBAL_66	14:33	14:34	0:01	TRANSFORMER FAULT
157	4-May-2021	MYSURU	66	HV5	SFCSHIVA_66	19:12 (04/05/2021)			TRANSFORMER OPEN, LINE CLEAR AVAILED
158	4-May-2021	MYSURU	66	HV5	SFCSHIVA_66	18:28 (03/05/2021)	8:01 (04/05/2021)	13:33 HRS	TRANSFORMER CHARGED
159	4-May-2021	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	18:40	18:46	0:06	LINE FAULT
160	4-May-2021	MYSURU	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	6:52	7:06	0:14	LINE FAULT
161	4-May-2021	MYSURU	66	KADAKOLA-NANJANGUDU 2	THANDYA_66	6:52	7:08	0:16	LINE FAULT
162	4-May-2021	MYSURU	66	KADAKOLA-SARAGUR 2	DOORA_66 HURA_66 HULLAHALLI_66	13:48	13:52	0:04	LINE FAULT
163	4-May-2021	MYSURU	66	KUSHALANAGARA 220-BYLUKUPPE	NO STATIONS EFFECTED	12:08	12:53	0:44	LINE CLEAR AVAILED
164	4-May-2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	19:00	19:12	0:12	LINE FAULT
165	4-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
166	4-May-2021	MYSURU	66	TUBINAKERE-MC-2	CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MANDYA_66	5:54	6:02	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
167	4-May-2021	MYSURU	66	TUBINAKERE-MC-4	CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MANDYA_66	5:54	6:01	0:07	LINE FAULT
168	4-May-2021	MYSURU	220	KADAKOLA-KOZHIKODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
169	4-May-2021	MYSURU	220	KUSHALANAGARA 220-BASTHIPURA 1	NO STATIONS EFFECTED	10:02	15:18	5:16	HAND TRIPPED
170	4-May-2021	TUMKUR	66	BILCHODU	UCHCHANGIDURGA_66	16:38	17:08	0:30	LINE FAULT
171	4-May-2021	TUMKUR	66	CHITRADURGA 220KV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	16:25	16:57	0:32	LINE FAULT
172	4-May-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:44	6:52	0:08	LINE FAULT
173	4-May-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	16:45	16:50	0:04	HAND TRIPPED
174	4-May-2021	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:11	9:20	0:09	LINE FAULT
175	4-May-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66	11:44	11:53	0:09	LINE FAULT
176	4-May-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	1:40	2:02	0:22	LINE FAULT
177	4-May-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	4:27	4:47	0:20	LINE FAULT
178	4-May-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	2:57	3:07	0:10	LINE FAULT
179	4-May-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	4:27	4:47	0:20	LINE FAULT
180	4-May-2021	TUMKUR	66	MADHUGIRI 220KV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	18:56	19:15	0:18	LINE FAULT
181	4-May-2021	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:49	19:16	0:26	LINE FAULT
182	4-May-2021	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	18:57	19:16	0:19	HAND TRIPPED
183	4-May-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:16	12:44	0:28	LINE CLEAR AVAILED
184	4-May-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	15:04	15:19	0:15	TRANSFORMER FAULT
185	4-May-2021	TUMKUR	66	TR-1	PAVAGADA_66	10:10	10:14	0:03	HAND TRIPPED
186	4-May-2021	TUMKUR	66	TR-1	PAVAGADA_66	12:45	12:59	0:13	TRANSFORMER FAULT
187	4-May-2021	TUMKUR	66	TR-2	PAVAGADA_66	10:10	10:14	0:03	HAND TRIPPED
188	4-May-2021	TUMKUR	110	TR-2	HULIYAR_110	15:49	15:56	0:06	LINE CLEAR AVAILED
189	4-May-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	15:35	18:59	3:24	LINE FAULT
190	4-May-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	18:02(4.5.21)			LINE OPEN, LINE FAULT
191	4-May-2021	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	15:35	20:10	4:35	LINE FAULT
192	4-May-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	18:02(4.5.21)			LINE OPEN, LINE FAULT
193	4-May-2021	TUMKUR	400	NARENDRA2	GUTTUR_400	18:01:32			LINE OPEN, LINE FAULT
194	5-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
195	5-May-2021	BAGALKOT	110	110/11KV, HV1	GUTTAL_110	16:40	17:05	0:25	TRANSFORMER FAULT
196	5-May-2021	BAGALKOT	110	110/11KV, HV2	SHIROL_110	17:59	18:10	0:11	TRANSFORMER FAULT
197	5-May-2021	BAGALKOT	110	110/11KV, HV2	NAVALGUND_110	21:24 (05.05.2021)			TRANSFORMER FAULT
198	5-May-2021	BAGALKOT	110	110/11KV, HV4	KULIGOD_110	15:21	16:35	1:14	LINE CLEAR AVAILED
199	5-May-2021	BAGALKOT	110	110/33KV, HV1	KADANKOPPA_110	18:46	22:20	3:34	TRANSFORMER FAULT
200	5-May-2021	BAGALKOT	110	110/33KV, HV3	LAXMESHVAR_110	20:51	21:53	1:02	TRANSFORMER FAULT
201	5-May-2021	BAGALKOT	110	110/33KV, HV1	CHIKKODI_110 & KABBUR, VIJANAGR_33	17:03	18:49	1:46	HAND TRIPPED
202	5-May-2021	BAGALKOT	110	110/33KV, HV2	CHIKKODI_110 & KAROSHI, KERUR_33	18:40	18:49	0:09	HAND TRIPPED
203	5-May-2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	10:50	10:59	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
204	5-May-2021	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	22:56	23:08	0:12	LINE FAULT
205	5-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
206	5-May-2021	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL(ACHANUR)	MUDEDEBIHAL_110	3:58	4:12	0:14	LINE FAULT
207	5-May-2021	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	22:08	22:30	0:22	HAND TRIPPED
208	5-May-2021	BAGALKOT	110	BELLATTI-ENERCON	BELLATTI_110	22:08	22:33	0:25	HAND TRIPPED
209	5-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
210	5-May-2021	BAGALKOT	110	BIJAPUR220-BIJAPUR	BIJAPUR_110	16:10	16:31	0:21	LINE FAULT
211	5-May-2021	BAGALKOT	110	BIJAPUR220-ENERCON(BAGEWADI)	BIJAPUR_220	16:31	16:39	0:08	LINE FAULT
212	5-May-2021	BAGALKOT	110	BPCL- NARAGUND	NARAGUND_110	19:46	21:12	1:26	LINE FAULT
213	5-May-2021	BAGALKOT	110	CHIKKODI 220-CHIKKODI110	CHIKKODI_110	17:03	18:32	1:29	LINE FAULT
214	5-May-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	18:23	18:56	0:33	LINE FAULT
215	5-May-2021	BAGALKOT	110	CHIKKODI-WINDMILL	CHIKKODI_110	18:40	18:43	0:03	HAND TRIPPED
216	5-May-2021	BAGALKOT	110	DAMBAL-EILS L1	DAMBAL_110	9:57	11:22	1:25	HAND TRIPPED
217	5-May-2021	BAGALKOT	110	DAMBAL-EILS L1	DAMBAL_110	21:47 (5.5.2021)			LINE OPEN,LINE FAULT
218	5-May-2021	BAGALKOT	110	DAMBAL-SUZLON L2	DAMBAL_110	9:57	11:22	1:25	HAND TRIPPED
219	5-May-2021	BAGALKOT	110	DAMBAL-SUZLON L3	DAMBAL_110	9:57	11:22	1:25	HAND TRIPPED
220	5-May-2021	BAGALKOT	110	DHAVALSHWAR-SAIDAPUR	SAIDAPUR_110	17:50	18:52	1:02	LINE CLEAR AVAILED
221	5-May-2021	BAGALKOT	110	GADAG-DAMBAL	DAMBAL-110	9:56	11:16	1:20	LINE CLEAR AVAILED
222	5-May-2021	BAGALKOT	110	HAVERI220- HANGAL	HANGAL_110	22:01	22:30	0:29	LINE FAULT
223	5-May-2021	BAGALKOT	110	HIRA SUGARS 1&2- SANKESHWAR	SANKESHWAR_110	19:02	19:37	0:35	HAND TRIPPED
224	5-May-2021	BAGALKOT	110	HUBLI- RAMANKOPPA	RAMANKOPPA_110	21:04 (05.05.2021)			LINE OPEN,LINE FAULT
225	5-May-2021	BAGALKOT	110	HUBLI(RAMANKOPPA)- MUNDAGOD	MUNDAGOD_110	21:37	21:58	17:08	LINE FAULT
226	5-May-2021	BAGALKOT	110	KADANKOPPA- KAVALWADA	KADANKOPPA_110	10:50	11:14	0:24	LINE FAULT
227	5-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
228	5-May-2021	BAGALKOT	110	LAXMESHVAR- BELLATTI	BELLATTI_110	21:58	22:28	0:30	LINE FAULT
229	5-May-2021	BAGALKOT	110	MACHE- UDYAMBAG	MACHE_110	9:07	9:38	0:31	HAND TRIPPED
230	5-May-2021	BAGALKOT	110	MKHUBLI110- KITTUR	MKHUBLI_110	7:41	7:54	0:13	HAND TRIPPED
231	5-May-2021	BAGALKOT	110	MUDEDEBIHAL- BALAGI SUGARS	MUDEDEBIHAL_110	4:05	4:19	0:14	HAND TRIPPED
232	5-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
233	5-May-2021	BAGALKOT	110	SANKESHWAR- HUKKERI	HUKKERI_110	18:23	19:02	0:39	HAND TRIPPED
234	5-May-2021	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	SIDDAPUR_110	23:25	23:54	0:29	HAND TRIPPED
235	5-May-2021	BAGALKOT	110	SIRSI220- UMMACHAGI	UMMACHAGI_110	22:56 (05.05.2021)			LINE OPEN,LINE FAULT
236	5-May-2021	BAGALKOT	110	VUAYNAGAR SUGARS- MUNDARGI	MUNDARGI_110	20:25	21:00	0:35	LINE FAULT
237	5-May-2021	BAGALKOT	110	VUAYNAGAR SUGARS- MUNDARGI	MUNDARGI_110	21:47	22:44	0:57	LINE FAULT
238	5-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)			LINE OPEN, LINE CLEAR AVAILED
239	5-May-2021	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	5:26	9:03	3:37	HAND TRIPPED
240	5-May-2021	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	20:41 (5.5.2021)			LINE OPEN,LINE FAULT
241	5-May-2021	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	5:25	9:04	3:39	HAND TRIPPED
242	5-May-2021	BAGALKOT	220	CHIKKODI-BELGAUM 1	CHIKKODI_220	18:45	19:39	0:54	LINE FAULT
243	5-May-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN, LINE CLEAR AVAILED
244	5-May-2021	BAGALKOT	220	DHONI-GADAG 1	DHONI_400	12:43	15:02	2:19	LINE CLEAR AVAILED
245	5-May-2021	BAGALKOT	220	DHONI-GADAG 2	DHONI_400	20:45 (4.5.2021)	15:02 (5.5.2021)	18:16	LINE FAULT
246	5-May-2021	BAGALKOT	220	GADAG -DHONI	GADAG_220	20:46 (4.5.2021)	15:02 (5.5.2021)	18:16	LINE FAULT
247	5-May-2021	BAGALKOT	220	GADAG-DHONI 1	GADAG_220	12:41	15:04	2:23	LINE CLEAR AVAILED
248	5-May-2021	BAGALKOT	220	GHATAPRABHA-NARENDRA2	GHATAPRABHA_220	18:15 (4.5.2021)	00:52 (05.05.2021)	6:37	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
249	5-May-2021	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	22:40 (05.05.2021)			LINE OPEN,LINE FAULT
250	5-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
251	5-May-2021	BAGALKOT	220	MKHUBLI- NARENDRA2	MKHUBLI_220	12:38	15:20	2:42	LINE CLEAR AVAILED
252	5-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
253	5-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:15 (04.05.2021)			LINE OPEN, LINE CLEAR AVAILED
254	5-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:16 (04.05.2021)			LINE OPEN, LINE CLEAR AVAILED
255	5-May-2021	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	12:42	21:40	8:58	LOAD CURTAILMENT
256	5-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
257	5-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
258	5-May-2021	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	15:19(01/05/2021)			LINE OPEN,LINE FAULT
259	5-May-2021	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	21:05	21:21	0:16	LINE FAULT
260	5-May-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	18:48	18:53	0:05	LINE FAULT
261	5-May-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN,LINE FAULT
262	5-May-2021	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	6:25	6:55	0:30	LINE FAULT
263	5-May-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	16:27	17:46	1:18	LINE FAULT
264	5-May-2021	BENGALURU	66	HV1	BOODIGERE	18:05	18:10	0:05	LINE CLEAR AVAILED
265	5-May-2021	BENGALURU	66	HV1	THIMMAMPALLI	13:10	13:15	0:05	LINE CLEAR AVAILED
266	5-May-2021	BENGALURU	66	HV2	KIADB DB PURA 220	13:00	13:19	0:19	LINE CLEAR AVAILED
267	5-May-2021	BENGALURU	66	HV3	ADUGODI	11:04	11:13	0:09	TRANSFORMER FAULT
268	5-May-2021	BENGALURU	66	ITI 220 - DRDO(EHT)	DRDO(EHT)	14:38	15:10	0:32	LINE FAULT
269	5-May-2021	BENGALURU	66	KENGERI SATELLITE TOWN - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	7:15	10:05	2:50	LINE FAULT
270	5-May-2021	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	7:15	8:03	0:48	LINE FAULT
271	5-May-2021	BENGALURU	66	KODIGEHALLI - T G HALLI	TAVAREKERE	6:23	7:13	0:50	LINE FAULT
272	5-May-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	5:50	6:00	0:10	LINE FAULT
273	5-May-2021	BENGALURU	66	TUBGERE - AFTL SOLAR	AFTL SOLAR	18:48	18:54	0:06	LINE FAULT
274	5-May-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)	15:46:00(05/04/2021)	1891:45HRS	LINE CHARGED
275	5-May-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110 ,KURUGOD_110,SHATVAHANA_I PP,AGARWAL_IPP,SUZLON_IPP,K AMALAPUR_110,MATRI_110,RB NS FACTORY	5:22	5:33	0:11	LINE FAULT
276	5-May-2021	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	16:26	17:17	0:09	LINE FAULT
277	5-May-2021	GULBARGA	110	HV1	NIRNA_110	14:41	14:50	0:09	TRANSFORMER FAULT
278	5-May-2021	GULBARGA	110	HV2	DEODURGA_110	17:34	17:50	0:16	TRANSFORMER FAULT
279	5-May-2021	GULBARGA	110	HV2	KAMPLI_110	20:01	20:13	0:12	TRANSFORMER FAULT
280	5-May-2021	GULBARGA	110	HV3	KOLHAR_110	14:20	14:35	0:15	TRANSFORMER FAULT
281	5-May-2021	GULBARGA	110	HV4	DEODURGA_110	17:34	17:50	0:16	TRANSFORMER FAULT
282	5-May-2021	GULBARGA	110	KAPNOOR-HUMNABAD2	ALNAD_110,KADAGANCHI_110	18:40	18:50	0:10	LINE FAULT
283	5-May-2021	GULBARGA	110	KEREHALLI-TALKUNTAI SOLAR	KEREHALLI_110	18:03(05.05.2021)			LINE OPEN, LINE CLEAR AVAILED
284	5-May-2021	GULBARGA	110	KUSHATGI-KUSHTAGISOLAR_IPP	KUSHTAGI_220	2:40	19:30	16:50	LINE FAULT
285	5-May-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	10:07	10:24	0:17	LINE CLEAR AVAILED
286	5-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	18:03	18:12	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
287	5-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	17:15	17:20	0:05	LINE FAULT
288	5-May-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADALAPUR_110,MANVI_110	5:35	5:40	0:05	LINE FAULT
289	5-May-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	17:00	17:09	0:09	LINE CLEAR AVAILED
290	5-May-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	19:50	19:59	0:09	LINE FAULT
291	5-May-2021	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	21:58	22:55	0:57	LINE FAULT
292	5-May-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	10:12	11:22	1:10	LINE CLEAR AVAILED
293	5-May-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IP	18:20	18:26	0:06	LINE FAULT
294	5-May-2021	GULBARGA	220	HV1	KUSHTAGI_220	2:40	3:00	0:20	TRANSFORMER FAULT
295	5-May-2021	GULBARGA	220	HV1	SEDAM_220	16:28	17:01	0:33	TRANSFORMER FAULT
296	5-May-2021	GULBARGA	220	HV1	HALBARGA_220	8:05	8:14	0:09	TRANSFORMER FAULT
297	5-May-2021	GULBARGA	220	HV1	HALBARGA_220	14:16	14:25	0:09	TRANSFORMER FAULT
298	5-May-2021	GULBARGA	220	LINGASUGUR-BAGEWADI1	BAGEWADI_220	11:47	13:36	1:49	LINE FAULT
299	5-May-2021	GULBARGA	220	LINGASUGUR-BAGEWADI1	BAGEWADI_220	18:30	20:07	1:37	LINE FAULT
300	5-May-2021	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI_220	11:47	13:39	1:52	LINE FAULT
301	5-May-2021	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI_220	18:30	20:08	1:38	LINE FAULT
302	5-May-2021	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	16:49	17:12	0:23	LINE FAULT
303	5-May-2021	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	7:37	7:43	0:06	LINE FAULT
304	5-May-2021	HASSAN	66	HANUBAL-SAKLESPUR	HANUBALU_66	12:18	13:45	1:27	MAIN SUPPLY FAILURE
305	5-May-2021	HASSAN	66	HASSN22-BELUR	HASSAN_220	14:25	14:36	0:11	LINE FAULT
306	5-May-2021	HASSAN	66	HV1	ALDUR_66	11:57	12:59	1:02	LINE CLEAR AVAILED
307	5-May-2021	HASSAN	66	HV1	HANUBALU_66	12:18	13:45	1:27	MAIN SUPPLY FAILURE
308	5-May-2021	HASSAN	66	HV1	KANDLI_66	17:46	18:55	1:09	TRANSFORMER FAULT
309	5-May-2021	HASSAN	66	HV1	SAKLESHPUA_66	8:24	8:38	0:14	TRANSFORMER FAULT
310	5-May-2021	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	12:16	13:43	1:27	HAND TRIPPED
311	5-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	8:50(12.4.2021)	18:30(5.5.2021)	561:40hrs	LINE CHARGED
312	5-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	9:17	18:30	9:13	LINE CLEAR AVAILED
313	5-May-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	16:37	16:47	0:10	LINE FAULT
314	5-May-2021	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	23:17	23:28	0:11	LINE FAULT
315	5-May-2021	HASSAN	110	ANANDA-LPH(LST-4)	ANANDPURA_66	20:35	21:40	1:05	LINE FAULT
316	5-May-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	14:51	15:05	0:14	HAND TRIPPED
317	5-May-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:20	17:17	1:57	MAIN SUPPLY FAILURE
318	5-May-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:20	15:39	0:19	MAIN SUPPLY FAILURE
319	5-May-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:57	17:44	1:47	MAIN SUPPLY FAILURE
320	5-May-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	17:26	17:54	0:28	MAIN SUPPLY FAILURE
321	5-May-2021	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	17:26	18:13	0:47	MAIN SUPPLY FAILURE
322	5-May-2021	HASSAN	110	HV1	KEMAR_220	10:19	12:26	2:07	LINE CLEAR AVAILED
323	5-May-2021	HASSAN	110	HV1	BAIKAMPADY_110	10:11	11:34	1:23	LINE CLEAR AVAILED
324	5-May-2021	HASSAN	110	HV2	ANAVATTI_110	22:19(5.05.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
325	5-May-2021	HASSAN	110	HV2	PUTTUR_110	10:12	14:05	3:53	LINE CLEAR AVAILED
326	5-May-2021	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	9:35	15:53	6:18	LINE CLEAR AVAILED
327	5-May-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:16	17:16	2:00	LINE FAULT
328	5-May-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:16	15:39	0:23	LINE FAULT
329	5-May-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:51	17:44	1:53	LINE FAULT
330	5-May-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	23:05	23:29	0:24	MAIN SUPPLY FAILURE
331	5-May-2021	HASSAN	110	MRSSHM-SS2	MRSMG_220	23:17	23:40	0:23	LINE FAULT
332	5-May-2021	HASSAN	110	SAGARA-ALKLA	SAGARA_110	23:16	23:57	0:41	MAIN SUPPLY FAILURE
333	5-May-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	22:57(5.5.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
334	5-May-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	22:37	23:50	1:13	LINE FAULT
335	5-May-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	5:15	6:21	1:06	LINE FAULT
336	5-May-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	17:03	17:29	0:26	HAND TRIPPED
337	5-May-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	16:40	17:10	0:30	LINE FAULT
338	5-May-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	16:40	17:10	0:30	LINE FAULT
339	5-May-2021	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	18:50	20:20	1:30	LINE FAULT
340	5-May-2021	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	15:13	15:58	0:45	LINE CLEAR AVAILED
341	5-May-2021	HASSAN	220	TALAGU-ST2	TALGUPPA_400	15:13	15:58	0:45	LINE CLEAR AVAILED
342	5-May-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	16:40	17:11	0:31	LINE FAULT
343	5-May-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	16:40	17:11	0:31	LINE FAULT
344	5-May-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	18:50	20:21	1:31	LINE FAULT
345	5-May-2021	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS INTERRUPTED	8:31	8:42	0:10	LINE FAULT
346	5-May-2021	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66	23:31	23:38	0:06	LINE FAULT
347	5-May-2021	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66	23:54 (05/05/2021)			LINE OPEN,LINE FAULT
348	5-May-2021	MYSURU	66	G UKKADA-SR PATNA	SRIRANGAPATNA_66	11:25	11:31	0:06	LINE FAULT
349	5-May-2021	MYSURU	66	HV1	DATTAGALLY_66	11:30	12:28	0:57	LINE CLEAR AVAILED
350	5-May-2021	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
351	5-May-2021	MYSURU	66	HV2	SFCSHIVA_66	10:02	17:16	7:14	LINE CLEAR AVAILED
352	5-May-2021	MYSURU	66	HV5	SFCSHIVA_66	14:23 (05/05/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
353	5-May-2021	MYSURU	66	HV5	SFCSHIVA_66	19:12 (04/05/2021)	6:00 (05/05/2021)	10:48 HRS	TRANSFORMER CHARGED
354	5-May-2021	MYSURU	66	KR PETE-AKKIHEBBAL1	AKKIHEBBAL_66	11:22	11:27	0:05	LINE FAULT
355	5-May-2021	MYSURU	66	KR PETE-AKKIHEBBAL2	AKKIHEBBAL_66	11:22	11:27	0:05	LINE FAULT
356	5-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
357	5-May-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	8:56	9:00	0:03	LINE FAULT
358	5-May-2021	MYSURU	220	HOOTAGALLI-BASTIPURA 1	NO STATIONS INTERRUPTED	11:55	14:21	2:26	LINE CLEAR AVAILED
359	5-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
360	5-May-2021	MYSURU	220	VAJMANGALA-HOOTAGALLI	NO STATIONS INTERRUPTED	11:51	14:27	2:36	HAND TRIPPED
361	5-May-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	18:12	18:50	0:38	LINE CLEAR AVAILED
362	5-May-2021	TUMKUR	66	CHAWDANKUPPE-ANCHP-HLDRG	CHAWANAKUPPE_66	12:07	12:32	0:25	LINE CLEAR AVAILED
363	5-May-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:40	23:07	1:27	LINE FAULT
364	5-May-2021	TUMKUR	66	HIRIYURkV 220kV- SUZLON 2	SUZLON2_IPP_66	23:15	23:45	0:30	LINE FAULT
365	5-May-2021	TUMKUR	66	HIRIYURkV 220kV- SUZLON 2	SUZLON2_IPP_66	20:20	20:55	0:35	LINE FAULT
366	5-May-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	23:52	23:58	0:05	LINE FAULT
367	5-May-2021	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	22:33	23:04	0:31	LINE FAULT
368	5-May-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	21:02	21:51	0:48	LINE FAULT
369	5-May-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	22:03	22:54	0:50	LINE FAULT
370	5-May-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	21:19	21:40	0:21	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
371	5-May-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:20	23:34	2:13	LINE FAULT
372	5-May-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	6:23	7:57	1:33	LINE FAULT
373	5-May-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	6:37	6:40	0:02	HAND TRIPPED
374	5-May-2021	TUMKUR	66	TR-1	BALENAHALLI_66	12:46	12:48	0:01	LINE CLEAR AVAILED
375	5-May-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	23:36	23:44	0:08	TRANSFORMER FAULT
376	5-May-2021	TUMKUR	66	TR-1	MATHOD_66	21:44	21:51	0:06	TRANSFORMER FAULT
377	5-May-2021	TUMKUR	66	TR-1	PAVAGADA_220	9:25	9:30	0:05	TRANSFORMER FAULT
378	5-May-2021	TUMKUR	66	TR-1	TAVAREKERE(C)_66	22:47	22:48	0:01	TRANSFORMER FAULT
379	5-May-2021	TUMKUR	66	TR-2	THOVINAKERE_66	12:31	13:16	0:44	LINE CLEAR AVAILED
380	5-May-2021	TUMKUR	66	TR-3	THALLAKK_220	6:23	6:30	0:07	TRANSFORMER FAULT
381	6-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
382	6-May-2021	BAGALKOT	110	110/11KV, HV2	NAVALGUND_110	21:24 (05.05.2021)	11:15 (6.5.2021)	13:41	TRANSFORMER FAULT
383	6-May-2021	BAGALKOT	110	110/11KV,HV 3	MRUTYUNJAYNAGAR_110	18:37	18:57	0:20	LINE CLEAR AVAILED
384	6-May-2021	BAGALKOT	110	110/11KV,HV1	KADANAKOPPA_110	21:09	21:28	0:19	HAND TRIPPED
385	6-May-2021	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	15:55	15:56	0:01	TRANSFORMER FAULT
386	6-May-2021	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	12:16	15:07	2:51	LINE CLEAR AVAILED
387	6-May-2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	14:50	15:05	0:15	TRANSFORMER FAULT
388	6-May-2021	BAGALKOT	110	110/11KV,HV2	MUDEDEBIHAL_110	11:24	11:38	0:14	TRANSFORMER FAULT
389	6-May-2021	BAGALKOT	110	110/11KV,HV2	MUDEDEBIHAL_110	18:42	18:53	0:11	TRANSFORMER FAULT
390	6-May-2021	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	17:49			TRANSFORMER FAULT
391	6-May-2021	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & AMINGAD,KARADI_33	22:02	22:08	0:06	TRANSFORMER FAULT
392	6-May-2021	BAGALKOT	110	110/33KV,HV3	GAJENDRAGAD_110 & WIND 3,4_33	15:03	15:19	0:16	TRANSFORMER FAULT
393	6-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
394	6-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
395	6-May-2021	BAGALKOT	110	DAMBAL-EILS L1	DAMBAL_110	21:47 (5.5.2021)	15:27 (6.5.2021)	17:39	LINE FAULT
396	6-May-2021	BAGALKOT	110	GADAG-DAMBAL 2	DAMBAL_110	2:32	10:11	7:39	LINE FAULT
397	6-May-2021	BAGALKOT	110	GHATAPRABHA-PG HUNASYAL	PG HUANASYAL_110	20:13	20:31	0:18	LINE FAULT
398	6-May-2021	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	1:26	1:43	0:17	LINE FAULT
399	6-May-2021	BAGALKOT	110	HUBLI- RAMANKOPPA	RAMANKOPPA_110	21:04 (05.05.2021)	10:47 (06.05.2021)	13:41	LINE FAULT
400	6-May-2021	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	16:50	18:07	1:17	HAND TRIPPED
401	6-May-2021	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	21:10	21:17	0:07	HAND TRIPPED
402	6-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
403	6-May-2021	BAGALKOT	110	NARAGUND-GOPANAKOPPA	GOPANAKOPPA_110	9:57	10:05	0:08	HAND TRIPPED
404	6-May-2021	BAGALKOT	110	NARAGUND-GOPANAKOPPA	GOPANAKOPPA_110	13:53	14:13	0:20	HAND TRIPPED
405	6-May-2021	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	10:12	14:14	4:02	HAND TRIPPED
406	6-May-2021	BAGALKOT	110	NAVLGUND-KONNUR-NARAGUND	NARGUND,KONNUR_110	9:56	14:11	4:15	LINE CLEAR AVAILED
407	6-May-2021	BAGALKOT	110	PG HUNASYAL-MUDALAGI	MUDALAGI_110	20:33	20:39	0:06	HAND TRIPPED
408	6-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
409	6-May-2021	BAGALKOT	110	SANKESHWAR-HSF CO GEN	SANKESHWAR_110	12:38	12:50	0:12	LINE CLEAR AVAILED
410	6-May-2021	BAGALKOT	110	SIRS220- UMMACHAGI	UMMACHAGI_110	22:56 (05.05.2021)	11:35 (06.05.2021)	12:39	LINE FAULT
411	6-May-2021	BAGALKOT	110	SOUDATTI-ENERCON 1	SOUDATTI_110	5:12	11:02	5:50	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
412	6-May-2021	BAGALKOT	110	SOUDATTI-MUNAVALLI	MUNAVALLI_110	4:29	4:47	0:18	LINE FAULT
413	6-May-2021	BAGALKOT	110	SOUDATTI-MUNAVALLI	MUNAVALLI_110	5:14	7:18	2:04	LINE FAULT
414	6-May-2021	BAGALKOT	220	220/110KV,HV3	MAHALINGAPUR_220	8:56	9:08	0:12	TRANSFORMER FAULT
415	6-May-2021	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	18:13	18:33	0:20	LINE FAULT
416	6-May-2021	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	18:36	18:54	0:18	LINE FAULT
417	6-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
418	6-May-2021	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	20:41 (5.5.2021)	8:40 (6.5.2021)	11:59	LINE FAULT
419	6-May-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
420	6-May-2021	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	22:40 (05.05.2021)	12:49 (6.5.2021)	14:09	LINE FAULT
421	6-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
422	6-May-2021	BAGALKOT	220	MK HUBLI-NARENDRA 1	MK HUBLI_220	11:06	14:23	3:17	LINE CLEAR AVOIDED
423	6-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
424	6-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:15 (04.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
425	6-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:16 (04.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
426	6-May-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	12:49	14:51	2:02	LINE FAULT
427	6-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
428	6-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
429	6-May-2021	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	15:19(01/05/2021)			LINE OPEN, LINE FAULT
430	6-May-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN, LINE FAULT
431	6-May-2021	BENGALURU	66	HV1	SARIJAPURA 220	15:35	15:45	0:10	TRANSFORMER FAULT
432	6-May-2021	BENGALURU	66	HV2	HOSOR RAMAPURA	13:10	13:17	0:07	TRANSFORMER FAULT
433	6-May-2021	BENGALURU	66	HV2	SARIJAPURA 220	15:35	15:46	0:11	TRANSFORMER FAULT
434	6-May-2021	BENGALURU	66	HV2	BMTC	9:32	9:35	0:03	LINE CLEAR AVOIDED
435	6-May-2021	BENGALURU	66	TG HALLI - BYADRAHALLI	BWSSB (EHT)	15:56	17:00	1:04	LINE CLEAR AVOIDED
436	6-May-2021	BENGALURU	66	VIDYANAGAR - HOSKOTE	NO STATION AFFECTED	16:41	18:50	2:08	LINE FAULT
437	6-May-2021	GULBARGA	66	HV1	KOGALI_66	11:10	11:20	0:10	TRANSFORMER FAULT
438	6-May-2021	GULBARGA	66	HV2	KOGALI_66	16:20	16:30	0:10	TRANSFORMER FAULT
439	6-May-2021	GULBARGA	66	KOGALI-ASTRSLR	KOGALI_66	14:08	14:11	0:03	LINE OPEN, LINE CLEAR AVOIDED
440	6-May-2021	GULBARGA	66	KOGALI-ITTAGGI,ASTRSLR_IPP	KOGALI_66	11:25	13:00	1:35	LINE OPEN, LINE CLEAR AVOIDED
441	6-May-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110	19:50	20:04	0:14	LINE FAULT
442	6-May-2021	GULBARGA	110	HV2	NALWAR_110	13:25	13:40	0:15	TRANSFORMER FAULT
443	6-May-2021	GULBARGA	110	KEREHALLI-TALKUNTAI SOLAR	KEREHALLI_110	18:03(05.05.2021)	2:23(06.05.2021)	8:20 HRS	LINE CHARGED
444	6-May-2021	GULBARGA	110	KEREHALLI-TALKUNTAI SOLAR	KEREHALLI_110	2:58	3:10	0:12	LINE OPEN, LINE CLEAR AVOIDED
445	6-May-2021	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	13:45	14:00	0:15	LINE FAULT
446	6-May-2021	GULBARGA	110	RAJESHWAR-SATHAPUR	SASTHAPUR_110	13:00	13:05	0:05	LINE FAULT
447	6-May-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	15:53	16:20	0:27	LINE CLEAR AVOIDED
448	6-May-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREEN IPP,	1:04	1:14	0:10	LINE FAULT
449	6-May-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	4:56	5:00	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
450	6-May-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RADONA_110,SRNAGAR_110,MA LLAPUR_110	5:18	5:28	0:10	LINE FAULT
451	6-May-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	11:30	13:02	1:32	LINE CLEAR AVAILED
452	6-May-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	1:05	1:17	0:12	LINE FAULT
453	6-May-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	2:35	4:00	1:25	LINE FAULT
454	6-May-2021	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	11:57	12:19	0:22	LINE FAULT
455	6-May-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	13:55	14:11	0:16	LINE FAULT
456	6-May-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	8:40	8:50	0:10	LINE FAULT
457	6-May-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	20:00	20:05	0:05	LINE FAULT
458	6-May-2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	5:55	6:00	0:05	LINE FAULT
459	6-May-2021	HASSAN	66	HV1	ALDUR_66	11:43	13:48	2:05	LINE CLEAR AVAILED
460	6-May-2021	HASSAN	66	HV1	BALEHONNUR_66	12:47	13:45	0:58	LINE CLEAR AVAILED
461	6-May-2021	HASSAN	66	HV1	DODDAKADANUR_66	12:01	12:09	0:08	HAND TRIPPED
462	6-May-2021	HASSAN	66	HV1	DUDDA_66	2:09	2:15	0:06	TRANSFORMER FAULT
463	6-May-2021	HASSAN	66	HV1	SHANTHIGRAMA_66	11:54	14:27	2:33	LINE CLEAR AVAILED
464	6-May-2021	HASSAN	66	HV2	HOLEHONNUR_66	12:50	13:28	0:38	LINE CLEAR AVAILED
465	6-May-2021	HASSAN	66	HV2	SHANTHIGRAMA_66	11:54	14:27	2:33	LINE CLEAR AVAILED
466	6-May-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	4:05	4:50	0:45	HAND TRIPPED
467	6-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	9:00	17:02	8:02	LINE CLEAR AVAILED
468	6-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	8:59	17:02	8:03	LINE CLEAR AVAILED
469	6-May-2021	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	11:54	14:27	2:33	LINE CLEAR AVAILED
470	6-May-2021	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	11:57	12:20	0:23	LINE FAULT
471	6-May-2021	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	8:15	9:10	0:55	LINE CLEAR AVAILED
472	6-May-2021	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	9:20	9:41	0:21	LINE CLEAR AVAILED
473	6-May-2021	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	16:59	19:20	2:21	LINE CLEAR AVAILED
474	6-May-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	6:08	16:42	10:34	LINE CLEAR AVAILED
475	6-May-2021	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	18:25	18:57	0:32	MAIN SUPPLY FAILURE
476	6-May-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	18:15	19:19	1:04	MAIN SUPPLY FAILURE
477	6-May-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	18:15	18:20	0:05	MAIN SUPPLY FAILURE
478	6-May-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	18:29	19:30	1:01	MAIN SUPPLY FAILURE
479	6-May-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	17:42	18:38	0:56	MAIN SUPPLY FAILURE
480	6-May-2021	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	17:42	18:38	0:56	MAIN SUPPLY FAILURE
481	6-May-2021	HASSAN	110	HV1	PUTTUR_110	10:11	12:13	2:02	LINE CLEAR AVAILED
482	6-May-2021	HASSAN	110	HV1	ALKOLA_110	12:13	13:33	1:20	LINE CLEAR AVAILED
483	6-May-2021	HASSAN	110	HV1	ESSUR_110	13:03	16:17	3:14	LINE CLEAR AVAILED
484	6-May-2021	HASSAN	110	HV1	KEMAR_220	18:32	18:53	0:21	MAIN SUPPLY FAILURE
485	6-May-2021	HASSAN	110	HV1	KONAJE_110	6:23	6:26	0:03	HAND TRIPPED
486	6-May-2021	HASSAN	110	HV2	ANAVATTI_110	22:19(5.05.2021)	9:43(6.5.2021)	11:24hrs	TRANSFORMER CHARGED
487	6-May-2021	HASSAN	110	HV2	ANAVATTI_110	18:54	19:09	0:15	TRANSFORMER FAULT
488	6-May-2021	HASSAN	110	HV2	KEMAR_220	18:32	18:53	0:21	MAIN SUPPLY FAILURE
489	6-May-2021	HASSAN	110	HV2	KONAJE_110	6:23	6:26	0:03	HAND TRIPPED
490	6-May-2021	HASSAN	110	HV2	KUNDAP_110	12:31	12:42	0:11	TRANSFORMER FAULT
491	6-May-2021	HASSAN	110	HV2	SORABA_110	9:52	11:42	1:50	LINE CLEAR AVAILED
492	6-May-2021	HASSAN	110	HV3	KONAJE_110	6:23	6:26	0:03	HAND TRIPPED
493	6-May-2021	HASSAN	110	KAVOOR-AMR	KAVOOR_220	16:51	17:02	0:11	LINE FAULT
494	6-May-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:31	19:18	1:47	LINE FAULT
495	6-May-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:31	18:15	0:44	LINE FAULT
496	6-May-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	18:32	19:30	0:58	MAIN SUPPLY FAILURE
497	6-May-2021	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	18:33	19:05	0:32	MAIN SUPPLY FAILURE
498	6-May-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	18:24	19:37	1:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
499	6-May-2021	HASSAN	110	KEMAR-Manipal1	KEMAR_220	19:42	19:52	0:10	HAND TRIPPED
500	6-May-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	18:24	20:10	1:46	LINE FAULT
501	6-May-2021	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	18:32	19:20	0:48	MAIN SUPPLY FAILURE
502	6-May-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	18:32	19:02	0:30	MAIN SUPPLY FAILURE
503	6-May-2021	HASSAN	110	LV1	KEMAR_220	18:24	18:52	0:28	TRANSFORMER FAULT
504	6-May-2021	HASSAN	110	LV2	KEMAR_220	18:24	19:45	1:21	TRANSFORMER FAULT
505	6-May-2021	HASSAN	110	LV3	KEMAR_220	18:24	19:01	0:37	TRANSFORMER FAULT
506	6-May-2021	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	17:45	18:38	0:53	MAIN SUPPLY FAILURE
507	6-May-2021	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	17:43	18:39	0:56	MAIN SUPPLY FAILURE
508	6-May-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	18:29	20:01	1:32	MAIN SUPPLY FAILURE
509	6-May-2021	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	19:54	20:18	0:24	MAIN SUPPLY FAILURE
510	6-May-2021	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	18:29	19:54	1:25	LINE FAULT
511	6-May-2021	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	18:27	19:22	0:55	MAIN SUPPLY FAILURE
512	6-May-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	18:26	19:04	0:38	MAIN SUPPLY FAILURE
513	6-May-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	18:26	19:16	0:50	MAIN SUPPLY FAILURE
514	6-May-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	18:27	19:16	0:49	MAIN SUPPLY FAILURE
515	6-May-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_66	18:29	19:04	0:35	MAIN SUPPLY FAILURE
516	6-May-2021	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	18:39	20:05	1:26	MAIN SUPPLY FAILURE
517	6-May-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	22:57(5.5.2021)	0:23(6.5.2021)	1:26hrs	LINE CHARGED
518	6-May-2021	HASSAN	220	HV2	KEMAR_220	18:24	19:45	1:21	TRANSFORMER FAULT
519	6-May-2021	HASSAN	220	HV3	KEMAR_220	18:24	18:58	0:34	TRANSFORMER FAULT
520	6-May-2021	HASSAN	220	HVI	KEMAR_220	18:24	18:52	0:28	TRANSFORMER FAULT
521	6-May-2021	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	8:55	16:19	7:24	LINE CLEAR AVAILED
522	6-May-2021	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	0:17	16:10	15:53	LINE FAULT
523	6-May-2021	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	0:17	16:10	15:53	LINE FAULT
524	6-May-2021	HASSAN	220	VARAH1-KEMAR2	varahi_gen	17:40	18:05	0:25	LINE FAULT
525	6-May-2021	HASSAN	220	VARAH1-SHMG3	varahi_gen	8:56	16:19	7:23	NFBC ISSUED
526	6-May-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	8:58	15:16	6:18	LINE CLEAR AVAILED
527	6-May-2021	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	5:50	5:57	0:06	LINE FAULT
528	6-May-2021	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66	23:54 (05/05/2021)	6:34 (06/05/2021)	6:40 HRS	LINE CHARGED
529	6-May-2021	MYSURU	66	HV1	SFCSHIVA_66	13:59 (06/05/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
530	6-May-2021	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)	12:30 (06/05/2021)	887:11 HRS	TRANSFORMER CHARGED
531	6-May-2021	MYSURU	66	HV5	SFCSHIVA_66	14:23 (05/05/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
532	6-May-2021	MYSURU	66	JAKKANAHALLY-NAGAMANGALA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	8:31	8:36	0:04	LINE FAULT
533	6-May-2021	MYSURU	66	KR NAGARA-MYSORE-1	MIRLE_66	5:50	10:58	5:07	LINE FAULT
534	6-May-2021	MYSURU	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	5:51	10:56	5:04	LINE FAULT
535	6-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
536	6-May-2021	MYSURU	66	SHANIVARASANTHE-MALIPATNA	SANIVARASANTHE_66	4:20	4:30	0:10	HAND TRIPPED
537	6-May-2021	MYSURU	66	SHANIVARASANTHE-YESSLUR	SANIVARASANTHE_66	4:15	4:42	0:27	HAND TRIPPED
538	6-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
539	6-May-2021	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMVATTUR_66	7:56	8:13	0:17	LINE FAULT
540	6-May-2021	TUMKUR	66	BASAVAPATNA-VESTAE WIND	BASAVAPATNA_66	1:33	2:29	0:55	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
541	6-May-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	14:12	14:31	0:18	LINE FAULT
542	6-May-2021	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	1:34	1:42	0:07	LINE FAULT
543	6-May-2021	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:00	14:10	0:09	LINE FAULT
544	6-May-2021	TUMKUR	66	KATTIGE- BEDRUGADDE	KATTIGE-66	9:05	11:40	2:35	NFBC ISSUED
545	6-May-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	12:39	12:48	0:09	LINE FAULT
546	6-May-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	13:20	13:32	0:12	LINE FAULT
547	6-May-2021	TUMKUR	66	TR-1	CHANNAGIRI_66	21:16	21:23	0:07	TRANSFORMER FAULT
548	6-May-2021	TUMKUR	66	TR-1	PAVAGADA_220	8:05	8:15	0:10	TRANSFORMER FAULT
549	6-May-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	13:54	13:58	0:04	HAND TRIPPED
550	6-May-2021	TUMKUR	66	TR-2	BUKKAPATNA_66	12:08	12:40	0:31	LINE CLEAR AVAILED
551	6-May-2021	TUMKUR	66	TR-2	MALEBENNUR_66	10:02	12:22	2:19	TRANSFORMER FAULT
552	6-May-2021	TUMKUR	66	TR-2	MALEBENNUR_66	17:40	17:58	0:18	TRANSFORMER FAULT
553	6-May-2021	TUMKUR	66	TR-2	MALEBENNUR_66	18:12	18:32	0:20	TRANSFORMER FAULT
554	6-May-2021	TUMKUR	66	TR-2	MALEBENNUR_66	18:56	20:22	1:26	TRANSFORMER FAULT
555	6-May-2021	TUMKUR	66	TR-2	MALEBENNUR_66	21:39	22:05	0:25	TRANSFORMER FAULT
556	6-May-2021	TUMKUR	66	TR-2	RANGANATHAPURA_66	9:05	13:50	4:44	LINE CLEAR AVAILED
557	6-May-2021	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	23:15	23:31	0:16	LINE FAULT
558	6-May-2021	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	23:15	23:30	0:15	LINE FAULT
559	6-May-2021	TUMKUR	110	TR-1	K B CROSS_220	18:04	18:40	0:35	LINE CLEAR AVAILED
560	6-May-2021	TUMKUR	110	TR-1	KALLUR_110	21:38	21:59	0:21	TRANSFORMER FAULT
561	6-May-2021	TUMKUR	220	TR-1	K B CROSS_220	18:04	18:40	0:35	LINE CLEAR AVAILED
562	6-May-2021	TUMKUR	220	TR-1	PAVAGADA_220	8:05	8:11	0:06	TRANSFORMER FAULT
563	7-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
564	7-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HOSAHONNATI_110	11:30	11:42	0:12	TRANSFORMER FAULT
565	7-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TILUVALLI_110	16:55	17:15	0:20	LINE CLEAR AVAILED
566	7-May-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TILUVALLI_110	16:13	18:12	1:59	LINE CLEAR AVAILED
567	7-May-2021	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	6:37	7:29	0:52	LINE CLEAR AVAILED
568	7-May-2021	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	12:44	12:51	0:07	TRANSFORMER FAULT
569	7-May-2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	14:45	15:00	0:15	TRANSFORMER FAULT
570	7-May-2021	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	0:01	0:09	0:08	TRANSFORMER FAULT
571	7-May-2021	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	22:08	22:11	0:03	TRANSFORMER FAULT
572	7-May-2021	BAGALKOT	110	110/11KV,HV2	LAXMESHVAR_110	14:31	16:14	1:43	TRANSFORMER FAULT
573	7-May-2021	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(G)	17:21 (07.05.2021)			TRANSFORMER FAULT
574	7-May-2021	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	17:49 (06.05.2021)	15:00 (07.05.2021)	21:11 hrs	TRANSFORMER CHARGED
575	7-May-2021	BAGALKOT	110	110/11KV,HV3(HV4)	LAKANAHALLI_110,ALNAVAR_110	7:40	7:44	0:04	TRANSFORMER FAULT
576	7-May-2021	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TILUVALLI_110	15:34	18:41	3:07	LINE CLEAR AVAILED
577	7-May-2021	BAGALKOT	110	AMBEAWADI-NK1	HALIYAL_110	9:43	10:00	0:17	LINE CLEAR AVAILED
578	7-May-2021	BAGALKOT	110	AMBEAWADI-NK2	KAVALWADA_110	9:43	10:04	0:21	LINE FAULT
579	7-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
580	7-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
581	7-May-2021	BAGALKOT	110	BHUTNAL-THORVI	THORVI_110	14:45	15:00	0:15	LINE FAULT
582	7-May-2021	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED BIDNAL_220	7:02	13:42	6:40	LINE FAULT
583	7-May-2021	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED BIDNAL_220	7:01	15:45	8:44	LINE FAULT
584	7-May-2021	BAGALKOT	110	GADAG ROAD-(BIDNAL)GOPPANAKOPPA	STATION NOT AFFECTED GADAG ROAD_110	7:29	17:58	10:29	LINE FAULT
585	7-May-2021	BAGALKOT	110	GOPPANAKOPPA-GADAG ROAD	STATION NOT AFFECTED GOPPANAKOPPA_110	6:40	18:11	11:31	HAND TRIPPED
586	7-May-2021	BAGALKOT	110	GOPPANAKOPPA-NARGUND(BIDNAL-NAVALGUND)	STATION NOT AFFECTED GOPPANAKOPPA_110	6:40	18:16	11:36	LINE FAULT
587	7-May-2021	BAGALKOT	110	HAVERI220-BASAVANAKATTI	STATION NOT AFFECTED BASAVANKATTI_110	12:00	14:34	2:34	HAND TRIPPED
588	7-May-2021	BAGALKOT	110	HUBLI220-KALAGHATAGI(SIRSI)	KALAGHATAGI_110	7:01	10:08	3:07	LINE FAULT
589	7-May-2021	BAGALKOT	110	HUBLI220-RAMANAKOPPA	RAMANAKOPPA_110	7:06	10:20	3:14	LINE FAULT
590	7-May-2021	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	7:16	11:13	3:57	HAND TRIPPED
591	7-May-2021	BAGALKOT	110	JAMAKHANDI-PRABHULINGESHWAR(SIDDAPUR)	STATION NOT AFFECTED JAMAKHANDI_110	18:07	18:40	0:33	LINE FAULT
592	7-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
593	7-May-2021	BAGALKOT	110	MK HUBLI220-BIDI	BIDI_110	6:46	9:05	2:19	LINE FAULT
594	7-May-2021	BAGALKOT	110	NAVALGUND-BIDNAL220	STATION NOT AFFECTED NAVALAGUND_110	9:20	16:25	7:05	LINE FAULT
595	7-May-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
596	7-May-2021	BAGALKOT	110	RON-GAMESH IPP	GAMESH IPP_110 STATION NOT AFFECTED RON_110	8:33	13:57	5:24	LINE CLEAR AVAILED
597	7-May-2021	BAGALKOT	110	RON-GAMESH IPP	GAMESH IPP_110 RON_110	3:30	3:31	0:01	HAND TRIPPED
598	7-May-2021	BAGALKOT	110	SOUDATTI220-BENKATTI (YERGATTI)	BENAKATTI_110	4:33	7:40	3:07	LINE FAULT
599	7-May-2021	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	4:33	17:09	12:36	LINE FAULT
600	7-May-2021	BAGALKOT	110	SOUDATTI220-MUNAVALLI	STATION NOT AFFECTED SOUDATTI_220	14:15	14:16	0:01	HAND TRIPPED
601	7-May-2021	BAGALKOT	110	SOUDATTI220-SOUDATTI2	STATION NOT AFFECTED SOUDATTI_110	4:29	8:09	3:40	LINE FAULT
602	7-May-2021	BAGALKOT	110	SOUDATTI-ENERCON1	ENERCON IPP_110 STATION NOT AFFECTED SOUDATTI_110	4:29	8:23	3:54	LINE FAULT
603	7-May-2021	BAGALKOT	110	SOUDATTI-ENERCON1	ENERCON IPP_110 STATION NOT AFFECTED SOUDATTI_110	8:37	11:44	3:07	LINE FAULT
604	7-May-2021	BAGALKOT	110	SOUDATTI-ENERCON2	ENERCON IPP_110 STATION NOT AFFECTED SOUDATTI_110	4:29	8:18	3:49	LINE FAULT
605	7-May-2021	BAGALKOT	110	TAKKALAKI-WARDA IPP	WARDA IPP_110, TAKKALAKI_110	14:22	14:43	0:21	HAND TRIPPED
606	7-May-2021	BAGALKOT	110	THORVI-TAKKALAKI(TIKOTA)	TAKKALAKI_110	14:45	15:00	0:15	LINE FAULT
607	7-May-2021	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED BIJAPUR_220	14:21	14:43	0:22	TRANSFORMER FAULT
608	7-May-2021	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED CHIKKODI_220	11:01	12:13	1:12	LINE CLEAR AVAILED
609	7-May-2021	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED BIJAPUR_220	14:21	14:45	0:24	TRANSFORMER FAULT
610	7-May-2021	BAGALKOT	220	220/110KV,HV3,LV3	BAGALKOT_220	11:05	14:34	3:29	LINE CLEAR AVAILED
611	7-May-2021	BAGALKOT	220	AMBEWADI-NAGJHARI1	AMBEWADI_220	9:43	12:48	3:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
612	7-May-2021	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	9:45	10:45	1:00	LINE CLEAR AVAILED
613	7-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	7:13	8:02	0:49	HAND TRIPPED
614	7-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)	13:24 (07.05.2021)	386:45 hrs	LINE CHARGED
615	7-May-2021	BAGALKOT	220	BELGAUM-NAREBNDRA2	STATION NOT AFFECTED BELGAUM_220	7:07	8:00	0:53	LINE FAULT
616	7-May-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	6:39	9:08	2:29	LINE FAULT
617	7-May-2021	BAGALKOT	220	BIDNAL-HARTHI2	STATION NOT AFFECTED BIDNAL_220	6:58	9:09	2:11	LINE FAULT
618	7-May-2021	BAGALKOT	220	BIJAPUR-INDI2	STATION NOT AFFECTED BIJAPUR_220	14:21	15:39	1:18	LINE FAULT
619	7-May-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)	13:24 (07.05.2021)	385:19 hrs	LINE CHARGED
620	7-May-2021	BAGALKOT	220	GHATAPRABHA-NARENDRA1	STATION NOT AFFECTED GHATAPRABHA_220	6:06	8:01	1:55	LINE FAULT
621	7-May-2021	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	6:49	12:42	5:53	LINE FAULT
622	7-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
623	7-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
624	7-May-2021	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	7:37	8:13	0:36	LINE FAULT
625	7-May-2021	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	6:49	12:42	5:53	LINE FAULT
626	7-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:15 (04.05.2021)			LINE OPEN, LINE CLEAR AVAILED
627	7-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:16 (04.05.2021)			LINE OPEN, LINE CLEAR AVAILED
628	7-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
629	7-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
630	7-May-2021	BAGALKOT	400	400/220KV,ICT2(HV&LV)	DHONI_400	10:23	12:45	2:22	TRANSFORMER FAULT
631	7-May-2021	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	15:19(01/05/2021)	19:47(07/05/2021)	148:28HRS	LINE CHARGED
632	7-May-2021	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGLU	21:05	21:15	0:10	LINE FAULT
633	7-May-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN,LINE FAULT
634	7-May-2021	BENGALURU	66	GUNDAMGERE - GOWRIBIDANUR 220	GUNDAMGERE	12:00	13:02	1:02	LINE CLEAR AVAILED
635	7-May-2021	BENGALURU	66	HV1	BANGARPETE	10:35	10:40	0:05	TRANSFORMER FAULT
636	7-May-2021	BENGALURU	66	HV2	BANGARPETE	1:45	2:53	1:08	TRANSFORMER FAULT
637	7-May-2021	BENGALURU	66	HV2	BANGARPETE	10:30	14:12	3:42	LINE CLEAR AVAILED
638	7-May-2021	BENGALURU	66	KODIGENAHALLI - T G HALLI	TAVAREKERE	6:47	7:37	0:50	LINE CLEAR AVAILED
639	7-May-2021	BENGALURU	66	KOLAR 220 - BANGARPETE-2	BANGARPETE	11:28	11:33	0:04	LINE FAULT
640	7-May-2021	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, H GOLAHALLI, NANGLI, MUDIYANUR, BAIRAKURU	11:28	11:37	0:09	LINE FAULT
641	7-May-2021	BENGALURU	66	T G HALLI - BYDARAHALLI	BWSSB(EHT)	6:34	7:30	0:55	LINE CLEAR AVAILED
642	7-May-2021	BENGALURU	66	T K HALLI 220 - SIMSHA	T K HALLI 220	16:30	16:44	0:14	LINE FAULT
643	7-May-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	21:45	23:05	1:20	MAIN SUPPLY FAILURE
644	7-May-2021	GULBARGA	66	HV3	KUDLIGI_66	9:15	9:35	0:20	TRANSFORMER FAULT
645	7-May-2021	GULBARGA	66	KUDLIGI-ITTAGGI1	KUDLIGI_66	21:45	21:55	0:10	MAIN SUPPLY FAILURE
646	7-May-2021	GULBARGA	110	HV1	HANUMASAGAR_110	18:40	19:00	0:20	LINE CLEAR AVAILED
647	7-May-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	16:50	17:35	0:45	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
648	7-May-2021	HASSAN	66	AKALE-IPCL1	SAKLESH PURA_66	10:05	18:50	8:45	LINE CLEAR AVAILED
649	7-May-2021	HASSAN	66	AKALE-IPCL2	SAKLESH PURA_66	10:05	18:50	8:45	LINE CLEAR AVAILED
650	7-May-2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	21:46	22:20	0:34	LINE FAULT
651	7-May-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	23:15 (7.05.2021)			HAND TRIPPED
652	7-May-2021	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	23:15 (7.05.2021)			LINE OPEN,LINE FAULT
653	7-May-2021	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	22:53	23:18	0:25	LINE FAULT
654	7-May-2021	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	22:53	23:18	0:25	LINE FAULT
655	7-May-2021	HASSAN	66	HV1	MAGGE_66	22:50 (7.05.2021)			MAIN SUPPLY FAILURE
656	7-May-2021	HASSAN	66	HV1	BALEHONNUR_66	16:09	16:29	0:20	TRANSFORMER FAULT
657	7-May-2021	HASSAN	66	HV1	BYACHANAHALLI_66	12:00	12:40	0:40	LINE CLEAR AVAILED
658	7-May-2021	HASSAN	66	HV1	KANDLI_66	11:05	11:45	0:40	LINE CLEAR AVAILED
659	7-May-2021	HASSAN	66	HV1	MAGGE_66	7:11	7:45	0:34	MAIN SUPPLY FAILURE
660	7-May-2021	HASSAN	66	HV1	MALALI_66	22:55	23:18	0:23	MAIN SUPPLY FAILURE
661	7-May-2021	HASSAN	66	HV2	MAGGE_66	22:50 (7.05.2021)			MAIN SUPPLY FAILURE
662	7-May-2021	HASSAN	66	HV2	MAGGE_66	7:11	7:45	0:34	MAIN SUPPLY FAILURE
663	7-May-2021	HASSAN	66	KANDLI-HASSAN	KANDLI_66	23:25 (7.05.2021)			MAIN SUPPLY FAILURE
664	7-May-2021	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	23:25 (7.05.2021)			MAIN SUPPLY FAILURE
665	7-May-2021	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	7:15	7:44	0:29	LINE FAULT
666	7-May-2021	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	8:08	8:13	0:05	HAND TRIPPED
667	7-May-2021	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	10:45	11:15	0:30	HAND TRIPPED
668	7-May-2021	HASSAN	66	LV3	MRS MG_220	9:03	13:18	4:15	LINE CLEAR AVAILED
669	7-May-2021	HASSAN	66	MRSSHM-DVG2	MRS MG_220	20:22(7.4.2021)			LINE OPEN,LINE FAULT
670	7-May-2021	HASSAN	66	MRSSHM-DVG2	MRS MG_220	19:45	20:22	0:37	LINE FAULT
671	7-May-2021	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	22:35 (7.05.2021)			MAIN SUPPLY FAILURE
672	7-May-2021	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	7:14	7:52	0:38	LINE FAULT
673	7-May-2021	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	10:45	11:15	0:30	HAND TRIPPED
674	7-May-2021	HASSAN	66	SAKALE-HASSAN2	SAKLESH PURA_66	22:35 (7.05.2021)			MAIN SUPPLY FAILURE
675	7-May-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	20:22	21:05	0:43	HAND TRIPPED
676	7-May-2021	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGI_66	19:45 (7.05.2021)			MAIN SUPPLY FAILURE
677	7-May-2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	22:03	22:17	0:14	LINE FAULT
678	7-May-2021	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	22:38 (7.05.2021)			MAIN SUPPLY FAILURE
679	7-May-2021	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	22:38	23:35	0:57	MAIN SUPPLY FAILURE
680	7-May-2021	HASSAN	110	BANTWA-KAVOOR	BANTWAL_110	10:00	13:13	3:13	LINE CLEAR AVAILED
681	7-May-2021	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	20:56	22:14	1:18	LINE FAULT
682	7-May-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	6:18	15:33	9:15	LINE CLEAR AVAILED
683	7-May-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:29	11:07	0:38	MAIN SUPPLY FAILURE
684	7-May-2021	HASSAN	110	HV3	MRS MG_220	9:03	13:18	4:15	LINE CLEAR AVAILED
685	7-May-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:27	11:06	0:39	LINE CLEAR AVAILED
686	7-May-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	21:03	21:31	0:28	MAIN SUPPLY FAILURE
687	7-May-2021	HASSAN	110	MRSSHM-MPM	MRS MG_220	19:29(07.05.2021)			LINE OPEN,LINE FAULT
688	7-May-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	20:58	21:24	0:26	LINE FAULT
689	7-May-2021	HASSAN	220	KADUR-DABUSET	KADUR_220	21:43(07.05.2021)			LINE OPEN,LINE FAULT
690	7-May-2021	HASSAN	220	MRSSHM-ANTRSNH	MRS MG_220	15:11	16:05	0:54	LINE FAULT
691	7-May-2021	HASSAN	220	MRSSHM-CHMLR	MRS MG_220	19:30	21:33	2:03	LINE FAULT
692	7-May-2021	HASSAN	220	MRSSHM-HSN4001	MRS MG_220	22:36(07.05.2021)			LINE OPEN,LINE FAULT
693	7-May-2021	HASSAN	220	MRSSHM-HSN4001	MRS MG_220	18:47	22:36	3:49	LINE FAULT
694	7-May-2021	MYSURU	66	AMP SOLAR	HANNUR_66	5:34	6:17	0:42	LINE FAULT
695	7-May-2021	MYSURU	66	HV5	SFCSHIVA_66	14:23 (05/05/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
696	7-May-2021	MYSURU	66	KOPPA-HAMPAPURA	KOPPA_66 BESAGARAHALLI_66	17:42	17:52	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
697	7-May-2021	MYSURU	66	KR PETE 220-BOOKANAKERE	SHEELUNERE_66 GANGIGERE_66 CHINAKURALI_66 BANANGADI_66 BOOKANAKERE_66	23:50	23:56	0:06	LINE FAULT
698	7-May-2021	MYSURU	66	KR PETE 220-MAHADESHWARA	MAHADESHWARAPURA_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI_66 NAGAMANGALA_66	23:33	23:42	0:09	LINE FAULT
699	7-May-2021	MYSURU	66	KR PETE 220-MAHADESHWARA	MAHADESHWARAPURA, G MALLIGERE, GUDDENAHALLI, BOGADHI & NAGAMANGALA	23:44	0:00	0:16	LINE FAULT
700	7-May-2021	MYSURU	66	MADHUVANAHALLI-PG PALYA	PG PALYA_66	13:54	14:03	0:09	LINE FAULT
701	7-May-2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPETE_66 VIRAJPETE_66	14:44	14:49	0:05	LINE FAULT
702	7-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
703	7-May-2021	MYSURU	66	TUBINKERE-MANDYA 2	MANDYA_66 CHIKKA MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGRALL_66 KK HALLI_66	17:41	17:52	0:11	LINE FAULT
704	7-May-2021	MYSURU	66	TUBINKERE-MANDYA 4	MANDYA_66 CHIKKA MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGRALL_66 KK HALLI_66	17:41	17:52	0:11	LINE FAULT
705	7-May-2021	MYSURU	220	KADAKOLA-HV1	KOPPALURU_66 MANDAKALLI_66 DOORA_66 HAMPAPURA_66 HULLAHALLI_66 HURA_66 JAIPUR_66 MYSORESOUTH_66 NANJANGUDU_66 THANDYA_66	15:26	15:50	0:24	LINE FAULT
706	7-May-2021	MYSURU	220	KADAKOLA-HV2	KOPPALURU_66 MANDAKALLI_66 DOORA_66 HAMPAPURA_66 HULLAHALLI_66 HURA_66 JAIPUR_66 MYSORESOUTH_66 NANJANGUDU_66 THANDYA_66	15:26	15:51	0:25	LINE FAULT
707	7-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
708	7-May-2021	MYSURU	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS INTERRUPTED	12:32	14:01	1:29	LINE CLEAR AVAILED
709	7-May-2021	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	11:39	11:59	0:19	LINE FAULT
710	7-May-2021	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	16:41	16:52	0:11	LINE FAULT
711	7-May-2021	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 1	MEGMICON 1_IPP_66	11:19	12:11	0:51	LINE FAULT
712	7-May-2021	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 2	MEGMICON 1_IPP_66	11:19	11:59	0:39	LINE FAULT
713	7-May-2021	TUMKUR	66	H D PURA- CHITRADURGA220	MMCLWINDMILL_IPP_66	17:26	18:09	0:43	LINE FAULT
714	7-May-2021	TUMKUR	66	H D PURA- CHITRADURGA220	MMCLWINDMILL_IPP_66	17:26	18:38	1:12	LINE FAULT
715	7-May-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	10:20	17:52	7:32	LINE CLEAR AVAILED
716	7-May-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:06	11:22	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
717	7-May-2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	7:50	7:58	0:08	LINE FAULT
718	7-May-2021	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	18:19	18:41	0:21	LINE CLEAR AVAILED
719	7-May-2021	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	18:21	18:43	0:22	LINE CLEAR AVAILED
720	7-May-2021	TUMKUR	66	PALLAGATTE66-DVGSOKKE	PALLAGATTE_66	18:52	19:42	0:49	LINE CLEAR AVAILED
721	7-May-2021	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	18:29	18:38	0:08	HAND TRIPPED
722	7-May-2021	TUMKUR	66	SASALUHALLA-MAYAKONDA	SAVALANGA_66	12:15	12:43	0:27	LINE FAULT
723	7-May-2021	TUMKUR	66	SASALUHALLA-MAYAKONDA	SAVALANGA_66	12:50	12:55	0:05	LINE FAULT
724	7-May-2021	TUMKUR	66	TR-1	MADADKERE_66	4:05	4:10	0:05	TRANSFORMER FAULT
725	7-May-2021	TUMKUR	66	TR-1	MATHOD_66	16:22	16:33	0:11	TRANSFORMER FAULT
726	7-May-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	6:02	8:59	2:57	LINE CLEAR AVAILED
727	7-May-2021	TUMKUR	66	TR-1	TUMKUR_66	14:11	15:24	1:13	TRANSFORMER FAULT
728	7-May-2021	TUMKUR	66	TR-2	MALEBENNUR_66	14:46	14:54	0:08	TRANSFORMER FAULT
729	7-May-2021	TUMKUR	66	TR-2	UCHCHANGIDURGA_66	13:28	14:31	1:03	LINE CLEAR AVAILED
730	7-May-2021	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	12:23	13:08	0:44	HAND TRIPPED
731	7-May-2021	TUMKUR	110	HONNAVALLI 110- KADUR110	HONNAVALLI_110	21:39	22:03	0:23	LINE FAULT
732	7-May-2021	TUMKUR	110	TR-1	AMMASANDRA_110	12:55	13:27	0:31	LINE CLEAR AVAILED
733	7-May-2021	TUMKUR	110	TR-1	KALLUR_110	10:22	11:45	1:23	LINE CLEAR AVAILED
734	7-May-2021	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	11:07	13:58	2:50	LINE CLEAR AVAILED
735	7-May-2021	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	15:14	19:41	4:27	TRANSFORMER FAULT
736	7-May-2021	TUMKUR	220	TR-1	KBCROSS_220	11:07	13:58	2:50	LINE CLEAR AVAILED
737	7-May-2021	TUMKUR	220	TR-1	KBCROSS_220	15:14	19:40	4:26	TRANSFORMER FAULT
738	7-May-2021	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI_220	5:18:04 PM(07.05.2020)			TRANSFORMER FAULT
739	8-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
740	8-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TAKKALAKI_110	12:23	13:38	1:15	HAND TRIPPED
741	8-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAREGAL_110	3:09	3:32	0:23	TRANSFORMER FAULT
742	8-May-2021	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(G)	17:21 (07.05.2021)	13:21 (08.05.2021)	20:00	TRANSFORMER FAULT
743	8-May-2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	13:21	13:23	0:02	TRANSFORMER FAULT
744	8-May-2021	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	1:31	1:46	0:15	TRANSFORMER FAULT
745	8-May-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	21:36	21:51	0:15	TRANSFORMER FAULT
746	8-May-2021	BAGALKOT	110	110/33, HV3	MYTRA SOLAR IPP_33, STATION NOT AFFECTED SINDAGI_110	13:22	14:03	0:41	LINE CLEAR AVAILED
747	8-May-2021	BAGALKOT	110	110/33KV, HV4	KALKERI_33, SHESHGERI_33, GUDDADMALLAPUR_33 STATION NOT AFFECTED TILUVALLI_110	9:38	9:55	0:17	LINE CLEAR AVAILED
748	8-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
749	8-May-2021	BAGALKOT	110	BELGAUM220-HUDLI	STATION NOT AFFECTED HUDLI_110	19:38 (08.05.2021)			LINE OPEN, LINE FAULT
750	8-May-2021	BAGALKOT	110	BELGAUM-ANKALAGI	STATION NOT AFFECTED BELGAUM_220	19:31 (08.05.2021)			LINE OPEN, LINE FAULT
751	8-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
752	8-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
753	8-May-2021	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	STATION NOT AFFECTED HIDIKAL 110	9:58	10:06	0:08	HAND TRIPPED
754	8-May-2021	BAGALKOT	110	MUNDAGOD-RAMANAKOPPA(HUBLI)	STATION NOT AFFECTED MUNDAGOD 110	6:24	9:53	3:29	HAND TRIPPED
755	8-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
756	8-May-2021	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON 110	3:30	17:10	13:40	HAND TRIPPED
757	8-May-2021	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON 110	3:30	10:03	6:33	HAND TRIPPED
758	8-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	19:16 (08.05.2021)			LINE OPEN,LINE FAULT
759	8-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM 220	19:51 (08.05.2021)			LINE OPEN,LINE FAULT
760	8-May-2021	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI 220	19:15 (08.05.2021)			LINE OPEN,LINE FAULT
761	8-May-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI 220	19:15 (08.05.2021)			LINE OPEN,LINE FAULT
762	8-May-2021	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI 220	0:08	11:06	10:58	LINE FAULT
763	8-May-2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI 220	0:08	11:06	10:58	LINE FAULT
764	8-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVALIED
765	8-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
766	8-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	14:15 (04.05.2021)			LINE OPEN, LINE CLEAR AVALIED
767	8-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	14:16 (04.05.2021)			LINE OPEN, LINE CLEAR AVALIED
768	8-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
769	8-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVALIED
770	8-May-2021	BENGALURU	66	DB PURA 220 - DG1	AIR(EHT)	18:58	19:29	0:31	LINE FAULT
771	8-May-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN,LINE FAULT
772	8-May-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	8:30	8:48	0:18	LINE FAULT
773	8-May-2021	BENGALURU	66	HOSUR RAMAPURA - NITRALLI	NITRALLI	11:10	11:24	0:14	LINE CLEAR AVALIED
774	8-May-2021	BENGALURU	66	HOSUR RAMAPURA - NITRALLI	NITRALLI	12:45	13:23	0:37	LINE CLEAR AVALIED
775	8-May-2021	BENGALURU	66	HV1	GODURU	4:20	4:23	0:03	MAIN SUPPLY FAILURE
776	8-May-2021	BENGALURU	66	HV1	GODURU	22:40	22:54	0:14	MAIN SUPPLY FAILURE
777	8-May-2021	BENGALURU	66	HV1	GODURU	23:05	23:10	0:05	MAIN SUPPLY FAILURE
778	8-May-2021	BENGALURU	66	HV1	SIDDLAGHATTA	8:27	8:45	0:17	LINE CLEAR AVALIED
779	8-May-2021	BENGALURU	66	HV2	MANCHENAHALLI	15:45	15:50	0:05	LINE CLEAR AVALIED
780	8-May-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	11:00	11:11	0:11	LINE CLEAR AVALIED
781	8-May-2021	BENGALURU	66	KOLAR 220 - BANGARPETE-2	BANGARPETE	11:53	12:02	0:09	LINE FAULT
782	8-May-2021	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, H GOLAHALLI, NANGLI, MUDIYANUR, BAIRAKURU	11:53	12:01	0:08	LINE FAULT
783	8-May-2021	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	22:54(08.05.2021)			LINE OPEN, LINE CLEAR AVALIED
784	8-May-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	19:30	22:25	2:55	MAIN SUPPLY FAILURE
785	8-May-2021	GULBARGA	66	HOSAHALLI-AVADA SLR	HOSAHALLI_66	3:15	3:24	0:09	LINE FAULT
786	8-May-2021	GULBARGA	66	HOSAHALLI-KUDLIGI	HOSAHALLI_66	22:54(08.05.2021)			LINE OPEN, LINE CLEAR AVALIED
787	8-May-2021	GULBARGA	66	HOSAHALLI-SML_WIND	HOSAHALLI_66	3:15	3:24	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
788	8-May-2021	GULBARGA	66	HV1	HANASI_66	16:25	16:30	0:05	TRANSFORMER FAULT
789	8-May-2021	GULBARGA	66	HV2	KUDLIGI_66	19:25	22:30	3:05	TRANSFORMER FAULT
790	8-May-2021	GULBARGA	66	HV2	HANASI_66	4:00	4:15	0:15	TRANSFORMER FAULT
791	8-May-2021	GULBARGA	66	HV3	KUDLIGI_66	12:25	12:55	0:30	TRANSFORMER FAULT
792	8-May-2021	GULBARGA	66	KUDLIGI-ITTAGGI1	KUDLIGI_66	19:30	22:25	2:55	MAIN SUPPLY FAILURE
793	8-May-2021	GULBARGA	110	HV1	HANUMASAGAR_110	17:38	19:48	2:10	LINE CLEAR AVAILED
794	8-May-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	23:15 (7.05.2021)	7:22 (8.05.2021)	8:6 hrs	LINE CHARGED
795	8-May-2021	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	23:15 (7.05.2021)	13:18 (8.05.2021)	13:58 hrs	LINE CHARGED
796	8-May-2021	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	19:59	20:35	0:36	LINE CLEAR AVAILED
797	8-May-2021	HASSAN	66	HV1	MAGGE_66	22:50 (7.05.2021)	0:34 (8.05.2021)	1:43 hrs	TRANSFORMER CHARGED
798	8-May-2021	HASSAN	66	HV1	ALDUR_66	0:13	0:35	0:22	TRANSFORMER FAULT
799	8-May-2021	HASSAN	66	HV1	MAGGE_66	15:45	18:36	2:51	TRANSFORMER FAULT
800	8-May-2021	HASSAN	66	HV1	MAGGE_66	18:43	18:57	0:14	HAND TRIPPED
801	8-May-2021	HASSAN	66	HV1	SAKLESH PURA_66	10:00	10:10	0:10	TRANSFORMER FAULT
802	8-May-2021	HASSAN	66	HV2	MAGGE_66	22:50 (7.05.2021)	0:34 (8.05.2021)	1:43 hrs	TRANSFORMER CHARGED
803	8-May-2021	HASSAN	66	HV2	MAGGE_66	15:45	18:36	2:51	TRANSFORMER FAULT
804	8-May-2021	HASSAN	66	HV2	MAGGE_66	18:43	18:57	0:14	HAND TRIPPED
805	8-May-2021	HASSAN	66	KANDLI-HASSAN	KANDLI_66	23:25 (7.05.2021)	0:15 (8.05.2021)	0:49 hrs	LINE CHARGED
806	8-May-2021	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	23:25 (7.05.2021)	0:30 (8.05.2021)	1:04 hrs	LINE CHARGED
807	8-May-2021	HASSAN	66	MRSSHM-DVG2	MRS MG_220	20:22 (7.4.2021)	11:12 (08.05.2021)	14:49 hrs	LINE CHARGED
808	8-May-2021	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	22:35 (7.05.2021)	0:25 (8.05.2021)	1:49 hrs	LINE CHARGED
809	8-May-2021	HASSAN	66	SAKALE-HASSAN2	SAKLESH PURA_66	22:35 (7.05.2021)	0:25 (8.05.2021)	1:49 hrs	LINE CHARGED
810	8-May-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	14:55	15:15	0:20	HAND TRIPPED
811	8-May-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	17:34	19:29	1:55	LINE CLEAR AVAILED
812	8-May-2021	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	15:12	19:24	4:12	LINE CLEAR AVAILED
813	8-May-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	11:25	11:32	0:07	HAND TRIPPED
814	8-May-2021	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGI_66	19:45 (7.05.2021)	11:31 (8.05.2021)	15:44 hrs	LINE CHARGED
815	8-May-2021	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	15:15	19:23	4:08	NFBC ISSUED
816	8-May-2021	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	22:38 (7.05.2021)	9:20 (8.05.2021)	10:41 hrs	LINE CHARGED
817	8-May-2021	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	9:29	13:20	3:51	NFBC ISSUED
818	8-May-2021	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	20:02	20:36	0:34	MAIN SUPPLY FAILURE
819	8-May-2021	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	11:05	13:20	2:15	MAIN SUPPLY FAILURE
820	8-May-2021	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	15:05	17:34	2:29	NFBC ISSUED
821	8-May-2021	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	20:02	20:30	0:28	MAIN SUPPLY FAILURE
822	8-May-2021	HASSAN	110	DMKURK-HONNAVALI	DMKURKE_110	0:25	0:45	0:20	MAIN SUPPLY FAILURE
823	8-May-2021	HASSAN	110	DMKURK-HONNAVALI	DMKURKE_110	16:55	17:00	0:05	MAIN SUPPLY FAILURE
824	8-May-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:44	16:50	1:06	MAIN SUPPLY FAILURE
825	8-May-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:44	16:27	0:43	MAIN SUPPLY FAILURE
826	8-May-2021	HASSAN	110	HV1	HULICAL_110	22:52	23:02	0:10	TRANSFORMER FAULT
827	8-May-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:40	16:49	1:09	LINE FAULT
828	8-May-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:40	16:23	0:43	LINE FAULT
829	8-May-2021	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	15:37	16:30	0:53	LINE FAULT
830	8-May-2021	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	15:42	16:25	0:43	LINE FAULT
831	8-May-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	15:42	16:27	0:45	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
832	8-May-2021	HASSAN	110	LPH-MGHE 2	lph_gen	9:49	10:55	1:06	HAND TRIPPED
833	8-May-2021	HASSAN	110	MRSSHM-MPM	MRSMSG_220	19:29(07.05.2021)	00:18(08.05.2021)	4:48 hrs	LINE CHARGED
834	8-May-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	15:49	16:29	0:40	MAIN SUPPLY FAILURE
835	8-May-2021	HASSAN	220	KADUR-DABUSET	KADUR_220	21:43(07.05.2021)	10:13(08.05.2021)	12:29 hrs	LINE CHARGED
836	8-May-2021	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	16:03	16:20	0:17	LINE FAULT
837	8-May-2021	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	16:03	16:40	0:37	LINE FAULT
838	8-May-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:31	16:09	0:38	LINE FAULT
839	8-May-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	16:11	16:35	0:24	LINE FAULT
840	8-May-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	15:31	16:09	0:38	LINE FAULT
841	8-May-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	16:11	16:29	0:18	LINE FAULT
842	8-May-2021	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	22:36(07.05.2021)	10:53(08.05.2021)	12:16 hrs	LINE CHARGED
843	8-May-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	16:03	16:32	0:29	LINE FAULT
844	8-May-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	16:03	16:40	0:37	LINE FAULT
845	8-May-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:32	16:09	0:37	LINE FAULT
846	8-May-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	16:10	16:35	0:25	LINE FAULT
847	8-May-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:32	16:10	0:38	LINE FAULT
848	8-May-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	16:11	16:29	0:18	LINE FAULT
849	8-May-2021	MYSURU	66	AMP SOLAR	HANNUR_66	18:48	19:03	0:15	LINE FAULT
850	8-May-2021	MYSURU	66	HV1	BASARALU_66	20:53	21:12	0:18	HAND TRIPPED
851	8-May-2021	MYSURU	66	HV1	BYLUKUPPE_66	14:09	15:06	0:57	LINE CLEAR AVAILED
852	8-May-2021	MYSURU	66	HV5	SFCSHIVA_66	14:23 (05/05/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
853	8-May-2021	MYSURU	66	KADAKOLA-SARGUR 1	JAYAPURA_66 HAMPAPURA_66	7:02	7:14	0:12	LINE FAULT
854	8-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
855	8-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
856	8-May-2021	TUMKUR	66	ANCHEPALYA 220- HEBBUR	SIRA_66, KALLAMBELLA_66	11:32	14:03	2:31	LINE CLEAR AVAILED
857	8-May-2021	TUMKUR	66	ANCHEPALYA 220- HEBBUR	SIRA_66, KALLAMBELLA_66	14:05	16:48	2:42	LINE CLEAR AVAILED
858	8-May-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	5:06	5:14	0:07	HAND TRIPPED
859	8-May-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:58	13:04	0:05	LINE FAULT
860	8-May-2021	TUMKUR	66	KATTIGE- BEDRUGADDE	KATTIGE-66	14:09	20:41	6:32	NFBC ISSUED
861	8-May-2021	TUMKUR	66	KATTIGE- RENEW WIND IPP	KATTIGE_66	14:09	20:41	6:32	NFBC ISSUED
862	8-May-2021	TUMKUR	66	PAVAGADA 220kv- MADHUGIRI 1	PAVAGADA_220	14:56	15:00	0:03	HAND TRIPPED
863	8-May-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	19:01	19:40	0:38	LINE FAULT
864	8-May-2021	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	19:28	19:40	0:12	HAND TRIPPED
865	8-May-2021	TUMKUR	66	TR-1	MADADKERE_66	9:50	9:54	0:03	TRANSFORMER FAULT
866	8-May-2021	TUMKUR	66	TR-2	MADANAYAKANAHALLI_66	7:11	8:15	1:03	LINE CLEAR AVAILED
867	8-May-2021	TUMKUR	110	HONNAVALI 110- KADUR110	HONNAVALI_110	0:25	0:31	0:06	LINE FAULT
868	9-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
869	9-May-2021	BAGALKOT	110	110/11KV,HV1	KANABARAGI LAYOUT_110	9:14	14:23	5:09	LINE CLEAR AVAILED
870	9-May-2021	BAGALKOT	110	110/11KV,HV2	HUNGUND_110,AMINAGAD_33, KARADI_33,MYTRA SOLAR_33	6:00	6:03	0:03	TRANSFORMER FAULT
871	9-May-2021	BAGALKOT	110	110/11KV,HV2	KANABARAGI LAYOUT_110	15:31	16:38	1:07	LINE CLEAR AVAILED
872	9-May-2021	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110,	9:12	10:03	0:51	LINE CLEAR AVAILED
873	9-May-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	20:03	20:08	0:05	TRANSFORMER FAULT
874	9-May-2021	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	2:02	2:06	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
875	9-May-2021	BAGALKOT	110	110/33KV,HV1	JAMAKHANDI_110,HIPPARAGI_3 3,MADARKHANDI_33,	9:12	10:19	1:07	LINE CLEAR AVAILED
876	9-May-2021	BAGALKOT	110	110/33KV,HV2	JAMAKHANDI_110,HIPPARAGI_3 3,MADARKHANDI_33,	9:12	10:20	1:08	LINE CLEAR AVAILED
877	9-May-2021	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED NARENDRA_220	11:15	12:22	1:07	HAND TRIPPED
878	9-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN, LINE CLEAR AVAILED
879	9-May-2021	BAGALKOT	110	BELGAUM220(MACHE)-BELGAUM	BELGAUM_110	4:19	4:27	0:08	LINE FAULT
880	9-May-2021	BAGALKOT	110	BELGAUM220-BELGAUM110	STATION NOT AFFECTED BELGAUM_220	4:07	4:26	0:19	LINE FAULT
881	9-May-2021	BAGALKOT	110	BELGAUM-ANKALAGI	STATION NOT AFFECTED BELGAUM_220	19:31 (08.05.2021)	4:43 (09.05.2021)	9:12	LINE FAULT
882	9-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN, LINE CLEAR AVAILED
883	9-May-2021	BAGALKOT	110	HATTARAGI-DADDI	STATION NOT AFFECTED HATTARAGI_110	5:23	11:15	5:52	LINE FAULT
884	9-May-2021	BAGALKOT	110	HUDLI-BELGAUM220	STATION NOT AFFECTED HUDLI_110	19:38 (08.05.2021)	8:02 (09.05.2021)	12:24	LINE FAULT
885	9-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT
886	9-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
887	9-May-2021	BAGALKOT	110	SOUDATTI220-SOUDATTI2	STATION NOT AFFECTED SOUDATTI_110	5:34	15:25	9:51	LINE FAULT
888	9-May-2021	BAGALKOT	110	SOUDATTI-ENERCON1	STATION NOT AFFECTED SOUDATTI_110	5:34	5:43	0:09	LINE FAULT
889	9-May-2021	BAGALKOT	110	SOUDATTI-ENERCON2	STATION NOT AFFECTED SOUDATTI_110	5:34	5:43	0:09	LINE FAULT
890	9-May-2021	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED NARENDRA_220	11:15	12:13	0:58	HAND TRIPPED
891	9-May-2021	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED BELGAUM_220	11:00	11:43	0:43	LINE CLEAR AVAILED
892	9-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	19:16 (08.05.2021)	13:14 (09.05.2021)	17:58	LINE FAULT
893	9-May-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	19:51 (08.05.2021)	13:22 (09.05.2021)	17:31	LINE FAULT
894	9-May-2021	BAGALKOT	220	BELGAUM-NAREBNDRA2	STATION NOT AFFECTED BELGAUM_220	5:58	7:00	1:02	LINE FAULT
895	9-May-2021	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	19:15 (08.05.2021)	3:18 (09.05.2021)	8:03	LINE FAULT
896	9-May-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	19:15 (08.05.2021)	3:19 (09.05.2021)	8:04	LINE FAULT
897	9-May-2021	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	17:24	19:57	2:33	LINE FAULT
898	9-May-2021	BAGALKOT	220	HUBLI-NAGZARI1	STATION NOT AFFECTED HUBLI_220	21:10 (09.05.2021)			LINE OPEN, LINE CLEAR AVAILED
899	9-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
900	9-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
901	9-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:15 (04.05.2021)			LINE OPEN, LINE CLEAR AVAILED
902	9-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:16 (04.05.2021)			LINE OPEN, LINE CLEAR AVAILED
903	9-May-2021	BAGALKOT	220	VAJJRAMATTI-KAVATAGI LIS	STATION NOT AFFECTED VAJJRAMATTI_220	0:05	1:53	1:48	LINE FAULT
904	9-May-2021	BAGALKOT	220	VAJJRAMATTI-KAVATAGI LIS	STATION NOT AFFECTED VAJJRAMATTI_220	1:54	2:12	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
905	9-May-2021	BAGALKOT	220	VAJJRAMATTI-KUDAGI1	STATION NOT AFFECTED VAJJRAMATTI 220	0:05	12:52	12:47	LINE FAULT
906	9-May-2021	BAGALKOT	220	VAJJRAMATTI-KUDAGI2	STATION NOT AFFECTED VAJJRAMATTI 220	0:05	13:05	13:00	LINE FAULT
907	9-May-2021	BAGALKOT	220	VAJJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
908	9-May-2021	BAGALKOT	220	VAJJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
909	9-May-2021	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	16:30	16:35	0:05	LOAD CHANGE OVER
910	9-May-2021	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	19:02	19:21	0:19	LINE CLEAR AVAILED
911	9-May-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	19:02	19:21	0:19	LINE CLEAR AVAILED
912	9-May-2021	BENGALURU	66	DOMMASANDRA - KACHAMARANAHALLI	DOMMASANDRA	14:05	14:10	0:05	LOAD CHANGE OVER
913	9-May-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN,LINE FAULT
914	9-May-2021	BENGALURU	66	HV1	ELITA PROMENADE	20:45	22:08	1:23	TRANSFORMER FAULT
915	9-May-2021	BENGALURU	66	HV1	ELITA PROMENADE	22:34	23:59	1:25	TRANSFORMER FAULT
916	9-May-2021	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	11:30	11:35	0:05	LINE CLEAR AVAILED
917	9-May-2021	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	12:40	12:45	0:05	LOAD CHANGE OVER
918	9-May-2021	BENGALURU	66	HV1	SARJAPURA 220	15:00	15:05	0:05	LINE CLEAR AVAILED
919	9-May-2021	BENGALURU	66	HV1	VOLVO	6:39	6:53	0:14	TRANSFORMER FAULT
920	9-May-2021	BENGALURU	66	HV1	KIADB DB PURA 220	15:20	15:42	0:22	LINE CLEAR AVAILED
921	9-May-2021	BENGALURU	66	HV1	ELITA PROMENADE	22:34:00(09/05/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
922	9-May-2021	BENGALURU	66	HV2	BIDADI 220	19:02	19:21	0:19	LINE CLEAR AVAILED
923	9-May-2021	BENGALURU	66	HV2	SARJAPURA 220	12:16	13:02	0:46	MAIN SUPPLY FAILURE
924	9-May-2021	BENGALURU	66	HV2	SARJAPURA 220	15:00	15:05	0:05	LINE CLEAR AVAILED
925	9-May-2021	BENGALURU	66	HV3	BIDADI 220	19:02	19:21	0:19	LINE CLEAR AVAILED
926	9-May-2021	BENGALURU	66	HV3	MANYATHA TECH PARK 220	14:57	15:16	0:19	LINE CLEAR AVAILED
927	9-May-2021	BENGALURU	66	KOLAR 220 - BANGARPETE-2	BANGARPETE	14:08	14:27	0:19	LINE FAULT
928	9-May-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	GOWNIPALLI, ADDAGAL	17:17	17:25	0:07	LINE FAULT
929	9-May-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	9:15	9:22	0:07	LINE FAULT
930	9-May-2021	BENGALURU	66	MANYATHA TECH PARK 220 - HENNUR CROSS	HENNUR CROSS, SHOBHA CITY	14:57	15:16	0:19	LINE CLEAR AVAILED
931	9-May-2021	BENGALURU	66	PRIMAL PROJECT - VIKAS TECH PARK 220	PRIMAL PROJECT	12:15	12:38	0:23	MAIN SUPPLY FAILURE
932	9-May-2021	BENGALURU	66	PRIMAL PROJECT - VIKAS TECH PARK 220	PRIMAL PROJECT	13:00	13:03	0:03	MAIN SUPPLY FAILURE
933	9-May-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:16	13:00	0:44	MAIN SUPPLY FAILURE
934	9-May-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:16	13:08	0:52	MAIN SUPPLY FAILURE
935	9-May-2021	BENGALURU	66	T G HALLI - ANCHEPALYA	T G HALLI	6:00	6:18	0:18	MAIN SUPPLY FAILURE
936	9-May-2021	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	12:15	12:38	0:23	MAIN SUPPLY FAILURE
937	9-May-2021	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	13:00	13:03	0:03	MAIN SUPPLY FAILURE
938	9-May-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:15	12:38	0:23	MAIN SUPPLY FAILURE
939	9-May-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:00	13:03	0:03	MAIN SUPPLY FAILURE
940	9-May-2021	BENGALURU	220	HOODY 220 - MALUR 220	MALUR 220	12:15	13:36	1:21	LINE FAULT
941	9-May-2021	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 220	14:57	15:12	0:15	LINE FAULT
942	9-May-2021	BENGALURU	220	HV1	SARJAPURA 220	12:42	14:50	2:08	TRANSFORMER FAULT
943	9-May-2021	BENGALURU	220	HV2	BIDADI 220	19:02	19:21	0:19	TRANSFORMER FAULT
944	9-May-2021	BENGALURU	220	HV2	SARJAPURA 220	12:16	13:52	1:36	MAIN SUPPLY FAILURE
945	9-May-2021	BENGALURU	220	MANYATHA TECH PARK 220 - HOODY 220	MANYATHA TECH PARK 220	14:57	15:12	0:15	MAIN SUPPLY FAILURE
946	9-May-2021	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	12:16	12:40	0:24	MAIN SUPPLY FAILURE
947	9-May-2021	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	12:15	12:37	0:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
948	9-May-2021	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	22:54(08.05.2021)	3:43(09.05.2021)	4:49 HRS	LINE CHARGED
949	9-May-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	7:05	7:25	0:20	MAIN SUPPLY FAILURE
950	9-May-2021	GULBARGA	66	HOSAHALLI-KUDLIGI	HOSAHALLI_66	22:54(08.05.2021)	3:43(09.05.2021)	4:49 HRS	LINE CHARGED
951	9-May-2021	GULBARGA	66	KUDLIGI-ITTAGGI1	KUDLIGI_66	7:05	7:25	0:20	MAIN SUPPLY FAILURE
952	9-May-2021	GULBARGA	110	HATTI-GAMESHA	HATTI_110	14:38	15:01	0:23	LINE FAULT
953	9-May-2021	GULBARGA	110	HV1	BHALKI_110	18:10	19:20	1:10	LINE CLEAR AVAILED
954	9-May-2021	GULBARGA	110	HV1	KADAGANCHI_110	14:02	14:09	0:07	TRANSFORMER FAULT
955	9-May-2021	GULBARGA	110	HV2	HATTI_110	13:34	13:36	0:02	TRANSFORMER FAULT
956	9-May-2021	GULBARGA	110	HV3	GULBARGA SOUTH_110	11:30	12:20	0:50	LINE CLEAR AVAILED
957	9-May-2021	GULBARGA	110	KAVITAL-MALLAT	KAVITHAL_110	13:25	13:30	0:05	MAIN SUPPLY FAILURE
958	9-May-2021	GULBARGA	110	KAVITAL-MALLAT	KAVITHAL_110	11:00	11:25	0:25	MAIN SUPPLY FAILURE
959	9-May-2021	GULBARGA	110	KAVITAL-MALLAT	KAVITHAL_110	12:50	13:05	0:15	MAIN SUPPLY FAILURE
960	9-May-2021	GULBARGA	110	KAVITAL-SINDHANOOR	KAVITHAL_110	14:10	14:15	0:05	LINE FAULT
961	9-May-2021	GULBARGA	110	YELBURGA-KUKUNOOR	KUKUNOOR_110	21:12	21:25	0:13	LINE FAULT
962	9-May-2021	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	21:12	22:10	0:58	LINE FAULT
963	9-May-2021	HASSAN	66	HV1	HNPURA_66	13:07	13:12	0:05	HAND TRIPPED
964	9-May-2021	HASSAN	66	HV1	SIGEBAGI_66	10:32	11:18	0:46	LINE CLEAR AVAILED
965	9-May-2021	HASSAN	66	HV2	HNPURA_66	13:07	13:12	0:05	HAND TRIPPED
966	9-May-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	17:37	18:30	0:53	MAIN SUPPLY FAILURE
967	9-May-2021	HASSAN	110	HV1	BAIKAMPADI_110	9:54	15:42	5:48	LINE CLEAR AVAILED
968	9-May-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:37	18:30	0:53	LINE FAULT
969	9-May-2021	HASSAN	220	MRSSHM-HSN4001	MRS MG_220	12:36	15:48	3:12	LINE FAULT
970	9-May-2021	MYSURU	66	CR NAGARA-YALANDUR	YALANDUR_66	5:42	6:11	0:29	LINE FAULT
971	9-May-2021	MYSURU	66	HV1	KIRUGAVALU_66	22:41	22:54	0:12	HAND TRIPPED
972	9-May-2021	MYSURU	66	HV2	PONNAMPETE_66	15:45	16:35	0:49	TRANSFORMER FAULT
973	9-May-2021	MYSURU	66	HV5	SFCSHIVA_66	14:23 (05/05/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
974	9-May-2021	MYSURU	66	PONNAMPETE-VIRAJPET	VIRAJPETE_66	15:45	16:25	0:40	LINE FAULT
975	9-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
976	9-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
977	9-May-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:16	12:26	0:10	LINE FAULT
978	9-May-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	5:56	6:06	0:10	LINE FAULT
979	9-May-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:22	11:25	0:03	LINE FAULT
980	9-May-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:56	12:02	0:05	LINE FAULT
981	9-May-2021	TUMKUR	66	TR-1	HDPURA_66	19:52	19:55	0:02	TRANSFORMER FAULT
982	9-May-2021	TUMKUR	66	TR-1	MADADAKERE_66	16:42	16:50	0:08	TRANSFORMER FAULT
983	9-May-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	12:04	12:19	0:14	TRANSFORMER FAULT
984	9-May-2021	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	3:40	7:03	3:22	HAND TRIPPED
985	9-May-2021	TUMKUR	66	TR-2	HONNUDIKE_66	9:36	10:11	0:35	LINE CLEAR AVAILED
986	9-May-2021	TUMKUR	66	TR-2	SASALUHALLA_66	13:10	13:17	0:07	TRANSFORMER FAULT
987	9-May-2021	TUMKUR	66	TR-2	NIDISALE_66	10:26	10:36	0:09	TRANSFORMER FAULT
988	9-May-2021	TUMKUR	66	TR-2	SASALUHALLA_66	13:10	13:17	0:07	TRANSFORMER FAULT
989	9-May-2021	TUMKUR	110	TR-1	KALLUR_110	18:10	19:37	1:27	TRANSFORMER FAULT
990	9-May-2021	TUMKUR	110	TR-2	TIMMANAHALLI_110	6:13	7:27	1:13	TRANSFORMER FAULT
1	10-May-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
2	10-May-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVOIDED
3	10-May-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN, LINE FAULT
4	10-May-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
5	10-May-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVOIDED
6	10-May-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
7	10-May-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN, LINE FAULT
8	10-May-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39(06.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
9	10-May-2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19(20.04.2021)			LINE OPEN, LINE CLEAR AVOIDED
10	10-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	14:15 (04.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
11	10-May-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:16 (04.05.2021)			LINE OPEN, LINE CLEAR AVOIDED
12	10-May-2021	BAGALKOT	220	HUBLI-NAGZARI1	STATION NOT AFFECTED HUBLI_220	21:10 (09.05.2021)	17:45 (10.05.2021)	20:35HRS	LINE CHARGED
13	10-May-2021	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED AMBEWADI_220	13:07	18:33	5:26	LINE CLEAR AVOIDED
14	10-May-2021	BAGALKOT	110	AMBEWADI-NK1	STATION NOT AFFECTED AMBEWADI_220	13:02	13:47	0:45	LINE FAULT
15	10-May-2021	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED AMBEWADI_220	18:51	19:05	0:14	LINE CLEAR AVOIDED
16	10-May-2021	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	11:55	12:17	0:22	LINE FAULT
17	10-May-2021	BAGALKOT	110	AMBEWADI-NK2	STATION NOT AFFECTED AMBEWADI_220	13:02	13:47	0:45	LINE FAULT
18	10-May-2021	BAGALKOT	110	AMBEWADI-SUPA1	STATION NOT AFFECTED AMBEWADI_220	13:08	13:19	0:11	LINE CLEAR AVOIDED
19	10-May-2021	BAGALKOT	110	AMBEWADI-SUPA2	STATION NOT AFFECTED AMBEWADI_220	13:08	13:45	0:37	LINE CLEAR AVOIDED
20	10-May-2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	7:34	8:30	0:56	LINE CLEAR AVOIDED
21	10-May-2021	BAGALKOT	110	BAGALKOT-NEER BUDIHAL(KATARAKI)	NEER BUDIHAL_110	12:42	12:50	0:08	LINE FAULT
22	10-May-2021	BAGALKOT	220	CHIKKODI-KUDUCHI2(GHATAPRBHA2)	STATION NOT AFFECTED CHIKKODI_220	10:41	10:48	0:07	LINE FAULT
23	10-May-2021	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED CHIKKODI_220	10:41	10:47	0:06	TRANSFORMER FAULT
24	10-May-2021	BAGALKOT	220	CHIKKODI-KUDUCHI1(GHATAPRBHA1)	STATION NOT AFFECTED CHIKKODI_220	12:22	12:26	0:04	LINE FAULT
25	10-May-2021	BAGALKOT	220	CHIKKODI-KUDUCHI2(GHATAPRBHA2)	STATION NOT AFFECTED CHIKKODI_220	12:23	12:24	0:01	LINE FAULT
26	10-May-2021	BAGALKOT	220	CHIKKODI-MUGALKOD1(GATP1)	STATION NOT AFFECTED CHIKKODI_220	12:29	12:30	0:01	LINE FAULT
27	10-May-2021	BAGALKOT	220	CHIKKODI-MUGALKOD2(GATP1)	STATION NOT AFFECTED CHIKKODI_220	12:37	12:38	0:01	LINE FAULT
28	10-May-2021	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	19:25	19:35	0:10	LINE FAULT
29	10-May-2021	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	21:48	21:56	0:08	LINE FAULT
30	10-May-2021	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	23:52 (10.05.2021)			LINE OPEN, LINE FAULT
31	10-May-2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	7:31	7:45	0:14	TRANSFORMER FAULT
32	10-May-2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	17:15	17:23	0:08	TRANSFORMER FAULT
33	10-May-2021	BAGALKOT	110	CHIKKODI-BHOJ	BHOJ_110	10:43	10:55	0:12	LINE FAULT
34	10-May-2021	BAGALKOT	110	HAVERI-HANAGAL(TILUVALI)	HANAGAL_110	18:18 (10.05.2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
35	10-May-2021	BAGALKOT	110	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	13:38	19:57	6:19	LINE FAULT
36	10-May-2021	BAGALKOT	110	110/11KV,HV1(HV4)	HUKKERI_110	17:30	17:33	0:03	TRANSFORMER FAULT
37	10-May-2021	BAGALKOT	110	JAMAKHANDI- SIDDAPUR(PRABHULINGESHWAR)	STATION NOT AFFECTED JAMAKHANDI_110	15:03	19:58	4:55	LINE CLEAR AVALIED
38	10-May-2021	BAGALKOT	110	110/33KV,HV1	JAMAKHANDI_110,HIPPARAGI_3 3	19:47	20:01	0:14	TRANSFORMER FAULT
39	10-May-2021	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	11:55	18:29	6:34	LINE FAULT
40	10-May-2021	BAGALKOT	110	110/11KV,HV2	KALAGATAGI_110	13:54	16:21	2:27	LINE CLEAR AVALIED
41	10-May-2021	BAGALKOT	220	BIDNAL-HARTHI2	STATION NOT AFFECTED BIDNAL_220	16:13	18:18	2:05	LINE FAULT
42	10-May-2021	BAGALKOT	220	BIDNAL-HUBLI	STATION NOT AFFECTED BIDNAL_220	18:46 (10.05.2021)			LOAD CURTAILMENT
43	10-May-2021	BAGALKOT	110	VAJJRAMATTI220-KATARKI	KATARKI_110	3:56	4:03	0:07	LINE FAULT
44	10-May-2021	BAGALKOT	110	VAJJRAMATTI220-MANTUR1	MANTUR_110	12:32	12:43	0:11	LINE FAULT
45	10-May-2021	BAGALKOT	110	VAJJRAMATTI220-MANTUR1	MANTUR_110	13:54	14:05	0:11	LINE FAULT
46	10-May-2021	BAGALKOT	110	VAJJRAMATTI220-MANTUR2	MANTUR_110	13:57	14:05	0:08	LINE FAULT
47	10-May-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED UGARKHOD_110	4:00	4:10	0:10	TRANSFORMER FAULT
48	10-May-2021	BAGALKOT	110	SHIRHATTI-BPCL	BPCL IPP_110 STATION NOT AFFECTED SHIRHATTI_110	19:01	19:48	0:47	LINE FAULT
49	10-May-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SAVALAGI_110	11:11	11:30	0:19	HAND TRIPPED
50	10-May-2021	BAGALKOT	110	RON-GAJENDRAGAD1	GAJENDRAGAD_110	18:00	18:25	0:25	HAND TRIPPED
51	10-May-2021	BAGALKOT	110	RON-GAJENDRAGAD2	GAJENDRAGAD_110	18:00	18:25	0:25	HAND TRIPPED
52	10-May-2021	BAGALKOT	110	RON-BELAVANKI	BELAVANKI_110	18:00	18:25	0:25	HAND TRIPPED
53	10-May-2021	BAGALKOT	110	RON-GAMESH	GAMESH IPP_110 RON_110	18:00	18:25	0:25	HAND TRIPPED
54	10-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAREGAL_110	10:45	12:33	1:48	TRANSFORMER FAULT
55	10-May-2021	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	18:02	18:25	0:23	HAND TRIPPED
56	10-May-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	18:06	18:41	0:35	LINE FAULT
57	10-May-2021	BAGALKOT	110	MUDEDEBIHAL-BAGEWADI220	MUDEDEBIHAL_110	19:25	19:47	0:22	LINE FAULT
58	10-May-2021	BAGALKOT	110	MUDEDEBIHAL-BAGEWADI220	MUDEDEBIHAL_110	21:49	22:07	0:18	LINE FAULT
59	10-May-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LOKAPUR_110	22:05	22:18	0:13	TRANSFORMER FAULT
60	10-May-2021	BAGALKOT	110	110/33KV, HV3	BATKURKI_33, RSSKN_33 STATION NOT AFFECTED LOKAPUR_110	18:56	18:57	0:01	TRANSFORMER FAULT
61	10-May-2021	BAGALKOT	110	110/33KV, HV3	MMCL IPP_33 STATION NOT AFFECTED LAKSHMESHVAR_110	16:15	17:42	1:27	TRANSFORMER FAULT
62	10-May-2021	BAGALKOT	110	KIRUVATTI-AMBEWADI220(SIRSI)	STATION NOT AFFECTED KIRUVATTI_110	18:16	20:09	1:53	LINE FAULT
63	10-May-2021	BAGALKOT	220	HUBLI-NAGZARI2	STATION NOT AFFECTED HUBLI_220	13:02	17:28	4:26	LINE FAULT
64	10-May-2021	BAGALKOT	220	HUBLI-NAGZARI3	STATION NOT AFFECTED HUBLI_220	13:01	15:49	2:48	LINE FAULT
65	10-May-2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	18:07 (10.05.2021)			LINE OPEN,LINE FAULT
66	10-May-2021	BENGALURU	66	A STATION 66 - A STATION 220	A STATION 66	21:10	21:14	0:04	MAIN SUPPLY FAILURE
67	10-May-2021	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	21:10	21:14	0:04	MAIN SUPPLY FAILURE
68	10-May-2021	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	21:10	21:14	0:04	MAIN SUPPLY FAILURE
69	10-May-2021	BENGALURU	220	HV1	BIDADI 220	18:30	18:42	0:12	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
70	10-May-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	18:30	18:50	0:20	LINE CLEAR AVAILED
71	10-May-2021	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	18:30	18:50	0:20	LINE CLEAR AVAILED
72	10-May-2021	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	18:30	18:50	0:20	LINE CLEAR AVAILED
73	10-May-2021	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	18:30	18:50	0:20	LINE CLEAR AVAILED
74	10-May-2021	BENGALURU	66	HV1	BIDADI 220	18:30	18:45	0:15	LINE CLEAR AVAILED
75	10-May-2021	BENGALURU	66	HV2	BIDADI 220	18:30	18:45	0:15	LINE CLEAR AVAILED
76	10-May-2021	BENGALURU	66	HV3	BIDADI 220	18:30	18:45	0:15	LINE CLEAR AVAILED
77	10-May-2021	BENGALURU	220	HV1	BIDADI 220	21:02	21:32	0:30	TRANSFORMER FAULT
78	10-May-2021	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	21:02	21:20	0:18	LINE CLEAR AVAILED
79	10-May-2021	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	21:02	21:20	0:18	LINE CLEAR AVAILED
80	10-May-2021	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	21:02	21:20	0:18	LINE CLEAR AVAILED
81	10-May-2021	BENGALURU	66	HV1	BIDADI 220	21:02	21:20	0:18	LINE CLEAR AVAILED
82	10-May-2021	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	21:10	21:30	0:20	MAIN SUPPLY FAILURE
83	10-May-2021	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	21:10	22:45	1:35	MAIN SUPPLY FAILURE
84	10-May-2021	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	21:10	22:45	1:35	MAIN SUPPLY FAILURE
85	10-May-2021	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA	22:32	22:43	0:11	LOAD CHANGE OVER
86	10-May-2021	BENGALURU	220	KHODAYS 220 - SOMANAHALLI 220	KHODAYS 220	16:44	16:58	0:14	MAIN SUPPLY FAILURE
87	10-May-2021	BENGALURU	66	KHODAYS 220 - ANJANAPURA	ANJANAPURA	16:44	17:07	0:23	LINE CLEAR AVAILED
88	10-May-2021	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	16:44	17:07	0:23	LINE CLEAR AVAILED
89	10-May-2021	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	16:44	17:07	0:23	LINE CLEAR AVAILED
90	10-May-2021	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	16:44	17:07	0:23	LINE CLEAR AVAILED
91	10-May-2021	BENGALURU	220	KHODAYS 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	16:44	17:05	0:21	LINE FAULT
92	10-May-2021	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN	NO STATION AFFECTED	12:26	13:28	1:02	LINE FAULT
93	10-May-2021	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K & C VALLEY	16:25	16:48	0:23	LINE FAULT
94	10-May-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	21:10	21:17	0:07	MAIN SUPPLY FAILURE
95	10-May-2021	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	23:02	23:08	0:06	LOAD CHANGE OVER
96	10-May-2021	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	21:10	21:33	0:23	MAIN SUPPLY FAILURE
97	10-May-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	21:10	21:37	0:27	LINE CLEAR AVAILED
98	10-May-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	21:10	21:37	0:27	LINE CLEAR AVAILED
99	10-May-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	21:10	21:45	0:35	LINE CLEAR AVAILED
100	10-May-2021	BENGALURU	66	PLATINUM CITY - ATTUR	PLATINUM CITY, WELCAST	14:29	14:50	0:21	MAIN SUPPLY FAILURE
101	10-May-2021	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	17:00	17:07	0:07	LOAD CHANGE OVER
102	10-May-2021	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	14:59	16:24	1:25	LINE FAULT
103	10-May-2021	BENGALURU	66	ATTUR YELAHANKA - DG 4	NO STATION AFFECTED	14:59	15:47	0:48	LINE FAULT
104	10-May-2021	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	16:46	17:04	0:18	MAIN SUPPLY FAILURE
105	10-May-2021	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	21:59	22:04	0:05	LOAD CHANGE OVER
106	10-May-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	21:10	21:30	0:20	MAIN SUPPLY FAILURE
107	10-May-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	22:50	23:08	0:18	LOAD CHANGE OVER
108	10-May-2021	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 2	SRS PEENYA 220	21:10	21:45	0:35	MAIN SUPPLY FAILURE
109	10-May-2021	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	SRS PEENYA 220	21:10	21:45	0:35	MAIN SUPPLY FAILURE
110	10-May-2021	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 4	SRS PEENYA 220	21:10	21:45	0:35	MAIN SUPPLY FAILURE
111	10-May-2021	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 1	SRS PEENYA 220	21:10	21:45	0:35	LINE FAULT
112	10-May-2021	BENGALURU	66	SRS PEENYA 220 - BMRCL (EHT)	BMRCL (EHT)	21:10	21:45	0:35	LINE CLEAR AVAILED
113	10-May-2021	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC, NELAMANGALA 66	21:10	22:13	1:03	LINE CLEAR AVAILED
114	10-May-2021	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	21:10	22:04	0:54	LINE CLEAR AVAILED
115	10-May-2021	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	21:10	22:04	0:54	LINE CLEAR AVAILED
116	10-May-2021	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALLI	21:10	22:19	1:09	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
117	10-May-2021	BENGALURU	66	SRS PEENYA 220 - NELAKADRINAHALLI	NELAKADRINAHALLI	21:10	22:14	1:04	LINE CLEAR AVAILED
118	10-May-2021	BENGALURU	66	SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	21:10	22:14	1:04	LINE CLEAR AVAILED
119	10-May-2021	BENGALURU	220	SUBRAMANYAPURA 220 - KHODAYS 220	SUBRAMANYAPURA 220	16:44	17:05	0:21	MAIN SUPPLY FAILURE
120	10-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	16:44	17:08	0:24	LINE CLEAR AVAILED
121	10-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	16:44	17:08	0:24	LINE CLEAR AVAILED
122	10-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - PADMANABHANAGAR	PADMANABHANAGAR	16:44	17:08	0:24	LINE CLEAR AVAILED
123	10-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	16:44	17:08	0:24	LINE CLEAR AVAILED
124	10-May-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	16:44	17:08	0:24	LINE CLEAR AVAILED
125	10-May-2021	BENGALURU	66	T K HALLI 220 - SIMSHA	T K HALLI 220	14:34	14:58	0:24	LINE FAULT
126	10-May-2021	BENGALURU	66	T K HALLI 220 - SIMSHA	T K HALLI 220	18:12	18:25	0:13	LINE FAULT
127	10-May-2021	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHNAGAR, YEDUMADU	14:10	14:25	0:15	LINE FAULT
128	10-May-2021	BENGALURU	220	SOMANAHALLI 220 - SUBRAMANYAPURA 220	KHODAYS 220, SUBRAMANYAPURA 220	16:44	16:58	0:14	LINE FAULT
129	10-May-2021	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	16:45	16:48	0:03	LOAD CHANGE OVER
130	10-May-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI	11:01	11:15	0:13	LINE FAULT
131	10-May-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	21:09	21:45	0:36	MAIN SUPPLY FAILURE
132	10-May-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	21:09	21:40	0:31	MAIN SUPPLY FAILURE
133	10-May-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	21:09	21:40	0:31	MAIN SUPPLY FAILURE
134	10-May-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	21:09	21:46	0:37	MAIN SUPPLY FAILURE
135	10-May-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	21:09	21:48	0:38	MAIN SUPPLY FAILURE
136	10-May-2021	BENGALURU	220	DB PURA 220 - NELAMANGALA 1	DB PURA 220	21:09	21:47	0:37	MAIN SUPPLY FAILURE
137	10-May-2021	BENGALURU	220	DB PURA 220 - NELAMANGALA 2	DB PURA 220	21:09	22:27	1:18	MAIN SUPPLY FAILURE
138	10-May-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	21:09	21:44	0:35	MAIN SUPPLY FAILURE
139	10-May-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:09	21:13	0:04	LINE FAULT
140	10-May-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	21:09	21:15	0:06	LINE FAULT
141	10-May-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	10:23	10:32	0:08	LINE FAULT
142	10-May-2021	BENGALURU	66	HV1	KUTAGALU	11:11	12:15	1:03	LINE CLEAR AVAILED
143	10-May-2021	BENGALURU	220	NELMANGALA 400 - DB PURA 1	DB PURA 220	21:09	21:47	0:37	LINE FAULT
144	10-May-2021	BENGALURU	220	NELMANGALA 400 - DB PURA 1	DB PURA 220	21:09	21:47	0:37	LINE FAULT
145	10-May-2021	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 2	SRS PEENYA 220	21:09	21:46	0:36	LINE FAULT
146	10-May-2021	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 3	SRS PEENYA 220	21:09	21:45	0:35	LINE FAULT
147	10-May-2021	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 4	NRS 220	21:09	21:45	0:35	LINE FAULT
148	10-May-2021	BENGALURU	220	NELAMANGALA 400 - YELAHANKA 220	NO STATION AFFECTED	21:09	21:49	0:39	LINE FAULT
149	10-May-2021	BENGALURU	220	NELAMANGALA 400 - ANCHEPALYA 1	ANCHEPALYA 220	21:09	21:57	0:47	LINE FAULT
150	10-May-2021	BENGALURU	220	NELAMANGALA 400 - ANCHEPALYA 2	MAGADI 220	21:09	21:57	0:47	LINE FAULT
151	10-May-2021	BENGALURU	220	NELAMANGALA 400 - DABUSPET 220	DABUSPET 220	21:09	21:49	0:39	LINE FAULT
152	10-May-2021	BENGALURU	400	HV1	NELMANGALA 400	21:09	21:44	0:34	TRANSFORMER FAULT
153	10-May-2021	BENGALURU	400	HV2	NELMANGALA 400	21:09	21:44	0:34	TRANSFORMER FAULT
154	10-May-2021	BENGALURU	400	HV3	NELMANGALA 400	21:09	21:49	0:39	TRANSFORMER FAULT
155	10-May-2021	BENGALURU	66	TG HALLI - ANCHEPALYA 220	TG HALLI 220	21:09	22:06	0:06	MAIN SUPPLY FAILURE
156	10-May-2021	BENGALURU	66	HV1	ELITA PROMENADE	22:34:00(09/05/2021)	00:08(10/05/2021)	1:44HRS	TRANSFORMER CHARGED
157	10-May-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)	14:18(10/05/2021)	240:09HRS	LINE CHARGED
158	10-May-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	NO STATION AFFECTED	21:02:00(10/05/2021)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
159	10-May-2021	GULBARGA	220	HV1	HALBARGA_220	7:18	7:26	0:08	LINE CLEAR AVAILED
160	10-May-2021	GULBARGA	220	HV1	HALBARGA_220	15:35	15:50	0:15	LINE CLEAR AVAILED
161	10-May-2021	GULBARGA	110	HV2	BISIHALLI_110	10:30	10:35	0:05	TRANSFORMER FAULT
162	10-May-2021	GULBARGA	110	HV3	KOLHAR_110	19:30	19:35	0:05	TRANSFORMER FAULT
163	10-May-2021	GULBARGA	110	HV3	KOLHAR_110	20:20	20:25	0:05	TRANSFORMER FAULT
164	10-May-2021	GULBARGA	110	HV3	KOLHAR_110	20:50	20:55	0:05	TRANSFORMER FAULT
165	10-May-2021	GULBARGA	110	KEREHALLI-TALATATAI_IPP	KEREHALLI_110	18:30	21:45	3:15	LINE CLEAR AVAILED
166	10-May-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	5:36	5:50	0:14	LINE FAULT
167	10-May-2021	GULBARGA	110	MALLAT-BAGEWADI2	MADLAPUR_110,MANVI_110	19:42	20:18	0:36	LINE FAULT
168	10-May-2021	GULBARGA	110	MUNIRABAD-SINDHNOOR2	KAMPLI_110,KPC_IPP,MUKUNDA_110,KEREHALLI_110,MALLAPUR A_110	16:04	16:12	0:08	LINE FAULT
169	10-May-2021	GULBARGA	110	SHAHABAD-NALWAR	NALWAR_110	18:20	18:40	0:20	LINE FAULT
170	10-May-2021	GULBARGA	110	NALWAR-SHAHAPUR	SHAHAPUR_110	18:20	18:40	0:20	LINE FAULT
171	10-May-2021	GULBARGA	110	NALWAR-CLNSLR_IPP	NALWAR_110	11:00	11:10	0:10	LINE FAULT
172	10-May-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	10:17	10:22	0:05	LINE CLEAR AVAILED
173	10-May-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	10:43	14:43	4:00	LINE CLEAR AVAILED
174	10-May-2021	GULBARGA	110	HV2	YELBURGA_110	19:40	20:20	0:40	LINE CLEAR AVAILED
175	10-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	14:40	16:05	1:25	LINE FAULT
176	10-May-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	23:21	23:26	0:05	LINE FAULT
177	10-May-2021	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110	17:35	19:10	1:35	MAIN SUPPLY FAILURE
178	10-May-2021	GULBARGA	66	GUDEKOTE-HANAGAL	HANGAL_66	13:00(10.5.21)			LINE OPEN,LINE FAULT
179	10-May-2021	GULBARGA	66	HV1	CHORNOOR_66	10:45	10:50	0:05	TRANSFORMER FAULT
180	10-May-2021	GULBARGA	66	HV1	CHORNOOR_66	18:35	18:40	0:05	TRANSFORMER FAULT
181	10-May-2021	GULBARGA	66	HV1	CHORNOOR_66	18:50	18:55	0:05	TRANSFORMER FAULT
182	10-May-2021	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66	14:50	15:00	0:10	MAIN SUPPLY FAILURE
183	10-May-2021	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	16:40	16:45	0:05	LINE FAULT
184	10-May-2021	GULBARGA	66	MUNIRABAD-HANASI	HANASI_66	16:40	20:00	3:20	LINE FAULT
185	10-May-2021	GULBARGA	66	HOSAHALLI-SMLWIND_IPP	HOSAHALLI_66	13:00	13:10	0:10	LINE FAULT
186	10-May-2021	GULBARGA	66	CJHALLI-HOSAHALLI	HOSAHALLI_66	14:45	15:00	0:15	MAIN SUPPLY FAILURE
187	10-May-2021	GULBARGA	66	KOTTUR-UJJAINI	UJJAINI_66	13:50	14:05	0:15	LINE FAULT
188	10-May-2021	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	14:09	16:17	2:08	LINE FAULT
189	10-May-2021	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:41	15:34	5:53	LINE CLEAR AVAILED
190	10-May-2021	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	16:25	19:00	2:35	LINE FAULT
191	10-May-2021	HASSAN	220	SHRAVITY-SHIMOGA1	sharavathy_gen	14:09	16:17	2:08	LINE FAULT
192	10-May-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	9:41	15:36	5:55	LINE CLEAR AVAILED
193	10-May-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	16:25	19:00	2:35	LINE FAULT
194	10-May-2021	HASSAN	110	HV2	ANANDPURA_110	11:49	12:40	0:51	LINE CLEAR AVAILED
195	10-May-2021	HASSAN	110	HV2	ANANDPURA_110	14:45	18:59	4:14	LINE CLEAR AVAILED
196	10-May-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	16:07	17:06	0:59	MAIN SUPPLY FAILURE
197	10-May-2021	HASSAN	110	HOSNGD-VTRG1	HOSANAGADI_110	16:10	16:40	0:30	LINE FAULT
198	10-May-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:07	17:05	0:58	LINE FAULT
199	10-May-2021	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	16:23	17:14	0:51	LINE FAULT
200	10-May-2021	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	21:21	21:40	0:19	LINE FAULT
201	10-May-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	21:11	21:31	0:20	LINE FAULT
202	10-May-2021	HASSAN	66	HV2	HASSAN_66	19:00	19:07	0:07	TRANSFORMER FAULT
203	10-May-2021	HASSAN	66	HV1	HNPURA_66	12:02	13:21	1:19	LINE CLEAR AVAILED
204	10-May-2021	HASSAN	66	HV2	HNPURA_66	13:28	15:16	1:48	LINE CLEAR AVAILED
205	10-May-2021	HASSAN	66	HV1	MAGGE_66	11:00	12:59	1:59	LINE CLEAR AVAILED
206	10-May-2021	HASSAN	66	HV2	MAGGE_66	11:00	12:59	1:59	LINE CLEAR AVAILED
207	10-May-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	9:14	18:25	9:11	LINE CLEAR AVAILED
208	10-May-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	9:14	18:25	9:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
209	10-May-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	10:01	10:23	0:22	LINE CLEAR AVAILED
210	10-May-2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	20:38	21:50	1:12	LINE FAULT
211	10-May-2021	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	9:17	18:16	8:59	LINE FAULT
212	10-May-2021	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	8:28	8:40	0:12	LINE FAULT
213	10-May-2021	MYSURU	66	HV1	ARAKERE_66	9:07	9:12	0:04	TRANSFORMER FAULT
214	10-May-2021	MYSURU	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	21:40	22:20	0:40	HAND TRIPPED
215	10-May-2021	MYSURU	66	HD KOTE-TARAKA	NO STATIONS INTERRUPTED	16:40	16:52	0:12	LINE FAULT
216	10-May-2021	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS INTERRUPTED	10:56	11:25	0:29	NFBC ISSUED
217	10-May-2021	MYSURU	66	KRPETE 220-KRPET 1	KRPET_66 AKKIHEBBAL_66 AND KIKKERI_66	23:46	23:56	0:10	LINE FAULT
218	10-May-2021	MYSURU	66	KRPETE 220-KRPET 2	KRPET_66 AKKIHEBBAL_66 AND KIKKERI_66	23:46	23:56	0:10	LINE FAULT
219	10-May-2021	MYSURU	66	HV1	MADDUR_66	12:19	12:28	0:09	TRANSFORMER FAULT
220	10-May-2021	MYSURU	66	PERIAPATNA-HUNSUR	KAMPALAPURA_66	9:22	9:29	0:07	LINE FAULT
221	10-May-2021	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS INTERRUPTED	14:22	14:30	0:07	LINE FAULT
222	10-May-2021	MYSURU	66	HV5	SFCSHIVA_66	14:23 (05/05/2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
223	10-May-2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN, LINE CLEAR AVAILED
224	10-May-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN, LINE CLEAR AVAILED
225	10-May-2021	MYSURU	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	11:38 (10/05/2021)			LINE OPEN, LINE CLEAR AVAILED
226	10-May-2021	TUMKUR	220	ANCHEPALYA 220KV- NELMANGALA 1	ANCHEPALYA_220	21:07	22:13	1:06	MAIN SUPPLY FAILURE
227	10-May-2021	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	2:12	3:32	1:20	LINE FAULT
228	10-May-2021	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALI_110	2:12	3:33	1:20	LINE FAULT
229	10-May-2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	19:24	20:16	0:52	TRANSFORMER FAULT
230	10-May-2021	TUMKUR	110	TR-1	KBCROSS_220	15:26(10.5.2021)			LINE OPEN, LINE CLEAR AVAILED
231	10-May-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	17:36	18:08	0:31	LINE FAULT
232	10-May-2021	TUMKUR	66	TR-1	BRAHMASANDRA_66	13:23	13:47	0:23	LINE CLEAR AVAILED
233	10-May-2021	TUMKUR	66	TR-1	HDPURA_66	9:59	10:02	0:02	TRANSFORMER FAULT
234	10-May-2021	TUMKUR	66	TR-1	HDPURA_66	11:04	11:06	0:02	TRANSFORMER FAULT
235	10-May-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELA GUNDA_66	9:28	9:43	0:14	LINE FAULT
236	10-May-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	13:35	15:39	2:03	LINE CLEAR AVAILED
237	10-May-2021	TUMKUR	66	PAVAGADA_220-NAGALMADIKE	PAVAGADA_220	5:15	5:22	0:07	LINE FAULT
238	10-May-2021	TUMKUR	66	SASALUHALLA-MAYAKONDA	SAVALANGA_66	12:35	19:47	7:12	LINE CLEAR AVAILED
239	10-May-2021	TUMKUR	66	SASALUHALLA-CHIKKAJAJUR	SASALUHALLA_66	16:09	18:26	2:17	LINE FAULT
240	10-May-2021	TUMKUR	66	TR-1	SASALUHALLA_66	16:09	18:29	2:19	HAND TRIPPED
241	10-May-2021	TUMKUR	66	TR-2	SASALUHALLA_66	16:09	18:29	2:19	HAND TRIPPED
242	10-May-2021	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	17:42	18:25	0:42	MAIN SUPPLY FAILURE
243	10-May-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- BELLAVI	BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	5:27	5:49	0:22	LINE FAULT
244	10-May-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- BELLAVI	BELLAVI_66,MALLASANDRA_66, HEGGERE_66, DODDASARANGI_66	12:31	16:43	4:12	LINE CLEAR AVAILED