

400/220/110/66 kV TRANSMISSION OUTAGES FROM 14 TO 20 SEPTEMBER 2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	14-Sep-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVALIED
2	14-Sep-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
3	14-Sep-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVALIED
4	14-Sep-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVALIED
5	14-Sep-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
6	14-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
7	14-Sep-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVALIED
8	14-Sep-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
9	14-Sep-21	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:12 (29.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
10	14-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVALIED
11	14-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVALIED
12	14-Sep-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVALIED
13	14-Sep-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVALIED
14	14-Sep-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	14:07	17:42	3:35	LINE FAULT
15	14-Sep-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK2)	STATION NOT AFFECTED AMBEWADI_220	16:16	17:43	1:27	LINE CLEAR AVALIED
16	14-Sep-21	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	13:08 (14.09.2021)			LINE OPEN: LINE CLEAR AVALIED
17	14-Sep-21	BAGALKOT	110	MUGALKHOD-RAIBAG1	STATION NOT AFFECTED MUGALKHOD_220	19:00	19:28	0:28	LINE FAULT
18	14-Sep-21	BAGALKOT	110	110/11KV,HV1	MANTUR_110	6:20	6:26	0:06	TRANSFORMER FAULT
19	14-Sep-21	BAGALKOT	110	110/11KV,HV1	MANTUR_110	6:35	7:05	0:30	TRANSFORMER FAULT
20	14-Sep-21	BAGALKOT	110	110/11KV,HV2	MANTUR(GHP)_110	6:20	7:19	0:59	TRANSFORMER FAULT
21	14-Sep-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	11:25	16:13	4:48	LINE CLEAR AVALIED
22	14-Sep-21	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	11:22	16:13	4:51	LINE CLEAR AVALIED
23	14-Sep-21	BAGALKOT	110	110/33KV, HV2	RATNA CEMENT_33 & KATAWA CEMENT_33 STATION NOT AFFECTED UTTUR_110	11:01	11:18	0:17	LINE CLEAR AVALIED
24	14-Sep-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIRBUR_110	17:59	18:09	0:10	HAND TRIPPED
25	14-Sep-21	BAGALKOT	110	RAIBAG-MUGALKHOD1(ITNAL)	STATION NOT AFFECTED RAIBAG_110	19:00	19:30	0:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
26	14-Sep-21	BAGALKOT	110	MK HUBLI-KITTUR(NARENDRA)	STATION NOT AFFECTED MK HUBLI_110	10:48	13:24	2:36	LINE CLEAR AVAILED
27	14-Sep-21	BAGALKOT	110	110/33KV, HV3	MMCL_33, SSM_33 STATION NOT AFFECTED LAKSHMESHWAR_110	8:30	8:55	0:25	TRANSFORMER FAULT
28	14-Sep-21	BAGALKOT	110	HANAGAL-HAVERI220	HANAGAL_110	23:16	23:32	0:16	LINE FAULT
29	14-Sep-21	BAGALKOT	220	220/110KV, HV1 & LV1	STATION NOT AFFECTED KUDACHI_220	14:52	15:28	0:36	LINE CLEAR AVAILED
30	14-Sep-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED GOKAK_110	13:33	13:50	0:17	TRANSFORMER FAULT
31	14-Sep-21	BAGALKOT	110	SIRSI220-KAVALWADA	SIRSI_220	19:05 (09.09.2021)			LINE OPEN: LINE CLEAR AVAILED
32	14-Sep-21	BAGALKOT	110	SIRSI220-UMMACHAGI	SIRSI_220	09:06 (10.09.2021)			LINE OPEN: LINE CLEAR AVAILED
33	14-Sep-21	BAGALKOT	110	UAS-NARENDRA	UAS_110	13:40	13:43	0:03	HAND TRIPPED
34	14-Sep-21	BAGALKOT	110	UAS-MR NAGAR	UAS_110	13:40	13:43	0:03	HAND TRIPPED
35	14-Sep-21	BAGALKOT	110	110/11KV,HV1	SHIROL_110	7:40	7:50	0:10	LINE CLEAR AVAILED
36	14-Sep-21	BAGALKOT	110	110/11KV,HV1	KATARAKI_110	12:05	12:55	0:50	LINE CLEAR AVAILED
37	14-Sep-21	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	11:02 (14.09.2021)			LINE OPEN: LINE CLEAR AVAILED
38	14-Sep-21	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	11:02 (14.09.2021)			LINE OPEN: LINE CLEAR AVAILED
39	14-Sep-21	BAGALKOT	110	INDI220-INDI	STATION NOT AFFECTED INDI_220	11:23	12:13	0:50	LINE CLEAR AVAILED
40	14-Sep-21	BAGALKOT	110	INDI220-LACHYAN	STATION NOT AFFECTED INDI_220	11:23	12:13	0:50	LINE CLEAR AVAILED
41	14-Sep-21	BENGALURU	66	ATTUR YELAHANKA - DG3	ABBIGERE, WELCAST	8:36	9:12	0:36	LINE FAULT
42	14-Sep-21	BENGALURU	66	ATTUR YELAHANKA - SRS PEENYA 220	ABBIGERE, WELCAST	9:53	9:58	0:05	LOAD CHANGE OVER
43	14-Sep-21	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	21:48	21:53	0:05	LOAD CHANGE OVER
44	14-Sep-21	BENGALURU	66	HV1	AMAR JYOTHI	8:51	8:56	0:05	LOAD CHANGE OVER
45	14-Sep-21	BENGALURU	66	HV1	AMAR JYOTHI	14:11	14:12	0:01	LINE CLEAR AVAILED
46	14-Sep-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	5:16	5:23	0:07	LOAD CHANGE OVER
47	14-Sep-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	21:00	21:07	0:07	LOAD CHANGE OVER
48	14-Sep-21	BENGALURU	66	HV2	BRIGADE METROPOLIS	15:45	15:50	0:05	LINE CLEAR AVAILED
49	14-Sep-21	BENGALURU	66	HV1	GOLF LINK	12:58	14:09	1:11	LINE CLEAR AVAILED
50	14-Sep-21	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	10:18	10:23	0:05	LOAD CHANGE OVER
51	14-Sep-21	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	1:54	2:01	0:07	LOAD CHANGE OVER
52	14-Sep-21	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	NO STATION AFFECTED	2:14	3:38	1:24	LINE FAULT
53	14-Sep-21	BENGALURU	220	MANYATHA TECH PARK 220 - HOODY 220	NO STATION AFFECTED	2:14	2:53	0:39	LINE FAULT
54	14-Sep-21	BENGALURU	66	HV2	NRS 220	21:25	21:28	0:03	LOAD CHANGE OVER
55	14-Sep-21	BENGALURU	66	HV2	TELECOM LAYOUT	8:32	8:52	0:20	LINE CLEAR AVAILED
56	14-Sep-21	BENGALURU	66	HBR LAYOUT -L R BANDE	HBR LAYOUT	5:14	5:18	0:04	LOAD CHANGE OVER
57	14-Sep-21	BENGALURU	66	POTTERY ROAD - ITI 220	POTTERY ROAD	10:02	15:03	5:01	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
58	14-Sep-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	9:35	9:43	0:08	LINE FAULT
59	14-Sep-21	BENGALURU	66	HV1	ATTIBELE	8:05	8:10	0:05	LOAD CHANGE OVER
60	14-Sep-21	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE, SOMENAHALLI	14:12	16:37	2:25	LINE CLEAR AVAILED
61	14-Sep-21	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALI	14:12	16:35	2:23	LINE CLEAR AVAILED
62	14-Sep-21	BENGALURU	66	GOWRIBIDANUR 220 - AFTL (IPP)	NO STATIONS AFFECTED	14:12	16:34	2:22	LINE CLEAR AVAILED
63	14-Sep-21	BENGALURU	220	HV3	GOWRIBIDANUR 220	14:13	16:30	2:17	LINE CLEAR AVAILED
64	14-Sep-21	BENGALURU	66	HV1	KAMASAMUDRA	7:35	7:56	0:21	TRANSFORMER FAULT
65	14-Sep-21	BENGALURU	66	HV1	MITTEMARI 220	17:02	17:06	0:04	TRANSFORMER FAULT
66	14-Sep-21	BENGALURU	66	T G HALLI - TAVAREKERE	TAVAREKERE	23:08	23:24	0:16	LINE FAULT
67	14-Sep-21	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR, BAGEPALLI	9:50	9:55	0:05	LINE FAULT
68	14-Sep-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	19:04(13/09/2021)	2:12(14/09/2021)	7:08 HRS	LINE CHARGED
69	14-Sep-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	17:34(10.09.2021)			LINE OPEN: LINE CLEAR AVAILED
70	14-Sep-21	GULBARGA	400	BPS-PAVGADA	PAVGADA_400	14:04	14:30	0:26	LINE CLEAR AVAILED
71	14-Sep-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
72	14-Sep-21	GULBARGA	220	HUMNABAD-KAPNOOR2	HUMNABAD_220	15:48	18:11	2:23	NFBC ISSUED
73	14-Sep-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	14:10	17:44	3:34	LINE CLEAR AVAILED
74	14-Sep-21	GULBARGA	220	HV1	SHAHABAD_220	14:25	16:50	2:25	TRANSFORMER FAULT
75	14-Sep-21	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	21:55	22:05	0:10	LINE FAULT
76	14-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
77	14-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
78	14-Sep-21	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
79	14-Sep-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	22:02(14.09.2021)			LINE OPEN: LINE FAULT
80	14-Sep-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	1:05	1:15	0:10	LINE FAULT
81	14-Sep-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	11:25	12:35	1:10	LINE CLEAR AVAILED
82	14-Sep-21	GULBARGA	110	SINDHANORR-SIRGUPPA	DHADESUGUR_110,SIRGUPPA_110,TEK KALKOTE_110,NSL SUGAR_IPP	21:25	21:35	0:10	LINE FAULT
83	14-Sep-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:45	23:01	0:16	LINE FAULT
84	14-Sep-21	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	5:47	6:57	1:10	LINE FAULT
85	14-Sep-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	22:49	22:59	0:10	LINE FAULT
86	14-Sep-21	GULBARGA	110	LV1 & LV2	SHAHAPUR_220	3:26	3:57	0:31	TRANSFORMER FAULT
87	14-Sep-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	4:03	4:21	0:18	LINE FAULT
88	14-Sep-21	GULBARGA	110	SHAHABAD-WADI	WADI_110	14:25	21:10	6:45	LINE FAULT
89	14-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	18:40	18:50	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
90	14-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	18:40	18:50	0:10	LINE FAULT
91	14-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GABBUR_110,DEODURGA_110,GOOGLE_110	19:34	19:40	0:06	LINE FAULT
92	14-Sep-21	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	23:41	23:50	0:09	LINE FAULT
93	14-Sep-21	GULBARGA	110	HV2	MANTHAL_110	18:50	19:15	0:25	LINE CLEAR AVAILED
94	14-Sep-21	GULBARGA	110	HV2	TEKKALKOTE_110	7:40	7:50	0:10	TRANSFORMER FAULT
95	14-Sep-21	GULBARGA	110	TEKKALKOTE-SINDHANOOR	TEKKALKOTE_110	19:50	20:05	0:15	LINE FAULT
96	14-Sep-21	GULBARGA	110	HV1	TEKKALKOTE_110	19:50			TRANSFORMER OPEN: LINE CLEAR AVAILED
97	14-Sep-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	14:20	14:59	0:39	LINE FAULT
98	14-Sep-21	GULBARGA	110	HV1	MANVI_110	0:23	0:28	0:05	TRANSFORMER FAULT
99	14-Sep-21	GULBARGA	110	HV1	MANVI_110	0:31	0:36	0:05	TRANSFORMER FAULT
100	14-Sep-21	GULBARGA	110	HV3	HATTI_110	12:41	12:44	0:03	TRANSFORMER FAULT
101	14-Sep-21	GULBARGA	110	HV4	AFZALPUR_110	16:36	16:45	0:09	TRANSFORMER FAULT
102	14-Sep-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
103	14-Sep-21	HASSAN	220	MRSSHM-DVG2	MRSMG_220	17:08 (30.08.2021)			LINE OPEN: LINE CLEAR AVAILED
104	14-Sep-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	19:56(13.9.2021)	17:47(14.09.2021)	21:50 hrs	LINE CHARGED
105	14-Sep-21	HASSAN	110	HV2	ESSUR_110	14:47	15:38	0:51	LINE CLEAR AVAILED
106	14-Sep-21	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	4:02	4:07	0:05	LINE FAULT
107	14-Sep-21	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	4:07	4:55	0:48	LINE FAULT
108	14-Sep-21	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	4:55	6:05	1:10	LINE FAULT
109	14-Sep-21	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	6:05	6:53	0:48	LINE FAULT
110	14-Sep-21	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	6:55	7:05	0:10	LINE FAULT
111	14-Sep-21	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	11:28	11:38	0:10	LINE FAULT
112	14-Sep-21	HASSAN	66	HV1	NAGARTHI_66	14:30	14:51	0:21	TRANSFORMER FAULT
113	14-Sep-21	MYSURU	220	HV1	HOOTAGALLI_220	10:54	13:07	2:13	LINE CLEAR AVAILED
114	14-Sep-21	MYSURU	66	HV1	BASARALU_66	12:16	12:41	0:24	HAND TRIPPED
115	14-Sep-21	MYSURU	66	HV2	DATAGALLI_66	15:56	16:46	0:49	LINE CLEAR AVAILED
116	14-Sep-21	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	9:25	13:29	4:03	LINE CLEAR AVAILED
117	14-Sep-21	MYSURU	66	HV2	HAMPAPURA_66	13:00	15:55	2:55	LINE CLEAR AVAILED
118	14-Sep-21	MYSURU	66	HV1	HAMPAPURA_66	13:00	14:05	1:05	LINE CLEAR AVAILED
119	14-Sep-21	MYSURU	66	HV1	HAMPAPURA_66	14:30	15:32	1:02	LINE CLEAR AVAILED
120	14-Sep-21	MYSURU	66	HV2	HAMPAPURA_66	17:08	17:35	0:26	LINE CLEAR AVAILED
121	14-Sep-21	MYSURU	66	HV2	HAMPAPURA_66	18:08	18:21	0:13	HAND TRIPPED
122	14-Sep-21	MYSURU	66	HV2	HAMPAPURA_66	18:21	19:48	1:27	LINE CLEAR AVAILED
123	14-Sep-21	MYSURU	66	JYOTHINAGARA-FTS	BANNIMANTAP_66 VIJAYANAGARA_66	11:51	12:05	0:14	LINE FAULT
124	14-Sep-21	MYSURU	66	KUSHALNAGARA-MYSORE 1	MIRLE_66	8:22	9:33	1:11	LINE CLEAR AVAILED
125	14-Sep-21	MYSURU	66	KUSHALNAGARA-MYSORE 1	MIRLE_66	23:32	23:44	0:12	LINE FAULT
126	14-Sep-21	MYSURU	66	HV2	SB HALLI_66	12:11	13:03	0:52	TRANSFORMER FAULT
127	14-Sep-21	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	7:19	19:27	12:08	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
128	14-Sep-21	MYSURU	66	HV1	YALANDUR_66	12:50	14:38	1:48	LINE CLEAR AVAILED
129	14-Sep-21	MYSURU	66	HV2	YALANDUR_66	10:54	12:52	1:58	LINE CLEAR AVAILED
130	14-Sep-21	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN: LINE CLEAR AVAILED
131	14-Sep-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN: LINE CLEAR AVAILED
132	14-Sep-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
133	14-Sep-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
134	14-Sep-21	MYSURU	66	KR NAGARA-CHUNCHUNKATTE	NO STATIONS EFFECTED	16:41 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
135	14-Sep-21	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:15 (14.9.2021)			LINE OPEN: LINE CLEAR AVAILED
136	14-Sep-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:37	15:32	3:54	NFBC ISSUED
137	14-Sep-21	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:37	15:33	3:56	LINE CLEAR AVAILED
138	14-Sep-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:01	15:39	3:38	LINE CLEAR AVAILED
139	14-Sep-21	TUMKUR	66	CHITRADURGA 220kV- HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	10:43	17:58	7:15	LINE CLEAR AVAILED
140	14-Sep-21	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	3:49	4:04	0:14	LINE FAULT
141	14-Sep-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:42	9:50	0:08	LINE FAULT
142	14-Sep-21	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	ENERCON1_IPP_66	9:31	9:38	0:06	HAND TRIPPED
143	14-Sep-21	TUMKUR	66	TR-1	NIDSALE_66	13:40	14:11	0:30	LINE CLEAR AVAILED
144	14-Sep-21	TUMKUR	66	TR-1	PATNAYAKANAHALLI_66	8:42	8:45	0:03	HAND TRIPPED
145	14-Sep-21	TUMKUR	66	TR-1	PATNAYAKANAHALLI_66	12:20	15:09	2:48	LINE CLEAR AVAILED
146	14-Sep-21	TUMKUR	66	TR-2	PATNAYAKANAHALLI_66	8:42	8:45	0:03	HAND TRIPPED
147	14-Sep-21	TUMKUR	66	TR-2	PATNAYAKANAHALLI_66	12:20	12:30	0:10	LINE CLEAR AVAILED
148	14-Sep-21	TUMKUR	66	TR-2	PAVAGADA_66	2:50	3:08	0:17	TRANSFORMER FAULT
149	14-Sep-21	TUMKUR	66	PAVAGADA 220kV- SHYLA PURA	SHYLA PURA_66	1:36	1:45	0:08	LINE FAULT
150	14-Sep-21	TUMKUR	66	TR-2	TAVAREKERE(H)_66	11:20	12:11	0:50	LINE CLEAR AVAILED
151	14-Sep-21	TUMKUR	66	TR-1(HV-1)	YADVANI_66	13:39	14:46	1:07	LINE CLEAR AVAILED
152	14-Sep-21	TUMKUR	66	TR-2(HV-2)	YADVANI_66	14:02	14:55	0:52	LINE CLEAR AVAILED
153	14-Sep-21	TUMKUR	66	TR-1(LV-1)	YADVANI_66	14:14	14:46	0:32	LINE CLEAR AVAILED
154	15-Sep-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
155	15-Sep-21	BAGALKOT	110	RANE BENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANE BENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
156	15-Sep-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
157	15-Sep-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
158	15-Sep-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
159	15-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
160	15-Sep-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
161	15-Sep-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
162	15-Sep-21	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:12 (29.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
163	15-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVAILED
164	15-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVAILED
165	15-Sep-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
166	15-Sep-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
167	15-Sep-21	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	13:08 (14.09.2021)			LINE OPEN: LINE CLEAR AVAILED
168	15-Sep-21	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	STATION NOT AFFECTED AMBEWADI_220	13:12	13:52	0:40	LINE FAULT
169	15-Sep-21	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	13:59	16:47	2:48	LINE FAULT
170	15-Sep-21	BAGALKOT	110	ITNAL1-MUGALKOD(HIDIKAL2)	ITNAL_110	9:53	12:07	2:14	LINE CLEAR AVAILED
171	15-Sep-21	BAGALKOT	110	MUGALKHOD-ITNAL1(LN4)	STATION NOT AFFECTED MUGALKHOD_220	9:53	12:07	2:14	NFBC ISSUED
172	15-Sep-21	BAGALKOT	110	110/11KV,HV2	RAIBAG_110	7:01	7:11	0:10	LOAD CURTAILMENT
173	15-Sep-21	BAGALKOT	110	110/11KV,HV2	RAIBAG_110	18:40	18:50	0:10	LOAD CURTAILMENT
174	15-Sep-21	BAGALKOT	110	110/11KV,HV2	GAJENDRAGHAD_110	7:02	7:15	0:13	LOAD CURTAILMENT
175	15-Sep-21	BAGALKOT	110	110/11KV,HV2	GAJENDRAGHAD_110	18:39	18:47	0:08	LOAD CURTAILMENT
176	15-Sep-21	BAGALKOT	110	MUNDARAGI-VIJAYA SUGARS	STATION NOT AFFECTED MUNGARGI_110	13:08	14:25	1:17	LINE CLEAR AVAILED
177	15-Sep-21	BAGALKOT	220	KUDUCHI-ATHANI	STATION NOT AFFECTED KUDUCHI_220	12:22	18:45	6:23	LINE CLEAR AVAILED
178	15-Sep-21	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	7:01	7:10	0:09	LOAD CURTAILMENT
179	15-Sep-21	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	7:33	7:45	0:12	LOAD CURTAILMENT
180	15-Sep-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	7:01	7:33	0:32	LOAD CURTAILMENT
181	15-Sep-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	18:39	18:50	0:11	LOAD CURTAILMENT
182	15-Sep-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	STATION NOT AFFECTED ALBAL_110	6:13	6:25	0:12	LINE FAULT
183	15-Sep-21	BAGALKOT	110	ALBAL-RAY SOLAR	STATION NOT AFFECTED ALBAL_110	6:13	6:27	0:14	LINE FAULT
184	15-Sep-21	BAGALKOT	110	ANKOLA-KUMTA(2)	ANKOLA_110	13:26	14:07	0:41	LINE CLEAR AVAILED
185	15-Sep-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	7:02	7:10	0:08	LOAD CURTAILMENT
186	15-Sep-21	BAGALKOT	110	110/11KV, HV1	ATHARGA_110	18:40	18:52	0:12	LOAD CURTAILMENT
187	15-Sep-21	BAGALKOT	110	110/11KV,HV2	GULEDAGUDDA_110	11:06	12:42	1:36	LINE CLEAR AVAILED
188	15-Sep-21	BAGALKOT	110	BAGALKOT-GULEDAGUDDA	GULEDAGUDDA_110	12:34	12:42	0:08	HAND TRIPPED
189	15-Sep-21	BAGALKOT	110	110/33KV, HV1	PALA_33 HANAGAL_110	6:40	6:54	0:14	LOAD CURTAILMENT
190	15-Sep-21	BAGALKOT	110	110/33KV, HV1	PALA_33 HANAGAL_110	8:00	8:48	0:48	LOAD CURTAILMENT
191	15-Sep-21	BAGALKOT	110	110/33KV, HV3	KOLIGUDDA_33 HIDIKAL_110	18:40	18:46	0:06	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
192	15-Sep-21	BAGALKOT	110	110/33KV, HV3	RUSTUMPUR LIS_33,BGM W/S 1,BGM W/S 2&3 HIDIKAL DAM_110	13:38	16:12	2:34	LINE CLEAR AVAIED
193	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALBAGI_110	7:02	7:13	0:11	LOAD CURTAILMENT
194	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALBAGI_110	18:41	18:49	0:08	LOAD CURTAILMENT
195	15-Sep-21	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	16:01	17:16	1:15	LINE CLEAR AVAIED
196	15-Sep-21	BAGALKOT	110	110/33KV, HV2	KALABILAGI_33, TUNGAL LIS_33, HIREPADASALAGI LIS_33 STATION NOT AFFECTED SAVALAGI_110	7:02	7:33	0:31	LOAD CURTAILMENT
197	15-Sep-21	BAGALKOT	110	110/33KV, HV2	KALABILAGI_33, TUNGAL LIS_33, HIREPADASALAGI LIS_33 STATION NOT AFFECTED SAVALAGI_110	18:40	18:52	0:12	LOAD CURTAILMENT
198	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDUGANUR_110	6:45	6:55	0:10	LOAD CURTAILMENT
199	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDUGANUR_110	7:02	7:10	0:08	LOAD CURTAILMENT
200	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDUGANUR_110	18:40	18:50	0:10	LINE CLEAR AVAIED
201	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDUGANUR_110	19:05	19:40	0:35	LINE CLEAR AVAIED
202	15-Sep-21	BAGALKOT	110	MUKARTIHAL-NIDAGUNDI(BAGEWADI)	NIDAGUNDI_110	16:25	16:36	0:11	LINE FAULT
203	15-Sep-21	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED MUDALAGI_110	10:16	16:52	6:36	LINE CLEAR AVAIED
204	15-Sep-21	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED MUDALAGI_110	17:24	17:32	0:08	HAND TRIPPED
205	15-Sep-21	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED MUDALAGI_110	18:10	18:21	0:11	HAND TRIPPED
206	15-Sep-21	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED MUDALAGI_110	19:38	19:40	0:02	HAND TRIPPED
207	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LAKSHMESHWAR_110	7:01	7:15	0:14	LOAD CURTAILMENT
208	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LAKSHMESHWAR_110	7:33	7:50	0:17	LOAD CURTAILMENT
209	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LAKSHMESHWAR_110	18:38	18:46	0:08	LOAD CURTAILMENT
210	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDALASANGAM_110	7:01	7:15	0:14	LOAD CURTAILMENT
211	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDALASANGAM_110	18:39	19:01	0:22	LOAD CURTAILMENT
212	15-Sep-21	BAGALKOT	110	110/33KV, HV2	AMINAGAD_33, KARADI_33, MYTRA SOLAR_33 STATION NOT AFFECTED HUNAGUND_110	12:41	13:25	0:44	HAND TRIPPED
213	15-Sep-21	BAGALKOT	110	HUNAGUND-KBJNL	KBJNL_110 STATION NOT AFFECTED HUNAGUND_110	12:15	13:02	0:47	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
214	15-Sep-21	BAGALKOT	110	HUNAGUND-KUDALASANGAM(BAGEWADI)	KUDALASANGAM_110 STATION NOT AFFECTED HUNAGUND_110	12:15	13:02	0:47	HAND TRIPPED
215	15-Sep-21	BAGALKOT	110	HUNAGUND-JSW (JINDAL)	JSW(JINDAL)_110 STATION NOT AFFECTED HUNAGUND_110	15:28	16:05	0:37	HAND TRIPPED
216	15-Sep-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HIREKERUR_110	14:58	15:24	0:26	LINE CLEAR AVAILED
217	15-Sep-21	BAGALKOT	110	SIRSI220-KAVALWADA	SIRSI_220	19:05 (09.09.2021)			LINE OPEN: LINE CLEAR AVAILED
218	15-Sep-21	BAGALKOT	110	SIRSI220-UMMACHAGI	SIRSI_220	09:06 (10.09.2021)			LINE OPEN: LINE CLEAR AVAILED
219	15-Sep-21	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	11:02 (14.09.2021)	13:33 (15.09.2021)	26:31HRS	LINE CHARGED
220	15-Sep-21	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	11:02 (14.09.2021)	13:33 (15.09.2021)	26:31HRS	LINE CHARGED
221	15-Sep-21	BAGALKOT	110	GOKAK-MAMADAPUR	GOKAK_110	5:20	5:30	0:10	LINE FAULT
222	15-Sep-21	BAGALKOT	220	220/110KV,HV1,LV1	BAGEWADI_220	12:40	13:14	0:34	LINE CLEAR AVAILED
223	15-Sep-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	5:05	5:07	0:02	LOAD CHANGE OVER
224	15-Sep-21	BENGALURU	66	HV1	EPIP 220	12:38	12:48	0:10	TRANSFORMER FAULT
225	15-Sep-21	BENGALURU	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	11:04	11:11	0:07	LINE CLEAR AVAILED
226	15-Sep-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	10:16	17:26	7:10	LINE CLEAR AVAILED
227	15-Sep-21	BENGALURU	66	HV1	KHODAYS 220	15:09	15:19	0:10	TRANSFORMER FAULT
228	15-Sep-21	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	17:46	17:56	0:10	TRANSFORMER FAULT
229	15-Sep-21	BENGALURU	66	TELECOM LAYOUT - NRS 2	TELECOM LAYOUT	6:18	6:22	0:04	LOAD CHANGE OVER
230	15-Sep-21	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	NO STATION AFFECTED	13:28	13:42	0:14	LINE FAULT
231	15-Sep-21	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	6:13	6:18	0:05	LOAD CHANGE OVER
232	15-Sep-21	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	11:56	12:20	0:24	MAIN SUPPLY FAILURE
233	15-Sep-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	11:40	11:49	0:09	LINE FAULT
234	15-Sep-21	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	18:45	18:50	0:05	LOAD CURTAILMENT
235	15-Sep-21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	18:38	18:49	0:11	LOAD CURTAILMENT
236	15-Sep-21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	18:38	18:49	0:11	LOAD CURTAILMENT
237	15-Sep-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	9:01	9:11	0:10	LINE FAULT
238	15-Sep-21	BENGALURU	66	HV1	HOSKOTE 220	16:32	16:49	0:17	TRANSFORMER FAULT
239	15-Sep-21	BENGALURU	66	HV1	KAMASAMUDRA	6:54	7:03	0:09	TRANSFORMER FAULT
240	15-Sep-21	BENGALURU	66	HV1	KAMASAMUDRA	14:52	14:55	0:03	LINE CLEAR AVAILED
241	15-Sep-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	17:16	17:42	0:26	LINE CLEAR AVAILED
242	15-Sep-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	17:17	17:43	0:26	LINE CLEAR AVAILED
243	15-Sep-21	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	17:21	17:55	0:34	LINE CLEAR AVAILED
244	15-Sep-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	17:18	17:55	0:37	LINE CLEAR AVAILED
245	15-Sep-21	BENGALURU	220	HV3	KOLAR 220	17:20	17:40	0:20	LINE CLEAR AVAILED
246	15-Sep-21	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	17:20	17:55	0:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
247	15-Sep-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	17:21	17:43	0:22	LINE CLEAR AVAILED
248	15-Sep-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	17:21	17:43	0:22	LINE CLEAR AVAILED
249	15-Sep-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	17:23	17:42	0:19	LINE CLEAR AVAILED
250	15-Sep-21	BENGALURU	220	HV1	KOLAR 220	17:24	17:53	0:29	LINE CLEAR AVAILED
251	15-Sep-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	17:23	17:47	0:24	LINE CLEAR AVAILED
252	15-Sep-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:21	18:14	0:53	LINE CLEAR AVAILED
253	15-Sep-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:51	19:43	0:52	LOAD CURTAILMENT
254	15-Sep-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	18:51	19:43	0:52	LOAD CURTAILMENT
255	15-Sep-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:47	20:38	0:51	LOAD CURTAILMENT
256	15-Sep-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	18:58	19:50	0:52	LOAD CURTAILMENT
257	15-Sep-21	BENGALURU	66	HV2	MALLASANDRA	11:00	11:10	0:10	LINE CLEAR AVAILED
258	15-Sep-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	11:56	12:37	0:41	LINE FAULT
259	15-Sep-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	18:04	18:09	0:05	LOAD CHANGE OVER
260	15-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	19:11	20:11	1:00	LOAD CURTAILMENT
261	15-Sep-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	19:15	20:16	1:01	LOAD CURTAILMENT
262	15-Sep-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	19:22	19:30	0:08	LOAD CURTAILMENT
263	15-Sep-21	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	11:55	12:25	0:30	LINE FAULT
264	15-Sep-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:55	12:25	0:30	MAIN SUPPLY FAILURE
265	15-Sep-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:52	12:56	0:04	LOAD CHANGE OVER
266	15-Sep-21	BENGALURU	66	HV1	SARJAPURA 220	11:55	12:25	0:30	MAIN SUPPLY FAILURE
267	15-Sep-21	BENGALURU	66	HV1	SARJAPURA 220	12:52	12:58	0:06	LOAD CHANGE OVER
268	15-Sep-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:55	12:25	0:30	MAIN SUPPLY FAILURE
269	15-Sep-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:52	13:06	0:14	LOAD CHANGE OVER
270	15-Sep-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:55	12:25	0:30	MAIN SUPPLY FAILURE
271	15-Sep-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:52	13:06	0:14	LOAD CHANGE OVER
272	15-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	11:55	12:37	0:42	MAIN SUPPLY FAILURE
273	15-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	11:55	12:37	0:42	MAIN SUPPLY FAILURE
274	15-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:55	12:37	0:42	MAIN SUPPLY FAILURE
275	15-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	11:55	12:37	0:42	MAIN SUPPLY FAILURE
276	15-Sep-21	BENGALURU	66	VIDYANAGARA - HENNUR CROSS	HENNUR CROSS	13:02	14:02	1:00	LINE FAULT
277	15-Sep-21	BENGALURU	66	HAMUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	19:20	19:25	0:05	LOAD CHANGE OVER
278	15-Sep-21	GULBARGA	400	BPS-JSWVL	BPS_400	6:21	9:49	3:28	LINE CLEAR AVAILED
279	15-Sep-21	GULBARGA	220	LINGAPUR-MUNIRABAD TR1	MUNIRABAD_220	8:51	16:01	7:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
280	15-Sep-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
281	15-Sep-21	GULBARGA	220	HV1	MUNIRABAD_220	8:52	16:01	7:09	LINE CLEAR AVAILED
282	15-Sep-21	GULBARGA	220	RAICHUR-JURALA1	RAICHUR_220	11:26	13:40	2:14	LINE FAULT
283	15-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
284	15-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
285	15-Sep-21	GULBARGA	110	HV1	TEKKALKOTE_110	19:50(14.09.2021)	15:20(15.09.2021)	19:30HRS	TRANSFORMER CHARGED
286	15-Sep-21	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
287	15-Sep-21	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	22:02(14.09.2021)	00:28(15.09.2021)	2:20HRS	LINE CHARGED
288	15-Sep-21	GULBARGA	110	HV2	MANTHAL_110	6:45	7:00	0:15	LOAD CURTAILMENT
289	15-Sep-21	GULBARGA	110	HV2	MANTHAL_110	7:33	7:50	0:17	LOAD CURTAILMENT
290	15-Sep-21	GULBARGA	110	HV1	KURKUNTA_110	6:40	6:50	0:10	LOAD CURTAILMENT
291	15-Sep-21	GULBARGA	110	HV1	KURKUNTA_110	7:00	7:05	0:05	LOAD CURTAILMENT
292	15-Sep-21	GULBARGA	110	HV1	KURKUNTA_110	7:33	7:38	0:05	LOAD CURTAILMENT
293	15-Sep-21	GULBARGA	110	HV1	MAHAGOAN_110	6:43	7:07	0:24	LOAD CURTAILMENT
294	15-Sep-21	GULBARGA	110	HV3	YELBURGA_110	7:01	7:21	0:20	LOAD CURTAILMENT
295	15-Sep-21	GULBARGA	110	HV4	YELBURGA_110	6:40	7:05	0:25	LOAD CURTAILMENT
296	15-Sep-21	GULBARGA	110	HV3	CHIDRI_110	7:35	7:40	0:05	TRANSFORMER FAULT
297	15-Sep-21	GULBARGA	110	HV3	CHIDRI_110	6:50	7:25	0:35	TRANSFORMER FAULT
298	15-Sep-21	GULBARGA	110	HV2	CHINCHOLI_110	6:43	7:00	0:17	TRANSFORMER FAULT
299	15-Sep-21	GULBARGA	110	HV1	CHINCHOLI_110	7:33	7:46	0:13	TRANSFORMER FAULT
300	15-Sep-21	GULBARGA	110	HV2	DEODURGA_110	10:30	11:30	1:00	LINE CLEAR AVAILED
301	15-Sep-21	GULBARGA	110	HV2	HATTI_110	12:41	12:43	0:02	TRANSFORMER FAULT
302	15-Sep-21	GULBARGA	110	HV2	HATTI_110	7:00	7:03	0:03	LOAD CURTAILMENT
303	15-Sep-21	GULBARGA	110	HV3	JEEWARGI_110	7:00	7:15	0:15	TRANSFORMER FAULT
304	15-Sep-21	GULBARGA	110	HV3	JEEWARGI_110	7:35	7:55	0:20	TRANSFORMER FAULT
305	15-Sep-21	GULBARGA	110	HV1	AFZALPUR_110	10:55	11:42	0:47	TRANSFORMER FAULT
306	15-Sep-21	GULBARGA	110	MALLAT-BYAGAWAT	BYGAWAT_110,VALAKAMDINNI_110	13:41	13:52	0:11	LINE CLEAR AVAILED
307	15-Sep-21	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	14:04	14:32	0:28	LINE CLEAR AVAILED
308	15-Sep-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	14:58	15:04	0:06	LINE CLEAR AVAILED
309	15-Sep-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	15:15	15:24	0:09	LINE CLEAR AVAILED
310	15-Sep-21	GULBARGA	110	MUNIRABAD-KOPPAL	KOPPAL_110,KIRLOSKAR,HARE KRISHNA,METALLIC,GINIGERA_110,KOPP PAL_110	10:04	14:40	4:36	LINE CLEAR AVAILED
311	15-Sep-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRAWAR_110	22:30	22:35	0:05	LINE CLEAR AVAILED
312	15-Sep-21	GULBARGA	110	JANAWADA-SANTAPUR	JANAWADA_110	19:00	22:00	3:00	LOAD CURTAILMENT
313	15-Sep-21	GULBARGA	110	HV2	JEEWARGI_110	12:20	14:30	2:10	LINE CLEAR AVAILED
314	15-Sep-21	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	16:22	16:52	0:30	LINE FAULT
315	15-Sep-21	GULBARGA	110	SEDAM-GULBARGA LINE -1	MARGUTTI_110,MAHAGOAH_110	10:10	15:30	5:20	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
316	15-Sep-21	GULBARGA	110	MAHAGOAN-KAPNOOR	MAHAGOAN_110	9:52	16:02	6:10	LINE CLEAR AVAILED
317	15-Sep-21	GULBARGA	110	HV2	MANTHAL_110	18:40	19:00	0:20	LOAD CURTAILMENT
318	15-Sep-21	GULBARGA	110	HV1	TEKKALKOTE_110	15:21	15:40	0:19	LINE CLEAR AVAILED
319	15-Sep-21	GULBARGA	110	HV1	TEKKALKOTE_110	18:40	19:00	0:20	LOAD CURTAILMENT
320	15-Sep-21	GULBARGA	110	MARAGUTTI-KAPNOOR	MARGUTTI_110	9:52	10:20	0:28	MAIN SUPPLY FAILURE
321	15-Sep-21	GULBARGA	110	MARAGUTTI-KAPNOOR,HUMNABAD	MARGUTTI_110	10:20	16:02	5:42	LINE CLEAR AVAILED
322	15-Sep-21	GULBARGA	110	HV1	RAJESHWAR_110	18:39	19:00	0:21	LOAD CURTAILMENT
323	15-Sep-21	GULBARGA	110	HV2	RAJESHWAR_110	18:39	18:55	0:16	LOAD CURTAILMENT
324	15-Sep-21	GULBARGA	110	LV1 & LV2	SHAHAPUR_220	3:26	3:36	0:10	TRANSFORMER FAULT
325	15-Sep-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	4:03	4:21	0:18	LINE FAULT
326	15-Sep-21	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110,MARGUTTI_110	9:50	16:02	6:12	NFBC ISSUED
327	15-Sep-21	GULBARGA	66	HV1	SOVENAHALLI_66	7:10	7:20	0:10	TRANSFORMER FAULT
328	15-Sep-21	GULBARGA	66	HV2	TAMBRAHALLI_66	4:00	4:14	0:14	TRANSFORMER FAULT
329	15-Sep-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
330	15-Sep-21	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN: LINE CLEAR AVAILED
331	15-Sep-21	HASSAN	110	JOG110-AMBTR1	JOG_110	13:33(14.09.2021)			LINE OPEN: LINE FAULT
332	15-Sep-21	HASSAN	220	ARSK2-HSN	ARASIKERE_220	10:39	18:37	7:58	LINE FAULT
333	15-Sep-21	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	0:03	5:59	5:56	LINE CLEAR AVAILED
334	15-Sep-21	HASSAN	110	HV1	HALADY_110	6:43	6:54	0:11	LOAD CURTAILMENT
335	15-Sep-21	HASSAN	110	HV1	HALADY_110	7:05	7:20	0:15	LOAD CURTAILMENT
336	15-Sep-21	HASSAN	110	HV1	HALADY_110	7:34	8:10	0:36	LOAD CURTAILMENT
337	15-Sep-21	HASSAN	110	HV1	DMKURKE_110	7:33	7:56	0:23	LOAD CURTAILMENT
338	15-Sep-21	HASSAN	110	HV2	GANDASI_110	6:59	7:15	0:16	LOAD CURTAILMENT
339	15-Sep-21	HASSAN	110	HV2	GANDASI_110	7:33	7:55	0:22	LOAD CURTAILMENT
340	15-Sep-21	HASSAN	110	HV2	GANDASI_110	16:54	17:10	0:16	LOAD CURTAILMENT
341	15-Sep-21	HASSAN	110	HV2	GERUMARA_110	7:33	7:48	0:15	LOAD CURTAILMENT
342	15-Sep-21	HASSAN	110	HV2	GERUMARA_110	16:53	17:14	0:21	LOAD CURTAILMENT
343	15-Sep-21	HASSAN	110	HV1	JAVAGAL_110	7:00	7:10	0:10	LOAD CURTAILMENT
344	15-Sep-21	HASSAN	110	HV1	JAVAGAL_110	7:34	8:00	0:26	LOAD CURTAILMENT
345	15-Sep-21	HASSAN	110	HV1	JAVAGAL_110	18:38	18:58	0:20	LOAD CURTAILMENT
346	15-Sep-21	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:52	13:17	2:25	LINE CLEAR AVAILED
347	15-Sep-21	HASSAN	110	HV1	KONDENALU_110	6:41	7:00	0:19	LOAD CURTAILMENT
348	15-Sep-21	HASSAN	110	HV1	KONDENALU_110	7:01	7:21	0:20	LOAD CURTAILMENT
349	15-Sep-21	HASSAN	110	HV1	KONDENALU_110	7:35	8:07	0:32	LOAD CURTAILMENT
350	15-Sep-21	HASSAN	110	HV1	KONDENALU_110	18:39	18:52	0:13	LOAD CURTAILMENT
351	15-Sep-21	HASSAN	66	HV1	BYACHANAHALLY_66	11:55	12:35	0:40	LINE CLEAR AVAILED
352	15-Sep-21	HASSAN	66	HV1	BYACHANAHALLY_66	13:40	14:40	1:00	LINE CLEAR AVAILED
353	15-Sep-21	HASSAN	66	HV1	HALLYMYSORE_66	7:34	7:40	0:06	LOAD CURTAILMENT
354	15-Sep-21	HASSAN	66	HV1	HALLYMYSORE_66	16:53	17:21	0:28	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
355	15-Sep-21	HASSAN	66	HV2	HALLYMYSORE_66	12:35	17:00	4:25	LINE CLEAR AVAILED
356	15-Sep-21	HASSAN	66	HV1	HANGRANAHALLY_66	7:33	7:47	0:14	LOAD CURTAILMENT
357	15-Sep-21	HASSAN	66	HV1	HANGRANAHALLY_66	16:53	17:05	0:12	LOAD CURTAILMENT
358	15-Sep-21	HASSAN	66	HV1	KUDLIGERE_66	12:49	14:40	1:51	LINE CLEAR AVAILED
359	15-Sep-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:56	11:43	0:47	NFBC ISSUED
360	15-Sep-21	HASSAN	66	HV2	RAMESHWARANAGARA_66	6:41	7:00	0:19	LOAD CURTAILMENT
361	15-Sep-21	HASSAN	66	HV2	RAMESHWARANAGARA_66	7:34	7:51	0:17	LOAD CURTAILMENT
362	15-Sep-21	HASSAN	66	HV2	RAMESHWARANAGARA_66	18:39	19:01	0:22	LOAD CURTAILMENT
363	15-Sep-21	HASSAN	66	HV2	SALAGAME_66	6:41	6:54	0:13	LOAD CURTAILMENT
364	15-Sep-21	HASSAN	66	HV2	SALAGAME_66	7:00	7:32	0:32	LOAD CURTAILMENT
365	15-Sep-21	HASSAN	66	HV2	SALAGAME_66	7:34	7:49	0:15	LOAD CURTAILMENT
366	15-Sep-21	HASSAN	66	HV2	SALAGAME_66	18:39	18:48	0:09	LOAD CURTAILMENT
367	15-Sep-21	HASSAN	66	HV1	S.BELAGOLA_66	18:39	18:51	0:12	LOAD CURTAILMENT
368	15-Sep-21	HASSAN	66	HV2	SINGAPURA_66	7:01	7:10	0:09	LOAD CURTAILMENT
369	15-Sep-21	HASSAN	66	HV1	YESLUR_66	10:59	12:04	1:05	NFBC ISSUED
370	15-Sep-21	HASSAN	66	YESLUR-SNVRSNT	YESLUR_66	10:59	12:04	1:05	NFBC ISSUED
371	15-Sep-21	HASSAN	66	HV2	BASAVAGHATTA_66	7:33	7:41	0:08	LOAD CURTAILMENT
372	15-Sep-21	HASSAN	66	HV2	BASAVAGHATTA_66	16:53	17:08	0:15	LOAD CURTAILMENT
373	15-Sep-21	MYSURU	66	HV2	AKKIHEBBAL_66	6:59	7:10	0:10	LOAD CURTAILMENT
374	15-Sep-21	MYSURU	66	HV2	AKKIHEBBAL_66	7:34	7:44	0:10	LOAD CURTAILMENT
375	15-Sep-21	MYSURU	66	HV2	AKKIHEBBAL_66	16:52	17:02	0:10	LOAD CURTAILMENT
376	15-Sep-21	MYSURU	66	HV1	BGNAGARA_66	6:41	6:48	0:07	LOAD CURTAILMENT
377	15-Sep-21	MYSURU	66	HV1	BGNAGARA_66	7:33	7:42	0:09	LOAD CURTAILMENT
378	15-Sep-21	MYSURU	66	HV1	BILIKERE_66	7:34	7:38	0:04	LOAD CURTAILMENT
379	15-Sep-21	MYSURU	66	HV1	BILIKERE_66	16:53	16:59	0:06	LOAD CURTAILMENT
380	15-Sep-21	MYSURU	66	HV2	BOOKANKERE_66	6:59	7:09	0:09	LOAD CURTAILMENT
381	15-Sep-21	MYSURU	66	HV2	BOOKANKERE_66	7:33	7:37	0:04	LOAD CURTAILMENT
382	15-Sep-21	MYSURU	66	HV2	BOOKANKERE_66	16:53	17:01	0:07	LOAD CURTAILMENT
383	15-Sep-21	MYSURU	66	HV1	BYLUKUPPE_66	12:05	13:12	1:06	LINE CLEAR AVAILED
384	15-Sep-21	MYSURU	66	CR NAGARA-PANNEDUNDI	PANDYADAHUNDI_66 HEMMARGALA_66 KARYA_66	5:53	6:15	0:21	LINE FAULT
385	15-Sep-21	MYSURU	66	DK MAIDANA-VAJMANGLA	NO STATIONS EFFECTED	14:20	15:09	0:48	HAND TRIPPED
386	15-Sep-21	MYSURU	66	HV1	DODDINADUVADI_66	7:33	7:48	0:14	LOAD CURTAILMENT
387	15-Sep-21	MYSURU	66	HV1	DODDINADUVADI_66	16:53	16:57	0:04	LOAD CURTAILMENT
388	15-Sep-21	MYSURU	66	HV2	DODDARAYAPET_66	7:35	7:40	0:05	LOAD CURTAILMENT
389	15-Sep-21	MYSURU	66	HV2	ELAVALA_66	6:59	7:10	0:10	LOAD CURTAILMENT
390	15-Sep-21	MYSURU	66	HV2	ELAVALA_66	7:34	8:01	0:27	LOAD CURTAILMENT
391	15-Sep-21	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	13:36	14:10	0:33	HAND TRIPPED
392	15-Sep-21	MYSURU	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	14:13	14:32	0:18	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
393	15-Sep-21	MYSURU	66	HV1	HAMPAPURA_66	12:55	14:30	1:35	LINE CLEAR AVAILED
394	15-Sep-21	MYSURU	66	HV1	HANAGODU_66	16:53	17:02	0:08	LOAD CURTAILMENT
395	15-Sep-21	MYSURU	66	HV2	HANNUR_66	6:59	7:10	0:10	LOAD CURTAILMENT
396	15-Sep-21	MYSURU	66	HV2	HANNUR_66	7:35	7:44	0:09	LOAD CURTAILMENT
397	15-Sep-21	MYSURU	66	HV2	HANNUR_66	16:53	17:02	0:09	LOAD CURTAILMENT
398	15-Sep-21	MYSURU	66	HV2	HD KOTE_66	7:34	7:47	0:12	LOAD CURTAILMENT
399	15-Sep-21	MYSURU	66	HV2	HD KOTE_66	16:54	17:02	0:07	LOAD CURTAILMENT
400	15-Sep-21	MYSURU	66	HV2	KIRUGAVALU_66	7:00	7:25	0:25	LOAD CURTAILMENT
401	15-Sep-21	MYSURU	66	HV2	KIRUGAVALU_66	7:35	7:57	0:21	LOAD CURTAILMENT
402	15-Sep-21	MYSURU	66	HV2	KIRUGAVALU_66	18:38	19:07	0:28	LOAD CURTAILMENT
403	15-Sep-21	MYSURU	66	HV2	KM DODDI_66	18:38	18:48	0:09	LOAD CURTAILMENT
404	15-Sep-21	MYSURU	66	KR PETE220-SANTEBACHALLI	SANTEBACHALLI_66 HARIYALDAMMATEMPLE_66	16:20	18:05	1:45	LINE CLEAR AVAILED
405	15-Sep-21	MYSURU	66	HV2	MALAVALLI_66	6:41	6:47	0:06	LOAD CURTAILMENT
406	15-Sep-21	MYSURU	66	HV2	MALAVALLI_66	7:00	7:05	0:04	LOAD CURTAILMENT
407	15-Sep-21	MYSURU	66	HV2	MALAVALLI_66	7:34	7:47	0:12	LOAD CURTAILMENT
408	15-Sep-21	MYSURU	66	HV2	MALAVALLI_66	18:38	18:42	0:04	LOAD CURTAILMENT
409	15-Sep-21	MYSURU	66	HV2	MALAVALLI_66	10:50	13:23	2:33	LINE CLEAR AVAILED
410	15-Sep-21	MYSURU	66	HV1	MALAVALLI_66	13:13	15:36	2:23	LINE CLEAR AVAILED
411	15-Sep-21	MYSURU	66	HV1	NAGAMANGLA_66	6:59	7:04	0:04	LOAD CURTAILMENT
412	15-Sep-21	MYSURU	66	HV1	PANDAVAPURA_66	6:41	6:51	0:10	LOAD CURTAILMENT
413	15-Sep-21	MYSURU	66	HV1	PANDAVAPURA_66	7:00	7:11	0:10	LOAD CURTAILMENT
414	15-Sep-21	MYSURU	66	HV1	PANDAVAPURA_66	7:34	7:40	0:06	LOAD CURTAILMENT
415	15-Sep-21	MYSURU	66	HV1	PANDAVAPURA_66	18:38	18:44	0:05	LOAD CURTAILMENT
416	15-Sep-21	MYSURU	66	HV2	SANTHESARAGUR_66	7:00	7:10	0:10	LOAD CURTAILMENT
417	15-Sep-21	MYSURU	66	HV2	SANTHESARAGUR_66	14:30	15:25	0:55	LINE CLEAR AVAILED
418	15-Sep-21	MYSURU	66	HV2	SANTEMARALLI_66	7:00	7:20	0:20	LOAD CURTAILMENT
419	15-Sep-21	MYSURU	66	SHANIVARSANTE-MALIPATNA	YESSLUR_66 SHANIVARSANTE_66 HETTUR_66	10:57	11:50	0:52	LINE CLEAR AVAILED
420	15-Sep-21	MYSURU	66	TUBINKERE-G UKKADA	NO STATIONS EFFECTED	12:13	12:32	0:18	LINE CLEAR AVAILED
421	15-Sep-21	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN: LINE CLEAR AVAILED
422	15-Sep-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN: LINE CLEAR AVAILED
423	15-Sep-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
424	15-Sep-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
425	15-Sep-21	MYSURU	66	KR NAGARA-CHUNCHUNKATTE	NO STATIONS EFFECTED	16:41 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
426	15-Sep-21	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:15 (14.9.2021)			LINE OPEN: LINE CLEAR AVAILED
427	15-Sep-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	10:19	14:25	4:05	LINE CLEAR AVAILED
428	15-Sep-21	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	10:39	18:37	7:58	LINE CLEAR AVAILED
429	15-Sep-21	TUMKUR	220	TR-1	NITTUR_220	10:56	18:17	7:20	LINE CLEAR AVAILED
430	15-Sep-21	TUMKUR	220	TR-2	NITTUR_220	10:56	18:14	7:17	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
431	15-Sep-21	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	10:54	18:14	7:20	LINE CLEAR AVAIED
432	15-Sep-21	TUMKUR	110	TR-1	BIDARE_110	10:01	18:45	8:43	LINE CLEAR AVAIED
433	15-Sep-21	TUMKUR	110	BIDARE- NITTUR-GUBBI	BIDARE_110	10:01	18:45	8:43	LINE CLEAR AVAIED
434	15-Sep-21	TUMKUR	110	TR-2	KADEHALLI_110	13:01	13:39	0:38	LINE CLEAR AVAIED
435	15-Sep-21	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	10:29	18:59	8:30	LINE CLEAR AVAIED
436	15-Sep-21	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	10:26	18:26	8:00	LINE CLEAR AVAIED
437	15-Sep-21	TUMKUR	110	TR-1(HV-1 & LV-1)	NITTUR_220	10:54	18:19	7:25	LINE CLEAR AVAIED
438	15-Sep-21	TUMKUR	110	TR-2(HV-2 & LV-2)	NITTUR_220	10:54	18:44	7:49	LINE CLEAR AVAIED
439	15-Sep-21	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	10:29	18:29	8:00	LINE CLEAR AVAIED
440	15-Sep-21	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	10:26	18:31	8:04	LINE CLEAR AVAIED
441	15-Sep-21	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	10:27	18:33	8:06	LINE CLEAR AVAIED
442	15-Sep-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2(KUDUR)	KUDUR_66, HULLENHALLI_66	19:09	19:22	0:12	LOAD CURTAILMENT
443	15-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	18:31	20:03	1:32	LOAD CURTAILMENT
444	15-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220KV- BELLAVI	BELLAVI_66	18:31	20:03	1:32	LOAD CURTAILMENT
445	15-Sep-21	TUMKUR	66	TR-2	BENNEHALLI_66	6:37	6:45	0:08	TRANSFORMER FAULT
446	15-Sep-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:33	15:43	3:10	LINE CLEAR AVAIED
447	15-Sep-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	0:39	0:45	0:05	LINE FAULT
448	15-Sep-21	TUMKUR	66	TR-1	HANAGAL_66	6:43	6:53	0:10	LOAD CURTAILMENT
449	15-Sep-21	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	13:05	14:28	1:22	LINE CLEAR AVAIED
450	15-Sep-21	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	11:45	12:01	0:16	LINE FAULT
451	15-Sep-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66	22:26	22:36	0:09	LINE FAULT
452	15-Sep-21	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND IPP	19:53	20:13	0:20	HAND TRIPPED
453	15-Sep-21	TUMKUR	66	TR-2	KORA_66	14:58	15:27	0:28	LINE CLEAR AVAIED
454	15-Sep-21	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA(SIRA2)	KALLAMBELLA_66, SIRA_66	18:52	20:00	1:07	LOAD CURTAILMENT
455	15-Sep-21	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66	10:19	18:20	8:01	LINE CLEAR AVAIED
456	15-Sep-21	TUMKUR	66	MADHUGIRI 220kV- SIRA	BUKKAPATNA_66	18:53	20:00	1:07	LOAD CURTAILMENT
457	15-Sep-21	TUMKUR	66	TR-1	PURUVARA_66	11:46	14:01	2:15	LINE CLEAR AVAIED
458	15-Sep-21	TUMKUR	66	TR-2	PULAMGHATTA_66	14:37	14:57	0:19	TRANSFORMER FAULT
459	15-Sep-21	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	19:25	20:06	0:41	LOAD CURTAILMENT
1	16-Sep-21	BAGALKOT	110	110/11KV,HV1	KATARAKI_110	13:15	13:35	0:20	LINE CLEAR AVAIED
2	16-Sep-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:10	15:15	3:05	LINE CLEAR AVAIED
3	16-Sep-21	BAGALKOT	110	DADDI-HATTARAGI	DADDI_110	13:30	13:35	0:05	LINE FAULT
4	16-Sep-21	BAGALKOT	110	DADDI-HATTARAGI	DADDI_110	14:40	14:45	0:05	LINE FAULT
5	16-Sep-21	BAGALKOT	110	DADDI-HATTARAGI	DADDI_110	18:35	18:45	0:10	LINE CLEAR AVAIED
6	16-Sep-21	BAGALKOT	110	GOKAK-MAMDAPUR	GOKAK_110	5:25	5:30	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
7	16-Sep-21	BAGALKOT	110	HIDIKAL-ISLAMPUR	ISLAMPUR_110	5:05	5:35	0:30	MAIN SUPPLY FAILURE
8	16-Sep-21	BAGALKOT	110	HIDIKAL-ISLAMPUR	ISLAMPUR_110	12:10	12:50	0:40	MAIN SUPPLY FAILURE
9	16-Sep-21	BAGALKOT	110	HIDIKAL-ISLAMPUR	ISLAMPUR_110	3:55	4:15	0:20	LINE FAULT
10	16-Sep-21	BAGALKOT	110	SANKESHWAR-HATTARAGI	HATTARAGI_110	18:33	18:43	0:10	LINE CLEAR AVAIED
11	16-Sep-21	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	18:33	18:43	0:10	LINE CLEAR AVAIED
12	16-Sep-21	BAGALKOT	220	RANEBENNUR-GUTTUR	STATION NOT AFFECTED RANEBENNUR_220	9:48	16:41	6:53	NFBC ISSUED
13	16-Sep-21	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	10:19	16:48	6:29	NFBC ISSUED
14	16-Sep-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:35	14:50	1:15	LINE CLEAR AVAIED
15	16-Sep-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT)	11:04	11:24	0:20	LINE FAULT
16	16-Sep-21	BENGALURU	66	HV1	CHANDRA LAYOUT	6:32	6:40	0:08	TRANSFORMER FAULT
17	16-Sep-21	BENGALURU	66	HV1	RAJANUKUNTE	15:40	15:45	0:05	TRANSFORMER FAULT
18	16-Sep-21	BENGALURU	66	HV1	RAJANUKUNTE	19:45	19:50	0:05	TRANSFORMER FAULT
19	16-Sep-21	BENGALURU	66	HV1	CHIKKENAHALLI	8:23	8:48	0:25	LINE CLEAR AVAIED
20	16-Sep-21	BENGALURU	66	HV1	KODIHALLI CHINTAMANI	15:50	16:00	0:10	TRANSFORMER FAULT
21	16-Sep-21	BENGALURU	66	HV1	KEMBODI	12:45	12:55	0:10	LINE CLEAR AVAIED
22	16-Sep-21	BENGALURU	66	HV1	PATH PALYA	12:55	13:50	0:55	LINE CLEAR AVAIED
23	16-Sep-21	BENGALURU	66	HV1	YELAHANKA 220	13:04	13:06	0:01	LINE CLEAR AVAIED
24	16-Sep-21	BENGALURU	66	HV2	ITI 220	19:11	19:38	0:27	TRANSFORMER FAULT
25	16-Sep-21	BENGALURU	66	HV2	DODDABELAVANGALA	13:35	14:50	1:15	TRANSFORMER FAULT
26	16-Sep-21	BENGALURU	66	HV2	IRGAMPALLI	15:10	17:38	2:28	LINE CLEAR AVAIED
27	16-Sep-21	BENGALURU	66	HV2	KODIHALLI CHINTAMANI	15:50	16:00	0:10	TRANSFORMER FAULT
28	16-Sep-21	BENGALURU	66	HV2	KEMBODI	12:55	13:10	0:15	LINE CLEAR AVAIED
29	16-Sep-21	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	NO STATION AFFECTED	5:55	6:18	0:23	LINE FAULT
30	16-Sep-21	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	NO STATION AFFECTED	17:30	17:45	0:14	LINE CLEAR AVAIED
31	16-Sep-21	BENGALURU	66	KODIHALLI - CHINTAMANI 220	KODIHALLI CHINTAMANI	15:50	16:00	0:10	LINE FAULT
32	16-Sep-21	BENGALURU	66	KODIHALLI - SRINIVASPURA	SRINIVASPURA	15:50	16:06	0:16	LINE FAULT
33	16-Sep-21	BENGALURU	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	13:36	14:14	0:37	LINE FAULT
34	16-Sep-21	BENGALURU	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	14:14	15:31	1:17	LINE FAULT
35	16-Sep-21	BENGALURU	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	15:32	18:45	3:12	LINE CLEAR AVAIED
36	16-Sep-21	GULBARGA	66	HV2	HANASI_66	11:46	11:54	0:08	TRANSFORMER FAULT
37	16-Sep-21	GULBARGA	66	MUNIRABAD-MHD	VENKATAPURA_66,RR STEELS_FACTORY,UPHALLI_66	10:11	13:22	3:11	LINE CLEAR AVAIED
38	16-Sep-21	GULBARGA	66	NEELAGUNDA-HARAPANAHALLI	HARAPANAHALLI_110	18:36	18:42	0:06	LINE FAULT
39	16-Sep-21	GULBARGA	110	CHITAGUPPA-HUMNABAD	CHITAGUPPA_110,NIRNA_110,ACME_SL R_IPP	12:30	12:50	0:20	LINE FAULT
40	16-Sep-21	GULBARGA	110	CHITGUPPA-NIRNA	NIRNA_110	12:30	12:55	0:25	MAIN SUPPLY FAILURE
41	16-Sep-21	GULBARGA	110	GURMITKAL-KONKAL	GURMITKAL_110	1:08	1:12	0:04	LINE FAULT
42	16-Sep-21	GULBARGA	110	GURMITKAL-KONKAL	GURMITKAL_110	5:37	5:43	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
43	16-Sep-21	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	21:45	21:50	0:05	LINE FAULT
44	16-Sep-21	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	21:05	21:10	0:05	LINE FAULT
45	16-Sep-21	GULBARGA	110	HV1	JEWARGI_110	11:30	13:25	1:55	LINE CLEAR AVAIED
46	16-Sep-21	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)	00:05(16.09.2021)	372:50 HRS	TRANSFORMER CHARGED
47	16-Sep-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	18:17	18:24	0:07	LINE FAULT
48	16-Sep-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	9:43	13:30	3:47	LINE CLEAR AVAIED
49	16-Sep-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	9:43	13:26	3:43	LINE CLEAR AVAIED
50	16-Sep-21	GULBARGA	110	RAICHUR-APMC1,2	APMC_110,CHIKKASUGUR_110,SHAKTHI NAGA_110	4:11	4:18	0:07	LINE FAULT
51	16-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GABBUR_110,DEODURGA_110,GOOGLE _110	13:35	13:44	0:09	LINE FAULT
52	16-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:22	22:35	0:13	LINE FAULT
53	16-Sep-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	16:22	16:52	0:30	LINE FAULT
54	16-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAIED
55	16-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAIED
56	16-Sep-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRGUPPA_110,TEK KALKOTE_110,NSL SUGAR_IPP	18:22	18:32	0:10	LINE FAULT
57	16-Sep-21	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	0:10	0:40	0:30	MAIN SUPPLY FAILURE
58	16-Sep-21	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	0:43	0:45	0:02	MAIN SUPPLY FAILURE
59	16-Sep-21	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	0:49	0:52	0:03	MAIN SUPPLY FAILURE
60	16-Sep-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED
61	16-Sep-21	GULBARGA	220	HV2	MALLAT_220	12:09	13:10	1:01	LINE CLEAR AVAIED
62	16-Sep-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:12(16.09.2021)			LINE OPEN: LINE CLEAR AVAIED
63	16-Sep-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	1:13	6:32	5:19	LINE CLEAR AVAIED
64	16-Sep-21	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	4:29	6:57	2:28	LINE CLEAR AVAIED
65	16-Sep-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	17:34(10.09.2021)	06:49(16.09.2021)	133:15HRS	LINE CHARGED
66	16-Sep-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:31	14:31	4:00	LINE CLEAR AVAIED
67	16-Sep-21	HASSAN	66	HV1	BALEHONNUR_66	10:35	15:07	4:32	MAIN SUPPLY FAILURE
68	16-Sep-21	HASSAN	66	HV1	KUDLIGERE_66	11:10	17:00	5:50	LINE CLEAR AVAIED
69	16-Sep-21	HASSAN	66	HV2	HALLIMYSORE_66	11:30	11:45	0:15	LOAD CURTAILMENT
70	16-Sep-21	HASSAN	66	HV2	HALLIMYSORE_66	11:50	15:20	3:30	LOAD CURTAILMENT
71	16-Sep-21	HASSAN	66	HV2	RAMNATHPURA_66	12:19	17:31	5:12	LINE CLEAR AVAIED
72	16-Sep-21	HASSAN	66	HV3	BALEHONNUR_66	10:35	15:10	4:35	MAIN SUPPLY FAILURE
73	16-Sep-21	HASSAN	66	HV3	BALEHONNUR_66	10:35	15:07	4:32	MAIN SUPPLY FAILURE
74	16-Sep-21	HASSAN	66	Lv1	HOLENARASIPURA_220	11:01	17:31	6:30	LINE CLEAR AVAIED
75	16-Sep-21	HASSAN	110	JOG110-AMBTR1	JOG_110	13:33(14.09.2021)	11:15(16.09.2021)	45:42hrs	LINE CHARGED
76	16-Sep-21	HASSAN	110	JOG110-AMBTR2	JOG_110	11:15	11:25	0:10	HAND TRIPPED
77	16-Sep-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAIED
78	16-Sep-21	HASSAN	110	LV2	PUTTUR_220	9:43	13:51	4:08	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
79	16-Sep-21	HASSAN	220	HV1	HOLENARASIPURA_220	11:01	17:31	6:30	LINE CLEAR AVAILED
80	16-Sep-21	HASSAN	220	HV2	PUTTUR_220	9:43	13:49	4:06	LINE CLEAR AVAILED
81	16-Sep-21	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN: LINE CLEAR AVAILED
82	16-Sep-21	MYSURU	66	ADDIHALLI-TUBINKERE	ADDIHALLI_66	13:45	14:21	0:36	LINE CLEAR AVAILED
83	16-Sep-21	MYSURU	66	ADDIHALLI-TUBINKERE	ADDIHALLI_66	11:05	11:10	0:05	HAND TRIPPED
84	16-Sep-21	MYSURU	66	ADDIHALLI-TUBINKERE	ADDIHALLI_66	11:50	11:55	0:05	HAND TRIPPED
85	16-Sep-21	MYSURU	66	BANANGADI-CHINKURALI	BANANGADI_66	10:00	18:30	8:30	LINE CLEAR AVAILED
86	16-Sep-21	MYSURU	66	BOGADHI-HOOTAGALLI	NO STATIONS EFFECTED	9:27	9:33	0:06	HAND TRIPPED
87	16-Sep-21	MYSURU	66	BOGADHI-HOOTAGALLI	NO STATIONS EFFECTED	15:26	15:30	0:03	HAND TRIPPED
88	16-Sep-21	MYSURU	66	BOOKANAKERE-CHINKURALI	CHINAKURALI_66	11:13	15:55	4:42	NFBC ISSUED
89	16-Sep-21	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:15 (14.9.2021)			LINE OPEN: LINE CLEAR AVAILED
90	16-Sep-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	13:13	13:24	0:10	LINE FAULT
91	16-Sep-21	MYSURU	66	DB HALLI-TUBINKERE	DODDABYADARAHALLI_66	10:04	17:38	7:34	LINE CLEAR AVAILED
92	16-Sep-21	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	8:40	15:37	6:56	LINE CLEAR AVAILED
93	16-Sep-21	MYSURU	66	G UKKADA-PANDAVAPURA	PANDAVAPURA_66	9:45	17:13	7:27	NFBC ISSUED
94	16-Sep-21	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN: LINE CLEAR AVAILED
95	16-Sep-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
96	16-Sep-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
97	16-Sep-21	MYSURU	66	HV1	HAMPAPURA_66	10:22	13:02	2:40	LINE CLEAR AVAILED
98	16-Sep-21	MYSURU	66	HV2	AKKIHEBBAL_66	7:29	7:45	0:16	TRANSFORMER FAULT
99	16-Sep-21	MYSURU	66	HV2	HAMPAPURA_66	13:02	15:09	2:06	LINE CLEAR AVAILED
100	16-Sep-21	MYSURU	66	KR NAGARA-CHUNCHUNKATTE	NO STATIONS EFFECTED	16:41 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
101	16-Sep-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN: LINE CLEAR AVAILED
102	16-Sep-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	5:42	5:50	0:07	LINE FAULT
103	16-Sep-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	9:40	9:56	0:15	HAND TRIPPED
104	16-Sep-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI_66 BG NAGARA_66 AC GIRI_66 VADERALLI_66	15:21	17:40	2:18	LINE CLEAR AVAILED
105	16-Sep-21	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	10:59	15:44	4:45	LINE CLEAR AVAILED
106	16-Sep-21	MYSURU	220	HV2	HOOTAGALLY_220	11:20	15:15	3:55	LINE CLEAR AVAILED
107	16-Sep-21	MYSURU	220	VAJMANGALA-TKHALI	NO STATIONS EFFECTED	7:36	19:08	11:32	NFBC ISSUED
108	16-Sep-21	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	9:43	9:51	0:07	LINE FAULT
109	16-Sep-21	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	10:47	11:11	0:23	LINE FAULT
110	16-Sep-21	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	15:49	15:53	0:04	LINE FAULT
111	16-Sep-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	7:51	9:35	1:43	LINE FAULT
112	16-Sep-21	TUMKUR	66	TR-1	BADDIHALLI_66	8:41	8:48	0:06	HAND TRIPPED
113	16-Sep-21	TUMKUR	66	TR-1	BHARAMAGIRI_66	7:02	7:12	0:09	TRANSFORMER FAULT
114	16-Sep-21	TUMKUR	66	TR-1	GARAGA_66	12:24	12:38	0:13	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
115	16-Sep-21	TUMKUR	66	TR-1	HARIYABBE_66	13:45	14:01	0:15	LINE CLEAR AVAILED
116	16-Sep-21	TUMKUR	66	TR-1	HIREHALLY_66	7:52	8:02	0:09	HAND TRIPPED
117	16-Sep-21	TUMKUR	66	TR-1	HIREHALLY_66	9:33	9:39	0:05	HAND TRIPPED
118	16-Sep-21	TUMKUR	66	TR-2	BADDIHALLI_66	8:41	8:48	0:07	HAND TRIPPED
119	16-Sep-21	TUMKUR	66	TR-2	BENNEHALLI_66	11:01	11:05	0:03	TRANSFORMER FAULT
120	16-Sep-21	TUMKUR	66	TR-2	BENNEHALLI_66	18:14	18:27	0:12	LINE CLEAR AVAILED
121	16-Sep-21	TUMKUR	66	TR-2	GARAGA_66	12:41	12:46	0:05	LINE CLEAR AVAILED
122	16-Sep-21	TUMKUR	66	TR-2	GARAGA_66	14:00	14:15	0:15	LINE CLEAR AVAILED
123	16-Sep-21	TUMKUR	66	TR-2	GARAGA_66	14:24	14:32	0:08	LINE CLEAR AVAILED
124	16-Sep-21	TUMKUR	66	TR-2	HARIYABBE_66	13:34	14:07	0:32	LINE CLEAR AVAILED
125	16-Sep-21	TUMKUR	66	TR-2	HIREHALLY_66	7:53	8:02	0:09	HAND TRIPPED
126	16-Sep-21	TUMKUR	66	TR-2	HIREHALLY_66	9:33	9:39	0:05	HAND TRIPPED
127	16-Sep-21	TUMKUR	110	TR-2	BANDIHALLI_110	11:08	11:16	0:08	HAND TRIPPED
128	16-Sep-21	TUMKUR	220	TR-2	KIADB V N PURA_220	12:25	12:51	0:26	HAND TRIPPED
1	17-Sep-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
2	17-Sep-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
3	17-Sep-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
4	17-Sep-21	BAGALKOT	110	110/11KV,HV1	KATARAKI_110	11:00	12:15	1:15	LINE CLEAR AVAILED
5	17-Sep-21	BAGALKOT	110	110/11KV,HV1	KUDAL SANGAM_110	15:09	15:54	0:45	LINE CLEAR AVAILED
6	17-Sep-21	BAGALKOT	110	110/11KV,HV1	KAMBAGI_110	8:20	8:25	0:05	TRANSFORMER FAULT
7	17-Sep-21	BAGALKOT	110	110/11KV,HV1	KATARAKI_110	11:00	12:15	1:15	LINE CLEAR AVAILED
8	17-Sep-21	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	11:31	18:52	7:21	LINE CLEAR AVAILED
9	17-Sep-21	BAGALKOT	110	110/11KV,HV2	GOKAK_110	21:33	23:24	1:51	LINE CLEAR AVAILED
10	17-Sep-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	7:50	7:55	0:05	TRANSFORMER FAULT
11	17-Sep-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	9:35	9:40	0:05	TRANSFORMER FAULT
12	17-Sep-21	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	9:32	13:15	3:43	LINE CLEAR AVAILED
13	17-Sep-21	BAGALKOT	110	BANAHATTI-NAVALAGI(JAMAKHANDI)	NAVALAGI_110 JAMAKHANDI_110	13:08	13:27	0:19	LINE FAULT
14	17-Sep-21	BAGALKOT	110	BELGAUM-HONAGA	HONAGA_110	21:45	22:05	0:20	MAIN SUPPLY FAILURE
15	17-Sep-21	BAGALKOT	110	BELGAUM-UCHAGOAN	UCHAGOAN_110	21:48	22:04	0:16	LINE FAULT
16	17-Sep-21	BAGALKOT	110	BELGAUM-UCHAGOAN(HUKKERI)	STATION NOT AFFECTED BELGAUM_220	21:48	22:04	0:16	LINE FAULT
17	17-Sep-21	BAGALKOT	110	BELGAUM-UDYAMBAG	UDYAMBAG_110	21:48	22:04	0:16	LINE FAULT
18	17-Sep-21	BAGALKOT	110	BELLATTI-AB SOLAR	STATION NOT AFFECTED BELLATTI_110	18:53 (16.09.2021)	6:17 (17.09.2021)	11:24 hrs	LINE CHARGED
19	17-Sep-21	BAGALKOT	110	BELLATTI-AB SOLAR	STATION NOT AFFECTED BELLATTI_110	14:04	15:44	1:40	LINE CLEAR AVAILED
20	17-Sep-21	BAGALKOT	110	DAMBAL MUNDARAGI1	DAMBAL_110	5:47	6:45	0:58	LINE FAULT
21	17-Sep-21	BAGALKOT	110	DAMBAL MUNDARAGI2	DAMBAL_110	5:47	8:07	2:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
22	17-Sep-21	BAGALKOT	110	ENERCON-BELLATTI	STATION NOT AFFECTED BELLATTI_110	14:08	15:46	1:38	LINE CLEAR AVAILED
23	17-Sep-21	BAGALKOT	110	GADAG-DAMBAL	DAMBAL_110,SINGATALUR_110	5:46	6:29	0:43	LINE FAULT
24	17-Sep-21	BAGALKOT	110	GADAG-LAXMESHWAR	STATION NOT AFFECTED LAXMESHWAR_110	13:51 (17.09.2021)			LINE OPEN: LINE FAULT
25	17-Sep-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
26	17-Sep-21	BAGALKOT	110	HAVERI220-GUTTUR1	STATION NOT AFFECTED HAVERI_220	9:49	17:50	8:01	NFBC ISSUED
27	17-Sep-21	BAGALKOT	110	HUBLI-BIDNAL2	STATION NOT AFFECTED HUBLI_220	10:09	15:45	5:36	LINE CLEAR AVAILED
28	17-Sep-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY (RAMBAPUR1)	KIADB BIJAPUR_110	14:48	17:05	2:17	LINE CLEAR AVAILED
29	17-Sep-21	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	13:50	15:30	1:40	LINE CLEAR AVAILED
30	17-Sep-21	BAGALKOT	110	LAXMESHWAR-GADAG	STATION NOT AFFECTED GADAG_220	13:51 (17.09.2021)			LINE OPEN: LINE FAULT
31	17-Sep-21	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110	13:27	13:47	0:20	HAND TRIPPED
32	17-Sep-21	BAGALKOT	110	MUNDARAGI-DAMBAL2	MUNDARAGI_110	6:46	8:08	1:22	LINE FAULT
33	17-Sep-21	BAGALKOT	110	MUNDARAGI-SIGATALUR	SINGATALUR_110	11:45	11:50	0:05	MAIN SUPPLY FAILURE
34	17-Sep-21	BAGALKOT	110	MUNDARAGI-VIJAYA SUGARS	MUNDARAGI_110	6:46	9:11	2:25	LINE FAULT
35	17-Sep-21	BAGALKOT	110	RAIBAG-MUGALKHOD220 1&2	STATION NOT AFFECTED RAIBAG_110	8:00	8:09	0:09	HAND TRIPPED
36	17-Sep-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
37	17-Sep-21	BAGALKOT	110	RANNABELAGALI-MAHALINGAPUR220	STATION NOT AFFECTED RANNABELAGALI_110	14:38	17:10	2:32	LINE FAULT
38	17-Sep-21	BAGALKOT	110	SHIRHATTI-BPC1&2	BPCL_110 SHIRHATTI_110	14:44	15:08	0:24	HAND TRIPPED
39	17-Sep-21	BAGALKOT	110	SHIRHATTI-GADAG220	SHIRAHATTI_110	13:43	14:35	0:52	LINE FAULT
40	17-Sep-21	BAGALKOT	110	SHIRHATTI-LAXMESHWAR	LAXMESHWAR_110	14:44	14:58	0:14	HAND TRIPPED
41	17-Sep-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN: LINE CLEAR AVAILED
42	17-Sep-21	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	9:19 (16.09.2021)			LINE OPEN: LINE CLEAR AVAILED
43	17-Sep-21	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	9:19 (16.09.2021)			LINE OPEN: LINE CLEAR AVAILED
44	17-Sep-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN: LINE CLEAR AVAILED
45	17-Sep-21	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	14:51	14:52	0:01	HAND TRIPPED
46	17-Sep-21	BAGALKOT	110	SIRSI-KUMTA2	KUMTA_110	14:52	15:06	0:14	HAND TRIPPED
47	17-Sep-21	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 TAKKALAKI_110	12:13	12:34	0:21	HAND TRIPPED
48	17-Sep-21	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 TAKKALAKI_110	12:13	12:34	0:21	HAND TRIPPED
49	17-Sep-21	BAGALKOT	110	VAJRAMATTI-MUDHOL	STATION NOT AFFECTED VAJRAMATTI_220	15:00	15:05	0:05	HAND TRIPPED
50	17-Sep-21	BAGALKOT	220	AMBEWADI-NARENDRA1	STATION NOT AFFECTED AMBEWADI_220	14:01	14:04	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
51	17-Sep-21	BAGALKOT	220	AMBEWADI-NARENDRA1	STATION NOT AFFECTED AMBEWADI_220	14:57	17:23	2:26	LINE CLEAR AVAILED
52	17-Sep-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
53	17-Sep-21	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	13:08 (14.09.2021)			LINE OPEN: LINE CLEAR AVAILED
54	17-Sep-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
55	17-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	13:56	17:22	3:26	LINE CLEAR AVAILED
56	17-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
57	17-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVAILED
58	17-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVAILED
59	17-Sep-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
60	17-Sep-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
61	17-Sep-21	BAGALKOT	220	VIJAYAPUR-INDI	INDI_220,SAVALSANG_110,DEVARAHIP PARAGI_110,INDI_110,LACHYAN_110,Z ALKI_110,	12:14	12:29	0:15	MAIN SUPPLY FAILURE
62	17-Sep-21	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	12:06	12:22	0:16	MAIN SUPPLY FAILURE
63	17-Sep-21	BENGALURU	66	C STATION - A STATION 220	C STATION	13:01	13:03	0:02	LOAD CHANGE OVER
64	17-Sep-21	BENGALURU	66	C STATION - A STATION 220	C STATION	17:15	17:19	0:04	LOAD CHANGE OVER
65	17-Sep-21	BENGALURU	66	C STATION - HEBBALA 220	C STATION	12:06	12:16	0:10	MAIN SUPPLY FAILURE
66	17-Sep-21	BENGALURU	66	C STATION - HEBBALA 220	C STATION	13:23	13:26	0:03	MAIN SUPPLY FAILURE
67	17-Sep-21	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALIC CROSS, YENNIGADALE, CHELUR, CHAKAVELU	13:02	13:26	0:24	LINE CLEAR AVAILED
68	17-Sep-21	BENGALURU	66	HBR LAYOUT - YELLARBANDE	HBR LAYOUT, BELL CERAMICS (EHT)	19:18	19:21	0:03	LOAD CHANGE OVER
69	17-Sep-21	BENGALURU	66	HEBBALA 220 - LR BANDE	LR BANDE	12:06	12:15	0:09	MAIN SUPPLY FAILURE
70	17-Sep-21	BENGALURU	66	HEBBALA 220 - LR BANDE	LR BANDE	13:23	13:26	0:03	MAIN SUPPLY FAILURE
71	17-Sep-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	16:35	19:13	2:38	LINE FAULT
72	17-Sep-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	18:19	18:23	0:03	LINE CLEAR AVAILED
73	17-Sep-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	16:35	17:05	0:30	LOAD CHANGE OVER
74	17-Sep-21	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	12:06	12:35	0:29	MAIN SUPPLY FAILURE
75	17-Sep-21	BENGALURU	66	HV1	AMAR JYOTHI	11:03	11:06	0:03	LINE CLEAR AVAILED
76	17-Sep-21	BENGALURU	66	HV1	BANASAWADI	12:06	12:13	0:07	MAIN SUPPLY FAILURE
77	17-Sep-21	BENGALURU	66	HV1	BANASAWADI	13:23	13:59	0:36	MAIN SUPPLY FAILURE
78	17-Sep-21	BENGALURU	66	HV1	BANASAWADI	12:54	12:57	0:03	LOAD CHANGE OVER
79	17-Sep-21	BENGALURU	66	HV1	NIMHANS 220	12:08	12:30	0:22	MAIN SUPPLY FAILURE
80	17-Sep-21	BENGALURU	66	HV1	M GOLLAHALLI	12:18	12:39	0:21	TRANSFORMER FAULT
81	17-Sep-21	BENGALURU	66	HV1	KYALANUR	15:54	16:05	0:10	TRANSFORMER FAULT
82	17-Sep-21	BENGALURU	66	HV1	JANGAMKOTE	12:56	14:41	1:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
83	17-Sep-21	BENGALURU	66	HV1	KOLAR 220	17:40	18:25	0:45	MAIN SUPPLY FAILURE
84	17-Sep-21	BENGALURU	66	HV1	KOLAR 220	17:40	18:25	0:45	MAIN SUPPLY FAILURE
85	17-Sep-21	BENGALURU	66	HV2	AMAR JYOTHI	15:40	16:18	0:38	LINE CLEAR AVAILED
86	17-Sep-21	BENGALURU	66	HV2	HSR LAYOUT 220	12:06	12:35	0:29	MAIN SUPPLY FAILURE
87	17-Sep-21	BENGALURU	66	HV2	NIMHANS 220	12:08	12:30	0:22	MAIN SUPPLY FAILURE
88	17-Sep-21	BENGALURU	66	HV2	KOLAR 220	13:51	14:28	0:37	MAIN SUPPLY FAILURE
89	17-Sep-21	BENGALURU	66	HV2	KOLAR 220	13:51	14:28	4:34	MAIN SUPPLY FAILURE
90	17-Sep-21	BENGALURU	66	HV3	BANASAWADI	12:06	12:13	0:07	MAIN SUPPLY FAILURE
91	17-Sep-21	BENGALURU	66	HV3	BANASAWADI	13:23	13:59	0:36	MAIN SUPPLY FAILURE
92	17-Sep-21	BENGALURU	66	HV3	BANASAWADI	12:54	12:57	0:03	LOAD CHANGE OVER
93	17-Sep-21	BENGALURU	66	IISc - HEBBAL 220	IISC	12:06	12:15	0:09	MAIN SUPPLY FAILURE
94	17-Sep-21	BENGALURU	66	IISc - NRS 220	IISC	17:32	17:35	0:03	LOAD CHANGE OVER
95	17-Sep-21	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	12:06	12:19	0:13	MAIN SUPPLY FAILURE
96	17-Sep-21	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	12:06	12:43	0:37	MAIN SUPPLY FAILURE
97	17-Sep-21	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	15:54	15:57	0:03	LOAD CHANGE OVER
98	17-Sep-21	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGAR, NATIONAL COLLEGE	12:06	12:26	0:20	MAIN SUPPLY FAILURE
99	17-Sep-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	13:51	14:28	0:37	MAIN SUPPLY FAILURE
100	17-Sep-21	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	17:40	18:25	2:18	MAIN SUPPLY FAILURE
101	17-Sep-21	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	13:51	14:28	0:37	MAIN SUPPLY FAILURE
102	17-Sep-21	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	17:40	19:58	2:18	MAIN SUPPLY FAILURE
103	17-Sep-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:51	14:28	0:37	MAIN SUPPLY FAILURE
104	17-Sep-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:40	18:25	0:45	MAIN SUPPLY FAILURE
105	17-Sep-21	BENGALURU	66	KORAMANGALA 220 - GOLF LINK 1	GOLF LINK	12:06	12:51	0:45	MAIN SUPPLY FAILURE
106	17-Sep-21	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	12:06	12:51	0:45	MAIN SUPPLY FAILURE
107	17-Sep-21	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	12:55	12:57	0:02	LOAD CHANGE OVER
108	17-Sep-21	BENGALURU	66	LR BANDE - HBR LAYOUT	LR BANDE	16:10	16:13	0:03	LOAD CHANGE OVER
109	17-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	7:29	7:37	0:08	LINE FAULT
110	17-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:01	18:04	8:03	LINE CLEAR AVAILED
111	17-Sep-21	BENGALURU	66	PADMANABHANAGARA - NIMHANS 220	PADMANABHANAGARA	12:06	12:19	0:13	MAIN SUPPLY FAILURE
112	17-Sep-21	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	15:51	15:55	0:04	LOAD CHANGE OVER
113	17-Sep-21	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	NO STATION AFFECTED	11:47	13:48	2:01	LINE FAULT
114	17-Sep-21	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	12:06	12:45	0:39	MAIN SUPPLY FAILURE
115	17-Sep-21	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	13:24	13:45	0:21	MAIN SUPPLY FAILURE
116	17-Sep-21	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	HEBBALA 220	12:06	12:41	0:35	LINE FAULT
117	17-Sep-21	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	HEBBALA 220	13:24	13:45	0:21	LINE FAULT
118	17-Sep-21	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	NO STATION AFFECTED	12:08	14:04	1:56	LINE FAULT
119	17-Sep-21	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	NO STATION AFFECTED	11:47	12:35	0:48	LINE FAULT
120	17-Sep-21	BENGALURU	220	HV2	KOLAR 220	13:51	14:24	0:33	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
121	17-Sep-21	BENGALURU	220	HV2	KOLAR 220	17:40	18:22	0:42	TRANSFORMER FAULT
122	17-Sep-21	BENGALURU	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220	12:06	12:51	0:45	MAIN SUPPLY FAILURE
123	17-Sep-21	BENGALURU	220	MANYATHA TECH PARK 220 - HOODY 220	HEBBALA 220	12:06	12:45	0:39	LINE FAULT
124	17-Sep-21	BENGALURU	220	MANYATHA TECH PARK 220 - HOODY 220	HEBBALA 220	13:24	13:38	0:14	LINE FAULT
125	17-Sep-21	BENGALURU	220	NIMHANS 220 - KORAMANGALA 220	NIMHANS 220	12:06	12:29	0:23	MAIN SUPPLY FAILURE
126	17-Sep-21	GULBARGA	110	CHITAGUPPA-HUMNABAD	CHITAGUPPA_110,NIRNA_110,ACME_SL R_IPP	5:20	5:35	0:15	LINE FAULT
127	17-Sep-21	GULBARGA	110	CHITAGUPPA-NIRNA	NIRNA_110	5:20	5:35	0:15	MAIN SUPPLY FAILURE
128	17-Sep-21	GULBARGA	110	CHITGUPPA_NIRNA	NIRNA_110	5:20	5:35	0:15	MAIN SUPPLY FAILURE
129	17-Sep-21	GULBARGA	110	CHITGUPPA_NIRNA	NIRNA_110	18:55	19:00	0:05	MAIN SUPPLY FAILURE
130	17-Sep-21	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	5:45	5:50	0:05	LINE FAULT
131	17-Sep-21	GULBARGA	110	HALBARGA-SANTHPUR	SANTHAPUR_110,DONGARGAON_110,D IGGI_110	4:22	4:32	0:10	LINE FAULT
132	17-Sep-21	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BH ALKI SUGAR_IPP	18:55	19:16	0:21	LINE FAULT
133	17-Sep-21	GULBARGA	110	HV1	TEKKALKOTE_110	9:50	14:01	4:11	LINE CLEAR AVAILED
134	17-Sep-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	2:43	2:53	0:10	MAIN SUPPLY FAILURE
135	17-Sep-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	3:16	3:23	0:07	MAIN SUPPLY FAILURE
136	17-Sep-21	GULBARGA	110	PDHALLI-BASAI IPP	PD_HALLI_110	7:40	13:10	5:30	LINE CLEAR AVAILED
137	17-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GABBUR_110,DEODURGA_110,GOOGLE _110	18:45	18:50	0:05	LINE FAULT
138	17-Sep-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRAWAR_110	0:20	0:35	0:15	LINE FAULT
139	17-Sep-21	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	13:20	17:38	4:18	LINE CLEAR AVAILED
140	17-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
141	17-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
142	17-Sep-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	3:40	3:50	0:10	LINE FAULT
143	17-Sep-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	5:25	5:35	0:10	LINE FAULT
144	17-Sep-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	8:30	16:40	8:10	LINE CHARGED
145	17-Sep-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRGUPPA_110,TEK KALKOTE_110,NSL SUGAR_IPP	5:05	5:15	0:10	LINE FAULT
146	17-Sep-21	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDINAGAR_110	10:25	10:35	0:10	LINE FAULT
147	17-Sep-21	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	5:45	6:15	0:30	MAIN SUPPLY FAILURE
148	17-Sep-21	GULBARGA	220	HV2	SEDAM_220	17:03	18:03	1:00	LINE CLEAR AVAILED
149	17-Sep-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
150	17-Sep-21	GULBARGA	220	HV2,LV2	HALBARGA_220	4:22	4:31	0:09	TRANSFORMER FAULT
151	17-Sep-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	1:52	3:09	1:17	MAIN SUPPLY FAILURE
152	17-Sep-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:12(16.09.2021)	6:30(17.09.2021)	9:18HRS	LINE CHARGED
153	17-Sep-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:09			LINE OPEN: LINE CLEAR AVAILED
154	17-Sep-21	HASSAN	110	HV1	ARASIKERE_110	14:07	17:19	3:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
155	17-Sep-21	HASSAN	110	HV1	KADUR_220	13:14	13:35	0:21	LINE CLEAR AVAILED
156	17-Sep-21	HASSAN	110	HV1	KONAJE_110	9:40	9:44	0:04	HAND TRIPPED
157	17-Sep-21	HASSAN	110	HV1	MADHUVANA_110	15:34	16:13	0:39	LINE CLEAR AVAILED
158	17-Sep-21	HASSAN	110	HV1	MADHUVANA_110	16:42	17:30	0:48	LINE CLEAR AVAILED
159	17-Sep-21	HASSAN	110	HV1	MSEZ_220	11:59	14:37	2:38	LINE CLEAR AVAILED
160	17-Sep-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
161	17-Sep-21	HASSAN	110	HV2	BARANGI_110	13:00	16:55	3:55	LINE CLEAR AVAILED
162	17-Sep-21	HASSAN	110	HV2	KONAJE_110	9:40	9:45	0:05	HAND TRIPPED
163	17-Sep-21	HASSAN	110	HV3	KONAJE_110	9:40	9:44	0:04	HAND TRIPPED
164	17-Sep-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
165	17-Sep-21	HASSAN	110	LV1	PUTTUR_220	9:37	13:22	3:45	LINE CLEAR AVAILED
166	17-Sep-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	11:51	11:53	0:02	NFBC ISSUED
167	17-Sep-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	14:32	14:34	0:02	NFBC ISSUED
168	17-Sep-21	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	11:51	14:33	2:42	LINE CLEAR AVAILED
169	17-Sep-21	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	11:51	14:33	2:42	MAIN SUPPLY FAILURE
170	17-Sep-21	HASSAN	220	HV1	PUTTUR_220	9:37	13:21	3:44	LINE CLEAR AVAILED
171	17-Sep-21	HASSAN	220	HV2	HOLENARASIPURA_220	10:53	16:07	5:14	LINE CLEAR AVAILED
172	17-Sep-21	HASSAN	220	MRSSHM-DVG2	MRSMG_220	17:08 (30.08.2021)			LINE OPEN: LINE CLEAR AVAILED
173	17-Sep-21	HASSAN	220	SHRAVITY-TALGUPA3	sharavathy_gen	13:13	14:51	1:38	LINE CLEAR AVAILED
174	17-Sep-21	HASSAN	220	TALAGU-STRP3	TALAGUPPA_400	13:14	14:51	1:37	LINE CLEAR AVAILED
175	17-Sep-21	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:15 (14.9.2021)			LINE OPEN: LINE CLEAR AVAILED
176	17-Sep-21	MYSURU	66	CR NAGARA-HONNAHALLI	ATTIGULIPURA_66 HONNALLY_MYS_66 ARKALAWADI_66	6:04	6:17	0:12	LINE FAULT
177	17-Sep-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	10:36	10:47	0:10	LINE FAULT
178	17-Sep-21	MYSURU	66	HANNUR -KOTTANUR	NO STATIONS EFFECTED	6:08	6:17	0:08	LINE FAULT
179	17-Sep-21	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)	9:20 (18/09/2021)	359:55 HRS	LINE CHARGED
180	17-Sep-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
181	17-Sep-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
182	17-Sep-21	MYSURU	66	HV1	HONNALLY_MYS_66	12:40	13:45	1:05	LINE CLEAR AVAILED
183	17-Sep-21	MYSURU	66	HV1	MADESWARAPURA_66	10:37	14:45	4:07	LINE CLEAR AVAILED
184	17-Sep-21	MYSURU	66	HV2	HONNALLY_MYS_66	11:03	12:44	1:41	LINE CLEAR AVAILED
185	17-Sep-21	MYSURU	66	HV2	MADESWARAPURA_66	10:30	14:45	4:15	LINE CLEAR AVAILED
186	17-Sep-21	MYSURU	66	KR NAGARA-CHUNCHUNKATTE	NO STATIONS EFFECTED	16:41 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
187	17-Sep-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN: LINE CLEAR AVAILED
188	17-Sep-21	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	5:03	5:14	0:11	LINE FAULT
189	17-Sep-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
190	17-Sep-21	MYSURU	220	KUSHALNAGARA-HV2	NO STATIONS EFFECTED	17:27	17:40	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
191	17-Sep-21	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	7:57	19:19	11:22	NFBC ISSUED
192	17-Sep-21	TUMKUR	66	BALENAHALLI66-FEFCWINDWIND_IPP_66	FEFCWINDWIND_IPP_66	3:33	3:39	0:05	LINE FAULT
193	17-Sep-21	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	13:01	13:44	0:43	LINE CLEAR AVAIED
194	17-Sep-21	TUMKUR	66	BELLAVI-KONARK POWER_IPP_66	KONARK POWER_IPP_66	13:01	13:43	0:42	LINE CLEAR AVAIED
195	17-Sep-21	TUMKUR	66	BELLAVI-KORA66	BELLAVI_66	13:01	13:43	0:42	LINE CLEAR AVAIED
196	17-Sep-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	6:44	6:52	0:08	LINE FAULT
197	17-Sep-21	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	18:38	20:06	1:28	LINE CLEAR AVAIED
198	17-Sep-21	TUMKUR	66	TR-1	KORA_66	15:14	15:32	0:18	LINE CLEAR AVAIED
199	17-Sep-21	TUMKUR	66	TR-2	BELLAVI_66	13:01	13:46	0:44	LINE CLEAR AVAIED
200	17-Sep-21	TUMKUR	66	TR-2	BENNEHALLI_66	6:15	14:24	8:08	LINE CLEAR AVAIED
201	17-Sep-21	TUMKUR	66	TR-2	BRAHMASANDRA_66	17:35	18:21	0:46	LINE CLEAR AVAIED
202	17-Sep-21	TUMKUR	66	TR-2	HIRIYUR_66	11:17	11:32	0:15	TRANSFORMER FAULT
203	17-Sep-21	TUMKUR	66	TR-2	HIRIYUR_66	19:13	19:27	0:13	TRANSFORMER FAULT
204	17-Sep-21	TUMKUR	66	TR-2	KORA_66	15:33	16:03	0:30	LINE CLEAR AVAIED
205	17-Sep-21	TUMKUR	66	TR-2	KORTAGERE_66	17:20	18:14	0:53	LINE CLEAR AVAIED
206	17-Sep-21	TUMKUR	66	TR-2	MELKOTE_66	14:33	14:59	0:26	TRANSFORMER FAULT
207	17-Sep-21	TUMKUR	66	TR-2	RAPPURA_66	10:29	10:37	0:08	TRANSFORMER FAULT
1	18-Sep-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAIED
2	18-Sep-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
3	18-Sep-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAIED
4	18-Sep-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAIED
5	18-Sep-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
6	18-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
7	18-Sep-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAIED
8	18-Sep-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
9	18-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVAIED
10	18-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVAIED
11	18-Sep-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED
12	18-Sep-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED
13	18-Sep-21	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	13:08 (14.09.2021)			LINE OPEN: LINE CLEAR AVAIED
14	18-Sep-21	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	9:19 (16.09.2021)			LINE OPEN: LINE CLEAR AVAIED
15	18-Sep-21	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	9:19 (16.09.2021)			LINE OPEN: LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
16	18-Sep-21	BAGALKOT	110	BELLATTI-AB SOLAR	STATION NOT AFFECTED BELLATTI_110	18:53 (16.09.2021)	6:17 (18.09.2021)	35:24HRS	LINE CHARGED
17	18-Sep-21	BAGALKOT	110	GADAG-LAXMESHWAR	STATION NOT AFFECTED LAXMESHWAR_110	13:51 (17.09.2021)	19:00 (18.09.2021)	29:09HRS	LINE CHARGED
18	18-Sep-21	BAGALKOT	110	LAXMESHWAR-GADAG	STATION NOT AFFECTED GADAG_220	13:51 (17.09.2021)	19:37 (18.09.2021)	28:18HRS	LINE CHARGED
19	18-Sep-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	17:44	17:54	0:10	LOAD CURTAILMENT
20	18-Sep-21	BAGALKOT	110	ALAMEL- KPR SUGARS	ALMEL_110	9:27	16:41	7:14	LINE CLEAR AVAILED
21	18-Sep-21	BAGALKOT	110	ALAMEL- JAMAKHANDI SUGARS	ALMEL_110	10:20	10:43	0:23	HAND TRIPPED
22	18-Sep-21	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	7:56	8:16	0:20	HAND TRIPPED
23	18-Sep-21	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	17:45	17:55	0:10	LOAD CURTAILMENT
24	18-Sep-21	BAGALKOT	110	BELLATTI-AB_SOLAR	BELLATTI_110	9:55	19:25	9:30	LINE CLEAR AVAILED
25	18-Sep-21	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	9:55	19:25	9:30	LINE CLEAR AVAILED
26	18-Sep-21	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	16:41	17:20	0:39	LINE CLEAR AVAILED
27	18-Sep-21	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	9:55	10:07	0:12	LINE FAULT
28	18-Sep-21	BAGALKOT	110	110/11KV,HV 4	GAJENDRAGAD_110	17:45	17:57	0:12	LOAD CURTAILMENT
29	18-Sep-21	BAGALKOT	110	110/11KV,HV2	GOKAK_110	9:55	16:38	6:43	LINE CLEAR AVAILED
30	18-Sep-21	BAGALKOT	110	110/11KV,HV1	HANAGALL_110	17:45	18:17	0:32	LOAD CURTAILMENT
31	18-Sep-21	BAGALKOT	110	110/11KV,HV1	HIDIKAL_110	17:45	18:13	0:28	LOAD CURTAILMENT
32	18-Sep-21	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	10:21	10:24	0:03	LINE FAULT
33	18-Sep-21	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	10:21	10:23	0:02	LINE FAULT
34	18-Sep-21	BAGALKOT	110	110/33KV,HV1&2	JAMAKHANDI_110 & HIPPARAGI,MADARKHANDI_33	16:38	16:41	0:03	TRANSFORMER FAULT
35	18-Sep-21	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	17:04	18:54	1:50	LOAD CURTAILMENT
36	18-Sep-21	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	16:38	17:17	0:39	LINE CLEAR AVAILED
37	18-Sep-21	BAGALKOT	220	220/110KV, HV2&LV2	NARENDRA_220	14:56	17:52	2:56	LINE CLEAR AVAILED
38	18-Sep-21	BAGALKOT	220	NARENDRA- HAVERI1 (BIDNAL)	NARENDRA_220	16:42	17:22	0:40	LINE CLEAR AVAILED
39	18-Sep-21	BAGALKOT	220	MUGALKOD- CHIKKODI1	MUGALKOD_220	10:15	12:58	2:43	LINE CLEAR AVAILED
40	18-Sep-21	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	10:19	19:33	9:14	LINE CLEAR AVAILED
41	18-Sep-21	BAGALKOT	110	KUDACHI220- UGARKHUD (KUDACHI110)	KUDACHI_110	10:08	18:48	8:40	LINE CLEAR AVAILED
42	18-Sep-21	BAGALKOT	110	HAVERI- SAVANUR	SAVANUR_110	10:47	13:50	2:57	LINE CLEAR AVAILED
43	18-Sep-21	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	17:25	18:24	0:59	LINE CLEAR AVAILED
44	18-Sep-21	BAGALKOT	110	GADAG220- SHIRAHATTI	SHIRAHATTI_110	10:05	19:37	9:32	LINE CLEAR AVAILED
45	18-Sep-21	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	17:45	18:14	0:29	LOAD CURTAILMENT
46	18-Sep-21	BAGALKOT	110	110/11KV, HV3	HUBLI_220	16:53	17:24	0:31	HAND TRIPPED
47	18-Sep-21	BAGALKOT	110	SHIRAHATTI- BPCL1&2	SHIRAHATTI_110	19:32	19:34	0:02	HAND TRIPPED
48	18-Sep-21	BAGALKOT	110	110/11KV, HV2	SAVALAGI_110	17:45	18:01	0:16	LOAD CURTAILMENT
49	18-Sep-21	BAGALKOT	110	SANKESHWAR- HUKKERI	SANKESHWAR_110	9:55	10:17	0:22	LINE FAULT
50	18-Sep-21	BAGALKOT	110	110/11KV, HV2	RAMDURG_110	10:13	16:37	6:24	LINE CLEAR AVAILED
51	18-Sep-21	BAGALKOT	110	NARENDRA- MRUTHYUNJAY NAGAR	MRUTHYUNJAY NAGAR_110	13:30	18:30	5:00	LINE CLEAR AVAILED
52	18-Sep-21	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	9:06	9:12	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
53	18-Sep-21	BAGALKOT	110	110/11KV, HV1	MORATAGI_110	10:05	10:10	0:05	TRANSFORMER FAULT
54	18-Sep-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN: LINE CLEAR AVAILED
55	18-Sep-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN: LINE CLEAR AVAILED
56	18-Sep-21	BAGALKOT	110	SINDAGI- CHANDKAVATE	CHANDKAVATE_110	8:00	8:15	0:15	MAIN SUPPLY FAILURE
57	18-Sep-21	BAGALKOT	110	SINDAGI- CHANDKAVATE	CHANDKAVATE_110	8:25	8:35	0:10	MAIN SUPPLY FAILURE
58	18-Sep-21	BAGALKOT	110	SINDAGI- CHANDKAVATE	CHANDKAVATE_110	10:15	10:20	0:05	LINE FAULT
59	18-Sep-21	Bagalkot	110	110/11KV, HV1	LAXMESHWAR_110	10:05	19:00	8:55	LINE CLEAR AVAILED
60	18-Sep-21	Bagalkot	110	110/11KV,HV2	LAXMESHWAR_110	10:05	19:00	8:55	LINE CLEAR AVAILED
61	18-Sep-21	Bagalkot	110	110/33KV, HV3	LAXMESHWAR_110	10:05	19:00	8:55	LINE CLEAR AVAILED
62	18-Sep-21	Bagalkot	110	BELLATTI- LAXMESHWAR	LAXMESHWAR_110	10:05	19:00	8:55	LINE CLEAR AVAILED
63	18-Sep-21	Bagalkot	110	LAXMESHWAR- SHIRAHATTI	SHIRAHATTI_110	10:05	19:05	9:00	LINE CLEAR AVAILED
64	18-Sep-21	Bagalkot	110	110/11KV, HV1	SHIRAHATTI_110	10:05	19:05	9:00	LINE CLEAR AVAILED
65	18-Sep-21	Bagalkot	110	110/11KV, HV2	SHIRAHATTI_110	10:05	19:15	9:10	LINE CLEAR AVAILED
66	18-Sep-21	BAGALKOT	220	ATHANI- KAKAMARI1	ATHANI_220	13:41	16:08	2:27	LINE CLEAR AVAILED
67	18-Sep-21	BAGALKOT	220	ATHANI- KAKAMARI2	ATHANI_220	16:10	17:04	0:54	LINE CLEAR AVAILED
68	18-Sep-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	12:02	12:31	0:29	HAND TRIPPED
69	18-Sep-21	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	12:34	13:31	0:57	HAND TRIPPED
70	18-Sep-21	BAGALKOT	220	NARENDRA- HAVERI	NARENDRA_220	17:25	18:24	0:59	LINE CLEAR AVAILED
71	18-Sep-21	BAGALKOT	110	NARENDRA- MRUTHYUNJAY NAGAR	MRUTHYUNJAY NAGAR_110	13:30	18:30	5:00	LINE CLEAR AVAILED
72	18-Sep-21	BAGALKOT	110	NARENDRA- UAS	UAS_110	13:35	18:30	4:55	LINE CLEAR AVAILED
73	18-Sep-21	Bagalkot	110	110/11KV, HV1	SADALAGA_110	12:25	16:50	4:25	LINE CLEAR AVAILED
74	18-Sep-21	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	NO STATION AFFECTED	12:58	16:03	3:05	LINE FAULT
75	18-Sep-21	BENGALURU	220	HSR LAYOUT 220 - HOODY 400	NO STATION AFFECTED	12:58	16:40	3:42	LINE FAULT
76	18-Sep-21	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	10:53	11:00	0:07	LOAD CHANGE OVER
77	18-Sep-21	BENGALURU	66	HV2	HSR LAYOUT 220	10:53	11:00	0:07	LOAD CHANGE OVER
78	18-Sep-21	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	9:49	9:57	0:08	LOAD CHANGE OVER
79	18-Sep-21	BENGALURU	66	KODIGEHALLI - BYDRAHALLI	KODIGEHALLI, TAVAREKERE	16:18	16:23	0:05	LINE FAULT
80	18-Sep-21	BENGALURU	220	MANYATHA TECH PARK 220 - HEBBALA 220	HEBBALA 220	12:13	12:50	0:37	LINE FAULT
81	18-Sep-21	BENGALURU	66	REMCO -SUBRAMANYAPURA 220	REMCO	19:55	20:16	0:21	MAIN SUPPLY FAILURE
82	18-Sep-21	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	12:31	18:34	6:03	LINE FAULT
83	18-Sep-21	BENGALURU	220	HV3	SUBRAMANYAPURA 220	19:55	20:16	0:21	TRANSFORMER FAULT
84	18-Sep-21	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	12:13	12:17	0:04	MAIN SUPPLY FAILURE
85	18-Sep-21	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	12:58	13:00	0:02	LOAD CHANGE OVER
86	18-Sep-21	BENGALURU	220	HOODY 220 - MANYATHA 220	HEBBAL 220	12:13	12:50	0:37	LINE FAULT
87	18-Sep-21	BENGALURU	220	HOODY 220 - MALUR 220	SARIJAPURA 220, VIKAS TECH PARK 220	12:33	13:50	1:17	LINE FAULT
88	18-Sep-21	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	12:13	12:30	0:17	MAIN SUPPLY FAILURE
89	18-Sep-21	BENGALURU	66	HEBBAL 220 - IISc	IISC	12:13	12:24	0:11	MAIN SUPPLY FAILURE
90	18-Sep-21	BENGALURU	220	HV1	HEBBAL 220	12:13	12:50	0:37	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
91	18-Sep-21	BENGALURU	220	HV2	HEBBAL 220	12:13	12:50	0:37	MAIN SUPPLY FAILURE
92	18-Sep-21	BENGALURU	66	HV1	HEBBAL 220	12:13	12:50	0:37	MAIN SUPPLY FAILURE
93	18-Sep-21	BENGALURU	66	HV2	HEBBAL 220	12:13	12:50	0:37	MAIN SUPPLY FAILURE
94	18-Sep-21	BENGALURU	66	BANASWADI - HEBBAL 220	BANASWADI	15:40	16:49	1:09	LINE CLEAR AVAIED
95	18-Sep-21	BENGALURU	66	BANASWADI - ITI 220	BANASWADI	10:06	16:52	6:46	LINE CLEAR AVAIED
96	18-Sep-21	BENGALURU	66	C STATION - A STATION 220	C STATION	16:42	16:44	0:02	LOAD CHANGE OVER
97	18-Sep-21	BENGALURU	66	HV1	EXORA PARK	13:15	13:20	0:05	LOAD CHANGE OVER
98	18-Sep-21	BENGALURU	66	HV2	EXORA PARK	8:55	9:00	0:05	LOAD CHANGE OVER
99	18-Sep-21	BENGALURU	66	IISc - NRS 220	IISc	20:47	20:50	0:03	LOAD CHANGE OVER
100	18-Sep-21	BENGALURU	66	HV1	MALLASANDRA	16:30	16:40	0:10	LINE CLEAR AVAIED
101	18-Sep-21	BENGALURU	66	HV2	KANAKAPURA 66	10:59	11:05	0:05	TRANSFORMER FAULT
102	18-Sep-21	BENGALURU	66	HV1	KAMASAMUDRA	3:13	3:26	0:13	TRANSFORMER FAULT
103	18-Sep-21	BENGALURU	66	HV1	HOSPALYA CIRCLE	8:50	9:05	0:14	TRANSFORMER FAULT
104	18-Sep-21	BENGALURU	66	HV1	HOSPALYA CIRCLE	9:23	9:34	0:10	TRANSFORMER FAULT
105	18-Sep-21	BENGALURU	66	HV1	HOSKOTE 220	3:54	4:10	0:16	TRANSFORMER FAULT
106	18-Sep-21	BENGALURU	66	HV1	GUNDAMGERE	12:05	12:30	0:25	TRANSFORMER FAULT
107	18-Sep-21	BENGALURU	66	HV1	GOWRIBIDANUR 220	12:30	12:54	0:24	TRANSFORMER FAULT
108	18-Sep-21	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	10:17	10:20	0:02	LINE CLEAR AVAIED
109	18-Sep-21	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	11:02	11:13	0:11	LINE FAULT
110	18-Sep-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	9:50	11:02	1:12	LINE CLEAR AVAIED
111	18-Sep-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:31	17:36	0:05	LINE FAULT
112	18-Sep-21	BENGALURU	66	CHANDAPURA - YERANDANAHALLI	CHANDAPURA	17:30	17:40	0:10	MAIN SUPPLY FAILURE
113	18-Sep-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	10:05	10:10	0:05	LOAD CHANGE OVER
114	18-Sep-21	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	9:41	9:44	0:03	LOAD CHANGE OVER
115	18-Sep-21	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT	11:34	11:37	0:03	LOAD CHANGE OVER
116	18-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	2:15	2:20	0:05	LINE FAULT
117	18-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	3:09	10:01	6:52	LINE FAULT
118	18-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:01	18:00	7:59	LINE CLEAR AVAIED
119	18-Sep-21	BENGALURU	220	MALUR 220 - HOODY 220	NO STATION AFFECTED	12:33	13:55	1:22	LINE FAULT
120	18-Sep-21	BENGALURU	220	MALUR 220 - SOMANHALLI 1	SARIJAPURA 220, VIKAS TEC PARK 220	12:54	13:19	0:25	LINE FAULT
121	18-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	21:06	21:13	0:07	LINE FAULT
122	18-Sep-21	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	12:54	13:53	0:59	MAIN SUPPLY FAILURE
123	18-Sep-21	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:54	13:31	0:37	MAIN SUPPLY FAILURE
124	18-Sep-21	BENGALURU	66	SARIJAPURA 220 - ATTIBELE	ATTIBELE	12:54	13:32	0:38	MAIN SUPPLY FAILURE
125	18-Sep-21	BENGALURU	220	HV1	SARIJAPURA 220	12:54	13:30	0:36	MAIN SUPPLY FAILURE
126	18-Sep-21	BENGALURU	220	HV2	SARIJAPURA 220	12:54	13:30	0:36	MAIN SUPPLY FAILURE
127	18-Sep-21	BENGALURU	66	HV1	SARIJAPURA 220	12:54	13:31	0:37	MAIN SUPPLY FAILURE
128	18-Sep-21	BENGALURU	66	BIAL BEGUR 220 - VIDYANAGAR	VIDYANAGAR, HENNUR CROSS	18:48	19:05	0:17	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
129	18-Sep-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:02(17.09.2021)	4:12(18.09.2021)	6:10HRS	LINE CHARGED
130	18-Sep-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
131	18-Sep-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:09(17.09.2021)	05:46(18.09.2021)	08:37HRS	LINE CHARGED
132	18-Sep-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	22:55(18.09.2021)			LINE OPEN: LINE CLEAR AVAILED
133	18-Sep-21	GULBARGA	220	HV1	HUMNABAD_220	15:25	16:25	1:00	LINE CLEAR AVAILED
134	18-Sep-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	20:25	20:31	0:06	LINE FAULT
135	18-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
136	18-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
137	18-Sep-21	GULBARGA	110	HV2	HATTI_110	7:40	7:45	0:05	TRANSFORMER FAULT
138	18-Sep-21	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110	5:50	6:00	0:10	LINE FAULT
139	18-Sep-21	GULBARGA	110	HV2	MYLAR_110	4:10	4:15	0:05	TRANSFORMER FAULT
140	18-Sep-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	5:51	6:01	0:05	LINE FAULT
141	18-Sep-21	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	5:35	5:45	0:10	LINE FAULT
142	18-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	18:28	18:34	0:06	LINE FAULT
143	18-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	12:05	12:30	0:25	LINE CLEAR AVAILED
144	18-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GABBUR_110,DEODURGA_110,GOOGLE_110	22:20	22:30	0:10	LINE FAULT
145	18-Sep-21	GULBARGA	110	HV1	SINDHANOOR_220	17:25	17:35	0:10	TRANSFORMER FAULT
146	18-Sep-21	GULBARGA	110	HV3	CHIDRI_110	17:44	17:54	0:10	LOAD CURTAILMENT
147	18-Sep-21	GULBARGA	110	HV2	JEWARGI_110	17:44	17:58	0:14	LOAD CURTAILMENT
148	18-Sep-21	GULBARGA	110	HV3	YELBURGA_110	17:45	18:04	0:19	LOAD CURTAILMENT
149	18-Sep-21	GULBARGA	110	HV4	YELBURGA_110	17:45	18:10	0:25	LOAD CURTAILMENT
150	18-Sep-21	GULBARGA	110	HV1	KURKUNTA_110	17:44	18:15	0:31	LOAD CURTAILMENT
151	18-Sep-21	GULBARGA	110	HV2	VALKAMDINNI_110	13:30	14:45	1:15	LINE CLEAR AVAILED
152	18-Sep-21	GULBARGA	110	HV1	TEKKALKOTE_110	17:44	17:55	0:11	LOAD CURTAILMENT
153	18-Sep-21	GULBARGA	110	SIRIGUPPA-SINDHANOOR	SIRIGUPPA_110,TEKKALKOTE_110	19:41	19:52	0:11	MAIN SUPPLY FAILURE
154	18-Sep-21	GULBARGA	66	HANASI-BADALADAKU	HANASI_66	10:12	18:08	7:56	LINE CLEAR AVAILED
155	18-Sep-21	GULBARGA	66	HV1	SOVENHALLI_66	17:44	17:50	0:06	TRANSFORMER FAULT
156	18-Sep-21	GULBARGA	66	HV2	TAMBRAHALLI_66	7:15	7:35	0:20	LINE CLEAR AVAILED
157	18-Sep-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
158	18-Sep-21	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN: LINE CLEAR AVAILED
159	18-Sep-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
160	18-Sep-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	3:38	6:23	2:45	LINE CLEAR AVAILED
161	18-Sep-21	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	12:44	13:13	0:29	LINE FAULT
162	18-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:44	13:13	0:29	LINE FAULT
163	18-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	14:16	14:38	0:22	HAND TRIPPED
164	18-Sep-21	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	14:22	15:03	0:41	LINE FAULT
165	18-Sep-21	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	14:16	14:38	0:22	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
166	18-Sep-21	HASSAN	110	HV1	DMKURKE_110	18:50	19:09	0:19	LOAD CURTAILMENT
167	18-Sep-21	HASSAN	110	HV2	GANDASI_66	18:50	19:09	0:19	LOAD CURTAILMENT
168	18-Sep-21	HASSAN	110	HV2	GERUMARA_110	18:50	19:09	0:19	LOAD CURTAILMENT
169	18-Sep-21	HASSAN	110	HV1	JAVAGAL_110	18:51	19:04	0:13	LOAD CURTAILMENT
170	18-Sep-21	HASSAN	110	HV1	MADHUVANA_110	10:27	14:28	4:01	LINE CLEAR AVAIED
171	18-Sep-21	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	10:13	11:28	1:15	NFBC ISSUED
172	18-Sep-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	9:15	18:25	9:10	NFBC ISSUED
173	18-Sep-21	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	11:20	14:22	3:02	LINE CLEAR AVAIED
174	18-Sep-21	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:45	11:55	0:10	LINE FAULT
175	18-Sep-21	HASSAN	66	HV1	HALLIMYSORE_66	18:51	18:56	0:05	LOAD CURTAILMENT
176	18-Sep-21	HASSAN	66	HV2	HALLIMYSORE_66	11:00	12:50	1:50	TRANSFORMER FAULT
177	18-Sep-21	HASSAN	66	HV1	HANGARANAHALLY_66	18:51	18:59	0:08	LOAD CURTAILMENT
178	18-Sep-21	HASSAN	66	HV1	HIRISAVE_66	9:59	15:10	5:11	LINE CLEAR AVAIED
179	18-Sep-21	HASSAN	66	HV2	HIRISAVE_66	10:00	15:00	5:00	LINE CLEAR AVAIED
180	18-Sep-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	18:45	18:55	0:10	LINE FAULT
181	18-Sep-21	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	11:20	12:20	1:00	LINE CLEAR AVAIED
182	18-Sep-21	HASSAN	66	HV2	RAMESHWARNAGARA_66	18:51	19:10	0:19	LOAD CURTAILMENT
183	18-Sep-21	HASSAN	66	HV2	SALAGAME_66	18:51	19:07	0:16	LOAD CURTAILMENT
184	18-Sep-21	HASSAN	66	HV2	SINGAPURA_66	18:52	19:03	0:11	LOAD CURTAILMENT
185	18-Sep-21	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	14:34	15:10	0:36	LINE FAULT
186	18-Sep-21	HASSAN	66	HV1	CHANNARAYAPATNA_66	12:50	14:20	1:30	LINE CLEAR AVAIED
187	18-Sep-21	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:15	12:50	1:35	LINE CLEAR AVAIED
188	18-Sep-21	HASSAN	66	HV2	CHANNARAYAPATNA_66	14:40	14:45	0:05	TRANSFORMER FAULT
189	18-Sep-21	HASSAN	66	HV2	BASAVAGHATTA_66	18:51	18:55	0:04	LOAD CURTAILMENT
190	18-Sep-21	MYSURU	66	HV2	ADDIHALLI_66	18:50	18:54	0:04	LINE CLEAR AVAIED
191	18-Sep-21	MYSURU	66	HV2	AKKIHEBBAL_66	3:43	3:55	0:12	TRANSFORMER FAULT
192	18-Sep-21	MYSURU	66	HV2	AKKIHEBBAL_66	18:50	19:01	0:10	LINE CLEAR AVAIED
193	18-Sep-21	MYSURU	66	BANNIMANTAP-VIJAYNAGAR	NO STATIONS EFFECTED	10:30	18:17	7:47	NFBC ISSUED
194	18-Sep-21	MYSURU	66	HV1	BILIKERE_66	18:50	19:25	0:34	LINE CLEAR AVAIED
195	18-Sep-21	MYSURU	66	HV2	BILIKERE_66	11:26	11:34	0:08	TRANSFORMER FAULT
196	18-Sep-21	MYSURU	66	DATAGALLI-RK NAGARA	RKNAGARA_66	10:14	17:13	6:58	NFBC ISSUED
197	18-Sep-21	MYSURU	66	HV1	DODDINADUVADI_66	18:50	19:40	0:49	LINE CLEAR AVAIED
198	18-Sep-21	MYSURU	66	DEVNUR(MYS)-RAJEEV NAGARA	RAJEEVNAGARA_66	10:15	17:29	7:13	NFBC ISSUED
199	18-Sep-21	MYSURU	66	HV2	ELAVALA_66	18:51	19:34	0:43	LINE CLEAR AVAIED
200	18-Sep-21	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	9:51	18:25	8:33	NFBC ISSUED
201	18-Sep-21	MYSURU	66	GUNDLUPETE-BEGUR	NO STATIONS EFFECTED	10:10	17:10	7:00	NFBC ISSUED
202	18-Sep-21	MYSURU	66	HV1	HANAGODU_66	18:51	19:04	0:12	LINE CLEAR AVAIED
203	18-Sep-21	MYSURU	66	HV2	HANNUR_66	18:51	19:34	0:43	LINE CLEAR AVAIED
204	18-Sep-21	MYSURU	66	HV2	HDKOTE_66	18:50	19:34	0:43	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
205	18-Sep-21	MYSURU	66	HV2	JAIPUR_66	18:51	19:40	0:49	LINE CLEAR AVAILED
206	18-Sep-21	MYSURU	66	JYOTHINAGARA-DK MAIDANA	NO STATIONS EFFECTED	10:27	18:41	8:14	LINE CLEAR AVAILED
207	18-Sep-21	MYSURU	66	JYOTHINAGARA-FTS	NO STATIONS EFFECTED	9:54	18:08	8:14	LINE CLEAR AVAILED
208	18-Sep-21	MYSURU	66	HV1	KHBCOLONY_66	10:01	17:10	7:08	LINE CLEAR AVAILED
209	18-Sep-21	MYSURU	66	HV2	KHBCOLONY_66	10:01	17:10	7:08	LINE CLEAR AVAILED
210	18-Sep-21	MYSURU	66	HV2	KIRUGAVALU_66	18:51	19:22	0:30	LINE CLEAR AVAILED
211	18-Sep-21	MYSURU	66	HV2	KMDODDI_66	18:51	19:01	0:10	LINE CLEAR AVAILED
212	18-Sep-21	MYSURU	66	MADDUR-K.HONALGERE	SOMANAHALLI_66	9:03	9:14	0:11	LINE FAULT
213	18-Sep-21	MYSURU	66	HV2	MALAVALLI_66	18:51	18:58	0:06	LINE CLEAR AVAILED
214	18-Sep-21	MYSURU	66	MYSORE SOUTHKADAKOLA	NO STATIONS EFFECTED	10:16	18:31	8:15	LINE CLEAR AVAILED
215	18-Sep-21	MYSURU	66	RK NAGARAMANTAGALLI	RKNAGARA_66	10:06	17:10	7:03	LINE CLEAR AVAILED
216	18-Sep-21	MYSURU	66	SANTHESARGUR-BEGUR	NO STATIONS EFFECTED	9:30	16:50	7:20	NFBC ISSUED
217	18-Sep-21	MYSURU	66	HV2	SANTHEMARAHALLI_66	18:51	19:07	0:16	LINE CLEAR AVAILED
218	18-Sep-21	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	10:37	17:32	6:55	NFBC ISSUED
219	18-Sep-21	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	7:39	19:11	11:32	NFBC ISSUED
220	18-Sep-21	MYSURU	66	VIJAYANAGARA-FTS	NO STATIONS EFFECTED	10:28	17:52	7:23	LINE CLEAR AVAILED
221	18-Sep-21	MYSURU	66	VIJAYANAGARA-HOOTAGALLI	VIJAYANAGRAMYS_66	10:48	17:31	6:42	LINE CLEAR AVAILED
222	18-Sep-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
223	18-Sep-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
224	18-Sep-21	MYSURU	66	KR NAGARA-CHUNCHUNKATTE	NO STATIONS EFFECTED	16:41 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
225	18-Sep-21	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:15 (14.9.2021)			LINE OPEN: LINE CLEAR AVAILED
226	18-Sep-21	TUMKUR	110	TR-1	AMMASANDRA_110	9:00	10:21	1:21	TRANSFORMER FAULT
227	18-Sep-21	TUMKUR	66	ANCHEPALYA 220- HEBBUR	SIRA_66, KALLAMBELLA_66	7:41	7:56	0:14	LOAD CURTAILMENT
228	18-Sep-21	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	7:42	8:09	0:27	LOAD CURTAILMENT
229	18-Sep-21	TUMKUR	66	ANTHRASANAHALI 220KV- BELLAVI	BELLAVI_66	7:42	8:10	0:28	LOAD CURTAILMENT
230	18-Sep-21	TUMKUR	66	TR-2	BENNEHALI_66	9:14	9:26	0:11	TRANSFORMER FAULT
231	18-Sep-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	4:48	6:12	1:23	LINE FAULT
232	18-Sep-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:37	18:46	0:09	LINE FAULT
233	18-Sep-21	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	10:09	22:17	12:08	LINE CLEAR AVAILED
234	18-Sep-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	10:09	22:17	12:08	LINE CLEAR AVAILED
235	18-Sep-21	TUMKUR	66	TR-2	HARIYABBE_66	10:09	22:17	12:08	LINE CLEAR AVAILED
236	18-Sep-21	TUMKUR	66	TR-3	HARIYABBE_66	10:09	22:17	12:08	LINE CLEAR AVAILED
237	18-Sep-21	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:30	9:42	0:11	LINE FAULT
238	18-Sep-21	TUMKUR	66	HONNALLI 220kv- SASVEHALLI	SAAVEHALLI_66	18:41	18:50	0:09	LINE FAULT
239	18-Sep-21	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	10:10	23:34	13:23	LINE CLEAR AVAILED
240	18-Sep-21	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	10:09	23:34	13:24	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
241	18-Sep-21	TUMKUR	66	PDKOTE-HARIYABBE	PDKOTE_66	10:10	23:34	13:23	LINE CLEAR AVAILED
242	18-Sep-21	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	10:09	21:00	10:50	LINE CLEAR AVAILED
243	18-Sep-21	TUMKUR	66	TR-1	PDKOTE_66	10:10	23:34	13:23	LINE CLEAR AVAILED
244	18-Sep-21	TUMKUR	66	TR-1	PAVAGADA_220	19:01	19:28	0:27	TRANSFORMER FAULT
245	18-Sep-21	TUMKUR	66	TR-1	TUMAKURU_66	8:40	9:05	0:24	LINE CLEAR AVAILED
246	19-Sep-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
247	19-Sep-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
248	19-Sep-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
249	19-Sep-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
250	19-Sep-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
251	19-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
252	19-Sep-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
253	19-Sep-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
254	19-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVAILED
255	19-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVAILED
256	19-Sep-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
257	19-Sep-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
258	19-Sep-21	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	13:08 (14.09.2021)			LINE OPEN: LINE CLEAR AVAILED
259	19-Sep-21	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	9:19 (16.09.2021)	21:38 (19.09.2021)	84:19HRS	LINE CHARGED
260	19-Sep-21	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	9:19 (16.09.2021)	21:38 (19.09.2021)	84:19HRS	LINE CHARGED
261	19-Sep-21	BAGALKOT	220	AMBEWADI--PONDA 1	AMBEWADI_220	11:15	15:48	4:33	LINE CLEAR AVAILED
262	19-Sep-21	BAGALKOT	220	AMBEWADI--PONDA 2	AMBEWADI_220	11:20	15:50	4:30	LINE CLEAR AVAILED
263	19-Sep-21	BAGALKOT	110	ANKOLA-ARGA(L1)	ANKOLA_110	14:29	14:34	0:05	LINE FAULT
264	19-Sep-21	BAGALKOT	110	110/33KV,HV3	MACHE_110 &GLOBAL,ASHOK IRON_33	12:44	17:58	5:14	LINE CLEAR AVAILED
265	19-Sep-21	BAGALKOT	66	110/11KV,HV2	HOSPET_66	12:40	13:59	1:19	LINE CLEAR AVAILED
266	19-Sep-21	BAGALKOT	110	INDI- ZALKI	ZALKI_110	13:03	16:28	3:25	LINE CLEAR AVAILED
267	19-Sep-21	BAGALKOT	220	220/110KV, HV1&LV1	VAJRAMATTI_220, VAJRAMATTI_110, BILAGI_110, SHIRGUPPI_110, GIRISAGAR_110, BISNAL_110, MANTUR_110, MUDHOL_110, UTTUR_110	13:29	13:39	0:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
268	19-Sep-21	BAGALKOT	220	220/110KV, HV2&LV2	VAJRAMATTI_220, VAJRAMATTI_110, BILAGI_110, SHIRGUPPI_110, GIRISAGAR_110, BISNAL_110, MANTUR_110, MUDHOL_110, UTTUR_110	13:29	13:39	0:10	TRANSFORMER FAULT
269	19-Sep-21	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110	13:39	13:42	0:03	HAND TRIPPED
270	19-Sep-21	BAGALKOT	110	VAJRAMATTI220- MANTUR	MANTUR_110	13:39	13:41	0:02	HAND TRIPPED
271	19-Sep-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	12:46	14:48	2:02	LINE FAULT
272	19-Sep-21	BAGALKOT	220	220/110KV, HV1&LV1	MKHUBLI_220	9:24	16:00	6:36	LINE CLEAR AVAILED
273	19-Sep-21	BAGALKOT	110	MKHUBLI220- HIREBAGEWADI	HIREBAGEWADI_110	12:36	16:51	4:15	LINE CLEAR AVAILED
274	19-Sep-21	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	MAHALINGAPUR_220	12:43	14:45	2:02	LINE FAULT
275	19-Sep-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	12:55 (19.09.2021)			LINE OPEN: LINE FAULT
276	19-Sep-21	BAGALKOT	110	GADAG220- SHIRAHATTI	SHIRAHATTI_110	19:59	20:28	0:29	HAND TRIPPED
277	19-Sep-21	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	16:23	17:58	1:35	LINE CLEAR AVAILED
278	19-Sep-21	BAGALKOT	110	SATTI- RABAKAVI	RABAKAVI_110	13:26	13:29	0:03	HAND TRIPPED
279	19-Sep-21	BAGALKOT	110	SATTI- RABAKAVI	RABAKAVI_110	13:43	14:05	0:22	HAND TRIPPED
280	19-Sep-21	BAGALKOT	110	SATTI- RABAKAVI	RABAKAVI_110	16:34	16:39	0:05	HAND TRIPPED
281	19-Sep-21	BAGALKOT	110	SADALAGA- VPPL	SADALAGA_110	12:44	17:52	5:08	LINE CLEAR AVAILED
282	19-Sep-21	BAGALKOT	110	MAHALINGAPUR- RANNABELAGALI	RANNABELAGALI_110	13:18	16:14	2:56	LINE CLEAR AVAILED
283	19-Sep-21	BAGALKOT	110	MAMADAPU(B)- SHIRABUR	SHIRABUR_110	20:13	21:17	1:04	LINE CLEAR AVAILED
284	19-Sep-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN: LINE CLEAR AVAILED
285	19-Sep-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN: LINE CLEAR AVAILED
286	19-Sep-21	Bagalkot	110	HUBLI- TARIHAL1	TARIHAL_110	10:47	16:25	5:38	LINE CLEAR AVAILED
287	19-Sep-21	Bagalkot	110	HUBLI- TARIHAL1	TARIHAL_110	10:47	16:24	5:37	LINE CLEAR AVAILED
288	19-Sep-21	Bagalkot	220	CHIKKODI- KUDACHI2	CHIKKODI_220	5:31	6:28	0:57	LINE FAULT
289	19-Sep-21	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	10:06	10:12	0:06	LOAD CHANGE OVER
290	19-Sep-21	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	12:13	12:18	0:05	LOAD CHANGE OVER
291	19-Sep-21	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	10:04	12:05	2:01	LINE CLEAR AVAILED
292	19-Sep-21	BENGALURU	66	HV3	A STATION 66	6:33	6:43	0:10	LOAD CHANGE OVER
293	19-Sep-21	BENGALURU	66	HV4	A STATION 66	6:33	6:43	0:10	LOAD CHANGE OVER
294	19-Sep-21	BENGALURU	66	HV3	A STATION 66	13:43	13:58	0:15	LOAD CHANGE OVER
295	19-Sep-21	BENGALURU	66	HV4	A STATION 66	13:43	13:58	0:15	LOAD CHANGE OVER
296	19-Sep-21	BENGALURU	66	HV1	A STATION 66	16:54	17:01	0:07	LOAD CHANGE OVER
297	19-Sep-21	BENGALURU	66	GLOBAL TECH PARK - HSR LAYOUT 220	GLOBAL TECH PARK	15:25	15:32	0:07	MAIN SUPPLY FAILURE
298	19-Sep-21	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	15:25	15:31	0:06	LOAD CHANGE OVER
299	19-Sep-21	BENGALURU	66	HV3	HSR LAYOUT 220	15:25	15:38	0:13	LOAD CHANGE OVER
300	19-Sep-21	BENGALURU	66	HV2	HSR LAYOUT 220	15:25	15:45	0:20	LOAD CHANGE OVER
301	19-Sep-21	BENGALURU	220	MANYATHA TECH PARK 220 - HEBBALA 220	HEBBALA 220	13:03	13:16	0:13	LINE FAULT
302	19-Sep-21	BENGALURU	66	PLATINUM CITY - ATTUR YELAHANKA	PLATINUM CITY	10:05	10:15	0:10	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
303	19-Sep-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	13:35	13:45	0:10	LOAD CHANGE OVER
304	19-Sep-21	BENGALURU	66	REMCO - SUBRAMANYAPURA 220	REMCO	6:03	6:11	0:08	MAIN SUPPLY FAILURE
305	19-Sep-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	18:38	18:44	0:06	LOAD CHANGE OVER
306	19-Sep-21	BENGALURU	220	VIKAS TECH PARK 220 - SARJAPURA 220	VIKAS TECH PARK 220	10:06	11:10	1:04	MAIN SUPPLY FAILURE
307	19-Sep-21	BENGALURU	220	VIKAS TECH PARK 220 - SARJAPURA 220	VIKAS TECH PARK 220	12:35	12:55	0:20	MAIN SUPPLY FAILURE
308	19-Sep-21	BENGALURU	220	VIKAS TECH PARK 220 - SARJAPURA 220	VIKAS TECH PARK 220	15:15	15:35	0:20	MAIN SUPPLY FAILURE
309	19-Sep-21	BENGALURU	220	VIKAS TECH PARK 220 - SARJAPURA 220	VIKAS TECH PARK 220	19:30	19:40	0:10	MAIN SUPPLY FAILURE
310	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	10:06	11:10	1:04	MAIN SUPPLY FAILURE
311	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	10:06	11:10	1:04	MAIN SUPPLY FAILURE
312	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	10:06	11:10	1:04	MAIN SUPPLY FAILURE
313	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	12:35	12:55	0:20	MAIN SUPPLY FAILURE
314	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	12:35	12:55	0:20	MAIN SUPPLY FAILURE
315	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:35	12:55	0:20	MAIN SUPPLY FAILURE
316	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	15:15	15:35	0:20	MAIN SUPPLY FAILURE
317	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	15:15	15:35	0:20	MAIN SUPPLY FAILURE
318	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	15:15	15:35	0:20	MAIN SUPPLY FAILURE
319	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	19:30	19:40	0:10	MAIN SUPPLY FAILURE
320	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	19:30	19:40	0:10	MAIN SUPPLY FAILURE
321	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	19:30	19:40	0:10	MAIN SUPPLY FAILURE
322	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	10:06	11:10	1:04	MAIN SUPPLY FAILURE
323	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	12:35	12:55	0:20	MAIN SUPPLY FAILURE
324	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	15:15	15:35	0:20	MAIN SUPPLY FAILURE
325	19-Sep-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	19:30	19:40	0:10	MAIN SUPPLY FAILURE
326	19-Sep-21	BENGALURU	220	HV1	YARANDANAHALLI 220	22:33	23:38	1:05	TRANSFORMER FAULT
327	19-Sep-21	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	14:04	14:40	0:36	LINE FAULT
328	19-Sep-21	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	14:04	14:40	0:36	LINE FAULT
329	19-Sep-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	22:33	23:38	1:05	LINE CLEAR AVAILED
330	19-Sep-21	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	13:02	13:06	0:04	MAIN SUPPLY FAILURE
331	19-Sep-21	BENGALURU	66	IISC - NRS 220	IISC	17:45	17:49	0:04	LOAD CHANGE OVER
332	19-Sep-21	BENGALURU	220	HOODY 220 - MANYATHA 220	HEBBAL 220	13:01	13:59	0:58	LINE FAULT
333	19-Sep-21	BENGALURU	66	C STATION - A STATION 220	C STATION	15:13	15:15	0:02	LOAD CHANGE OVER
334	19-Sep-21	BENGALURU	66	HEBBAL 220 - C STATION 1	C STATION	13:03	13:05	0:02	MAIN SUPPLY FAILURE
335	19-Sep-21	BENGALURU	66	HEBBAL 220 - IISC	IISC	13:03	13:15	0:12	MAIN SUPPLY FAILURE
336	19-Sep-21	BENGALURU	220	HV1	HEBBAL 220	13:03	13:16	0:13	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
337	19-Sep-21	BENGALURU	220	HV2	HEBBAL 220	13:03	13:16	0:13	MAIN SUPPLY FAILURE
338	19-Sep-21	BENGALURU	66	HV1	HEBBAL 220	13:03	13:16	0:13	MAIN SUPPLY FAILURE
339	19-Sep-21	BENGALURU	66	HV2	HEBBAL 220	13:03	13:16	0:13	MAIN SUPPLY FAILURE
340	19-Sep-21	BENGALURU	66	BANASWADI - HEBBAL 220	BANASWADI	13:03	16:49	3:46	LINE CLEAR AVAILED
341	19-Sep-21	BENGALURU	66	BANASWADI - ITI 220	BANASWADI	13:03	16:52	3:49	LINE CLEAR AVAILED
342	19-Sep-21	BENGALURU	66	HV1	MULBAGLU	10:33	10:40	0:07	TRANSFORMER FAULT
343	19-Sep-21	BENGALURU	66	HV1	MELUR	16:22	17:08	0:45	TRANSFORMER FAULT
344	19-Sep-21	BENGALURU	66	HV1	KAMASAMUDRA	2:20	3:20	1:00	TRANSFORMER FAULT
345	19-Sep-21	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	8:05	8:07	0:02	LINE CLEAR AVAILED
346	19-Sep-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	14:16	14:21	0:04	LINE FAULT
347	19-Sep-21	BENGALURU	66	CHANDAPURA - SARJAPURA	CHANDAPURA	10:08	10:20	0:12	MAIN SUPPLY FAILURE
348	19-Sep-21	BENGALURU	66	CHANDAPURA - YERANDANAHALLI	CHANDAPURA	11:16	11:40	0:24	MAIN SUPPLY FAILURE
349	19-Sep-21	BENGALURU	66	JIGANI LINK ROAD - JAGANI 220	JIGANI LINK ROAD	8:50	9:00	0:10	LOAD CHANGE OVER
350	19-Sep-21	BENGALURU	66	JIGANI LINK ROAD - B G ROAD	JIGANI LINK ROAD	22:05	22:10	0:05	LOAD CHANGE OVER
351	19-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	6:12	6:18	0:06	LINE FAULT
352	19-Sep-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:00	16:32	6:32	LINE CLEAR AVAILED
353	19-Sep-21	BENGALURU	220	MALUR 220 - SOMANHALLI 1	SARJAPURA 220, VIKAS TEC PARK 220	10:08	12:11	2:03	LINE FAULT
354	19-Sep-21	BENGALURU	220	MALUR 220 - SOMANHALLI 1	SARJAPURA 220, VIKAS TEC PARK 220	12:36	15:04	2:28	LINE FAULT
355	19-Sep-21	BENGALURU	220	MALUR 220 - SOMANHALLI 1	SARJAPURA 220, VIKAS TEC PARK 220	15:26	16:52	1:26	LINE FAULT
356	19-Sep-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:08	12:17	2:09	MAIN SUPPLY FAILURE
357	19-Sep-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	10:08	12:16	2:08	MAIN SUPPLY FAILURE
358	19-Sep-21	BENGALURU	220	HV1	SARJAPURA 220	10:08	12:13	2:05	MAIN SUPPLY FAILURE
359	19-Sep-21	BENGALURU	220	HV2	SARJAPURA 220	10:08	12:14	2:06	MAIN SUPPLY FAILURE
360	19-Sep-21	BENGALURU	66	HV1	SARJAPURA 220	10:08	12:17	2:09	MAIN SUPPLY FAILURE
361	19-Sep-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:36	15:17	2:41	MAIN SUPPLY FAILURE
362	19-Sep-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:36	15:19	2:43	MAIN SUPPLY FAILURE
363	19-Sep-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:36	15:18	2:42	MAIN SUPPLY FAILURE
364	19-Sep-21	BENGALURU	220	HV1	SARJAPURA 220	12:36	15:15	2:39	MAIN SUPPLY FAILURE
365	19-Sep-21	BENGALURU	220	HV2	SARJAPURA 220	12:36	15:16	2:40	MAIN SUPPLY FAILURE
366	19-Sep-21	BENGALURU	66	HV1	SARJAPURA 220	12:36	15:20	2:44	MAIN SUPPLY FAILURE
367	19-Sep-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	15:26	21:20	5:54	MAIN SUPPLY FAILURE
368	19-Sep-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:26	17:40	2:14	MAIN SUPPLY FAILURE
369	19-Sep-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	15:26	17:07	1:41	MAIN SUPPLY FAILURE
370	19-Sep-21	BENGALURU	220	HV1	SARJAPURA 220	15:26	17:14	1:48	MAIN SUPPLY FAILURE
371	19-Sep-21	BENGALURU	220	HV2	SARJAPURA 220	15:26	17:06	1:40	MAIN SUPPLY FAILURE
372	19-Sep-21	BENGALURU	66	HV1	SARJAPURA 220	15:26	17:38	2:12	MAIN SUPPLY FAILURE
373	19-Sep-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:19	12:12	0:53	LINE FAULT
374	19-Sep-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	15:25	15:40	0:15	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
375	19-Sep-21	BENGALURU	66	ANEKAL - ATTIBELE	ATTIBELE	14:04	14:49	0:45	LINE FAULT
376	19-Sep-21	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	15:40	15:42	0:02	LOAD CHANGE OVER
377	19-Sep-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	17:10	17:20	0:10	LOAD CHANGE OVER
378	19-Sep-21	BENGALURU	66	JIGANI 66 - JAGANI 220	JIGANI 66	8:55	9:10	0:15	LOAD CHANGE OVER
379	19-Sep-21	BENGALURU	66	JIGANI 66 - YERANDANAHALLI 220	JIGANI 66	18:05	18:50	0:45	LOAD CHANGE OVER
380	19-Sep-21	BENGALURU	220	HV1	JIGANI 220	10:55	18:43	7:48	LINE CLEAR AVAIED
381	19-Sep-21	BENGALURU	220	HV2	JIGANI 220	9:04	18:55	9:51	LINE CLEAR AVAIED
382	19-Sep-21	BENGALURU	66	HV1	JIGANI 220	10:23	18:44	8:21	LINE CLEAR AVAIED
383	19-Sep-21	BENGALURU	66	HV2	JIGANI 220	10:55	18:44	7:49	LINE CLEAR AVAIED
384	19-Sep-21	BENGALURU	220	HV2	HSR LAYOUT 220	15:25(19/09/2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
385	19-Sep-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
386	19-Sep-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:43(19.09.2021)			LINE OPEN: LINE CLEAR AVAIED
387	19-Sep-21	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	12:17	13:14	0:57	LINE FAULT
388	19-Sep-21	GULBARGA	220	HV2	RAICHUR_220	12:18	13:11	0:53	TRANSFORMER FAULT
389	19-Sep-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	12:52	13:27	0:35	LINE FAULT
390	19-Sep-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	22:55(18.09.2021)	5:59(19.09.2021)	6:34HRS	LINE CHARGED
391	19-Sep-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	12:53	13:05	0:12	LINE FAULT
392	19-Sep-21	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	5:34	8:15	2:41	LINE FAULT
393	19-Sep-21	GULBARGA	220	HV2	ALIPUR_220	20:55	22:23	1:28	TRANSFORMER FAULT
394	19-Sep-21	GULBARGA	220	HV1	ALIPUR_220	20:55	21:27	0:32	TRANSFORMER FAULT
395	19-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAIED
396	19-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAIED
397	19-Sep-21	GULBARGA	110	MALLAT-BYAGAWAT	BYGAWAT_110,VALAKAMDINNI_110	18:16	18:26	0:10	LINE FAULT
398	19-Sep-21	GULBARGA	110	MALLAT-MADALAPUR	ADAVIAMARESHWARA_110	15:45	15:55	0:10	LINE FAULT
399	19-Sep-21	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	3:15	3:30	0:15	LINE FAULT
400	19-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	1:44	2:00	0:16	LINE FAULT
401	19-Sep-21	GULBARGA	110	LV1	RAICHUR_220	12:18	12:40	0:22	TRANSFORMER FAULT
402	19-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	19:25	19:35	0:10	LINE FAULT
403	19-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:25	19:35	0:10	LINE FAULT
404	19-Sep-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:03	4:12	0:09	LINE FAULT
405	19-Sep-21	GULBARGA	110	HV2	SHAHAPUR_220	16:15	16:38	0:23	TRANSFORMER FAULT
406	19-Sep-21	GULBARGA	110	KADAGANCHI-KBS SOLAR	KADAGANCHI_110	18:27	18:34	0:07	LINE FAULT
407	19-Sep-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	3:15	3:20	0:05	LINE FAULT
408	19-Sep-21	GULBARGA	110	HV1	NIRNA_110	14:10	14:18	0:08	TRANSFORMER FAULT
409	19-Sep-21	GULBARGA	110	SOMASAMUNNDRA-ALIPUR	SOMASAMUNDRA_110	12:55	13:32	0:37	LINE CLEAR AVAIED
410	19-Sep-21	GULBARGA	110	SOMASAMUNNDRA-ALIPUR	SOMASAMUNDRA_110	20:55	21:32	0:37	MAIN SUPPLY FAILURE
411	19-Sep-21	GULBARGA	110	HV3	VALKAMDINNI_110	6:30	6:50	0:20	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
412	19-Sep-21	GULBARGA	110	HV3	VALKAMDINNI_110	16:25	16:36	0:11	TRANSFORMER FAULT
413	19-Sep-21	GULBARGA	66	NEELAGUNDA-HARAPANAHALLI	HARAPANAHALLI_66	18:26	18:51	0:25	LINE FAULT
414	19-Sep-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
415	19-Sep-21	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN: LINE CLEAR AVAILED
416	19-Sep-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
417	19-Sep-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	3:06	14:59	11:53	LINE FAULT
418	19-Sep-21	HASSAN	220	HV1	HEGGUNJE_220	9:35	17:31	7:56	LINE CLEAR AVAILED
419	19-Sep-21	HASSAN	220	HGUNJE-VRH	HEGGUNJE_220	9:40	17:34	7:54	LINE CLEAR AVAILED
420	19-Sep-21	HASSAN	220	HGUNJE-HV2	HEGGUNJE_220	9:35	17:38	8:03	LINE CLEAR AVAILED
421	19-Sep-21	HASSAN	110	LV2	HEGGUNJE_220	9:35	17:38	8:03	LINE CLEAR AVAILED
422	19-Sep-21	HASSAN	220	HGUNJE-KMR	HEGGUNJE_220	9:27	17:28	8:01	LINE CLEAR AVAILED
423	19-Sep-21	HASSAN	110	HGUNJE-HIRYAD	HEGGUNJE_220	8:51	18:01	9:10	LINE CLEAR AVAILED
424	19-Sep-21	HASSAN	110	HGUNJE-HALADY	HEGGUNJE_220	8:56	18:00	9:04	LINE CLEAR AVAILED
425	19-Sep-21	HASSAN	110	HV1	HEGGUNJE_220	9:33	17:43	8:10	LINE CLEAR AVAILED
426	19-Sep-21	HASSAN	220	KEMAR-HEGUNJE	KEMAR_220	9:27	17:27	8:00	NFBC ISSUED
427	19-Sep-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	13:25	15:13	1:48	LINE FAULT
428	19-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	14:22	15:03	0:41	LINE FAULT
429	19-Sep-21	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	3:06	14:59	11:53	LINE FAULT
430	19-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:16	12:35	0:19	LINE FAULT
431	19-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:02	13:45	1:43	LINE FAULT
432	19-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	14:25	14:55	0:30	LINE FAULT
433	19-Sep-21	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	9:17	9:38	0:21	LINE FAULT
434	19-Sep-21	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	12:16	12:35	0:19	LINE FAULT
435	19-Sep-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:02	13:45	1:43	LINE FAULT
436	19-Sep-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	14:25	14:55	0:30	LINE FAULT
437	19-Sep-21	HASSAN	220	VARAHI-KEMAR3	varahi_gen	9:39	17:34	7:55	NFBC ISSUED
438	19-Sep-21	HASSAN	220	GOPALAP-BASTIPURA	GOPALAPURA_220	11:00	12:20	1:20	LINE FAULT
439	19-Sep-21	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	9:00	18:01	9:01	NFBC ISSUED
440	19-Sep-21	HASSAN	110	HIRIYA-HIRIYA-HALADY	HIRIYADKA_110	9:00	18:01	9:01	NFBC ISSUED
441	19-Sep-21	HASSAN	110	HV1	MSEZ_220	10:03	13:16	3:13	LINE CLEAR AVAILED
442	19-Sep-21	HASSAN	110	HV2	MSEZ_220	13:10	14:48	1:38	LINE CLEAR AVAILED
443	19-Sep-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	9:17	9:38	0:21	LINE FAULT
444	19-Sep-21	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	18:09	18:28	0:19	LINE FAULT
445	19-Sep-21	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	18:09	19:10	1:01	LINE FAULT
446	19-Sep-21	MYSURU	66	BANNIMANTAP-FTS	NO STATIONS EFFECTED	8:28	7:12	22:44	NFBC ISSUED
447	19-Sep-21	MYSURU	66	HV1	BGNAGARA_66	10:15	17:42	7:27	LINE CLEAR AVAILED
448	19-Sep-21	MYSURU	66	HV2	BGNAGARA_66	10:15	17:43	7:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
449	19-Sep-21	MYSURU	66	BG NAGARA -ADDIHALLY	BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66	6:12	17:34	11:22	NFBC ISSUED
450	19-Sep-21	MYSURU	66	CR NAGARA-DR PETE-1	DODDARAYAPET_66 SANTHEMARAHALLI_66	9:29	10:13	0:44	HAND TRIPPED
451	19-Sep-21	MYSURU	66	CR NAGARA-DR PETE-2	DODDARAYAPET_66 SANTHEMARAHALLI_66	9:29	10:13	0:44	HAND TRIPPED
452	19-Sep-21	MYSURU	220	CR NAGARA-HV1	NO STATIONS EFFECTED	12:18	16:06	3:48	LINE CLEAR AVAILED
453	19-Sep-21	MYSURU	220	CR NAGARA-MADHUVANAHALLI-1	MADHUVANAHALLI_220 AJJIPURA_66 CHANDALLI_66 COWDALLI_66 DODDINADUVADI_66 HANNUR_66 JANNUR_66 KOLLEGALA_66 KOTTANUR_66 KUNTHUR_66 MAMBALLI_66 MUGUR_66 PARINAMIPURA_66 PGPALYA_66 RAMAPURA_MYS_66 SANTHEMARAHALLI_66 SATHEGALA_66 THALAKADU_66 THAYURU_66 TNARASIPURA_66	9:32	9:46	0:14	HAND TRIPPED
454	19-Sep-21	MYSURU	220	CR NAGARA-MADHUVANAHALLI-2	MADHUVANAHALLI_220 AJJIPURA_66 CHANDALLI_66 COWDALLI_66 DODDINADUVADI_66 HANNUR_66 JANNUR_66 KOLLEGALA_66 KOTTANUR_66 KUNTHUR_66 MAMBALLI_66 MUGUR_66 PARINAMIPURA_66 PGPALYA_66 RAMAPURA_MYS_66 SANTHEMARAHALLI_66 SATHEGALA_66 THALAKADU_66 THAYURU_66 TNARASIPURA_66	9:32	9:46	0:14	HAND TRIPPED
455	19-Sep-21	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66 MAMBALLI_66	9:35	9:52	0:17	LINE FAULT
456	19-Sep-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	14:09	14:16	0:06	LINE FAULT
457	19-Sep-21	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	9:00	16:58	7:58	NFBC ISSUED
458	19-Sep-21	MYSURU	66	FTS-RAJEEV NAGARA	FTS_66	10:10	18:02	7:52	LINE CLEAR AVAILED
459	19-Sep-21	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	8:50	18:52	10:02	LINE CLEAR AVAILED
460	19-Sep-21	MYSURU	66	HARADANJ-LAXJEET	NO STATIONS EFFECTED	12:33	12:39	0:06	LINE FAULT
461	19-Sep-21	MYSURU	66	HARVEY-BEGUR	HARVEY_66	9:30	17:28	7:58	LINE CLEAR AVAILED
462	19-Sep-21	MYSURU	66	HEBBAL-HOOTAGALLI	HEBBAL_66	10:09	14:32	4:23	LINE CLEAR AVAILED
463	19-Sep-21	MYSURU	66	HEBBAL-METAGALLI	METAGALLY_66	10:06	17:49	7:43	NFBC ISSUED
464	19-Sep-21	MYSURU	66	KADAKOLA-MANTAGALLI	MANTAGALLI_66	10:05	15:55	5:50	NFBC ISSUED
465	19-Sep-21	MYSURU	66	RK NAGARA-MANTAGALLI	NO STATIONS EFFECTED	10:08	16:35	6:27	NFBC ISSUED
466	19-Sep-21	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	13:24	13:35	0:10	LINE FAULT
467	19-Sep-21	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	13:50	14:23	0:33	HAND TRIPPED
468	19-Sep-21	MYSURU	66	KUSHALNAGARA 220RAMANTHAPURA 1	KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66	1:14	1:20	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
469	19-Sep-21	MYSURU	66	KUSHALNAGARA 220SUNTIKOPPA	SUNTIKOPPA_66	13:50	14:23	0:33	HAND TRIPPED
470	19-Sep-21	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	15:47	16:14	0:26	LINE CLEAR AVAILED
471	19-Sep-21	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	17:02	17:41	0:39	LINE CLEAR AVAILED
472	19-Sep-21	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	15:32	15:59	0:26	LINE CLEAR AVAILED
473	19-Sep-21	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	15:59	16:42	0:42	LINE CLEAR AVAILED
474	19-Sep-21	MYSURU	66	HV1	MADHUVANAHALLI_220	13:05	13:58	0:53	LINE CLEAR AVAILED
475	19-Sep-21	MYSURU	66	HV2	MADHUVANAHALLI_220	14:08	14:52	0:44	LINE CLEAR AVAILED
476	19-Sep-21	MYSURU	66	MADHUVANAHALLI-KOLLEGALA 1	NO STATIONS EFFECTED	16:41	17:16	0:35	LINE CLEAR AVAILED
477	19-Sep-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66 LOKKANAHALLI_66	15:56	16:21	0:24	LINE CLEAR AVAILED
478	19-Sep-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	15:06	18:54	3:47	LINE CLEAR AVAILED
479	19-Sep-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	19:39	19:46	0:07	HAND TRIPPED
480	19-Sep-21	MYSURU	66	MADHUVANAHALLI-DODDINADUWADI	NO STATIONS EFFECTED	17:24	18:54	1:29	LINE CLEAR AVAILED
481	19-Sep-21	MYSURU	220	VAJMANGALA-TKHALLI	NO STATIONS EFFECTED	7:30	19:10	11:40	NFBC ISSUED
482	19-Sep-21	MYSURU	66	KIADB MANDYA-HV1	K_HONNALGERE_66 KMDODDI_66 KKDODDI_66 KIADBMANDYA_66 SOMANAHALLI_66 TUMBEEKERE_66	9:32	10:35	1:03	LINE CLEAR AVAILED
483	19-Sep-21	MYSURU	66	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	13:24(19.9.21)			LINE OPEN: LINE FAULT
484	19-Sep-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
485	19-Sep-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
486	19-Sep-21	MYSURU	66	KR NAGARA-CHUNCHUNKATTE	NO STATIONS EFFECTED	16:41 (13.09.2021)			LINE OPEN: LINE CLEAR AVAILED
487	19-Sep-21	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:15 (14.9.2021)			LINE OPEN: LINE CLEAR AVAILED
488	19-Sep-21	TUMKUR	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	13:25	15:13	1:48	LINE FAULT
489	19-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	13:26	14:42	1:15	LINE FAULT
490	19-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	10:26	17:31	7:05	LINE CLEAR AVAILED
491	19-Sep-21	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	12:21	12:37	0:15	MAIN SUPPLY FAILURE
492	19-Sep-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	11:31	12:11	0:40	LINE CLEAR AVAILED
493	19-Sep-21	TUMKUR	66	TR-2	GULIGENAHALLI_66	16:05	16:36	0:30	LINE CLEAR AVAILED
494	19-Sep-21	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	7:36	7:46	0:10	LINE FAULT
495	19-Sep-21	TUMKUR	66	TR-1	MAVINAKATTE_66	11:56	12:19	0:23	LINE CLEAR AVAILED
496	19-Sep-21	TUMKUR	66	TR-1	P R PURA	7:15	7:45	0:30	MAIN SUPPLY FAILURE
497	19-Sep-21	TUMKUR	66	TR-1	PURUVARA_66	13:10	14:04	0:54	TRANSFORMER FAULT
498	19-Sep-21	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	12:24	12:34	0:10	LINE FAULT
499	19-Sep-21	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	12:22	12:34	0:11	LINE FAULT
500	19-Sep-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	11:31	18:28	6:56	LINE CLEAR AVAILED
1	20-Sep-21	BAGALKOT	66	66/11KV,HV2	HARIHAR HOSPET_66	11:53	15:18	3:25	LINE CLEAR AVAILED
2	20-Sep-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
3	20-Sep-21	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
4	20-Sep-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
5	20-Sep-21	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	11:04	12:11	1:07	TRANSFORMER FAULT
6	20-Sep-21	BAGALKOT	110	110/11KV,HV1	GULEDGUDDA_110	20:50	21:45	0:55	HAND TRIPPED
7	20-Sep-21	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	18:15	18:36	0:21	HAND TRIPPED
8	20-Sep-21	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	10:52	11:05	0:13	HAND TRIPPED
9	20-Sep-21	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:53	12:59	0:06	HAND TRIPPED
10	20-Sep-21	BAGALKOT	110	ATHANI220- AIGALI	AIGALI_110	12:32	12:40	0:08	LINE FAULT
11	20-Sep-21	BAGALKOT	110	ATHANI220- HALIYAL	HALIYAL_110	11:10	11:18	0:08	HAND TRIPPED
12	20-Sep-21	BAGALKOT	110	ATHANI220- HALIYAL	HALIYAL_110	16:15	20:03	3:48	LINE CLEAR AVAILED
13	20-Sep-21	BAGALKOT	110	ATHANI220- HALIYAL	HALIYAL_110	20:06	20:17	0:11	LINE FAULT
14	20-Sep-21	BAGALKOT	110	ATHANI220- HALIYAL	HALIYAL_110	20:27	20:31	0:04	HAND TRIPPED
15	20-Sep-21	BAGALKOT	110	ATHANI220- KSSKN	ATHANI_220	17:27	20:03	2:36	LINE CLEAR AVAILED
16	20-Sep-21	BAGALKOT	110	BABLESHWAR-MAMADAPUR	BABLESHWAR_110	11:26	11:37	0:11	LINE CLEAR AVAILED
17	20-Sep-21	BAGALKOT	110	BAGALKOT220- NAVANAGAR1	NAVANAGAR_110	14:54	17:12	2:18	LINE CLEAR AVAILED
18	20-Sep-21	BAGALKOT	110	GHATAPRABHA-KABBUR	KABBUR_110	11:13	16:27	5:14	LINE CLEAR AVAILED
19	20-Sep-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
20	20-Sep-21	BAGALKOT	110	HALIYAL-GMR	HALIYAL_110	9:52	10:00	0:08	HAND TRIPPED
21	20-Sep-21	BAGALKOT	110	HUKKERI-VS SUGARS	HUKKERI_110	11:58	17:20	5:22	LINE CLEAR AVAILED
22	20-Sep-21	BAGALKOT	110	HUNGUND -KUDALASANGAM	KUDALASANGAM_110	23:03	23:47	0:44	LINE FAULT
23	20-Sep-21	BAGALKOT	110	INDI- HIREMASALI	HIREMASALI_110	3:45	3:49	0:04	MAIN SUPPLY FAILURE
24	20-Sep-21	BAGALKOT	110	MALGHAN-MANALI SUGARS	MALGHAN(S)_110	21:33	21:42	0:09	LINE FAULT
25	20-Sep-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
26	20-Sep-21	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN: LINE CLEAR AVAILED
27	20-Sep-21	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	09:06 (10.09.2021)			LINE OPEN: LINE CLEAR AVAILED
28	20-Sep-21	BAGALKOT	110	TARIHAL-IDLE(KIADB)	TARIHAL_110	10:16	10:21	0:05	HAND TRIPPED
29	20-Sep-21	BAGALKOT	110	TODALABAGI-MAMADAPUR	TODALABAGI_110	9:55	13:50	3:55	LINE CLEAR AVAILED
30	20-Sep-21	BAGALKOT	110	TODALABAGI-MAMADAPUR	TODALABAGI_110	16:18	17:48	1:30	LINE CLEAR AVAILED
31	20-Sep-21	BAGALKOT	220	220/110KV, HV3&LV3	HUBLI_220	11:20	12:44	1:24	LINE CLEAR AVAILED
32	20-Sep-21	BAGALKOT	220	220/110KV, HV3&LV3	GADAG_220	12:50	17:32	4:42	LINE CLEAR AVAILED
33	20-Sep-21	BAGALKOT	220	220/110KV,HV2&LV2	BAGALKOT_220	11:10	12:22	1:12	LINE CLEAR AVAILED
34	20-Sep-21	BAGALKOT	220	BELGAUM- CHIKKODI1	BELGAUM_220	10:22 (20.09.2021)			LINE OPEN: LINE CLEAR AVAILED
35	20-Sep-21	BAGALKOT	220	BIDNAL- HARTI2	BIDNAL_220	18:01 (20.09.2021)			LINE OPEN: LINE FAULT
36	20-Sep-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
37	20-Sep-21	BAGALKOT	220	GADAG- LINGAPUR1(DHONI1)	GADAG_220	10:55	15:34	4:39	LINE CLEAR AVAILED
38	20-Sep-21	BAGALKOT	220	GADAG- LINGAPUR2(DHONI2)	GADAG_220	15:37	18:19	2:42	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
39	20-Sep-21	BAGALKOT	220	GADAG-HARTHI1	STATION NOT AFFECTED GADAG_220	13:08 (14.09.2021)			LINE OPEN: LINE CLEAR AVAILED
40	20-Sep-21	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:32	15:58	4:26	LINE CLEAR AVAILED
41	20-Sep-21	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	10:28	15:55	5:27	LINE CLEAR AVAILED
42	20-Sep-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	12:55 (19.09.2021)			LINE OPEN: LINE FAULT
43	20-Sep-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
44	20-Sep-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
45	20-Sep-21	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	11:21	15:58	4:37	LINE CLEAR AVAILED
46	20-Sep-21	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	15:56 (20.09.2021)			LINE OPEN: LINE CLEAR AVAILED
47	20-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)	11:21 (20.09.2021)	212:23 hrs	LINE CHARGED
48	20-Sep-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN: LINE CLEAR AVAILED
49	20-Sep-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
50	20-Sep-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
51	20-Sep-21	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA, YELDUR	12:48	12:52	0:04	LINE FAULT
52	20-Sep-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:09	18:37	0:27	LINE CLEAR AVAILED
53	20-Sep-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:37	18:45	0:08	LINE FAULT
54	20-Sep-21	BENGALURU	66	DABUSPET 220 - HIREHALI	HIREHALI, HONNUDIKE	14:10	16:00	1:49	LINE CLEAR AVAILED
55	20-Sep-21	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	8:15	8:22	0:07	LOAD CHANGE OVER
56	20-Sep-21	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	16:47	16:50	0:03	LOAD CHANGE OVER
57	20-Sep-21	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	6:40	6:50	0:10	LOAD CHANGE OVER
58	20-Sep-21	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	2:12	2:15	0:03	LOAD CHANGE OVER
59	20-Sep-21	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	8:10	8:12	0:02	LOAD CHANGE OVER
60	20-Sep-21	BENGALURU	66	HOSUR RAMAPURA - NITRALLI	NO STATION AFFECTED	15:31	15:54	0:23	LINE CLEAR AVAILED
61	20-Sep-21	BENGALURU	66	HV1	HSR LAYOUT 220	13:20	13:44	0:24	TRANSFORMER FAULT
62	20-Sep-21	BENGALURU	66	HV1	KUMBALAGODU	9:15	9:25	0:10	LINE CLEAR AVAILED
63	20-Sep-21	BENGALURU	66	HV1	RAJANUKUNTE	13:30	13:35	0:05	TRANSFORMER FAULT
64	20-Sep-21	BENGALURU	66	HV1	VIJAYANAGARA	7:36	7:41	0:05	LOAD CHANGE OVER
65	20-Sep-21	BENGALURU	66	HV1	VRISHABHAVATHI 220	12:55	12:59	0:04	LINE CLEAR AVAILED
66	20-Sep-21	BENGALURU	66	HV1	M GOLLAHALLI	2:50	3:07	0:17	TRANSFORMER FAULT
67	20-Sep-21	BENGALURU	66	HV1	KIADB HARDWARE PARK DEVANAHALLI 220	16:33	16:41	0:08	TRANSFORMER FAULT
68	20-Sep-21	BENGALURU	66	HV1	CHANDAPURA	14:16	14:26	0:09	TRANSFORMER FAULT
69	20-Sep-21	BENGALURU	66	HV1	MITTEMARI 220	15:42	16:12	0:30	MAIN SUPPLY FAILURE
70	20-Sep-21	BENGALURU	66	HV2	VOLVO	2:29	2:35	0:05	TRANSFORMER FAULT
71	20-Sep-21	BENGALURU	66	HV3	ELECTRONIC CITY	8:11	8:28	0:17	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
72	20-Sep-21	BENGALURU	66	HV3	YARANDANAHALLI 220	9:05	9:30	0:25	TRANSFORMER FAULT
73	20-Sep-21	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	NO STATION AFFECTED	12:21	20:01	7:40	LINE CLEAR AVAILED
74	20-Sep-21	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON, SUBRAMANYAPURA 66	8:18	8:28	0:10	LOAD CHANGE OVER
75	20-Sep-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	16:01	16:21	0:20	LINE FAULT
76	20-Sep-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	16:03	16:17	0:14	LINE FAULT
77	20-Sep-21	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	10:39	17:24	6:45	LINE CLEAR AVAILED
78	20-Sep-21	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	1:15	1:45	0:30	LINE FAULT
79	20-Sep-21	BENGALURU	66	KODIGEHALI - BYDRAHALI	KODIGEHALI, TAVAREKERE	12:18	12:24	0:06	LINE FAULT
80	20-Sep-21	BENGALURU	66	KODIHALLI - SRINIVASPURA	SRINIVASPURA, YELDUR	12:50	13:00	0:10	LINE FAULT
81	20-Sep-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	14:59	17:01	2:01	LINE FAULT
82	20-Sep-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	15:42	16:13	0:31	MAIN SUPPLY FAILURE
83	20-Sep-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	15:42	16:12	0:30	MAIN SUPPLY FAILURE
84	20-Sep-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	15:42	16:12	0:30	MAIN SUPPLY FAILURE
85	20-Sep-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	15:42	16:13	0:31	MAIN SUPPLY FAILURE
86	20-Sep-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	15:42	16:13	0:31	MAIN SUPPLY FAILURE
87	20-Sep-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	13:43	13:48	0:05	LINE FAULT
88	20-Sep-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	15:42	16:12	0:30	MAIN SUPPLY FAILURE
89	20-Sep-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	15:42	16:12	0:30	MAIN SUPPLY FAILURE
90	20-Sep-21	BENGALURU	66	RBI - KHODAYS 220	RBI	18:35	18:38	0:03	LOAD CHANGE OVER
91	20-Sep-21	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	16:50	16:56	0:06	LOAD CHANGE OVER
92	20-Sep-21	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	14:39	15:12	0:33	LINE CLEAR AVAILED
93	20-Sep-21	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	16:23	16:44	0:21	LINE CLEAR AVAILED
94	20-Sep-21	BENGALURU	66	T G HALLI 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	7:21	7:54	0:33	LINE FAULT
95	20-Sep-21	BENGALURU	66	V R DODDI - SOMANAHALLI 220	V R DODDI	6:35	6:40	0:05	LOAD CHANGE OVER
96	20-Sep-21	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	0:06	0:21	0:14	LINE FAULT
97	20-Sep-21	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	1:40	1:47	0:06	LINE FAULT
98	20-Sep-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	6:58	7:05	0:07	LOAD CHANGE OVER
99	20-Sep-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:34	6:52	0:17	LINE FAULT
100	20-Sep-21	BENGALURU	66	YERANDAHALLI 220 - ANEKAL	ANEKAL	14:35	15:18	0:43	LINE CLEAR AVAILED
101	20-Sep-21	BENGALURU	66	YERANDAHALLI 220 - ANEKAL	ANEKAL	16:22	16:45	0:23	LINE CLEAR AVAILED
102	20-Sep-21	BENGALURU	220	DABUSPET 220 - NELAMNGALA 400	NO STATION AFFECTED	13:50	15:42	1:51	LINE FAULT
103	20-Sep-21	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	15:42	16:02	0:20	LINE FAULT
104	20-Sep-21	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	15:42	16:12	0:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
105	20-Sep-21	BENGALURU	220	HV1	MITTEMARI 220	15:42	16:12	0:30	MAIN SUPPLY FAILURE
106	20-Sep-21	BENGALURU	220	HV2	MITTEMARI 220	15:42	16:12	0:30	MAIN SUPPLY FAILURE
107	20-Sep-21	BENGALURU	220	HV2	HSR LAYOUT 220	15:25(19/09/2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
108	20-Sep-21	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	15:42	16:02	0:20	LINE FAULT
109	20-Sep-21	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	15:42	16:12	0:30	LINE FAULT
110	20-Sep-21	BENGALURU	220	NELMANGALA 400 - DABUSPETE 2	NO STATION AFFECTED	13:50	15:44	1:53	LINE FAULT
111	20-Sep-21	GULBARGA	66	MUNIRABAD-MHD LINE	VENKATAPUR_66,RRSTRRLS,UP HALLI_66	11:12(20.09.2021)			LINE OPEN: LINE CLEAR AVAILED
112	20-Sep-21	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110	6:25	6:32	0:07	LINE FAULT
113	20-Sep-21	GULBARGA	110	HV1	MANVI_110	10:48	11:49	1:01	LINE CLEAR AVAILED
114	20-Sep-21	GULBARGA	110	HV1	MANVI_110	15:41	15:49	0:08	TRANSFORMER FAULT
115	20-Sep-21	GULBARGA	110	HV1	MANVI_110	15:51	16:00	0:09	TRANSFORMER FAULT
116	20-Sep-21	GULBARGA	110	HV2	MANVI_110	9:52	11:29	1:37	LINE CLEAR AVAILED
117	20-Sep-21	GULBARGA	110	HV2	NIRNA_110	9:42	9:46	0:04	TRANSFORMER FAULT
118	20-Sep-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	18:51	18:59	0:08	LINE FAULT
119	20-Sep-21	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110	3:52	4:35	0:43	LINE FAULT
120	20-Sep-21	GULBARGA	110	LV1	SHAHAPUR_220	4:10	4:18	0:08	TRANSFORMER FAULT
121	20-Sep-21	GULBARGA	110	RAICHUR-APMC1,2	APMC_110,CHIKKASUGUR_110,SHAKTH INAGA_110	21:52	21:57	0:05	LINE FAULT
122	20-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GABBUR_110,DEODURGA_110,GOOGLE_110	4:00	4:20	0:20	LINE FAULT
123	20-Sep-21	GULBARGA	110	RAICHUR-SHAHAPUR1&2	GABBUR_110,DEODURGA_110,GOOGLE_110	5:00	5:05	0:05	LINE FAULT
124	20-Sep-21	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	23:29	23:34	0:05	LINE FAULT
125	20-Sep-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	14:02	14:06	0:04	LINE FAULT
126	20-Sep-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
127	20-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1	GULBARGA UNIVERSITY_110	3:45	3:50	0:05	LINE FAULT
128	20-Sep-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
129	20-Sep-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	4:39	4:56	0:17	LINE FAULT
130	20-Sep-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	5:29	5:41	0:12	LINE FAULT
131	20-Sep-21	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	4:10	4:28	0:18	LINE FAULT
132	20-Sep-21	GULBARGA	110	YELBURGA-PRPJ SLR	YELBURGA_110	9:56	10:05	0:09	LOAD CURTAILMENT
133	20-Sep-21	GULBARGA	220	HV2	ALIPUR_220	23:51(19.09.2021)	00:39(20.09.2021)	00:48HRS	LINE CHARGED
134	20-Sep-21	GULBARGA	220	KAPNOOR-SHAHAPUR	SHAHAPUR_220	11:19	14:25	3:06	LINE CLEAR AVAILED
135	20-Sep-21	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	9:37	18:48	9:11	LINE FAULT
136	20-Sep-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	23:43(19.09.2021)	6:17(20.09.2021)	6:34HRS	LINE CHARGED
137	20-Sep-21	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	23:02	23:06	0:04	LINE FAULT
138	20-Sep-21	GULBARGA	220	SHAHAPUR-KAPNOOR	SHAHAPUR_220	11:15	14:25	3:10	NFBC ISSUED
139	20-Sep-21	GULBARGA	400	JSWL-BPS	BPS_400	11:33	13:19	1:46	NFBC ISSUED
140	20-Sep-21	GULBARGA	400	RTPS-BTPS	RTPS_400	11:44	16:59	5:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
141	20-Sep-21	HASSAN	66	HV1	SOMANAHALLI_66	15:35	15:40	0:05	HAND TRIPPED
142	20-Sep-21	HASSAN	66	HV1	SOMANAHALLI_66	17:05	17:10	0:05	HAND TRIPPED
143	20-Sep-21	HASSAN	66	HV2	RAMNATHPURA_66	12:02	14:17	2:15	LINE CLEAR AVAILED
144	20-Sep-21	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	11:24	12:57	1:33	LINE CLEAR AVAILED
145	20-Sep-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
146	20-Sep-21	HASSAN	110	HV2	ESSUR_110	11:27	12:44	1:17	LINE CLEAR AVAILED
147	20-Sep-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
148	20-Sep-21	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	9:18(19.09.2021)			LINE OPEN: LINE CLEAR AVAILED
149	20-Sep-21	HASSAN	220	GERUSOPA-SHIMOGA	gerusoppa_gen	10:15	11:56	1:41	LINE CLEAR AVAILED
150	20-Sep-21	HASSAN	220	HSN4001	MRSMG_220	12:00	15:00	3:00	LINE FAULT
151	20-Sep-21	HASSAN	220	MRSSHM-DVG2	MRSMG_220	17:08 (30.08.2021)			LINE OPEN: LINE CLEAR AVAILED
152	20-Sep-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	10:15	11:56	1:41	LINE CLEAR AVAILED
153	20-Sep-21	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	9:18(19.09.2021)			LINE OPEN: LINE CLEAR AVAILED
154	20-Sep-21	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:15 (14.9.2021)	13:10:00 (21.09.2021)	172:55 hrs	LINE CHARGED
155	20-Sep-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	12:04	12:10	0:05	LINE FAULT
156	20-Sep-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	16:50 (13.09.2021)	13:25:00 (21.09.2021)	188:34 hrs	LINE CHARGED
157	20-Sep-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	16:50 (13.09.2021)	13:25:00 (21.09.2021)	188:34 hrs	LINE CHARGED
158	20-Sep-21	MYSURU	66	HV 1	MADIKERI_66	16:10	17:00	0:50	LINE CLEAR AVAILED
159	20-Sep-21	MYSURU	66	HV1	BANNIMANTAPA-	10:48	14:09	22:44	LINE CLEAR AVAILED
160	20-Sep-21	MYSURU	66	HV1	KKDODDI_66	11:40	13:08	1:28	LINE CLEAR AVAILED
161	20-Sep-21	MYSURU	66	HV2	PANDAVAPURA_66	14:44	14:55	0:11	TRANSFORMER FAULT
162	20-Sep-21	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	18:45	18:51	0:06	LINE FAULT
163	20-Sep-21	MYSURU	66	KADAKOLA-SARGUR 1	HAMPAPURA_66 JAIPUR_66	6:40	6:50	0:10	LINE FAULT
164	20-Sep-21	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	11:08	11:19	0:10	LINE FAULT
165	20-Sep-21	MYSURU	66	KR NAGARA-CHUNCHUNKATTE	NO STATIONS EFFECTED	16:41 (13.09.2021)	13:00:00 (21.09.2021)	188:18 hrs	LINE CHARGED
166	20-Sep-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)	13:05:00 (21.09.2021)	809:02 hrs	LINE CHARGED
167	20-Sep-21	MYSURU	66	KR PETE 220-SANTEBACHALLI	ADICHUNCHANAGIRI_66 SANTHEBACHALLI_66 VADERALLI_66 BGNAGARA_66	7:12	7:19	0:06	LINE FAULT
168	20-Sep-21	MYSURU	66	MADHUVANALLI-MAMBALLI	YELANDUR_66 MAMBALLI_66	9:57	10:02	0:04	LINE FAULT
169	20-Sep-21	MYSURU	66	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	13:24:24 (19.09.2021)	13:40:00 (20.09.2021)	24:15 hrs	LINE CHARGED
170	20-Sep-21	MYSURU	66	MEGLAPURA-HEBBANI	NO STATIONS EFFECTED	9:20	9:31	0:11	LINE FAULT
171	20-Sep-21	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	12:39:06(20.09.2021)			LINE OPEN: LINE CLEAR AVAILED
172	20-Sep-21	MYSURU	66	TUBINKERE-PANDAVAPURA	NO STATIONS EFFECTED	5:42	5:52	0:10	HAND TRIPPED
173	20-Sep-21	MYSURU	220	HV1	TUBINAKERE_220	9:13:35 (17/09/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
174	20-Sep-21	MYSURU	220	VAJMANGLA-TK HALLI	NO STATIONS EFFECTED	7:26	19:24	11:58	LINE FAULT
175	20-Sep-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2(KUDUR)	KUDUR_66, HULLENAHALLI_66	14:20	15:25	1:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
176	20-Sep-21	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	14:25	15:24	0:58	HAND TRIPPED
177	20-Sep-21	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	14:21	15:26	1:04	LINE CLEAR AVAILED
178	20-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:09	11:45	0:36	LINE CLEAR AVAILED
179	20-Sep-21	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	13:40	14:15	0:35	LINE FAULT
180	20-Sep-21	TUMKUR	66	HANAGAL- B G KERE	BGKERE_66, GUDEKOTE_66	12:27	12:43	0:15	HAND TRIPPED
181	20-Sep-21	TUMKUR	66	HANAGAL-GUDEKOTE(THALLAK)	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	16:55	17:02	0:07	HAND TRIPPED
182	20-Sep-21	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	8:27	8:40	0:13	LINE FAULT
183	20-Sep-21	TUMKUR	66	TR-1	HIRIYUR_66	6:28	6:40	0:11	TRANSFORMER FAULT
184	20-Sep-21	TUMKUR	66	TR-1	KORATAGERE_66	9:20	9:33	0:12	TRANSFORMER FAULT
185	20-Sep-21	TUMKUR	66	TR-1	LINGADAHALLI_66	15:38	16:14	0:36	LINE CLEAR AVAILED
186	20-Sep-21	TUMKUR	66	TR-1	RANGANATHAPURA_66	8:02	8:50	0:47	LINE CLEAR AVAILED
187	20-Sep-21	TUMKUR	66	TR1(LV-1)	ANCHEPALUA_220	14:20	15:21	1:00	LINE CLEAR AVAILED
188	20-Sep-21	TUMKUR	66	TR-2	SASALUHALLA_66	12:04	13:09	1:05	LINE CLEAR AVAILED
189	20-Sep-21	TUMKUR	110	HONNAVALI 110- KADUR220(ARASEKERE)	HONNAVALI_110	16:00	16:05	0:04	HAND TRIPPED
190	20-Sep-21	TUMKUR	110	TR-1	BANDIHALLI_110	1:43	1:55	0:11	TRANSFORMER FAULT
191	20-Sep-21	TUMKUR	110	TR-2	MAYASANDRA_110	2:44	18:27	15:43	TRANSFORMER FAULT
192	20-Sep-21	TUMKUR	110	TR-2	HONNAVALI_110	16:00	17:00	1:00	LINE CLEAR AVAILED
193	20-Sep-21	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	13:17	13:55	0:38	LINE CLEAR AVAILED
194	20-Sep-21	TUMKUR	220	TR-1	ANCHEPALUA_220	14:20	15:19	0:59	TRANSFORMER FAULT