

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 17.08.2021 to 23.08.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	17-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVOIDED
2	17-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
3	17-Aug-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MAMADAPUR(B)_110	13:39	13:58	0:19	LINE CLEAR AVOIDED
4	17-Aug-21	BAGALKOT	110	110/33KV, HV2	BHOJ_33 STATION NOT AFFECTED SADALGA_110	16:20	16:30	0:10	LINE CLEAR AVOIDED
5	17-Aug-21	BAGALKOT	110	110/33KV,HV3	RSSKN_33,BATAKURKI_33 LOKAPUR_110	16:47	16:50	0:03	TRANSFORMER FAULT
6	17-Aug-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED HUBLI_220	9:59	13:34	3:35	LINE CLEAR AVOIDED
7	17-Aug-21	BAGALKOT	110	ALBAL-Saipriya	ALBAL_110	9:52	12:30	2:38	LINE CLEAR AVOIDED
8	17-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN: LINE CLEAR AVOIDED
9	17-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN: LINE CLEAR AVOIDED
10	17-Aug-21	BAGALKOT	110	ASHOK IRON PLANT-MACHE	MACHE_110	11:30	12:14	0:44	HAND TRIPPED
11	17-Aug-21	BAGALKOT	110	GAMESH-KULIGOD	KULIGOD_110	20:20	21:07	0:47	HAND TRIPPED
12	17-Aug-21	BAGALKOT	110	GHATAPRABHA-PG HUNSHYAL	PG HUNSHYAL_110	20:16	20:33	0:17	LINE FAULT
13	17-Aug-21	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	STATION NOT AFFECTED GHATAPRABHA_110	20:08	20:17	0:09	LINE FAULT
14	17-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVOIDED
15	17-Aug-21	BAGALKOT	110	HIREBEVANUR-SHIVSAGAR SUGAR	HIREBEVANUR_110	7:24	9:15	1:51	LINE FAULT
16	17-Aug-21	BAGALKOT	110	JAMAKHANDI-(SIDDAPUR)MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	1:33	1:38	0:05	LINE FAULT
17	17-Aug-21	BAGALKOT	110	JAMBAGI-HALKI(MUDHOL)	HALKI_110	5:20	5:27	0:07	LINE FAULT
18	17-Aug-21	BAGALKOT	110	KULIGERE CROSS-KERUR	KERUR_110	12:16	12:30	0:14	LINE CLEAR AVOIDED
19	17-Aug-21	BAGALKOT	110	MALAGHAN(B)-BASAVESHVAR SUGARS	BASAVESHVAR SUGARS_110 STATION NOT AFFECTED MALAGHAN(B)_110	23:03 (17.08.2021)			LINE OPEN: LINE FAULT
20	17-Aug-21	BAGALKOT	110	NAVALGUND-BIDNAL220	STATION NOT AFFECTED NAVALAGUND_110	10:06 (16.08.2021)	12:33 (17.08.2021)	2:27	LINE CHARGED
21	17-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN: LINE CLEAR AVOIDED
22	17-Aug-21	BAGALKOT	110	RAMANAKOPPA-MUNDAGOD(SAVANUR)	MUNDAGOD_110	3:32	3:55	0:23	LINE FAULT
23	17-Aug-21	BAGALKOT	110	RAMANAKOPPA-MUNDAGOD(SAVANUR)	STATION NOT AFFECTED RAMANAKOPPA_110	6:06	11:21	5:15	LINE FAULT
24	17-Aug-21	BAGALKOT	110	RANEBENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI_110	15:42 (10.08.2021)			LINE OPEN: LINE CLEAR AVOIDED
25	17-Aug-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
26	17-Aug-21	BAGALKOT	110	VADAGAON-BELGAUM220	STATION NOT AFFECTED VADAGAON_110	12:09	14:50	2:41	LINE CLEAR AVOIDED
27	17-Aug-21	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED HUBLI_220	9:59	13:33	3:34	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
28	17-Aug-21	BAGALKOT	220	BAGALKOT-ADPH1(ADPH2)	BAGLKOT_220	9:35	13:15	3:40	LINE CLEAR AVAILED
29	17-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
30	17-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
31	17-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
32	17-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
33	17-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
34	17-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
35	17-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
36	17-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
37	17-Aug-21	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	23:11	23:16	0:05	LOAD CHANGE OVER
38	17-Aug-21	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	10:17	10:18	0:01	LOAD CHANGE OVER
39	17-Aug-21	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 220	BAGEPALLI	17:35	17:43	0:08	LOAD CHANGE OVER
40	17-Aug-21	BENGALURU	66	HV1	BMTC	15:10	15:12	0:02	LOAD CHANGE OVER
41	17-Aug-21	BENGALURU	66	HV1	YARANDANAHALLI 220	9:05	19:00	9:55	LINE CLEAR AVAILED
42	17-Aug-21	BENGALURU	66	HV1	VIDHURASHWATHA	16:45	16:50	0:05	LINE CLEAR AVAILED
43	17-Aug-21	BENGALURU	66	HV1	HUKUNDA	10:45	18:01	7:16	LINE CLEAR AVAILED
44	17-Aug-21	BENGALURU	66	HV2	BMTC	11:35	11:38	0:03	LOAD CHANGE OVER
45	17-Aug-21	BENGALURU	66	HV2	NRS 220	15:08	16:27	1:19	LINE CLEAR AVAILED
46	17-Aug-21	BENGALURU	66	HV2	REMCO	6:40	6:56	0:16	LOAD CHANGE OVER
47	17-Aug-21	BENGALURU	66	HV2	YARANDANAHALLI 220	9:05	19:00	9:55	LINE CLEAR AVAILED
48	17-Aug-21	BENGALURU	66	HV2	ATTUR YELAHANKA	12:40	12:43	0:03	LOAD CHANGE OVER
49	17-Aug-21	BENGALURU	66	HV2	ATTUR YELAHANKA	14:20	14:22	0:02	LOAD CHANGE OVER
50	17-Aug-21	BENGALURU	66	HV2	ATTUR YELAHANKA	22:10	23:49	1:39	LINE CLEAR AVAILED
51	17-Aug-21	BENGALURU	66	HV2	HUKUNDA	10:45	18:02	7:17	LINE CLEAR AVAILED
52	17-Aug-21	BENGALURU	66	HV3	YARANDANAHALLI 220	9:05	19:00	9:55	LINE CLEAR AVAILED
53	17-Aug-21	BENGALURU	66	HV5	NRS 220	13:50	13:51	0:01	LINE CLEAR AVAILED
54	17-Aug-21	BENGALURU	66	MANYATHA TECH PARK 220 - SHOBHA CITY	SHOBHA CITY	11:56	12:08	0:12	MAIN SUPPLY FAILURE
55	17-Aug-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	NO STATION AFFECTED	10:05	17:15	7:10	LINE CLEAR AVAILED
56	17-Aug-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	10:14	10:20	0:06	LINE CLEAR AVAILED
57	17-Aug-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	16:17	16:30	0:13	LINE CLEAR AVAILED
58	17-Aug-21	BENGALURU	66	NATIONAL COLLEGE - BMTC	BMTC	11:48	11:55	0:07	LOAD CHANGE OVER
59	17-Aug-21	BENGALURU	66	NATIONAL COLLEGE - JAYANAGARA	BMTC	22:30	22:36	0:06	LOAD CHANGE OVER
60	17-Aug-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	14:40	14:45	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
61	17-Aug-21	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	12:45	12:50	0:05	LOAD CHANGE OVER
62	17-Aug-21	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	16:30	17:05	0:35	LINE CLEAR AVAILED
63	17-Aug-21	BENGALURU	66	RAMANAGARA - DASHAVARA	BEVOOR,SANKALGERE, DASHAVARA	9:10	15:30	6:20	LINE CLEAR AVAILED
64	17-Aug-21	BENGALURU	66	SOMAYAJANAHALLI - TATA SOLAR IPP	NO STATION AFFECTED	18:17	20:33	2:15	LINE CLEAR AVAILED
65	17-Aug-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	6:40	6:50	0:10	LINE CLEAR AVAILED
66	17-Aug-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN: LINE FAULT
67	17-Aug-21	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 220	11:56	12:06	0:10	LINE CLEAR AVAILED
68	17-Aug-21	GULBARGA	110	GULBARGA WEST-KAPNOOR	GULBARGA WEST_110	18:05	18:08	0:03	MAIN SUPPLY FAILURE
69	17-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
70	17-Aug-21	GULBARGA	110	HV1	DEODURGA_110	10:30	10:55	0:25	TRANSFORMER FAULT
71	17-Aug-21	GULBARGA	110	HV1	KAVITHAL_110	22:35	22:50	0:15	TRANSFORMER FAULT
72	17-Aug-21	GULBARGA	110	HV1	KADAGANCHI_110	22:05	22:10	0:05	TRANSFORMER FAULT
73	17-Aug-21	GULBARGA	110	HV1	KUDITINI_110	8:05	8:40	0:35	TRANSFORMER FAULT
74	17-Aug-21	GULBARGA	110	HV3	YELBURGA_110	14:47	14:56	0:09	LINE CLEAR AVAILED
75	17-Aug-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	6:05	6:15	0:10	LINE FAULT
76	17-Aug-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	6:20	6:30	0:10	LINE FAULT
77	17-Aug-21	GULBARGA	110	KADAGANCHI-KAPNOOR	KADAGANCHI_110	13:40	13:50	0:10	MAIN SUPPLY FAILURE
78	17-Aug-21	GULBARGA	110	KUDITINI-TORANGAL	KUDITINI_110	18:45	19:05	0:20	MAIN SUPPLY FAILURE
79	17-Aug-21	GULBARGA	110	LADHA-BHALKI	LADHA_110	7:20	7:25	0:05	MAIN SUPPLY FAILURE
80	17-Aug-21	GULBARGA	110	LADHA-BHALKI	LADHA_110	20:20	20:30	0:10	MAIN SUPPLY FAILURE
81	17-Aug-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	5:54	6:00	0:06	LINE FAULT
82	17-Aug-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	10:50	14:40	3:50	LINE CLEAR AVAILED
83	17-Aug-21	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110	10:35	14:42	4:07	NFBC ISSUED
84	17-Aug-21	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110	15:35	17:28	1:53	NFBC ISSUED
85	17-Aug-21	GULBARGA	110	MADIYAL-NSL SUGARS_IPP	MADIYAL_110	11:10	17:35	6:25	LINE CLEAR AVAILED
86	17-Aug-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	20:11	20:20	0:09	LINE FAULT
87	17-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	0:45	9:00	8:15	LINE FAULT
88	17-Aug-21	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	22:32	22:52	0:20	LINE FAULT
89	17-Aug-21	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	6:08	6:35	0:27	LINE FAULT
90	17-Aug-21	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	6:35	7:45	1:10	MAIN SUPPLY FAILURE
91	17-Aug-21	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110	16:40	17:29	0:49	LINE CLEAR AVAILED
92	17-Aug-21	GULBARGA	110	RAICHUR-MATAMARI,SINDHANOOR2	MATAMARI_110,KURDICROSS_110,MAD LAPUR_110,MANVI_110	16:05	17:29	1:24	LINE CLEAR AVAILED
93	17-Aug-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	15:36	15:43	0:07	LINE FAULT
94	17-Aug-21	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	22:28	22:42	0:14	LINE FAULT
95	17-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVAN GAON_110,RENUKA_IPP,AFZALPUR_110 ,KARAJAGI_110	21:35	21:50	0:15	LINE FAULT
96	17-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	6:50	6:58	0:08	LINE FAULT
97	17-Aug-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
98	17-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
99	17-Aug-21	GULBARGA	110	SHAHABAD-RAICHUR2	JEWARGI_110,NALWAR_110	5:40	5:45	0:05	LINE FAULT
100	17-Aug-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
101	17-Aug-21	GULBARGA	220	HV2	SEDAM_220	16:51	17:27	0:36	LINE CLEAR AVAILED
102	17-Aug-21	GULBARGA	220	SEDAM-HUMNABAD	SEDAM_220	23:47(16.08.2021)	7:05(17.08.2021)	7:18HRS	LINE CHARGED
103	17-Aug-21	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	22:14(17.08.2021)			LINE OPEN: LINE CLEAR AVAILED
104	17-Aug-21	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	13:30	15:52	2:22	LINE CLEAR AVAILED
105	17-Aug-21	GULBARGA	220	SEDAM-VCATSAGAR_IPP	SEDAM_220	21:08	21:13	0:05	LINE FAULT
106	17-Aug-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	2:54	15:43	12:49	LINE FAULT
107	17-Aug-21	HASSAN	66	HV1	DODDAKADANUR_66	0:34	1:48	1:14	MAIN SUPPLY FAILURE
108	17-Aug-21	HASSAN	66	HV1	HALLYMYSORE_66	10:55	12:19	1:24	LINE CLEAR AVAILED
109	17-Aug-21	HASSAN	66	HV1	KANDLI_66	10:40	15:33	4:53	LINE CLEAR AVAILED
110	17-Aug-21	HASSAN	66	HV1	KUDLIGERE_66	9:37	14:06	4:29	TRANSFORMER FAULT
111	17-Aug-21	HASSAN	66	HV1	MAGGE_66	11:57	15:36	3:39	MAIN SUPPLY FAILURE
112	17-Aug-21	HASSAN	66	HV2	ARAKALGUD_66	12:09	12:20	0:11	LINE CLEAR AVAILED
113	17-Aug-21	HASSAN	66	HV2	KANDLI_66	10:35	15:40	5:05	LINE CLEAR AVAILED
114	17-Aug-21	HASSAN	66	HV2	MAGGE_66	11:57	15:36	3:39	MAIN SUPPLY FAILURE
115	17-Aug-21	HASSAN	66	KANDLI-HASSAN	KANDLI_66	12:02	15:30	3:28	LINE CLEAR AVAILED
116	17-Aug-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:55	15:31	3:36	LINE CLEAR AVAILED
117	17-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN: LINE CLEAR AVAILED
118	17-Aug-21	HASSAN	66	Lv1	HOLENARASIPURA_220	0:31	1:35	1:04	TRANSFORMER FAULT
119	17-Aug-21	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	11:55	15:31	3:36	NFBC ISSUED
120	17-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
121	17-Aug-21	HASSAN	110	HV1	KEMAR_220	11:27	12:15	0:48	LINE CLEAR AVAILED
122	17-Aug-21	HASSAN	110	HV1	KONDENALU_110	10:29	15:10	4:41	LINE CLEAR AVAILED
123	17-Aug-21	HASSAN	110	HV2	MSEZ_220	10:48	14:57	4:09	LINE CLEAR AVAILED
124	17-Aug-21	HASSAN	110	HV2	KONDENALU_110	10:42	16:03	5:21	LINE CLEAR AVAILED
125	17-Aug-21	HASSAN	110	HV2	MOODABIDRE_110	11:25	11:55	0:30	LINE CLEAR AVAILED
126	17-Aug-21	HASSAN	110	JOG-JLT4	mghejog_gen	17:45(16.8.2021)	12:00(17.8.2021)	18:15hrs	LINE CHARGED
127	17-Aug-21	HASSAN	110	LPH-MGHE 2	lph_gen	17:45(16.8.2021)	12:16(17.8.2021)	18:31hrs	LINE CHARGED
128	17-Aug-21	HASSAN	220	GOPALAPR-HNPUR21	GOPALPURA_220	0:32	2:47	2:15	LINE FAULT
129	17-Aug-21	HASSAN	220	GOPALAPR-HNPUR21	GOPALPURA_220	7:30	8:35	1:05	LINE FAULT
130	17-Aug-21	HASSAN	220	HV1	HOLENARASIPURA_220	0:31	1:35	1:04	TRANSFORMER FAULT
131	17-Aug-21	HASSAN	220	HV2	HOLENARASIPURA_220	0:31	1:38	1:07	TRANSFORMER FAULT
132	17-Aug-21	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	12:20	13:47	1:27	LINE CLEAR AVAILED
133	17-Aug-21	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	12:20	13:47	1:27	LINE FAULT
134	17-Aug-21	MYSURU	66	DR PETE-CR NAGARA 1	DODDARAYAPET_66	5:55	6:15	0:20	LINE FAULT
135	17-Aug-21	MYSURU	66	DR PETE-CR NAGARA 2	DODDARAYAPET_66	5:55	6:15	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
136	17-Aug-21	MYSURU	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	5:55			LINE OPEN: LINE FAULT
137	17-Aug-21	MYSURU	66	HV1	ATTIGULIPURA_66	14:33	17:17	2:43	LINE CLEAR AVAILED
138	17-Aug-21	MYSURU	66	HV1	BANNIMANTAP_66	11:55	13:15	1:19	LINE CLEAR AVAILED
139	17-Aug-21	MYSURU	66	HV1	KHBCOLONY_66	5:23	8:09	2:46	LINE CLEAR AVAILED
140	17-Aug-21	MYSURU	66	HV1	MANDGERE_66	0:35	1:55	1:20	LINE CLEAR AVAILED
141	17-Aug-21	MYSURU	66	HV1	SANTHEBACHALLI_66	16:25	16:36	0:10	HAND TRIPPED
142	17-Aug-21	MYSURU	66	HV2	HANNUR_66	15:05	15:50	0:45	LINE CLEAR AVAILED
143	17-Aug-21	MYSURU	66	HV2	SATHEGALA_66	11:25	12:18	0:52	LINE CLEAR AVAILED
144	17-Aug-21	MYSURU	66	HV2	SANTHEBACHALLI_66	16:25	16:36	0:10	HAND TRIPPED
145	17-Aug-21	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	8:54	9:50	0:55	LINE FAULT
146	17-Aug-21	MYSURU	66	KUNTHUR-DR PETE	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	5:56	6:18	0:22	LINE FAULT
147	17-Aug-21	MYSURU	66	MUGUR-KUNTHUR	NO STATIONS EFFECTED	12:01			LINE OPEN: LINE CLEAR AVAILED
148	17-Aug-21	MYSURU	66	SATHEGALA-BPCL	NO STATIONS EFFECTED	9:53	23:35	13:41	NFBC ISSUED
149	17-Aug-21	MYSURU	66	SATHEGALA-HEBBANI	SATHEGALA_66	9:53	23:26	13:32	NFBC ISSUED
150	17-Aug-21	MYSURU	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	3:13	3:23	0:09	LINE FAULT
151	17-Aug-21	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:37	11:49	0:11	LINE FAULT
152	17-Aug-21	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	KALLAMBELLA_66, BUKKAPATNA_66	13:35	13:48	0:12	LINE FAULT
153	17-Aug-21	TUMKUR	66	PALLAGATTE66kv-DAVANGERE	PALLAGATTE_66	13:01	13:11	0:09	LINE FAULT
154	17-Aug-21	TUMKUR	66	TR-1	CHANNAGIRI_66	19:54	20:00	0:05	TRANSFORMER FAULT
155	17-Aug-21	TUMKUR	66	TR-1	PATTANAYAKANAHALLI_66	13:32	15:49	2:17	LINE CLEAR AVAILED
156	17-Aug-21	TUMKUR	66	TR-1	PAVAGADA_220	13:22	13:27	0:05	TRANSFORMER FAULT
157	17-Aug-21	TUMKUR	66	TR-1	TUMKUR_66	10:37	11:46	1:09	LINE CLEAR AVAILED
158	17-Aug-21	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	12:30	15:50	3:20	LINE CLEAR AVAILED
159	17-Aug-21	TUMKUR	66	TR-2	HINDASGHATTA_66	17:09	17:46	0:36	TRANSFORMER FAULT
160	17-Aug-21	TUMKUR	110	TR-1	DODDAGUNI_66	9:01	11:23	2:21	LINE CLEAR AVAILED
161	17-Aug-21	TUMKUR	110	TR-1	THIMMANAHALLI_110	14:52	16:25	1:33	LINE CLEAR AVAILED
162	18-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
163	18-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
164	18-Aug-21	BAGALKOT	110	110/11KV, HV1	HIREKERUR_110	12:48	13:34	0:46	LINE CLEAR AVAILED
165	18-Aug-21	BAGALKOT	110	110/11KV, HV2	MURDESHWAR_110, BHATKALA_33	10:16	13:03	2:47	LINE CLEAR AVAILED
166	18-Aug-21	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	10:25	17:54	7:29	LINE CLEAR AVAILED
167	18-Aug-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TAKKALAKI_110	8:40	9:00	0:20	HAND TRIPPED
168	18-Aug-21	BAGALKOT	110	110/11KV, HV2 (HV3)	STATION NOT AFFECTED TIKOTA_110	17:31	19:10	1:39	LINE CLEAR AVAILED
169	18-Aug-21	BAGALKOT	110	110/11KV, HV3	MURDESHWAR_110, BHATKALA_33	10:16	13:04	2:48	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
170	18-Aug-21	BAGALKOT	110	110/33KLV, HV4 (HV3)	MANGASULI_33, SHEDBAL_33 UGARKHUD_110	10:25	17:54	7:29	LINE CLEAR AVAILED
171	18-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
172	18-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
173	18-Aug-21	BAGALKOT	110	BELGAUM SUGARS- HUDLI	HUDLI_110	11:18	18:15	6:57	LINE CLEAR AVAILED
174	18-Aug-21	BAGALKOT	110	DAMBAL- ASF SOLAR	DAMBAL_110	11:45	13:28	1:43	LINE CLEAR AVAILED
175	18-Aug-21	BAGALKOT	110	DAMBAL- ENERCON	DAMBAL_110	11:45	13:25	1:40	LINE CLEAR AVAILED
176	18-Aug-21	BAGALKOT	110	DAMBAL- SAMBAPUR ROAD	DAMBAL_110	4:15	13:22	9:07	LINE FAULT
177	18-Aug-21	BAGALKOT	110	DAMBAL- SUZLON1&2	DAMBAL_110	11:45	13:31	1:46	LINE CLEAR AVAILED
178	18-Aug-21	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_110	5:18	5:40	0:22	LINE FAULT
179	18-Aug-21	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_110	12:44	14:05	1:21	LINE CLEAR AVAILED
180	18-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
181	18-Aug-21	BAGALKOT	110	HUBLI220-RAMANAKOPPA	STATION NOT AFFECTED RAMANAKOPPA_110	13:08	18:56	5:48	LINE CLEAR AVAILED
182	18-Aug-21	BAGALKOT	110	MALAGHAN(B)-BASAVESHVAR SUGARS	BASAVESHWAR SUGARS_110 STATION NOT AFFECTED MALAGHAN(B)_110	23:03 (17.08.2021)	00:06 (18.08.2021)	1:03	LINE CHARGED
183	18-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN: LINE CLEAR AVAILED
184	18-Aug-21	BAGALKOT	110	RANEENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI_110	15:42 (10.08.2021)			LINE OPEN: LINE CLEAR AVAILED
185	18-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
186	18-Aug-21	BAGALKOT	110	SAMBAPUR ROAD- DAMBAL	SAMBAPUR ROAD_110	4:15	13:22	9:07	LINE FAULT
187	18-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
188	18-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
189	18-Aug-21	BAGALKOT	220	HUBLI-NAGZARI3	STATION NOT AFFECTED HUBLI_220	13:08	18:56	5:48	LINE FAULT
190	18-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
191	18-Aug-21	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	10:26	15:57	5:31	LINE CLEAR AVAILED
192	18-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
193	18-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
194	18-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
195	18-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
196	18-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
197	18-Aug-21	BENGALURU	66	ANEKAL - YARANDANAHALLI 220	ANEKAL	10:00	18:42	8:42	LINE CLEAR AVAILED
198	18-Aug-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	9:25	9:30	0:05	LOAD CHANGE OVER
199	18-Aug-21	BENGALURU	66	ATTIBELE - SARIAPURA 220	ATTIBELE	19:30	19:35	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
200	18-Aug-21	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	14:03	15:16	1:13	MAIN SUPPLY FAILURE
201	18-Aug-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	14:03	15:06	1:03	MAIN SUPPLY FAILURE
202	18-Aug-21	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	14:03	15:30	1:27	MAIN SUPPLY FAILURE
203	18-Aug-21	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	14:03	15:14	1:11	MAIN SUPPLY FAILURE
204	18-Aug-21	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	14:03	15:24	1:21	MAIN SUPPLY FAILURE
205	18-Aug-21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	14:03	15:08	1:05	MAIN SUPPLY FAILURE
206	18-Aug-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:46	17:36	1:49	LINE CLEAR AVOIDED
207	18-Aug-21	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	10:09	18:00	7:51	LINE CLEAR AVOIDED
208	18-Aug-21	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	10:09	18:07	7:58	LINE CLEAR AVOIDED
209	18-Aug-21	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA	10:09	18:30	8:21	LINE CLEAR AVOIDED
210	18-Aug-21	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	10:09	18:27	8:18	LINE CLEAR AVOIDED
211	18-Aug-21	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	10:09	18:05	7:56	LINE CLEAR AVOIDED
212	18-Aug-21	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI,	10:09	18:38	8:29	LINE CLEAR AVOIDED
213	18-Aug-21	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKAL, D PALYA, GUDIBANDE	10:09	18:55	8:46	LINE CLEAR AVOIDED
214	18-Aug-21	BENGALURU	66	HEBBALA 220 - IISc	IISc	9:38	10:40	1:02	LINE FAULT
215	18-Aug-21	BENGALURU	66	HV1	DABUSPETE 220	14:03	15:02	0:59	MAIN SUPPLY FAILURE
216	18-Aug-21	BENGALURU	66	HV1	MITTEMARI 220	10:54	18:55	8:01	LINE CLEAR AVOIDED
217	18-Aug-21	BENGALURU	66	HV1	GOWRIBIDANUR 220	8:55	9:10	0:15	TRANSFORMER FAULT
218	18-Aug-21	BENGALURU	66	HV1	GOWRIBIDANUR 220	10:10	17:40	7:30	LINE CLEAR AVOIDED
219	18-Aug-21	BENGALURU	66	HV1	VOLVO	17:14	17:43	0:28	TRANSFORMER FAULT
220	18-Aug-21	BENGALURU	66	HV1	KONDASPURA	11:40	13:39	1:59	LINE CLEAR AVOIDED
221	18-Aug-21	BENGALURU	66	HV1	CB PURA URBAN	12:20	12:56	0:36	LINE CLEAR AVOIDED
222	18-Aug-21	BENGALURU	66	HV2	KUMBALAGODU	12:16	13:57	1:41	LINE CLEAR AVOIDED
223	18-Aug-21	BENGALURU	66	HV2	REMCO	6:27	6:38	0:11	LOAD CHANGE OVER
224	18-Aug-21	BENGALURU	66	HV2	ATTUR YELAHANKA	13:07	14:46	1:39	LINE CLEAR AVOIDED
225	18-Aug-21	BENGALURU	66	HV2	DABUSPETE 220	14:03	15:02	0:59	MAIN SUPPLY FAILURE
226	18-Aug-21	BENGALURU	66	HV2	GOWRIBIDANUR 220	10:10	17:40	7:30	LINE CLEAR AVOIDED
227	18-Aug-21	BENGALURU	66	HV2	VOLVO	17:43	17:48	0:05	TRANSFORMER FAULT
228	18-Aug-21	BENGALURU	66	HV2	VOLVO	17:48	17:50	0:01	TRANSFORMER FAULT
229	18-Aug-21	BENGALURU	66	HV2	SARJAPURA 220	13:00	13:10	0:09	LINE CLEAR AVOIDED
230	18-Aug-21	BENGALURU	66	HV2	KONDASPURA	14:33	16:26	1:52	LINE CLEAR AVOIDED
231	18-Aug-21	BENGALURU	66	ITI 220 - BAGHMANE WORLD TECH PARK	BAGHMANE WORLD TECH PARK	11:57	12:06	0:09	LINE FAULT
232	18-Aug-21	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	15:15	15:18	0:03	LOAD CHANGE OVER
233	18-Aug-21	BENGALURU	66	L R BANDE - HEBBALA 220	L R BANDE	14:02	14:05	0:03	LOAD CHANGE OVER
234	18-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	VOKKALERI	5:48	5:54	0:06	LINE FAULT
235	18-Aug-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	NO STATION AFFECTED	11:05	18:37	7:32	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
236	18-Aug-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	10:28	19:01	8:33	LINE CLEAR AVAILED
237	18-Aug-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	10:38	18:34	7:56	LINE CLEAR AVAILED
238	18-Aug-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	10:08	18:40	8:32	LINE CLEAR AVAILED
239	18-Aug-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	5:48	5:56	0:08	LINE FAULT
240	18-Aug-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	10:54	18:32	7:38	LINE CLEAR AVAILED
241	18-Aug-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	10:36	18:30	7:54	LINE CLEAR AVAILED
242	18-Aug-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	10:48	18:37	7:49	LINE CLEAR AVAILED
243	18-Aug-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	6:26	6:33	0:07	LINE CLEAR AVAILED
244	18-Aug-21	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	17:21	17:30	0:09	LOAD CHANGE OVER
245	18-Aug-21	BENGALURU	66	SURYANAGAR - ANEKAL	SURYANAGAR	18:28	18:42	0:14	LOAD CHANGE OVER
246	18-Aug-21	BENGALURU	66	SURYANAGAR - YARANDANAHALLI 220	SURYANAGAR	10:12	10:30	0:18	LOAD CHANGE OVER
247	18-Aug-21	BENGALURU	66	T G HALLI - ANCHEPALYA 220	T G HALLI, BYDARAHALLI, MAGADI 66	10:00	18:40	8:40	LINE CLEAR AVAILED
248	18-Aug-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN: LINE FAULT
249	18-Aug-21	BENGALURU	220	HV1	DABUSPETE 220	14:02	14:52	0:50	TRANSFORMER FAULT
250	18-Aug-21	BENGALURU	220	HV1	MITTEMARI 220	10:54	18:24	7:30	LINE CLEAR AVAILED
251	18-Aug-21	BENGALURU	220	HV1	GOWRIBIDANUR 220	10:10	17:08	6:58	LINE CLEAR AVAILED
252	18-Aug-21	BENGALURU	220	HV2	DABUSPETE 220	14:02	14:57	0:55	TRANSFORMER FAULT
253	18-Aug-21	BENGALURU	220	HV2	MITTEMARI 220	10:54	18:24	7:30	LINE CLEAR AVAILED
254	18-Aug-21	BENGALURU	220	HV2	GOWRIBIDANUR 220	10:10	17:10	7:00	LINE CLEAR AVAILED
255	18-Aug-21	BENGALURU	220	HV3	GOWRIBIDANUR 220	10:10	17:45	7:35	LINE CLEAR AVAILED
256	18-Aug-21	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	MITTEMARI 220	10:54	18:23	7:29	LINE CLEAR AVAILED
257	18-Aug-21	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	10:54	18:23	7:29	LINE CLEAR AVAILED
258	18-Aug-21	BENGALURU	220	NELMANGALA 400 - DABUSPETE 220	NO STATION AFFECTED	14:01	15:03	1:01	LINE FAULT
259	18-Aug-21	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	16:14	18:57	2:43	LINE FAULT
260	18-Aug-21	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH	GULBARGA SOUTH_110	7:00	20:00	13:00	LINE CLEAR AVAILED
261	18-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
262	18-Aug-21	GULBARGA	110	HATTI	HV2	16:22	16:33	0:11	LINE FAULT
263	18-Aug-21	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	6:17	6:25	0:08	LINE FAULT
264	18-Aug-21	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	21:13	21:18	0:05	LINE FAULT
265	18-Aug-21	GULBARGA	110	HV1	DUBALGUNDI_110	16:35	16:40	0:05	LINE CLEAR AVAILED
266	18-Aug-21	GULBARGA	110	HV1	NIRNA_110	14:40	14:45	0:05	TRANSFORMER FAULT
267	18-Aug-21	GULBARGA	110	HV1	TEKKALKOTE_110	18:10	19:15	1:05	LINE CLEAR AVAILED
268	18-Aug-21	GULBARGA	110	HV2	YEDRAMI_110	10:44(18.08.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
269	18-Aug-21	GULBARGA	110	HV2	DUBALGUNDI_110	16:25	16:30	0:05	LINE CLEAR AVAILED
270	18-Aug-21	GULBARGA	110	HV2,HV3	TEKKALKOTE_110	18:10	18:20	0:10	LINE CLEAR AVAILED
271	18-Aug-21	GULBARGA	110	LADHA-BHALKI	LADHA_110	0:05	0:15	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
272	18-Aug-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	4:34	4:50	0:16	LINE FAULT
273	18-Aug-21	GULBARGA	110	MUNIRABAD-VYSANKERE2	STAR METALLIC_IPP	9:00	12:08	3:08	LINE CHARGED
274	18-Aug-21	GULBARGA	110	NALWAR-SHAHAPUR	JEWARGI_110	6:00	8:05	2:05	LINE FAULT
275	18-Aug-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	21:17	21:29	0:12	LINE FAULT
276	18-Aug-21	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	6:22	6:30	0:08	LINE FAULT
277	18-Aug-21	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	13:58	15:26	1:28	LINE CLEAR AVAILED
278	18-Aug-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	2:29(18.08.2021)			LINE OPEN: LINE FAULT
279	18-Aug-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
280	18-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
281	18-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:44	19:48	0:04	LINE FAULT
282	18-Aug-21	GULBARGA	110	SINDHANOOR-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	22:42	22:52	0:10	LINE FAULT
283	18-Aug-21	GULBARGA	110	TEKKALKOTE-RENEW AGNI_IPP	TEKKALKOTE_110	18:10	19:05	0:55	LINE CLEAR AVAILED
284	18-Aug-21	GULBARGA	110	TEKKALKOTE-SHAHI SLR_IPP	TEKKALKOTE_110	18:10	18:20	0:10	LINE CLEAR AVAILED
285	18-Aug-21	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	9:49	9:57	0:08	LINE CLEAR AVAILED
286	18-Aug-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
287	18-Aug-21	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	17:10	17:14	0:04	LINE FAULT
288	18-Aug-21	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	22:14(17.08.2021)	6:33(18.08.2021)	8:19HRS	LINE CHARGED
289	18-Aug-21	GULBARGA	220	SEDAM-ORIENTCEMENTS_IPP	ORIENTCEMENTS_IPP	15:49	17:54	2:05	LINE CLEAR AVAILED
290	18-Aug-21	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	10:08	14:24	4:16	LINE CLEAR AVAILED
291	18-Aug-21	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	10:29	17:43	7:14	LINE CLEAR AVAILED
292	18-Aug-21	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	10:37	12:52	2:15	LINE CLEAR AVAILED
293	18-Aug-21	HASSAN	66	HASSN22-SKPURA2	HASSAN_220	10:45	14:13	3:28	LINE CLEAR AVAILED
294	18-Aug-21	HASSAN	66	HV1	AREHALLI_HSN_66	10:16	16:27	6:11	LINE CLEAR AVAILED
295	18-Aug-21	HASSAN	66	HV1	BALLUPETE_66	10:06	16:33	6:27	LINE CLEAR AVAILED
296	18-Aug-21	HASSAN	66	HV1	HANBALU_66	10:29	17:43	7:14	LINE CLEAR AVAILED
297	18-Aug-21	HASSAN	66	HV1	MAGGE_66	10:38	13:00	2:22	MAIN SUPPLY FAILURE
298	18-Aug-21	HASSAN	66	HV1	MAGGE_66	0:35	2:05	1:30	LINE CLEAR AVAILED
299	18-Aug-21	HASSAN	66	HV1	SAKLESH PURA_66	10:00	15:45	5:45	LINE CLEAR AVAILED
300	18-Aug-21	HASSAN	66	HV2	MAGGE_66	0:12	9:58	9:46	TRANSFORMER FAULT
301	18-Aug-21	HASSAN	66	HV2	MAGGE_66	10:38	13:00	2:22	MAIN SUPPLY FAILURE
302	18-Aug-21	HASSAN	66	HV2	SAKLESH PURA_66	10:00	14:45	4:45	LINE CLEAR AVAILED
303	18-Aug-21	HASSAN	66	KANDLI-HASSAN	KANDLI_66	10:38	12:55	2:17	LINE CLEAR AVAILED
304	18-Aug-21	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	10:44	12:56	2:12	LINE CLEAR AVAILED
305	18-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN: LINE CLEAR AVAILED
306	18-Aug-21	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	10:00	16:22	6:22	LINE CLEAR AVAILED
307	18-Aug-21	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	10:00	14:35	4:35	LINE CLEAR AVAILED
308	18-Aug-21	HASSAN	66	SAKALE-HASSAN2	SAKLESH PURA_66	10:00	14:35	4:35	LINE CLEAR AVAILED
309	18-Aug-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	10:00	14:35	4:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
310	18-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
311	18-Aug-21	HASSAN	110	HV1	GANDSI_110	10:28	17:05	6:37	LINE CLEAR AVAILED
312	18-Aug-21	HASSAN	110	HV1	KONAJE_110	12:47	14:43	1:56	LINE CLEAR AVAILED
313	18-Aug-21	HASSAN	110	HV1	SORABA_110	9:33	10:51	1:18	LINE CLEAR AVAILED
314	18-Aug-21	HASSAN	110	HV2	GANDSI_110	10:28	17:05	6:37	LINE CLEAR AVAILED
315	18-Aug-21	HASSAN	110	HV2	KONAJE_110	14:40	14:42	0:02	TRANSFORMER FAULT
316	18-Aug-21	HASSAN	110	HV3	KONAJE_110	10:35	13:14	2:39	LINE CLEAR AVAILED
317	18-Aug-21	HASSAN	110	LV1	KADUR_220	12:38	13:25	0:47	TRANSFORMER FAULT
318	18-Aug-21	HASSAN	110	MSEZ-GSS31	MSEZ_220	14:20	17:33	3:13	NFBC ISSUED
319	18-Aug-21	HASSAN	110	MSEZ-GSS32	MSEZ_220	9:47	14:02	4:15	NFBC ISSUED
320	18-Aug-21	HASSAN	110	SHRLKP-KITTAHALI	SHIRALKOPPA_220	10:51	11:22	0:31	LINE FAULT
321	18-Aug-21	HASSAN	220	HV1	KADUR_220	12:38	13:21	0:43	TRANSFORMER FAULT
322	18-Aug-21	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	9:54	14:28	4:34	LINE CLEAR AVAILED
323	18-Aug-21	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	9:54	14:02	4:08	NFBC ISSUED
324	18-Aug-21	MYSURU	66	BG PURA-SFC	NO STATIONS EFFECTED	10:20	15:40	5:19	NFBC ISSUED
325	18-Aug-21	MYSURU	66	DR PETE-CR NAGARA 1	NO STATIONS EFFECTED	16:09	16:43	0:33	LINE CLEAR AVAILED
326	18-Aug-21	MYSURU	66	DR PETE-CR NAGARA 2	NO STATIONS EFFECTED	15:34	16:07	0:33	LINE CLEAR AVAILED
327	18-Aug-21	MYSURU	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	5:55 (17/08/2021)			LINE OPEN: LINE FAULT
328	18-Aug-21	MYSURU	66	HANGALA-GUNDLUPETE	HANGLA_66	10:55	11:08	0:13	LINE FAULT
329	18-Aug-21	MYSURU	66	HANGALA-GUNDLUPETE	HANGLA_66	14:10	15:05	0:55	LINE CLEAR AVAILED
330	18-Aug-21	MYSURU	66	HARADANAHALLI(JAK)-TUBINKERE	HARADANAHALLI(JAK)_66	12:10	12:59	0:48	LINE CLEAR AVAILED
331	18-Aug-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03			LINE OPEN: LINE CLEAR AVAILED
332	18-Aug-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03			LINE OPEN: LINE CLEAR AVAILED
333	18-Aug-21	MYSURU	66	HV1	BGPURA_66	7:10	11:44	4:34	LINE CLEAR AVAILED
334	18-Aug-21	MYSURU	66	HV1	BOGADHI_66	10:36	12:25	1:49	LINE CLEAR AVAILED
335	18-Aug-21	MYSURU	66	HV1	BYLUKUPPE_66	10:43	11:24	0:41	LINE CLEAR AVAILED
336	18-Aug-21	MYSURU	66	HV1	K_HONNALGERE_66	11:39	12:03	0:24	LINE CLEAR AVAILED
337	18-Aug-21	MYSURU	66	HV2	BOGADHI_66	12:20	13:45	1:25	LINE CLEAR AVAILED
338	18-Aug-21	MYSURU	66	HV2	MADDUR_66	12:18	22:05	9:46	LINE CLEAR AVAILED
339	18-Aug-21	MYSURU	66	HV2	PERIYAPATNA_66	11:14	13:05	1:50	LINE CLEAR AVAILED
340	18-Aug-21	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66	10:07	15:35	5:28	LINE CLEAR AVAILED
341	18-Aug-21	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66 CHANDRAVADI_66	10:07	14:34	4:27	LINE CLEAR AVAILED
342	18-Aug-21	MYSURU	66	KM DODDI-TK HALI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66 TALAGAVADI_66	15:23	15:39	0:16	LINE FAULT
343	18-Aug-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
344	18-Aug-21	MYSURU	66	KR PETE 220-CR PATNA	ANEGOLAL_66 KRISHNAPURA_66	5:11	5:18	0:06	LINE FAULT
345	18-Aug-21	MYSURU	66	MEGALAPURA-HEBBANI	CHIDRAVALI_66 THUMBLA_66	10:29	15:38	5:08	NFBC ISSUED
346	18-Aug-21	MYSURU	66	MUGUR-KUNTHUR	NO STATIONS EFFECTED	12:01 (17/08/2021)	10:19	22:09 HRS	LINE CHARGED
347	18-Aug-21	MYSURU	220	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	10:02	14:59	4:57	LINE CLEAR AVAILED
348	18-Aug-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:53	12:11	0:17	HAND TRIPPED
349	18-Aug-21	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:53	12:11	0:17	HAND TRIPPED
350	18-Aug-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	6:32	6:43	0:10	LINE FAULT
351	18-Aug-21	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:41	19:23	2:41	LINE CLEAR AVAILED
352	18-Aug-21	TUMKUR	66	HIRIYUR 220KV- SUZLON 2	SUZLON1_IPP_66	16:41	19:23	2:41	LINE CLEAR AVAILED
353	18-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	18:38	18:51	0:12	LINE FAULT
354	18-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	18:56	19:07	0:11	LINE FAULT
355	18-Aug-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	6:17	6:28	0:11	LINE FAULT
356	18-Aug-21	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	10:59	19:09	8:09	MAIN SUPPLY FAILURE
357	18-Aug-21	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	10:59	18:59	7:59	MAIN SUPPLY FAILURE
358	18-Aug-21	TUMKUR	66	TR-1	IDHALLI_66	10:59	18:59	7:59	MAIN SUPPLY FAILURE
359	18-Aug-21	TUMKUR	66	TR-1	KALMARANAHALLI_66	15:37	15:45	0:07	HAND TRIPPED
360	18-Aug-21	TUMKUR	66	TR-1	NITRAHALLI_66	18:34	18:51	0:17	MAIN SUPPLY FAILURE
361	18-Aug-21	TUMKUR	66	TR-1	LOKEKERE_66	15:05	15:10	0:05	TRANSFORMER FAULT
362	18-Aug-21	TUMKUR	66	TR-2	BHARAMGIRI_66	10:25	10:29	0:04	TRANSFORMER FAULT
363	18-Aug-21	TUMKUR	66	TR-2	IDHALLI_66	10:59	18:59	7:59	MAIN SUPPLY FAILURE
364	18-Aug-21	TUMKUR	66	TR-2	MAVINAKATTE_66	11:24	13:06	1:42	LINE CLEAR AVAILED
365	18-Aug-21	TUMKUR	66	TR-2	MAVINAKATTE_66	13:10	13:14	0:04	HAND TRIPPED
366	18-Aug-21	TUMKUR	66	TR-2	NITRAHALLI_66	18:34	18:52	0:18	MAIN SUPPLY FAILURE
367	18-Aug-21	TUMKUR	66	TR-2	YEDIYUR_66	10:27	15:42	5:15	LINE CLEAR AVAILED
368	18-Aug-21	TUMKUR	66	TR-2	YEDIYUR_66	17:17	17:25	0:08	LINE CLEAR AVAILED
369	18-Aug-21	TUMKUR	220	TR-3	DAVANGERE_SRS_220	11:54:00 AM(18.8.21)			TRANSFORMER OPEN: LINE CLEAR AVAILED
370	19-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
371	19-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
372	19-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED RAIBAG_110	12:32	12:42	0:10	TRANSFORMER FAULT
373	19-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NAVANAGAR BAGALKOT	10:40	17:17	6:37	LINE CLEAR AVAILED
374	19-Aug-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NAVANAGAR BAGALKOT	11:03	11:09	0:06	HAND TRIPPED
375	19-Aug-21	BAGALKOT	110	110/11KV,HV2	AREMALLAPUR_110	4:10	17:17	13:07	LINE CLEAR AVAILED
376	19-Aug-21	BAGALKOT	110	110/33KV, HV2	STATION NOT AFFECTED MURDESHWAR_110	10:58	12:08	1:10	LINE CLEAR AVAILED
377	19-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR	ALBAL_110	7:30	9:57	2:27	LINE CLEAR AVAILED
378	19-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR(RFE)	ALBAL_110	15:55	18:43	2:48	LINE CLEAR AVAILED
379	19-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS(SPRS)	ALBAL_110	7:30	18:43	11:13	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
380	19-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS(SPRS)	ALBAL_110	15:55	18:43	2:48	LINE CLEAR AVAILED
381	19-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
382	19-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
383	19-Aug-21	BAGALKOT	110	ATHARGA-KNI SOLAR	STATION NOT AFFECTED ATHARGA_110	18:50	21:48	2:58	LINE CLEAR AVAILED
384	19-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
385	19-Aug-21	BAGALKOT	110	HUDLI-BSPL	STATION NOT AFFECTED HUDLI_110	11:20	12:02	0:42	LINE CLEAR AVAILED
386	19-Aug-21	BAGALKOT	110	KANABARGI LAYOUT-NEHARU NAGAR	KANABARGI LAYOUT_110	11:45	12:49	1:04	LINE CLEAR AVAILED
387	19-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)	11:08 (19.08.2021)	22:39	LINE CHARGED
388	19-Aug-21	BAGALKOT	110	RANEENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI_110	15:42 (10.08.2021)			LINE OPEN: LINE CLEAR AVAILED
389	19-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
390	19-Aug-21	BAGALKOT	110	RANNABELAGALI-UTTUR(MUDHOL)	UTTUR_110	6:48	7:30	0:42	LINE FAULT
391	19-Aug-21	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	11:47	13:15	1:28	LINE CLEAR AVAILED
392	19-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
393	19-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
394	19-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
395	19-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
396	19-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
397	19-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
398	19-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
399	19-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
400	19-Aug-21	BENGALURU	66	ADUGODI - HSR LAYOUT 1	ADUGODI	11:09	11:18	0:09	LOAD CHANGE OVER
401	19-Aug-21	BENGALURU	66	ADUGODI - HSR LAYOUT 2	ADUGODI	7:51	8:15	0:24	MAIN SUPPLY FAILURE
402	19-Aug-21	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	16:15	16:19	0:04	LOAD CHANGE OVER
403	19-Aug-21	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	13:49	13:52	0:03	LOAD CHANGE OVER
404	19-Aug-21	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	7:51	8:15	0:24	LINE FAULT
405	19-Aug-21	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	12:34	12:40	0:06	LINE CLEAR AVAILED
406	19-Aug-21	BENGALURU	66	HV1	SRIGANDA KAVALU	13:30	13:40	0:10	LINE CLEAR AVAILED
407	19-Aug-21	BENGALURU	66	HV1	YELAHANKA 220	11:55	11:57	0:01	LINE CLEAR AVAILED
408	19-Aug-21	BENGALURU	66	HV1	TUBUGERE	10:02	17:50	7:47	LINE CLEAR AVAILED
409	19-Aug-21	BENGALURU	66	HV1	MAGADI 66	9:58	10:14	0:15	TRANSFORMER FAULT
410	19-Aug-21	BENGALURU	66	HV1	HOSPALYA CIRCLE	7:15	7:21	0:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
411	19-Aug-21	BENGALURU	66	HV1	HOSPALYA CIRCLE	7:35	7:40	0:04	TRANSFORMER FAULT
412	19-Aug-21	BENGALURU	66	HV2	NIMHANS 220	18:33	18:58	0:25	TRANSFORMER FAULT
413	19-Aug-21	BENGALURU	66	HV2	SRIGANDA KAVALU	13:18	13:24	0:06	LINE CLEAR AVAILED
414	19-Aug-21	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	11:29	11:34	0:05	MAIN SUPPLY FAILURE
415	19-Aug-21	BENGALURU	66	KODIGEHALLI - T G HALLI	TAVAREKERE	10:05	16:43	6:38	LINE CLEAR AVAILED
416	19-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	10:04	11:01	0:57	LINE FAULT
417	19-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	21:25	22:39	1:13	LINE FAULT
418	19-Aug-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADHOSAHALLI	10:37	10:45	0:07	LINE FAULT
419	19-Aug-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	7:46	8:03	0:17	LOAD CHANGE OVER
420	19-Aug-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	7:46	8:05	0:19	LOAD CHANGE OVER
421	19-Aug-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	18:49	18:55	0:06	LINE FAULT
422	19-Aug-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	7:46	8:02	0:16	LOAD CHANGE OVER
423	19-Aug-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	7:46	8:02	0:16	LOAD CHANGE OVER
424	19-Aug-21	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	11:20	11:25	0:05	LOAD CHANGE OVER
425	19-Aug-21	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	10:00	10:05	0:05	LOAD CHANGE OVER
426	19-Aug-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN: LINE FAULT
427	19-Aug-21	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	18:15	18:17	0:02	MAIN SUPPLY FAILURE
428	19-Aug-21	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	23:46	23:48	0:02	MAIN SUPPLY FAILURE
429	19-Aug-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	11:12	12:24	1:12	LINE CLEAR AVAILED
430	19-Aug-21	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	10:33	11:09	0:35	LINE CLEAR AVAILED
431	19-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
432	19-Aug-21	GULBARGA	110	HV1	KOLHAR_110	7:49	7:55	0:06	TRANSFORMER FAULT
433	19-Aug-21	GULBARGA	110	HV2	YEDRAMI_110	10:44(18.08.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
434	19-Aug-21	GULBARGA	110	HV2	HATTI_110	13:41	13:43	0:02	TRANSFORMER FAULT
435	19-Aug-21	GULBARGA	110	KAVITAL-MALLAT	KAVITAL_110	5:00	5:15	0:15	MAIN SUPPLY FAILURE
436	19-Aug-21	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	15:48	18:10	2:22	LINE CLEAR AVAILED
437	19-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	11:17	18:46	7:29	LINE CLEAR AVAILED
438	19-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	22:38	22:48	0:10	LINE FAULT
439	19-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	23:38	23:48	0:10	LINE FAULT
440	19-Aug-21	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	4:58	5:15	0:17	LINE FAULT
441	19-Aug-21	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	21:36	21:48	0:12	LINE FAULT
442	19-Aug-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:59	20:28	0:29	LINE FAULT
443	19-Aug-21	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	2:29(18.08.2021)	11:26(19.08.2021)	20:00 hrs	LINE CHARGED
444	19-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	6:30	6:35	0:05	LINE FAULT
445	19-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:12	11:30	0:18	LINE CLEAR AVAILED
446	19-Aug-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
447	19-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
448	19-Aug-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	23:15	23:27	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
449	19-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	14:28	14:31	0:03	LINE CLEAR AVAILED
450	19-Aug-21	GULBARGA	110	STAR METALLIC_IPP-MUNIRABAD	MUNIRABAD_220	21:45	22:01	0:16	LINE FAULT
451	19-Aug-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:35	14:40	0:05	MAIN SUPPLY FAILURE
452	19-Aug-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
453	19-Aug-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	3:37	7:19	3:42	LINE CLEAR AVAILED
454	19-Aug-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:03	13:44	2:41	LINE CLEAR AVAILED
455	19-Aug-21	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	13:53	13:57	0:04	LINE FAULT
456	19-Aug-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	13:00	13:30	0:30	NFBC ISSUED
457	19-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN: LINE CLEAR AVAILED
458	19-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	3:34	3:59	0:25	LINE FAULT
459	19-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	4:05	4:17	0:12	LINE FAULT
460	19-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	17:29	17:37	0:08	LINE FAULT
461	19-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	19:20	19:27	0:07	LINE FAULT
462	19-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	20:43	20:51	0:08	LINE FAULT
463	19-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	21:43	22:02	0:19	LINE FAULT
464	19-Aug-21	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	12:41	13:34	0:53	LINE CLEAR AVAILED
465	19-Aug-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41	13:39	0:58	LINE CLEAR AVAILED
466	19-Aug-21	HASSAN	110	BARANG-ANVATTI	BARANGI_110	10:25	13:50	3:25	MAIN SUPPLY FAILURE
467	19-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
468	19-Aug-21	HASSAN	110	HV1	MRSMG_220	8:59	12:44	3:45	LINE CLEAR AVAILED
469	19-Aug-21	HASSAN	110	HV1	NANDIKUR_110	3:20	4:23	1:03	TRANSFORMER FAULT
470	19-Aug-21	HASSAN	110	HV1	NAVUNDA_110	1:55	2:03	0:08	TRANSFORMER FAULT
471	19-Aug-21	HASSAN	110	HV1	BARANGI_110	9:58	13:50	3:52	MAIN SUPPLY FAILURE
472	19-Aug-21	HASSAN	110	HV1	KADUR_220	17:57	18:09	0:12	LINE CLEAR AVAILED
473	19-Aug-21	HASSAN	110	HV1	KARAYA_110	8:55	17:35	8:40	LINE CLEAR AVAILED
474	19-Aug-21	HASSAN	110	HV2	ANAVATTI_110	18:15	18:39	0:24	TRANSFORMER FAULT
475	19-Aug-21	HASSAN	110	HV2	BARANGI_110	10:25	13:50	3:25	MAIN SUPPLY FAILURE
476	19-Aug-21	HASSAN	110	HV2	KARAYA_110	8:55	17:35	8:40	LINE CLEAR AVAILED
477	19-Aug-21	HASSAN	110	KARAYA-PUTTUR	KARAYA_110	8:55	17:35	8:40	LINE CLEAR AVAILED
478	19-Aug-21	HASSAN	110	LV1	KEMAR_220	10:33	12:45	2:12	LINE CLEAR AVAILED
479	19-Aug-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:10	13:43	3:33	LINE CLEAR AVAILED
480	19-Aug-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:48	15:51	2:03	LINE CLEAR AVAILED
481	19-Aug-21	HASSAN	220	HV1	KEMAR_220	10:33	12:44	2:11	LINE CLEAR AVAILED
482	19-Aug-21	HASSAN	220	SHRAVTY-SHIMOGA 2	sharavathy_gen	10:12	14:00	3:48	LINE CLEAR AVAILED
483	19-Aug-21	MYSURU	66	BYLUKUPPE-KUSHALNAGARA	NO STATIONS EFFECTED	11:37	12:00	0:23	LINE CLEAR AVAILED
484	19-Aug-21	MYSURU	66	BYLUKUPPE-KUSHALNAGARA	BYLUKUPPE_66	16:27	16:46	0:18	LINE FAULT
485	19-Aug-21	MYSURU	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66	19:10	19:18	0:07	LINE FAULT
486	19-Aug-21	MYSURU	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66	22:18			LINE OPEN: LINE CLEAR AVAILED
487	19-Aug-21	MYSURU	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
488	19-Aug-21	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	DEVANORNGUDU_66 SUTTUR_66	13:43	13:54	0:10	LINE FAULT
489	19-Aug-21	MYSURU	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	5:55 (17/08/2021)			LINE OPEN: LINE FAULT
490	19-Aug-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAILED
491	19-Aug-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAILED
492	19-Aug-21	MYSURU	66	HV1	BYLUKUPPE_66	11:36	12:00	0:23	LINE CLEAR AVAILED
493	19-Aug-21	MYSURU	66	HV1	HUNSUR_66	11:01	11:33	0:31	LINE CLEAR AVAILED
494	19-Aug-21	MYSURU	66	HV1	JAKKANAHALLY_66	14:53	23:08	8:15	LINE CLEAR AVAILED
495	19-Aug-21	MYSURU	66	HV1	MYSORESOUTH_66	10:59	12:16	1:17	LINE CLEAR AVAILED
496	19-Aug-21	MYSURU	66	HV2	MYSORESOUTH_66	12:19	15:29	3:09	LINE CLEAR AVAILED
497	19-Aug-21	MYSURU	66	HV2	THALAKADU_66	18:40	18:45	0:05	HAND TRIPPED
498	19-Aug-21	MYSURU	66	HV3	PONNAMPET_66	10:49	10:55	0:06	TRANSFORMER FAULT
499	19-Aug-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN: LINE CLEAR AVAILED
500	19-Aug-21	MYSURU	66	KUNTHUR-DR PETE	SANTHEMARAHALLI_66	11:49	16:40	4:51	NFBC ISSUED
501	19-Aug-21	MYSURU	66	KUSHALNAGARA 220-MYSORE 1	MIRLE_66	8:28	10:45	2:16	LINE CLEAR AVAILED
502	19-Aug-21	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-1	NO STATIONS EFFECTED	5:09	5:14	0:04	LINE FAULT
503	19-Aug-21	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	19:58	20:10	0:12	HAND TRIPPED
504	19-Aug-21	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66,SAS ALUHALLA_66	3:53	3:59	0:06	LINE FAULT
505	19-Aug-21	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:32	14:36	0:04	HAND TRIPPED
506	19-Aug-21	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	17:33	17:41	0:07	HAND TRIPPED
507	19-Aug-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	14:32	14:37	0:04	HAND TRIPPED
508	19-Aug-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	17:34	17:39	0:05	HAND TRIPPED
509	19-Aug-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	14:36	14:43	0:06	LINE CLEAR AVAILED
510	19-Aug-21	TUMKUR	66	TR-1	BADAVANAHALLI_	18:10	18:33	0:22	LINE CLEAR AVAILED
511	19-Aug-21	TUMKUR	66	TR-1	RAMPURA_66	12:52	13:02	0:10	LINE CLEAR AVAILED
512	19-Aug-21	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	14:37	17:32	2:55	LINE CLEAR AVAILED
513	19-Aug-21	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	18:10	18:33	0:22	LINE FAULT
514	19-Aug-21	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	14:37	17:31	2:54	LINE CLEAR AVAILED
515	20-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
516	20-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
517	20-Aug-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUNAVALLI_110	11:06	11:10	0:04	TRANSFORMER FAULT
518	20-Aug-21	BAGALKOT	110	110/11KV,HV1	KONNUR_110	16:08	16:49	0:41	LINE CLEAR AVAILED
519	20-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR(RFE)	ALBAL_110	6:31	7:50	1:19	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
520	20-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
521	20-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
522	20-Aug-21	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	6:28	11:36	5:08	LINE CLEAR AVAILED
523	20-Aug-21	BAGALKOT	110	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	3:46	4:01	0:15	HAND TRIPPED
524	20-Aug-21	BAGALKOT	110	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	4:11	11:36	7:25	LINE CLEAR AVAILED
525	20-Aug-21	BAGALKOT	110	BIDNAL-ANNIGERI	BIDNAL_220	10:15	10:34	0:19	HAND TRIPPED
526	20-Aug-21	BAGALKOT	110	BIDNAL-GADAG ROAD	BIDNAL_220	10:15	10:30	0:15	HAND TRIPPED
527	20-Aug-21	BAGALKOT	110	BIDNAL-NAVALGUND	BIDNAL_220	10:15	10:33	0:18	HAND TRIPPED
528	20-Aug-21	BAGALKOT	110	BIDNAL-P H COMPOUND	BIDNAL_220	10:15	10:22	0:07	HAND TRIPPED
529	20-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
530	20-Aug-21	BAGALKOT	110	HUBLI220-TARIHAL2	STATION NOT AFFECTED HUBLI_220	9:35	13:19	3:44	LINE CLEAR AVAILED
531	20-Aug-21	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MALGHAN(S)_110	4:45	5:03	0:18	LINE FAULT
532	20-Aug-21	BAGALKOT	110	MRUTHYUNJAYANAGAR- NARENDRA1	MRUTHYUNJAYANAGAR_110	14:03	17:00	2:57	LINE CLEAR AVAILED
533	20-Aug-21	BAGALKOT	110	NARENDRA220-BELUR	STATION NOT AFFECTED NARENDRA_220	11:05	13:49	2:44	LINE CLEAR AVAILED
534	20-Aug-21	BAGALKOT	110	RANEBENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI_110	15:42 (10.08.2021)			LINE OPEN: LINE CLEAR AVAILED
535	20-Aug-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
536	20-Aug-21	BAGALKOT	220	AMBEWADI-PONDA1	STATION NOT AFFECTED AMBEWADI_220	14:23	17:23	3:00	LINE FAULT
537	20-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:04 (08.08.2021)	13:14 (20.08.2021)	2:10	LINE CHARGED
538	20-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	13:21	13:47	0:26	HAND TRIPPED
539	20-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
540	20-Aug-21	BAGALKOT	220	BIDNAL-HARTHI2	BIDNAL_220	10:15	11:09	0:54	HAND TRIPPED
541	20-Aug-21	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	10:15	10:21	0:06	HAND TRIPPED
542	20-Aug-21	BAGALKOT	220	BIDNAL-HIREBENDIGERI2(TADAS1)	BIDNAL_220	10:15	12:52	2:37	LINE CLEAR AVAILED
543	20-Aug-21	BAGALKOT	220	BIDNAL-HIREBENDIGERI2(TADAS2)	BIDNAL_220	10:15 (20.08.2021)			LINE OPEN: LINE FAULT
544	20-Aug-21	BAGALKOT	220	BIDNAL-NAGJHARI	BIDNAL_220	10:15	10:40	0:25	HAND TRIPPED
545	20-Aug-21	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	10:15	10:19	0:04	HAND TRIPPED
546	20-Aug-21	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	10:15	10:56	0:41	HAND TRIPPED
547	20-Aug-21	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	12:45	12:45	0:01	LINE FAULT
548	20-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
549	20-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
550	20-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_ 220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
551	20-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_ 220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
552	20-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_ 220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
553	20-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_ 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
554	20-Aug-21	BENGALURU	66	BANASHANKARI - SUBRAMANYAPURA 220	BANASHANKARI	17:24	17:27	0:03	LOAD CHANGE OVER
555	20-Aug-21	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	15:50	16:07	0:17	MAIN SUPPLY FAILURE
556	20-Aug-21	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	15:51	16:22	0:31	MAIN SUPPLY FAILURE
557	20-Aug-21	BENGALURU	66	CHATRA - KANAKAPURA 220	CHATRA	15:50	16:18	0:28	MAIN SUPPLY FAILURE
558	20-Aug-21	BENGALURU	66	CHATRA - SOMANAHALLI 220	CHATRA	23:45	23:50	0:05	LOAD CHANGE OVER
559	20-Aug-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	6:33	6:48	0:14	LINE FAULT
560	20-Aug-21	BENGALURU	66	GODUR - MARALWADI	GODUR	15:50	17:40	1:50	MAIN SUPPLY FAILURE
561	20-Aug-21	BENGALURU	66	GODUR - MARALWADI	GODUR	18:12	18:17	0:05	MAIN SUPPLY FAILURE
562	20-Aug-21	BENGALURU	66	GODUR - MARALWADI	GODUR	23:12	23:17	0:05	MAIN SUPPLY FAILURE
563	20-Aug-21	BENGALURU	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	15:50	17:30	1:40	MAIN SUPPLY FAILURE
564	20-Aug-21	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	18:10	18:15	0:05	MAIN SUPPLY FAILURE
565	20-Aug-21	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	23:40	23:45	0:05	MAIN SUPPLY FAILURE
566	20-Aug-21	BENGALURU	66	HONNIGANAHALLI - KANAKAPURA 220	HONNIGANAHALLI	15:50	17:08	1:18	MAIN SUPPLY FAILURE
567	20-Aug-21	BENGALURU	66	HV1	SOMANAHALLI 220	23:56	23:58	0:02	LINE CLEAR AVAILED
568	20-Aug-21	BENGALURU	66	HV1	MAGADI 66	11:23	12:40	1:16	LINE CLEAR AVAILED
569	20-Aug-21	BENGALURU	66	HV1	MAGADI 66	6:57	7:00	0:03	LINE CLEAR AVAILED
570	20-Aug-21	BENGALURU	66	HV1	NG HULKUR	12:25	12:30	0:05	LINE CLEAR AVAILED
571	20-Aug-21	BENGALURU	66	HV2	JAYANAGARA	12:05	12:10	0:05	LINE CLEAR AVAILED
572	20-Aug-21	BENGALURU	66	HV2	SOMANAHALLI 220	18:18	18:20	0:02	LINE CLEAR AVAILED
573	20-Aug-21	BENGALURU	66	HV2	SOMANAHALLI 220	23:39	23:42	0:03	LINE CLEAR AVAILED
574	20-Aug-21	BENGALURU	66	HV2	DODDABELAVANGALA	6:33	6:50	0:16	TRANSFORMER FAULT
575	20-Aug-21	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	15:52	17:38	1:46	LINE CLEAR AVAILED
576	20-Aug-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA	15:52	17:42	1:50	LINE CLEAR AVAILED
577	20-Aug-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	MARALWADI, YEDUMADU	15:52	17:40	1:48	LINE CLEAR AVAILED
578	20-Aug-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELA	15:52	17:48	1:56	LINE CLEAR AVAILED
579	20-Aug-21	BENGALURU	66	KENGERI SATELLITE TOWN - VRISHABHAVATHI 220	KENGERI SATELLITE TOWN	15:51	16:35	0:44	MAIN SUPPLY FAILURE
580	20-Aug-21	BENGALURU	66	NRS	VRISHABHAVATHI 220	15:51	16:22	0:30	MAIN SUPPLY FAILURE
581	20-Aug-21	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	17:10	17:14	0:04	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
582	20-Aug-21	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	17:27	17:32	0:05	LOAD CHANGE OVER
583	20-Aug-21	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	15:52	16:12	0:20	MAIN SUPPLY FAILURE
584	20-Aug-21	BENGALURU	66	SOBHA FOREST - SOMANAHALLI 220	SOBHA FOREST	17:20	17:52	0:32	MAIN SUPPLY FAILURE
585	20-Aug-21	BENGALURU	66	SOBHA FOREST - SOMANAHALLI 220	SOBHA FOREST	23:53	23:59	0:06	MAIN SUPPLY FAILURE
586	20-Aug-21	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	17:21	17:51	0:30	LINE CLEAR AVAILED
587	20-Aug-21	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	23:56	23:58	0:02	LINE CLEAR AVAILED
588	20-Aug-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	17:21	18:04	0:43	LINE CLEAR AVAILED
589	20-Aug-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	23:56	23:58	0:02	LINE CLEAR AVAILED
590	20-Aug-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD	17:21	18:08	0:47	LINE CLEAR AVAILED
591	20-Aug-21	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD	23:56	23:58	0:02	LINE CLEAR AVAILED
592	20-Aug-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	18:16	18:17	0:01	LINE CLEAR AVAILED
593	20-Aug-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	23:43	23:45	0:02	LINE CLEAR AVAILED
594	20-Aug-21	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	17:18	17:53	0:35	MAIN SUPPLY FAILURE
595	20-Aug-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN: LINE FAULT
596	20-Aug-21	BENGALURU	66	VRISHBHAVATHI 220 - RR NAGAR	NO STATION AFFECTED	15:51	16:21	0:30	MAIN SUPPLY FAILURE
597	20-Aug-21	BENGALURU	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	15:51	16:23	0:31	MAIN SUPPLY FAILURE
598	20-Aug-21	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	NO STATION AFFECTED	13:29	15:22	1:53	LINE FAULT
599	20-Aug-21	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	NO STATION AFFECTED	13:29	15:36	2:07	LINE FAULT
600	20-Aug-21	BENGALURU	220	HV1	SOMANAHALLI 220	15:52	16:45	0:53	MAIN SUPPLY FAILURE
601	20-Aug-21	BENGALURU	220	HV1	VRISHBHAVATHI 220	15:51	16:19	0:27	MAIN SUPPLY FAILURE
602	20-Aug-21	BENGALURU	220	HV2	VRISHBHAVATHI 220	15:51	16:19	0:27	MAIN SUPPLY FAILURE
603	20-Aug-21	BENGALURU	220	KANAKAPURA 220 - SOMANAHALLI 220	KANAKAPURA 220	15:52	17:30	1:38	MAIN SUPPLY FAILURE
604	20-Aug-21	BENGALURU	220	SOMANAHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	15:52	23:27	7:35	LINE CLEAR AVAILED
605	20-Aug-21	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI 220	NO STATION AFFECTED	15:52	16:16	0:24	LINE CLEAR AVAILED
606	20-Aug-21	BENGALURU	220	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	15:51	16:07	0:15	MAIN SUPPLY FAILURE
607	20-Aug-21	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHBHAVATHI 220	15:51	16:18	0:27	LINE FAULT
608	20-Aug-21	GULBARGA	66	HV2	HANASI_66	12:30	12:35	0:05	TRANSFORMER FAULT
609	20-Aug-21	GULBARGA	66	HV2	HANASI_66	12:36(20.08.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
610	20-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
611	20-Aug-21	GULBARGA	110	HALBARGA-SANTHPUR	SANTHPUR_110	5:10	5:15	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
612	20-Aug-21	GULBARGA	110	HATTI-LINGSUGUR	HATTI_110	15:19	16:58	1:39	MAIN SUPPLY FAILURE
613	20-Aug-21	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	5:52	6:10	0:18	LINE FAULT
614	20-Aug-21	GULBARGA	110	HV2	YEDRAMI_110	10:44(18.08.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
615	20-Aug-21	GULBARGA	110	HV3	KEREHALLI_110	7:17	7:28	0:11	TRANSFORMER FAULT
616	20-Aug-21	GULBARGA	110	HV3	LADHA_110	12:10	12:30	0:20	TRANSFORMER FAULT
617	20-Aug-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	17:47	17:57	0:10	LINE FAULT
618	20-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	0:25	0:35	0:10	LINE FAULT
619	20-Aug-21	GULBARGA	110	MUNIRABAD-VYSANKERE2	DONIMALAI_110	6:07	6:17	0:10	LINE FAULT
620	20-Aug-21	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110	19:40	19:52	0:12	LINE FAULT
621	20-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	4:46	4:51	0:05	LINE FAULT
622	20-Aug-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
623	20-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
624	20-Aug-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	19:25	19:45	0:20	LINE FAULT
625	20-Aug-21	GULBARGA	110	SHAHAPUR-SEDAM	SEDAM_220	22:44(20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
626	20-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	11:26(20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
627	20-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN: LINE CLEAR AVAILED
628	20-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	5:46	5:51	0:05	LINE FAULT
629	20-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	6:26	6:32	0:06	LINE FAULT
630	20-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	7:04	7:07	0:03	LINE FAULT
631	20-Aug-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	11:47	12:07	0:20	HAND TRIPPED
632	20-Aug-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	11:45	12:13	0:28	LINE FAULT
633	20-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
634	20-Aug-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:45	12:07	0:22	LINE FAULT
635	20-Aug-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	11:45	12:12	0:27	LINE FAULT
636	20-Aug-21	HASSAN	110	LPH	JOG_110	11:10(20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
637	20-Aug-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
638	20-Aug-21	HASSAN	220	HV1	MSEZ_220	12:50	13:38	0:48	LINE CLEAR AVAILED
639	20-Aug-21	HASSAN	220	HV2	MSEZ_220	10:35	12:52	2:17	LINE CLEAR AVAILED
640	20-Aug-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	17:11	20:35	3:24	LINE FAULT
641	20-Aug-21	HASSAN	220	LV1	MSEZ_220	12:50	13:38	0:48	LINE CLEAR AVAILED
642	20-Aug-21	HASSAN	220	LV2	MSEZ_220	10:35	12:52	2:17	LINE CLEAR AVAILED
643	20-Aug-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	14:45	16:22	1:37	LINE FAULT
644	20-Aug-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	14:44	16:22	1:38	LINE FAULT
645	20-Aug-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	17:11	20:36	3:25	LINE FAULT
646	20-Aug-21	MYSURU	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66	22:18 (19/08/2021)	0:18 (20/08/2021)	2 HRS	LINE CHARGED
647	20-Aug-21	MYSURU	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20 (19/08/2021)			LINE OPEN: LINE CLEAR AVAILED
648	20-Aug-21	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	13:39	13:46	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
649	20-Aug-21	MYSURU	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	5:55 (17/08/2021)			LINE OPEN: LINE FAULT
650	20-Aug-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAILED
651	20-Aug-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAILED
652	20-Aug-21	MYSURU	66	HV1	KABHALLY_66	13:49	14:08	0:18	TRANSFORMER FAULT
653	20-Aug-21	MYSURU	66	HV2	DEVANORNGUDU_66	8:04	8:14	0:09	TRANSFORMER FAULT
654	20-Aug-21	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	19:09	19:24	0:15	LINE FAULT
655	20-Aug-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN: LINE CLEAR AVAILED
656	20-Aug-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	5:51	6:14	0:23	LINE FAULT
657	20-Aug-21	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	18:03	18:16	0:13	LINE FAULT
658	20-Aug-21	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	9:58	11:17	1:19	LINE FAULT
659	20-Aug-21	TUMKUR	66	TR-1	CHIKKATOTLUKERE_66	13:15	13:59	0:43	LINE CLEAR AVAILED
660	20-Aug-21	TUMKUR	66	TR-1	RAMAPURA_66	9:28	10:57	1:28	LINE CLEAR AVAILED
661	20-Aug-21	TUMKUR	66	TR-2	KORA_66	11:02	11:52	0:50	TRANSFORMER FAULT
662	20-Aug-21	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	5:51	6:18	0:26	LINE FAULT
663	20-Aug-21	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	5:51	7:22	1:31	LINE FAULT
664	20-Aug-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	3:36	13:55	10:18	LINE FAULT
665	20-Aug-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:42	13:27	2:45	LINE CLEAR AVAILED
666	20-Aug-21	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	3:36	13:55	10:18	LINE FAULT
667	20-Aug-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:42	13:26	2:43	LINE CLEAR AVAILED
668	20-Aug-21	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	17:57	19:29	1:32	LINE CLEAR AVAILED
669	20-Aug-21	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	1:42	7:18	5:35	LINE FAULT
1	21-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
2	21-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
3	21-Aug-21	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	9:52	10:01	0:09	TRANSFORMER FAULT
4	21-Aug-21	BAGALKOT	110	110/11KV, HV1	KULIGERI CROSS_110	18:37	18:51	0:14	LINE CLEAR AVAILED
5	21-Aug-21	BAGALKOT	110	110/11KV, HV1	TILUVALLI_110	22:51 (21.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
6	21-Aug-21	BAGALKOT	110	110/11KV, HV2	KULIGERI CROSS_110	18:37	18:51	0:14	LINE CLEAR AVAILED
7	21-Aug-21	BAGALKOT	110	110/11KV, HV3	UGARKHUD_110, SHEDBAL_33	15:05	15:27	0:22	LINE CLEAR AVAILED
8	21-Aug-21	BAGALKOT	110	110/11KV, HV1	ANANDA NAGAR_110	11:55	13:07	1:12	LINE CLEAR AVAILED
9	21-Aug-21	BAGALKOT	110	110/11KV, HV1	BABLESHWAR_110	18:00	18:38	0:38	LINE CLEAR AVAILED
10	21-Aug-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED AMBEWADI_220	21:36	21:40	0:04	TRANSFORMER FAULT
11	21-Aug-21	BAGALKOT	110	110/11KV, HV2	BJCTY(THORVI)_110	7:26	7:35	0:09	TRANSFORMER FAULT
12	21-Aug-21	BAGALKOT	110	110/33KV, HV2	GAJENDRAGAD_110 & WIND 1&WIND2	23:04	23:19	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
13	21-Aug-21	BAGALKOT	110	110/33KV,HV2	GAJENDRAGAD_110 & WIND 1&WIND2	23:53	23:58	0:05	TRANSFORMER FAULT
14	21-Aug-21	BAGALKOT	110	110/33KV,HV2	KUDACHI_110 & CHINCHALI_33	15:17	15:35	0:18	TRANSFORMER FAULT
15	21-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
16	21-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
17	21-Aug-21	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT AFFECTED ANKALAGI_110	13:55	14:03	0:08	LINE CLEAR AVAILED
18	21-Aug-21	BAGALKOT	110	ATHARGA-KNI SOLAR	STATION NOT AFFECTED ATHARGA_110	21:36	21:54	0:18	LINE CLEAR AVAILED
19	21-Aug-21	BAGALKOT	110	BELGAUM-HUDLI	HUDLI_110	14:05	17:10	3:05	LINE CLEAR AVAILED
20	21-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
21	21-Aug-21	BAGALKOT	110	NARENDRA- KUD DHARWAD	KUD DHARWAD_110	12:36	15:18	2:42	LINE CLEAR AVAILED
22	21-Aug-21	BAGALKOT	110	NARENDRA-KUD DHARWAD	KUD DHARWAD_110	12:55	15:50	2:55	LINE CLEAR AVAILED
23	21-Aug-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
24	21-Aug-21	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	18:21	19:04	0:43	LINE FAULT
25	21-Aug-21	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	19:20	19:33	0:13	LINE FAULT
26	21-Aug-21	BAGALKOT	110	VIJAYANAGAR SUGARS- MUNDARGI	MUNDARGI_110	12:50	15:16	2:26	LINE CLEAR AVAILED
27	21-Aug-21	BAGALKOT	220	AMBEWADI-XELDOM(PONDA1)	STATION NOT AFFECTED AMBEWADI_220	12:35	13:20	0:45	LINE FAULT
28	21-Aug-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	12:48	14:10	1:22	LOAD CURTAILMENT
29	21-Aug-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	14:56 (21.08.2021)			LOAD CURTAILMENT
30	21-Aug-21	BAGALKOT	220	BELGAUM-KANABARGI1	STATION NOT AFFECTED BELGAUM_220	14:09	14:36	0:27	LINE FAULT
31	21-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
32	21-Aug-21	BAGALKOT	220	BIDNAL-HIREBENDIGERI2(TADAS2)	STATION NOT AFFECTED BIDNAL_220	10:15 (20.08.2021)			LINE OPEN: LINE FAULT
33	21-Aug-21	BAGALKOT	220	BIDNAL-NARENDRA	STATION NOT AFFECTED BIDNAL_220	11:04	13:29	2:25	LINE CLEAR AVAILED
34	21-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
35	21-Aug-21	BAGALKOT	220	NARENDRA- BIDNAL	NARENDRA_220	11:04	13:26	2:22	LINE CLEAR AVAILED
36	21-Aug-21	BAGALKOT	220	NARENDRA-KANABARGI1(BELGAUM1)	NARENDRA_220	14:09	14:35	0:26	LINE FAULT
37	21-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
38	21-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
39	21-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
40	21-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
41	21-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
42	21-Aug-21	BENGALURU	66	A STATION 220 - A STATION 1	A STATION 66	2:15	2:35	0:20	LINE CLEAR AVAILED
43	21-Aug-21	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	2:15	2:35	0:20	LINE CLEAR AVAILED
44	21-Aug-21	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	2:15	2:35	0:20	LINE CLEAR AVAILED
45	21-Aug-21	BENGALURU	66	BANGARPET - MALUR 220	BANGARPET	8:25	8:35	0:10	MAIN SUPPLY FAILURE
46	21-Aug-21	BENGALURU	66	BANGARPET - MALUR 220	BANGARPET	12:10	12:20	0:10	MAIN SUPPLY FAILURE
47	21-Aug-21	BENGALURU	66	BANGARPET - MALUR 220	BANGARPET	8:25	8:35	0:10	MAIN SUPPLY FAILURE
48	21-Aug-21	BENGALURU	66	BANGARPET - MALUR 220	BANGARPET	12:10	12:20	0:10	MAIN SUPPLY FAILURE
49	21-Aug-21	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	BG ROAD	6:28	6:38	0:10	LOAD CHANGE OVER
50	21-Aug-21	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	12:05	12:18	0:13	LINE CLEAR AVAILED
51	21-Aug-21	BENGALURU	66	ELITE PROMONEDE - KHODAYS 220	ELITE PROMONEDE	10:00	15:00	5:00	LINE CLEAR AVAILED
52	21-Aug-21	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	10:15	10:25	0:10	LOAD CHANGE OVER
53	21-Aug-21	BENGALURU	66	GOLF LINK - HSR LAYOUT 220	GOLF LINK	14:20	14:25	0:05	LOAD CHANGE OVER
54	21-Aug-21	BENGALURU	66	HONNIGANAHALLI - T K HALLI 220	HONNIGANAHALLI, DODDALAHALLI	8:20	8:35	0:15	LOAD CHANGE OVER
55	21-Aug-21	BENGALURU	66	HV1	AMAR JYOTHI	12:16	12:25	0:09	LINE CLEAR AVAILED
56	21-Aug-21	BENGALURU	66	HV1	R R NAGAR	16:51	17:20	0:29	TRANSFORMER FAULT
57	21-Aug-21	BENGALURU	66	HV1	SARJAPURA 220	9:00	10:25	1:25	MAIN SUPPLY FAILURE
58	21-Aug-21	BENGALURU	66	HV1	SARJAPURA 220	12:34	12:36	0:02	LOAD CHANGE OVER
59	21-Aug-21	BENGALURU	66	HV2	AMAR JYOTHI	9:19	9:24	0:05	LINE CLEAR AVAILED
60	21-Aug-21	BENGALURU	66	HV2	PADMANABHANAGARA	11:10	11:15	0:05	LINE CLEAR AVAILED
61	21-Aug-21	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	14:40	18:00	3:19	LINE CLEAR AVAILED
62	21-Aug-21	BENGALURU	66	HV2	SARJAPURA 220	9:00	9:12	0:12	MAIN SUPPLY FAILURE
63	21-Aug-21	BENGALURU	66	HV2	SARJAPURA 220	12:34	12:36	0:02	LOAD CHANGE OVER
64	21-Aug-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	9:25	12:10	2:45	MAIN SUPPLY FAILURE
65	21-Aug-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	12:37	12:43	0:06	LOAD CURTAILMENT
66	21-Aug-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	9:25	12:10	2:45	MAIN SUPPLY FAILURE
67	21-Aug-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	12:37	12:43	0:06	LOAD CURTAILMENT
68	21-Aug-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:25	12:10	2:45	MAIN SUPPLY FAILURE
69	21-Aug-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	9:25	12:10	2:45	MAIN SUPPLY FAILURE
70	21-Aug-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR	9:25	12:12	2:47	MAIN SUPPLY FAILURE
71	21-Aug-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR	9:25	12:12	2:47	MAIN SUPPLY FAILURE
72	21-Aug-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT)	9:25	12:10	2:45	MAIN SUPPLY FAILURE
73	21-Aug-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT)	9:25	12:10	2:45	MAIN SUPPLY FAILURE
74	21-Aug-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:25	12:10	2:45	MAIN SUPPLY FAILURE
75	21-Aug-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:25	12:10	2:45	MAIN SUPPLY FAILURE
76	21-Aug-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL	9:25	12:12	2:47	MAIN SUPPLY FAILURE
77	21-Aug-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL	9:25	12:12	2:47	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
78	21-Aug-21	BENGALURU	66	KOLAR 220 - VOKKALERI 1	VOKKALERI	8:25	8:35	0:10	MAIN SUPPLY FAILURE
79	21-Aug-21	BENGALURU	66	KOLAR 220 - VOKKALERI 1	VOKKALERI	12:10	12:25	0:15	MAIN SUPPLY FAILURE
80	21-Aug-21	BENGALURU	66	KOLAR 220 - VOKKALERI 1	VOKKALERI	8:25	8:35	0:10	MAIN SUPPLY FAILURE
81	21-Aug-21	BENGALURU	66	KOLAR 220 - VOKKALERI 1	VOKKALERI	12:10	12:25	0:15	MAIN SUPPLY FAILURE
82	21-Aug-21	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	9:25	12:13	2:48	MAIN SUPPLY FAILURE
83	21-Aug-21	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	9:25	12:13	2:48	MAIN SUPPLY FAILURE
84	21-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	VOKKALERI	8:24	8:36	0:12	MAIN SUPPLY FAILURE
85	21-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	VOKKALERI	12:10	12:23	0:13	LOAD CHANGE OVER
86	21-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	8:24	8:36	0:12	MAIN SUPPLY FAILURE
87	21-Aug-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:10	12:23	0:13	LOAD CHANGE OVER
88	21-Aug-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	8:24	8:36	0:12	MAIN SUPPLY FAILURE
89	21-Aug-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	12:10	12:23	0:13	LOAD CHANGE OVER
90	21-Aug-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), BANGARPETE	8:24	8:36	0:12	MAIN SUPPLY FAILURE
91	21-Aug-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), BANGARPETE	12:10	12:23	0:13	LOAD CHANGE OVER
92	21-Aug-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	8:24	8:36	0:12	MAIN SUPPLY FAILURE
93	21-Aug-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	12:10	12:23	0:13	LOAD CHANGE OVER
94	21-Aug-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	8:24	8:36	0:12	MAIN SUPPLY FAILURE
95	21-Aug-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	12:10	12:23	0:13	LOAD CHANGE OVER
96	21-Aug-21	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	8:24	8:36	0:12	MAIN SUPPLY FAILURE
97	21-Aug-21	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	12:10	12:23	0:13	LOAD CHANGE OVER
98	21-Aug-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	11:30	11:35	0:05	LINE FAULT
99	21-Aug-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	11:35	15:53	4:18	LINE FAULT
100	21-Aug-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	14:27	15:53	1:26	LINE CLEAR AVAILED
101	21-Aug-21	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	2:15	2:46	0:31	LINE CLEAR AVAILED
102	21-Aug-21	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	2:15	2:46	0:31	LINE CLEAR AVAILED
103	21-Aug-21	BENGALURU	66	NRS 220 - MYSORE ROAD 2	VIJAYANAGARA	2:15	2:46	0:31	LINE CLEAR AVAILED
104	21-Aug-21	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	2:15	2:46	0:31	LINE CLEAR AVAILED
105	21-Aug-21	BENGALURU	66	RBI - KHODAYS 220	RBI	5:14	5:19	0:05	LOAD CHANGE OVER
106	21-Aug-21	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	7:28	8:30	1:02	MAIN SUPPLY FAILURE
107	21-Aug-21	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	12:32	12:42	0:10	MAIN SUPPLY FAILURE
108	21-Aug-21	BENGALURU	66	SARIAPURA 220 - ATTIBELE	ATTIBELE	8:15	8:20	0:05	MAIN SUPPLY FAILURE
109	21-Aug-21	BENGALURU	66	SARIAPURA 220 - ATTIBELE	ATTIBELE	8:55	9:00	0:05	MAIN SUPPLY FAILURE
110	21-Aug-21	BENGALURU	66	SARIAPURA 220 - ATTIBELE	ATTIBELE	12:32	12:38	0:06	LOAD CHANGE OVER
111	21-Aug-21	BENGALURU	66	SARIAPURA 220 - CHANDAPURA	CHANDAPURA	8:57	8:59	0:02	LOAD CHANGE OVER
112	21-Aug-21	BENGALURU	66	SARIAPURA 220 - DOMMASANDRA	DOMMASANDRA	9:00	9:05	0:05	MAIN SUPPLY FAILURE
113	21-Aug-21	BENGALURU	66	SARIAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:32	12:36	0:04	LOAD CHANGE OVER
114	21-Aug-21	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISCON	17:20	17:28	0:08	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
115	21-Aug-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN: LINE FAULT
116	21-Aug-21	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	2:15	2:35	0:20	MAIN SUPPLY FAILURE
117	21-Aug-21	BENGALURU	220	HV1	NRS 220	2:15	2:45	0:30	LINE CLEAR AVAILED
118	21-Aug-21	BENGALURU	220	HV1	KOLAR 220	9:25	12:00	2:35	LINE CLEAR AVAILED
119	21-Aug-21	BENGALURU	220	HV1	MALUR 220	8:24	8:35	0:11	MAIN SUPPLY FAILURE
120	21-Aug-21	BENGALURU	220	HV1	MALUR 220	12:12	12:22	0:10	LOAD CHANGE OVER
121	21-Aug-21	BENGALURU	220	HV1	SARIJAPURA 220	9:05	9:07	0:02	MAIN SUPPLY FAILURE
122	21-Aug-21	BENGALURU	220	HV1	SARIJAPURA 220	12:34	12:36	0:02	LOAD CHANGE OVER
123	21-Aug-21	BENGALURU	220	HV1	KOLAR 220	9:25	12:00	2:35	LINE CLEAR AVAILED
124	21-Aug-21	BENGALURU	220	HV2	NRS 220	2:15	2:45	0:30	LINE CLEAR AVAILED
125	21-Aug-21	BENGALURU	220	HV2	MALUR 220	8:24	8:34	0:10	MAIN SUPPLY FAILURE
126	21-Aug-21	BENGALURU	220	HV2	MALUR 220	12:12	12:22	0:10	LOAD CHANGE OVER
127	21-Aug-21	BENGALURU	220	HV2	SARIJAPURA 220	9:05	10:25	1:20	MAIN SUPPLY FAILURE
128	21-Aug-21	BENGALURU	220	HV2	SARIJAPURA 220	12:34	12:36	0:02	LOAD CHANGE OVER
129	21-Aug-21	BENGALURU	220	HV3	NRS 220	2:15	2:45	0:30	LINE CLEAR AVAILED
130	21-Aug-21	BENGALURU	220	HV3	KOLAR 220	9:25	12:02	2:37	LINE CLEAR AVAILED
131	21-Aug-21	BENGALURU	220	HV3	KOLAR 220	9:25	12:02	2:37	LINE CLEAR AVAILED
132	21-Aug-21	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	9:25	11:49	2:24	LINE CLEAR AVAILED
133	21-Aug-21	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	9:25	11:49	2:24	LINE CLEAR AVAILED
134	21-Aug-21	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	9:25	11:50	2:25	LINE CLEAR AVAILED
135	21-Aug-21	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	9:25	11:50	2:25	LINE CLEAR AVAILED
136	21-Aug-21	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	2:15	2:40	0:25	MAIN SUPPLY FAILURE
137	21-Aug-21	BENGALURU	220	SARIJAPURA 220 - MALUR 220	SARIJAPURA 220	8:50	8:55	0:05	LOAD CHANGE OVER
138	21-Aug-21	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	2:15	2:40	0:25	LINE FAULT
139	21-Aug-21	GULBARGA	66	HV2	HANASI_66	12:36(20.08.2021)	8:40(21.08.2021)	20:04 HRS	TRANSFORMER CHARGED
140	21-Aug-21	GULBARGA	66	NEELAGUNDA-PUNMABGHATA	PUNMABGHATA_66	9:19	9:35	0:16	LINE FAULT
141	21-Aug-21	GULBARGA	66	NEELAGUNDA-PUNMABGHATA	PUNMABGHATA_66	9:35	10:40	1:05	LINE FAULT
142	21-Aug-21	GULBARGA	66	NEELAGUNDA-TELADI	TELADI_66	10:26	12:07	1:41	LINE CLEAR AVAILED
143	21-Aug-21	GULBARGA	110	ALLIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURGOD_110,SHATHVANA_IPP,AGRAWAL_IPP,SUZLON_IPP,KAMALAPUR_110,MATHRI_110 RBNS FACTORY	22:40	23:06	0:26	LINE FAULT
144	21-Aug-21	GULBARGA	110	GULBARGASOUTH-GULBARGA UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
145	21-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
146	21-Aug-21	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110	23:30	23:35	0:05	LINE FAULT
147	21-Aug-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	12:41	15:25	2:44	MAIN SUPPLY FAILURE
148	21-Aug-21	GULBARGA	110	HV1	CHINCHOLI_110	21:38	21:58	0:20	TRANSFORMER FAULT
149	21-Aug-21	GULBARGA	110	HV1	CHINCHOLI_110	22:40	22:52	0:12	TRANSFORMER FAULT
150	21-Aug-21	GULBARGA	110	HV1	KAMALNAGAR_110	17:55	18:00	0:05	TRANSFORMER FAULT
151	21-Aug-21	GULBARGA	110	HV2	YEDRAMI_110	10:44(18.08.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
152	21-Aug-21	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110,NSSK SUGAR FACTORY IPP	14:09	14:18	0:09	LINE CLEAR AVAILED
153	21-Aug-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:39	19:55	0:16	LINE FAULT
154	21-Aug-21	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	19:02	19:22	0:20	LINE FAULT
155	21-Aug-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	21:44	22:25	0:41	MAIN SUPPLY FAILURE
156	21-Aug-21	GULBARGA	110	PD_HALLI-BELLARY NORTH	PD_HALLI_110	0:52	1:04	0:12	MAIN SUPPLY FAILURE
157	21-Aug-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
158	21-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
159	21-Aug-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	0:24	0:30	0:06	LINE FAULT
160	21-Aug-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110,UGARSUGAR_IPP	0:24	0:30	0:06	LINE FAULT
161	21-Aug-21	GULBARGA	110	SHAHAPUR-RAICHUR2(IDLE LINE)	GOOGLE_110	23:34(21.08.2021)			LINE OPEN: LINE FAULT
162	21-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	11:26(20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
163	21-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	11:26	18:15	6:49	LINE CLEAR AVAILED
164	21-Aug-21	GULBARGA	110	SINDHANOOR-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	0:43	0:53	0:10	LINE FAULT
165	21-Aug-21	GULBARGA	220	HV2	ALLIPUR_220	22:40	22:53	0:13	MAIN SUPPLY FAILURE
166	21-Aug-21	GULBARGA	220	HV2	NEELAGUNDA_220	12:20	13:29	1:09	LINE CLEAR AVAILED
167	21-Aug-21	GULBARGA	220	HV2	NEELAGUNDA_220	9:19	9:30	0:11	LINE CLEAR AVAILED
168	21-Aug-21	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	5:50	9:30	3:40	LINE CLEAR AVAILED
169	21-Aug-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:44(20.08.2021)	6:23(21.08.2021)	7:39HRS	LINE CHARGED
170	21-Aug-21	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	15:01	17:36	2:35	LINE CLEAR AVAILED
171	21-Aug-21	HASSAN	66	HV1	MALLIPATNA_66	12:21	13:01	0:40	LINE CLEAR AVAILED
172	21-Aug-21	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	10:22	14:25	4:03	LINE CLEAR AVAILED
173	21-Aug-21	HASSAN	66	HV2	HALLYMYSORE_66	7:20	7:25	0:05	TRANSFORMER FAULT
174	21-Aug-21	HASSAN	66	HV2	RAMNATHPURA_66	8:50	16:27	7:37	LINE CLEAR AVAILED
175	21-Aug-21	HASSAN	66	HV2	SALAGAME_66	3:49	6:55	3:06	TRANSFORMER FAULT
176	21-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN: LINE CLEAR AVAILED
177	21-Aug-21	HASSAN	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	11:56	12:58	1:02	LINE CLEAR AVAILED
178	21-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	11:13	11:15	0:02	LINE FAULT
179	21-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	11:58	13:00	1:02	LINE CLEAR AVAILED
180	21-Aug-21	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	9:44	12:30	2:46	LINE CLEAR AVAILED
181	21-Aug-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	10:00	16:45	6:45	LINE CLEAR AVAILED
182	21-Aug-21	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	12:38	13:28	0:50	LINE CLEAR AVAILED
183	21-Aug-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	8:49	9:01	0:12	LINE FAULT
184	21-Aug-21	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	10:46	11:11	0:25	LINE CLEAR AVAILED
185	21-Aug-21	HASSAN	110	HV1	KADUR_220	10:48	12:30	1:42	LINE CLEAR AVAILED
186	21-Aug-21	HASSAN	110	HV1	HOSANGADI_110	14:48	17:28	2:40	TRANSFORMER FAULT
187	21-Aug-21	HASSAN	110	HV3	KAVOOR_220	5:36	5:52	0:16	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
188	21-Aug-21	HASSAN	110	JOG110-LPH	JOG_110	11:13 (20.8.2021)	10:32 (21.8.2021)	23:19hrs	LINE CHARGED
189	21-Aug-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAIED
190	21-Aug-21	HASSAN	110	LV2	KEMAR_220	11:18	12:37	1:19	LINE CLEAR AVAIED
191	21-Aug-21	HASSAN	110	LV3	KEMAR_220	12:15	13:28	1:13	LINE CLEAR AVAIED
192	21-Aug-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	22:34 (21.8.2021)			LINE OPEN: LINE FAULT
193	21-Aug-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:25	14:13	0:48	LINE FAULT
194	21-Aug-21	HASSAN	220	HV2	KEMAR_220	11:18	12:37	1:19	LINE CLEAR AVAIED
195	21-Aug-21	HASSAN	220	HV3	KEMAR_220	12:15	13:28	1:13	LINE CLEAR AVAIED
196	21-Aug-21	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	11:00	11:06	0:06	LINE FAULT
197	21-Aug-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	22:34 (21.8.2021)			LINE OPEN: LINE FAULT
198	21-Aug-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:25	14:07	0:42	LINE FAULT
199	21-Aug-21	MYSURU	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20 (19/08/2021)			LINE OPEN: LINE CLEAR AVAIED
200	21-Aug-21	MYSURU	66	CR NAGARA-YALANDUR	NO STATIONS EFFECTED	11:16	11:23	0:06	LINE FAULT
201	21-Aug-21	MYSURU	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	5:55 (17/08/2021)			LINE OPEN: LINE FAULT
202	21-Aug-21	MYSURU	66	HALAGUR-TK HALLI	HALAGUR_66	8:35	8:53	0:18	HAND TRIPPED
203	21-Aug-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAIED
204	21-Aug-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAIED
205	21-Aug-21	MYSURU	66	HV1	GUNDLUPETE_66	10:34	15:11	4:37	LINE CLEAR AVAIED
206	21-Aug-21	MYSURU	66	HV1	JAKKANAHALLI_66	11:19	12:18	0:59	LINE CLEAR AVAIED
207	21-Aug-21	MYSURU	66	HV2	BANNIMANTAP_66	10:56	12:18	1:21	LINE CLEAR AVAIED
208	21-Aug-21	MYSURU	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	10:44	13:57	3:13	LINE CLEAR AVAIED
209	21-Aug-21	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	10:41	13:24	2:43	LINE CLEAR AVAIED
210	21-Aug-21	MYSURU	66	KADAKOLA-THANDYA	NO STATIONS EFFECTED	10:43	13:24	2:41	LINE CLEAR AVAIED
211	21-Aug-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021			LINE OPEN: LINE CLEAR AVAIED
212	21-Aug-21	MYSURU	66	KR PETE 220-BOOKANAKERE	BOOKANAKERE_66 SHILANERE_66 GANGIGERE_66 BANANGADI_66CHINKURALI_66	17:27	17:33	0:05	LINE FAULT
213	21-Aug-21	MYSURU	66	KR PETE 220-CR PATNA	ANEGOLA_66 KRISHNAPURA_66	17:10	17:15	0:05	LINE FAULT
214	21-Aug-21	MYSURU	66	KR PETE-KIKKERI	KIKKERI_66	17:12	17:19	0:07	LINE FAULT
215	21-Aug-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI_66 BG NAGARA_66 AC GIRI_66 VADERALLI_66 BASARALU_66 KESALGERE_66	20:38	20:52	0:14	LINE FAULT
216	21-Aug-21	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	13:32	13:56	0:24	LINE FAULT
217	21-Aug-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	9:38	9:55	0:16	LINE FAULT
218	21-Aug-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	11:24	12:17	0:53	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
219	21-Aug-21	TUMKUR	66	DEVARAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66	9:03	18:33	9:30	MAIN SUPPLY FAILURE
220	21-Aug-21	TUMKUR	66	HONNALLI 220kV-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	8:44	18:36	9:52	LINE CLEAR AVAILED
221	21-Aug-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	8:46	18:38	9:52	LINE CLEAR AVAILED
222	21-Aug-21	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	23:44	23:49	0:05	MAIN SUPPLY FAILURE
223	21-Aug-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	8:50	18:55	10:05	LINE CLEAR AVAILED
224	21-Aug-21	TUMKUR	66	TELAGI- VESTAS IPP	VESTAS_IPP_66	12:20	16:29	4:09	LINE CLEAR AVAILED
225	21-Aug-21	TUMKUR	66	TR-1	DEVARAHALLI_66	9:03	18:33	9:30	MAIN SUPPLY FAILURE
226	21-Aug-21	TUMKUR	66	TR-1	HONNALLI_220	12:19	16:26	4:06	LINE CLEAR AVAILED
227	21-Aug-21	TUMKUR	66	TR-1	BENKIKERE_66	19:05	19:12	0:07	TRANSFORMER FAULT
228	21-Aug-21	TUMKUR	66	TR-1	BENKIKERE_66	21:57	22:06	0:09	TRANSFORMER FAULT
229	21-Aug-21	TUMKUR	66	TR-1(LV SIDE)	DAVANAGERE SRS	20:06	21:29	1:22	TRANSFORMER FAULT
230	21-Aug-21	TUMKUR	66	TR-2	BENNEHALLI	17:40	17:45	0:05	TRANSFORMER FAULT
231	21-Aug-21	TUMKUR	220	TR-1	DAVANGERE_SRS_220	20:06	21:27	1:21	TRANSFORMER FAULT
232	21-Aug-21	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	12:19	16:19	3:59	LINE CLEAR AVAILED
233	22-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
234	22-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
235	22-Aug-21	BAGALKOT	110	110/11KV, HV1	TILUVALLI_110	22:51 (21.08.2021)	8:33 (22.08.2021)	9:42 hrs	TRANSFORMER CHARGED
236	22-Aug-21	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	6:17	6:45	0:28	TRANSFORMER FAULT
237	22-Aug-21	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED AMBEWADI_220	9:03	9:32	0:29	LINE CLEAR AVAILED
238	22-Aug-21	BAGALKOT	110	110/33KV, HV3	LOKAPUR_110, BHATKURKI_33, RSKKN_33	10:27	16:36	6:09	LINE CLEAR AVAILED
239	22-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR	ALBAL_110	15:59	18:44	2:45	LINE CLEAR AVAILED
240	22-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGAR	ALBAL_110	15:58	18:42	2:44	LINE CLEAR AVAILED
241	22-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
242	22-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
243	22-Aug-21	BAGALKOT	110	BAGALKOT-LOKAPUR	LOKAPUR_110	5:56	6:06	0:10	LINE FAULT
244	22-Aug-21	BAGALKOT	110	GAMESHA- KULIGOD	KULIGOD_110	7:47	7:50	0:03	HAND TRIPPED
245	22-Aug-21	BAGALKOT	110	GHATAPRABHA-PG HUNASYAL	HUNASYAL_110	7:18	7:27	0:09	LINE FAULT
246	22-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
247	22-Aug-21	BAGALKOT	110	HAVERI220- TILUVALLI	TILUVALLI_110	6:54	7:24	0:30	LINE FAULT
248	22-Aug-21	BAGALKOT	110	HAVERI-TILUVALLI(HANAGALL)	TILUVALLI_110	6:54	7:24	0:30	LINE FAULT
249	22-Aug-21	BAGALKOT	110	HUNGUND-KUDALASANGAM(BAGEWADI)	HUNGUND_110	12:35	12:53	0:18	LINE FAULT
250	22-Aug-21	BAGALKOT	110	HUNGUND-KUDALASANGAM(BAGEWADI)	HUNGUND_110	13:23	13:36	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
251	22-Aug-21	BAGALKOT	110	HUNGUND-KUDALASANGAM(BAGEWADI)	HUNGUND_110	13:35	13:57	0:22	LINE FAULT
252	22-Aug-21	BAGALKOT	110	ILKAL2-HUNGUND	HUNGUND_110	12:42	12:53	0:11	HAND TRIPPED
253	22-Aug-21	BAGALKOT	110	ILKAL2-HUNGUND	HUNGUND_110	14:03	17:41	3:38	LINE CLEAR AVAILED
254	22-Aug-21	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	6:08	6:22	0:14	LINE FAULT
255	22-Aug-21	BAGALKOT	110	NARENDRA- BELUR1	BELUR_110	10:52	18:46	7:54	LINE CLEAR AVAILED
256	22-Aug-21	BAGALKOT	110	NARENDRA- BELUR2	BELUR_110	12:00	14:22	2:22	LINE CLEAR AVAILED
257	22-Aug-21	BAGALKOT	110	NARENDRA2-BELUR	BELUR_110	10:38 (22.08.2021)			LINE OPEN: LINE FAULT
258	22-Aug-21	BAGALKOT	110	RANEENNUR- GUTTAL	GUTTAL_110	7:27	7:45	0:18	LINE FAULT
259	22-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
260	22-Aug-21	BAGALKOT	110	SATTI- RABAKAVI	SATTI_110	6:20	9:02	2:42	LINE CLEAR AVAILED
261	22-Aug-21	BAGALKOT	110	UGARKHUD- UGAR SUGARS	UGARKHUD_110	5:21	5:32	0:11	LINE FAULT
262	22-Aug-21	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	LOKAPUR_110	15:37	17:32	1:55	LINE CLEAR AVAILED
263	22-Aug-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	14:56 (21.08.2021)			LOAD CURTAILMENT
264	22-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
265	22-Aug-21	BAGALKOT	220	BIDNAL-HIREBENDIGERI2(TADAS2)	STATION NOT AFFECTED BIDNAL_220	10:15 (20.08.2021)			LINE OPEN: LINE FAULT
266	22-Aug-21	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	11:04	15:19	4:15	LINE FAULT
267	22-Aug-21	BAGALKOT	220	DHONI-HALVARTI(LINGAPUR2	DHONI_400	10:50	18:15	7:25	LINE FAULT
268	22-Aug-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	14:18	18:50	4:32	LINE FAULT
269	22-Aug-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	15:06	18:06	3:00	LINE FAULT
270	22-Aug-21	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	15:13	16:21	1:08	LINE FAULT
271	22-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
272	22-Aug-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	14:18	18:51	4:33	LINE FAULT
273	22-Aug-21	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	12:07	12:27	0:20	LINE FAULT
274	22-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
275	22-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
276	22-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
277	22-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
278	22-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
279	22-Aug-21	BENGALURU	66	AGALKOTE - KEMPANAHALLI	AGALKOTE	10:15	18:15	8:00	LINE CLEAR AVAILED
280	22-Aug-21	BENGALURU	66	APPAREL PARK - KIADB 220	APPAREL PARK	10:10	17:10	7:00	LINE CLEAR AVAILED
281	22-Aug-21	BENGALURU	66	CHANDAPURA - YERANDANAHALLI	CHANDAPURA	12:18	12:28	0:10	LOAD CHANGE OVER
282	22-Aug-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	18:46	19:04	0:18	LINE FAULT
283	22-Aug-21	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	10:00	16:53	6:53	LINE CLEAR AVAILED
284	22-Aug-21	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	10:00	16:53	6:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
285	22-Aug-21	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	11:47	12:47	1:00	LINE CLEAR AVAILED
286	22-Aug-21	BENGALURU	66	HV1	KORAMANGALA 220	12:05	12:36	0:31	LINE CLEAR AVAILED
287	22-Aug-21	BENGALURU	66	HV1	YEDUMADU	12:20	12:25	0:05	TRANSFORMER FAULT
288	22-Aug-21	BENGALURU	66	HV1	VOLVO	6:49	7:11	0:21	TRANSFORMER FAULT
289	22-Aug-21	BENGALURU	66	HV1	VOLVO	16:05	16:21	0:16	TRANSFORMER FAULT
290	22-Aug-21	BENGALURU	66	HV1	CHAKAVELU	9:22	9:26	0:04	TRANSFORMER FAULT
291	22-Aug-21	BENGALURU	66	HV1	KIADB DB PURA 220	10:05	17:18	7:13	LINE CLEAR AVAILED
292	22-Aug-21	BENGALURU	66	HV2	ANJANAPURA	22:13	22:20	0:07	TRANSFORMER FAULT
293	22-Aug-21	BENGALURU	66	HV2	KORAMANGALA 220	12:05	12:36	0:31	LINE CLEAR AVAILED
294	22-Aug-21	BENGALURU	66	HV2	NANDINI LAYOUT	1:55	4:39	2:44	TRANSFORMER FAULT
295	22-Aug-21	BENGALURU	66	HV2	KIADB DB PURA 220	10:05	17:18	7:13	LINE CLEAR AVAILED
296	22-Aug-21	BENGALURU	66	HV3	KIADB DB PURA 220	10:05	17:18	7:13	LINE CLEAR AVAILED
297	22-Aug-21	BENGALURU	66	IISc - HEBBALA 220	IISc	9:35	9:40	0:05	LOAD CHANGE OVER
298	22-Aug-21	BENGALURU	66	IISc - NRS 220	IISc	17:41	17:49	0:08	LOAD CHANGE OVER
299	22-Aug-21	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	16:18	16:30	0:12	LINE FAULT
300	22-Aug-21	BENGALURU	66	KIADB DB PURA 220 - APPEATEL PARK	APPEATEL PARK	10:14	17:18	7:04	LINE CLEAR AVAILED
301	22-Aug-21	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT)	HIMAT SINGHA FACTORY (EHT)	12:25	17:18	4:53	LINE CLEAR AVAILED
302	22-Aug-21	BENGALURU	66	KIADB DB PURA 220 - INDOMEN (EHT)	INDOMEN (EHT)	12:38	17:18	4:40	LINE CLEAR AVAILED
303	22-Aug-21	BENGALURU	66	KORMANGALA 220 - AMARJYOTHI	AMARJYOTHI	12:05	12:36	0:31	LINE CLEAR AVAILED
304	22-Aug-21	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	12:05	12:36	0:31	LINE CLEAR AVAILED
305	22-Aug-21	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	8:19	8:23	0:04	LOAD CHANGE OVER
306	22-Aug-21	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	17:20	17:25	0:05	LOAD CHANGE OVER
307	22-Aug-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	5:58	6:05	0:07	LINE FAULT
308	22-Aug-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	17:32	17:42	0:10	LINE FAULT
309	22-Aug-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	16:52	16:57	0:04	LINE FAULT
310	22-Aug-21	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	12:05	12:36	0:31	LINE CLEAR AVAILED
311	22-Aug-21	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	12:05	12:36	0:31	LINE CLEAR AVAILED
312	22-Aug-21	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	17:22	17:24	0:02	LOAD CHANGE OVER
313	22-Aug-21	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	9:08	9:11	0:03	LOAD CHANGE OVER
314	22-Aug-21	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	17:12	17:22	0:10	LOAD CHANGE OVER
315	22-Aug-21	BENGALURU	66	SARIAPURA 220 - CHANDAPURA	CHANDAPURA	22:00	22:05	0:05	LOAD CHANGE OVER
316	22-Aug-21	BENGALURU	66	T GOLLAHALLI 220 - KGF	ANDERSONPETE,KYASAMBALLI, DODDAKARI	2:09	2:37	0:28	LINE FAULT
317	22-Aug-21	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN: LINE FAULT
318	22-Aug-21	BENGALURU	220	EPiP 220 - HSR LAYOUT 220	KORAMANGALA 220, NAGANATHPURA 220	12:05	12:36	0:31	LINE FAULT
319	22-Aug-21	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	11:25	12:23	0:58	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
320	22-Aug-21	BENGALURU	220	HSR LAYOUT 220 - HOODY 400	HSR LAYOUT 220	11:36	12:26	0:50	LINE FAULT
321	22-Aug-21	BENGALURU	220	HV1	KORAMANGALA 220	12:05	12:36	0:31	LINE CLEAR AVAILED
322	22-Aug-21	BENGALURU	220	HV1	KIADB DB PURA 220	12:23	17:18	4:55	LINE CLEAR AVAILED
323	22-Aug-21	BENGALURU	220	HV2	HSR LAYOUT 220	11:36	12:26	0:50	LINE CLEAR AVAILED
324	22-Aug-21	BENGALURU	220	HV2	KORAMANGALA 220	12:05	12:36	0:31	LINE CLEAR AVAILED
325	22-Aug-21	BENGALURU	220	HV2	KIADB DB PURA 220	12:23	17:18	4:55	LINE CLEAR AVAILED
326	22-Aug-21	BENGALURU	220	KIADB DB PURA 220 - GOWRIBIDANUR 220	KIADB DB PURA 220	10:05	17:15	7:10	LINE CLEAR AVAILED
327	22-Aug-21	BENGALURU	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220	12:05	12:36	0:31	MAIN SUPPLY FAILURE
328	22-Aug-21	BENGALURU	220	NAGANATHPURA 220 - HSR LAYOUT 220	NAGANATHPURA 220	12:05	12:36	0:31	MAIN SUPPLY FAILURE
329	22-Aug-21	GULBARGA	110	GULBARGASOUTH-GULBARGA UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
330	22-Aug-21	GULBARGA	110	GURMITKAL-SEDAM	GURMITKAL_110	3:40	3:45	0:05	LINE FAULT
331	22-Aug-21	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110	7:48	7:54	0:06	LINE FAULT
332	22-Aug-21	GULBARGA	110	HV2	YEDRAMI_110	10:44(18.08.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
333	22-Aug-21	GULBARGA	110	HV3	KEREHALI_110	19:00	19:05	0:05	TRANSFORMER FAULT
334	22-Aug-21	GULBARGA	110	KAPANOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	18:51	18:57	0:06	LINE FAULT
335	22-Aug-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	5:43	5:47	0:04	LINE FAULT
336	22-Aug-21	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	5:53	6:06	0:13	LINE FAULT
337	22-Aug-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	1:15	1:30	0:15	MAIN SUPPLY FAILURE
338	22-Aug-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	5:14	6:01	0:47	MAIN SUPPLY FAILURE
339	22-Aug-21	GULBARGA	110	SEDAM- VICAT SAGAR	VICAT SAGR CEMENT_IPP	5:44	5:59	0:15	LINE FAULT
340	22-Aug-21	GULBARGA	110	SEDAM-CHITHAPUR	KORAWAR TEMPLE_110	1:36	1:46	0:10	LINE FAULT
341	22-Aug-21	GULBARGA	110	SEDAM-CHITHAPUR	KORAWAR TEMPLE_110	2:12	2:15	0:03	LINE FAULT
342	22-Aug-21	GULBARGA	110	SEDAM-CHITHAPUR	KORAWAR TEMPLE_110	2:17	2:43	0:26	LINE FAULT
343	22-Aug-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
344	22-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
345	22-Aug-21	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	5:46	6:01	0:15	LINE FAULT
346	22-Aug-21	GULBARGA	110	SINDHANOOR-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	10:10	10:20	0:10	LINE FAULT
347	22-Aug-21	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	8:27	8:35	0:08	LINE FAULT
348	22-Aug-21	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	3:03	9:50	6:47	LINE FAULT
349	22-Aug-21	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	3:05	10:10	7:05	MAIN SUPPLY FAILURE
350	22-Aug-21	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	18:37	18:57	0:20	LINE FAULT
351	22-Aug-21	HASSAN	66	HV1	MAGGE_66	17:33	17:52	0:19	TRANSFORMER FAULT
352	22-Aug-21	HASSAN	66	HV2	HALLYMYSORE_66	16:18	18:47	2:29	LINE CLEAR AVAILED
353	22-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN: LINE CLEAR AVAILED
354	22-Aug-21	HASSAN	66	SOMNHL-GDNEHALI	SOMANAHALLI_66	18:37	19:14	0:37	LINE FAULT
355	22-Aug-21	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	3:03	3:19	0:16	LINE FAULT
356	22-Aug-21	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	3:56	4:14	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
357	22-Aug-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
358	22-Aug-21	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	22:34 (21.8.2021)	12:37 (22.8.2021)	14:03hrs	LINE CHARGED
359	22-Aug-21	HASSAN	220	GER SOPA-TALGUPA2	gerusoppa_gen	10:24	18:38	8:14	LINE CLEAR AVAILED
360	22-Aug-21	HASSAN	220	KADUR-DABUSET	KADUR_220	13:44	14:47	1:03	LINE FAULT
361	22-Aug-21	HASSAN	220	MRSSH M-SHARAVATHY1	MRS MG_220	22:34 (21.8.2021)	12:29 (22.8.2021)	13:54hrs	LINE CHARGED
362	22-Aug-21	HASSAN	220	MRSSH M-SHARAVATHY3	MRS MG_220	14:00	14:34	0:34	LINE FAULT
363	22-Aug-21	HASSAN	220	MRSSH M-SHARAVATHY3	MRS MG_220	12:03	13:51	1:48	LINE FAULT
364	22-Aug-21	HASSAN	220	MRSSH M-SHARAVATHY4	MRS MG_220	10:53	12:24	1:31	LINE FAULT
365	22-Aug-21	HASSAN	220	SHRAV TY-SHIMO GA3	sharavathy_gen	12:03	13:51	1:48	LINE FAULT
366	22-Aug-21	HASSAN	220	SHRAV TY-SHIMO GA3	sharavathy_gen	14:00	14:34	0:34	LINE FAULT
367	22-Aug-21	HASSAN	220	SHRAV TY-SHIMO GA4	sharavathy_gen	10:53	12:26	1:33	LINE FAULT
368	22-Aug-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	9:56	18:33	8:37	LINE FAULT
369	22-Aug-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:07(22.8.2021)			LINE OPEN: LINE CLEAR AVAILED
370	22-Aug-21	MYSURU	66	BOOKANAKERE-KR PETE	BOOKANAKERE_66 CHINKURALI_66 BANANGADI_66	7:16	9:24	2:08	NFBC ISSUED
371	22-Aug-21	MYSURU	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20 (19/08/2021)			LINE OPEN: LINE CLEAR AVAILED
372	22-Aug-21	MYSURU	66	DR PETE-KUNTHUR	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	5:55 (17/08/2021)			LINE OPEN: LINE FAULT
373	22-Aug-21	MYSURU	66	HANNUR-KOTTHANUR	NO STATIONS EFFECTED	5:55	6:00	0:05	LINE FAULT
374	22-Aug-21	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAILED
375	22-Aug-21	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAILED
376	22-Aug-21	MYSURU	66	HV1	JAKKANAHALLI_66	11:52	12:32	0:39	TRANSFORMER FAULT
377	22-Aug-21	MYSURU	66	HV1	JAKKANAHALLI_66	14:45	16:02	1:17	TRANSFORMER FAULT
378	22-Aug-21	MYSURU	66	HV1	JAKKANAHALLI_66	17:50	17:54	0:04	HAND TRIPPED
379	22-Aug-21	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	2:41	2:53	0:12	LINE FAULT
380	22-Aug-21	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN: LINE CLEAR AVAILED
381	22-Aug-21	MYSURU	66	KR PETE 220-BOOKANAKERE	SHILANERE_66 GANGIGERE_66	7:31	9:24	1:52	LINE CLEAR AVAILED
382	22-Aug-21	MYSURU	66	KUSHALNAGARA 220- RAMANTHAPURA1	KANGAL_66 RUDRAPATNA_66 CB HALLI_66 ALLURSIDDAPURA_66.	15:44	22:33	6:48	LINE FAULT
383	22-Aug-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	6:14	6:19	0:05	LINE FAULT
384	22-Aug-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI_66 BG NAGARA_66 AC GIRI_66 VADERALLI_66 BASARALU_66 KESALGERE_66	8:40	8:47	0:07	LINE FAULT
385	22-Aug-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI_66 BG NAGARA_66 AC GIRI_66 VADERALLI_66 BASARALU_66 KESALGERE_66	8:47	9:12	0:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
386	22-Aug-21	MYSURU	66	VAJMANGALA-BANNUR	BANNUR_66	13:04	13:11	0:07	LINE FAULT
387	22-Aug-21	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	9:08	9:18	0:10	LINE FAULT
388	22-Aug-21	TUMKUR	66	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_220	9:08	9:18	0:10	LINE FAULT
389	22-Aug-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66,MELEKATTE_66	20:08	20:34	0:25	LINE FAULT
390	22-Aug-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	20:12	20:34	0:22	LINE FAULT
391	22-Aug-21	TUMKUR	66	DEVARAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66	9:07	18:19	9:12	MAIN SUPPLY FAILURE
392	22-Aug-21	TUMKUR	66	HANAGAL-THALLAK	HANAGAL_66	13:41	13:48	0:06	LINE FAULT
393	22-Aug-21	TUMKUR	66	HANAGAL-THALLAK	HANAGAL_66	14:19	14:26	0:07	LINE FAULT
394	22-Aug-21	TUMKUR	66	HONNALLI 220KV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:17	12:36	0:18	MAIN SUPPLY FAILURE
395	22-Aug-21	TUMKUR	66	HONNALLI 220KV-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:03	18:06	9:02	LINE CLEAR AVAILED
396	22-Aug-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	12:17	12:36	0:18	MAIN SUPPLY FAILURE
397	22-Aug-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	9:03	18:06	9:03	LINE CLEAR AVAILED
398	22-Aug-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	9:07	18:07	9:00	LINE CLEAR AVAILED
399	22-Aug-21	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	10:02	18:02	8:00	LINE CLEAR AVAILED
400	22-Aug-21	TUMKUR	66	TR-1	BENKIKERE_66	9:38	16:42	7:04	MAIN SUPPLY FAILURE
401	22-Aug-21	TUMKUR	66	TR-1	DEVARAHALLI_66	9:07	18:19	9:12	MAIN SUPPLY FAILURE
402	22-Aug-21	TUMKUR	66	TR-1	NAGASAMUDRA_66	7:13	7:25	0:12	TRANSFORMER FAULT
403	22-Aug-21	TUMKUR	66	TR-1(HV SIDE)	HONNALLI_220	12:20	12:34	0:13	MAIN SUPPLY FAILURE
404	22-Aug-21	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	12:20	12:32	0:11	MAIN SUPPLY FAILURE
405	22-Aug-21	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	16:49	18:03	1:14	LINE CLEAR AVAILED
406	22-Aug-21	TUMKUR	66	TR-2	BENKIKERE_66	9:38	16:43	7:05	MAIN SUPPLY FAILURE
407	22-Aug-21	TUMKUR	66	TR-2	CHIKKABANAGERE_66	14:20	14:50	0:30	LINE CLEAR AVAILED
408	22-Aug-21	TUMKUR	66	TR-2	LINGDHALLI_66	18:35	18:43	0:07	TRANSFORMER FAULT
409	22-Aug-21	TUMKUR	66	TR-2	TELAGI_66	8:25	8:39	0:14	HAND TRIPPED
410	22-Aug-21	TUMKUR	66	TR-2(HV SIDE)	HONNALLI_220	12:20	12:36	0:15	MAIN SUPPLY FAILURE
411	22-Aug-21	TUMKUR	66	TR-2(LV SIDE)	HONNALLI_220	12:20	12:34	0:14	MAIN SUPPLY FAILURE
412	22-Aug-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	12:17	12:30	0:12	LINE FAULT
413	22-Aug-21	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	13:01	15:30	2:29	LINE FAULT
414	22-Aug-21	TUMKUR	220	HONNALLI 220KV- SUZLON2	SUZLON_IPP_66	12:24	12:57	0:33	LINE FAULT
415	22-Aug-21	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	12:20	12:31	0:10	MAIN SUPPLY FAILURE
1	23-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
2	23-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)	16:18 (23.08.2021)	1024:52 HRS	TRANSFORMER CHARGED
3	23-Aug-21	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	11:14	11:53	0:39	LINE CLEAR AVAILED
4	23-Aug-21	BAGALKOT	110	110/11KV,HV2	GOKAK_110	0:08	0:21	0:13	TRANSFORMER FAULT
5	23-Aug-21	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	11:59	12:36	0:37	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
6	23-Aug-21	BAGALKOT	110	220/110KV, LV3	MAHALINGAPUR_220	10:38	13:54	3:16	LINE CLEAR AVAILED
7	23-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR	ALBAL_110	7:30	9:43	2:13	LINE CLEAR AVAILED
8	23-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	ALBAL_110	7:29	9:43	2:14	LINE FAULT
9	23-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	ALBAL_110	11:18	11:54	0:36	LINE CLEAR AVAILED
10	23-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
11	23-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN: LINE CLEAR AVAILED
12	23-Aug-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	3:51	4:14	0:23	LINE FAULT
13	23-Aug-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	6:50	7:06	0:16	LINE FAULT
14	23-Aug-21	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	13:22	16:45	3:23	LINE CLEAR AVAILED
15	23-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
16	23-Aug-21	BAGALKOT	110	KPR SUGARS-ALMEL	ALMEL_110	6:47	20:12	13:25	LINE CLEAR AVAILED
17	23-Aug-21	BAGALKOT	110	MAHALINGAPUR- HIDIKAL&RABAKAVI	HIDIKAL_110 & RABAKAVI_110	10:25	14:00	3:35	LINE CLEAR AVAILED
18	23-Aug-21	BAGALKOT	110	MALGHAN(SO-MANALI SUGARS)	MALGHAN(S)_110	3:36	3:40	0:04	LINE FAULT
19	23-Aug-21	BAGALKOT	110	MAMADPUR-BABALESHWAR	BABALESHWAR_110	4:18	4:25	0:07	HAND TRIPPED
20	23-Aug-21	BAGALKOT	110	MAMADPUR-BLGM SLR	MAMADAPUR_110	4:18	4:25	0:07	HAND TRIPPED
21	23-Aug-21	BAGALKOT	110	MAMADPUR-SHIRABUR	SHIRABUR_110	4:18	4:27	0:09	HAND TRIPPED
22	23-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
23	23-Aug-21	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	GUTTAL_110	10:31	10:40	0:09	LINE FAULT
24	23-Aug-21	BAGALKOT	110	SRS-RAMNAKOPPA	RAMANAKOPPA_110	2:50	14:09	11:19	LINE CLEAR AVAILED
25	23-Aug-21	BAGALKOT	220	AMBEWADI-(PONDA1)XELDOM	AMBEWADI_220	12:28	13:36	1:08	LINE FAULT
26	23-Aug-21	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	11:41	14:42	3:01	LINE FAULT
27	23-Aug-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	14:56 (21.08.2021)			LOAD CURTAILMENT
28	23-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN: LINE FAULT
29	23-Aug-21	BAGALKOT	220	BIDNAL-HIREBENDIGERI2(TADAS2)	STATION NOT AFFECTED BIDNAL_220	10:15 (20.08.2021)			LINE OPEN: LINE FAULT
30	23-Aug-21	BAGALKOT	220	BIDNAL-NAGJHARI	BIDNAL_220	11:29	11:55	0:26	LINE FAULT
31	23-Aug-21	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	12:59	13:53	0:54	LINE FAULT
32	23-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
33	23-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
34	23-Aug-21	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	13:04	14:50	1:46	LINE FAULT
35	23-Aug-21	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	12:59	13:46	0:47	LINE FAULT
36	23-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
37	23-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN: LINE CLEAR AVAILED
38	23-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
39	23-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
40	23-Aug-21	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	13:09	13:21	0:12	LINE CLEAR AVAILED
41	23-Aug-21	BANGALORE	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:28	12:20	0:52	LINE CLEAR AVAILED
42	23-Aug-21	BANGALORE	66	HAL 220 - HOODY 1	KADUBEESANAHALLI, ISRO (EHT), CESSNA (EHT)	9:03	9:44	0:40	LINE FAULT
43	23-Aug-21	BANGALORE	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:30	7:03	0:33	LINE FAULT
44	23-Aug-21	BANGALORE	66	HV1	HOSPALYA CIRCLE	7:25	7:38	0:13	TRANSFORMER FAULT
45	23-Aug-21	BANGALORE	66	HV1	KAMASAMUDRA	13:25	14:04	0:39	LINE CLEAR AVAILED
46	23-Aug-21	BANGALORE	66	HV1	HENNUR CROSS	5:45	8:35	2:50	TRANSFORMER FAULT
47	23-Aug-21	BANGALORE	66	HV2	THIMMAMPALLI	5:05	8:35	3:30	TRANSFORMER FAULT
48	23-Aug-21	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	7:22	7:39	0:17	LINE FAULT
49	23-Aug-21	Bangalore	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN: LINE FAULT
50	23-Aug-21	BANGALORE	220	HOODY 400 - MALUR 220	NO STATION AFFECTED	13:25	17:16	3:51	LINE FAULT
51	23-Aug-21	BANGALORE	220	MALUR 220 - HOODY 400	NO STATION AFFECTED	13:26	17:16	3:50	LINE FAULT
52	23-Aug-21	BANGALORE	400	HOODY 400 - DEVANAHALLI 400	NO STATION AFFECTED	17:25	19:16	1:51	LINE CLEAR AVAILED
53	23-Aug-21	GULBARGA	66	HV1	GUDEKOTE_66	7:02	7:10	0:08	TRANSFORMER FAULT
54	23-Aug-21	GULBARGA	66	HV1	ITTAGI_220	10:10	12:55	2:45	LINE CLEAR AVAILED
55	23-Aug-21	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66,TUNGABHADRA_IPP	6:05	6:15	0:10	LINE FAULT
56	23-Aug-21	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66,TUNGABHADRA_IPP	9:25	9:42	0:17	LINE FAULT
57	23-Aug-21	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	5:20	5:39	0:19	LINE FAULT
58	23-Aug-21	GULBARGA	110	GABUR-RAICHUR	GABUR_110	5:20	5:30	0:10	MAIN SUPPLY FAILURE
59	23-Aug-21	GULBARGA	110	GULBARGASOUTH-GULBARGA UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
60	23-Aug-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	5:34	7:26	1:52	MAIN SUPPLY FAILURE
61	23-Aug-21	GULBARGA	110	HV2	YEDRAMI_110	10:44(18.08.2021)	12:10(23.08.2021)	121:26 HRS	TRANSFORMER CHARGED
62	23-Aug-21	GULBARGA	110	HV3	TEKKALKOTE_110	12:03	13:40	1:37	LINE CLEAR AVAILED
63	23-Aug-21	GULBARGA	110	KAPANOOR-GULBARGA WEST	GULBARGA WEST_110	14:13	15:49	1:36	LINE CLEAR AVAILED
64	23-Aug-21	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110,NSSK SUGAR FACTORY_IPP	12:35	13:02	0:27	LINE CLEAR AVAILED
65	23-Aug-21	GULBARGA	110	LINGASUGUR-CHYADEVI_IPP	LINGASUGUR_220	0:30	0:55	0:25	LINE FAULT
66	23-Aug-21	GULBARGA	110	LINGASUGUR-CHYADEVI_IPP	LINGASUGUR_220	5:10	5:20	0:10	LINE FAULT
67	23-Aug-21	GULBARGA	110	LINGASUGUR-CHYADEVI_IPP	LINGASUGUR_220	13:26	14:18	0:52	LINE CLEAR AVAILED
68	23-Aug-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	5:25	5:30	0:05	LINE FAULT
69	23-Aug-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:34	5:46	0:12	LINE FAULT
70	23-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	3:35	3:40	0:05	LINE FAULT
71	23-Aug-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
72	23-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
73	23-Aug-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	20:52	20:53	0:01	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
74	23-Aug-21	GULBARGA	110	SINDHANOOOR-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	8:10	8:20	0:10	LINE FAULT
75	23-Aug-21	GULBARGA	110	SINDHANOOOR-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	22:10	22:20	0:10	LINE FAULT
76	23-Aug-21	GULBARGA	110	SINDHANOOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	21:45	21:55	0:10	LINE FAULT
77	23-Aug-21	GULBARGA	110	SINDHANOOOR-THURVIHAL	THUIRVIHAL_110	13:05	13:20	0:15	LINE FAULT
78	23-Aug-21	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	10:27	10:30	0:03	LOAD CURTAILMENT
79	23-Aug-21	GULBARGA	220	HALWARTHI-DONI1	HALWARTHI_220	14:56(23.08.2021)			LINE OPEN: LINE FAULT
80	23-Aug-21	GULBARGA	220	HALWARTHI-DONI1	HALWARTHI_220	10:47	14:56	4:09	LINE FAULT
81	23-Aug-21	GULBARGA	220	HV1	LINGASUGUR_220	5:30	5:45	0:15	TRANSFORMER FAULT
82	23-Aug-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
83	23-Aug-21	GULBARGA	220	HV2	LINGASUGUR_220	5:30	5:45	0:15	TRANSFORMER FAULT
84	23-Aug-21	GULBARGA	220	LINGSUGUR-SHAHAPUR	SHAHAPUR_220	20:02	20:29	0:27	LINE FAULT
85	23-Aug-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	19:44	19:54	0:10	LINE FAULT
86	23-Aug-21	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	9:20	15:04	5:44	LINE CLEAR AVAILED
87	23-Aug-21	HASSAN	66	BANDISH-HNPURA	BANDISHETTYHALLI_66	9:20	15:04	5:44	LINE CLEAR AVAILED
88	23-Aug-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	9:20	15:04	5:44	LINE CLEAR AVAILED
89	23-Aug-21	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	10:10	12:10	2:00	LINE CLEAR AVAILED
90	23-Aug-21	HASSAN	66	HV1	BALEHONNUR_66	5:05	5:25	0:20	TRANSFORMER FAULT
91	23-Aug-21	HASSAN	66	HV1	BANDISHETTYHALLI_66	9:20	15:04	5:44	LINE CLEAR AVAILED
92	23-Aug-21	HASSAN	66	HV1	BYACHANAHALLI_66	9:20	12:20	3:00	MAIN SUPPLY FAILURE
93	23-Aug-21	HASSAN	66	HV1	DIDIGA_66	18:30	18:52	0:22	TRANSFORMER FAULT
94	23-Aug-21	HASSAN	66	HV1	HALLIMYSORE_66	12:02	12:23	0:21	LINE CLEAR AVAILED
95	23-Aug-21	HASSAN	66	HV1	HANGARANAHALLY_66	11:14	12:21	1:07	LINE CLEAR AVAILED
96	23-Aug-21	HASSAN	66	HV1	RAMESHWARNAGARA_66	10:44	11:00	0:16	HAND TRIPPED
97	23-Aug-21	HASSAN	66	HV1	KUDLIGERE_66	11:09	14:05	2:56	MAIN SUPPLY FAILURE
98	23-Aug-21	HASSAN	66	HV2	HALLIMYSORE_66	12:30	13:40	1:10	LINE CLEAR AVAILED
99	23-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN: LINE CLEAR AVAILED
100	23-Aug-21	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	10:59	13:59	3:00	MAIN SUPPLY FAILURE
101	23-Aug-21	HASSAN	66	SBELAG-SNTBCHL	SHRAVANABELAGOLA_66	12:07 (23.08.2021)			LINE OPEN: LINE CLEAR AVAILED
102	23-Aug-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:50	14:00	3:10	LINE CLEAR AVAILED
103	23-Aug-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	15:08	15:26	0:18	LINE FAULT
104	23-Aug-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:53	12:45	1:52	NFBC ISSUED
105	23-Aug-21	HASSAN	110	HV3	PUTTUR_110	9:37	13:08	3:31	LINE CLEAR AVAILED
106	23-Aug-21	HASSAN	110	HV4	PUTTUR_110	13:09	17:14	4:05	LINE CLEAR AVAILED
107	23-Aug-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:53	12:45	1:52	LINE CLEAR AVAILED
108	23-Aug-21	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN: LINE CLEAR AVAILED
109	23-Aug-21	HASSAN	110	SHRLKP-KITTAHAHALI	SHIRALKOPPA_220	10:35	11:04	0:29	LINE FAULT
110	23-Aug-21	HASSAN	110	SINGATG-YAGATI	SINGATGERE_110	11:24	12:46	1:22	LINE CLEAR AVAILED
111	23-Aug-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:35	13:11	0:36	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
112	23-Aug-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:40	15:24	3:44	LINE FAULT
113	23-Aug-21	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	12:35	13:11	0:36	LINE FAULT
114	23-Aug-21	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	11:40	15:24	3:44	LINE FAULT
115	23-Aug-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:07(22.8.2021)	9:01 (23.08.2021)	14:54hrs	LINE CHARGED
116	23-Aug-21	MYSORE	66	BANNUR-VAJMANGALA	BANNUR_66	13:47	14:27	0:40	HAND TRIPPED
117	23-Aug-21	MYSORE	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20 (19/08/2021)			LINE OPEN: LINE CLEAR AVAILED
118	23-Aug-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	7:28	17:44	10:15	LINE CLEAR AVAILED
119	23-Aug-21	MYSORE	66	CR NAGARA-YALANDUR	NO STATIONS EFFECTED	7:45	17:46	10:00	LINE CLEAR AVAILED
120	23-Aug-21	MYSORE	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAILED
121	23-Aug-21	MYSORE	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN: LINE CLEAR AVAILED
122	23-Aug-21	MYSORE	66	HV1	GUNDLUPETE_66	15:12	15:38	0:25	LINE CLEAR AVAILED
123	23-Aug-21	MYSORE	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	10:12	13:04	2:52	LINE CLEAR AVAILED
124	23-Aug-21	MYSORE	66	KADAKOLA-MANTAKALLI	NO STATIONS EFFECTED	11:51	14:27	2:35	LINE CLEAR AVAILED
125	23-Aug-21	MYSORE	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	11:51	14:26	2:35	LINE CLEAR AVAILED
126	23-Aug-21	MYSORE	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN: LINE CLEAR AVAILED
127	23-Aug-21	MYSORE	66	KR PETE 220-BOOKANAKERE	SHILANERE_66 CHINKURALI_66 GANGIGERE_66 BOOKANAKERE_66 BANANGAD_66	8:41	8:48	0:07	LINE FAULT
128	23-Aug-21	MYSORE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	15:14	15:23	0:09	LINE FAULT
129	23-Aug-21	MYSORE	66	PERIYAPATNA-HANGODU	HANGODU_66 PONNAMPETE_66VIRAJPETE_66	3:02	3:14	0:12	LINE FAULT
130	23-Aug-21	MYSORE	66	PERIYAPATNA-KAMPLAPURA	KAMPLAPURA_66 HUNSUR_66	6:04	6:15	0:11	LINE FAULT
131	23-Aug-21	TUMKUR	66	CHITRADURGA 220kV- HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	13:43	14:01	0:17	LINE FAULT
132	23-Aug-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	6:33	6:44	0:11	LINE FAULT
133	23-Aug-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	16:45	16:58	0:13	HAND TRIPPED
134	23-Aug-21	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:45	16:58	0:13	HAND TRIPPED
135	23-Aug-21	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	9:14	17:48	8:33	MAIN SUPPLY FAILURE
136	23-Aug-21	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	10:44	10:51	0:06	HAND TRIPPED
137	23-Aug-21	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	12:05	15:41	3:35	LINE CLEAR AVAILED
138	23-Aug-21	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	8:59	18:13	9:14	LINE CLEAR AVAILED
139	23-Aug-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	8:59	18:13	9:13	LINE CLEAR AVAILED
140	23-Aug-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	11:27	11:29	0:02	MAIN SUPPLY FAILURE
141	23-Aug-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	12:30	13:00	0:30	MAIN SUPPLY FAILURE
142	23-Aug-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	9:00	18:21	9:21	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
143	23-Aug-21	TUMKUR	66	LINGADAHALLI-HONNALLI	LINGADAHALLY_66	8:59	18:09	9:10	MAIN SUPPLY FAILURE
144	23-Aug-21	TUMKUR	66	PATTNAYAKANAHALLI-TAVAREKERE(SIRA)	PATTNAYAKANAHALLI_66	13:06	13:08	0:02	HAND TRIPPED
145	23-Aug-21	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	12:25	12:29	0:04	LOAD CURTAILMENT
146	23-Aug-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	11:34	11:41	0:07	LOAD CURTAILMENT
147	23-Aug-21	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WLSPNSOLAR2	11:34	11:41	0:07	LOAD CURTAILMENT
148	23-Aug-21	TUMKUR	66	THALLAK 220kV - BGKERE 1	BGKERE 1	10:37	10:47	0:10	LOAD CURTAILMENT
149	23-Aug-21	TUMKUR	66	THALLAK 220kV - BGKERE 1	BGKERE 1	11:30	11:34	0:04	LOAD CURTAILMENT
150	23-Aug-21	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	THALLAK 220kV	11:30	11:34	0:04	LOAD CURTAILMENT
151	23-Aug-21	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	CHALLAKERE_66, SANIKERE_66	11:30	11:40	0:10	LOAD CURTAILMENT
152	23-Aug-21	TUMKUR	66	TR-1	BENNIKERE_66	13:31	14:14	0:43	LINE CLEAR AVAILED
153	23-Aug-21	TUMKUR	66	TR-1	DEVARAHALLI_66	9:14	17:45	8:31	MAIN SUPPLY FAILURE
154	23-Aug-21	TUMKUR	66	TR-1	LINGADAHALLY_66	8:59	19:10	10:10	MAIN SUPPLY FAILURE
155	23-Aug-21	TUMKUR	66	TR-1	MATHOD_66	6:15	6:22	0:07	TRANSFORMER FAULT
156	23-Aug-21	TUMKUR	66	TR-1	NIDASALE_66	13:14	14:27	1:13	LINE CLEAR AVAILED
157	23-Aug-21	TUMKUR	66	TR-1	PAVAGADA_220	13:04	13:08	0:03	HAND TRIPPED
158	23-Aug-21	TUMKUR	66	TR-2	BENNIKERE_66	13:31	14:12	0:41	LINE CLEAR AVAILED
159	23-Aug-21	TUMKUR	66	TR-2	LINGADAHALLY_66	8:59	18:20	9:20	MAIN SUPPLY FAILURE
160	23-Aug-21	TUMKUR	66	TR-2	PAVAGADA_220	13:05	13:08	0:03	HAND TRIPPED
161	23-Aug-21	TUMKUR	66	TR-2(LV-2)	THALLAK 220kV	11:28	11:32	0:04	TRANSFORMER FAULT
162	23-Aug-21	TUMKUR	66	TR-3	HOLALKERE_66	14:58	17:15	2:16	LINE CLEAR AVAILED
163	23-Aug-21	TUMKUR	110	HONNAVALI 110-KADUR220(ARASEKERE)	HONNAVALI_110	14:24	14:31	0:07	LINE FAULT
164	23-Aug-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	19:24	19:45	0:20	TRANSFORMER FAULT
165	23-Aug-21	TUMKUR	110	TR-2	HONNAVALI_110	14:00	14:35	0:35	TRANSFORMER FAULT
166	23-Aug-21	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	12:27	14:22	1:55	LINE FAULT
167	23-Aug-21	TUMKUR	220	HIRIYUR220-MADHUGIRI	MADHUGIRI_220	16:07	16:58	0:51	LINE FAULT
168	23-Aug-21	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	12:10	16:22	4:11	LINE CLEAR AVAILED
169	23-Aug-21	TUMKUR	220	THALLAK 220kV -HIRIYUR	SANEKERE_66, THALLAKK_220	8:40	14:11	5:31	LINE FAULT
170	23-Aug-21	TUMKUR	220	THALLAK 220kV -HIRIYUR	SANEKERE_66, THALLAKK_220	14:11	20:02	5:50	LINE FAULT
171	23-Aug-21	TUMKUR	220	TR-2	THALLAK_220	11:28	11:31	0:03	TRANSFORMER FAULT