

**400/220/110/66 kV TRANSMISSION OUTAGES FROM : 10.08.2021 to 16.08.21**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	10-Aug-21	BANGALORE	66	ADUGODI - HSR 1	ADUGODI	9:42	9:47	0:05	LOAD CHANGE OVER
2	10-Aug-21	BANGALORE	66	BAGHMANE WTP - HOODY 220	BAGHMANE WTP	12:43	12:48	0:05	LOAD CHANGE OVER
3	10-Aug-21	BANGALORE	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	15:57	16:46	0:49	LINE CLEAR AVOIDED
4	10-Aug-21	BANGALORE	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	16:52	17:05	0:13	LINE FAULT
5	10-Aug-21	BANGALORE	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	17:20	18:30	1:10	LINE FAULT
6	10-Aug-21	BANGALORE	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	8:27	9:07	0:40	LINE FAULT
7	10-Aug-21	BANGALORE	66	DALASNUR - SRINIVASPURA	DALASNUR	2:00	2:35	0:35	MAIN SUPPLY FAILURE
8	10-Aug-21	BANGALORE	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, BOSCH (EHT)	9:32	9:38	0:06	LOAD CHANGE OVER
9	10-Aug-21	BANGALORE	66	HV1	ELECTRONIC CITY P2 S1	12:45	13:15	0:30	LINE CLEAR AVOIDED
10	10-Aug-21	BANGALORE	66	HV1	ELECTRONIC CITY P2 S1	16:20	16:45	0:25	LINE CLEAR AVOIDED
11	10-Aug-21	BANGALORE	66	HV1	ITI 220	11:02	11:05	0:03	LINE CLEAR AVOIDED
12	10-Aug-21	BANGALORE	66	HV1	PRESTIGE SHANTINIKETHAN	14:30	14:35	0:05	LINE CLEAR AVOIDED
13	10-Aug-21	BANGALORE	66	HV1	TAVAREKERE	13:05	13:40	0:35	LINE CLEAR AVOIDED
14	10-Aug-21	BANGALORE	66	HV1	TAVAREKERE	15:08	15:14	0:06	LINE CLEAR AVOIDED
15	10-Aug-21	BANGALORE	66	HV1	T K HALLI 220	15:45	17:35	1:50	LINE CLEAR AVOIDED
16	10-Aug-21	BANGALORE	66	HV1	CHAKAVELU	17:35	18:21	0:46	LINE CLEAR AVOIDED
17	10-Aug-21	BANGALORE	66	HV1	CHANDAPURA	11:17	17:20	6:02	LINE CLEAR AVOIDED
18	10-Aug-21	BANGALORE	66	HV1	DEVANAHALLI	17:35	18:30	0:55	LINE CLEAR AVOIDED
19	10-Aug-21	BANGALORE	66	HV1	NELEMANGALA 66	15:34	16:04	0:30	LINE CLEAR AVOIDED
20	10-Aug-21	BANGALORE	66	HV1	VOLVO	4:20	4:35	0:14	TRANSFORMER FAULT
21	10-Aug-21	BANGALORE	66	HV2	TAVAREKERE	12:00	12:10	0:10	LINE CLEAR AVOIDED
22	10-Aug-21	BANGALORE	66	HV2	TAVAREKERE	15:08	15:14	0:06	LINE CLEAR AVOIDED
23	10-Aug-21	BANGALORE	66	HV2	CHANDAPURA	10:02	18:43	8:40	LINE CLEAR AVOIDED
24	10-Aug-21	BANGALORE	66	HV2	HUKUNDA	10:00	10:05	0:05	LINE CLEAR AVOIDED
25	10-Aug-21	BANGALORE	66	HV2	NELEMANGALA 66	16:02	16:25	0:23	LINE CLEAR AVOIDED
26	10-Aug-21	BANGALORE	66	HV2	THAYALUR	0:00	0:22	0:22	TRANSFORMER FAULT
27	10-Aug-21	BANGALORE	66	HV3	NELEMANGALA 66	16:28	17:05	0:37	LINE CLEAR AVOIDED
28	10-Aug-21	BANGALORE	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	10:00	15:00	5:00	LINE CLEAR AVOIDED
29	10-Aug-21	BANGALORE	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	6:10	6:30	0:20	LINE FAULT
30	10-Aug-21	BANGALORE	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	16:50	17:05	0:15	LINE FAULT
31	10-Aug-21	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	20:05	20:27	0:22	LINE CLEAR AVOIDED
32	10-Aug-21	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	20:05	20:24	0:19	LINE CLEAR AVOIDED
33	10-Aug-21	BANGALORE	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
34	10-Aug-21	BANGALORE	220	HV2	SUBRAMANYAPURA 220	20:05:00(10/08/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
35	10-Aug-21	GULBARGA	110	BYAGAWAT-ACME SOLAR	BYAGAWAT_110	19:14(10.08.2021)			LINE OPEN :LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
36	10-Aug-21	GULBARGA	110	GABUR-RAICHUR	GABUR_110	6:15	6:25	0:10	MAIN SUPPLY FAILURE
37	10-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
38	10-Aug-21	GULBARGA	110	HANASI-KUDLIGI	HANASI_110	14:00	15:35	1:35	LINE CLEAR AVAILED
39	10-Aug-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
40	10-Aug-21	GULBARGA	110	HV1	KOLHAR_110	11:57	16:40	4:43	LINE CLEAR AVAILED
41	10-Aug-21	GULBARGA	110	HV1	BENNU_110	12:30	12:40	0:10	TRANSFORMER FAULT
42	10-Aug-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	16:06	16:50	0:44	LINE FAULT
43	10-Aug-21	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110,TORANGALU_110	6:55	7:09	0:14	MAIN SUPPLY FAILURE
44	10-Aug-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	18:46	19:11	0:25	LINE FAULT
45	10-Aug-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	0:12	0:23	0:11	LINE FAULT
46	10-Aug-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	1:02	5:20	4:18	LINE FAULT
47	10-Aug-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	6:08	6:47	0:39	LINE CLEAR AVAILED
48	10-Aug-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	20:39	20:49	0:10	LINE FAULT
49	10-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:57	3:02	0:05	LINE FAULT
50	10-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	4:49	4:58	0:09	LINE FAULT
51	10-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	11:12	11:44	0:32	LINE CLEAR AVAILED
52	10-Aug-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	2:35	3:15	0:40	LINE FAULT
53	10-Aug-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	4:35	4:45	0:10	LINE FAULT
54	10-Aug-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	4:58	5:13	0:15	LINE FAULT
55	10-Aug-21	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	11:35	14:20	2:45	LINE CLEAR AVAILED
56	10-Aug-21	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	21:30(09.08.2021)	13:42(10.08.2021)	16:12HRS	LINE CHARGED
57	10-Aug-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:38(10.08.2021)			LINE OPEN :LINE CLEAR AVAILED
58	10-Aug-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:38(10.08.2021)	6:08(11.08.2021)	8:30HRS	LINE CHARGED
59	10-Aug-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALY_66	11:03	16:05	5:02	LINE CLEAR AVAILED
60	10-Aug-21	HASSAN	66	HASSN220-MALLALI	HASSAN_220	11:32	13:13	1:41	LINE CLEAR AVAILED
61	10-Aug-21	HASSAN	66	HV1	SALAGAME_66	9:29 (30.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
62	10-Aug-21	HASSAN	66	HV1	HALEBEEDU_66	13:57	14:40	0:43	LINE CLEAR AVAILED
63	10-Aug-21	HASSAN	66	HV1	MALLAPURA_66	14:47	15:39	0:52	LINE CLEAR AVAILED
64	10-Aug-21	HASSAN	66	HV2	MALLAPURA_66	14:46	15:39	0:53	LINE CLEAR AVAILED
65	10-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN :LINE CLEAR AVAILED
66	10-Aug-21	HASSAN	66	MALLAPUR-SHIMOGA	MALLAPURA_66	14:47	15:39	0:52	LINE CLEAR AVAILED
67	10-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
68	10-Aug-21	HASSAN	110	HV1	KONAJE_110	7:55	8:20	0:25	HAND TRIPPED
69	10-Aug-21	HASSAN	110	HV1	KONAJE_110	9:27	9:37	0:10	HAND TRIPPED
70	10-Aug-21	HASSAN	110	HV1	KONAJE_110	22:55	23:06	0:11	HAND TRIPPED
71	10-Aug-21	HASSAN	110	HV2	KONAJE_110	7:55	8:20	0:25	HAND TRIPPED
72	10-Aug-21	HASSAN	110	HV2	KONAJE_110	9:27	9:37	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
73	10-Aug-21	HASSAN	110	HV2	KONAJE_110	22:55	23:06	0:11	HAND TRIPPED
74	10-Aug-21	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	22:52 (10.08.2021)			LINE OPEN:LINE FAULT
75	10-Aug-21	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	7:53	11:45	3:52	LINE FAULT
76	10-Aug-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	7:55	8:30	0:35	MAIN SUPPLY FAILURE
77	10-Aug-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:27	9:51	0:24	MAIN SUPPLY FAILURE
78	10-Aug-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	22:55	23:17	0:22	MAIN SUPPLY FAILURE
79	10-Aug-21	HASSAN	110	LV2	SHIRALKOPPA_220	13:17	14:13	0:56	LINE CLEAR AVAILED
80	10-Aug-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	12:17	13:02	0:45	LINE FAULT
81	10-Aug-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	13:03	13:43	0:40	HAND TRIPPED
82	10-Aug-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	9:26	9:34	0:08	MAIN SUPPLY FAILURE
83	10-Aug-21	HASSAN	110	VITTAL-PUTR_SLTUR	VITLA_110	9:26	9:34	0:08	LINE FAULT
84	10-Aug-21	HASSAN	220	HV2	SHIRALKOPPA_220	13:17	14:13	0:56	LINE CLEAR AVAILED
85	10-Aug-21	HASSAN	220	KADUR-SHIMOGA	KADUR_220	16:24	18:20	1:56	LINE FAULT
86	10-Aug-21	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	10:08	11:15	1:07	LINE CLEAR AVAILED
87	10-Aug-21	HASSAN	220	KEMAR-UPCL2	KEMAR_220	9:53	17:54	8:01	NFBC ISSUED
88	10-Aug-21	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	10:02 (9.08.2021)	15:00 (10.08.2021)	28:58hrs	LINE CHARGED
89	10-Aug-21	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	16:24	18:13	1:49	LINE FAULT
90	10-Aug-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:02	15:28	2:26	LINE FAULT
91	10-Aug-21	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	9:40	11:45	2:05	NFBC ISSUED
92	10-Aug-21	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:09	11:15	1:06	NFBC ISSUED
93	10-Aug-21	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	13:02	15:28	2:26	LINE FAULT
94	10-Aug-21	HASSAN	220	UPCL-KEMAR2	upcl_gen	9:53	17:54	8:01	LINE CLEAR AVAILED
95	10-Aug-21	HASSAN	220	VARAH1-SHMG3	varahi_gen	9:40	11:45	2:05	LINE CLEAR AVAILED
96	10-Aug-21	MYSORE	66	CR NAGARA-BADANAGUPPE 2	BADANAGUPPE_66	9:09	17:30	8:21	NFBC ISSUED
97	10-Aug-21	MYSORE	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ARKALAWADI_66 ATTIGULIPURA_66	9:23	18:11	8:47	LINE CLEAR AVAILED
98	10-Aug-21	MYSORE	66	CR NAGARA-PANYADAHUNDI	NO STATIONS EFFECTED	10:28	12:27	1:58	LINE CLEAR AVAILED
99	10-Aug-21	MYSORE	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	12:06(10.08.21)			LINE OPEN :LINE CLEAR AVAILED
100	10-Aug-21	MYSORE	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	12:06(10.08.21)			LINE OPEN :LINE CLEAR AVAILED
101	10-Aug-21	MYSORE	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	7:25	7:49	0:23	HAND TRIPPED
102	10-Aug-21	MYSORE	66	HV2	CHANDAKAVADI_66	11:11	11:52	0:40	LINE CLEAR AVAILED
103	10-Aug-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:32	9:42	0:09	LINE FAULT
104	10-Aug-21	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66,SAS ALUHALLA_66	10:52	10:59	0:06	HAND TRIPPED
105	10-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2_66	10:34	10:52	0:18	LINE FAULT
106	10-Aug-21	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:00	15:04	0:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
107	10-Aug-21	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:11	16:15	0:03	LINE CLEAR AVAILED
108	10-Aug-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	15:00	16:14	1:14	LINE CLEAR AVAILED
109	10-Aug-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	15:05	15:20	0:15	MAIN SUPPLY FAILURE
110	10-Aug-21	TUMKUR	66	TR-1	BADDIHALLI_66	11:14	12:13	0:59	LINE CLEAR AVAILED
111	10-Aug-21	TUMKUR	66	TR-1	DODDASARANGI_66	11:23	12:44	1:21	LINE CLEAR AVAILED
112	10-Aug-21	TUMKUR	66	TR-1	UCHCHANGIDURGA_66	18:02	18:06	0:03	HAND TRIPPED
113	10-Aug-21	TUMKUR	66	TR-1	SOKKE_66	10:05	10:11	0:05	TRANSFORMER FAULT
114	10-Aug-21	TUMKUR	66	TR-1(LV-SIDE)	HONNALLI_220	15:07	16:10	1:02	LINE CLEAR AVAILED
115	10-Aug-21	TUMKUR	66	TR-2	BADDIHALLI_66	12:18	12:44	0:25	LINE CLEAR AVAILED
116	10-Aug-21	TUMKUR	66	TR-2	BEVINAHALLI_66	15:02	15:16	0:13	HAND TRIPPED
117	10-Aug-21	TUMKUR	66	TR-2	CHITRADURGA_66	15:05	16:54	1:48	LINE CLEAR AVAILED
118	10-Aug-21	TUMKUR	66	TR-2	UCHCHANGIDURGA_66	17:11	18:11	1:00	LINE CLEAR AVAILED
119	10-Aug-21	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	11:02	11:50	0:47	LINE CLEAR AVAILED
120	10-Aug-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:40	16:18	3:38	LINE CLEAR AVAILED
121	10-Aug-21	TUMKUR	220	TR-1	HONNALLI_220	15:07	16:09	1:01	LINE CLEAR AVAILED
122	11-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
123	11-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
124	11-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SUARNASOUDA_110	13:15	14:31	1:16	LINE CLEAR AVAILED
125	11-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NIDAGUNDI_110	8:58	9:02	0:04	TRANSFORMER FAULT
126	11-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUNDAGANUR_110	17:40	19:34	1:54	LINE CLEAR AVAILED
127	11-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MELLIGERI_110	15:33	17:00	1:27	LINE CLEAR AVAILED
128	11-Aug-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SUARNASOUDA_110	11:28	13:09	1:41	LINE CLEAR AVAILED
129	11-Aug-21	BAGALKOT	110	110/11KV, HV2 (HV4)	STATION NOT AFFECTED SADALAGA_110	9:17	12:28	3:11	TRANSFORMER FAULT
130	11-Aug-21	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED SAVALAGI_110	11:53	12:22	0:29	TRANSFORMER FAULT
131	11-Aug-21	BAGALKOT	110	110/11KV,HV1	AKSHAYA COLONY_110	16:52	18:27	1:35	LINE CLEAR AVAILED
132	11-Aug-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
133	11-Aug-21	BAGALKOT	110	110/33KV, HV3	KATAGERI_33, GADDANKERI_33 STATION NOT AFFECTED BAGALKOT_220	13:40	15:28	1:48	LINE CLEAR AVAILED
134	11-Aug-21	BAGALKOT	110	110/33KV, HV3	DEVARGENNUR_33, LINGADALLI LIS_33 STATION NOT AFFECTED MAMADAPUR(B)_110	7:11	7:23	0:12	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
135	11-Aug-21	BAGALKOT	110	110/33KV, HV3	BATAKURKI_33, RSSKN_33 STATION NOT AFFECTED LOKAPUR_110	12:00	12:10	0:10	TRANSFORMER FAULT
136	11-Aug-21	BAGALKOT	110	110/33KV, HV4	DHULKED_33, NEVARGI_33, ALSANGI_33 STATION NOT AFFECTED ZALKI_110	22:35	22:40	0:05	TRANSFORMER FAULT
137	11-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR (RFE)	ALBAL_110	8:16	9:59	1:43	LINE CLEAR AVAILED
138	11-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR (RFE)	STATION NOT AFFECTED ALBAL_110	16:00	18:37	2:37	LINE CLEAR AVAILED
139	11-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS(SPRS)	ALBAL_110	8:16	9:59	1:43	LINE CLEAR AVAILED
140	11-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS(SPRS)	ALBAL_110	16:00	18:37	2:37	LINE CLEAR AVAILED
141	11-Aug-21	BAGALKOT	110	AMBEWADI- SUPA1	STATION NOT AFFECTED AMBEWADI_220	11:13	17:17	6:04	LINE CLEAR AVAILED
142	11-Aug-21	BAGALKOT	110	AMBEWADI- SUPA2	STATION NOT AFFECTED AMBEWADI_220	11:38	12:12	0:34	LINE FAULT
143	11-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
144	11-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
145	11-Aug-21	BAGALKOT	110	BAGALKOT220- NAVANAGAR(B)2	STATION NOT AFFECTED NAVANAGAR(B)_110	13:14	18:25	5:11	LINE CLEAR AVAILED
146	11-Aug-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	6:58	7:08	0:10	LINE FAULT
147	11-Aug-21	BAGALKOT	110	BELGAUM220-ANKALAGI	ANKALAGI_110	6:43	6:58	0:15	LINE FAULT
148	11-Aug-21	BAGALKOT	110	BELGAUM220-HUDLI	HUDLI_110	6:43	7:08	0:25	HAND TRIPPED
149	11-Aug-21	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	10:03	16:29	6:26	NFBC ISSUED
150	11-Aug-21	BAGALKOT	110	BIDNAL-GADAG ROAD	STATION NOT AFFECTED GADAG ROAD_110	10:07	16:05	5:58	LINE CLEAR AVAILED
151	11-Aug-21	BAGALKOT	110	GADAG ROAD-BIDNAL220	GADAG ROAD_110	9:45	18:15	8:30	LINE CLEAR AVAILED
152	11-Aug-21	BAGALKOT	110	GADAG ROAD-SWRLY	GADAG ROAD_110 SWRLY_110	10:05	18:16	8:11	LINE CLEAR AVAILED
153	11-Aug-21	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_110	5:52	6:30	0:38	LINE FAULT
154	11-Aug-21	BAGALKOT	110	GOPANAKOPPA-GADAG ROAD	STATION NOT AFFECTED GOPANAKOPPA_110	9:41	17:33	7:52	NFBC ISSUED
155	11-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
156	11-Aug-21	BAGALKOT	110	KARWAR220-ARGA	STATION NOT AFFECTED KARWAR_220	20:41 (11.08.2021)			LINE OPEN:LINE FAULT
157	11-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN :LINE CLEAR AVAILED
158	11-Aug-21	BAGALKOT	110	PG HUNSHYAL-SATISH SUGARS	SATISH SUGARS STATION NOT AFFECTED PG HUNSHYAL_110	9:15 (07.08.2021)	12:42 (11.08.2021)	3:27	LINE CLEAR AVAILED
159	11-Aug-21	BAGALKOT	110	RANEBENNUR- BYADAGI	BYADAGI_110	15:42 (10.08.2021)			LINE OPEN :LINE CLEAR AVAILED
160	11-Aug-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
161	11-Aug-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN :LINE CLEAR AVAILED
162	11-Aug-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN :LINE CLEAR AVAILED
163	11-Aug-21	BAGALKOT	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	KD JAMBAGI_110	15:26	16:30	1:04	LINE CLEAR AVAILED
164	11-Aug-21	BAGALKOT	220	ALAMATTI1- BAGALKOT	STATION NOT AFFECTED BAGALKOT_220	12:33	16:20	3:47	LINE CLEAR AVAILED
165	11-Aug-21	BAGALKOT	220	ALAMATTI2- BAGALKOT	STATION NOT AFFECTED BAGALKOT_220	12:34	16:20	3:46	LINE CLEAR AVAILED
166	11-Aug-21	BAGALKOT	220	AMBEWADI- NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	10:34	11:32	0:58	LINE FAULT
167	11-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
168	11-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
169	11-Aug-21	BAGALKOT	220	GUTTURI1- HAVERI	STATION NOT AFFECTED HAVERI_220	11:31	16:01	4:30	LINE CLEAR AVAILED
170	11-Aug-21	BAGALKOT	220	GUTTURI2- HAVERI	HAVERI_220	20:19 (09.08.2021)	16:08 (11.08.2021)	19:49	LINE CHARGED
171	11-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
172	11-Aug-21	BAGALKOT	220	MUGALKHOD-CHIKKODI2	STATION NOT AFFECTED MUGALKHOD_220	10:50	15:55	5:05	NFBC ISSUED
173	11-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
174	11-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
175	11-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
176	11-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
177	11-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
178	11-Aug-21	BAGALKOT	400	DHONI-GUDDADAHALLI	STATION NOT AFFECTED DHONI_400	10:52	15:13	4:21	LINE CLEAR AVAILED
179	11-Aug-21	BAGALKOT	400	DHONI-GUTTURI	STATION NOT AFFECTED DHONI_400	10:52	15:13	4:21	LINE CLEAR AVAILED
180	11-Aug-21	BANGALORE	66	ANCHEPALYA 220 - AGALAKOTE	AGALAKOTE, MATHIKERE 66	16:25	17:20	0:55	MAIN SUPPLY FAILURE
181	11-Aug-21	BANGALORE	66	ANCHEPALYA 220 - HOSPALYA CIRCLE	HOSPALYA CIRCLE	16:25	17:20	0:55	MAIN SUPPLY FAILURE
182	11-Aug-21	BANGALORE	66	ANCHEPALYA 220 - MAGADI 66	MAGADI 66	16:25	17:20	0:55	MAIN SUPPLY FAILURE
183	11-Aug-21	BANGALORE	66	ANCHEPALYA 220 - T G HALLI	T G HALLI	16:25	17:20	0:55	MAIN SUPPLY FAILURE
184	11-Aug-21	BANGALORE	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	20:31	20:35	0:04	LOAD CHANGE OVER
185	11-Aug-21	BANGALORE	66	HV1	KEMPANAHALLI	14:50	15:00	0:10	TRANSFORMER FAULT
186	11-Aug-21	BANGALORE	66	HV2	BG ROAD	11:30	11:32	0:02	LINE CLEAR AVAILED
187	11-Aug-21	BANGALORE	66	HV2	HOODY 220	10:50	11:55	1:05	LINE CLEAR AVAILED
188	11-Aug-21	BANGALORE	66	HV2	KUMBALAGODU	16:02	17:18	1:16	LINE CLEAR AVAILED
189	11-Aug-21	BANGALORE	66	HV2	TK HALLI 220	2:00	2:09	0:09	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
190	11-Aug-21	BANGALORE	66	HV2	TYMAGONDLU	17:19	17:40	0:20	TRANSFORMER FAULT
191	11-Aug-21	BANGALORE	66	L R BANDE - HBR LAYOUT	L R BANDE	13:36	13:40	0:04	LOAD CHANGE OVER
192	11-Aug-21	BANGALORE	66	L R BANDE - HEBBALA 220	L R BANDE	11:51	12:00	0:09	LOAD CHANGE OVER
193	11-Aug-21	BANGALORE	66	MARALWADI - GODURU	GODURU	11:00	11:25	0:25	LINE CLEAR AVAILED
194	11-Aug-21	BANGALORE	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	10:00	16:38	6:38	LINE CLEAR AVAILED
195	11-Aug-21	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	10:18	18:24	8:06	LINE CLEAR AVAILED
196	11-Aug-21	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	8:18	8:59	0:41	LINE FAULT
197	11-Aug-21	BANGALORE	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
198	11-Aug-21	BANGALORE	220	HV2	SUBRAMANYAPURA 220	20:05:00(10/08/2021)	14:24(11/08/2021)	18:19HRS	TRANSFORMER CHARGED
199	11-Aug-21	GULBARGA	66	KUDLIGI-CHORNOOR	CHORNOOR_66	5:55	6:40	0:45	LINE FAULT
200	11-Aug-21	GULBARGA	110	BYAGAWAT-ACME SOLAR	BYAGAWAT_110	19:14(10.08.2021)	3:40(11.08.2021)	9:10 hrs	LINE CHARGED
201	11-Aug-21	GULBARGA	110	CHINCHOLI_CHETENAD	CHINCHOLI_110	12:45	12:50	0:05	LINE FAULT
202	11-Aug-21	GULBARGA	110	CHINCHOLI_MANAIKHELLI	CHINCHOLI_110	12:45	12:50	0:05	LINE FAULT
203	11-Aug-21	GULBARGA	110	CHINCHOLI_RENEW SOLAR	CHINCHOLI_110	12:45	12:50	0:05	LINE FAULT
204	11-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
205	11-Aug-21	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	5:40	5:48	0:08	LINE FAULT
206	11-Aug-21	GULBARGA	110	HANASI_KUDLIGI	HANASI_110	9:20	9:30	0:10	LINE FAULT
207	11-Aug-21	GULBARGA	110	HANASI_KUDLIGI	HANASI_110	10:20	10:30	0:10	LINE FAULT
208	11-Aug-21	GULBARGA	110	HV1	CHINCHOLI_110	19:28(06.07.2021)	16:28(11.08.2021)	861:00 HRS	TRANSFORMER IS CHARGED. TRIPPED ON BUCHCHOLZ RELAY,DIFFERENTIAL,MTR AT 23:45 LC ISSUED,LC NO M859 TO RT STAFF STILL OPEN. HV1 LOAD SHIFTED TO HV3,TRANSFORMER LOAD NOT EFFECTED AT 18:05 ON 14.07.2021 HV1 IDLE CHARGED, ON DATED 11.08.2021 HV1 CHARGED WITH LOAD AT 16:28 HRS
209	11-Aug-21	GULBARGA	110	HV1	SHAHAPUR_220	14:20	18:55	4:35	LINE CLEAR AVAILED
210	11-Aug-21	GULBARGA	110	HV1	CHINCHOLI_110	12:45	12:55	0:10	TRANSFORMER FAULT
211	11-Aug-21	GULBARGA	110	HV2	HANASI_110	11:00	11:15	0:15	TRANSFORMER FAULT
212	11-Aug-21	GULBARGA	110	HV3	GULBARGA UNIVERSITY_110	13:20	13:30	0:10	LINE CLEAR AVAILED
213	11-Aug-21	GULBARGA	110	HV3,HV4	YELBURGA_110	13:00	14:50	1:50	LINE CLEAR AVAILED
214	11-Aug-21	GULBARGA	110	JANWADA_SANTHPUR	JANWADA_110	6:30	8:50	2:20	LINE CLEAR AVAILED
215	11-Aug-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	14:52	15:23	0:31	LINE CLEAR AVAILED
216	11-Aug-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110-MANVI_110	9:35	18:20	8:45	LINE CLEAR AVAILED
217	11-Aug-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110-MANVI_110	23:05	23:15	0:10	LINE FAULT
218	11-Aug-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:43	20:53	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
219	11-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:14	2:19	0:05	LINE FAULT
220	11-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:04	22:14	0:10	LINE FAULT
221	11-Aug-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	9:09	19:19	10:10	LINE CLEAR AVAILED
222	11-Aug-21	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	1:18	2:34	1:16	LINE FAULT
223	11-Aug-21	GULBARGA	220	BTPSG-LINGAPUR	LINGAPUR_220	1:18	2:40	1:22	LINE FAULT
224	11-Aug-21	GULBARGA	220	LINGAPUR-GUDHALLI2	GDHALLI_220,DHRUVADESH_IPP	11:12	20:39	9:27	LINE CLEAR AVAILED
225	11-Aug-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	10:45	11:13	0:28	HAND TRIPPED
226	11-Aug-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	13:28	13:33	0:05	HAND TRIPPED
227	11-Aug-21	HASSAN	66	HASSN22-HN PURA	HASSAN_220	11:13	13:33	2:20	LINE CLEAR AVAILED
228	11-Aug-21	HASSAN	66	HASSN22-MALLALI	HASSAN_220	11:13	13:33	2:20	LINE CLEAR AVAILED
229	11-Aug-21	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	18:43	18:56	0:13	LINE FAULT
230	11-Aug-21	HASSAN	66	HASSN22-SKPURA	HASSAN_220	10:45	11:00	0:15	HAND TRIPPED
231	11-Aug-21	HASSAN	66	HASSN22-SKPURA	HASSAN_220	13:28	13:33	0:05	HAND TRIPPED
232	11-Aug-21	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	16:55	17:22	0:27	LINE FAULT
233	11-Aug-21	HASSAN	66	HV1	CHANNARAYAPATNA_66	11:11	15:27	4:16	LINE CLEAR AVAILED
234	11-Aug-21	HASSAN	66	HV1	MAGGE_66	10:50	11:03	0:13	MAIN SUPPLY FAILURE
235	11-Aug-21	HASSAN	66	HV1	MAGGE_66	13:28	13:38	0:10	MAIN SUPPLY FAILURE
236	11-Aug-21	HASSAN	66	HV1	MALALI_66	9:42	13:01	3:19	LINE CLEAR AVAILED
237	11-Aug-21	HASSAN	66	HV1	SALAGAME_66	10:33	11:32	0:59	LINE CLEAR AVAILED
238	11-Aug-21	HASSAN	66	HV1	SALAGAME_66	11:51	13:20	1:29	TRANSFORMER FAULT
239	11-Aug-21	HASSAN	66	HV1	SOMANAHALLI_66	16:20	16:53	0:33	LINE CLEAR AVAILED
240	11-Aug-21	HASSAN	66	HV2	HALLIMYSORE_66	12:05	18:14	6:09	LINE CLEAR AVAILED
241	11-Aug-21	HASSAN	66	HV2	MAGGE_66	10:50	13:38	2:48	MAIN SUPPLY FAILURE
242	11-Aug-21	HASSAN	66	HV2	MAGGE_66	13:28	13:38	0:10	MAIN SUPPLY FAILURE
243	11-Aug-21	HASSAN	66	HV2	MAGGE_66	15:45	17:01	1:16	LINE CLEAR AVAILED
244	11-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN :LINE CLEAR AVAILED
245	11-Aug-21	HASSAN	66	LV1	HASSAN_220	11:15	13:13	1:58	LINE CLEAR AVAILED
246	11-Aug-21	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	18:41	20:10	1:29	LINE FAULT
247	11-Aug-21	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	18:43	19:25	0:42	LINE FAULT
248	11-Aug-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	10:46	11:01	0:15	MAIN SUPPLY FAILURE
249	11-Aug-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	13:30	13:35	0:05	MAIN SUPPLY FAILURE
250	11-Aug-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	10:46	11:01	0:15	MAIN SUPPLY FAILURE
251	11-Aug-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	13:30	13:35	0:05	MAIN SUPPLY FAILURE
252	11-Aug-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	19:28	20:58	1:30	MAIN SUPPLY FAILURE
253	11-Aug-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	9:25	9:37	0:12	LINE FAULT
254	11-Aug-21	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPLU_66	16:55	19:15	2:20	LINE FAULT
255	11-Aug-21	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPLU_66	17:20	17:59	0:39	HAND TRIPPED
256	11-Aug-21	HASSAN	66	UDDURKO-UDDUR	UDDURKOPLU_66	16:55	17:24	0:29	LINE FAULT
257	11-Aug-21	HASSAN	110	ANAVATRI-BARNGI	ANAVATTI_110	10:55	12:05	1:10	LINE CLEAR AVAILED
258	11-Aug-21	HASSAN	110	ARK2-ARSKR	ARASIKERE_220	18:43	19:20	0:37	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
259	11-Aug-21	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	12:09	13:10	1:01	LINE CLEAR AVAILED
260	11-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
261	11-Aug-21	HASSAN	110	HV1	SORABA_110	14:47	14:56	0:09	LINE CLEAR AVAILED
262	11-Aug-21	HASSAN	110	HV2	BANAVARA_110	16:42	19:15	2:33	MAIN SUPPLY FAILURE
263	11-Aug-21	HASSAN	110	HV2	HOSANGADI_110	14:17	15:25	1:08	LINE CLEAR AVAILED
264	11-Aug-21	HASSAN	110	HV2	KADUR_220	18:44	18:53	0:09	TRANSFORMER FAULT
265	11-Aug-21	HASSAN	110	HV3	KAVOOR_220	9:22	14:53	5:31	LINE CLEAR AVAILED
266	11-Aug-21	HASSAN	110	KADUR-NGNHL	KADUR_220	18:44	20:05	1:21	LINE FAULT
267	11-Aug-21	HASSAN	110	KADUR-TNGL	KADUR_220	18:44	19:54	1:10	LINE FAULT
268	11-Aug-21	HASSAN	110	KADUR-YGTI	KADUR_220	18:44	19:54	1:10	LINE FAULT
269	11-Aug-21	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	22:07	23:01	0:54	LINE CLEAR AVAILED
270	11-Aug-21	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	22:52 (10.08.2021)	1:15(11.8.2021)	2:21 hrs	LINE CHARGED
271	11-Aug-21	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	11:10	17:01	5:51	LINE CLEAR AVAILED
272	11-Aug-21	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	12:15	16:59	4:44	LINE CLEAR AVAILED
273	11-Aug-21	HASSAN	220	HV1	HASSAN_220	11:15	13:12	1:57	LINE CLEAR AVAILED
274	11-Aug-21	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	15:06	17:16	2:10	LINE CLEAR AVAILED
275	11-Aug-21	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	15:06	17:16	2:10	LINE CLEAR AVAILED
276	11-Aug-21	MYSORE	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66 ARAKALAVADI_66	11:28	13:52	2:23	LINE CLEAR AVAILED
277	11-Aug-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	11:43	11:45	0:01	HAND TRIPPED
278	11-Aug-21	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR_66	19:25	19:34	0:09	LINE FAULT
279	11-Aug-21	MYSORE	66	CR NAGARA-YALANDUR	NO STATIONS EFFECTED	19:38	22:41	3:03	LINE FAULT
280	11-Aug-21	MYSORE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	12:32	14:30	1:58	LINE CLEAR AVAILED
281	11-Aug-21	MYSORE	66	DUNDANALLI-HULIYURDURGA	NO STATIONS EFFECTED	15:49	17:21	1:31	LINE CLEAR AVAILED
282	11-Aug-21	MYSORE	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
283	11-Aug-21	MYSORE	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
284	11-Aug-21	MYSORE	66	HV1	HEBBAL_66	11:07	12:08	1:01	LINE CLEAR AVAILED
285	11-Aug-21	MYSORE	66	HV2	HEBBAL_66	12:14	13:27	1:13	LINE CLEAR AVAILED
286	11-Aug-21	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 K_HONNALGERE_66 SOMANAHALLI_66	8:48	10:15	1:27	LINE FAULT
287	11-Aug-21	MYSORE	66	KIADB MANDYA-TK HALLY	KIADBMANDYA_66 MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66	8:30	8:47	0:16	LINE FAULT
288	11-Aug-21	MYSORE	66	MADHUVANALLI-KUNTUR	NO STATIONS EFFECTED	18:08	18:14	0:05	LINE FAULT
289	11-Aug-21	MYSORE	66	MADHUVANALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	6:04	6:15	0:11	LINE FAULT
290	11-Aug-21	MYSORE	66	MADHUVANALLI-MAMBALLI	MAMBALLI_66	11:05	17:10	6:05	NFBC ISSUED
291	11-Aug-21	MYSORE	66	TALAKADU-ADANI	NO STATIONS EFFECTED	18:34	19:46	1:11	LINE CLEAR AVAILED
292	11-Aug-21	MYSORE	66	TUBINKERE-GUKKADA	SRIRANGAPATNA_66 GARUDANAUKADDA_66	15:17	15:29	0:11	LINE FAULT
293	11-Aug-21	MYSORE	66	VAJMANGALA-KADKOLA 2	NO STATIONS EFFECTED	18:48	18:52	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
294	11-Aug-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	15:09	16:11	1:01	LINE CLEAR AVAILED
295	11-Aug-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	16:51	16:53	0:01	HAND TRIPPED
296	11-Aug-21	TUMKUR	66	ANCHEPALYA 220- HEBBUR	SIRA_66, KALLAMBELLA_66	17:03	17:40	0:37	LINE CLEAR AVAILED
297	11-Aug-21	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	13:09	13:52	0:42	LINE CLEAR AVAILED
298	11-Aug-21	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	15:37	16:50	1:13	LINE CLEAR AVAILED
299	11-Aug-21	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	14:42	15:36	0:54	LINE CLEAR AVAILED
300	11-Aug-21	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	12:07	13:02	0:55	LINE CLEAR AVAILED
301	11-Aug-21	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	17:04	17:40	0:36	LINE CLEAR AVAILED
302	11-Aug-21	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	VIJAYA STEEL	11:43	12:14	0:30	LINE CLEAR AVAILED
303	11-Aug-21	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	13:20	14:30	1:10	LINE CLEAR AVAILED
304	11-Aug-21	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	13:25	17:56	4:30	MAIN SUPPLY FAILURE
305	11-Aug-21	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	6:57	7:00	0:02	LINE FAULT
306	11-Aug-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:06	18:32	0:26	LINE FAULT
307	11-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	11:46	11:56	0:09	LINE FAULT
308	11-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	18:06	18:17	0:11	LINE FAULT
309	11-Aug-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	12:34	13:56	1:22	LINE CLEAR AVAILED
310	11-Aug-21	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	6:57	7:08	0:11	LINE FAULT
311	11-Aug-21	TUMKUR	66	KANCHIPURA-MATHOD 66	KANCHIPURA_66	15:25	16:17	0:51	MAIN SUPPLY FAILURE
312	11-Aug-21	TUMKUR	66	TR-1	BADDIHALLI_66	10:10:36 AM(11.8.21)			TRANSFORMER OPEN :LINE CLEAR AVAILED
313	11-Aug-21	TUMKUR	66	TR-1	PATNAYAKANAHALLI_66	12:41	13:39	0:58	LINE CLEAR AVAILED
314	11-Aug-21	TUMKUR	66	TR-1	YADVANI_66	13:13	14:00	0:47	MAIN SUPPLY FAILURE
315	11-Aug-21	TUMKUR	66	TR-2	BELLAVI_66	13:25	17:57	4:32	LINE CLEAR AVAILED
316	11-Aug-21	TUMKUR	66	TR-2	HIREGUNTANUR_66	7:58	8:26	0:27	LINE CLEAR AVAILED
317	11-Aug-21	TUMKUR	66	TR-2	PATNAYAKANAHALLI_66	12:41	13:40	0:58	LINE CLEAR AVAILED
318	11-Aug-21	TUMKUR	66	TR-2	SANIKERE_66	13:05	13:17	0:11	TRANSFORMER FAULT
319	11-Aug-21	TUMKUR	66	TR-2	YADVANI_66	13:13	14:00	0:47	MAIN SUPPLY FAILURE
320	11-Aug-21	TUMKUR	66	YADAVANI-ANCHEPALYA	YADAVANI_66	13:13	14:00	0:47	MAIN SUPPLY FAILURE
321	11-Aug-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:45	14:31	2:46	LINE CLEAR AVAILED
322	11-Aug-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	14:32	16:20	1:47	LINE CLEAR AVAILED
323	11-Aug-21	TUMKUR	110	TR-1(LV-SIDE)	NITTUR_220	10:36	15:33	4:57	LINE CLEAR AVAILED
324	11-Aug-21	TUMKUR	110	TR-2(LV-2)	NITTUR_220	15:34	19:07	3:32	LINE CLEAR AVAILED
325	11-Aug-21	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	10:47	16:08	5:21	LINE CLEAR AVAILED
326	11-Aug-21	TUMKUR	220	TR-1	NITTUR_220	10:36	15:33	4:57	LINE CLEAR AVAILED
327	11-Aug-21	TUMKUR	220	TR-2	NITTUR_220	15:34	19:06	3:32	LINE CLEAR AVAILED
328	11-Aug-21	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	9:44	15:17	5:33	LINE CLEAR AVAILED
329	12-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
330	12-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
331	12-Aug-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NAVALGUND_110	17:37	17:57	0:20	LINE CLEAR AVAILED
332	12-Aug-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
333	12-Aug-21	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED CHIKKODI_220	16:19	22:56	6:37	LINE CLEAR AVAILED
334	12-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
335	12-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
336	12-Aug-21	BAGALKOT	110	BAGEWADI220-MAMDAPUR1	MAMDAPUR_110	10:00	10:07	0:07	LINE FAULT
337	12-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
338	12-Aug-21	BAGALKOT	110	KARWAR220-ARGA	STATION NOT AFFECTED KARWAR_220	20:41 (11.08.2021)	13:40 (12.08.2021)	17:02	LINE CHARGED
339	12-Aug-21	BAGALKOT	110	MUGALKHOD220-RAIBAG1	RAIBAG_110	18:07	21:15	3:08	LINE FAULT
340	12-Aug-21	BAGALKOT	110	MUGALKHOD220-RAIBAG2	RAIBAG_110	18:07	21:16	3:09	LINE FAULT
341	12-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN :LINE CLEAR AVAILED
342	12-Aug-21	BAGALKOT	110	RAIBAG-MUGALKHOD220-1(ITNAL)	RAIBAG_110	19:30	20:57	1:27	LINE CLEAR AVAILED
343	12-Aug-21	BAGALKOT	110	RAIBAG-MUGALKHOD220-2(ITNAL)	RAIBAG_110	19:30	21:18	1:48	LINE CLEAR AVAILED
344	12-Aug-21	BAGALKOT	110	RANEBENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI_110	15:42 (10.08.2021)			LINE OPEN :LINE CLEAR AVAILED
345	12-Aug-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
346	12-Aug-21	BAGALKOT	110	SRSHUBLI-RAMANKOPPA	STATION NOT AFFECTED RAMANAKOPPA_110	5:53	12:17	6:24	LINE FAULT
347	12-Aug-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL_110	17:00 (19.07.2021)			LINE OPEN :LINE CLEAR AVAILED
348	12-Aug-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL_110	16:59 (19.07.2021)			LINE OPEN :LINE CLEAR AVAILED
349	12-Aug-21	BAGALKOT	110	UTTUR-F2 YWD (YADWAD_110)	YADWAD_110	6:03	6:24	0:21	LINE FAULT
350	12-Aug-21	BAGALKOT	110	YADWAD-ISEL (IZRA)	YADWAD_110,IZRA_SOLAR	6:02	6:28	0:26	MAIN SUPPLY FAILURE
351	12-Aug-21	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED CHIKKODI_220	16:19	22:55	6:36	LINE CLEAR AVAILED
352	12-Aug-21	BAGALKOT	220	AMBEWADI-NAGJHARI2	AMBEWADI_220	12:13	12:31	0:18	LINE FAULT
353	12-Aug-21	BAGALKOT	220	BAGEWADI-RBRK WIND	RBRK WIND_220 STATION NOT AFFECTED BAGEWADI_220	11:22	11:47	0:25	LINE FAULT
354	12-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
355	12-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
356	12-Aug-21	BAGALKOT	220	CHIKKODI-KUDACHI2(GHATAPRABHA2)	STATION NOT AFFECTED CHIKKODI_220	21:07	21:28	0:21	LINE FAULT
357	12-Aug-21	BAGALKOT	220	KUDACHI-ATHANI	STATION NOT AFFECTED KUDACHI_220	10:35	13:12	2:37	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
358	12-Aug-21	BAGALKOT	220	KUDACHI-CHIKKODI2	STATION NOT AFFECTED KUDACHI_220	21:07	21:31	0:24	LINE FAULT
359	12-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
360	12-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
361	12-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
362	12-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
363	12-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
364	12-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
365	12-Aug-21	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	10:13	10:20	0:07	MAIN SUPPLY FAILURE
366	12-Aug-21	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	17:52	17:57	0:05	LINE CLEAR AVAILED
367	12-Aug-21	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	10:13	17:49	7:36	MAIN SUPPLY FAILURE
368	12-Aug-21	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:13	10:20	0:07	MAIN SUPPLY FAILURE
369	12-Aug-21	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:52	18:05	0:13	LINE CLEAR AVAILED
370	12-Aug-21	BANGALORE	66	EPIP 220 - ITC(EHT)	ITC(EHT)	12:07	13:05	0:58	LINE CLEAR AVAILED
371	12-Aug-21	BANGALORE	66	HV1	VRISHABHAVATHI 220	10:51	10:59	0:08	LINE CLEAR AVAILED
372	12-Aug-21	BANGALORE	66	HV1	DALASNUR	12:45	13:14	0:29	LINE CLEAR AVAILED
373	12-Aug-21	BANGALORE	66	HV1	BAIRAKURU	10:57	11:01	0:04	TRANSFORMER FAULT
374	12-Aug-21	BANGALORE	66	HV1	MAASTI	9:50	10:25	0:35	LINE CLEAR AVAILED
375	12-Aug-21	BANGALORE	66	HV1	MAASTI	11:05	11:15	0:10	LINE CLEAR AVAILED
376	12-Aug-21	BANGALORE	66	HV2	VRISHABHAVATHI 220	13:48	13:52	0:04	LINE CLEAR AVAILED
377	12-Aug-21	BANGALORE	66	HV2	TEMAGONDALU	10:17	11:29	1:12	LINE CLEAR AVAILED
378	12-Aug-21	BANGALORE	66	HV2	MAASTI	11:45	13:30	1:45	LINE CLEAR AVAILED
379	12-Aug-21	BANGALORE	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	21:42	22:21	0:39	MAIN SUPPLY FAILURE
380	12-Aug-21	BANGALORE	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:42	22:21	0:39	MAIN SUPPLY FAILURE
381	12-Aug-21	BANGALORE	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	21:42	22:20	0:38	MAIN SUPPLY FAILURE
382	12-Aug-21	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	21:42	22:20	0:38	MAIN SUPPLY FAILURE
383	12-Aug-21	BANGALORE	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	21:42	22:20	0:38	MAIN SUPPLY FAILURE
384	12-Aug-21	BANGALORE	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	21:42	22:20	0:38	MAIN SUPPLY FAILURE
385	12-Aug-21	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:42	22:20	0:38	MAIN SUPPLY FAILURE
386	12-Aug-21	BANGALORE	66	MALUR 220 - HOSKOTE 1	VOKKALERI	5:44	6:00	0:15	LINE FAULT
387	12-Aug-21	BANGALORE	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	0:59	1:23	0:23	LINE FAULT
388	12-Aug-21	BANGALORE	66	SM MANGALA - CHINTAMANI 220	SM MANGALA, SUGUTUR	10:59	12:05	1:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
389	12-Aug-21	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	18:33	18:46	0:13	LINE CLEAR AVAILED
390	12-Aug-21	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	18:33	18:46	0:13	LINE CLEAR AVAILED
391	12-Aug-21	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	10:48	17:36	6:48	LINE CLEAR AVAILED
392	12-Aug-21	BANGALORE	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:33	18:46	0:13	LINE CLEAR AVAILED
393	12-Aug-21	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	18:33	18:46	0:13	LINE CLEAR AVAILED
394	12-Aug-21	BANGALORE	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
395	12-Aug-21	BANGALORE	220	HV1	KOLAR 220	21:43	22:19	0:36	LINE CLEAR AVAILED
396	12-Aug-21	BANGALORE	220	HV2	DB PURA 220	10:14	16:23	6:09	LINE CLEAR AVAILED
397	12-Aug-21	BANGALORE	220	LV2	TK HALLI 220	18:33	18:46	0:13	TRANSFORMER FAULT
398	12-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
399	12-Aug-21	GULBARGA	110	HV2	SHAHAPUR_220	12:09	17:08	4:59	LINE CLEAR AVAILED
400	12-Aug-21	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	4:00	4:10	0:10	LINE FAULT
401	12-Aug-21	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	4:30	5:26	0:56	LINE FAULT
402	12-Aug-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	10:45	11:05	0:20	MAIN SUPPLY FAILURE
403	12-Aug-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADA GERA_110,SANNATHI_IPP,COREGREENS UGARS_IPP	10:10	17:10	7:00	LINE CLEAR AVAILED
404	12-Aug-21	GULBARGA	110	SHAHAPUR-RAICHUR1&2	GABUR_110, DEODURGA_110	10:10	13:08	2:58	NFBC ISSUED
405	12-Aug-21	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	11:58	15:22	3:24	LINE CLEAR AVAILED
406	12-Aug-21	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWAR	ADAVI AMARESHWAR_110	5:45	5:55	0:10	LINE FAULT
407	12-Aug-21	GULBARGA	110	YELBURGA-PRPJSLR	YELBURGA_110	21:41	21:56	0:15	LINE FAULT
408	12-Aug-21	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
409	12-Aug-21	GULBARGA	220	HV1	SHAHAPUR_220	12:09	17:05	4:56	LINE CLEAR AVAILED
410	12-Aug-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
411	12-Aug-21	GULBARGA	220	HV2	SEDAM_220	17:25	22:20	4:55	LINE CLEAR AVAILED
412	12-Aug-21	GULBARGA	220	MALLAT-LINGASUGUR	LINGASUGUR_220	3:29	5:11	1:42	LINE FAULT
413	12-Aug-21	GULBARGA	220	MALLAT-LINGASUGUR	LINGASUGUR_220	5:11	11:03	5:52	LINE CLEAR AVAILED
414	12-Aug-21	GULBARGA	220	SEDAM-RTPS2	RTPS_220	13:33	13:44	0:11	LOAD CHANGE OVER
415	12-Aug-21	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	14:58(12.08.2021)			LINE OPEN :LINE CLEAR AVAILED
416	12-Aug-21	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:07	15:13	4:06	LINE CLEAR AVAILED
417	12-Aug-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	14:38	14:43	0:05	LINE FAULT
418	12-Aug-21	HASSAN	66	HV1	SAKLESH PURA_66	14:43	16:22	1:39	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
419	12-Aug-21	HASSAN	66	HV2	HALLYMYSORE_66	9:22	18:44	9:22	LINE CLEAR AVAILED
420	12-Aug-21	HASSAN	66	HV2	MAGGE_66	11:50	14:10	2:20	LINE CLEAR AVAILED
421	12-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN :LINE CLEAR AVAILED
422	12-Aug-21	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	14:39	15:04	0:25	LINE FAULT
423	12-Aug-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	14:42	15:55	1:13	LINE FAULT
424	12-Aug-21	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	14:42	16:28	1:46	LINE CLEAR AVAILED
425	12-Aug-21	HASSAN	66	SAKALE-HASSAN	SAKLESHPUA_66	14:43	16:22	1:39	LINE CLEAR AVAILED
426	12-Aug-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	14:43	16:24	1:41	LINE CLEAR AVAILED
427	12-Aug-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	14:43	16:24	1:41	LINE CLEAR AVAILED
428	12-Aug-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	12:11	12:17	0:06	LINE FAULT
429	12-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
430	12-Aug-21	HASSAN	110	HV1	SORABA_110	9:45	20:22	10:37	LINE CLEAR AVAILED
431	12-Aug-21	HASSAN	110	HV2	BAIKAMPADY_110	13:40	14:38	0:58	HAND TRIPPED
432	12-Aug-21	HASSAN	110	HV2	SAGARA_110	12:18	13:58	1:40	LINE CLEAR AVAILED
433	12-Aug-21	HASSAN	110	LV2	SHIRALKOPPA_220	12:14	14:05	1:51	LINE CLEAR AVAILED
434	12-Aug-21	HASSAN	110	LV2	SHIRALKOPPA_220	15:04	16:18	1:14	LINE CLEAR AVAILED
435	12-Aug-21	HASSAN	110	MRSSHM-MPM	MRSMSG_220	12:59	13:50	0:51	HAND TRIPPED
436	12-Aug-21	HASSAN	110	MSEZ-GSS41	MSEZ_220	10:48	15:21	4:33	LINE CLEAR AVAILED
437	12-Aug-21	HASSAN	110	MSEZ-GSS42	MSEZ_220	10:48	15:21	4:33	LINE CLEAR AVAILED
438	12-Aug-21	HASSAN	110	SHIRAL-SANDA	SHIRALKOPPA_110	9:21	14:12	4:51	LINE FAULT
439	12-Aug-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	3:28	12:25	8:57	LINE FAULT
440	12-Aug-21	HASSAN	220	HV2	SHIRALKOPPA_220	12:16	14:04	1:48	LINE CLEAR AVAILED
441	12-Aug-21	HASSAN	220	HV2	SHIRALKOPPA_220	15:05	16:17	1:12	LINE CLEAR AVAILED
442	12-Aug-21	HASSAN	220	TALAGU-STRP2	TALAGUPP_400	3:28	12:24	8:56	LINE FAULT
443	12-Aug-21	MYSORE	66	AKKIHEBBAL-KR PETE2	KRPET_66	17:01	17:46	0:45	HAND TRIPPED
444	12-Aug-21	MYSORE	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
445	12-Aug-21	MYSORE	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
446	12-Aug-21	MYSORE	66	HAMPAPURA-CHIKKMANDYA	CHIKKA_MANDYA_66	14:46	15:54	1:07	LINE CLEAR AVAILED
447	12-Aug-21	MYSORE	66	HV1	KIADBMANDYA_66	18:33	18:46	0:12	MAIN SUPPLY FAILURE
448	12-Aug-21	MYSORE	66	HV1	KRPET_66	10:01	18:30	8:28	LINE CLEAR AVAILED
449	12-Aug-21	MYSORE	66	HV2	KRPET_66	10:01	18:30	8:28	LINE CLEAR AVAILED
450	12-Aug-21	MYSORE	66	HV3	KRPET_66	10:01	18:30	8:28	LINE CLEAR AVAILED
451	12-Aug-21	MYSORE	66	KHB STATION-HOOTGALLY	NO STATIONS EFFECTED	10:40	12:29	1:49	NFBC ISSUED
452	12-Aug-21	MYSORE	66	KR PETE 220-KR PETE1	KRPET_66	16:44	17:22	0:38	HAND TRIPPED
453	12-Aug-21	MYSORE	66	TALAKADU-ADANI	NO STATIONS EFFECTED	3:05	3:30	0:24	LINE FAULT
454	12-Aug-21	MYSORE	66	TALAKADU-ADANI	NO STATIONS EFFECTED	20:10	22:43	2:32	LINE CLEAR AVAILED
455	12-Aug-21	TUMKUR	66	H D PURA- CHITRADURGA220	MMCLWINDMILL_IPP_66	7:40	7:50	0:10	LINE FAULT
456	12-Aug-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	1:52	2:05	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
457	12-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	1:52	2:00	0:07	LINE FAULT
458	12-Aug-21	TUMKUR	66	TR-1	BADDIHALI_66	10:10:36 AM(11.8.21)	16:25(12.8.21)	1day 6 hrs	LINE CLEAR AVAILED
459	12-Aug-21	TUMKUR	66	TR-1	BHARAMAGIRI_66	13:46	13:51	0:04	TRANSFORMER FAULT
460	12-Aug-21	TUMKUR	66	TR-1	HALURAMESWARA_66	16:46	17:20	0:33	LINE CLEAR AVAILED
461	12-Aug-21	TUMKUR	66	TR-1	RANGANATHAPURA_66	10:05	10:53	0:48	LINE CLEAR AVAILED
462	12-Aug-21	TUMKUR	66	TR-2	BHARAMAGIRI_66	10:10	11:01	0:51	LINE CLEAR AVAILED
463	12-Aug-21	TUMKUR	66	TR-2	DEVARABELKERE_66	22:27	22:32	0:05	TRANSFORMER FAULT
464	12-Aug-21	TUMKUR	66	TR-2	HALURAMESWARA_66	16:12	17:26	1:13	LINE CLEAR AVAILED
465	12-Aug-21	TUMKUR	220	TR-2	ANTHRASANAHALI_220	13:10	17:23	4:12	LINE CLEAR AVAILED
466	13-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
467	13-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
468	13-Aug-21	BAGALKOT	110	110/11KV,HV2	MUKARTHAL_110	6:46	7:04	0:18	LINE CLEAR AVAILED
469	13-Aug-21	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	7:21	7:38	0:17	HAND TRIPPED
470	13-Aug-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	11:06 (14.07.2021)	17:42 (13.08.2021)	6:36	LINE CLEAR AVAILED
471	13-Aug-21	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKHE D_33, STATON NOT AFFECTED ZALKI_110,	9:36	9:44	0:08	TRANSFORMER FAULT
472	13-Aug-21	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKHE D_33, STATON NOT AFFECTED ZALKI_110,	10:10	12:11	2:01	TRANSFORMER FAULT
473	13-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR(RFE)	RAYSOLAR_110, ALBAL_110	15:56	19:51	3:55	LINE CLEAR AVAILED
474	13-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	SAIPRIYA SUGARS_110, ALBAL_110	15:56	19:48	3:52	LINE CLEAR AVAILED
475	13-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
476	13-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
477	13-Aug-21	BAGALKOT	110	ANKOLA- KUMTA L2	STATION NOT AFFECTED ANKOLA_110	12:05	14:51	2:46	LINE FAULT
478	13-Aug-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR(B)_110	9:51	10:12	0:21	LINE FAULT
479	13-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
480	13-Aug-21	BAGALKOT	110	HALIYAL-ALNAVAR	ALNAVAR_110	5:17	5:38	0:21	LINE FAULT
481	13-Aug-21	BAGALKOT	110	HALIYAL-PYARI SUGARS(GMR)	PYARI SUGARS_110 STATION NOT AFFECTED HALIYAL_110	7:05	7:50	0:45	LINE CLEAR AVAILED
482	13-Aug-21	BAGALKOT	110	JAMAKHANDI-PRABHULINGESHWAR SUGARS	PRABHULINGESHWAR SUGARS_110 STATION NOT AFFECTED JAMAKHANDI_110	3:12	3:30	0:18	LINE FAULT
483	13-Aug-21	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAGHATTI_110	3:01	3:09	0:08	LINE FAULT
484	13-Aug-21	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	11:05 (08.08.2021)	14:33 (13.08.2021)	3:28	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
485	13-Aug-21	BAGALKOT	110	MK HUBLI220-BIDI1	BIDI_110	12:15	13:00	0:45	LINE CLEAR AVAILED
486	13-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B) 110	12:29 (14.06.2021)			LINE OPEN :LINE CLEAR AVAILED
487	13-Aug-21	BAGALKOT	110	RANEENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI 110	15:42 (10.08.2021)			LINE OPEN :LINE CLEAR AVAILED
488	13-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
489	13-Aug-21	BAGALKOT	110	SADALAGA-BORGAON	BORGAON_110	6:05	6:20	0:15	LINE CLEAR AVAILED
490	13-Aug-21	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	10:27	12:16	1:49	NFBC ISSUED
491	13-Aug-21	BAGALKOT	110	TARIHAL-HUBLI1	STATION NOT AFFECTED TARIHAL 110	17:00 (19.07.2021)	13:10 (13.08.2021)	20:10	LINE CHARGED
492	13-Aug-21	BAGALKOT	110	TARIHAL-HUBLI1	TARIHAL 110	13:23	20:07	6:44	LINE CLEAR AVAILED
493	13-Aug-21	BAGALKOT	110	TARIHAL-HUBLI2	STATION NOT AFFECTED TARIHAL 110	16:59 (19.07.2021)	13:40 (13.08.2021)	20:41	LINE CHARGED
494	13-Aug-21	BAGALKOT	110	TARIHAL-HUBLI2	TARIHAL 110	17:02	20:07	3:05	LINE CLEAR AVAILED
495	13-Aug-21	BAGALKOT	110	UGARKHUD-UGARSUGAR WORK	UGARSUGAR_110	9:17	17:13	7:56	LINE CLEAR AVAILED
496	13-Aug-21	BAGALKOT	220	AMBEWADI-NAGJHARI12	STATION NOT AFFECTED AMBEWADI 220	12:12	13:15	1:03	LINE CLEAR AVAILED
497	13-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	11:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
498	13-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL 220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
499	13-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
500	13-Aug-21	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	13:05	15:23	2:18	LINE FAULT
501	13-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
502	13-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI 220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
503	13-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI 220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
504	13-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
505	13-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
506	13-Aug-21	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	10:45	10:50	0:05	LOAD CHANGE OVER
507	13-Aug-21	BANGALORE	66	EXORA - CESSNA	EXORA	10:11	10:26	0:15	MAIN SUPPLY FAILURE
508	13-Aug-21	BANGALORE	66	EXORA - VIKAS TECH PARK 220	EXORA	11:09	11:22	0:13	LOAD CHANGE OVER
509	13-Aug-21	BANGALORE	66	EXORA - VIKAS TECH PARK 220	EXORA	16:40	16:50	0:10	LOAD CHANGE OVER
510	13-Aug-21	BANGALORE	66	HV1	ALLIMARADANAHALLI	18:53	19:06	0:13	TRANSFORMER FAULT
511	13-Aug-21	BANGALORE	66	HV1	NIMHANS 220	17:52	18:04	0:12	LINE CLEAR AVAILED
512	13-Aug-21	BANGALORE	66	HV1	REMCO	20:13	21:14	1:01	LINE CLEAR AVAILED
513	13-Aug-21	BANGALORE	66	HV1	JANGAMKOTE	14:30	14:57	0:27	LINE CLEAR AVAILED
514	13-Aug-21	BANGALORE	66	HV1	HOSPALYA CIRCLE	10:18	10:25	0:07	TRANSFORMER FAULT
515	13-Aug-21	BANGALORE	66	HV1	AGALAKOTE	11:20	11:25	0:05	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
516	13-Aug-21	BANGALORE	66	HV2	MAGADI 66	1:20	1:33	0:13	TRANSFORMER FAULT
517	13-Aug-21	BANGALORE	66	HV2	MAASTHI	17:02	17:52	0:50	LINE CLEAR AVAIED
518	13-Aug-21	BANGALORE	66	HV2	JANGAMKOTE	13:01	14:42	1:41	LINE CLEAR AVAIED
519	13-Aug-21	BANGALORE	66	HV2	IRGAMPALLI	3:17	3:22	0:04	TRANSFORMER FAULT
520	13-Aug-21	BANGALORE	66	HV2	REMCO	20:08(13/08/2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
521	13-Aug-21	BANGALORE	66	MALUR 220 - HOSKOTE 1	VOKKALERI	21:09	21:22	0:13	LINE FAULT
522	13-Aug-21	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	10:26	10:33	0:07	LINE FAULT
523	13-Aug-21	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	11:52	12:16	0:24	LINE FAULT
524	13-Aug-21	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	12:32	12:52	0:20	LINE FAULT
525	13-Aug-21	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	13:29	15:03	1:34	LINE FAULT
526	13-Aug-21	BANGALORE	66	MALUR 220 - KGF 2	BEML (EHT)	10:26	10:33	0:07	LINE FAULT
527	13-Aug-21	BANGALORE	66	MALUR 220 - KGF 2	BEML (EHT)	11:52	12:16	0:24	LINE FAULT
528	13-Aug-21	BANGALORE	66	MALUR 220 - KGF 2	BEML (EHT)	12:32	12:52	0:20	LINE FAULT
529	13-Aug-21	BANGALORE	66	MALUR 220 - KGF 2	BEML (EHT)	13:55	15:03	1:08	LINE CLEAR AVAIED
530	13-Aug-21	BANGALORE	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	13:55	14:00	0:05	LINE FAULT
531	13-Aug-21	BANGALORE	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	11:50	16:50	5:00	LINE CLEAR AVAIED
532	13-Aug-21	BANGALORE	66	RAMANAGARA - DASHAVARA	BEVOOR, SANKALGERE, DASHAVARA	9:14	16:59	7:45	LINE CLEAR AVAIED
533	13-Aug-21	BANGALORE	66	RBI - SOMANAHALLI 220	RBI	10:00	16:35	6:35	LINE CLEAR AVAIED
534	13-Aug-21	BANGALORE	66	RMZ - VIKAS TECH PARK 220	RMZ	14:40	16:50	2:10	MAIN SUPPLY FAILURE
535	13-Aug-21	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	10:03	18:30	8:27	LINE CLEAR AVAIED
536	13-Aug-21	BANGALORE	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	10:10	16:20	6:10	LINE CLEAR AVAIED
537	13-Aug-21	BANGALORE	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
538	13-Aug-21	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	12:25	14:30	2:05	LINE CLEAR AVAIED
539	13-Aug-21	GULBARGA	66	KUDLIGI-ITTAGI(KUDLING 2)	KUDLIGI_220	6:10	6:35	0:25	LINE FAULT
540	13-Aug-21	GULBARGA	66	KUDLING-GUDEKOTE	GUDEKOTE_66	6:10	7:00	0:50	LINE FAULT
541	13-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN :LINE CLEAR AVAIED
542	13-Aug-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	5:57	7:08	1:11	MAIN SUPPLY FAILURE
543	13-Aug-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	19:40	19:45	0:05	MAIN SUPPLY FAILURE
544	13-Aug-21	GULBARGA	110	HATTI-SOMMANAMARDI_IPP	HATTI_110	5:57	6:14	0:17	LINE FAULT
545	13-Aug-21	GULBARGA	110	HATTI-SOMMANAMARDI_IPP	HATTI_110	20:48	20:53	0:05	LINE FAULT
546	13-Aug-21	GULBARGA	110	HV1	BENUR_110	17:14	17:29	0:15	TRANSFORMER FAULT
547	13-Aug-21	GULBARGA	110	HV1	GULBARGAUNIVERSITY_110	11:50	12:10	0:20	TRANSFORMER FAULT
548	13-Aug-21	GULBARGA	110	HV1	SRIRAMNAGAR_110	13:30	13:35	0:05	TRANSFORMER FAULT
549	13-Aug-21	GULBARGA	110	LINGASUGUR-CHAYADEVI	LINGASUGUR_220	5:58	6:25	0:27	LINE FAULT
550	13-Aug-21	GULBARGA	110	LINGASUGUR-KAREPOWER	LINGASUGUR_220	5:58	6:56	0:58	LINE FAULT
551	13-Aug-21	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	5:58	6:15	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
552	13-Aug-21	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	15:00	19:25	4:25	LINE FAULT
553	13-Aug-21	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110	10:30	10:45	0:15	MAIN SUPPLY FAILURE
554	13-Aug-21	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110	11:25	11:35	0:10	MAIN SUPPLY FAILURE
555	13-Aug-21	GULBARGA	110	MALLAT-BYGWAT2	ADAVI AMARESHWAR_110	1:12	1:24	0:12	LINE FAULT
556	13-Aug-21	GULBARGA	110	MALLAT-BYGWAT2	ADAVI AMARESHWAR_110	3:32	3:42	0:10	LINE FAULT
557	13-Aug-21	GULBARGA	110	MALLAT-BYGWAT2	ADAVI AMARESHWAR_110	5:25	5:38	0:13	LINE FAULT
558	13-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	6:58	7:30	0:32	LINE CLEAR AVAILED
559	13-Aug-21	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110	19:10	19:18	0:08	LINE FAULT
560	13-Aug-21	GULBARGA	110	SEDAM-ULTRATECH	RAJASHREE CEMENT WORKS,KORWAR TEMPLE_110,CHITAPUR_110	8:40	17:29	8:49	LINE FAULT
561	13-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:46	19:57	0:11	LINE FAULT
562	13-Aug-21	GULBARGA	220	HV1	KUDLIGI_220	21:45(17.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
563	13-Aug-21	GULBARGA	220	HV1	LINGASUGUR_220	5:58	6:15	0:17	TRANSFORMER FAULT
564	13-Aug-21	GULBARGA	220	HV1,HV2	LINGASUGUR_220	19:40	19:50	0:10	LINE CLEAR AVAILED
565	13-Aug-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)	16:40(13.08.2021)	24:22HRS	TRANSFORMER CHARGED
566	13-Aug-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	21:45	22:13	0:28	LINE FAULT
567	13-Aug-21	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	14:58(12.08.2021)	6:20(13.08.2021)	15:22HRS	NFBC ISSUED
568	13-Aug-21	HASSAN	66	HV1	YESLUR_66	12:41	14:18	1:37	LINE CLEAR AVAILED
569	13-Aug-21	HASSAN	66	HV2	HALLYMYSORE_66	7:09	18:01	10:52	LINE CLEAR AVAILED
570	13-Aug-21	HASSAN	66	HV2	MAGGE_66	11:06	11:15	0:09	LINE CLEAR AVAILED
571	13-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN :LINE CLEAR AVAILED
572	13-Aug-21	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	9:52	10:01	0:09	LINE FAULT
573	13-Aug-21	HASSAN	66	YESLUR-SNVRST	YESLUR_66	12:41	14:18	1:37	LINE CLEAR AVAILED
574	13-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
575	13-Aug-21	HASSAN	110	HV2	MSEZ_220	10:44	15:01	4:17	LINE CLEAR AVAILED
576	13-Aug-21	HASSAN	110	LV2	SHIRALKOPPA_220	10:54	17:50	6:56	LINE CLEAR AVAILED
577	13-Aug-21	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:37	12:22	1:45	LINE CLEAR AVAILED
578	13-Aug-21	HASSAN	220	HV2	SHIRALKOPPA_220	10:54	17:50	6:56	LINE CLEAR AVAILED
579	13-Aug-21	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	10:09	11:15	1:06	LINE CLEAR AVAILED
580	13-Aug-21	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	10:09	11:15	1:06	LINE CLEAR AVAILED
581	13-Aug-21	MYSORE	66	AKKIHEBBAL-KR PETE 1	AKKIHEBBAL_66	12:23	17:23	4:59	LINE CLEAR AVAILED
582	13-Aug-21	MYSORE	66	AKKIHEBBAL-KR PETE 2	AKKIHEBBAL_66	12:23	17:23	4:59	LINE CLEAR AVAILED
583	13-Aug-21	MYSORE	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	10:50	17:52	7:01	LINE CLEAR AVAILED
584	13-Aug-21	MYSORE	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
585	13-Aug-21	MYSORE	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
586	13-Aug-21	MYSORE	66	GUDDENAHALLI-JAKKANAHALLI	GUDDENAHALLI_66	10:30	17:09	6:39	LINE CLEAR AVAILED
587	13-Aug-21	MYSORE	66	HV1	NANJANGUDU_66	12:56	14:55	1:59	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
588	13-Aug-21	MYSORE	66	HV1	SHIVALLY_66	5:20	6:42	1:21	TRANSFORMER FAULT
589	13-Aug-21	MYSORE	66	HV2	DKMAIDANA_66	8:43	13:25	4:41	LINE CLEAR AVAILED
590	13-Aug-21	MYSORE	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	7:57	8:09	0:11	LINE FAULT
591	13-Aug-21	MYSORE	66	KUSHALNAGARA -MYSORE 2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	1:54	2:12	0:18	LINE FAULT
592	13-Aug-21	MYSORE	66	SHANIVARSANTHE-YESSLUR	NO STATIONS EFFECTED	12:41	13:55	1:13	LINE CLEAR AVAILED
593	13-Aug-21	TUMKUR	66	ANCHEPALYA 220KV- VIJAYA STEEL	VIJAYA STEEL	3:02	3:07	0:04	LINE FAULT
594	13-Aug-21	TUMKUR	66	ANCHEPALYA 220KV- VIJAYA STEEL	VIJAYA STEEL	4:33	4:36	0:02	LINE FAULT
595	13-Aug-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	9:09	9:14	0:05	LOAD CHANGE OVER
596	13-Aug-21	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	17:01	17:05	0:04	LOAD CHANGE OVER
597	13-Aug-21	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	21:17	21:21	0:04	LINE FAULT
598	13-Aug-21	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	21:21	21:37	0:15	LINE FAULT
599	13-Aug-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	8:45	18:59	10:13	LINE CLEAR AVAILED
600	13-Aug-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:39	11:47	0:08	LINE FAULT
601	13-Aug-21	TUMKUR	66	HONNALLI 220KV- LINGADAHALLI- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:26	6:36	0:10	LINE FAULT
602	13-Aug-21	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA(SIRA2)	KALLAMBELLA_66, SIRA_66	7:25	7:43	0:18	HAND TRIPPED
603	13-Aug-21	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI	21:17	21:21	0:03	LINE FAULT
604	13-Aug-21	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	12:12	15:23	3:11	MAIN SUPPLY FAILURE
605	13-Aug-21	TUMKUR	66	PAVAGADA 220KV- MADHUGIRI 1	PAVAGADA_220	11:41	15:22	3:40	LINE CLEAR AVAILED
606	13-Aug-21	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	11:41	15:18	3:36	LINE CLEAR AVAILED
607	13-Aug-21	TUMKUR	66	TR-1	KUNDUR_66	7:10	8:09	0:59	LINE CLEAR AVAILED
608	13-Aug-21	TUMKUR	66	TR-1	MATHOD_66	21:17	21:21	0:04	TRANSFORMER FAULT
609	13-Aug-21	TUMKUR	66	TR-1	NAGASAMUDRA_66	7:01	7:10	0:09	TRANSFORMER FAULT
610	13-Aug-21	TUMKUR	66	TR-1	NAGASAMUDRA_66	12:51	13:00	0:08	TRANSFORMER FAULT
611	13-Aug-21	TUMKUR	66	TR1(LV-1)	ANTHRASANAHALLI_220	9:20	9:22	0:02	LOAD CHANGE OVER
612	13-Aug-21	TUMKUR	66	TR1(LV-1)	ANTHRASANAHALLI_220	17:02	17:09	0:07	LOAD CHANGE OVER
613	13-Aug-21	TUMKUR	66	TR2(LV-2)	ANTHRASANAHALLI_220	9:20	9:22	0:02	LOAD CHANGE OVER
614	13-Aug-21	TUMKUR	66	TR2(LV-2)	ANTHRASANAHALLI_220	17:02	17:09	0:07	LOAD CHANGE OVER
615	13-Aug-21	TUMKUR	66	TR3(LV-3)	ANTHRASANAHALLI_220	9:20	9:22	0:02	LOAD CHANGE OVER
616	13-Aug-21	TUMKUR	66	TR3(LV-3)	ANTHRASANAHALLI_220	17:02	17:09	0:07	LOAD CHANGE OVER
617	13-Aug-21	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	17:35	17:41	0:06	LOAD CHANGE OVER
618	13-Aug-21	TUMKUR	110	NITTUR 220KV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	12:25	13:39	1:13	LINE CLEAR AVAILED
619	13-Aug-21	TUMKUR	110	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110, SAMPIGE_110	16:15	18:37	2:22	LINE CLEAR AVAILED
620	13-Aug-21	TUMKUR	110	SAMPIGE- RENEWIND_IPP	RENEW_WIND_IPP_110	16:15	19:26	3:11	LINE CLEAR AVAILED
621	13-Aug-21	TUMKUR	110	TR-1	DODDAGUNI_110	11:45	13:44	1:59	LINE CLEAR AVAILED
622	13-Aug-21	TUMKUR	110	TR-1	SAMPIGE_110	9:30	18:37	9:06	LINE CLEAR AVAILED
623	13-Aug-21	TUMKUR	110	TR-2	DODDAGUNI_110	12:20	13:40	1:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
624	13-Aug-21	TUMKUR	110	TR-2	SAMPIGE_110	11:02	18:37	7:34	LINE CLEAR AVAIED
625	13-Aug-21	TUMKUR	220	HV3	ANTHRASANAHALLI_220	9:25	17:03	7:38	LINE CLEAR AVAIED
626	13-Aug-21	TUMKUR	400	GUTUR_400-BEERANAHALLI-1	GUTUR_400	12:04	12:28	0:24	HAND TRIPPED
627	13-Aug-21	TUMKUR	400	GUTUR_400-BEERANAHALLI-2	GUTUR_400	14:48	16:04	1:16	LINE CLEAR AVAIED
628	14-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAIED
629	14-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
630	14-Aug-21	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	12:44	13:11	0:27	HAND TRIPPED
631	14-Aug-21	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	10:52	11:14	0:22	LINE CLEAR AVAIED
632	14-Aug-21	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKHE D_33, STATON NOT AFFECTED ZALKI_110,	4:25	4:40	0:15	TRANSFORMER FAULT
633	14-Aug-21	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKHE D_33, STATON NOT AFFECTED ZALKI_110,	8:03	8:10	0:07	TRANSFORMER FAULT
634	14-Aug-21	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKHE D_33, STATON NOT AFFECTED ZALKI_110,	12:07	12:15	0:08	TRANSFORMER FAULT
635	14-Aug-21	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKHE D_33, STATON NOT AFFECTED ZALKI_110,	15:40	16:11	0:31	LINE CLEAR AVAIED
636	14-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR(RFE)	RAYSOLAR_110, ALBAL_110	7:29	10:20	2:51	LINE CLEAR AVAIED
637	14-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	SAIPRIYA SUGARS_110, ALBAL_110	7:29	10:20	2:51	LINE CLEAR AVAIED
638	14-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN :LINE CLEAR AVAIED
639	14-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN :LINE CLEAR AVAIED
640	14-Aug-21	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	12:47	12:50	0:03	LINE FAULT
641	14-Aug-21	BAGALKOT	110	ATHARGA-KN SOLAR	KN SOLAR_110, ATHARGA_110	18:49	19:19	0:30	HAND TRIPPED
642	14-Aug-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR(B)_110	9:22	9:29	0:07	LINE FAULT
643	14-Aug-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR(B)_110	10:36	10:53	0:17	LINE FAULT
644	14-Aug-21	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	HIDAKAL DAM_110	5:39	5:58	0:19	LINE FAULT
645	14-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAIED
646	14-Aug-21	BAGALKOT	110	MAMADAPUR(B)-BABLESHWAR	BABLESHWAR_110	11:05	11:07	0:02	HAND TRIPPED
647	14-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN :LINE CLEAR AVAIED
648	14-Aug-21	BAGALKOT	110	RANEENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI_110	15:42 (10.08.2021)			LINE OPEN :LINE CLEAR AVAIED
649	14-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
650	14-Aug-21	BAGALKOT	110	SATTI-RABAKAVI	SATTI_110	17:50	18:07	0:17	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
651	14-Aug-21	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI_220	10:54	17:05	6:11	LINE CLEAR AVAILED
652	14-Aug-21	BAGALKOT	110	SIRSI-JOG2	SIRSI_110	11:00	14:01	3:01	LINE CLEAR AVAILED
653	14-Aug-21	BAGALKOT	110	SIRSI-KUMTA1&2	SIRSI_110	14:01	18:50	4:49	LINE CLEAR AVAILED
654	14-Aug-21	BAGALKOT	110	SIRSI-SIRSI220(1&2)	SIRSI_110	14:00	18:50	4:50	LINE CLEAR AVAILED
655	14-Aug-21	BAGALKOT	110	VAJRAMATTI220-MUDHOL	MUDHOL_110	1:18	1:25	0:07	LINE FAULT
656	14-Aug-21	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	10:05	11:14	1:09	LINE FAULT
657	14-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
658	14-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
659	14-Aug-21	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	13:08	15:23	2:15	LINE CLEAR AVAILED
660	14-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
661	14-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
662	14-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
663	14-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
664	14-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
665	14-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
666	14-Aug-21	BANGALORE	66	HV1	EPIP 220	9:58	12:44	2:46	LINE CLEAR AVAILED
667	14-Aug-21	BANGALORE	66	HV1	EPIP 220	16:04	16:12	0:08	LINE CLEAR AVAILED
668	14-Aug-21	BANGALORE	66	HV1	EPIP 220	16:24	16:26	0:02	LINE CLEAR AVAILED
669	14-Aug-21	BANGALORE	66	HV1	NIMHANS 220	13:15	14:55	1:40	LINE CLEAR AVAILED
670	14-Aug-21	BANGALORE	66	HV1	NRS 220	10:05	17:51	7:46	LINE CLEAR AVAILED
671	14-Aug-21	BANGALORE	66	HV1	VIJAYANAGARA	10:13	10:30	0:17	MAIN SUPPLY FAILURE
672	14-Aug-21	BANGALORE	66	HV1	VIJAYANAGARA	18:08	18:20	0:12	LOAD CHANGE OVER
673	14-Aug-21	BANGALORE	66	HV1	AVANI	9:35	10:35	1:00	TRANSFORMER FAULT
674	14-Aug-21	BANGALORE	66	HV2	EPIP 220	13:51	14:53	1:02	LINE CLEAR AVAILED
675	14-Aug-21	BANGALORE	66	HV2	EPIP 220	15:02	15:04	0:02	LINE CLEAR AVAILED
676	14-Aug-21	BANGALORE	66	HV2	NRS 220	10:05	18:02	7:57	LINE CLEAR AVAILED
677	14-Aug-21	BANGALORE	66	HV2	VIJAYANAGARA	10:13	10:28	0:15	MAIN SUPPLY FAILURE
678	14-Aug-21	BANGALORE	66	HV2	VIJAYANAGARA	18:28	18:38	0:10	LOAD CHANGE OVER
679	14-Aug-21	BANGALORE	66	HV2	SIDDALAGATTA	13:53	14:00	0:06	LINE CLEAR AVAILED
680	14-Aug-21	BANGALORE	66	HV2	REMCO	20:08(13/08/2021)	17:34:00(14/08/2021)	21:26HRS	TRANSFORMER CHARGED
681	14-Aug-21	BANGALORE	66	HV2 CB	HUKUNDA	17:30	17:40	0:10	TRANSFORMER FAULT
682	14-Aug-21	BANGALORE	66	HV3	NRS 220	10:05	17:18	7:13	LINE CLEAR AVAILED
683	14-Aug-21	BANGALORE	66	HV4	NRS 220	10:05	17:16	7:11	LINE CLEAR AVAILED
684	14-Aug-21	BANGALORE	66	HV5	NRS 220	10:05	17:52	7:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
685	14-Aug-21	BANGALORE	66	MALUR 220 - HOSKOTE 1	VOKKALERI	22:40	22:52	0:12	LINE FAULT
686	14-Aug-21	BANGALORE	66	MALUR 220 - HOSKOTE 1	VOKKALERI	22:52	23:07	0:15	LINE FAULT
687	14-Aug-21	BANGALORE	66	MALUR 220 - HOSKOTE 1	VOKKALERI	23:07(14-8-2021)			LINE OPEN:LINE FAULT
688	14-Aug-21	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	8:07	8:10	0:03	LINE CLEAR AVAILED
689	14-Aug-21	BANGALORE	66	MALUR 220 - KGF 2	BEML (EHT)	8:07	8:10	0:03	LINE CLEAR AVAILED
690	14-Aug-21	BANGALORE	66	MEI LAYOUT - WIDIA	WIDIA, WIDIA(EHT)	9:00	18:00	9:00	LINE CLEAR AVAILED
691	14-Aug-21	BANGALORE	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	10:25	17:57	7:32	LINE CLEAR AVAILED
692	14-Aug-21	BANGALORE	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	10:07	17:46	7:39	LINE CLEAR AVAILED
693	14-Aug-21	BANGALORE	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	10:07	19:06	8:59	LINE CLEAR AVAILED
694	14-Aug-21	BANGALORE	66	SRS PEENYA 220 - WIDIA	MEI LAYOUT	9:00	15:51	6:51	LINE CLEAR AVAILED
695	14-Aug-21	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	8:22	12:01	3:39	LINE CLEAR AVAILED
696	14-Aug-21	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	16:24	18:39	2:15	LINE CLEAR AVAILED
697	14-Aug-21	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	18:39	19:16	0:37	LINE FAULT
698	14-Aug-21	BANGALORE	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	8:49	9:12	0:23	LINE FAULT
699	14-Aug-21	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	8:59	12:22	3:23	LINE CLEAR AVAILED
700	14-Aug-21	BANGALORE	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
701	14-Aug-21	BANGALORE	66	YELAHANKA 220 - LINE7	KANASWADI	6:16	6:31	0:14	LINE FAULT
702	14-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
703	14-Aug-21	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	22:24	22:33	0:09	LINE FAULT
704	14-Aug-21	GULBARGA	110	HV1	CHINCHOLI_110	15:20	15:46	0:26	LINE CLEAR AVAILED
705	14-Aug-21	GULBARGA	110	HV2	SHAHAPUR_220	20:03	20:20	0:17	TRANSFORMER FAULT
706	14-Aug-21	GULBARGA	110	HV2	SOMASAMUDRA_110	12:16	16:25	4:09	TRANSFORMER FAULT
707	14-Aug-21	GULBARGA	110	HV2	SOMASAMUDRA_110	17:48	17:52	0:04	TRANSFORMER FAULT
708	14-Aug-21	GULBARGA	110	HV3	CHINCHOLI_110	23:24	23:36	0:12	TRANSFORMER FAULT
709	14-Aug-21	GULBARGA	110	HV3	KEREHALLI_110	16:00	16:05	0:05	TRANSFORMER FAULT
710	14-Aug-21	GULBARGA	110	HV3	ALIPUR_220	19:32	19:35	0:03	LINE CLEAR AVAILED
711	14-Aug-21	GULBARGA	110	LINGASUGUR-KAREPOWER	LINGASUGUR_220	12:06	12:39	0:33	LINE CLEAR AVAILED
712	14-Aug-21	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	11:06	13:51	2:45	LINE CLEAR AVAILED
713	14-Aug-21	GULBARGA	110	MALLAPUR-MUNIRABAD	MALLAPURA_110	19:16	19:24	0:08	MAIN SUPPLY FAILURE
714	14-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	9:55	14:40	4:45	LINE CLEAR AVAILED
715	14-Aug-21	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	19:12	19:24	0:12	LINE FAULT
716	14-Aug-21	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	6:45	7:50	1:05	LOAD CURTAILMENT
717	14-Aug-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	6:26	6:47	0:21	LOAD CURTAILMENT
718	14-Aug-21	GULBARGA	110	SEDAM-VICAT SAGAR	VICAT SAGAR CEMENTS	23:11	23:35	0:24	LINE FAULT
719	14-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	9:17(14.08.21)			LINE OPEN :LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
720	14-Aug-21	GULBARGA	110	SOMASAMUDRA-ALLIPUR	SOMASAMUDRA_110	12:16	12:20	0:04	LINE FAULT
721	14-Aug-21	GULBARGA	110	STAR METALLIC-SINDNOOR LINE	STAR METALLIC_IPP	19:15	19:30	0:15	LINE FAULT
722	14-Aug-21	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	10:35	12:19	1:44	LINE CLEAR AVAILED
723	14-Aug-21	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	1:48	2:43	0:55	LINE CLEAR AVAILED
724	14-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN :LINE CLEAR AVAILED
725	14-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
726	14-Aug-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:14	11:42	0:28	MAIN SUPPLY FAILURE
727	14-Aug-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:14	11:41	0:27	MAIN SUPPLY FAILURE
728	14-Aug-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:14	11:40	0:26	MAIN SUPPLY FAILURE
729	14-Aug-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:14	11:44	0:30	MAIN SUPPLY FAILURE
730	14-Aug-21	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	9:09	10:55	1:46	LINE CLEAR AVAILED
731	14-Aug-21	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	11:14	17:08	5:54	LINE FAULT
732	14-Aug-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:14	15:23	4:09	LINE FAULT
733	14-Aug-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	21:43	22:09	0:26	HAND TRIPPED
734	14-Aug-21	HASSAN	220	VARAH1-SHMG3	varahi_gen	9:09	10:55	1:46	LINE CLEAR AVAILED
735	14-Aug-21	MYSORE	66	ANEGOLA-KRISHNAPURA	ANEGOLAL_66	10:01	17:37	7:36	LINE CLEAR AVAILED
736	14-Aug-21	MYSORE	66	BANNUR-SFC	NO STATIONS EFFECTED	11:05	17:35	6:30	NFBC ISSUED
737	14-Aug-21	MYSORE	66	CR NAGARA-KABBALLI	NO STATIONS EFFECTED	0:32	0:39	0:06	LINE FAULT
738	14-Aug-21	MYSORE	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
739	14-Aug-21	MYSORE	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
740	14-Aug-21	MYSORE	66	HV1	BANNUR_66	16:18	16:33	0:15	LINE CLEAR AVAILED
741	14-Aug-21	MYSORE	66	HV1	KIRUGAVALU_66	9:28	11:27	1:59	LINE CLEAR AVAILED
742	14-Aug-21	MYSORE	66	HV2	CHANDAKAVADI_66	11:05	13:22	2:17	LINE CLEAR AVAILED
743	14-Aug-21	MYSORE	66	HV2	KIRUGAVALU_66	9:28	11:27	1:59	LINE CLEAR AVAILED
744	14-Aug-21	MYSORE	66	HV2	SATHEGALA_66	5:14	5:25	0:11	TRANSFORMER FAULT
745	14-Aug-21	MYSORE	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBKERE_66	8:49	9:18	0:29	LINE FAULT
746	14-Aug-21	MYSORE	66	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	11:37	12:19	0:42	LINE CLEAR AVAILED
747	14-Aug-21	MYSORE	66	MEGALAPURA-HEBBANI	THUMBLA_66 VYASRAJPURA_66 GARGESHWARI_66 CHIDRAVALLI_66 BGPURA_66	11:05	11:18	0:13	LINE FAULT
748	14-Aug-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:50	6:01	0:11	LINE FAULT
749	14-Aug-21	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66,SAS ALUHALLA_66	5:50	6:01	0:11	LINE FAULT
750	14-Aug-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	PANDRAHALLI2	17:18	17:31	0:13	MAIN SUPPLY FAILURE
751	14-Aug-21	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	6:04	6:23	0:18	LINE FAULT
752	14-Aug-21	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	ENERCON1_IPP_66	18:52	18:56	0:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
753	14-Aug-21	TUMKUR	66	TR-1	CHIKKABANAGERE_66	11:10	12:10	1:00	LINE CLEAR AVAILED
754	14-Aug-21	TUMKUR	66	TR-1	CHIKKABANAGERE_66	15:05	15:55	0:50	MAIN SUPPLY FAILURE
755	14-Aug-21	TUMKUR	66	TR-1	NIDASALE_66	10:15	10:25	0:10	TRANSFORMER FAULT
756	14-Aug-21	TUMKUR	66	TR-2	NAYAKANAHATTI_66	17:14	17:33	0:18	TRANSFORMER FAULT
757	14-Aug-21	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	12:02	14:43	2:41	LINE CLEAR AVAILED
758	14-Aug-21	TUMKUR	110	TR-1	THIMMANAHALLI_110	21:49	22:15	0:25	TRANSFORMER FAULT
759	15-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
760	15-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
761	15-Aug-21	BAGALKOT	110	110/11KV, HV1	ALBAL_110	11:56	11:58	0:02	TRANSFORMER FAULT
762	15-Aug-21	BAGALKOT	110	110/11KV, HV3(HV5)	STATION NOT AFFECTED INDI_110	18:33	21:44	3:11	LINE CLEAR AVAILED
763	15-Aug-21	BAGALKOT	110	110/11KV,HV2	ALBAL_110	11:56	12:01	0:05	TRANSFORMER FAULT
764	15-Aug-21	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED BABLESHWAR_110	18:13	18:32	0:19	LINE CLEAR AVAILED
765	15-Aug-21	BAGALKOT	110	110/11KV,HV2	MUKARTHAL_110	9:19	9:50	0:31	LINE CLEAR AVAILED
766	15-Aug-21	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKHE D_33, STATON NOT AFFECTED ZALKI_110,	5:38	5:43	0:05	TRANSFORMER FAULT
767	15-Aug-21	BAGALKOT	110	110/33KV,HV4	HALASANGI_33,NEVARGI_33,DHULKHE D_33, STATON NOT AFFECTED ZALKI_110,	8:50	8:55	0:05	TRANSFORMER FAULT
768	15-Aug-21	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	6:00	6:04	0:04	LINE FAULT
769	15-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR(RFE)	RAYSOLAR_110, ALBAL_110	11:56	12:01	0:05	LINE FAULT
770	15-Aug-21	BAGALKOT	110	ALBAL-RAY SOLAR(RFE)	RAYSOLAR_110, ALBAL_110	15:55	18:53	2:58	LINE CLEAR AVAILED
771	15-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	SAIPRIYA SUGARS_110, ALBAL_110	11:56	11:59	0:03	LINE FAULT
772	15-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	SAIPRIYA SUGARS_110, ALBAL_110	15:55	18:52	2:57	LINE CLEAR AVAILED
773	15-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
774	15-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
775	15-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
776	15-Aug-21	BAGALKOT	110	HAVERI220-SAVANUR	STATION NOT AFFECTED HAVERI_220	6:15	7:11	0:56	LINE FAULT
777	15-Aug-21	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	STATION NOT AFFECTED MALGHAN(S)_110	20:57	21:16	0:19	LINE FAULT
778	15-Aug-21	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	STATION NOT AFFECTED MALGHAN(S)_110	22:30	22:36	0:06	LINE FAULT
779	15-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN :LINE CLEAR AVAILED
780	15-Aug-21	BAGALKOT	110	RANEENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI_110	15:42 (10.08.2021)			LINE OPEN :LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
781	15-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
782	15-Aug-21	BAGALKOT	110	SHIGGOAN-(RMKP)MUNDAGOD	STATION NOT AFFECTED SHIGGOAN_110	15:45	16:04	0:19	HAND TRIPPED
783	15-Aug-21	BAGALKOT	110	TODALBAGI-JAMAKHANDI	TODALBAGI_110	6:09	6:10	0:01	LINE FAULT
784	15-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
785	15-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
786	15-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
787	15-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
788	15-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
789	15-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
790	15-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
791	15-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
792	15-Aug-21	BANGALORE	66	CHAKAVELU - MITTEMARI 220	CHAKAVELU	13:45	14:40	0:55	LINE FAULT
793	15-Aug-21	BANGALORE	66	CHIKKABALLAPURA I/A 1 - DB PURA 220	NO STATION AFFECTED	9:55	10:20	0:25	LINE FAULT
794	15-Aug-21	BANGALORE	66	HV1	T GOLLAHALLI 220	11:12	11:56	0:44	LINE CLEAR AVAILED
795	15-Aug-21	BANGALORE	66	HV1	HOSPALYA CIRCLE	9:13	9:58	0:44	TRANSFORMER FAULT
796	15-Aug-21	BANGALORE	66	HV2	SOMAYAJJANAHALLI	17:46	18:14	0:27	TRANSFORMER FAULT
797	15-Aug-21	BANGALORE	66	HV2	SIDDALAGATTA	13:54	14:00	0:05	TRANSFORMER FAULT
798	15-Aug-21	BANGALORE	66	HV2	IRGAMPALLI	14:00	14:04	0:04	TRANSFORMER FAULT
799	15-Aug-21	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	8:25	8:29	0:04	LOAD CHANGE OVER
800	15-Aug-21	BANGALORE	66	MALUR 220 - HOSKOTE 1	VOKKALERI	18:49	19:13	0:24	LINE FAULT
801	15-Aug-21	BANGALORE	66	MALUR 220 - HOSKOTE 1	VOKKALERI	23:07(14-8-2021)	8:38(15-08-2021)	9:30	LINE CHARGED
802	15-Aug-21	BANGALORE	66	MALUR 220 - MALUR I/A	MALUR I/A, STAR PANEL (EHT)	1:35	2:17	0:42	LINE CLEAR AVAILED
803	15-Aug-21	BANGALORE	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	16:05	19:56	3:51	LINE CLEAR AVAILED
804	15-Aug-21	BANGALORE	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	12:56	19:48	6:52	LINE CLEAR AVAILED
805	15-Aug-21	BANGALORE	66	T GOLLAHALLI 220 - KGF 1	KYASAMBALLI, ANDERSONPETE, DODDAKARI	11:12	11:56	0:44	LINE CLEAR AVAILED
806	15-Aug-21	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	5:38	5:43	0:05	LINE FAULT
807	15-Aug-21	BANGALORE	66	TUBGERE - CHIKKABALLPURA I/A 2	NO STATION AFFECTED	9:58	10:03	0:05	LINE FAULT
808	15-Aug-21	BANGALORE	66	TUBUGERE - DB PURA 220	TUBUGERE	9:58	10:03	0:05	LINE FAULT
809	15-Aug-21	BANGALORE	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
810	15-Aug-21	BANGALORE	220	T GOLLAHALLI 220 - PGCIL 1 & 2	T GOLLAHALLI 220	11:12	11:40	0:28	LINE FAULT
811	15-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
812	15-Aug-21	GULBARGA	110	HV1	SHAHAPUR_220	16:40	19:55	3:15	TRANSFORMER FAULT
813	15-Aug-21	GULBARGA	110	HV1	GULBARGAUNIVERSITY_110	22:05	22:20	0:15	TRANSFORMER FAULT
814	15-Aug-21	GULBARGA	110	HV3	SHORAPUR_110	19:46	19:55	0:09	TRANSFORMER FAULT
815	15-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	22:47	22:55	0:08	LINE FAULT
816	15-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVAN GAON_110,RENUKA_IPP,AFZALPUR_110 ,KARAJAGI_110	5:18	5:23	0:05	LINE FAULT
817	15-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	20:56	21:00	0:04	LINE FAULT
818	15-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	22:22	22:28	0:06	LINE FAULT
819	15-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	23:22	23:33	0:11	LINE FAULT
820	15-Aug-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
821	15-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN :LINE CLEAR AVAILED
822	15-Aug-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:16	22:22	0:06	LINE FAULT
823	15-Aug-21	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	16:35	16:50	0:15	LINE FAULT
824	15-Aug-21	GULBARGA	220	LV1	RAICHUR_220	23:55			TRANSFORMER OPEN:TRANSFORMER FAULT
825	15-Aug-21	GULBARGA	220	LV2	RAICHUR_220	23:55			TRANSFORMER OPEN:TRANSFORMER FAULT
826	15-Aug-21	HASSAN	66	HV1	BYACHANAHALLI_66	3:03	8:31	5:28	LINE CLEAR AVAILED
827	15-Aug-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	14:10	15:15	1:05	TRANSFORMER FAULT
828	15-Aug-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	20:25	20:48	0:23	HAND TRIPPED
829	15-Aug-21	HASSAN	66	HV1	YESLUR_66	7:28	8:31	1:03	TRANSFORMER FAULT
830	15-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN :LINE CLEAR AVAILED
831	15-Aug-21	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	15:25	20:49	5:24	NFBC ISSUED
832	15-Aug-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	9:02	9:11	0:09	LINE FAULT
833	15-Aug-21	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	18:34	19:55	1:21	LINE FAULT
834	15-Aug-21	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	15:15	15:20	0:05	LINE FAULT
835	15-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
836	15-Aug-21	HASSAN	110	HV2	NITTUR_110	12:04	12:12	0:08	TRANSFORMER FAULT
837	15-Aug-21	HASSAN	110	MRSSHM-MYSORE	MRSMG_220	10:50	16:25	5:35	LINE CLEAR AVAILED
838	15-Aug-21	HASSAN	220	VARAHI-SHMG3	varahi_gen	15:15	15:26	0:11	LINE FAULT
839	15-Aug-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:19(15.8.2021)			LINE OPEN :LINE CLEAR AVAILED
840	15-Aug-21	MYSORE	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66	23:46 (15/08/2021)			LINE OPEN:LINE FAULT
841	15-Aug-21	MYSORE	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
842	15-Aug-21	MYSORE	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)			LINE OPEN :LINE CLEAR AVAILED
843	15-Aug-21	MYSORE	66	HV1	HANAGODU_66	14:26	14:45	0:18	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
844	15-Aug-21	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	12:32	12:49	0:17	LINE FAULT
845	15-Aug-21	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	8:47	8:51	0:04	LINE FAULT
846	15-Aug-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	6:06	6:11	0:05	LINE FAULT
847	15-Aug-21	TUMKUR	66	PALLAGATTE66KV-DAVANGERE	PALLAGATTE_66	13:24	13:44	0:19	LINE CLEAR AVAILED
848	15-Aug-21	TUMKUR	66	TR-1	BHARAMGIRI_66	12:22	12:27	0:05	TRANSFORMER FAULT
849	15-Aug-21	TUMKUR	66	TR-1	BHARAMGIRI_66	12:45	12:46	0:01	TRANSFORMER FAULT
850	15-Aug-21	TUMKUR	66	TR-1	BHARAMGIRI_66	13:31	13:33	0:02	TRANSFORMER FAULT
851	15-Aug-21	TUMKUR	66	TR-1	HOLALKERE_66	11:19	11:31	0:11	TRANSFORMER FAULT
852	15-Aug-21	TUMKUR	66	TR-1	KORATAGERE_66	10:24	10:35	0:10	TRANSFORMER FAULT
853	15-Aug-21	TUMKUR	66	TR-1	YADVANI_66	11:06	11:19	0:13	HAND TRIPPED
854	15-Aug-21	TUMKUR	66	TR-2	CHIKKABANAGERE_66	15:30	16:38	1:07	LINE CLEAR AVAILED
855	15-Aug-21	TUMKUR	66	TR-2	RAMPURA_66	19:05	19:36	0:31	HAND TRIPPED
856	15-Aug-21	TUMKUR	66	TURUVANUR_66KV-CHITRADURGA220	TURUVANUR_66KV	17:13	18:53	1:40	LINE CLEAR AVAILED
857	15-Aug-21	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	9:49	11:09	1:19	LINE CLEAR AVAILED
858	15-Aug-21	TUMKUR	110	TR-1	KALLUR_110	9:47	11:09	1:21	LINE CLEAR AVAILED
859	16-Aug-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
860	16-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUGALKOD_220	00:34 (11.07.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
861	16-Aug-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SAVALAGI_110	13:56	14:20	0:24	HAND TRIPPED
862	16-Aug-21	BAGALKOT	110	110/11KV, HV2 (HV1)	STATION NOT AFFECTED TAUSHI (BALIGERA)_110	15:29	15:35	0:06	LINE CLEAR AVAILED
863	16-Aug-21	BAGALKOT	110	110/11KV,HV5	INDI_110	12:40	14:20	1:40	LINE CLEAR AVAILED
864	16-Aug-21	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED TARIHAL_110	9:38	13:13	3:35	LINE CLEAR AVAILED
865	16-Aug-21	BAGALKOT	110	110/33KV,HV2	SHIRBUR_33 KUDCHI_110	11:49	13:26	1:37	LINE CLEAR AVAILED
866	16-Aug-21	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED HUBLI_220	12:35	15:34	2:59	TRANSFORMER FAULT
867	16-Aug-21	BAGALKOT	110	ALBAL-SAIPRIYA SUGARS	ALBAL_110	14:55	18:50	3:55	LINE CLEAR AVAILED
868	16-Aug-21	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	17:48	18:40	0:52	LINE FAULT
869	16-Aug-21	BAGALKOT	110	ALMEL-KPR SUGARS	ALMEL_110	18:08	18:40	0:32	LINE FAULT
870	16-Aug-21	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
871	16-Aug-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN :LINE CLEAR AVAILED
872	16-Aug-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
873	16-Aug-21	BAGALKOT	110	HUBLI220-TARIHAL1	STATION NOT AFFECTED HUBLI_220	12:34	18:26	5:52	LINE FAULT
874	16-Aug-21	BAGALKOT	110	HUBLI220-TARIHAL2	STATION NOT AFFECTED HUBLI_220	12:34	18:27	5:53	LINE CLEAR AVAILED
875	16-Aug-21	BAGALKOT	110	JAMBAGI-HALKI(MUDHOL)	HALKI_110	6:55	7:03	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
876	16-Aug-21	BAGALKOT	110	KULIGERECROSS -KERUR	KERUR_110	10:05	10:19	0:14	HAND TRIPPED
877	16-Aug-21	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MALGHAN(S)_110	2:11	4:17	2:06	LINE FAULT
878	16-Aug-21	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN :LINE CLEAR AVAILED
879	16-Aug-21	BAGALKOT	110	RANEENNUR- BYADAGI	STATION NOT AFFECTED BYADAGI_110	15:42 (10.08.2021)			LINE OPEN :LINE CLEAR AVAILED
880	16-Aug-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
881	16-Aug-21	BAGALKOT	110	UGARKHUD-UGAR SUGARS	UGAR SUGARS_110 STATION NOT AFFECTED UGARKHUD_110	14:30	17:20	2:50	LINE CLEAR AVAILED
882	16-Aug-21	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED HUBLI_220	12:35	14:57	2:22	TRANSFORMER FAULT
883	16-Aug-21	BAGALKOT	220	BAGALKOT-ADPH2(ADPH1)	STATION NOT AFFECTED BAGALKOT_220	17:46	18:48	1:02	LINE FAULT
884	16-Aug-21	BAGALKOT	220	BAGALKOT-ADPH2(ADPH1)	STATION NOT AFFECTED BAGALKOT_220	18:48	19:13	0:25	LINE FAULT
885	16-Aug-21	BAGALKOT	220	BELGAUM- CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	11:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
886	16-Aug-21	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN:LINE FAULT
887	16-Aug-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
888	16-Aug-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
889	16-Aug-21	BAGALKOT	220	NARENDRA-KANABARGI1	STATION NOT AFFECTED NARENDRA_220	6:03	6:30	0:27	LINE FAULT
890	16-Aug-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
891	16-Aug-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	6:04 (08.08.2021)			LINE OPEN :LINE CLEAR AVAILED
892	16-Aug-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
893	16-Aug-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN :LINE CLEAR AVAILED
894	16-Aug-21	BANGALORE	66	BAGEPALLI - GUNDLU KOTTUR	GUNDLU KOTTUR	11:50	13:05	1:15	LINE CLEAR AVAILED
895	16-Aug-21	BANGALORE	66	BOODIGERE - HOSKOTE 220	BOODIGERE	11:45	11:50	0:05	LOAD CHANGE OVER
896	16-Aug-21	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	5:47	6:02	0:14	LINE FAULT
897	16-Aug-21	BANGALORE	66	HOSKOTE 220 - DG4	NO STATION AFFECTED	8:48	8:57	0:09	LINE FAULT
898	16-Aug-21	BANGALORE	66	HV1	NIMHANS 220	11:25	11:30	0:05	LINE CLEAR AVAILED
899	16-Aug-21	BANGALORE	66	HV1	KGF	11:25	12:15	0:50	LINE CLEAR AVAILED
900	16-Aug-21	BANGALORE	66	HV2	ATTUR YELAHANKA	11:47	12:23	0:36	LINE CLEAR AVAILED
901	16-Aug-21	BANGALORE	66	HV2	KGF	11:25	12:15	0:50	LINE CLEAR AVAILED
902	16-Aug-21	BANGALORE	66	HV3	KGF	11:25	12:15	0:50	LINE CLEAR AVAILED
903	16-Aug-21	BANGALORE	66	JAYANAGARA - NATIONAL COLLEGE	JAYANAGARA	16:55	17:00	0:05	LOAD CHANGE OVER
904	16-Aug-21	BANGALORE	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	13:21	13:30	0:09	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
905	16-Aug-21	BANGALORE	66	KGF - BEML (EHT)	BEML (EHT)	11:25	12:15	0:50	LINE FAULT
906	16-Aug-21	BANGALORE	66	MALUR 220 - HOSKOTE 1	VOKKALERI	11:18	11:45	0:26	LINE CLEAR AVAILED
907	16-Aug-21	BANGALORE	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	11:55	13:14	1:19	LINE CLEAR AVAILED
908	16-Aug-21	BANGALORE	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	5:38	5:46	0:08	LINE FAULT
909	16-Aug-21	BANGALORE	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	13:21	13:25	0:04	LOAD CHANGE OVER
910	16-Aug-21	BANGALORE	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	17:12	17:15	0:03	LOAD CHANGE OVER
911	16-Aug-21	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	7:16	7:21	0:05	LOAD CHANGE OVER
912	16-Aug-21	BANGALORE	66	VOKKALERI - KOLAR 220	VOKKALERI	13:10	13:50	0:40	LOAD CHANGE OVER
913	16-Aug-21	BANGALORE	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN:LINE FAULT
914	16-Aug-21	GULBARGA	66	HV1	TAMBRAHALLI_66	21:25	21:30	0:05	TRANSFORMER FAULT
915	16-Aug-21	GULBARGA	110	GABBUR-DEODURGA	DEODURGA_110	0:55	1:40	0:45	LINE FAULT
916	16-Aug-21	GULBARGA	110	GULBARGASOUTH-UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
917	16-Aug-21	GULBARGA	110	GURMITKAL-SEDAM	GURMITKAL_110	3:45	3:50	0:05	LINE FAULT
918	16-Aug-21	GULBARGA	110	GURMITKAL-SEDAM	GURMITKAL_110	5:40	5:45	0:05	LINE FAULT
919	16-Aug-21	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BH ALKI SUGAR IPP	6:09	6:16	0:07	LINE FAULT
920	16-Aug-21	GULBARGA	110	HV1	GULBARGAUNIVERSITY_110	9:00	9:10	0:10	TRANSFORMER FAULT
921	16-Aug-21	GULBARGA	110	HV1	GULBARGAUNIVERSITY_110	10:20	11:05	0:45	TRANSFORMER FAULT
922	16-Aug-21	GULBARGA	110	HV1	KADAGANCHI_110	21:50	22:00	0:10	TRANSFORMER FAULT
923	16-Aug-21	GULBARGA	110	HV3	LADHA_110	17:05	18:30	1:25	LINE CLEAR AVAILED
924	16-Aug-21	GULBARGA	110	HV4	YELBURGA_110	11:17	11:46	0:29	TRANSFORMER FAULT
925	16-Aug-21	GULBARGA	110	LV1	RAICHUR_220	23:55(15.08.2021)	00:05(16.08.2021)	0:10	TRANSFORMER CHARGED
926	16-Aug-21	GULBARGA	110	LV2	RAICHUR_220	23:55(15.08.2021)	00:05(16.08.2021)	0:10	TRANSFORMER CHARGED
927	16-Aug-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	0:52	1:17	0:25	LINE FAULT
928	16-Aug-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	2:15	2:20	0:05	LINE FAULT
929	16-Aug-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	5:05	5:10	0:05	LINE FAULT
930	16-Aug-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	20:25	20:35	0:10	LINE FAULT
931	16-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	1:21	1:31	0:10	LINE FAULT
932	16-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	5:38	5:48	0:10	LINE FAULT
933	16-Aug-21	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	22:50	22:57	0:07	LINE FAULT
934	16-Aug-21	GULBARGA	110	MYLAR-GUTAL	MYLAR_110	11:05	12:05	1:00	LINE CLEAR AVAILED
935	16-Aug-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	0:57	1:05	0:08	LINE FAULT
936	16-Aug-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	3:35	3:40	0:05	LINE FAULT
937	16-Aug-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
938	16-Aug-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN :LINE CLEAR AVAILED
939	16-Aug-21	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	22:23	22:30	0:07	LINE FAULT
940	16-Aug-21	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	19:35	22:16	2:41	LINE FAULT
941	16-Aug-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	2:35	8:55	6:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
942	16-Aug-21	GULBARGA	220	HV1	SEDAM_220	13:02	14:21	1:19	LINE CLEAR AVAILED
943	16-Aug-21	GULBARGA	220	HV1	SHAHAPUR_220	2:35	2:40	0:05	TRANSFORMER FAULT
944	16-Aug-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
945	16-Aug-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	3:58	4:22	0:24	LINE FAULT
946	16-Aug-21	GULBARGA	220	SEDAM-HUMNABAD	SEDAM_220	23:47(16.08.2021)			LINE OPEN :LINE CLEAR AVAILED
947	16-Aug-21	GULBARGA	400	JSWVL-BPS2	BTPS_400	14:03	14:50	0:47	LINE CLEAR AVAILED
948	16-Aug-21	GULBARGA	400	RTPS-BTPS	RTPS_400	3:11	16:18	13:07	LINE FAULT
949	16-Aug-21	HASSAN	66	HV1	MALLIPATNA_66	14:25	16:50	2:25	LINE CLEAR AVAILED
950	16-Aug-21	HASSAN	66	HV2	HALLYMYSORE_66	11:15	12:50	1:35	LINE CLEAR AVAILED
951	16-Aug-21	HASSAN	66	HV2	HALLYMYSORE_66	15:47	16:10	0:23	LINE CLEAR AVAILED
952	16-Aug-21	HASSAN	66	HV2	MALLIPATNA_66	11:35	14:35	3:00	LINE CLEAR AVAILED
953	16-Aug-21	HASSAN	66	HV2	MALLIPATNA_66	16:45	16:50	0:05	HAND TRIPPED
954	16-Aug-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:29(7.8.2021)			LINE OPEN :LINE CLEAR AVAILED
955	16-Aug-21	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	5:49	6:01	0:12	LINE FAULT
956	16-Aug-21	HASSAN	110	HV1	KADUR_220	14:15(19.07.2021)			TRANSFORMER OPEN :LINE CLEAR AVAILED
957	16-Aug-21	HASSAN	110	HV1	BIRUR_110	18:53	19:00	0:07	TRANSFORMER FAULT
958	16-Aug-21	HASSAN	110	HV1	BIRUR_110	19:39	19:48	0:09	TRANSFORMER FAULT
959	16-Aug-21	HASSAN	110	HV1	NANDIKUR_110	13:03	13:56	0:53	LINE CLEAR AVAILED
960	16-Aug-21	HASSAN	110	HV1	SORABA_110	0:07	0:11	0:04	HAND TRIPPED
961	16-Aug-21	HASSAN	110	JOG110-MGHE	JOG_110	17:45	20:14	2:29	LINE FAULT
962	16-Aug-21	HASSAN	110	JOG-JLT4	mghejog_gen	17:45(16.8.2021)			LINE OPEN:LINE FAULT
963	16-Aug-21	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	10:52	13:20	2:28	LINE CLEAR AVAILED
964	16-Aug-21	HASSAN	110	LPH-MGHE 2	lph_gen	17:45(16.8.2021)			LINE OPEN:LINE FAULT
965	16-Aug-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:23	12:25	2:02	LINE CLEAR AVAILED
966	16-Aug-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:23	12:25	2:02	NFBC ISSUED
967	16-Aug-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:19(15.8.2021)	7:55 (16.08.2021)	8:36hrs	LINE CHARGED
968	16-Aug-21	MYSORE	66	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66	23:46 (15/08/2021)	0:15 (16/08/2021)	0:29 HRS	LINE CHARGED
969	16-Aug-21	MYSORE	66	DR PETE-CR NAGARA 1	NO STATIONS EFFECTED	8:42	21:59	13:16	LINE CLEAR AVAILED
970	16-Aug-21	MYSORE	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)	17:10 (16/08/2021)	138:44 HRS	LINE CHARGED
971	16-Aug-21	MYSORE	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	12:06 (10/08/2021)	17:10 (16/08/2021)	138:44 HRS	LINE CHARGED
972	16-Aug-21	MYSORE	66	HV1	AKKIHEBBAL_66	8:02	8:15	0:13	TRANSFORMER FAULT
973	16-Aug-21	MYSORE	66	HV1	BANNUR_66	13:58	14:44	0:45	LINE CLEAR AVAILED
974	16-Aug-21	MYSORE	66	HV1	KRPET_220	11:31	12:11	0:40	LINE CLEAR AVAILED
975	16-Aug-21	MYSORE	66	HV2	AKKIHEBBAL_66	3:41	5:53	2:11	TRANSFORMER FAULT
976	16-Aug-21	MYSORE	66	HV2	KRPET_220	12:20	17:30	5:10	LINE CLEAR AVAILED
977	16-Aug-21	MYSORE	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	13:31	13:56	0:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
978	16-Aug-21	MYSORE	66	KUSHALNAGARA-RAMANTHAPURA1	ALUR SIDDAPURA_66	4:23	4:31	0:08	LINE FAULT
979	16-Aug-21	MYSORE	66	SB HALLI-MANJUNATHAPURA	SANTHEBACHALLI_66	10:06	20:32	10:26	LINE CLEAR AVAILED
980	16-Aug-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	22:50	22:56	0:05	LINE FAULT
981	16-Aug-21	TUMKUR	66	TR-1	HIRIYUR_66	10:07	10:50	0:43	LINE CLEAR AVAILED
982	16-Aug-21	TUMKUR	66	TR-1	HIRIYUR_66	15:04	16:35	1:30	LINE CLEAR AVAILED
983	16-Aug-21	TUMKUR	66	TR-2	HINDASGHATTA_66	17:04	18:13	1:08	LINE CLEAR AVAILED
984	16-Aug-21	TUMKUR	66	TR-2	KOLALA_66	16:17	17:26	1:08	LINE CLEAR AVAILED
985	16-Aug-21	TUMKUR	66	TR-2	KOLALA_66	18:02	18:59	0:57	LINE CLEAR AVAILED
986	16-Aug-21	TUMKUR	66	TR-2	RAMPURA_66	13:47	15:07	1:19	LINE CLEAR AVAILED
987	16-Aug-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	5:21	5:29	0:08	LINE CLEAR AVAILED
988	16-Aug-21	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	13:30	13:52	0:22	LINE CLEAR AVAILED
989	16-Aug-21	TUMKUR	110	TR-1	KBCROSS_220	13:54	14:12	0:17	LINE CLEAR AVAILED
990	16-Aug-21	TUMKUR	110	TR-1(LV-SIDE)	KBCROSS_220	12:33	12:58	0:24	LINE CLEAR AVAILED
991	16-Aug-21	TUMKUR	110	TR-2	KBCROSS_220	13:30	13:33	0:03	LINE CLEAR AVAILED
992	16-Aug-21	TUMKUR	110	TR-2	KBCROSS_220	14:14	14:29	0:15	LINE CLEAR AVAILED
993	16-Aug-21	TUMKUR	110	TR-2(LV-SIDE)	KBCROSS_220	13:00	13:28	0:27	LINE CLEAR AVAILED
994	16-Aug-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	10:45	19:37	8:52	LINE CLEAR AVAILED
995	16-Aug-21	TUMKUR	220	TR-1	KBCROSS_220	12:33	12:57	0:24	LINE CLEAR AVAILED
996	16-Aug-21	TUMKUR	220	TR-2	KBCROSS_220	13:00	13:51	0:51	LINE CLEAR AVAILED