

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 29.06.21 TO 05.07.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	29-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
2	29-Jun-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
3	29-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
4	29-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
5	29-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17(23.02.2021)			LINE OPEN,LINE FAULT
6	29-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
7	29-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39(06.04.2021)			LINE OPEN,LINE CLEAR AVAILED
8	29-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
9	29-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
10	29-Jun-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
11	29-Jun-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
12	29-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN,LINE CLEAR AVAILED
13	29-Jun-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
14	29-Jun-2021	BAGALKOT	110	(KIRVATTI) AMBEWADI-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	8:49 (28.6.2021)			LINE OPEN,LINE CLEAR AVAILED
15	29-Jun-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR CITY_110	8:14	8:32	0:18	LINE CLEAR AVAILED
16	29-Jun-2021	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	STATION NOT AFFECTED GHATAPRABHA_220	4:29	4:41	0:12	LINE FAULT
17	29-Jun-2021	BAGALKOT	110	KARWAR220-BINAGA(SOLARIS)	BINAGA_110	11:15	12:04	0:49	LINE CLEAR AVAILED
18	29-Jun-2021	BAGALKOT	110	HIDIKAL-ISLAMPUR	ISLAMPUR_110	4:30	4:45	0:15	LINE FAULT
19	29-Jun-2021	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	12:22	14:16	1:54	HAND TRIPPED
20	29-Jun-2021	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	STATION NOT AFFECTED MK HUBLI_220	8:33	14:10	5:37	LINE CLEAR AVAILED
21	29-Jun-2021	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	9:18	13:45	4:27	NFBC ISSUED
22	29-Jun-2021	BAGALKOT	110	110/11KV,(HV3)HV2	RATTIHALI_110	13:03	15:15	2:12	LINE CLEAR AVAILED
23	29-Jun-2021	BAGALKOT	110	VAJRAMATTI- MANTU(KD JAMBAGI)	KD JAMBAGI_110	11:49	12:07	0:18	LINE FAULT
24	29-Jun-2021	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	12:08	13:20	1:12	LINE CLEAR AVAILED
25	29-Jun-2021	BAGALKOT	110	VADAGOAN- BELGAUM	VADAGOAN_110	9:01	13:53	4:52	LINE CLEAR AVAILED
26	29-Jun-2021	BAGALKOT	220	HUBLI- NARENDRA2	HUBLI_220	9:17	13:44	4:27	LINE CLEAR AVAILED
27	29-Jun-2021	BAGALKOT	220	HUBLI- NAGJHARI3	HUBLI_220	10:36	12:24	1:48	LINE CLEAR AVAILED
28	29-Jun-2021	BAGALKOT	220	HUBLI- NAGJHARI3	HUBLI_220	12:49	13:38	0:49	LINE CLEAR AVAILED
29	29-Jun-2021	BAGALKOT	110	110/11KV, HV2	UTTUR_110	11:45	12:13	0:28	TRANSFORMER FAULT
30	29-Jun-2021	BAGALKOT	220	VAJRAMATTI- BAGALKOT2	VAJRAMATTI_220	15:12	16:38	1:26	LINE CLEAR AVAILED
31	29-Jun-2021	BAGALKOT	110	HUBLI- TARIHAL2	TARIHAL_110	12:36	12:37	0:01	LINE CLEAR AVAILED
32	29-Jun-2021	BAGALKOT	110	HUBLI- KADANKOPPA	KADANKOPPA_110	12:27	12:28	0:01	LINE CLEAR AVAILED
33	29-Jun-2021	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	9:18	13:45	4:27	LINE CLEAR AVAILED
34	29-Jun-2021	BAGALKOT	110	SIRSI- ESALE2(SIRSI220)	SIRSI_110	10:25	15:50	5:25	HAND TRIPPED
35	29-Jun-2021	BAGALKOT	110	SIRSI- JOG2	SIRSI_110	10:25	10:51	0:26	HAND TRIPPED
36	29-Jun-2021	BAGALKOT	110	SIRSI- ESALE1(SIRSI220)	SIRSI_110	10:51	11:33	0:42	HAND TRIPPED
37	29-Jun-2021	BAGALKOT	110	SIRSI- JOG2	SIRSI_110	11:16	16:45	5:29	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
38	29-Jun-2021	BENGALURU	66	HV1	B G ROAD	12:45	12:59	0:14	LINE CLEAR AVAIED
39	29-Jun-2021	BENGALURU	66	HV1	BOODIGERE	13:02	13:05	0:03	LINE CLEAR AVAIED
40	29-Jun-2021	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	11:50	11:55	0:05	TRANSFORMER FAULT
41	29-Jun-2021	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	11:10	11:20	0:10	LOAD CHANGE OVER
42	29-Jun-2021	BENGALURU	66	HENNUR CROSS - MANYATHA TECH PARK 220	HENNUR CROSS	16:58	17:14	0:16	MAIN SUPPLY FAILURE
43	29-Jun-2021	BENGALURU	220	HOODY 220 - MANYATHA TECH PARK 220	MANYATHA TECH PARK 220	16:58	17:15	0:17	LINE FAULT
44	29-Jun-2021	BENGALURU	66	HV2	MAHALAKSHMI LAYOUT	11:15	11:25	0:10	LINE CLEAR AVAIED
45	29-Jun-2021	BENGALURU	220	MANYATHA TECH PARK 220 - HOODY 220	MANYATHA TECH PARK 220	16:58	17:15	0:17	LINE FAULT
46	29-Jun-2021	BENGALURU	66	MANYATHA TECH PARK 220 - SAHAKARINAGAR	SAHAKARINAGAR	16:58	17:15	0:17	LINE CLEAR AVAIED
47	29-Jun-2021	BENGALURU	66	HV3	MANYATHA TECH PARK 220	16:58	17:15	0:17	LINE CLEAR AVAIED
48	29-Jun-2021	BENGALURU	66	HV1	PATH PALYA	14:37	14:47	0:09	TRANSFORMER FAULT
49	29-Jun-2021	BENGALURU	66	HV1	MANCHENAHALLI	13:41	13:45	0:03	LINE CLEAR AVAIED
50	29-Jun-2021	BENGALURU	66	HV1	MANCHENAHALLI	15:59	16:05	0:05	LINE CLEAR AVAIED
51	29-Jun-2021	BENGALURU	66	HV1	MAGADI 66	15:32	15:44	0:11	TRANSFORMER FAULT
52	29-Jun-2021	BENGALURU	66	HV1	KYALANUR	12:47	13:32	0:44	LINE CLEAR AVAIED
53	29-Jun-2021	BENGALURU	66	HV2	HAROBELE	13:40	13:45	0:05	LINE CLEAR AVAIED
54	29-Jun-2021	BENGALURU	66	HV1	HAROBELE	14:29	14:35	0:05	LINE CLEAR AVAIED
55	29-Jun-2021	BENGALURU	66	HV2	HOSKOTE 66	11:25	12:14	0:49	LINE CLEAR AVAIED
56	29-Jun-2021	BENGALURU	66	HV2	ANEKAL	12:45	13:00	0:14	TRANSFORMER FAULT
57	29-Jun-2021	BENGALURU	66	HV1	CHAKAVELU	21:25	21:33	0:08	LINE CLEAR AVAIED
58	29-Jun-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	14:27	14:58	0:30	LINE FAULT
59	29-Jun-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	7:18	7:25	0:06	LINE FAULT
60	29-Jun-2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	7:37	7:40	0:03	LINE FAULT
61	29-Jun-2021	BENGALURU	220	HV1	SARJAPURA 220	12:54	13:31	0:37	MAIN SUPPLY FAILURE
62	29-Jun-2021	BENGALURU	220	HV2	SARJAPURA 220	12:55	13:30	0:35	MAIN SUPPLY FAILURE
63	29-Jun-2021	BENGALURU	66	HV1	SARJAPURA 220	12:54	13:32	0:38	MAIN SUPPLY FAILURE
64	29-Jun-2021	BENGALURU	66	HV2	SARJAPURA 220	12:54	13:32	0:38	MAIN SUPPLY FAILURE
65	29-Jun-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:55	13:33	0:37	MAIN SUPPLY FAILURE
66	29-Jun-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:55	13:33	0:38	MAIN SUPPLY FAILURE
67	29-Jun-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:55	13:43	0:47	MAIN SUPPLY FAILURE
68	29-Jun-2021	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	12:54	13:29	0:34	LINE FAULT
69	29-Jun-2021	BENGALURU	220	MALUR 220 - HOODY 400	NO STATION AFFECTED	12:00	14:35	2:35	LINE CLEAR AVAIED
70	29-Jun-2021	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	18:25	18:46	0:21	LINE FAULT
71	29-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:36:16(28-6-2021)	17:09:09(29-6-2021)	22:31HRS	LINE CHARGED
72	29-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
73	29-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
74	29-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:10:08(29-6-2021)			LINE OPEN,LINE FAULT
75	29-Jun-2021	GULBARGA	220	SINDHANOOR-LINGAPUR	SINDHANOOR_220	11:18	15:30	4:12	LINE CLEAR AVAIED
76	29-Jun-2021	GULBARGA	220	HALBARGA-HUMNABAD1	HALBARGA_220	15:30	16:12	0:42	LINE CLEAR AVAIED
77	29-Jun-2021	GULBARGA	220	HALBARGA-HUMNABAD2	HALBARGA_220	16:20	16:45	0:25	LINE CLEAR AVAIED
78	29-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	23:43(28.06.2021)	6:36(29.06.2021)	6:53HRS	LINE CHARGED
79	29-Jun-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	9:01	19:35	10:34	LINE CLEAR AVAIED
80	29-Jun-2021	GULBARGA	110	BISIHALLI-ALIPUR	BISIHALLI_110	10:45	11:06	0:21	MAIN SUPPLY FAILURE
81	29-Jun-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:05	5:20	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
82	29-Jun-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRAGUPPA_110,TEKKALKOTE_110	0:55	1:05	0:10	LINE FAULT
83	29-Jun-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	10:40	18:25	7:45	LINE CLEAR AVAILED
84	29-Jun-2021	GULBARGA	110	SINDHANOOR- THURVIHAL	THURVIHAL_110	11:05	13:25	2:20	LINE CLEAR AVAILED
85	29-Jun-2021	GULBARGA	110	KAVITAL-MALLAT	KAVITHAL_110	11:20	11:25	0:05	LINE CLEAR AVAILED
86	29-Jun-2021	GULBARGA	110	KAVITAL-GMSH_IPP	KAVITHAL_110	11:26	12:01	0:10	LINE CLEAR AVAILED
87	29-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	1:35	1:45	1:10	LINE FAULT
88	29-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110,MANVI_110	4:46	4:54	2:10	LINE FAULT
89	29-Jun-2021	GULBARGA	110	YELBURGA-PRPJSR	YLEBURGA_110	18:43	22:45	4:02	LINE CLEAR AVAILED
90	29-Jun-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	18:28	18:48	0:20	LINE CLEAR AVAILED
91	29-Jun-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	20:05	20:20	0:15	LINE FAULT
92	29-Jun-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	23:02	23:28	0:26	LINE FAULT
93	29-Jun-2021	GULBARGA	110	MALLAT-BYAGAWAT-2	ADVIAMARESHWARA_110	20:37(06.06.2021)	09:35(29.06.2021)	504HRS	LINE CHARGED
94	29-Jun-2021	GULBARGA	110	MALLAT-BYAGAWAT-2	ADVIAMARESHWARA_110	19:55	20:05	0:10	LINE FAULT
95	29-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:24	20:34	0:10	LINE FAULT
96	29-Jun-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:37	21:47	0:10	LINE FAULT
97	29-Jun-2021	GULBARGA	110	MALLAT-BYAGAWAT-1	BYAGAWAT_110,VALKAMDINNI_110	21:49	21:59	0:10	LINE FAULT
98	29-Jun-2021	GULBARGA	110	MALLAT-BYAGAWAT-2	ADVIAMARESHWARA_110	22:08	22:22	0:14	LINE FAULT
99	29-Jun-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:37	13:15	1:38	LINE CLEAR AVAILED
100	29-Jun-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	19:07	19:28	0:21	LINE FAULT
101	29-Jun-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:35	21:55	0:20	LINE FAULT
102	29-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
103	29-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
104	29-Jun-2021	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
105	29-Jun-2021	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:00	13:47	2:47	LINE CLEAR AVAILED
106	29-Jun-2021	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	11:01	14:05	3:04	LINE CLEAR AVAILED
107	29-Jun-2021	HASSAN	110	HV2	DMKURKE_110	12:00	13:30	1:30	LINE CLEAR AVAILED
108	29-Jun-2021	HASSAN	110	HV1	DMKURKE_110	13:35	15:30	1:55	LINE CLEAR AVAILED
109	29-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	10:49	11:15	0:26	LINE FAULT
110	29-Jun-2021	HASSAN	110	HV2	KADUR_220	10:31	11:06	0:35	HAND TRIPPED
111	29-Jun-2021	HASSAN	110	KADUR-TNGL	KADUR_220	11:13	14:17	3:04	LINE CLEAR AVAILED
112	29-Jun-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:03	12:05	2:02	LINE CLEAR AVAILED
113	29-Jun-2021	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:48	14:29	3:41	NFBC ISSUED
114	29-Jun-2021	HASSAN	110	HV2	NAVUNDA_110	11:44	12:06	0:22	LINE CLEAR AVAILED
115	29-Jun-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	9:59	16:40	6:41	LINE CLEAR AVAILED
116	29-Jun-2021	HASSAN	110	HV2	SORABA_110	9:59	11:40	1:41	LINE CLEAR AVAILED
117	29-Jun-2021	HASSAN	66	HV1	HALEBEEDU_66	11:04	11:36	0:32	TRANSFORMER FAULT
118	29-Jun-2021	HASSAN	66	HV1	HALLYMYSORE_66	11:51	13:12	1:21	LINE CLEAR AVAILED
119	29-Jun-2021	HASSAN	66	HV1	HIEMAGALUR_66	10:47	15:32	4:45	LINE CLEAR AVAILED
120	29-Jun-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	15:50	16:05	0:15	HAND TRIPPED
121	29-Jun-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	12:15	12:20	0:05	HAND TRIPPED
122	29-Jun-2021	HASSAN	66	HV1	MAGGE_66	16:02	16:12	0:10	MAIN SUPPLY FAILURE
123	29-Jun-2021	HASSAN	66	HV2	MAGGE_66	16:02	16:12	0:10	MAIN SUPPLY FAILURE
124	29-Jun-2021	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	16:00	16:08	0:08	HAND TRIPPED
125	29-Jun-2021	HASSAN	66	HV1	SHANTHIGRAMA_66	12:15	13:54	1:39	LINE CLEAR AVAILED
126	29-Jun-2021	HASSAN	66	HV2	SHANTHIGRAMA_66	10:40	12:35	1:55	LINE CLEAR AVAILED
127	29-Jun-2021	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:06	10:10	0:04	LINE FAULT
128	29-Jun-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	9:35	18:21	8:46	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
129	29-Jun-2021	MYSURU	66	KUSHALNAGARA-RAMANATHAPURA 1	ALUR SIDDAPURA_66 KANAGAL_66	10:50	11:01	0:11	LINE FAULT
130	29-Jun-2021	MYSURU	66	CR NAGARA -KABBALLI	KABHALLY_66	17:08	17:29	0:20	LINE FAULT
131	29-Jun-2021	MYSURU	66	CR NAGARA -GUNDLUPETE 2	TERAKANAMBE_66	17:08	17:23	0:14	LINE FAULT
132	29-Jun-2021	MYSURU	66	HV1	ANEGOLAL_66	11:04	13:29	2:25	LINE CLEAR AVAILED
133	29-Jun-2021	MYSURU	66	HV2	ANEGOLAL_66	13:30	15:25	1:55	LINE CLEAR AVAILED
134	29-Jun-2021	MYSURU	66	HANNUR-AMP SOLAR	NO STATIONS EFFECTED	18:43	18:52	0:09	LINE FAULT
135	29-Jun-2021	MYSURU	66	HV1	JAKKANAHALLY_66	12:30	14:05	1:35	LINE CLEAR AVAILED
136	29-Jun-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	18:21	18:26	0:04	LINE FAULT
137	29-Jun-2021	MYSURU	66	HV1	MEGALAPURA_66	14:33	16:03	1:30	LINE CLEAR AVAILED
138	29-Jun-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	15:09 (09/06/2021)	13:26 (29/06/2021)	478:17HRS	LINE CHARGED
139	29-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
140	29-Jun-2021	TUMKUR	110	TR-1	DODDAGUNI_110	14:30	16:33	2:02	LINE CLEAR AVAILED
141	29-Jun-2021	TUMKUR	66	ANCHEPALYA-VIJAYASTEEL	VIJAYASTEEL_66	9:28	9:33	0:05	LINE FAULT
142	29-Jun-2021	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	11:50	18:36	6:46	HAND TRIPPED
143	29-Jun-2021	TUMKUR	66	TR-1	BRAMASANDRA_66	14:29	15:52	1:22	LINE CLEAR AVAILED
144	29-Jun-2021	TUMKUR	66	BRAMASANDRA-KORA	BRAMASANDRA_66	15:37	15:50	0:13	LINE CLEAR AVAILED
145	29-Jun-2021	TUMKUR	66	DEVARAHALLI-HONNALLI(CHANNAGIRI)	DEVARAHALLI_66	9:23	9:24	0:01	MAIN SUPPLY FAILURE
146	29-Jun-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	9:23	9:24	0:01	MAIN SUPPLY FAILURE
147	29-Jun-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66,MEL EKATTE_66	17:13	17:27	0:14	HAND TRIPPED
148	29-Jun-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:07	12:15	0:08	HAND TRIPPED
149	29-Jun-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	17:13	17:27	0:14	HAND TRIPPED
150	29-Jun-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	17:02	17:13	0:10	HAND TRIPPED
151	29-Jun-2021	TUMKUR	66	TR-2(LV-2)	DAVANAGERE_220	17:13	17:28	0:14	HAND TRIPPED
152	29-Jun-2021	TUMKUR	66	TR-2	HINDUSGATTA_66	17:42	19:01	1:19	LINE CLEAR AVAILED
153	29-Jun-2021	TUMKUR	66	TR-2	HIRIYUR_66	16:35	16:57	0:21	LINE CLEAR AVAILED
154	29-Jun-2021	TUMKUR	66	LINGADAHALLI-NALLUR	LINGADAHALLI_66	9:19	9:24	0:05	LINE FAULT
155	29-Jun-2021	TUMKUR	66	TR-1	LINGADAHALLI_66	13:58	14:05	0:06	TRANSFORMER FAULT
156	29-Jun-2021	TUMKUR	66	TR-2	MALEBENNUR_66	10:44	15:25	4:40	LINE CLEAR AVAILED
157	29-Jun-2021	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66	13:58	14:07	0:09	LINE FAULT
158	29-Jun-2021	TUMKUR	66	TR-2	RAMAPURA_66	11:10	11:15	0:04	TRANSFORMER FAULT
159	30-Jun-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
160	30-Jun-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
161	30-Jun-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
162	30-Jun-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
163	30-Jun-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
164	30-Jun-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
165	30-Jun-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)	20:22 (30.06.2021)	610:43HRS	LINE CHARGED
166	30-Jun-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
167	30-Jun-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
168	30-Jun-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
169	30-Jun-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
170	30-Jun-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN,LINE CLEAR AVAILED
171	30-Jun-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
172	30-Jun-2021	BAGALKOT	110	(KIRVATTI) AMBEWADI-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	8:49 (28.6.2021)			LINE OPEN,LINE CLEAR AVAILED
173	30-Jun-2021	BAGALKOT	220	AMBEWADI-PONDA1 (XELDOM)	STATION NOT AFFECTED AMBEWADI_220	12:29	13:08	0:39	LINE FAULT
174	30-Jun-2021	BAGALKOT	110	ANKOLA-KUMTA2	STATION NOT AFFECTED ANKOLA_110	10:13	14:10	3:57	NFBC ISSUED
175	30-Jun-2021	BAGALKOT	110	BABLESHWAR-RENEVABLE SOLAR (MAMADAPUR)	STATION NOT AFFECTED ANKOLA_110	19:21	19:49	0:28	LINE CLEAR AVAILED
176	30-Jun-2021	BAGALKOT	220	BIDNAL-HARTI2	STATION NOT AFFECTED BIDNAL_220	15:05	20:27	5:22	LINE FAULT
177	30-Jun-2021	BAGALKOT	110	110/11KV, HV2 (HV1)	STATION NOT AFFECTED DAVALESHWAR_110	19:14	21:43	2:29	TRANSFORMER FAULT
178	30-Jun-2021	BAGALKOT	110	GADAG220-BETAGERI	BETAGERI_110	12:21	13:00	0:39	LINE CLEAR AVAILED
179	30-Jun-2021	BAGALKOT	110	ITNAL-BAGALKOT220	STATION NOT AFFECTED ITNAL_110	10:50	12:16	1:26	LINE CLEAR AVAILED
180	30-Jun-2021	BAGALKOT	220	KUDACHI-ATHANI	STATION NOT AFFECTED KUDACHI_220	14:22	16:07	1:45	HAND TRIPPED
181	30-Jun-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUKARTIHAL_110	18:28	20:05	1:37	LINE CLEAR AVAILED
182	30-Jun-2021	BAGALKOT	110	RANEENNUR220- TUMMINAKATTI(RATHIHALLI)	STATION NOT AFFECTED RANEENNUR_220	13:34	17:16	3:42	LINE CLEAR AVAILED
183	30-Jun-2021	BAGALKOT	110	RATHIHALLI-HIREKERUR(RANEENNUR)	STATION NOT AFFECTED RATHIHALLI_110	22:10 (22.05.2021)	13:34 (30.06.2021)	927:24HRS	LINE CHARGED
184	30-Jun-2021	BAGALKOT	110	110/11KV,HV1	VAJRAMATTI_110	15:41	16:18	0:37	LINE CLEAR AVAILED
185	30-Jun-2021	BAGALKOT	110	110/11KV,HV1	UKKALI_110	15:43	15:55	0:12	TRANSFORMER FAULT
186	30-Jun-2021	BAGALKOT	110	110/11KV,HV1 & HV2	TUMMINAKATTI_110	14:00	17:20	3:20	HAND TRIPPED
187	30-Jun-2021	BAGALKOT	110	TUMMINAKATTI-RATTIHALLI	TUMMINAKATTI_110	14:01	17:29	3:28	NFBC ISSUED
188	30-Jun-2021	BAGALKOT	110	SIRSI-KUMATA 2	STATI NOT AFFECTED SIRSI_110	9:21	16:45	7:24	NFBC ISSUED
189	30-Jun-2021	BENGALURU	66	HV1	EPIP 220	14:43	14:47	0:04	TRANSFORMER FAULT
190	30-Jun-2021	BENGALURU	66	HV1	EPIP 220	14:51	14:53	0:02	TRANSFORMER FAULT
191	30-Jun-2021	BENGALURU	66	HV1	EPIP 220	14:56	15:08	0:12	TRANSFORMER FAULT
192	30-Jun-2021	BENGALURU	66	GURUVINAPURA - B V HALLI	B V HALLI	15:21	15:40	0:19	LINE FAULT
193	30-Jun-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	10:35	10:55	0:20	LINE FAULT
194	30-Jun-2021	BENGALURU	66	HV2	HSR LAYOUT 220	12:50	13:03	0:13	LINE CLEAR AVAILED
195	30-Jun-2021	BENGALURU	66	HV3	HSR LAYOUT 220	13:53	14:31	0:38	LINE CLEAR AVAILED
196	30-Jun-2021	BENGALURU	66	HV1	KHODAYS 220	10:33	10:35	0:02	LINE CLEAR AVAILED
197	30-Jun-2021	BENGALURU	66	HV1	NATIONAL COLLEGE	11:27	11:30	0:03	LINE CLEAR AVAILED
198	30-Jun-2021	BENGALURU	66	HV1	PRIMAL	13:15	13:30	0:15	LINE CLEAR AVAILED
199	30-Jun-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	13:21	14:10	0:49	LINE CLEAR AVAILED
200	30-Jun-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	10:50	11:15	0:25	LINE CLEAR AVAILED
201	30-Jun-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	13:40	13:53	0:13	LOAD CURTAILMENT
202	30-Jun-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	13:40	13:53	0:13	LOAD CURTAILMENT
203	30-Jun-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	13:40	13:53	0:13	LOAD CURTAILMENT
204	30-Jun-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	13:40	13:53	0:13	LOAD CURTAILMENT
205	30-Jun-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	17:40	17:45	0:05	LINE CLEAR AVAILED
206	30-Jun-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	17:40	17:45	0:05	LINE CLEAR AVAILED
207	30-Jun-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	17:40	17:45	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
208	30-Jun-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	17:40	17:45	0:05	LINE CLEAR AVAIED
209	30-Jun-2021	BENGALURU	220	MITTEMARI 220	LV1	13:40	17:44	4:04	LINE FAULT
210	30-Jun-2021	BENGALURU	66	HV1	GOWRIBIDANUR 220	15:45	15:57	0:12	TRANSFORMER FAULT
211	30-Jun-2021	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	13:10	15:02	1:52	LOAD CURTAILMENT
212	30-Jun-2021	BENGALURU	66	HV1	BANGARPET	18:34	18:50	0:15	TRANSFORMER FAULT
213	30-Jun-2021	BENGALURU	66	HV1	DOMMASANDRA	5:38	5:53	0:14	TRANSFORMER FAULT
214	30-Jun-2021	BENGALURU	66	HV1	DOMMASANDRA	8:24	8:28	0:04	TRANSFORMER FAULT
215	30-Jun-2021	BENGALURU	66	HV2	GUNDAMGERE	13:45	13:55	0:10	TRANSFORMER FAULT
216	30-Jun-2021	BENGALURU	66	HV1	HOSKOTE 66	16:47	16:51	0:03	TRANSFORMER FAULT
217	30-Jun-2021	BENGALURU	66	HV1	HOSOR RAMAPURA	14:20	14:35	0:15	TRANSFORMER FAULT
218	30-Jun-2021	BENGALURU	66	HV2	MAGADI 66	13:10	16:17	3:07	LINE CLEAR AVAIED
219	30-Jun-2021	BENGALURU	66	HV1	MULBAGLU	11:06	11:16	0:10	LINE CLEAR AVAIED
220	30-Jun-2021	BENGALURU	66	HV2	MULBAGLU	14:52	14:56	0:04	LINE CLEAR AVAIED
221	30-Jun-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:09	18:26	0:16	LINE FAULT
222	30-Jun-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:19	13:30	0:10	LINE CLEAR AVAIED
223	30-Jun-2021	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	13:19	13:30	0:10	LINE CLEAR AVAIED
224	30-Jun-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	14:42	14:53	0:11	LOAD CHANGE OVER
225	30-Jun-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
226	30-Jun-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
227	30-Jun-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:10:08(29-6-2021)			LINE OPEN,LINE FAULT
228	30-Jun-2021	GULBARGA	110	RTPS-MUNIRABAD(GD HALLI)	GD HALLI_110	11:12	17:24	6:12	LINE CLEAR AVAIED
229	30-Jun-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	2:17	5:55	3:38	LINE CLEAR AVAIED
230	30-Jun-2021	GULBARGA	110	VALKAMDINNI-BYAGAWAT(RAICHUR1)	BYAGAWAT_110	4:45	15:30	10:45	LINE CLEAR AVAIED
231	30-Jun-2021	GULBARGA	110	HV2	SINDHANOOR_110	5:14	5:25	0:11	TRANSFORMER FAULT
232	30-Jun-2021	GULBARGA	110	HV1	KUDITINI_110	12:58	15:10	2:12	LINE CLEAR AVAIED
233	30-Jun-2021	GULBARGA	110	NALWAR-CLNSLR	NALWAR_110	11:32	12:00	0:28	LINE FAULT
234	30-Jun-2021	GULBARGA	110	HV1	KUDITINI_110	15:56	16:16	0:20	LINE CLEAR AVAIED
235	30-Jun-2021	GULBARGA	110	MALLAT-BYAGAWAT-1	BYAGAWAT_110	21:45	21:50	0:05	LINE CLEAR AVAIED
236	30-Jun-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	1:35	1:45	0:10	LINE FAULT
237	30-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	4:46	4:54	0:08	LINE FAULT
238	30-Jun-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	15:12	15:15	0:03	LINE FAULT
239	30-Jun-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,SUGAR FACTORY IPP,CHOWDAPUR IPP	13:16	13:45	0:29	LINE CLEAR AVAIED
240	30-Jun-2021	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	13:40	14:07	0:27	LINE CLEAR AVAIED
241	30-Jun-2021	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110,MARAGUTTI_110	13:40	14:05	0:25	LINE CLEAR AVAIED
242	30-Jun-2021	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110,GULBARGA SOUTH_110	13:40	14:12	0:32	LINE CLEAR AVAIED
243	30-Jun-2021	GULBARGA	110	LV1	KAPNOOR_220	13:41	14:03	0:22	LINE CLEAR AVAIED
244	30-Jun-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,SUGAR FACTORY IPP,CHOWDAPUR IPP	13:55	14:06	0:11	LINE CLEAR AVAIED
245	30-Jun-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:14	21:27	0:13	LINE FAULT
246	30-Jun-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:07	22:18	0:11	LINE FAULT
247	30-Jun-2021	GULBARGA	110	MALLAT-BYGWAT	BYGWAT_110	21:30	22:00	0:30	MAIN SUPPLY FAILURE
248	30-Jun-2021	GULBARGA	66	MUNIRABAD-MSD LINE	HANASI_66	6:12	6:17	0:05	LINE FAULT
249	30-Jun-2021	GULBARGA	66	MUNIRABAD-MSD LINE	HANASI_66	9:40	9:55	0:15	LINE FAULT
250	30-Jun-2021	HASSAN	110	JOG-JLT3	mghejog_gen	22:12(16.06.2021)	16:00(30.06.2021)	329:48hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
251	30-Jun-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)			LINE OPEN,LINE CLEAR AVAILED
252	30-Jun-2021	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
253	30-Jun-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:02 (30.06.2021)			LINE OPEN,LINE CLEAR AVAILED
254	30-Jun-2021	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	11:36	14:48	3:12	NFBC ISSUED
255	30-Jun-2021	HASSAN	110	HV1	KEMAR_220	22:10	22:34	0:24	LINE CLEAR AVAILED
256	30-Jun-2021	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_220	9:16	9:41	0:25	LINE FAULT
257	30-Jun-2021	HASSAN	110	MRSSTM-MYSORE	MRSMSG_220	12:10	13:37	1:27	LINE FAULT
258	30-Jun-2021	HASSAN	110	SHIVAPUR-BIRUR	SHIVAPURA_110	11:10	13:55	2:45	LINE CLEAR AVAILED
259	30-Jun-2021	HASSAN	110	HV1	SHIVAPURA_110	10:19	14:05	3:46	LINE CLEAR AVAILED
260	30-Jun-2021	HASSAN	110	HIVAPUR-NERLEKERE	SHIVAPURA_110	11:10	13:54	2:44	LINE CLEAR AVAILED
261	30-Jun-2021	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	18:33	19:02	0:29	LINE CLEAR AVAILED
262	30-Jun-2021	HASSAN	66	HV1	SALAGAME_66	12:23	13:05	0:42	LINE CLEAR AVAILED
263	30-Jun-2021	HASSAN	66	HV2	SALAGAME_66	12:23	13:05	0:42	LINE CLEAR AVAILED
264	30-Jun-2021	MYSURU	66	CR NAGARA -YALANDUR	NO STATIONS EFFECTED	13:28	13:41	0:12	LINE FAULT
265	30-Jun-2021	MYSURU	66	CR NAGARA -KOLLEGALA	NO STATIONS EFFECTED	17:25	17:39	0:13	LINE FAULT
266	30-Jun-2021	MYSURU	66	HV2	MADDUR-	13:56	14:32	0:36	LINE CLEAR AVAILED
267	30-Jun-2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	5:12	5:17	0:05	LINE FAULT
268	30-Jun-2021	MYSURU	66	HV2	MALAVALLI_66	12:50	13:44	0:54	LINE CLEAR AVAILED
269	30-Jun-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
270	30-Jun-2021	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 1	PAVAGADA_220	3:36	3:48	0:11	LINE FAULT
271	30-Jun-2021	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 1	PAVAGADA_220	4:13	9:03	4:49	LINE FAULT
272	30-Jun-2021	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 1	PAVAGADA_220	10:03	10:08	0:04	LINE FAULT
273	30-Jun-2021	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI2	PAVAGADA_220	4:13	4:21	0:08	LINE FAULT
274	30-Jun-2021	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	3:36	3:58	0:21	TRANSFORMER FAULT
275	30-Jun-2021	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	4:13	4:34	0:20	TRANSFORMER FAULT
276	30-Jun-2021	TUMKUR	220	TR-2(HV SIDE)	PAVAGADA_220	3:36	3:59	0:22	TRANSFORMER FAULT
277	30-Jun-2021	TUMKUR	220	TR-2(HV SIDE)	PAVAGADA_220	4:13	4:37	0:23	TRANSFORMER FAULT
278	30-Jun-2021	TUMKUR	110	TR-2	TURUVEKERE_110	7:21	7:44	0:22	HAND TRIPPED
279	30-Jun-2021	TUMKUR	110	TR-1(HV SIDE)	KATRIKEHAL_66	12:14	14:33	2:19	LINE CLEAR AVAILED
280	30-Jun-2021	TUMKUR	110	TR-1(LV SIDE)	KATRIKEHAL_66	12:14	14:33	2:19	LINE CLEAR AVAILED
281	30-Jun-2021	TUMKUR	110	TR-2	TIMMANAHALLI_110	11:08	17:35	6:27	LINE CLEAR AVAILED
282	30-Jun-2021	TUMKUR	110	TR-2	TIMMANAHALLI_110	18:01	19:31	1:30	LINE CLEAR AVAILED
283	30-Jun-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	0:30	0:39	0:09	LINE FAULT
284	30-Jun-2021	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	5:40	5:55	0:15	MAIN SUPPLY FAILURE
285	30-Jun-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:03	11:12	0:08	LINE FAULT
286	30-Jun-2021	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	18:39	18:48	0:09	LINE FAULT
287	30-Jun-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	18:25	18:34	0:08	MAIN SUPPLY FAILURE
288	30-Jun-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	19:03	19:13	0:10	MAIN SUPPLY FAILURE
289	30-Jun-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	5:45	5:55	0:09	MAIN SUPPLY FAILURE
290	30-Jun-2021	TUMKUR	66	TR-2	KOLALA_66	16:06	19:03	2:57	LINE CLEAR AVAILED
291	30-Jun-2021	TUMKUR	66	TR-1	NAGASAMUDRA_66	16:35	16:55	0:19	TRANSFORMER FAULT
292	30-Jun-2021	TUMKUR	66	TR-2	NAYAKANAHATTI_66	13:21	13:26	0:04	TRANSFORMER FAULT
293	30-Jun-2021	TUMKUR	66	TR-2	RAMAPURA_66	11:55	12:45	0:49	LINE CLEAR AVAILED
294	30-Jun-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	8:20	8:56	0:36	LINE CLEAR AVAILED
295	30-Jun-2021	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	11:32	11:35	0:03	TRANSFORMER FAULT
296	30-Jun-2021	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	12:29	12:35	0:06	TRANSFORMER FAULT
297	30-Jun-2021	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	3:36	3:58	0:21	TRANSFORMER FAULT
298	30-Jun-2021	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	4:32	4:34	0:01	TRANSFORMER FAULT
299	30-Jun-2021	TUMKUR	66	TR-2(LV-2)	PAVAGADA_220	3:36	3:59	0:23	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
300	30-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	12:55	12:59	0:03	HAND TRIPPED
301	30-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	13:28	14:30	1:01	HAND TRIPPED
302	30-Jun-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	12:20	12:41	0:20	HAND TRIPPED
303	30-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	13:04	13:08	0:04	HAND TRIPPED
304	30-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	12:59	13:03	0:04	HAND TRIPPED
305	30-Jun-2021	TUMKUR	66	TR-2	ANCHEPALYA_220	12:26	12:40	0:14	HAND TRIPPED
306	30-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	13:24	13:28	0:03	HAND TRIPPED
307	30-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- VIJAYA STEEL	VIJAYA STEEL	12:21	12:25	0:04	HAND TRIPPED
308	30-Jun-2021	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	12:48	12:54	0:06	HAND TRIPPED
309	1-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
310	1-Jul-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
311	1-Jul-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
312	1-Jul-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
313	1-Jul-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
314	1-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
315	1-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
316	1-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
317	1-Jul-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
318	1-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
319	1-Jul-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN,LINE CLEAR AVAILED
320	1-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
321	1-Jul-2021	BAGALKOT	110	(KIRVATTI) AMBEWADI-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	8:49 (28.6.2021)			LINE OPEN,LINE CLEAR AVAILED
322	1-Jul-2021	BAGALKOT	110	110/11KV, HV2	ALBALA_110	8:00	9:08	1:08	HAND TRIPPED
323	1-Jul-2021	BAGALKOT	110	ATHANI- AIGALI	AIGALI_110	8:00	8:55	0:55	LINE FAULT
324	1-Jul-2021	BAGALKOT	110	AIGALI- SAVALAGI	SAVALAGI_110	8:00	9:04	1:04	HAND TRIPPED
325	1-Jul-2021	BAGALKOT	110	110/11KV, HV2	BABLESHWAR_110	18:17	18:39	0:22	LINE CLEAR AVAILED
326	1-Jul-2021	BAGALKOT	110	110/11KV, HV2	HIDIKAL DAM_110	13:06	13:49	0:43	LINE CLEAR AVAILED
327	1-Jul-2021	BAGALKOT	110	HIREBEVNUR- SHIVSAGAR SUGARS	HIREBEVNUR_110	12:17	13:06	0:49	LINE FAULT
328	1-Jul-2021	BAGALKOT	110	KERUR- KONNUR	KERUR_110	12:51	13:17	0:26	LINE CLEAR AVAILED
329	1-Jul-2021	BAGALKOT	110	KERUR- KONNUR	KERUR_110	13:43	13:47	0:04	LINE CLEAR AVAILED
330	1-Jul-2021	BAGALKOT	110	110/11KV, HV1	KULIGERI CROSS_110	10:25	10:53	0:28	LINE CLEAR AVAILED
331	1-Jul-2021	BAGALKOT	110	110/11KV, HV2	LAKMANAHALLI_110	8:17	12:14	3:57	TRANSFORMER FAULT
332	1-Jul-2021	BAGALKOT	110	110/11KV, HV2	LAKMANAHALLI_110	12:42	16:12	3:30	LINE CLEAR AVAILED
333	1-Jul-2021	BAGALKOT	110	110/11KV, HV1	LAKMANAHALLI_110	8:31	11:34	3:03	LINE CLEAR AVAILED
334	1-Jul-2021	BAGALKOT	110	VIJAYANAGAR SUGARS- MUNDARGI	MUNDARGI_110	18:42	19:42	1:00	LINE FAULT
335	1-Jul-2021	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	12:13	13:06	0:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
336	1-Jul-2021	BAGALKOT	220	VAJJRAMATTI-BAGALKOT2	STATION NOT AFFECTED VAJJRAMATTI 220	12:43	12:44	0:01	LINE CLEAR AVAILED
337	1-Jul-2021	BAGALKOT	220	KARWAR220-KADRA1	STATION NOT AFFECTED KARWAR 220	14:54	17:55	3:01	HAND TRIPPED
338	1-Jul-2021	BAGALKOT	220	KARWAR220-KADRA2	STATION NOT AFFECTED KARWAR 220	14:55	17:55	3:00	HAND TRIPPED
339	1-Jul-2021	BAGALKOT	110	KARWAR220-BINAGA(SOLARIS)	STATION NOT AFFECTED KARWAR 220	14:52	15:00	0:08	HAND TRIPPED
340	1-Jul-2021	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR 220	14:52	18:03	3:11	HAND TRIPPED
341	1-Jul-2021	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED KARWAR 220	14:52	18:03	3:11	HAND TRIPPED
342	1-Jul-2021	BAGALKOT	110	110/33KV, HV4	DULAKHED_33, NEVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI 110	12:47	12:53	0:06	TRANSFORMER FAULT
343	1-Jul-2021	BAGALKOT	110	SIRSI-JOG(JOG2)	STATION NOT AFFECTED SIRSI 110	10:20	10:30	0:10	HAND TRIPPED
344	1-Jul-2021	BAGALKOT	110	SIRSI-ESSALE220-2(KAVALAWAD)	STATION NOT AFFECTED SIRSI 110	10:25	11:08	0:43	HAND TRIPPED
345	1-Jul-2021	BAGALKOT	110	SIRSI-ESSALE220-1	STATION NOT AFFECTED SIRSI 110	11:00	11:15	0:15	HAND TRIPPED
346	1-Jul-2021	BAGALKOT	110	PG HUNSHYAL-SATISH SUGARS	SATISH SUGARS_110 STATION NOT AFFECTED PG HUNSHYAL 110	15:38			LINE OPEN,LINE CLEAR AVAILED
347	1-Jul-2021	BENGALURU	66	HV1	KHB	12:44	12:48	0:04	LINE CLEAR AVAILED
348	1-Jul-2021	BENGALURU	66	HV2	KHB	11:45	12:00	0:15	LINE CLEAR AVAILED
349	1-Jul-2021	BENGALURU	66	HV2	KODIGEHALLI	19:49	20:03	0:14	LINE CLEAR AVAILED
350	1-Jul-2021	BENGALURU	66	HV1	MATHIKERE	8:08	8:43	0:35	TRANSFORMER FAULT
351	1-Jul-2021	BENGALURU	66	NRS 220 - VIJAY NGR MY2	NO STATION AFFECTED	15:50	16:56	1:06	LINE FAULT
352	1-Jul-2021	BENGALURU	66	HV2	PADMANABHANAGARA	11:53	12:05	0:12	TRANSFORMER FAULT
353	1-Jul-2021	BENGALURU	66	HV1	VIJAYANAGARA	15:50	15:56	0:06	MAIN SUPPLY FAILURE
354	1-Jul-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	18:22	18:29	0:07	LINE FAULT
355	1-Jul-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	18:22	18:30	0:07	LINE FAULT
356	1-Jul-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	0:09	0:13	0:04	LINE FAULT
357	1-Jul-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	9:01	9:09	0:08	LINE FAULT
358	1-Jul-2021	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	1:08	1:11	0:03	LOAD CHANGE OVER
359	1-Jul-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	21:28	21:36	0:07	MAIN SUPPLY FAILURE
360	1-Jul-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	21:28	21:36	0:07	MAIN SUPPLY FAILURE
361	1-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	21:28	21:36	0:07	MAIN SUPPLY FAILURE
362	1-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	21:28	21:36	0:07	MAIN SUPPLY FAILURE
363	1-Jul-2021	BENGALURU	66	HV2	MANCHENAHALLI	15:25	16:21	0:56	LINE CLEAR AVAILED
364	1-Jul-2021	BENGALURU	66	HV1	M GOLLAHALLI	18:10	18:26	0:16	TRANSFORMER FAULT
365	1-Jul-2021	BENGALURU	66	HV2	BANGARPET	19:13	19:45	0:32	LINE CLEAR AVAILED
366	1-Jul-2021	BENGALURU	66	LV1	MITTEMARI 220	21:28	21:31	0:03	TRANSFORMER FAULT
367	1-Jul-2021	BENGALURU	66	LV1	MITTEMARI 220	21:31	21:36	1:03	TRANSFORMER FAULT
368	1-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
369	1-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
370	1-Jul-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:10:08(29-6-2021)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
371	1-Jul-2021	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	2:37	3:06	0:29	LINE FAULT
372	1-Jul-2021	GULBARGA	110	HV1	SANKLAPUR_110	11:01	11:06	0:05	TRANSFORMER FAULT
373	1-Jul-2021	GULBARGA	110	PDHALLI-CLNSLR	PD_HALLI_66	15:50	17:37	1:47	LINE CLEAR AVAILED
374	1-Jul-2021	GULBARGA	110	HV1	KAVITAL_110	18:25	18:30	0:05	LINE CLEAR AVAILED
375	1-Jul-2021	GULBARGA	110	HV2	SHAKTINAGAR_110	11:24	12:22	0:58	LINE CLEAR AVAILED
376	1-Jul-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110,SRNAGAR_110,KARATAGI_110	12:05	14:11	2:06	MAIN SUPPLY FAILURE
377	1-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT-1	BYAGAWAT_110	21:45(30.6.2021)	21:50(30.6.2021)	0.05HRS	LINE CHARGED
378	1-Jul-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIAMARESHWARA_110	2:55	3:05	0:10	MAIN SUPPLY FAILURE
379	1-Jul-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	10:36	11:41	1:05	LINE CLEAR AVAILED
380	1-Jul-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	10:46	10:51	0:05	LINE CLEAR AVAILED
381	1-Jul-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	14:47	14:50	0:03	LINE CLEAR AVAILED
382	1-Jul-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	14:05	15:10	1:05	LINE CLEAR AVAILED
383	1-Jul-2021	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
384	1-Jul-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:02 (30.06.2021)			LINE OPEN,LINE CLEAR AVAILED
385	1-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	14:55(16.06.2021)	10:37 (1.07.2021)	739:42hrs	LINE CHARGED
386	1-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
387	1-Jul-2021	HASSAN	110	HV1	MADHUVANA_110	23:22(1.7.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
388	1-Jul-2021	HASSAN	220	HV1	HGGUNJE_220	11:25	14:40	3:15	LINE CLEAR AVAILED
389	1-Jul-2021	HASSAN	220	HV2	HGGUNJE_220	14:44	15:48	1:04	LINE CLEAR AVAILED
390	1-Jul-2021	HASSAN	110	LV1	HGGUNJE_220	11:25	14:40	3:15	LINE CLEAR AVAILED
391	1-Jul-2021	HASSAN	110	LV2	HGGUNJE_220	14:44	15:48	1:04	LINE CLEAR AVAILED
392	1-Jul-2021	HASSAN	220	KEMARKavoor1	KEMAR_220	10:20	12:00	1:40	LINE CLEAR AVAILED
393	1-Jul-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:15	12:00	1:45	NFBC ISSUED
394	1-Jul-2021	HASSAN	110	HV2	BAIKAMPADY_110	10:23	10:59	0:36	LINE CLEAR AVAILED
395	1-Jul-2021	HASSAN	110	HV1	BARANGI_110	10:40	11:08	0:28	LINE CLEAR AVAILED
396	1-Jul-2021	HASSAN	110	HV1	ESSUR_110	13:40	14:21	0:41	LINE CLEAR AVAILED
397	1-Jul-2021	HASSAN	110	HV2	ESSUR_110	13:30	15:10	1:40	LINE CLEAR AVAILED
398	1-Jul-2021	HASSAN	110	HV1	KONAJE_110	9:21	9:25	0:04	HAND TRIPPED
399	1-Jul-2021	HASSAN	110	HV2	KONAJE_110	9:21	9:25	0:04	HAND TRIPPED
400	1-Jul-2021	HASSAN	110	HV3	KONAJE_110	9:21	9:25	0:04	HAND TRIPPED
401	1-Jul-2021	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	6:19	6:30	0:11	LINE FAULT
402	1-Jul-2021	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	6:19	6:30	0:11	LINE FAULT
403	1-Jul-2021	HASSAN	110	HV3	SAGARA_110	13:25	14:31	1:06	LINE CLEAR AVAILED
404	1-Jul-2021	HASSAN	110	SALATHU-KONAJE	SALATHUR_110	9:55	13:16	3:21	NFBC ISSUED
405	1-Jul-2021	HASSAN	110	HV1	SORABA_110	10:53	11:20	0:27	LINE CLEAR AVAILED
406	1-Jul-2021	HASSAN	66	HV2	HALEBEEDU_66	12:48	13:11	0:23	LINE CLEAR AVAILED
407	1-Jul-2021	HASSAN	66	HV1	HANGRANAHALLY_66	11:24	11:30	0:06	TRANSFORMER FAULT
408	1-Jul-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	16:17	16:32	0:15	HAND TRIPPED
409	1-Jul-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	16:34	18:37	2:03	LINE CLEAR AVAILED
410	1-Jul-2021	HASSAN	66	HV1	MAGGE_66	16:25	16:36	0:11	MAIN SUPPLY FAILURE
411	1-Jul-2021	HASSAN	66	HV1	MAGGE_66	16:42	18:38	1:56	MAIN SUPPLY FAILURE
412	1-Jul-2021	HASSAN	66	HV2	MAGGE_66	16:25	16:36	0:11	MAIN SUPPLY FAILURE
413	1-Jul-2021	HASSAN	66	HV2	MAGGE_66	16:42	18:38	1:56	MAIN SUPPLY FAILURE
414	1-Jul-2021	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	4:04	4:24	0:20	LINE FAULT
415	1-Jul-2021	HASSAN	66	HV1	RAMESHWARNAGARA_66	13:36	13:52	0:16	HAND TRIPPED
416	1-Jul-2021	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	16:22	16:33	0:11	HAND TRIPPED
417	1-Jul-2021	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	16:41	18:37	1:56	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
418	1-Jul-2021	MYSURU	66	HV1	DKMAIDANA_66	10:18	17:32	7:14	LINE CLEAR AVAILED
419	1-Jul-2021	MYSURU	66	HV1	HANGLA_66	13:36	13:58	0:22	LINE CLEAR AVAILED
420	1-Jul-2021	MYSURU	66	HV2	HANGLA_66	11:50	13:15	1:25	LINE CLEAR AVAILED
421	1-Jul-2021	MYSURU	66	HV1	HARADANAHALLI(JAK)_66	12:19	12:30	0:10	LINE CLEAR AVAILED
422	1-Jul-2021	MYSURU	66	HV2	KRNAGARA_66	11:00	11:34	0:34	LINE CLEAR AVAILED
423	1-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
424	1-Jul-2021	TUMKUR	110	TR-2	MAYASANDRA_110	10:02	10:26	0:19	HAND TRIPPED
425	1-Jul-2021	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	17:27	17:35	0:19	LINE CLEAR AVAILED
426	1-Jul-2021	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	18:54	21:34	0:19	LINE CLEAR AVAILED
427	1-Jul-2021	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	17:26	17:33	0:19	LINE FAULT
428	1-Jul-2021	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	SEI VENUS DIAMOND_IPP_66	18:54	21:34	0:19	LINE CLEAR AVAILED
429	1-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:33	15:44	0:19	LINE FAULT
430	1-Jul-2021	TUMKUR	66	TR-3	HARIYABBE_66	10:17	10:21	0:19	TRANSFORMER FAULT
431	1-Jul-2021	TUMKUR	66	TR-3	HARIYABBE_66	10:28	10:33	0:19	TRANSFORMER FAULT
432	1-Jul-2021	TUMKUR	66	TR-3	HARIYABBE_66	17:49	17:52	0:19	LINE CLEAR AVAILED
433	1-Jul-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:54	19:08	0:19	LINE FAULT
434	1-Jul-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	12:27	12:40	0:19	LINE FAULT
435	1-Jul-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	12:59	13:49	0:19	LINE CLEAR AVAILED
436	1-Jul-2021	TUMKUR	66	TR-1	HONNALI_66	18:26	18:58	0:19	LINE CLEAR AVAILED
437	1-Jul-2021	TUMKUR	66	TR-2	HONNUDIKE_66	22:13	23:08	0:19	TRANSFORMER FAULT
438	1-Jul-2021	TUMKUR	66	TR-1	IDHALLY_66	8:29	10:24	0:19	LINE CLEAR AVAILED
439	1-Jul-2021	TUMKUR	66	TR-2	IDHALLY_66	13:09	14:35	0:19	LINE CLEAR AVAILED
440	1-Jul-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS1_EHT_66	16:46	16:53	0:19	HAND TRIPPED
441	1-Jul-2021	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	16:47	18:46	0:19	LINE CLEAR AVAILED
442	1-Jul-2021	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	BADAVANAHALLI_66	16:46	18:47	0:19	LINE CLEAR AVAILED
443	1-Jul-2021	TUMKUR	66	TR-1	BADAVANAHALLI_66	16:46	18:48	0:19	LINE CLEAR AVAILED
444	1-Jul-2021	TUMKUR	66	TR-2	BADAVANAHALLI_66	16:46	18:48	0:19	LINE CLEAR AVAILED
445	1-Jul-2021	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	16:46	18:47	0:19	LINE CLEAR AVAILED
446	1-Jul-2021	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	8:57	9:08	0:19	LINE FAULT
447	1-Jul-2021	TUMKUR	66	TR-1	MATHOD_66	6:33	6:43	0:19	TRANSFORMER FAULT
448	1-Jul-2021	TUMKUR	66	TR-2	MATHOD_66	18:34	18:38	0:19	TRANSFORMER FAULT
449	1-Jul-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	16:17	16:18	0:19	TRANSFORMER FAULT
450	1-Jul-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	10:29	10:40	0:19	TRANSFORMER FAULT
451	1-Jul-2021	TUMKUR	66	TR-1	TUMKUR_66	15:43	15:54	0:19	HAND TRIPPED
452	2-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
453	2-Jul-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
454	2-Jul-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
455	2-Jul-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
456	2-Jul-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
457	2-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
458	2-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
459	2-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
460	2-Jul-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
461	2-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
462	2-Jul-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN,LINE CLEAR AVAILED
463	2-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
464	2-Jul-2021	BAGALKOT	110	(KIRVATTI) AMBEWADI-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	8:49 (28.6.2021)			LINE OPEN,LINE CLEAR AVAILED
465	2-Jul-2021	BAGALKOT	110	PG HUNSHYAL-SATISH SUGARS	SATISH SUGARS_110 STATION NOT AFFECTED PG HUNSHYAL_110	15:38 (01.07.2021)			LINE OPEN,LINE CLEAR AVAILED
466	2-Jul-2021	BAGALKOT	110	110/11KV,HV 2	ANKALI_110	16:42	16:54	0:12	HAND TRIPPED
467	2-Jul-2021	BAGALKOT	110	BIJAPUR220-ENERCON(BAGEWADI)	BIJAPUR_220	16:42	16:47	0:05	LINE FAULT
468	2-Jul-2021	BAGALKOT	110	HALIAL-ALNAVAR(GMR)	HALIYAL_110	4:32	5:39	1:07	LINE FAULT
469	2-Jul-2021	BAGALKOT	110	110/11KV,HV2	HIDIKALDAM_110	12:00	13:26	1:26	LINE CLEAR AVAILED
470	2-Jul-2021	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	12:05	12:31	0:26	LINE CLEAR AVAILED
471	2-Jul-2021	BAGALKOT	110	110/11KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	14:09	14:39	0:30	TRANSFORMER FAULT
472	2-Jul-2021	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	15:57	19:44	3:47	LINE CLEAR AVAILED
473	2-Jul-2021	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	10:32	19:44	9:12	LINE CLEAR AVAILED
474	2-Jul-2021	BENGALURU	66	HV1	EPIP 220	3:36	3:42	0:06	TRANSFORMER FAULT
475	2-Jul-2021	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	12:12	12:34	0:22	MAIN SUPPLY FAILURE
476	2-Jul-2021	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	12:12	12:34	0:22	MAIN SUPPLY FAILURE
477	2-Jul-2021	BENGALURU	66	GOKULA - MATHIKERE	MATHIKERE	12:12	12:17	0:05	LINE FAULT
478	2-Jul-2021	BENGALURU	66	HV1	HANUMANTHNAGARA	11:45	12:18	0:33	LINE CLEAR AVAILED
479	2-Jul-2021	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	13:00	13:10	0:10	LINE FAULT
480	2-Jul-2021	BENGALURU	66	IISC - HEBBAL 220	IISC	12:32	12:37	0:05	LOAD CHANGE OVER
481	2-Jul-2021	BENGALURU	66	IISC - NRS 220	IISC	15:35	15:41	0:06	LOAD CHANGE OVER
482	2-Jul-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	12:12	12:17	0:05	MAIN SUPPLY FAILURE
483	2-Jul-2021	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	15:20	15:25	0:05	LOAD CHANGE OVER
484	2-Jul-2021	BENGALURU	66	HV1	REMCO	13:15	13:23	0:08	LINE CLEAR AVAILED
485	2-Jul-2021	BENGALURU	66	HV2	REMCO	13:15	13:23	0:08	LINE CLEAR AVAILED
486	2-Jul-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	12:10	12:21	0:11	MAIN SUPPLY FAILURE
487	2-Jul-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	15:16	15:18	0:02	LOAD CHANGE OVER
488	2-Jul-2021	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, BEL (EHT), HMT (EHT)	12:12	12:34	0:22	LINE FAULT
489	2-Jul-2021	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, BEL (EHT), HMT (EHT)	12:12	12:34	0:22	LINE FAULT
490	2-Jul-2021	BENGALURU	66	HV1	SIDDALAGATTA	18:13	19:20	1:07	LINE CLEAR AVAILED
491	2-Jul-2021	BENGALURU	66	HV2	YELAHANKA 220	13:25	13:27	0:01	LINE CLEAR AVAILED
492	2-Jul-2021	BENGALURU	66	HV1	YELAHANKA 220	9:38	9:40	0:01	LINE CLEAR AVAILED
493	2-Jul-2021	BENGALURU	66	HV2	JANGAMKOTE	10:56	11:02	0:06	LINE CLEAR AVAILED
494	2-Jul-2021	BENGALURU	66	HV2	JANGAMKOTE	12:28	12:37	0:09	LINE CLEAR AVAILED
495	2-Jul-2021	BENGALURU	66	HV1	KGF	15:06	15:28	0:21	LINE CLEAR AVAILED
496	2-Jul-2021	BENGALURU	66	HV1	HOSKOTE 66	15:51	15:55	0:04	TRANSFORMER FAULT
497	2-Jul-2021	BENGALURU	66	HV1	HONNIGANAHALLI	14:09	16:55	2:45	LINE CLEAR AVAILED
498	2-Jul-2021	BENGALURU	66	HV2	HONNIGANAHALLI	14:09	16:55	2:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
499	2-Jul-2021	BENGALURU	66	HV2	ANEKAL	15:08	15:12	0:03	LINE CLEAR AVAILED
500	2-Jul-2021	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	17:20	17:24	0:04	LOAD CHANGE OVER
501	2-Jul-2021	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLSANDRA, DALSANUR	8:08	9:11	1:03	LINE CLEAR AVAILED
502	2-Jul-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	14:55	14:58	0:03	LOAD CHANGE OVER
503	2-Jul-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	14:55	14:58	0:03	LOAD CHANGE OVER
504	2-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	14:55	14:58	0:03	LOAD CHANGE OVER
505	2-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	14:55	14:58	0:03	LOAD CHANGE OVER
506	2-Jul-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	18:32	18:36	0:04	LINE FAULT
507	2-Jul-2021	BENGALURU	66	HV1	MITTEMARI 220	18:15	18:20	0:05	TRANSFORMER FAULT
508	2-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
509	2-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
510	2-Jul-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:10:08(29-6-2021)			LINE OPEN,LINE FAULT
511	2-Jul-2021	GULBARGA	220	ITTAGI-NEELGUNDA	NEELGUNDA_220	10:59	16:59	6:00	LINE CLEAR AVAILED
512	2-Jul-2021	GULBARGA	110	BYAGAWAT-MALLAT	BYAGAWAT_110	5:20	5:35	0:15	MAIN SUPPLY FAILURE
513	2-Jul-2021	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	5:45	5:50	0:05	MAIN SUPPLY FAILURE
514	2-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT-2	ADVIAMARESHWARA_110	22:08(29.06.2021)	22:22(02.07.2021)	72:14HRS	LINE CHARGED
515	2-Jul-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	11:03	11:37	0:34	LINE FAULT
516	2-Jul-2021	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	17:03	17:15	0:12	LINE FAULT
517	2-Jul-2021	GULBARGA	110	HV2	SINDHANOOR_110	17:35	17:57	0:22	TRANSFORMER FAULT
518	2-Jul-2021	GULBARGA	110	SINDHANOOR110-SINDHANOOR2(IDLE LINE)	SINDHANOOR_110	0:40	0:45	0:05	LINE FAULT
519	2-Jul-2021	GULBARGA	110	SINDHANOOR110-SINDHANOOR2(IDLE LINE)	SINDHANOOR_110	2:40	2:45	0:05	LINE FAULT
520	2-Jul-2021	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	13:10	13:25	0:15	MAIN SUPPLY FAILURE
521	2-Jul-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110	1:55	2:05	0:10	LINE FAULT
522	2-Jul-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERA DONA_110,SR NAGAR_110,MALLAPUR_110	2:55	3:10	0:15	LINE FAULT
523	2-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	4:58	5:13	0:15	LINE FAULT
524	2-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	5:14	5:25	0:11	LINE FAULT
525	2-Jul-2021	GULBARGA	110	SINDHANOOR-ADAVIAMARESHWARA	ADAVIAMARESHWARA_110	5:26	7:11	1:45	LINE FAULT
526	2-Jul-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KERE HALLI_110,MALLAPURA_110	11:03	11:55	0:52	LINE FAULT
527	2-Jul-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KERE HALLI_110,MALLAPURA_110	11:06	11:50	0:44	LINE FAULT
528	2-Jul-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KERE HALLI_110,MALLAPURA_110	18:04	18:13	0:09	LINE FAULT
529	2-Jul-2021	GULBARGA	110	MUNIRABAD-KEREHALI	KEREHALI_110	11:05	15:05	4:00	MAIN SUPPLY FAILURE
530	2-Jul-2021	GULBARGA	110	MUNIRABAD-KEREHALI	KEREHALI_110	18:05	18:10	0:05	MAIN SUPPLY FAILURE
531	2-Jul-2021	GULBARGA	110	HALBARGA-KOLHAR1	KOLHAR_110,JANWADA_110,NSSK FACTORY	11:06	11:12	0:06	LINE FAULT
532	2-Jul-2021	GULBARGA	110	HALBARGA-KOLHAR2	KOLHAR_110,JANWADA_110,NSSK FACTORY	11:06	11:12	0:06	LINE FAULT
533	2-Jul-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK SUGAR FACTORY IPP	20:40	20:45	0:05	LINE FAULT
534	2-Jul-2021	GULBARGA	66	HV1	HANASI_66	13:22	13:34	0:12	TRANSFORMER FAULT
535	2-Jul-2021	GULBARGA	66	ITTAGI-HIREHADAGALI1&2	HIREHADAGALI_66	12:15	13:35	1:20	LINE CLEAR AVAILED
536	2-Jul-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	15:20	15:40	0:20	LINE FAULT
537	2-Jul-2021	HASSAN	110	HV1	MADHUVANA_110	23:22(1.7.2021)	9:18(2.06.2021)	9:55 hrs	TRANSFORMER CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
538	2-Jul-2021	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)	14:14 (2.07.2021)	224:53 hrs	TRANSFORMER CHARGED
539	2-Jul-2021	HASSAN	110	HV1	SHIKARIPURA_110	15:20 (22.06.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
540	2-Jul-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:02 (30.06.2021)			LINE OPEN,LINE CLEAR AVAILED
541	2-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
542	2-Jul-2021	HASSAN	110	HV1	MADHUVANA_110	23:22(1.7.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
543	2-Jul-2021	HASSAN	110	KADUR-NGNHL	KADUR_220	10:41	12:24	1:43	LINE CLEAR AVAILED
544	2-Jul-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	6:50	9:14	2:24	LINE FAULT
545	2-Jul-2021	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	7:02	7:10	0:08	LINE FAULT
546	2-Jul-2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	9:35	13:49	4:14	NFBC ISSUED
547	2-Jul-2021	HASSAN	110	HV1	SHIKARIPURA_110	15:45	16:11	0:26	HAND TRIPPED
548	2-Jul-2021	HASSAN	110	HV2	TALAGUGUPPA_110	10:48	14:09	3:21	HAND TRIPPED
549	2-Jul-2021	HASSAN	66	HV1	MALLAPURA_66	13:05	13:37	0:32	LINE CLEAR AVAILED
550	2-Jul-2021	HASSAN	66	HV1	AREHALLI_HSN_66	13:14	13:40	0:26	LINE CLEAR AVAILED
551	2-Jul-2021	HASSAN	66	HV1	KANDLI_66	13:24	14:10	0:46	LINE CLEAR AVAILED
552	2-Jul-2021	HASSAN	66	HV1	RAMESHWARNAGARA_66	15:30	16:40	1:10	LINE CLEAR AVAILED
553	2-Jul-2021	HASSAN	66	HV2	RAMESHWARNAGARA_66	10:43	12:06	1:23	LINE CLEAR AVAILED
554	2-Jul-2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	12:18	12:27	0:09	LINE CLEAR AVAILED
555	2-Jul-2021	HASSAN	66	HV1	SALAGAME_66	6:00	6:30	0:30	TRANSFORMER FAULT
556	2-Jul-2021	MYSURU	220	KADAKOLA -KOZHIKODE	NO STATIONS EFFECTED	1:56	13:02	11:06	LINE FAULT
557	2-Jul-2021	MYSURU	66	HV1	BILIKERE_66	11:44	14:35	2:51	LINE CLEAR AVAILED
558	2-Jul-2021	MYSURU	66	HV2	BILIKERE_66	7:56	8:06	0:10	TRANSFORMER FAULT
559	2-Jul-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	14:21	16:25	2:04	LINE CLEAR AVAILED
560	2-Jul-2021	MYSURU	66	HV1	GAMANAHALLY_66	17:10	17:15	0:05	HAND TRIPPED
561	2-Jul-2021	MYSURU	66	HV2	HAMPAPURA_66	10:08	10:25	0:17	TRANSFORMER FAULT
562	2-Jul-2021	MYSURU	66	HV2	HDKOTE_66	11:30	12:59	1:28	LINE CLEAR AVAILED
563	2-Jul-2021	MYSURU	66	KIRUGAVALU-MALIYUR	MALIYURU_66	12:17	12:25	0:07	LINE FAULT
564	2-Jul-2021	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	6:23	6:35	0:11	LINE FAULT
565	2-Jul-2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	18:47	18:52	0:05	LINE FAULT
566	2-Jul-2021	MYSURU	66	HV1	TUBINAKERE_220	11:10	12:57	1:47	LINE CLEAR AVAILED
567	2-Jul-2021	MYSURU	66	HV2	TUBINAKERE_220	12:57	15:29	2:31	LINE CLEAR AVAILED
568	2-Jul-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	5:06	5:11	0:04	LINE FAULT
569	2-Jul-2021	MYSURU	66	VAJMANGALA-MEGHALAPURA	MEGALAPURA_66	5:53	6:00	0:07	LINE FAULT
570	2-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
571	2-Jul-2021	TUMKUR	110	TR-1	MAYASANDRA_110	11:15	11:41	0:26	HAND TRIPPED
572	2-Jul-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	10:12	10:29	0:17	LINE FAULT
573	2-Jul-2021	TUMKUR	66	TR-1	BENKIKERE_66	16:02	16:09	0:07	TRANSFORMER FAULT
574	2-Jul-2021	TUMKUR	66	BRAHMASANDRA- SIRA(KALAMBALA)	BRAHMASANDRA_66	9:42	9:55	0:12	LINE FAULT
575	2-Jul-2021	TUMKUR	66	BRAHMASANDRA- KORA (THOVINKERE)	THOVINAKERE_66, KORA_66	10:10	10:40	0:30	LINE FAULT
576	2-Jul-2021	TUMKUR	66	TR-2	CHITRADURGA_220	7:32	8:15	0:43	TRANSFORMER FAULT
577	2-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:51	11:59	0:07	LINE FAULT
578	2-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:09	12:21	0:12	LINE FAULT
579	2-Jul-2021	TUMKUR	66	HINDASGHATTA-HIRIYUR1	HINDASGHATTA_66	11:15	11:20	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
580	2-Jul-2021	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI(NALLUR)	LINGADAHALLI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	8:19	8:30	0:10	LINE FAULT
581	2-Jul-2021	TUMKUR	66	HONNALLI 220kv- LINGADAHALLI(NALLUR)	LINGADAHALLI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	8:40	8:55	0:15	LINE FAULT
582	2-Jul-2021	TUMKUR	66	TR-1	RAMPURA_66	11:04	11:09	0:05	TRANSFORMER FAULT
583	2-Jul-2021	TUMKUR	66	TR-2	SHYLAPURA_66	15:41	15:54	0:13	TRANSFORMER FAULT
584	2-Jul-2021	TUMKUR	66	TR-1	THOVINAKERE_66	10:11	14:42	4:31	LINE CLEAR AVAILED
585	2-Jul-2021	TUMKUR	66	TR-2	THOVINAKERE_66	10:11	14:42	4:30	LINE CLEAR AVAILED
586	2-Jul-2021	TUMKUR	66	TR-1	HALURAMESWARA_66	17:18	17:34	0:16	TRANSFORMER FAULT
587	3-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
588	3-Jul-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
589	3-Jul-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
590	3-Jul-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
591	3-Jul-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
592	3-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
593	3-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
594	3-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
595	3-Jul-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
596	3-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
597	3-Jul-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN,LINE CLEAR AVAILED
598	3-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
599	3-Jul-2021	BAGALKOT	110	(KIRVATTI) AMBEWADI-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	8:49 (28.6.2021)			LINE OPEN,LINE CLEAR AVAILED
600	3-Jul-2021	BAGALKOT	110	PG HUNSHYAL-SATISH SUGARS	SATISH SUGARS_110 STATION NOT AFFECTED PG HUNSHYAL_110	15:38 (01.07.2021)			LINE OPEN,LINE CLEAR AVAILED
601	3-Jul-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	2:16	11:23	9:07	LINE FAULT
602	3-Jul-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	2:18	2:28	0:10	LINE FAULT
603	3-Jul-2021	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	10:28	10:48	0:20	LINE FAULT
604	3-Jul-2021	BAGALKOT	110	220-110KV,LV1	MK HUBLI_220	19:45	22:48	3:03	LINE CLEAR AVAILED
605	3-Jul-2021	BAGALKOT	220	MK HUBLI-NARENDRA1	STATION NOT AFFECTED MK HUBLI_220	17:17	22:28	5:11	LINE FAULT
606	3-Jul-2021	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	12:59	17:58	4:59	LINE FAULT
607	3-Jul-2021	BAGALKOT	220	220/110KV,HV2,LV2	NARENDRA_220	19:22	20:07	0:45	LINE CLEAR AVAILED
608	3-Jul-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED MAHALINGAPUR_220	2:16	11:24	9:08	LINE FAULT
609	3-Jul-2021	BAGALKOT	110	110/11KV,HV1	THORVI_110	13:41	13:43	0:02	LINE CLEAR AVAILED
610	3-Jul-2021	BAGALKOT	110	BIJAPUR220-BIJAPUR CITY	BIJAPUR CITY	6:30	7:42	1:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
611	3-Jul-2021	BAGALKOT	110	HAVERI110-BASAVANAKATTI	STATION NOT AFFECTED BASAVANAKATTI_110	12:07	13:08	1:01	LINE CLEAR AVAILED
612	3-Jul-2021	BAGALKOT	110	HIREHAL-RON	HIREHAL_110	19:21	19:23	0:02	HAND TRIPPED
613	3-Jul-2021	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	18:06	18:10	0:04	TRANSFORMER FAULT
614	3-Jul-2021	BAGALKOT	110	RON-GAMESH	RON_110	19:43	20:18	0:35	LINE CLEAR AVAILED
615	3-Jul-2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	10:11	17:51	7:40	LINE CLEAR AVAILED
616	3-Jul-2021	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	12:59	17:58	4:59	LINE FAULT
617	3-Jul-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	2:16	11:23	9:07	LINE FAULT
618	3-Jul-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED YARAGATTI_110	19:08	19:25	0:17	TRANSFORMER FAULT
619	3-Jul-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)			LINE OPEN,LINE CLEAR AVAILED
620	3-Jul-2021	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)			LINE OPEN,LINE CLEAR AVAILED
621	3-Jul-2021	BAGALKOT	220	GADAG-DHONI1(LINGAPUR1)	STATION NOT AFFECTED GADAG_220	16:49 (03.07.2021)			LINE OPEN,LINE FAULT
622	3-Jul-2021	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI_400	16:49 (03.07.2021)			LINE OPEN,LINE FAULT
623	3-Jul-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SHIRGOAN_110	12:36	12:45	0:09	LINE CLEAR AVAILED
624	3-Jul-2021	BAGALKOT	110	110/11KV,(HV3)HV1	SAVALAGI_110	13:25	13:38	0:13	TRANSFORMER FAULT
625	3-Jul-2021	BAGALKOT	110	110/11KV,(HV3)HV1	SAVALAGI_110	15:47	19:36	3:49	LINE CLEAR AVAILED
626	3-Jul-2021	BENGALURU	66	HULIMANGALA - YARANDANAHALLI 220	HULIMANGALA	8:52	8:58	0:06	LOAD CHANGE OVER
627	3-Jul-2021	BENGALURU	66	HV1	HULIMANGALA	12:23	12:56	0:33	TRANSFORMER FAULT
628	3-Jul-2021	BENGALURU	66	HV2	ISRO LAYOUT	11:53	11:56	0:03	LINE CLEAR AVAILED
629	3-Jul-2021	BENGALURU	66	HV2	ITI 220	9:22	9:39	0:17	TRANSFORMER FAULT
630	3-Jul-2021	BENGALURU	66	KANAKAPURA 220 - T K HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	7:20	7:29	0:09	LINE FAULT
631	3-Jul-2021	BENGALURU	66	KODIGEHALLI - T G HALLI	TAVAREKERE	20:47	21:27	0:40	LINE FAULT
632	3-Jul-2021	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	9:30	9:45	0:15	LOAD CHANGE OVER
633	3-Jul-2021	BENGALURU	66	RAJANUKUNTE - D B PURA 220	RAJANUKUNTE	17:10	17:15	0:05	LOAD CHANGE OVER
634	3-Jul-2021	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	15:15	15:20	0:05	LOAD CHANGE OVER
635	3-Jul-2021	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	9:03	9:08	0:05	LINE CLEAR AVAILED
636	3-Jul-2021	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	9:56	10:25	0:29	LINE FAULT
637	3-Jul-2021	BENGALURU	66	HV2	EPIP 220	2:26	2:32	0:06	TRANSFORMER FAULT
638	3-Jul-2021	BENGALURU	66	HV2	EPIP 220	13:24	13:51	0:27	TRANSFORMER FAULT
639	3-Jul-2021	BENGALURU	66	HV2	MANCHENAHALLI	13:06	13:30	0:23	LINE CLEAR AVAILED
640	3-Jul-2021	BENGALURU	66	SM MANGALA - SUGUTURU	SUGUTURU	14:30	21:20	6:50	MAIN SUPPLY FAILURE
641	3-Jul-2021	BENGALURU	220	LV1	MITTEMARI 220	2:02	12:42	10:40	TRANSFORMER FAULT
642	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	2:02	2:09	0:07	MAIN SUPPLY FAILURE
643	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	2:02	2:09	0:07	MAIN SUPPLY FAILURE
644	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	2:02	2:09	0:07	MAIN SUPPLY FAILURE
645	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	2:02	2:09	0:07	MAIN SUPPLY FAILURE
646	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	12:34	12:45	0:11	LINE CLEAR AVAILED
647	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	12:34	12:45	0:11	LINE CLEAR AVAILED
648	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	12:34	12:45	0:11	LINE CLEAR AVAILED
649	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	12:34	12:45	0:11	LINE CLEAR AVAILED
650	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	15:00	15:07	0:07	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
651	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	15:00	15:07	0:07	MAIN SUPPLY FAILURE
652	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	15:00	15:07	0:07	MAIN SUPPLY FAILURE
653	3-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	15:00	15:07	0:07	MAIN SUPPLY FAILURE
654	3-Jul-2021	BENGALURU	66	HV1	MITTEMARI 220	2:02	2:09	0:07	MAIN SUPPLY FAILURE
655	3-Jul-2021	BENGALURU	66	HV1	MITTEMARI 220	12:34	12:37	0:03	LINE CLEAR AVAILED
656	3-Jul-2021	BENGALURU	66	JIGANI LINK ROAD - JIGANI 220	JIGANI LINK ROAD	9:30	9:35	0:05	LOAD CHANGE OVER
657	3-Jul-2021	BENGALURU	220	MALUR 220 - HOODY 220	MALUR 220	18:25	18:36	0:11	LOAD CHANGE OVER
658	3-Jul-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	14:36	15:28	0:52	MAIN SUPPLY FAILURE
659	3-Jul-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	14:36	15:30	0:54	MAIN SUPPLY FAILURE
660	3-Jul-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	14:36	15:30	0:54	MAIN SUPPLY FAILURE
661	3-Jul-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	14:36	15:43	1:07	MAIN SUPPLY FAILURE
662	3-Jul-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	14:36	15:40	1:04	MAIN SUPPLY FAILURE
663	3-Jul-2021	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	14:36	15:24	0:48	MAIN SUPPLY FAILURE
664	3-Jul-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:25	18:38	0:13	LOAD CHANGE OVER
665	3-Jul-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	18:25	18:38	0:13	LOAD CHANGE OVER
666	3-Jul-2021	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	18:25	18:38	0:13	LOAD CHANGE OVER
667	3-Jul-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:25	18:38	0:13	LOAD CHANGE OVER
668	3-Jul-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	18:25	18:38	0:13	LOAD CHANGE OVER
669	3-Jul-2021	BENGALURU	220	HV1	MALUR 220	18:25	18:38	0:13	LOAD CHANGE OVER
670	3-Jul-2021	BENGALURU	220	HV2	MALUR 220	18:25	18:38	0:13	LOAD CHANGE OVER
671	3-Jul-2021	BENGALURU	220	HV1	MALUR 220	14:36	15:50	1:14	MAIN SUPPLY FAILURE
672	3-Jul-2021	BENGALURU	220	HV2	MALUR 220	14:36	15:50	1:14	MAIN SUPPLY FAILURE
673	3-Jul-2021	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	18:25	18:38	0:13	LOAD CHANGE OVER
674	3-Jul-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	14:36	22:30	7:54	MAIN SUPPLY FAILURE
675	3-Jul-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	14:36	22:12	7:36	MAIN SUPPLY FAILURE
676	3-Jul-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 1	VOKKALERI	14:36	19:38	5:02	MAIN SUPPLY FAILURE
677	3-Jul-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	14:36	19:37	5:01	MAIN SUPPLY FAILURE
678	3-Jul-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	14:36	16:15	1:39	MAIN SUPPLY FAILURE
679	3-Jul-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:36	19:36	5:00	MAIN SUPPLY FAILURE
680	3-Jul-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	14:36	22:20	7:44	MAIN SUPPLY FAILURE
681	3-Jul-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	14:36	22:11	7:35	MAIN SUPPLY FAILURE
682	3-Jul-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	14:36	22:19	7:43	MAIN SUPPLY FAILURE
683	3-Jul-2021	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	14:36	17:27	2:51	MAIN SUPPLY FAILURE
684	3-Jul-2021	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	14:36	17:51	3:15	MAIN SUPPLY FAILURE
685	3-Jul-2021	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	14:36	18:21	3:45	MAIN SUPPLY FAILURE
686	3-Jul-2021	BENGALURU	220	KOLAR 220 - MALUR 3	VIKAS TECH PARK 220	14:36	18:01	3:25	MAIN SUPPLY FAILURE
687	3-Jul-2021	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 1	RAILWAY TRACTION (EHT)	14:36	18:06	3:30	MAIN SUPPLY FAILURE
688	3-Jul-2021	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 2	RAILWAY TRACTION (EHT)	14:36	18:07	3:31	MAIN SUPPLY FAILURE
689	3-Jul-2021	BENGALURU	220	HV1	KOLAR 220	14:36	19:39	5:03	TRANSFORMER FAULT
690	3-Jul-2021	BENGALURU	220	HV2	KOLAR 220	14:36	19:18	4:42	TRANSFORMER FAULT
691	3-Jul-2021	BENGALURU	220	HV3	KOLAR 220	14:36	19:18	4:42	MAIN SUPPLY FAILURE
692	3-Jul-2021	BENGALURU	66	HV1	KOLAR 220	14:36	19:49	5:13	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
693	3-Jul-2021	BENGALURU	220	LV2	KOLAR 220	14:36	19:18	4:42	TRANSFORMER FAULT
694	3-Jul-2021	BENGALURU	66	HV2	KOLAR 220	14:36	19:54	5:18	MAIN SUPPLY FAILURE
695	3-Jul-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	19:30	19:42	0:12	LINE CLEAR AVAILED
696	3-Jul-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	9:29	9:41	0:12	LINE CLEAR AVAILED
697	3-Jul-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	9:33	9:36	0:03	LINE CLEAR AVAILED
698	3-Jul-2021	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	12:45	12:52	0:06	LINE FAULT
699	3-Jul-2021	BENGALURU	220	HV1	YELAHANKA 220	9:51	14:01	4:10	LINE CLEAR AVAILED
700	3-Jul-2021	BENGALURU	220	HV2	YELAHANKA 220	14:04	17:01	2:57	LINE CLEAR AVAILED
701	3-Jul-2021	BENGALURU	66	HV2	NELEMANGALA 66	14:02	14:15	0:12	LINE CLEAR AVAILED
702	3-Jul-2021	BENGALURU	66	HV3	NELEMANGALA 66	14:25	14:33	0:08	LINE CLEAR AVAILED
703	3-Jul-2021	BENGALURU	66	HV1	HBR LAYOUT	15:51	15:55	0:04	LINE CLEAR AVAILED
704	3-Jul-2021	BENGALURU	66	HV2	HBR LAYOUT	15:57	16:01	0:03	LINE CLEAR AVAILED
705	3-Jul-2021	BENGALURU	66	HV2	HOSKOTE 66	16:01	17:37	1:36	TRANSFORMER FAULT
706	3-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
707	3-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
708	3-Jul-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:10:08(29-6-2021)			LINE OPEN,LINE FAULT
709	3-Jul-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	23:37(3-7-21)			LINE OPEN,LINE CLEAR AVAILED
710	3-Jul-2021	BENGALURU	220	LV1	MITTEMARI 220	15:00(3-7-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
711	3-Jul-2021	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	23:20	23:40	0:20	LINE FAULT
712	3-Jul-2021	GULBARGA	220	HV1	KAPNOOR_220	19:17	19:40	0:23	TRANSFORMER FAULT
713	3-Jul-2021	GULBARGA	220	KAPNOOR-SHAHAPUR	KAPNOOR_220	19:17	19:59	0:42	LINE FAULT
714	3-Jul-2021	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	19:17	19:44	0:27	LINE FAULT
715	3-Jul-2021	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	19:17	19:25	0:08	LINE FAULT
716	3-Jul-2021	GULBARGA	220	SEDAM-CLEANMAXSOLAR_IPP	SEDAM_110	20:03	22:46	2:43	LINE CLEAR AVAILED
717	3-Jul-2021	GULBARGA	220	HV2	SHAHAPUR_220	14:23	18:12	3:49	LINE CLEAR AVAILED
718	3-Jul-2021	GULBARGA	110	220KV SINDHANOOR-110KV SINDHANOOR1(IDLE LINE)	SINDHANOOR_110	11:01	14:15	3:14	LINE CLEAR AVAILED
719	3-Jul-2021	GULBARGA	110	MUNIRABAD -MSD(IDLE LINE)	HANASI_66	10:20	13:50	3:30	NFBC ISSUED
720	3-Jul-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	7:20	7:30	0:10	LINE FAULT
721	3-Jul-2021	GULBARGA	110	MUNIRABAD MALLAPURA	MALLAPURA_110	14:00	15:00	1:00	MAIN SUPPLY FAILURE
722	3-Jul-2021	GULBARGA	110	SINDHANOOR-SIRAGUPPA	DHADESUGUR_110,SIRAGUPPA_110, TEKKALKOTE_110	21:07	21:17	0:10	LINE FAULT
723	3-Jul-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110	21:30	22:00	0:30	LINE FAULT
724	3-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	20:21	20:31	0:10	LINE FAULT
725	3-Jul-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_110, MANVI_110	19:44	19:51	0:07	LINE FAULT
726	3-Jul-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGAWATH_110, VALKAMDIINI_110(IDLE)	19:44	19:52	0:08	LINE FAULT
727	3-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	22:59	23:05	0:06	LINE FAULT
728	3-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	23:06	23:19	0:13	LINE FAULT
729	3-Jul-2021	GULBARGA	110	SUZLON-MYLAR	MYLAR_110	14:15	14:25	0:10	MAIN SUPPLY FAILURE
730	3-Jul-2021	GULBARGA	110	SUZLON-MYLAR	MYLAR_110	21:20	21:50	0:30	MAIN SUPPLY FAILURE
731	3-Jul-2021	GULBARGA	110	HV1	SREERAMNAGAR_110	11:15	11:50	0:35	LINE CLEAR AVAILED
732	3-Jul-2021	GULBARGA	110	HV1	SREERAMNAGAR_110	17:55	18:55	1:00	LINE CLEAR AVAILED
733	3-Jul-2021	GULBARGA	110	HV4	YELBURGA_110	13:05	13:07	0:02	LINE CLEAR AVAILED
734	3-Jul-2021	GULBARGA	110	HV2	YELBURGA_110	13:17	13:18	0:01	LINE CLEAR AVAILED
735	3-Jul-2021	GULBARGA	110	HV2	JEWARGI_110	1:20	1:35	0:15	TRANSFORMER FAULT
736	3-Jul-2021	GULBARGA	110	HV3	DEODURGA_110	10:55	11:40	0:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
737	3-Jul-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	7:20	7:30	0:10	LINE FAULT
738	3-Jul-2021	GULBARGA	110	SINDHANOOR-MASKI	MASKI_110	10:30	10:50	0:20	MAIN SUPPLY FAILURE
739	3-Jul-2021	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGAON_110,MARAGUTTI_110	19:19	19:49	0:30	LINE CLEAR AVAILED
740	3-Jul-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110, NSL SUGAR FACTORY	19:19	19:50	0:31	LINE CLEAR AVAILED
741	3-Jul-2021	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	19:19	19:50	0:31	LINE CLEAR AVAILED
742	3-Jul-2021	GULBARGA	110	HV1	SHAHAPUR_220	13:47	18:23	4:36	LINE CLEAR AVAILED
743	3-Jul-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	14:15	18:10	3:55	LINE CLEAR AVAILED
744	3-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	14:10	18:05	3:55	LINE CLEAR AVAILED
745	3-Jul-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	5:05	5:16	0:11	LINE FAULT
746	3-Jul-2021	GULBARGA	66	BADALADUKU-HANASI	HANASI_66	10:15	13:50	3:35	MAIN SUPPLY FAILURE
747	3-Jul-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:02 (30.06.2021)			LINE OPEN,LINE CLEAR AVAILED
748	3-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
749	3-Jul-2021	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	10:43	13:08	2:25	LINE FAULT
750	3-Jul-2021	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:05	13:24	3:19	LINE CLEAR AVAILED
751	3-Jul-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	11:01	13:28	2:27	LINE CLEAR AVAILED
752	3-Jul-2021	HASSAN	110	HV1	HIRENALLUR_110	10:58	11:24	0:26	TRANSFORMER FAULT
753	3-Jul-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:01	13:29	2:28	NFBC ISSUED
754	3-Jul-2021	HASSAN	110	HV2	KEMAR_220	12:29	13:30	1:01	LINE CLEAR AVAILED
755	3-Jul-2021	HASSAN	110	HV1	MADHUVANA_110	9:47	18:33	8:46	LINE CLEAR AVAILED
756	3-Jul-2021	HASSAN	110	SAGARA-ALKLA	SAGARA_110	10:43	13:07	2:24	LINE FAULT
757	3-Jul-2021	HASSAN	110	SAGARA-SS2	SAGARA_110	10:44	11:10	0:26	LINE FAULT
758	3-Jul-2021	HASSAN	110	HV2	SHIKARIPURA_110	10:39	11:10	0:31	LINE CLEAR AVAILED
759	3-Jul-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	15:28	16:19	0:51	LINE FAULT
760	3-Jul-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	16:19	18:00	1:41	LINE FAULT
761	3-Jul-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	18:01	18:03	0:02	HAND TRIPPED
762	3-Jul-2021	HASSAN	110	SORABA-SHR220	SORABA_110	15:30	17:00	1:30	MAIN SUPPLY FAILURE
763	3-Jul-2021	HASSAN	66	HV1	ALDUR_66	16:25	17:37	1:12	LINE CLEAR AVAILED
764	3-Jul-2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	21:29	21:34	0:05	HAND TRIPPED
765	3-Jul-2021	HASSAN	66	HV1	HIRISAVE_66	12:35	13:26	0:51	LINE CLEAR AVAILED
766	3-Jul-2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	9:42	11:39	1:57	LINE CLEAR AVAILED
767	3-Jul-2021	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	10:11	10:20	0:08	LINE FAULT
768	3-Jul-2021	MYSURU	66	HV2	HDKOTE_66	7:10	8:44	1:34	LINE CLEAR AVAILED
769	3-Jul-2021	MYSURU	66	HD KOTE-TARAKA	NO STATIONS EFFECTED	17:48	17:55	0:07	HAND TRIPPED
770	3-Jul-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:58	10:07	0:08	LINE FAULT
771	3-Jul-2021	MYSURU	66	KR PETE 220-MADESHWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	6:14	6:19	0:04	LINE FAULT
772	3-Jul-2021	MYSURU	66	KUSHALNAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPURA_66	9:55	9:58	0:03	HAND TRIPPED
773	3-Jul-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	18:53	18:57	0:04	LINE FAULT
774	3-Jul-2021	MYSURU	66	HV2	YELANDUR_66	10:43	12:30	1:46	LINE CLEAR AVAILED
775	3-Jul-2021	MYSURU	66	HV1	YELANDUR_66	12:10	13:25	1:15	LINE CLEAR AVAILED
776	3-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
777	3-Jul-2021	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	9:10	9:43	0:32	HAND TRIPPED
778	3-Jul-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	9:30	9:38	0:08	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
779	3-Jul-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:11	9:30	0:19	LINE FAULT
780	3-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:10	8:18	0:08	LINE FAULT
781	3-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:27	12:00	0:33	LINE FAULT
782	3-Jul-2021	TUMKUR	66	TR-3	HARIYABBE_66	16:00	16:21	0:21	TRANSFORMER FAULT
783	3-Jul-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:05	9:33	0:27	MAIN SUPPLY FAILURE
784	3-Jul-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:21	15:22	0:00	MAIN SUPPLY FAILURE
785	3-Jul-2021	TUMKUR	66	HONNALLI 220KV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	9:43	9:48	0:05	HAND TRIPPED
786	3-Jul-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:43	9:46	0:03	HAND TRIPPED
787	3-Jul-2021	TUMKUR	66	HONNALLI 220KV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	9:43	9:44	0:01	HAND TRIPPED
788	3-Jul-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	9:43	9:47	0:04	HAND TRIPPED
789	3-Jul-2021	TUMKUR	66	TR-2	HONNUDIKE_66	15:29	16:31	1:01	LINE CLEAR AVAILED
790	3-Jul-2021	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	2:57	3:11	0:13	LINE FAULT
791	3-Jul-2021	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	3:28	7:42	4:13	LINE FAULT
792	3-Jul-2021	TUMKUR	66	TR-1	NAGASAMUDRA_66	18:06	18:18	0:12	TRANSFORMER FAULT
793	3-Jul-2021	TUMKUR	66	PAVAGADA-VENKATAPURA	PAVAGADA_66	10:35	11:54	1:18	LINE CLEAR AVAILED
794	3-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_66	10:34	11:56	1:21	LINE CLEAR AVAILED
795	3-Jul-2021	TUMKUR	66	TR-2	PAVAGADA_66	10:35	11:56	1:21	LINE CLEAR AVAILED
796	3-Jul-2021	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	10:35	11:53	1:17	LINE CLEAR AVAILED
797	3-Jul-2021	TUMKUR	66	TR-1	PDKOTE_66	10:05	10:12	0:06	TRANSFORMER FAULT
798	3-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_220	17:26	17:32	0:05	TRANSFORMER FAULT
799	3-Jul-2021	TUMKUR	66	TR-1	SOKKE_66	16:59	17:18	0:19	HAND TRIPPED
800	3-Jul-2021	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	7:13	7:37	0:23	LINE FAULT
801	4-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
802	4-Jul-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
803	4-Jul-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
804	4-Jul-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
805	4-Jul-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
806	4-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
807	4-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
808	4-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
809	4-Jul-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
810	4-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
811	4-Jul-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)			LINE OPEN,LINE CLEAR AVAILED
812	4-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
813	4-Jul-2021	BAGALKOT	110	(KIRVATTI) AMBEWADI-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	8:49 (28.6.2021)			LINE OPEN,LINE CLEAR AVAILED
814	4-Jul-2021	BAGALKOT	110	PG HUNSHYAL-SATISH SUGARS	SATISH SUGARS_110 STATION NOT AFFECTED PG HUNSHYAL_110	15:38 (01.07.2021)			LINE OPEN,LINE CLEAR AVAILED
815	4-Jul-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)			LINE OPEN,LINE CLEAR AVAILED
816	4-Jul-2021	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)			LINE OPEN,LINE CLEAR AVAILED
817	4-Jul-2021	BAGALKOT	220	GADAG-DHONI1(LINGAPUR1)	STATION NOT AFFECTED GADAG_220	16:49 (03.07.2021)	16:00 (04.07.2021)	23:11HRS	LINE CHARGED
818	4-Jul-2021	BAGALKOT	220	DHONI-GADAG1	STATION NOT AFFECTED DHONI_400	16:49 (03.07.2021)	16:00 (04.07.2021)	23:11HRS	LINE CHARGED
819	4-Jul-2021	BAGALKOT	110	110/33KV,HV1	CHIKKODI_110	12:55	13:05	0:10	TRANSFORMER FAULT
820	4-Jul-2021	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	KANABARGI LAYOUT_110	9:07	17:14	8:07	LINE CLEAR AVAILED
821	4-Jul-2021	BAGALKOT	110	KANABARGI LAYOUT-BELGAUM	KANABARGI LAYOUT_110	17:53	18:27	0:34	NFBC ISSUED
822	4-Jul-2021	BAGALKOT	220	HAVERI220-GUTTUR1	STATION NOT AFFECTED HAVERI_220	12:48	16:08	3:20	LINE FAULT
823	4-Jul-2021	BAGALKOT	110	110/11KV,HV1,HV2,HV3	JAMAKHANDI_110	12:20	12:38	0:18	TRANSFORMER FAULT
824	4-Jul-2021	BAGALKOT	110	110/33KV,HV1A,HV2A	JAMAKHANDI_110	12:20	12:38	0:18	TRANSFORMER FAULT
825	4-Jul-2021	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)- JAMAKHANDI	JAMAKHANDI_110	12:20 (04.07.2021)			LINE OPEN,LINE FAULT
826	4-Jul-2021	BAGALKOT	110	PRABHULINGESHWAR(SIDDAPUR)- JAMAKHANDI	JAMAKHANDI_110	22:25	23:55	1:30	LINE FAULT
827	4-Jul-2021	BAGALKOT	110	110/33KV,HV3	MMCL_33,SSM_33 LAXMESHVAR_110	11:25	11:52	0:27	TRANSFORMER FAULT
828	4-Jul-2021	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	15:02	16:33	1:31	TRANSFORMER FAULT
829	4-Jul-2021	BAGALKOT	110	VAJJARMATTI220-MANTUR1	MANTUR_110	22:23	22:44	0:21	LINE FAULT
830	4-Jul-2021	BAGALKOT	110	VAJJARMATTI220-MANTUR1	MANTUR_110	23:23 (04.07.2021)			LINE OPEN,LINE CLEAR AVAILED
831	4-Jul-2021	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 STATION NOT AFFETCED TAKKALAKI_110	20:00 (03.07.2021)	00:12 (04.07.2021)	4:12HRS	LINE CHARGED
832	4-Jul-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFETCED TAKKALAKI_110	12:06	13:00	0:54	HAND TRIPPED
833	4-Jul-2021	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 STATION NOT AFFETCED TAKKALAKI_110	15:47	15:51	0:04	LINE FAULT
834	4-Jul-2021	BENGALURU	66	HULIMANGALA - NAGANATHPURA 220	HULIMANGALA	17:42	17:52	0:10	LOAD CHANGE OVER
835	4-Jul-2021	BENGALURU	66	KHB - YELAHANKA 220	KHB	9:21	9:30	0:09	LOAD CHANGE OVER
836	4-Jul-2021	BENGALURU	66	KHB - SRS PEENYA 220	KHB	17:11	17:15	0:04	LOAD CHANGE OVER
837	4-Jul-2021	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	11:18	11:35	0:17	LOAD CHANGE OVER
838	4-Jul-2021	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	14:18	14:23	0:05	LOAD CHANGE OVER
839	4-Jul-2021	BENGALURU	66	NRS - VIJAYNAGAR MYS 1	NO STATION AFFECTED	17:46	20:03	2:17	LINE FAULT
840	4-Jul-2021	BENGALURU	66	HV1	VIJAYANAGARA	17:46	17:55	0:09	LOAD CHANGE OVER
841	4-Jul-2021	BENGALURU	66	HV1	VIJAYANAGARA	20:04	20:05	0:01	LOAD CHANGE OVER
842	4-Jul-2021	BENGALURU	220	VIKAS TECH PARK 220 - HSR LAYOUT 220	VIKAS TECH PARK 220	12:40	13:00	0:20	LOAD CHANGE OVER
843	4-Jul-2021	BENGALURU	66	HV1	APPAREL PARK	10:30	14:20	3:50	LINE CLEAR AVAILED
844	4-Jul-2021	BENGALURU	66	HV2	APPAREL PARK	10:30	10:55	0:25	LINE CLEAR AVAILED
845	4-Jul-2021	BENGALURU	66	ELECTRONIC CITY - NAGNATHPURA 220	ELECTRONIC CITY, INFOSYS (EHT)	17:45	17:52	0:07	LOAD CHANGE OVER
846	4-Jul-2021	BENGALURU	66	ATTIBELE - YARANDANAHALLI 220	ATTIBELE	22:40	22:50	1:07	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
847	4-Jul-2021	BENGALURU	66	HV1	ATTIBELE	22:40	23:15	2:07	LINE CLEAR AVAILED
848	4-Jul-2021	BENGALURU	66	HV2	ATTIBELE	13:00	13:05	2:07	LOAD CHANGE OVER
849	4-Jul-2021	BENGALURU	66	HV1	M GOLAHALLI	18:38	18:51	0:12	TRANSFORMER FAULT
850	4-Jul-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:58	11:10	0:12	LINE CLEAR AVAILED
851	4-Jul-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:58	11:10	0:12	LINE CLEAR AVAILED
852	4-Jul-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:00	11:05	0:05	LINE CLEAR AVAILED
853	4-Jul-2021	BENGALURU	220	LV1	SARJAPURA 220	11:03	12:55	1:52	LINE CLEAR AVAILED
854	4-Jul-2021	BENGALURU	220	LV2	SARJAPURA 220	11:03	12:45	1:42	LINE CLEAR AVAILED
855	4-Jul-2021	BENGALURU	66	HV1	SARJAPURA 220	11:14	12:53	1:39	LINE CLEAR AVAILED
856	4-Jul-2021	BENGALURU	66	HV2	SARJAPURA 220	11:14	11:15	0:01	LINE CLEAR AVAILED
857	4-Jul-2021	BENGALURU	66	HV2	SARJAPURA 220	12:46	12:55	0:09	LINE CLEAR AVAILED
858	4-Jul-2021	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220	11:16	12:45	1:29	LINE CLEAR AVAILED
859	4-Jul-2021	BENGALURU	66	ATTUR YELAHANKA - DG 3	WELCASTE STEEL	5:50	5:55	0:05	LINE FAULT
860	4-Jul-2021	BENGALURU	66	ATTUR YELAHANKA - DG 3	ABBIGERE	5:50	6:06	0:16	LINE FAULT
861	4-Jul-2021	BENGALURU	66	WELCASTE STEEL - PEENYA 220	WELCASTE STEEL	8:50	8:54	0:04	LOAD CHANGE OVER
862	4-Jul-2021	BENGALURU	66	ABBIGERE - PEENYA 220	ABBIGERE	8:43	8:46	0:03	LOAD CHANGE OVER
863	4-Jul-2021	BENGALURU	66	SM MANGALA - SUGUTURU	SUGUTURU	0:50	1:53	1:03	LINE FAULT
864	4-Jul-2021	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA, DOMMASANDRA	13:05	13:08	0:03	LOAD CHANGE OVER
865	4-Jul-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	21:08	21:31	0:23	LINE FAULT
866	4-Jul-2021	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT	22:10	22:13	0:03	LOAD CHANGE OVER
867	4-Jul-2021	BENGALURU	220	LV2	DB PURA 220	5:53	6:45	0:52	TRANSFORMER FAULT
868	4-Jul-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	5:53	6:46	0:53	MAIN SUPPLY FAILURE
869	4-Jul-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	5:53	6:46	0:53	MAIN SUPPLY FAILURE
870	4-Jul-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	5:53	6:46	0:53	MAIN SUPPLY FAILURE
871	4-Jul-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	5:53	6:46	0:53	MAIN SUPPLY FAILURE
872	4-Jul-2021	BENGALURU	66	HV1	SOMAYAJJANAHALLI	7:40	8:25	0:45	TRANSFORMER FAULT
873	4-Jul-2021	BENGALURU	66	HV2	HOSKOTE 66	9:35	12:15	2:40	LINE CLEAR AVAILED
874	4-Jul-2021	BENGALURU	220	LV1	MITTEMARI 220	15:00(3-7-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
875	4-Jul-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	23:37(3-7-21)	0:50(4-7-2021)	1:13HRS	LINE CHARGED
876	4-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
877	4-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
878	4-Jul-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:10:08(29-6-2021)			LINE OPEN,LINE FAULT
879	4-Jul-2021	GULBARGA	220	HV1	SHAHABAD_220	1:20	1:34	0:14	TRANSFORMER FAULT
880	4-Jul-2021	GULBARGA	220	HV2	KAPNOOR_220	1:25	1:35	0:10	TRANSFORMER FAULT
881	4-Jul-2021	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	11:54	12:35	0:41	LINE FAULT
882	4-Jul-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	1:30	2:55	1:25	LINE FAULT
883	4-Jul-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	19:30	19:45	0:15	LINE FAULT
884	4-Jul-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	1:30	1:36	0:06	LINE FAULT
885	4-Jul-2021	GULBARGA	110	RAICHUR-SINDHANOOR1(IDLE LINE)	SIRWAR_110,ALKOD_110,BYAGAWATH_110,VALKAMDINNI_110(IDLE)	1:53	1:58	0:05	LINE FAULT
886	4-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	1:11	1:21	0:10	LINE FAULT
887	4-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	4:43	4:53	0:10	LINE FAULT
888	4-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT2	ADAVIAMARESHWARA_110	20:49	20:59	0:10	LINE FAULT
889	4-Jul-2021	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	5:48	5:58	0:10	LINE FAULT
890	4-Jul-2021	GULBARGA	110	KUSHJTAGI-ILKAL1	ILKAL_110	5:26	6:18	0:52	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
891	4-Jul-2021	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR_IPP	KUSHTAGI_220	10:25	11:53	1:28	LINE FAULT
892	4-Jul-2021	GULBARGA	110	HV2	MANVI_110	15:08	15:26	0:18	TRANSFORMER FAULT
893	4-Jul-2021	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	1:20	1:39	0:19	LINE FAULT
894	4-Jul-2021	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	5:15	5:22	0:07	LINE FAULT
895	4-Jul-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	1:20	1:40	0:20	MAIN SUPPLY FAILURE
896	4-Jul-2021	GULBARGA	110	SHAHBAD-NALWAR	NALWAR_110	5:40	5:50	0:10	LINE FAULT
897	4-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	22:47	22:53	0:06	LINE FAULT
898	4-Jul-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:02 (30.06.2021)			LINE OPEN,LINE CLEAR AVAILED
899	4-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
900	4-Jul-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:56	16:31	2:35	LINE FAULT
901	4-Jul-2021	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	8:26	11:02	2:36	LINE FAULT
902	4-Jul-2021	HASSAN	110	HV1	TOGARSI_110	10:30	15:50	5:20	LINE CLEAR AVAILED
903	4-Jul-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	23:52	23:59	0:07	LINE FAULT
904	4-Jul-2021	HASSAN	66	HV1	YESLUR_66	8:47	10:12	1:25	LINE CLEAR AVAILED
905	4-Jul-2021	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	16:20	17:05	0:45	LINE FAULT
906	4-Jul-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	16:20	17:00	0:40	LINE FAULT
907	4-Jul-2021	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	16:20	16:35	0:15	LINE FAULT
908	4-Jul-2021	MYSURU	66	HV1	BASARALU_66	20:45 (04/07/2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
909	4-Jul-2021	MYSURU	66	HV1	BETTADHAPURA_66	11:51	12:27	0:36	LINE CLEAR AVAILED
910	4-Jul-2021	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	18:33	19:00	0:26	LINE FAULT
911	4-Jul-2021	MYSURU	66	HV2	HANNUR_66	22:52	23:05	0:12	TRANSFORMER FAULT
912	4-Jul-2021	MYSURU	66	HV1	HARADANAHALLI(JAK)_66	19:00	19:33	0:33	TRANSFORMER FAULT
913	4-Jul-2021	MYSURU	66	KABHALLY-ATRIA SOLAR	NO STATIONS EFFECTED	23:06	23:32	0:26	LINE FAULT
914	4-Jul-2021	MYSURU	66	KIKKERI-KR PETE	NO STATIONS EFFECTED	14:38	19:45	5:06	HAND TRIPPED
915	4-Jul-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	18:08	18:34	0:26	LINE FAULT
916	4-Jul-2021	MYSURU	220	HV1	KRPET_220	15:04	19:24	4:20	TRANSFORMER FAULT
917	4-Jul-2021	MYSURU	66	KR PETE 220-KR PETE 1	KRPET_66 AKKIEBBAL_66 KIKKERI_66	13:44	18:24	4:39	LINE FAULT
918	4-Jul-2021	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66 CHUNCHUNKATTE_66	13:09	13:22	0:12	LINE FAULT
919	4-Jul-2021	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	BILIKERE_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	13:09	13:21	0:11	LINE FAULT
920	4-Jul-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	20:47	20:59	0:12	TRANSFORMER FAULT
921	4-Jul-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	19:05	19:15	0:09	MAIN SUPPLY FAILURE
922	4-Jul-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	22:57	23:00	0:03	MAIN SUPPLY FAILURE
923	4-Jul-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	22:56	23:00	0:03	MAIN SUPPLY FAILURE
924	4-Jul-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	19:05	19:15	0:10	MAIN SUPPLY FAILURE
925	4-Jul-2021	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	19:05	19:15	0:10	MAIN SUPPLY FAILURE
926	4-Jul-2021	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	22:57	22:59	0:02	MAIN SUPPLY FAILURE
927	4-Jul-2021	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	19:00	19:20	0:19	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
928	4-Jul-2021	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	22:53	23:06	0:13	LINE FAULT
929	4-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
930	4-Jul-2021	TUMKUR	110	TR-1	TURUVEKERE_110	15:46	16:49	1:02	TRANSFORMER FAULT
931	4-Jul-2021	TUMKUR	66	TR-2	BENNEHALLI_66	12:57	13:03	0:06	TRANSFORMER FAULT
932	4-Jul-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	8:40	8:51	0:11	HAND TRIPPED
933	4-Jul-2021	TUMKUR	66	TR-1	CHIKKABANAGERE_66	18:15	18:25	0:09	TRANSFORMER FAULT
934	4-Jul-2021	TUMKUR	66	TR-2	CHIKKABANAGERE_66	8:40	8:51	0:10	HAND TRIPPED
935	4-Jul-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	8:57	9:09	0:11	LINE FAULT
936	4-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:46	11:54	0:08	LINE FAULT
937	4-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:48	13:10	0:21	LINE FAULT
938	4-Jul-2021	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:57	15:03	0:05	LINE FAULT
939	4-Jul-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:57	12:01	0:03	LINE FAULT
940	4-Jul-2021	TUMKUR	66	TR-2	HIRIYUR_66	22:31	23:02	0:30	HAND TRIPPED
941	4-Jul-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:49	18:57	0:07	LINE FAULT
942	4-Jul-2021	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	6:29	6:43	0:13	LINE FAULT
943	4-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_66	11:06	11:15	0:08	TRANSFORMER FAULT
944	4-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_220	15:01	15:10	0:08	TRANSFORMER FAULT
945	4-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_220	21:01	21:03	0:01	TRANSFORMER FAULT
946	4-Jul-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	8:07	8:45	0:38	LINE CLEAR AVAILED
947	4-Jul-2021	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	18:26	19:05	0:39	LINE FAULT
948	5-Jul-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
949	5-Jul-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
950	5-Jul-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
951	5-Jul-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
952	5-Jul-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
953	5-Jul-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
954	5-Jul-2021	BAGALKOT	110	ATHANI220-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN,LINE CLEAR AVAILED
955	5-Jul-2021	BAGALKOT	110	NAVANAGAR-BAGALKOT2	STATION NOT AFFECTED NAVANAGAR(B)_110	12:29 (14.06.2021)			LINE OPEN,LINE CLEAR AVAILED
956	5-Jul-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
957	5-Jul-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
958	5-Jul-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	13:36 (23.06.2021)	11:46 (05.07.2021)	286:10HRS	LINE CHARGED
959	5-Jul-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
960	5-Jul-2021	BAGALKOT	110	(KIRVATTI) AMBEWADI-UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	8:49 (28.6.2021)	17:52 (05.07.2021)	177:03HRS	LINE CHARGED
961	5-Jul-2021	BAGALKOT	110	PG HUNSHYAL-SATISH SUGARS	SATISH SUGARS_110 STATION NOT AFFECTED PG HUNSHYAL_110	15:38 (01.07.2021)			LINE OPEN,LINE CLEAR AVAILED
962	5-Jul-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:46 (03.07.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
963	5-Jul-2021	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	10:09 (03.07.2021)			LINE OPEN,LINE CLEAR AVAILED
964	5-Jul-2021	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)- JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	12:20 (04.07.2021)			LINE OPEN,LINE FAULT
965	5-Jul-2021	BAGALKOT	110	VAJJARMATTI220-MANTUR1	STATION NOT AFFECTED MANTUR_110	23:23 (04.07.2021)	11:29 (05.07.2021)	12:06HRS	LINE CHARGED
966	5-Jul-2021	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	STATION NOT AFFECTED GHATAPRABHA_220	6:50	7:08	0:18	LINE FAULT
967	5-Jul-2021	BAGALKOT	110	110/11KV,HV3	KULIGOD_110	15:09	17:03	1:54	LINE CLEAR AVAILED
968	5-Jul-2021	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(NAGANUR)	PG HUNSHYAL_110	8:05	9:30	1:25	LINE CLEAR AVAILED
969	5-Jul-2021	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	19:21	19:28	0:07	LOAD CURTAILMENT
970	5-Jul-2021	BAGALKOT	110	110/33KV,HV3	LAXMESHWAR_110	18:10	19:27	1:17	TRANSFORMER FAULT
971	5-Jul-2021	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	19:21	19:30	0:09	LOAD CURTAILMENT
972	5-Jul-2021	BAGALKOT	110	220/110KV,HV2,LV2	NARENDRA_220	19:22	20:07	0:45	LINE CLEAR AVAILED
973	5-Jul-2021	BAGALKOT	110	110/11KV,HV1	ANAND NAGAR_110	16:03	16:46	0:43	LINE CLEAR AVAILED
974	5-Jul-2021	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	17:14	20:26	3:12	LINE FAULT
975	5-Jul-2021	BAGALKOT	110	110/11KV,HV1	ATHARGA_110	19:22	19:33	0:11	LOAD CURTAILMENT
976	5-Jul-2021	BAGALKOT	110	110/11KV,HV2(HV4)	GAJENDRAGAD_110	19:21	19:26	0:05	LOAD CURTAILMENT
977	5-Jul-2021	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	17:24	18:27	1:03	TRANSFORMER FAULT
978	5-Jul-2021	BAGALKOT	110	110/33KV,HV1	PALA_33 STATION NOT AFFECTED HANAGAL_110	19:23	19:43	0:20	LOAD CURTAILMENT
979	5-Jul-2021	BAGALKOT	110	110/33KV,HV3	KOLIGUDDA_33 STATION NOT AFFECTED HIDIKAL_110	19:23	19:28	0:05	LOAD CURTAILMENT
980	5-Jul-2021	BAGALKOT	110	HIREHAL-RON	RON_110	12:48	13:08	0:20	HAND TRIPPED
981	5-Jul-2021	BAGALKOT	110	JAMBAGI-HALKI(MUDHOL)	HALKI_110	23:51	23:56	0:05	LINE FAULT
982	5-Jul-2021	BAGALKOT	110	110/11KV,HV2	KUDAL SANGAM_110	19:21	19:28	0:07	LOAD CURTAILMENT
983	5-Jul-2021	BAGALKOT	110	110/11KV,HV2	MAMADAPUR(B)_110	18:59	19:10	0:11	TRANSFORMER FAULT
984	5-Jul-2021	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	19:22	19:31	0:09	LOAD CURTAILMENT
985	5-Jul-2021	BAGALKOT	110	110/11KV,HV2	RANNABELAGALI_110	17:43	17:46	0:03	TRANSFORMER FAULT
986	5-Jul-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	7:05	7:17	0:12	LINE FAULT
987	5-Jul-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	7:05	7:17	0:12	LINE FAULT
988	5-Jul-2021	BAGALKOT	220	HUBLI-BIDNAL1	STATION NOT AFFECTED HUBLI_220	11:35	19:35	8:00	LINE CLEAR AVAILED
989	5-Jul-2021	BAGALKOT	220	BIDNAL-HUBLI1	STATION NOT AFFECTED BIDNAL_220	10:57	19:35	8:38	NFBC ISSUED
990	5-Jul-2021	BAGALKOT	220	AMBEWADI-XELDOM (PONDA1)	XELDOM_220	12:31	13:55	1:24	LINE FAULT
991	5-Jul-2021	BAGALKOT	220	AMBEWADI-NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	12:12	14:24	2:12	LINE CLEAR AVAILED
992	5-Jul-2021	BAGALKOT	110	110/33KV, HV4	DULKHED_33, NEVARGI_33, HALASANGI_33 STATION NOT AFFECTED ZALKI_110	15:03	17:38	2:35	TRANSFORMER FAULT
993	5-Jul-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TODALBAGI_110	19:21	19:27	0:06	LOAD CURTAILMENT
994	5-Jul-2021	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	18:09	18:14	0:05	LINE FAULT
995	5-Jul-2021	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	18:52	19:08	0:16	LINE CLEAR AVAILED
996	5-Jul-2021	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED SAVALAGI_110	17:09	17:38	0:29	LINE CLEAR AVAILED
997	5-Jul-2021	BENGALURU	66	HV1	BYADRAHALLI	15:15	15:22	0:07	LINE CLEAR AVAILED
998	5-Jul-2021	BENGALURU	66	HV2	BYADRAHALLI	15:25	15:30	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
999	5-Jul-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK (EHT)	9:09	9:37	0:28	LINE FAULT
1000	5-Jul-2021	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	2:45	13:33	10:48	LINE FAULT
1001	5-Jul-2021	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGARA	15:15	15:19	0:04	LOAD CHANGE OVER
1002	5-Jul-2021	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGARA	17:14	17:17	0:03	LOAD CHANGE OVER
1003	5-Jul-2021	BENGALURU	66	HV2	PADMANABHANAGARA	11:23	11:27	0:04	LINE CLEAR AVAIED
1004	5-Jul-2021	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	6:50	7:15	0:25	MAIN SUPPLY FAILURE
1005	5-Jul-2021	BENGALURU	66	DIVYASHREE TECH PARK - DOMMASANDRA	DOMMASANDRA, KACHAMARANAHALLI	16:43	17:05	0:22	LINE FAULT
1006	5-Jul-2021	BENGALURU	66	HV2	SOLDEVANAHALLI	12:29	12:38	0:09	LINE CLEAR AVAIED
1007	5-Jul-2021	BENGALURU	66	HV1	SOLDEVANAHALLI	12:46	12:56	0:10	LINE CLEAR AVAIED
1008	5-Jul-2021	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	YEDUMADU	17:36	17:50	0:14	LINE FAULT
1009	5-Jul-2021	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	7:10	7:16	0:06	LINE CLEAR AVAIED
1010	5-Jul-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	7:10	7:15	0:05	LINE CLEAR AVAIED
1011	5-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADAHOSANAHALLI	7:10	7:15	0:05	LINE CLEAR AVAIED
1012	5-Jul-2021	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	7:10	7:16	0:06	LINE CLEAR AVAIED
1013	5-Jul-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	11:40	11:55	0:15	MAIN SUPPLY FAILURE
1014	5-Jul-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:40	11:53	0:13	MAIN SUPPLY FAILURE
1015	5-Jul-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	11:40	11:53	0:13	MAIN SUPPLY FAILURE
1016	5-Jul-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:40	11:53	0:13	MAIN SUPPLY FAILURE
1017	5-Jul-2021	BENGALURU	66	VIJAYPURA - KANAKPURA 220	VIJAYAPURA, JANGAMAKOTE	14:15	14:20	0:05	LOAD CHANGE OVER
1018	5-Jul-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	14:03	14:08	0:05	LINE CLEAR AVAIED
1019	5-Jul-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	14:03	14:08	0:05	LINE CLEAR AVAIED
1020	5-Jul-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	14:03	14:08	0:05	LINE CLEAR AVAIED
1021	5-Jul-2021	BENGALURU	220	HV2	DB PURA 220	11:40	14:02	2:22	LINE CLEAR AVAIED
1022	5-Jul-2021	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANKUNTE	6:48	7:15	0:27	LINE FAULT
1023	5-Jul-2021	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANKUNTE	10:20	10:25	0:05	LOAD CHANGE OVER
1024	5-Jul-2021	BENGALURU	66	HV1	WEL CAST STEEL	14:19	14:25	0:06	LINE CLEAR AVAIED
1025	5-Jul-2021	BENGALURU	66	HV2	WEL CAST STEEL	15:40	15:48	0:08	LINE CLEAR AVAIED
1026	5-Jul-2021	BENGALURU	66	HV2	TADIGOLU	8:50	9:04	0:14	TRANSFORMER FAULT
1027	5-Jul-2021	BENGALURU	66	HV2	TADIGOLU	10:29	11:46	1:16	TRANSFORMER FAULT
1028	5-Jul-2021	BENGALURU	66	HV1	PALLICHERLU	12:11	13:59	1:47	LINE CLEAR AVAIED
1029	5-Jul-2021	BENGALURU	66	HV1	MATHIKERE NELMANGALA	7:10	9:10	1:59	LINE CLEAR AVAIED
1030	5-Jul-2021	BENGALURU	66	HV1	MATHIKERE NELMANGALA	12:30	12:50	0:20	LINE CLEAR AVAIED
1031	5-Jul-2021	BENGALURU	66	HV1	HOSKOTE 66	15:31	15:50	0:18	LINE CLEAR AVAIED
1032	5-Jul-2021	BENGALURU	66	HV1	ATTIBELE	13:23	13:42	0:18	LINE CLEAR AVAIED
1033	5-Jul-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	12:26	12:40	0:14	LINE CLEAR AVAIED
1034	5-Jul-2021	BENGALURU	66	KOLAR 220 - NARSAPURA 2	NO STATION AFFECTED	7:50	7:55	0:05	LINE FAULT
1035	5-Jul-2021	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	NO STATION AFFECTED	12:16:00(13-06-2021)			LINE OPEN,LINE FAULT
1036	5-Jul-2021	BENGALURU	66	HV2	CHANDAPURA	15:05(14-06-2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1037	5-Jul-2021	BENGALURU	400	NELAMANGALA 400 - HASSAN 400	NO STATION AFFECTED	18:10:08(29-6-2021)			LINE OPEN,LINE FAULT
1038	5-Jul-2021	BENGALURU	220	LV1	MITTEMARI 220	15:00(3-7-2021)	7:16(5-7-2021)	40:14HRS	TRANSFORMER CHARGED
1039	5-Jul-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	1:15	12:44	11:29	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1040	5-Jul-2021	GULBARGA	220	SHAHABAD-KAPANOOR	KAPANOOR_220	17:40	17:47	0:07	LINE FAULT
1041	5-Jul-2021	GULBARGA	220	HV1	KAPANOOR_220	17:40	18:52	1:12	TRANSFORMER FAULT
1042	5-Jul-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110	23:53(05.07.2021)			LINE OPEN,LINE FAULT
1043	5-Jul-2021	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	4:58	5:14	0:16	LINE FAULT
1044	5-Jul-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	11:49	17:45	5:56	LINE CLEAR AVAILED
1045	5-Jul-2021	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,D EVANGAON_110,RENUKA_IPP,AFZ ALPUR_110,KARAJAGI_110	13:52	14:20	0:28	LINE FAULT
1046	5-Jul-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:10	5:17	0:07	LINE FAULT
1047	5-Jul-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:02	20:25	0:23	LINE FAULT
1048	5-Jul-2021	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADAVIAMARESHWARA_110	20:43	21:05	0:22	LINE FAULT
1049	5-Jul-2021	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADAVIAMARESHWARA_110	21:09	21:19	0:10	LINE FAULT
1050	5-Jul-2021	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADAVIAMARESHWARA_110	21:21	22:15	0:54	LINE FAULT
1051	5-Jul-2021	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADAVIAMARESHWARA_110	22:28(05.07.2021)			LINE OPEN,LINE FAULT
1052	5-Jul-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERA DONA_110,SR NAGAR_110,MALLAPUR_110	23:48	23:58	0:10	LINE FAULT
1053	5-Jul-2021	GULBARGA	110	MALLA-BYAGAWAT2	ADAVIAMARESHWARA_110	1:27	1:37	0:10	LINE FAULT
1054	5-Jul-2021	GULBARGA	110	MALLA-BYAGAWAT2	ADAVIAMARESHWARA_110	19:43	19:52	0:09	LINE FAULT
1055	5-Jul-2021	GULBARGA	110	MALLA-BYAGAWAT1	BYAGAWAT_110	19:56	20:07	0:11	LINE FAULT
1056	5-Jul-2021	GULBARGA	110	M ALLAT-ALKOD	ALKOD_110	20:08	20:19	0:11	LINE FAULT
1057	5-Jul-2021	GULBARGA	110	MALLA-BYAGAWAT2	ADAVIAMARESHWARA_110	20:28	21:40	1:12	LINE FAULT
1058	5-Jul-2021	GULBARGA	110	MALLA-BYAGAWAT2	ADAVIAMARESHWARA_110	22:00	22:14	0:14	LINE FAULT
1059	5-Jul-2021	GULBARGA	110	HV2	DEODURGA_110	16:45	17:46	1:01	TRANSFORMER FAULT
1060	5-Jul-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:46	20:28	0:42	LINE CLEAR AVAILED
1061	5-Jul-2021	GULBARGA	110	GULBARGASOUTH-GULBARGAWEST	GULBARGAWEST_110	17:40	17:55	0:15	MAIN SUPPLY FAILURE
1062	5-Jul-2021	GULBARGA	110	GULBARGASOUTH-GULBARGAWEST	GULBARGAWEST_110	19:40	19:42	0:02	MAIN SUPPLY FAILURE
1063	5-Jul-2021	GULBARGA	110	SINDHANOOR-HATTI	HATTI_110	20:49	20:50	0:01	MAIN SUPPLY FAILURE
1064	5-Jul-2021	GULBARGA	110	HV3	HATTI_110	20:49	21:04	0:15	TRANSFORMER FAULT
1065	5-Jul-2021	GULBARGA	110	HV1	MYLAR_110	20:49	21:04	0:15	TRANSFORMER FAULT
1066	5-Jul-2021	GULBARGA	110	HV2	MYLAR_110	20:49	21:04	0:15	TRANSFORMER FAULT
1067	5-Jul-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KERE HALLI_110,MALLAPURA_110	9:17	9:22	0:05	LINE FAULT
1068	5-Jul-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KERE HALLI_110,MALLAPURA_110	9:30	9:36	0:06	LINE FAULT
1069	5-Jul-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KERE HALLI_110,MALLAPURA_110	9:45	9:55	0:10	LINE FAULT
1070	5-Jul-2021	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	6:20	6:28	0:08	LINE FAULT
1071	5-Jul-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGAR FACTORY_IPP,CHOWDAPUR_110	11:15	11:19	0:04	LINE FAULT
1072	5-Jul-2021	GULBARGA	110	KAPNOOR220-KAPNOOR110	KAPNOOR_110	17:40	19:25	1:45	LINE FAULT
1073	5-Jul-2021	GULBARGA	110	GULBARGA WEST-KAPNOOR	GULBARGA WEST_110	17:40	19:07	1:27	MAIN SUPPLY FAILURE
1074	5-Jul-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	11:35	11:40	0:05	TRANSFORMER FAULT
1075	5-Jul-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:02 (30.06.2021)			LINE OPEN,LINE CLEAR AVAILED
1076	5-Jul-2021	HASSAN	110	JOG-NK2	mghejog_gen	18:17 (1.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1077	5-Jul-2021	HASSAN	110	HV1	BARANGI_110	15:37	15:48	0:11	HAND TRIPPED
1078	5-Jul-2021	HASSAN	110	HV2	BARANGI_110	15:37	15:48	0:11	HAND TRIPPED
1079	5-Jul-2021	HASSAN	110	HV3	GURUVAYANAKERE_110	10:18	14:14	3:56	LINE CLEAR AVAILED
1080	5-Jul-2021	HASSAN	110	HV1	HALADY_110	19:21	19:42	0:21	LOAD CURTAILMENT
1081	5-Jul-2021	HASSAN	110	HV1	HIRENALLUR_110	10:47	18:19	7:32	MAIN SUPPLY FAILURE
1082	5-Jul-2021	HASSAN	110	HIRENAL-KADUR	HIRENALLUR_110	10:47	18:19	7:32	MAIN SUPPLY FAILURE
1083	5-Jul-2021	HASSAN	110	HIRIYA-KEMAR	HIRIYADKA_110	13:04	17:04	4:00	NFBC ISSUED
1084	5-Jul-2021	HASSAN	110	KADUR-AJAMPURA	KADUR_220	10:38	18:03	7:25	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1085	5-Jul-2021	HASSAN	110	HV2	KADUR_220	13:25	13:40	0:15	TRANSFORMER FAULT
1086	5-Jul-2021	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	13:07	17:02	3:55	LINE CLEAR AVAILED
1087	5-Jul-2021	HASSAN	110	KEMAR-MOODAB	KEMAR_220	14:52	17:33	2:41	LINE CLEAR AVAILED
1088	5-Jul-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	14:50	17:33	2:43	NFBC ISSUED
1089	5-Jul-2021	HASSAN	66	HV1	DODDAKADANUR_66	11:15	11:20	0:05	MAIN SUPPLY FAILURE
1090	5-Jul-2021	HASSAN	66	HV1	HALEBEEDU_66	14:00	15:10	1:10	LINE CLEAR AVAILED
1091	5-Jul-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	1:19	1:38	0:19	LINE FAULT
1092	5-Jul-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	3:22	3:28	0:06	LINE FAULT
1093	5-Jul-2021	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	11:15	11:20	0:05	LINE CLEAR AVAILED
1094	5-Jul-2021	HASSAN	66	MALALI-SHANTIGRMA	MALALI_66	5:35	6:05	0:30	LINE FAULT
1095	5-Jul-2021	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	10:35	10:48	0:13	LINE FAULT
1096	5-Jul-2021	MYSURU	66	HV1	BASARALU_66	7:10	12:11	5:01	LINE CLEAR AVAILED
1097	5-Jul-2021	MYSURU	66	HV2	DUNDANAHALLI_66	10:35	12:10	1:35	LINE CLEAR AVAILED
1098	5-Jul-2021	MYSURU	66	HV1	HEBBAL_66	12:37	13:06	0:28	LINE CLEAR AVAILED
1099	5-Jul-2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	5:39	5:45	0:06	LINE FAULT
1100	5-Jul-2021	MYSURU	66	PERIYAPATNA-HANGUD	NO STATIONS EFFECTED	14:31	16:42	2:10	LINE CLEAR AVAILED
1101	5-Jul-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	16:20	16:36	0:16	LINE CLEAR AVAILED
1102	5-Jul-2021	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	17:08	17:31	0:22	LINE FAULT
1103	5-Jul-2021	MYSURU	66	PARINAMIPURA-TALAKADU	CHANDALLI_66, THALAKADU_66	6:07	6:14	0:07	LINE FAULT
1104	5-Jul-2021	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66	11:27	11:54	0:26	LINE CLEAR AVAILED
1105	5-Jul-2021	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	10:45	10:50	0:05	LINE CLEAR AVAILED
1106	5-Jul-2021	MYSURU	66	HV1	BASARALU_66	20:45 (04/07/2021)	12:10 (05/07/2021)	15:25 HRS	TRANSFORMER CHARGED
1107	5-Jul-2021	MYSURU	66	PANDAVAPURA-ATRIA 1	NO STATIONS EFFECTED	5:23 (09/06/2021)			LINE OPEN,LINE CLEAR AVAILED
1108	5-Jul-2021	TUMKUR	220	TR-2	NITTUR_220	12:06	14:12	2:05	LINE CLEAR AVAILED
1109	5-Jul-2021	TUMKUR	220	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_220	3:05	5:58	2:52	LINE FAULT
1110	5-Jul-2021	TUMKUR	110	TR-1	BANDIHALLI_110	11:57	12:15	0:17	LINE CLEAR AVAILED
1111	5-Jul-2021	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	2:27	2:33	0:06	TRANSFORMER FAULT
1112	5-Jul-2021	TUMKUR	110	TR-3	GUBBI_110	13:24	13:26	0:01	LINE CLEAR AVAILED
1113	5-Jul-2021	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	12:00	12:05	0:04	LINE CLEAR AVAILED
1114	5-Jul-2021	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	14:24	14:33	0:09	LINE CLEAR AVAILED
1115	5-Jul-2021	TUMKUR	110	TR-2	NITTUR_220	12:05	14:12	2:07	LINE CLEAR AVAILED
1116	5-Jul-2021	TUMKUR	66	BALENAHALLI66-FEFCWINDWIND_IPP_66	FEFCWINDWIND_IPP_66	10:16	19:00	8:43	LINE CLEAR AVAILED
1117	5-Jul-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	19:16	19:30	0:13	LINE FAULT
1118	5-Jul-2021	TUMKUR	66	TR-1	HONNALLI_66	0:33	1:13	0:39	TRANSFORMER FAULT
1119	5-Jul-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	14:22	14:44	0:21	LINE CLEAR AVAILED
1120	5-Jul-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	13:56	14:44	0:48	LINE CLEAR AVAILED
1121	5-Jul-2021	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	8:17	8:49	0:32	LINE CLEAR AVAILED
1122	5-Jul-2021	TUMKUR	66	TR-1	MADADAKERE_66	8:49	8:56	0:06	TRANSFORMER FAULT
1123	5-Jul-2021	TUMKUR	66	TR-1	MATHOD_66	4:22	4:25	0:02	TRANSFORMER FAULT
1124	5-Jul-2021	TUMKUR	66	TR-1	MATHOD_66	7:06	7:12	0:05	TRANSFORMER FAULT
1125	5-Jul-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	11:35	11:41	0:06	TRANSFORMER FAULT
1126	5-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_220	19:53	19:56	0:02	TRANSFORMER FAULT
1127	5-Jul-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	6:37	7:22	0:45	LINE FAULT
1128	5-Jul-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	RANGANATHAPURA_66	6:37	8:03	1:26	LINE FAULT
1129	5-Jul-2021	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	3:37	13:22	9:45	LINE CLEAR AVAILED
1130	5-Jul-2021	TUMKUR	400	GUTUR_400-BEERANAHALLI-1	GUTUR_400	10:12	16:43	6:31	LINE CLEAR AVAILED
1131	5-Jul-2021	TUMKUR	66	TR-3	AVAREGERE_66	8:16	8:18	0:01	TRANSFORMER FAULT
1132	5-Jul-2021	TUMKUR	66	TR-2	AVAREGERE_66	14:25	14:30	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1133	5-Jul-2021	TUMKUR	66	TR-2	AVAREGERE_66	14:30	15:20	0:49	TRANSFORMER FAULT
1134	5-Jul-2021	TUMKUR	66	TR-1	AVAREGERE_66	14:10	14:25	0:15	MAIN SUPPLY FAILURE
1135	5-Jul-2021	TUMKUR	66	TR-2	AVAREGERE_66	14:10	14:27	0:17	MAIN SUPPLY FAILURE
1136	5-Jul-2021	TUMKUR	66	TR-3	AVAREGERE_66	14:10	14:29	0:19	MAIN SUPPLY FAILURE
1137	5-Jul-2021	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	17:43	19:50	2:06	LINE CLEAR AVAILED
1138	5-Jul-2021	TUMKUR	66	TR-2	BELLAVI_66	9:15	10:15	0:59	LINE CLEAR AVAILED
1139	5-Jul-2021	TUMKUR	66	TR-1	BENKIKERE_66	13:39	13:43	0:03	TRANSFORMER FAULT
1140	5-Jul-2021	TUMKUR	66	TR-1	BENKIKERE_66	14:00	14:04	0:03	TRANSFORMER FAULT
1141	5-Jul-2021	TUMKUR	66	TR-1	BENKIKERE_66	15:14	15:19	0:05	TRANSFORMER FAULT
1142	5-Jul-2021	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	15:36	15:49	0:13	LINE FAULT
1143	5-Jul-2021	TUMKUR	66	TR-2	CHANNAGIRI_66	14:00	14:17	0:17	TRANSFORMER FAULT
1144	5-Jul-2021	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	12:12	13:05	0:52	LINE CLEAR AVAILED
1145	5-Jul-2021	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	5:50	6:27	0:36	MAIN SUPPLY FAILURE
1146	5-Jul-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	2:15	2:24	0:09	MAIN SUPPLY FAILURE
1147	5-Jul-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:36	12:49	0:12	LINE FAULT
1148	5-Jul-2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	14:27	14:35	0:07	LINE FAULT
1149	5-Jul-2021	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA	KALLAMBELLA_66, SIRA_66	23:08	23:20	0:11	LINE FAULT
1150	5-Jul-2021	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	KALLAMBELLA_66, BUKKAPATNA_66	23:08	23:19	0:10	LINE FAULT
1151	5-Jul-2021	TUMKUR	66	TR-2	MALEBENNUR_66	16:08	16:35	0:26	HAND TRIPPED
1152	5-Jul-2021	TUMKUR	66	TR-1	MATHOD_66	6:32	6:40	0:07	TRANSFORMER FAULT
1153	5-Jul-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	5:40	5:49	0:08	TRANSFORMER FAULT
1154	5-Jul-2021	TUMKUR	66	TR-1	PAVAGADA_220	14:43	14:57	0:14	TRANSFORMER FAULT
1155	5-Jul-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	9:50	10:35	0:45	LINE CLEAR AVAILED
1156	5-Jul-2021	TUMKUR	66	TR-1	SOKKE_66	19:18	19:35	0:16	TRANSFORMER FAULT
1157	5-Jul-2021	TUMKUR	66	TR-3(HV-3)	THALLAKK_220	18:37	18:50	0:13	TRANSFORMER FAULT
1158	5-Jul-2021	TUMKUR	66	TR-3(LV-3)	THALLAKK_220	18:37	18:51	0:14	TRANSFORMER FAULT
1159	5-Jul-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:37	18:56	0:18	LINE FAULT
1160	5-Jul-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	18:48	18:56	0:07	HAND TRIPPED