## 400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 06.11.2018 to 12.11.2018

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	6-Nov-18	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	12:12	12:22	0:10	TRANSFORMER FAULT
2	6-Nov-18	BAGALKOT	110	110/11KV,HV-3	BAILHONGAL_110	19:26	22:15	2:49	TRANSFORMER FAULT
3	6-Nov-18	BAGALKOT	110	110/11KV,HV-2	NIPPANI_110	10:05	10:45	0:40	TRANSFORMER FAULT
4	6-Nov-18	BAGALKOT	110	110/11KV,HV-2	RANNABELAGALI_110	17:58	18:15	0:17	TRANSFORMER FAULT
5	6-Nov-18	BAGALKOT	110	TERADAL-SVRG	TERADAL_110	9:10	10:03	0:53	LINE CLEAR AVAILED
6	6-Nov-18	BAGALKOT	110	110/33KV,HV-4	ZALAKI_110	3:31	3:34	0:03	TRANSFORMER FAULT
7	6-Nov-18	BAGALKOT	110	110/33KV,HV-4	ZALAKI_110	14:29	14:31	0:02	TRANSFORMER FAULT
8	6-Nov-18	BAGALKOT	110	110/33KV,HV-4	ZALAKI_110	23:54	23:59	0:05	LINE CLEAR AVAILED
9	6-Nov-18	BAGALKOT	66	HOSPET 66-BANUVALLI	BANUVALLI_66	6:03	23:59	17:56	LINE FAULT
10	7-Nov-18	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	9:10	11:13	2:03	HAND TRIPPED
11	7-Nov-18	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	6:12	13:50	7:38	TRANSFORMER FAULT
12	7-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI1	BELAGAUM_220	19:39	22:07	2:28	HAND TRIPPED
13	7-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI2	BELAGAUM_220	20:07	23:59	3:52	HAND TRIPPED
14	7-Nov-18	BAGALKOT	110	220/110, LV3	MAHALINGAPUR_220, HIDIKAL_110, RABKAVI_110	9:33	9:41	0:08	TRANSFORMER FAULT
15	7-Nov-18	BAGALKOT	110	220/110, LV2	MK HUBLI_220	20:11	23:59	3:48	HAND TRIPPED
16	7-Nov-18	BAGALKOT	110	VIJAYA NAGAR SUGARS- MUNDARGI	MUNDARGI_110	18:37	18:47	0:10	LINE FAULT
17	7-Nov-18	BAGALKOT	110	110/33KV, HV4	ZALKI_110	0:00	0:14	0:14	LINE CLEAR AVAILED
18	7-Nov-18	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	10:03	10:10	0:07	TRANSFORMER FAULT
19	8-Nov-18	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	8:06	13:48	5:42	HAND TRIPPED
20	8-Nov-18	BAGALKOT	220	BIJAPUR-INDI2	BIJAPUR_220	16:35	17:25	0:50	HAND TRIPPED
21	8-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI2	BELAGAUM_220	0:00	6:54	6:54	HAND TRIPPED
22	8-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI2	BELAGAUM_220	20:46	23:59	3:13	HAND TRIPPED
23	8-Nov-18	BAGALKOT	110	220/110, LV2	MK HUBLI_220	0:00	0:14	0:14	HAND TRIPPED
24	8-Nov-18	BAGALKOT	110	110/11KV, HJV1	NARAGUND_110	13:36	13:52	0:16	TRANSFORMER FAULT
25	8-Nov-18	BAGALKOT	110	110/11KV, HV3	SAVALGI_110	15:07	15:18	0:11	HAND TRIPPED
26	8-Nov-18	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	14:59	15:19	0:20	TRANSFORMER FAULT
27	8-Nov-18	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	10:29	10:32	0:03	TRANSFORMER FAULT
28	9-Nov-18	BAGALKOT	110	110/11KV,HV-1	BAGALKOT_110	10:10	11:10	1:00	HAND TRIPPED
29	9-Nov-18	BAGALKOT	110	110/11KV,HV-3	BAILHONGAL_110	15:03	15:48	0:45	HAND TRIPPED
30	9-Nov-18	BAGALKOT	110	110/11KV,HV-2	BELUR_110	8:27	9:05	0:38	HAND TRIPPED
31	9-Nov-18	BAGALKOT	110	110/11KV, HV2	YELLAPARHATTI_110	13:42	14:04	0:22	LINE CLEAR AVAILED
32	9-Nov-18	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	17:00	17:12	0:12	LINE CLEAR AVAILED
33	9-Nov-18	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	11:50	12:19	0:29	LINE CLEAR AVAILED
34	9-Nov-18	BAGALKOT	220	GADAG-BAGALKOT1	GADAG_220	11:15	13:19	2:04	NBFC ISSUED
35	9-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	7:28	7:28	HAND TRIPPED
36	9-Nov-18	BAGALKOT	110	110/11KV,HV-1	BAGALKOT_110	10:10	11:10	1:00	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
37	9-Nov-18	BAGALKOT	110	110/11KV,HV-3	BAILHONGAL_110	15:03	15:48	0:45	HAND TRIPPED
38	9-Nov-18	BAGALKOT	110	110/11KV,HV-2	BELUR_110	8:27	9:05	0:38	HAND TRIPPED
39	9-Nov-18	BAGALKOT	110	110/11KV, HV2	YELLAPARHATTI_110	13:42	14:04	0:22	LINE CLEAR AVAILED
40	9-Nov-18	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	17:00	17:12	0:12	LINE CLEAR AVAILED
41	9-Nov-18	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	11:50	12:19	0:29	LINE CLEAR AVAILED
42	9-Nov-18	BAGALKOT	220	GADAG-BAGALKOT1	GADAG_220	11:15	13:19	2:04	NBFC ISSUED
43	9-Nov-18	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	0:00	7:28	7:28	HAND TRIPPED
44	10-Nov-18	BAGALKOT	110	110/11KV,HV-2	ANKALI_110	9:26	17:11	7:45	HAND TRIPPED
45	10-Nov-18	BAGALKOT	110	110/11KV,HV-1	ATHARGA_110	17:02	17:22	0:20	HAND TRIPPED
46	10-Nov-18	BAGALKOT	110	110/11KV,HV-2	BELUR_110	23:16	23:29	0:13	TRANSFORMER FAULT
47	10-Nov-18	BAGALKOT	110	110/11KV,HV-2	BELUR_110	23:32	23:59	0:27	HAND TRIPPED
48	10-Nov-18	BAGALKOT	110	110/11KV,HV-2	GOKAK_110	0:26	0:28	0:02	TRANSFORMER FAULT
49	10-Nov-18	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	11:44	17:54	6:10	HAND TRIPPED
50	10-Nov-18	BAGALKOT	66	HARIHAR HOSPET-BANUVALLI	BANUVALLI_66	0:00	13:42	13:42	LINE CLEAR AVAILED
51	10-Nov-18	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	0:00	8:58	8:58	HAND TRIPPED
52	10-Nov-18	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	15:14	15:38	0:24	LINE FAULT
53	10-Nov-18	BAGALKOT	110	220/110, LV3	MAHALINGAPUR_220, HIDIKAL_110, RABKAVI_110	7:00	7:06	0:06	TRANSFORMER FAULT
54	10-Nov-18	BAGALKOT	110	220/110, LV3	MAHALINGAPUR_220, HIDIKAL_110, RABKAVI_110	8:16	17:44	9:28	TRANSFORMER FAULT
55	10-Nov-18	BAGALKOT	110	110/11KV, HV5	INDI_110	15:17	16:09	0:52	HAND TRIPPED
56	11-Nov-18	BAGALKOT	110	110/11KV,HV-1	ATHARGA_110	7:27	7:34	0:07	HAND TRIPPED
57	11-Nov-18	BAGALKOT	110	110/11KV,HV-2	BELUR_110	0:00	0:14	0:14	LINE CLEAR AVAILED
58	11-Nov-18	BAGALKOT	110	110/11KV,HV-2	BELUR_110	12:08	12:15	0:07	TRANSFORMER FAULT
59	11-Nov-18	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	11:51	14:31	2:40	HAND TRIPPED
60	11-Nov-18	BAGALKOT	220	AMBEWADI-NARENDRA 1	AMBEWADI_220	10:34	14:31	3:57	HAND TRIPPED
61	11-Nov-18	BAGALKOT	110	GHATAPRABHA- KABBUR	KABBUR_110	6:08	6:24	0:16	LINE FAULT
62	11-Nov-18	BAGALKOT	110	110/11KV,HV2	SUVARNA SOUDA_110	8:44	11:43	2:59	HAND TRIPPED
63	11-Nov-18	BAGALKOT	110	110/11KV,HV1	SUVARNA SOUDA_110	11:44	14:06	2:22	HAND TRIPPED
64	11-Nov-18	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	12:58	13:00	0:02	TRANSFORMER FAULT
65	12-Nov-18	BAGALKOT	110	110/1KV,HV-1	BAGALKOT_110	16:07	16:17	0:10	HAND TRIPPED
66	12-Nov-18	BAGALKOT	220	BIJAPUR -INDI 2	BIJAPUR_220	17:39	17:40	0:01	HAND TRIPPED
67	12-Nov-18	BAGALKOT	110	110/33KV,HV-4	HIDIKAL_110	4:37	4:47	0:10	TRANSFORMER FAULT
68	12-Nov-18	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	0:00	0:32	0:32	LINE FAULT
69	12-Nov-18	BAGALKOT	220	NARENDRA-MAHALINGAPUR	MAHALINGAPUR_220	10:07	18:00	7:53	HAND TRIPPED
70	12-Nov-18	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	13:26	15:05	1:39	HAND TRIPPED
71	12-Nov-18	BAGALKOT	110	220/110KV,LV-3	MAHALINGAPUR_220	13:27	15:01	1:34	HAND TRIPPED
72	12-Nov-18	BAGALKOT	110	110/11KV,HV-2	PH COMPOUND_110	5:58	6:15	0:17	TRANSFORMER FAULT
73	12-Nov-18	BAGALKOT	110	SOUDATTI-ENERCON 1	SOUDATTI_110	13:56	17:35	3:39	LINE CLEAR AVAILED
74	12-Nov-18	BAGALKOT	110	220/110LV,LV-1	SOUDATTI_220	11:14	11:49	0:35	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
75	12-Nov-18	BAGALKOT	110	110/11KV,HV-1	SOUDATTI_220	11:14	11:44	0:30	TRANSFORMER FAULT
76	12-Nov-18	BAGALKOT	110	SOUDATTI-MUNAVALLI	MUNAVALLI_110	11:14	11:51	0:37	LINE FAULT
77	12-Nov-18	BAGALKOT	110	SOUDATTI-NARAGUND	NARAGUND_110	11:14	11:55	0:41	LINE FAULT
78	12-Nov-18	BAGALKOT	110	SOUDATTI-SOUDATTI 1	SOUDATTI_110	11:14	12:52	1:38	LINE FAULT
79	12-Nov-18	BAGALKOT	110	SOUDATTI-SOUDATTI 2	SOUDATTI_110	11:14	11:50	0:36	LINE FAULT
80	12-Nov-18	BAGALKOT	110	SOUDATTI-YARAGATTI	YARAGATTI_110	11:14	12:06	0:52	LINE FAULT
81	12-Nov-18	BAGALKOT	110	JAMKHANDI SUGERS-TODALBAGI	TODALBAGI_110	14:10	15:15	1:05	LINE CLEAR AVAILED
82	12-Nov-18	BAGALKOT	110	110/33KV,HV-4	ZALKI_110	15:53	16:54	1:01	TRANSFORMER FAULT
83	6-Nov-18	BANGALORE	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE, MATHIKERE	17:25	23:59	6:34	MAIN SUPPLY FAILURE
84	6-Nov-18	BANGALORE	66	HV2	DODDABELAVANGALA	8:57	9:03	0:06	TRANSFORMER FAULT
85	6-Nov-18	BANGALORE	66	KOLAR 220 - NARASAPURA1	NARASAPURA	15:11	15:22	0:11	LINE FAULT
86	6-Nov-18	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	7:28	7:38	0:10	LINE FAULT
87	6-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 4	SAHAKARINAGAR, RAILWAYS (EHT)	16:29	16:48	0:18	LINE FAULT
88	6-Nov-18	BANGALORE	66	HV1	EPIP 220	14:41	16:03	1:22	LINE CLEAR AVAILED
89	6-Nov-18	BANGALORE	66	HSR LAYOUT 220 - KORMANGALA	KORMANGALA, K & C VALLEY, NAL (EHT)	11:15	11:43	0:28	LINE FAULT
90	6-Nov-18	BANGALORE	66	HV1	NIMHANS 220	13:39	13:56	0:16	LINE CLEAR AVAILED
91	7-Nov-18	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	12:59	13:08	0:09	LINE FAULT
92	7-Nov-18	BANGALORE	66	HV2	HONNIGANAHALLI	0:00	11:05	11:05	TRANSFORMER FAULT
93	7-Nov-18	BANGALORE	66	HV1	HONNIGANAHALLI	16:15	17:15	1:00	LINE CLEAR AVAILED
94	7-Nov-18	BANGALORE	66	HOSKOTE 220- HOSKOETE 1	VIDYANAGAR, HENNUR CROSS,	23:19	23:37	0:18	LINE FAULT
95	7-Nov-18	BANGALORE	66	HV1	KEMBODI	11:34	12:23	0:49	LINE CLEAR AVAILED
96	7-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 4	SAHAKARINAGAR, RAILWAYS (EHT)	10:25	10:31	0:05	LINE FAULT
97	7-Nov-18	BANGALORE	66	HSR LAYOUT 220 - KORMANGALA	K&C VALLY, NAL (EHT)	10:55	14:46	3:51	LINE CLEAR AVAILED
98	7-Nov-18	BANGALORE	66	HV1	KORMANGALA	10:55	11:10	0:14	MAIN SUPPLY FAILURE
99	7-Nov-18	BANGALORE	66	ATTUR YELAHANKA - DG 4	SAHAKARINAGARA	10:25	13:44	3:18	LINE CLEAR AVAILED
100	7-Nov-18	BANGALORE	66	ATTUR YELAHANKA - DG 3	MANYATHA TECH PARK, ATTUR YELAHANKA	12:30	13:44	1:14	LINE CLEAR AVAILED
101	7-Nov-18	BANGALORE	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	12:30	12:42	0:12	LOAD CHANGEOVER
102	7-Nov-18	BANGALORE	66	ABBIGERE - WELCAST	ABBIGERE	13:45	13:49	0:04	LOAD CHANGEOVER
103	7-Nov-18	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	12:13	12:19	0:06	LINE FAULT
104	8-Nov-18	BANGALORE	66	HV2	ANDERSONPET	8:53	9:13	0:19	LINE CLEAR AVAILED
105	8-Nov-18	BANGALORE	66	HV2	ANDERSONPET	15:59	17:38	1:38	LINE CLEAR AVAILED
106	8-Nov-18	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	0:12	0:24	0:11	LINE FAULT
107	8-Nov-18	BANGALORE	66	DB PURA 220 - CB PURA 2	TUBUGERE	12:38	12:50	0:12	LINE FAULT
108	8-Nov-18	BANGALORE	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	18:03	18:46	0:42	LINE FAULT
109	8-Nov-18	BANGALORE	66	HV2	DODDABELAVANGALA	7:10	7:14	0:04	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
110	8-Nov-18	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66, ALUR	9:53	9:56	0:02	LOAD CHANGEOVER
111	8-Nov-18	BANGALORE	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	6:05	6:10	0:05	LOAD CHANGEOVER
112	8-Nov-18	BANGALORE	66	YEDUMADU - HANUMANTHNAGAR	YEDUMADU	9:15	9:20	0:05	LOAD CHANGEOVER
113	8-Nov-18	BANGALORE	66	KEMPANAHALLI - RAMANAGARA	MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, RAMANAGARA	6:08	6:19	0:10	LINE FAULT
114	8-Nov-18	BANGALORE	66	HV3	MANYATHA TECH PARK	7:06	10:06	3:00	TRANSFORMER FAULT
115	8-Nov-18	BANGALORE	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	6:12	6:22	0:10	LOAD CHANGEOVER
116	8-Nov-18	BANGALORE	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	8:50	9:00	0:10	LOAD CHANGEOVER
117	8-Nov-18	BANGALORE	66	HV1	EPIP 220	23:47	23:59	0:11	TRANSFORMER FAULT
118	8-Nov-18	BANGALORE	66	SRS PEENYA 220 - GOKULA 1	GOKULA	17:54	18:17	0:22	LINE FAULT
119	8-Nov-18	BANGALORE	66	SRS PEENYA 220 - GOKULA 2	GOKULA	17:54	18:18	0:23	LINE FAULT
120	8-Nov-18	BANGALORE	66	GOKULA - HMT (EHT)	HMT (EHT)	17:54	18:42	0:47	LINE FAULT
121	8-Nov-18	BANGALORE	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	17:54	18:28	0:33	MAIN SUPPLY FAILURE
122	8-Nov-18	BANGALORE	66	GOKULA - BEL (EHT)	BEL (EHT)	17:54	18:37	0:42	MAIN SUPPLY FAILURE
123	8-Nov-18	BANGALORE	66	MATHIKERE - SRS PEENYA 220	MATHIKERE	17:54	18:15	0:20	MAIN SUPPLY FAILURE
124	8-Nov-18	BANGALORE	66	MATHIKERE - GOKULA	MATHIKERE	22:35	22:40	0:05	LOAD CHANGEOVER
125	8-Nov-18	BANGALORE	66	HV2	HSR LAYOUT 220	7:11	9:45	2:33	TRANSFORMER FAULT
126	8-Nov-18	BANGALORE	66	HV2	ISRO LAYOUT	5:05	5:30	0:24	TRANSFORMER FAULT
127	8-Nov-18	BANGALORE	66	HV2	ISRO LAYOUT	11:24	11:45	0:20	TRANSFORMER FAULT
128	8-Nov-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	12:19	12:25	0:05	LINE FAULT
129	8-Nov-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	12:31	12:41	0:09	LINE FAULT
130	8-Nov-18	BANGALORE	66	HV2	KADUBISANAHALLI	6:58	7:32	0:33	TRANSFORMER FAULT
131	8-Nov-18	BANGALORE	220	HV3	SOMANAHALLI 220	5:42	8:48	3:06	TRANSFORMER FAULT
132	8-Nov-18	BANGALORE	66	SRS PEENYA 220 - DG 2	ALUR, NELAMANGALA 66	7:04	7:19	0:15	LINE FAULT
133	8-Nov-18	BANGALORE	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	6:25	6:30	0:05	LOAD CHANGEOVER
134	8-Nov-18	BANGALORE	220	HV1	KOLAR 220	6:30	7:43	1:13	TRANSFORMER FAULT
135	8-Nov-18	BANGALORE	220	HV2	KOLAR 220	6:30	7:45	1:15	TRANSFORMER FAULT
136	8-Nov-18	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	6:30	8:15	1:45	MAIN SUPPLY FAILURE
137	8-Nov-18	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	6:30	8:18	1:48	MAIN SUPPLY FAILURE
138	8-Nov-18	BANGALORE	66	KOLAR 220 - BANGARPET 2	BANGARPET	6:30	8:18	1:48	MAIN SUPPLY FAILURE
139	8-Nov-18	BANGALORE	66	KOLAR 220 - MULABAGAL	MULBAGAL, AVANI	6:30	8:21	1:51	MAIN SUPPLY FAILURE
140	8-Nov-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	6:30	8:17	1:47	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
141	8-Nov-18	BANGALORE	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	6:30	8:25	1:55	MAIN SUPPLY FAILURE
142	8-Nov-18	BANGALORE	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR	6:30	8:45	2:15	MAIN SUPPLY FAILURE
143	8-Nov-18	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	6:30	8:30	2:00	LINE FAULT
144	8-Nov-18	BANGALORE	66	HV1	KOLAR 220	6:30	19:20	12:50	TRANSFORMER FAULT
145	9-Nov-18	BANGALORE	66	HV1	D CROSS	14:04	14:09	0:05	TRANSFORMER FAULT
146	9-Nov-18	BANGALORE	66	HV1	HOSKOTE 66	12:34	16:38	4:04	TRANSFORMER FAULT
147	9-Nov-18	BANGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:09	15:17	0:07	LINE FAULT
148	9-Nov-18	BANGALORE	66	HV1	KOLAR 220	10:05	11:34	1:29	LINE CLEAR AVAILED
149	9-Nov-18	BANGALORE	220	HV3	KOLAR 220	10:55	14:32	3:37	LINE CLEAR AVAILED
150	9-Nov-18	BANGALORE	66	KOLAR 220 - NARASAPURA	NARASAPURA	10:55	14:32	3:37	MAIN SUPPLY FAILURE
151	9-Nov-18	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:55	14:32	3:37	MAIN SUPPLY FAILURE
152	9-Nov-18	BANGALORE	66	HV1	KOLAR 220	16:48	17:00	0:12	LINE CLEAR AVAILED
153	9-Nov-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI	5:57	6:04	0:06	LINE FAULT
154	9-Nov-18	BANGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	6:07	6:12	0:04	LOAD CHANGEOVER
155	9-Nov-18	BANGALORE	66	HV2	KHODAYS 220	18:33	18:37	0:03	LINE CLEAR AVAILED
156	9-Nov-18	BANGALORE	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE, RBI	7:08	7:42	0:34	LINE FAULT
157	9-Nov-18	BANGALORE	66	HV2	HSR LAYOUT 220	14:07	14:10	0:02	LINE CLEAR AVAILED
158	9-Nov-18	BANGALORE	220	HV3	HOODY 220	13:40	14:05	0:25	TRANSFORMER FAULT
159	9-Nov-18	BANGALORE	220	LV2	HOODY 220	13:40	14:02	0:22	TRANSFORMER FAULT
160	9-Nov-18	BANGALORE	66	HOODY 220 - HAL 1 & 2	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT), BANASWADI	13:40	14:18	0:38	MAIN SUPPLY FAILURE
161	9-Nov-18	BANGALORE	66	HOODY 220 - ITI	ITI	13:40	14:09	0:29	MAIN SUPPLY FAILURE
162	9-Nov-18	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	13:40	14:38	0:58	MAIN SUPPLY FAILURE
163	9-Nov-18	BANGALORE	66	HV1	EPIP 220	0:00	4:55	4:55	TRANSFORMER FAULT
164	9-Nov-18	BANGALORE	66	HV1	ELITE PROMENEDE	7:08	7:44	0:36	MAIN SUPPLY FAILURE
165	10-Nov-18	BANGALORE	66	HV1	ANDERSONPET	5:44	6:07	0:22	TRANSFORMER FAULT
166	10-Nov-18	BANGALORE	66	HV2	KODIHALLI (HAROBELE)	12:54	12:56	0:02	TRANSFORMER FAULT
167	10-Nov-18	BANGALORE	66	HV2	KODIHALLI (HAROBELE)	13:22	13:37	0:14	TRANSFORMER FAULT
168	10-Nov-18	BANGALORE	66	HV1	KOLAR 220	13:37	15:25	1:47	LINE CLEAR AVAILED
169	10-Nov-18	BANGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:00	15:15	0:15	LINE FAULT
170	10-Nov-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, NANGALI, BAIRAKUR	19:42	20:04	0:21	LINE CLEAR AVAILED
171	10-Nov-18	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	5:43	6:07	0:24	LINE FAULT
172	10-Nov-18	BANGALORE	66	HV2	TEMAGONDALU	5:26	5:37	0:10	TRANSFORMER FAULT
173	10-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	2:18	2:30	0:12	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
174	10-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	6:08	6:22	0:13	LINE CLEAR AVAILED
175	10-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	16:11	16:21	0:09	LINE CLEAR AVAILED
176	10-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	18:08	18:23	0:14	LINE CLEAR AVAILED
177	10-Nov-18	BANGALORE	66	HV1	EPIP 220	14:28	14:51	0:22	LINE CLEAR AVAILED
178	10-Nov-18	BANGALORE	66	HV1	EPIP 220	15:24	15:43	0:18	TRANSFORMER FAULT
179	10-Nov-18	BANGALORE	66	HV1	KADUGODI	13:42	14:12	0:29	LINE CLEAR AVAILED
180	10-Nov-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	11:20	11:27	0:07	LINE FAULT
181	10-Nov-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	11:58	12:05	0:07	LINE FAULT
182	10-Nov-18	BANGALORE	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	9:52	17:15	7:23	LINE CLEAR AVAILED
183	10-Nov-18	BANGALORE	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	6:37	6:49	0:11	LINE FAULT
184	10-Nov-18	BANGALORE	66	HV1	VIJAYANAGARA	6:37	6:50	0:12	MAIN SUPPLY FAILURE
185	11-Nov-18	BANGALORE	66	HV1	ANDERSONPET	5:44	6:07	0:22	TRANSFORMER FAULT
186	11-Nov-18	BANGALORE	66	HV2	KODIHALLI (HAROBELE)	12:54	12:56	0:02	TRANSFORMER FAULT
187	11-Nov-18	BANGALORE	66	HV2	KODIHALLI (HAROBELE)	13:22	13:37	0:14	TRANSFORMER FAULT
188	11-Nov-18	BANGALORE	66	HV1	KOLAR 220	13:37	15:25	1:47	LINE CLEAR AVAILED
189	11-Nov-18	BANGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:00	15:15	0:15	LINE FAULT
190	11-Nov-18	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, NANGALI, BAIRAKUR	19:42	20:04	0:21	LINE CLEAR AVAILED
191	11-Nov-18	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	5:43	6:07	0:24	LINE FAULT
192	11-Nov-18	BANGALORE	66	HV2	TEMAGONDALU	5:26	5:37	0:10	TRANSFORMER FAULT
193	11-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	2:18	2:30	0:12	LINE CLEAR AVAILED
194	11-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	6:08	6:22	0:13	LINE CLEAR AVAILED
195	11-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	16:11	16:21	0:09	LINE CLEAR AVAILED
196	11-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	18:08	18:23	0:14	LINE CLEAR AVAILED
197	11-Nov-18	BANGALORE	66	HV1	EPIP 220	14:28	14:51	0:22	LINE CLEAR AVAILED
198	11-Nov-18	BANGALORE	66	HV1	EPIP 220	15:24	15:43	0:18	TRANSFORMER FAULT
199	11-Nov-18	BANGALORE	66	HV1	KADUGODI	13:42	14:12	0:29	LINE CLEAR AVAILED
200	11-Nov-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	11:20	11:27	0:07	LINE FAULT
201	11-Nov-18	BANGALORE	66	KANAKAPURA 220 - TK HALLI 1	HAROBELE, KODIHALLI, HUNSENAHALLI, HUKUNDA, BIJJALLI	11:58	12:05	0:07	LINE FAULT
202	11-Nov-18	BANGALORE	66	RMV - TATA INSTITUTE (EHT)	TATA INSTITUTE (EHT)	9:52	17:15	7:23	LINE CLEAR AVAILED
203	11-Nov-18	BANGALORE	66	NRS 220 - VIJAY NGR MY2	VIJAYANAGARA	6:37	6:49	0:11	LINE FAULT
204	11-Nov-18	BANGALORE	66	HV1	VIJAYANAGARA	6:37	6:50	0:12	MAIN SUPPLY FAILURE
205	11-Nov-18	BANGALORE	66	CHIKKENAHALLI-CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:05	6:18	0:13	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
206	11-Nov-18	BANGALORE	66	CHIKKENAHALLI-CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	11:00	11:06	0:05	LINE CLEAR AVAILED
207	11-Nov-18	BANGALORE	66	DABUSPET 220 - TYAMAGONDLU	TYAMAGONDLU, T BEGUR	12:55	13:21	0:26	LINE CLEAR AVAILED
208	11-Nov-18	BANGALORE	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	20:55	21:02	0:06	LINE FAULT
209	11-Nov-18	BANGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:48	16:40	4:52	LINE CLEAR AVAILED
210	11-Nov-18	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	14:08	14:20	0:12	LINE FAULT
211	11-Nov-18	BANGALORE	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	7:24	7:29	0:04	LOAD CHANGEOVER
212	11-Nov-18	BANGALORE	66	HV2	NELAMANGALA 66	9:58	10:06	0:07	LOAD CHANGEOVER
213	11-Nov-18	BANGALORE	66	HV3	NELAMANGALA 66	7:24	7:29	0:05	LOAD CHANGEOVER
214	11-Nov-18	BANGALORE	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	7:10	7:29	0:19	MAIN SUPPLY FAILURE
215	11-Nov-18	BANGALORE	66	SRS PEENYA 220 - DG 2	ALUR, NELAMANGALA 66	7:13	7:29	0:16	LINE FAULT
216	11-Nov-18	BANGALORE	66	ALUR - NELAMANGALA 66	ALUR	9:56	10:04	0:08	LOAD CHANGEOVER
217	11-Nov-18	BANGALORE	66	ALUR - SRS PEENYA 220	ALUR	7:29	7:34	0:05	LOAD CHANGEOVER
218	11-Nov-18	BANGALORE	66	HV2	AMAR JYOTHI	10:49	11:41	0:51	MAIN SUPPLY FAILURE
219	11-Nov-18	BANGALORE	66	ELECTRONIC CITY PH 2 SEC 2 - BIOCON (EHT)	BIOCON (EHT)	16:15	23:59	7:44	LINE FAULT
220	11-Nov-18	BANGALORE	66	ELECTRONIC CITY PH 2 SEC 2 - NAGANATHPURA 220	ELECTRONIC CITY PH 2 SEC 2, TECH MAHINDRA (EHT)	16:15	16:30	0:15	LINE FAULT
221	11-Nov-18	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE, AMARJYOTHI	10:49	12:40	1:50	LINE CLEAR AVAILED
222	11-Nov-18	BANGALORE	66	HAL 220 - ADUGODI 2	LEELA VENTURE, GOLF LINKS	10:49	13:10	2:20	LINE CLEAR AVAILED
223	11-Nov-18	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	18:05	18:38	0:32	LINE FAULT
224	11-Nov-18	BANGALORE	66	HV2	NANDINI LAYOUT	15:44	19:23	3:39	TRANSFORMER FAULT
225	11-Nov-18	BANGALORE	66	HV1	NAGANATHPURA 220	5:24	6:34	1:09	TRANSFORMER FAULT
226	12-Nov-18	BANGALORE	66	HV2	DODDABELAVANGALA	15:13	15:17	0:04	TRANSFORMER FAULT
227	12-Nov-18	BANGALORE	66	HV1	DEVANAHALLI	15:18	16:05	0:47	LINE CLEAR AVAILED
228	12-Nov-18	BANGALORE	66	DB PURA 220 - DG 2	GUDIBANDE, PERESANDRA, MANDIKAL	11:46	11:52	0:05	LOAD CHANGEOVER
229	12-Nov-18	BANGALORE	66	D PALYA - GUDIBANDE	GUDIBANDE, PERESANDRA, MANDIKAL	12:54	13:20	0:25	LINE CLEAR AVAILED
230	12-Nov-18	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR	10:16	17:54	7:38	LINE CLEAR AVAILED
231	12-Nov-18	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR	18:06	18:17	0:10	LINE CLEAR AVAILED
232	12-Nov-18	BANGALORE	66	HULLENAHALLI - KUDUR	KUDUR	18:38	18:42	0:03	LINE CLEAR AVAILED
233	12-Nov-18	BANGALORE	66	KANASWADI - DB PURA 220	KANASWADI	15:31	15:37	0:06	LOAD CHANGEOVER
234	12-Nov-18	BANGALORE	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	4:30	4:42	0:12	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
235	12-Nov-18	BANGALORE	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	15:58	16:27	0:29	LINE CLEAR AVAILED
236	12-Nov-18	BANGALORE	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:20	9:31	0:11	LINE FAULT
237	12-Nov-18	BANGALORE	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	14:33	15:58	1:24	LINE CLEAR AVAILED
238	12-Nov-18	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:12	17:30	0:18	LINE FAULT
239	12-Nov-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI	11:47	12:43	0:55	LINE FAULT
240	12-Nov-18	BANGALORE	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI	16:17	16:26	0:08	LINE FAULT
241	12-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	1:25	1:37	0:12	LINE FAULT
242	12-Nov-18	BANGALORE	66	YELAHANKA 220 - LINE 7	KANASWADI	1:37	2:14	0:36	LINE FAULT
243	12-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	11:08	11:17	0:08	LINE CLEAR AVAILED
244	12-Nov-18	BANGALORE	66	HV2	DEVARABISANAHALLI	18:21	18:33	0:12	LINE CLEAR AVAILED
245	12-Nov-18	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	6:05	6:25	0:20	LINE FAULT
246	6-Nov-18	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	10:05	12:57	2:52	LINE FAULT
247	6-Nov-18	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	15:25	15:38	0:13	LINE FAULT
248	6-Nov-18	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	18:10	18:20	0:10	LINE FAULT
249	6-Nov-18	GULBARGA	110	HV2	KOLHAR_110	16:00	16:15	0:15	TRANSFORMER FAULT
250	6-Nov-18	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110	0:06	0:47	0:41	LINE FAULT
251	6-Nov-18	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,KPC FACTORY,MUKUNDA_110,KEREHALLI_110,MA LLAPUR_110	14:30	14:35	0:05	LINE FAULT
252	6-Nov-18	GULBARGA	110	MUNIRABAD-STAR METALLIC	STAR METALLIC_IPP	14:25	15:06	0:41	LINE FAULT
253	6-Nov-18	GULBARGA	110	SANTHAPUR-RNW_SLR	SANTHAPUR_110	10:55	11:45	0:50	LINE FAULT
254	6-Nov-18	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	10:50	11:25	0:35	LINE CLEAR AVAILED
255	6-Nov-18	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	11:26	13:35	2:09	LINE FAULT
256	6-Nov-18	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	13:35	14:40	1:05	LINE CLEAR AVAILED
257	6-Nov-18	GULBARGA	110	MALLAT-MADALAPUR	MADALAPUR_110	0:06	0:47	0:41	LINE FAULT
258	6-Nov-18	GULBARGA	110	JANAWADA-SANTHAPUR	JANAWADA_110	21:40	22:05	0:25	LINE FAULT
259	6-Nov-18	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	0:00	1:10	1:10	LINE CLEAR AVAILED
260	7-Nov-18	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	15:29	15:36	0:07	LINE CLEAR AVAILED
261	7-Nov-18	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_ 110,KAMALAPUR_110,METRI_110	0:29	1:42	1:13	LINE FAULT
262	7-Nov-18	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	4:20	4:39	0:19	LINE FAULT
263	7-Nov-18	GULBARGA	110	SINDHANOOR-MUKUND	SIRIGUPPA_110,TEKKALAKOTE_110,DHADESU GUR_110	3:05	3:20	0:15	LINE FAULT
264	7-Nov-18	GULBARGA	110	SINDHANOOR-MUKUND	SIRIGUPPA_110,TEKKALAKOTE_110,DHADESU GUR_110	4:29	12:10	7:41	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
265	7-Nov-18	GULBARGA	110	SINDHANOOR-MUKUND	SIRIGUPPA_110,TEKKALAKOTE_110,DHADESU GUR_110	16:17	16:38	0:21	LINE FAULT
266	7-Nov-18	GULBARGA	110	SINDHANOOR-RAICHUR2(IDLE LINE)	MANVI_110,MADALAPURA_110	3:45	3:55	0:10	LINE FAULT
267	7-Nov-18	GULBARGA	110	SINDHANOOR-RAICHUR2(IDLE LINE)	MANVI_110,MADALAPURA_110	13:25	13:43	0:18	LINE FAULT
268	7-Nov-18	GULBARGA	110	SINDHANOOR-RAICHUR1	VALKAMDINNI_110,BYAGAWAT_110,ALKOD_ 110,SIRWAR_110	13:44	13:56	0:12	LINE FAULT
269	7-Nov-18	GULBARGA	110	BETAGERA-KSHVCMNT_SLR	BETAGERA_110	18:37	19:16	0:39	LINE FAULT
270	7-Nov-18	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	22:43	23:00	0:17	LINE FAULT
271	8-Nov-18	GULBARGA	110	GURUGUNTA-LINGASUGUR	GURUGUNTA_110	1:28	1:33	0:05	LINE FAULT
272	8-Nov-18	GULBARGA	110	GURUGUNTA-LINGASUGUR	GURUGUNTA_110	4:30	4:35	0:05	LINE FAULT
273	8-Nov-18	GULBARGA	110	GURUGUNTA-KHEL_IPP	GURUGUNTA_110	4:30	16:21	11:51	LINE FAULT
274	8-Nov-18	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110	23:25	23:31	0:06	LINE FAULT
275	8-Nov-18	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110	23:31	23:43	0:12	LINE FAULT
276	8-Nov-18	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	12:58	13:13	0:15	LINE FAULT
277	8-Nov-18	GULBARGA	110	HV2	KOLHAR_110	15:25	15:35	0:10	TRANSFORMER FAULT
278	8-Nov-18	GULBARGA	110	SINDHANOOR-FUTURE1	TURVIHAL_110	10:01	10:11	0:10	LINE FAULT
279	8-Nov-18	GULBARGA	66	ITTAGI-HBHALLI	HAGRIBOMMANAHALLI_66,UPANAYAKANAH ALLI_66	22:27	22:33	0:06	LINE FAULT
280	9-Nov-18	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	10:35	23:59	13:24	NBFC ISSUED
281	9-Nov-18	GULBARGA	110	HV2	BETAGERA_110	10:13	10:25	0:12	TRANSFORMER FAULT
282	9-Nov-18	GULBARGA	110	GURUGUNTA-LJVL_IPP	LJVL_IPP	15:50	16:00	0:10	LINE FAULT
283	9-Nov-18	GULBARGA	110	HV1	HANUMANAL_110	9:20	9:25	0:05	TRANSFORMER FAULT
284	9-Nov-18	GULBARGA	110	WADAGERA-RENEWSOLAR	WADAGERA_110	16:21	17:56	1:35	LINE FAULT
285	9-Nov-18	GULBARGA	110	PDHALLI-CLNSLR	PD_HALLI_110	20:07	20:20	0:13	LINE FAULT
286	9-Nov-18	GULBARGA	110	HV1	GURGUNTA_110	20:30	20:40	0:10	TRANSFORMER FAULT
287	10-Nov-18	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	0:00	17:15	17:15	NBFC ISSUED
288	10-Nov-18	GULBARGA	110	LINGASUGUR-GURUGUNTA	GURUGUNTA_110,KHEL_IPP,LJVL_IPP	23:40	23:45	0:05	LINE FAULT
289	10-Nov-18	GULBARGA	110	ALIPUR-MUNIRABAD	KURUGOD_110,KUDITINI_110,KAMALAPUR_1 10,TORANGALLU_110,	8:04	8:32	0:28	LINE FAULT
290	10-Nov-18	GULBARGA	110	BELLARY NORTH-ALIPUR	BELLARYNORTH_110,MOKA_110,SOMASAMU DRA_110,PD_HALLI_110	20:10	20:30	0:20	LINE FAULT
291	10-Nov-18	GULBARGA	110	HV1	HUMNABAD_220	13:35	19:35	6:00	TRANSFORMER FAULT
292	10-Nov-18	GULBARGA	110	MASKI-HATTI	HATTI_110(NO EFFECTED STATION)	12:16	23:59	11:43	LINE CLEAR AVAILED
293	10-Nov-18	GULBARGA	66	ITTAGGI-HIREHADAGALLI1,2	HIREHADAGALI_66,GIRIYAPURA_66,SOVENAH ALLI_66,MAGALA_66	6:51	6:59	0:08	LINE FAULT
294	10-Nov-18	GULBARGA	66	HV1	ITTAGI_220	14:40	14:50	0:10	TRANSFORMER FAULT
295	10-Nov-18	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	13:51	18:49	4:58	LINE CLEAR AVAILED
296	11-Nov-18	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	2:42	3:05	0:23	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
297	11-Nov-18	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	15:08	18:26	3:18	LINE CLEAR AVAILED
298	11-Nov-18	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	6:21	6:33	0:12	LINE FAULT
299	11-Nov-18	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	20:48	21:14	0:26	LINE FAULT
300	11-Nov-18	GULBARGA	66	UPNAYAKANAHALLI-MUNIRABAD	UPANAYAKANAHALLI_66	19:10	20:05	0:55	NBFC ISSUED
301	11-Nov-18	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKANAHALLI_66	18:50	20:10	1:20	LINE CLEAR AVAILED
302	11-Nov-18	GULBARGA	66	MUNIRABD-MSD LINE	HANASI_66	8:14	18:32	10:18	LINE CLEAR AVAILED
303	12-Nov-18	GULBARGA	220	HV2	MUNIRABAD_220	9:35	12:45	3:10	LINE CLEAR AVAILED
304	12-Nov-18	GULBARGA	110	MUNIRABD-HAGARI	HAGARI_110,SANKLAPUR_110,KAMALAPUR_1 10,KUDITINI_110,TORANGALLU_110	14:01	14:10	0:09	LINE CLEAR AVAILED
305	12-Nov-18	GULBARGA	110	HV7	MUNIRABAD_220	9:25	13:10	3:45	LINE CLEAR AVAILED
306	12-Nov-18	GULBARGA	110	HUMNABAD220-CHITGUPPA	CHITGUPPA_110	11:07	11:25	0:18	LINE FAULT
307	12-Nov-18	GULBARGA	110	HV2	KUSTAGI_220	15:10	16:16	1:06	TRANSFORMER FAULT
308	12-Nov-18	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	18:16	18:40	0:24	LINE FAULT
309	12-Nov-18	GULBARGA	110	GULBARGA UNIVERSITY - GULBARGA NORTH	GULBARGA UNIVERSITY_110	10:42	11:47	1:05	LINE CLEAR AVAILED
310	12-Nov-18	GULBARGA	110	HV1,HV2	LINGASUGUR_220	6:49	7:00	0:11	TRANSFORMER FAULT
311	12-Nov-18	GULBARGA	66	ITTAGGI-HBHALLI	HAGARIBOMMANAHALLI_66	1:20	1:23	0:03	LINE FAULT
312	6-Nov-18	HASSAN	220kV	GERSOP-TALGUPA1	GERSOPPA_GEN	12:03	12:54	0:51	HAND TRIPPED
313	6-Nov-18	HASSAN	220kV	GERSOP-TALGUPA2	GERSOPPA_GEN	0:00	13:42	13:42	LINE FAULT
314	6-Nov-18	HASSAN	220kV	GERSOP-TALGUPA2	GERSOPPA_GEN	13:42	14:25	0:43	LINE FAULT
315	6-Nov-18	HASSAN	220kV	GERSOP-TALGUPA2	GERSOPPA_GEN	14:42	23:59	9:17	LINE FAULT
316	6-Nov-18	HASSAN	220kV	MRSSHM-SHARAVATHY1	MRSMG_220	12:03	12:54	0:51	HAND TRIPPED
317	6-Nov-18	HASSAN	220kV	STALAGUPTRP2	TALAGUPPA_400	13:43	15:48	2:05	LINE CLEAR AVAILED
318	6-Nov-18	HASSAN	110kV	JOG-AMBTR2	JOG_110	11:48	23:59	12:11	LINE CLEAR AVAILED
319	6-Nov-18	HASSAN	110kV	MADHUVA-KUNDAPURA	MADHUVANA_110	0:00	2:54	2:54	LINE FAULT
320	6-Nov-18	HASSAN	66	CHANRAYAP-UDAYAPURA	CHANNARAYAPATNA_66	14:51	14:56	0:05	HAND TRIPPED
321	7-Nov-18	HASSAN	66	HNPURA	BYACHAN_66	11:07	11:21	0:14	LINE CLEAR AVAILED
322	7-Nov-18	HASSAN	66	HV1	BYACHAN_66	11:07	11:21	0:14	LINE CLEAR AVAILED
323	7-Nov-18	HASSAN	220	GERSOP-TALGUPA1	GERSOPPA_GEN	16:56	18:05	1:09	LINE CLEAR AVAILED
324	7-Nov-18	HASSAN	220	GERSOP-TALGUPA2	GERSOPPA_GEN	0:00	19:08	19:08	NBFC ISSUED
325	7-Nov-18	HASSAN	110	HV2	KADUR_220	5:28	11:26	5:58	TRANSFORMER FAULT
326	7-Nov-18	HASSAN	110	HV2	KADUR_220	22:19	23:59	1:40	LINE CLEAR AVAILED
327	7-Nov-18	HASSAN	220	HV1	KADUR_220	12:11	13:29	1:18	LINE CLEAR AVAILED
328	7-Nov-18	HASSAN	220	HV2	KAVOOR_220	10:19	16:52	6:33	LINE CLEAR AVAILED
329	7-Nov-18	HASSAN	110	HV1	KONAJE_110	9:44	9:50	0:06	HAND TRIPPED
330	7-Nov-18	HASSAN	110	HV1	KONAJE_110	16:58	17:01	0:03	HAND TRIPPED
331	7-Nov-18	HASSAN	110	HV2	KONAJE_110	9:46	10:45	0:59	HAND TRIPPED
332	7-Nov-18	HASSAN	110	HV2	KONAJE_110	16:58	17:02	0:04	HAND TRIPPED
333	7-Nov-18	HASSAN	110	HV3	KONAJE_110	9:46	9:49	0:03	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
334	7-Nov-18	HASSAN	110	HV3	KONAJE_110	16:59	17:02	0:03	HAND TRIPPED
335	7-Nov-18	HASSAN	66	HV2	MATTANAVILE_66	15:32	15:37	0:05	TRANSFORMER FAULT
336	7-Nov-18	HASSAN	220	SHARAVATHY1	MRSMG_220	16:57	18:05	1:08	HAND TRIPPED
337	7-Nov-18	HASSAN	110	HV2	NERALEKERE_110	14:00	15:25	1:25	LINE CLEAR AVAILED
338	7-Nov-18	HASSAN	220	STRP2	TALAGUPPA_400	0:00	18:40	18:40	LINE CLEAR AVAILED
339	8-Nov-18	HASSAN	220	Varahi1	KEMAR	13:24	13:54	0:30	LINE FAULT
340	8-Nov-18	HASSAN	220	KEMAR1	VARAHI_GEN	13:25	13:54	0:29	LINE FAULT
341	8-Nov-18	HASSAN	220	KEMAR2	VARAHI_GEN	13:24	13:58	0:34	LINE FAULT
342	9-Nov-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	11:16	16:13	4:57	LINE CLEAR AVAILED
343	9-Nov-18	HASSAN	220	MRSSHM-VARAHI1	MRSMG_220	13:03	13:22	0:19	LINE FAULT
344	9-Nov-18	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	13:03	13:22	0:19	LINE FAULT
345	9-Nov-18	HASSAN	110	HV1	ESSUR_110	12:06	13:11	1:05	LINE CLEAR AVAILED
346	9-Nov-18	HASSAN	110	HV2	ESSUR_110	13:12	15:30	2:18	LINE CLEAR AVAILED
347	9-Nov-18	HASSAN	110	KADUR-NGNHL	KADUR_220	3:15	8:54	5:39	LINE FAULT
348	9-Nov-18	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	13:45	17:47	4:02	LINE CLEAR AVAILED
349	9-Nov-18	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	14:13	14:28	0:15	LINE FAULT
350	9-Nov-18	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:27	13:35	0:08	LINE FAULT
351	9-Nov-18	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	14:23	14:28	0:05	LINE FAULT
352	9-Nov-18	HASSAN	66	HV1	CHIKMAGALUR_66	15:48	16:05	0:17	TRANSFORMER FAULT
353	10-Nov-18	HASSAN	66	HV2	BELUR_66	14:14	14:24	0:10	TRANSFORMER FAULT
354	10-Nov-18	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	18:02	18:08	0:06	LINE FAULT
355	10-Nov-18	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	9:28	17:28	8:00	LINE CLEAR AVAILED
356	10-Nov-18	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	7:22	7:38	0:16	LINE FAULT
357	10-Nov-18	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	9:29	17:38	8:09	LINE CLEAR AVAILED
358	10-Nov-18	HASSAN	66	HV2	BASAVAGHATTA_66	15:05	15:10	0:05	TRANSFORMER FAULT
359	11-Nov-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:42	19:42	1:00	LINE FAULT
360	11-Nov-18	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:09	23:59	2:50	LINE FAULT
361	11-Nov-18	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	17:10	17:53	0:43	LINE FAULT
362	11-Nov-18	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	17:53	23:59	6:06	LINE FAULT
363	11-Nov-18	HASSAN	220	MRSSHM-VARAHI2	MRSSHM	17:02	21:29	4:27	LINE FAULT
364	11-Nov-18	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	17:10	18:00	0:50	LINE FAULT
365	11-Nov-18	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	11:46	23:59	12:13	LINE CLEAR AVAILED
366	11-Nov-18	HASSAN	110	HV4	MANIPAL_110	7:36	7:53	0:17	TRANSFORMER FAULT
367	11-Nov-18	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:54	10:10	0:16	LINE FAULT
368	11-Nov-18	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:53	17:15	3:22	LINE FAULT
369	11-Nov-18	HASSAN	66	HV1	CHIKMAGALUR_66	11:35	11:43	0:08	TRANSFORMER FAULT
370	11-Nov-18	HASSAN	66	SAKALE-HANBAL	SAKALESHPURA_66	5:55	6:07	0:12	LINE FAULT
371	11-Nov-18	HASSAN	66	SAKALE-HANBAL	SAKALESHPURA_66	18:04	18:13	0:09	LINE FAULT
372	12-Nov-18	HASSAN	400kV	TALAGU-NELAMANGALA#2	TALAGUPPA_400	10:22	16:09	5:47	LINE CLEAR AVAILED
373	12-Nov-18	HASSAN	400kV	UPCL-HASSAN2	upcl_gen	0:00	16:54	16:54	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
374	12-Nov-18	HASSAN	220kV	MRSSHM-SHARAVATHY4	MRSMG_220	0:00	11:59	11:59	LINE FAULT
375	12-Nov-18	HASSAN	220kV	MRSSHM-VARAHI2	MRSMG_220	17:32	23:41	6:09	LINE FAULT
376	12-Nov-18	HASSAN	220kV	SHRAVTY-SHIMOGA4	sharavathy_gen	0:00	12:00	12:00	LINE FAULT
377	12-Nov-18	HASSAN	220kV	VARAHI-SHIMOGA2	varahi_gen	17:32	23:43	6:11	LINE FAULT
378	12-Nov-18	HASSAN	220kV	GOPALAP-BASTIPURA	GOPALAPURA_220	9:46	16:05	6:19	LINE CLEAR AVAILED
379	12-Nov-18	HASSAN	220kV	HV1	GOPALAPURA_220	9:53	15:03	5:10	LINE CLEAR AVAILED
380	12-Nov-18	HASSAN	110kV	KAVOOR-BAIKAMPADI	KAVOOR_220	0:00	19:52	19:52	LINE CLEAR AVAILED
381	12-Nov-18	HASSAN	110kV	KAVOOR-BAIKAMPADI	KAVOOR_220	20:31	20:58	0:27	HAND TRIPPED
382	12-Nov-18	HASSAN	110kV	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	7:45	7:51	0:06	LINE FAULT
383	12-Nov-18	HASSAN	110kV	HV1	CHANDRAGUTTI_110	12:17	13:56	1:39	LINE CLEAR AVAILED
384	12-Nov-18	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLI_66	12:27	13:17	0:50	LINE FAULT
385	12-Nov-18	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:56	16:04	0:08	LINE FAULT
386	12-Nov-18	HASSAN	66	HV1	CHIKMAGALUR_66	17:06	18:46	1:40	TRANSFORMER FAULT
387	12-Nov-18	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	17:55	18:04	0:09	LINE FAULT
388	6-Nov-18	MYSORE	220	HV1	HANAGODU_66	12:29	12:47	0:17	LINE CLEAR AVAILED
389	6-Nov-18	MYSORE	220	HANAGUD-HV2	HANAGODU_66	12:29	12:47	0:17	LINE CLEAR AVAILED
390	6-Nov-18	MYSORE	220	HOOTAGALLY-DATTAGALLI	DATTAGALLY_66 RKNAGARA_66	10:32	10:34	0:01	HAND TRIPPED
391	6-Nov-18	MYSORE	220	HOOTAGALLY-BELAGOLA	DATTAGALLY_66 RKNAGARA_66	10:32	20:03	9:31	HAND TRIPPED
392	6-Nov-18	MYSORE	220	KIADB MANDYA-MADDUR	K_HONNALGERE_66 MADDUR_66	11:47	11:58	0:10	LINE FAULT
393	6-Nov-18	MYSORE	220	MADHUVANAHALLY-PGPALYA	PGPALYA_66	6:04	6:16	0:11	LINE FAULT
394	6-Nov-18	MYSORE	220	MADHUVANAHALLY-PGPALYA	PGPALYA_66	6:16	6:35	0:19	LINE FAULT
395	6-Nov-18	MYSORE	220	NANJANAGUDU-BEGUR	SINDHUVALLI_66	14:49	15:02	0:13	LINE FAULT
396	6-Nov-18	MYSORE	66	HV1	HANAGODU_66	12:29	12:47	0:17	LINE CLEAR AVAILED
397	6-Nov-18	MYSORE	66	HANAGUD-HV2	HANAGODU_66	12:29	12:47	0:17	LINE CLEAR AVAILED
398	6-Nov-18	MYSORE	66	HOOTAGALLY-DATTAGALLI	DATTAGALLY_66 RKNAGARA_66	10:32	10:34	0:01	HAND TRIPPED
399	6-Nov-18	MYSORE	66	HOOTAGALLY-BELAGOLA	DATTAGALLY_66 RKNAGARA_66	10:32	20:03	9:31	HAND TRIPPED
400	6-Nov-18	MYSORE	66	KIADB MANDYA-MADDUR	K_HONNALGERE_66 MADDUR_66	11:47	11:58	0:10	LINE FAULT
401	6-Nov-18	MYSORE	66	MADHUVANAHALLY-PGPALYA	PGPALYA_66	6:04	6:16	0:11	LINE FAULT
402	6-Nov-18	MYSORE	66	MADHUVANAHALLY-PGPALYA	PGPALYA_66	6:16	6:35	0:19	LINE FAULT
403	6-Nov-18	MYSORE	66	NANJANAGUDU-BEGUR	SINDHUVALLI_66	14:49	15:02	0:13	LINE FAULT
404	7-Nov-18	MYSORE	66	FTS-JYOTHINAGARA	JYOTHINAGARA_66	7:45	7:56	0:11	HAND TRIPPED
405	7-Nov-18	MYSORE	66	JYOTHINAGARA-VAJMANGALA	JYOTHINAGARA_66	7:48	7:55	0:06	HAND TRIPPED
406	7-Nov-18	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA_66 ANTHARSANTHE_66 HDKOTE_66	18:18	18:23	0:04	LINE FAULT
407	7-Nov-18	MYSORE	66	MANDYA-HAMPAPURA	CHIKKA_MANDYA_66 HAMPAPURA_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	17:37	17:46	0:08	LINE FAULT
408	8-Nov-18	MYSORE	66	HV2	BILIKERE_66	13:08	13:40	0:31	TRANSFORMER FAULT
409	8-Nov-18	MYSORE	66	HANAGODU-PONNAMPETE	HANAGODU_66	12:15	12:22	0:07	LINE FAULT
410	8-Nov-18	MYSORE	66	HV2	HONNALY_MYS_66	9:12	9:29	0:17	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
411	8-Nov-18	MYSORE	66	KR NAGARA-KUSHALANAGARA	KRNAGARA_66 BILIKERE_66 GVGUDI_66	11:23	11:45	0:21	LINE FAULT
412	8-Nov-18	MYSORE	66	HV3	KUSHALNAGARA_220	8:06	8:32	0:26	TRANSFORMER FAULT
413	8-Nov-18	MYSORE	66	KUSHALANAGARA-MYSORE 1	MIRLE_66	11:23	11:36	0:13	LINE FAULT
414	8-Nov-18	MYSORE	66	HV2	PONNAMPET_66	20:15	20:25	0:10	TRANSFORMER FAULT
415	9-Nov-18	MYSORE	66	HV1	BOMMALAPURA_66	13:40	14:50	1:10	LINE CLEAR AVAILED
416	9-Nov-18	MYSORE	66	BOMMALAPURA-HV2	BOMMALAPURA_66	12:39	14:51	2:12	LINE CLEAR AVAILED
417	9-Nov-18	MYSORE	66	CR NAGARA-YALANDUR	YELANDUR	6:30	6:45	0:14	LINE FAULT
418	9-Nov-18	MYSORE	66	HV2	DEVANOORNGUDU_66	11:32	12:13	0:41	LINE CLEAR AVAILED
419	9-Nov-18	MYSORE	66	HV2	DEVANOORNGUDU_66	12:43	13:15	0:31	LINE CLEAR AVAILED
420	9-Nov-18	MYSORE	66	HD KOTE-KADAKOLA	HDKOTE_66	14:10	14:35	0:25	HAND TRIPPED
421	9-Nov-18	MYSORE	66	HV1	HONNALY_MYS_66	10:22	15:40	5:18	LINE CLEAR AVAILED
422	9-Nov-18	MYSORE	66	HV2	HONNALY_MYS_66	11:47	16:04	4:16	LINE CLEAR AVAILED
423	9-Nov-18	MYSORE	66	HV1	K_HONNALGERE_66	18:06	18:25	0:18	HAND TRIPPED
424	9-Nov-18	MYSORE	66	HV2	K_HONNALGERE_66	18:06	18:25	0:18	HAND TRIPPED
425	9-Nov-18	MYSORE	66	HV1	KIKKERI_66	12:04	12:58	0:53	LINE CLEAR AVAILED
426	9-Nov-18	MYSORE	66	KR PETE 220- MADESHWARAPURA	JAKKANAHALLY_66 GUDDENAHALLI_66 G MALLIGERE_66 BOGADHI MANDYA_66 NAGAMANGALA_66 MADESWARAPURA_66	6:14	6:24	0:10	LINE FAULT
427	9-Nov-18	MYSORE	66	KR PETE 220- MADESHWARAPURA	JAKKANAHALLY_66 GUDDENAHALLI_66 G MALLIGERE_66 BOGADHI MANDYA_66 NAGAMANGALA_66 MADESWARAPURA_66	6:59	8:07	1:07	HAND TRIPPED
428	9-Nov-18	MYSORE	66	KR PETE 220- MADESHWARAPURA	JAKKANAHALLY_66 GUDDENAHALLI_66 G MALLIGERE_66 BOGADHI MANDYA_66 NAGAMANGALA_66 MADESWARAPURA_66	9:50	13:27	3:37	LINE CLEAR AVAILED
429	9-Nov-18	MYSORE	66	KR PETE 220- MADESHWARAPURA	JAKKANAHALLY_66 GUDDENAHALLI_66 G MALLIGERE_66 BOGADHI MANDYA_66 NAGAMANGALA_66 MADESWARAPURA_66	16:03	16:09	0:06	LINE FAULT
430	9-Nov-18	MYSORE	66	MADHUVANAHALLI-YELANDUR	YELANDUR_66	6:30	6:40	0:10	LINE FAULT
431	9-Nov-18	MYSORE	66	HV1	MADHUVANAHALLI_220	15:08	16:06	0:58	TRANSFORMER FAULT
432	9-Nov-18	MYSORE	66	HV1	MANDYA_66	15:17	17:39	2:22	LINE CLEAR AVAILED
433	9-Nov-18	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66	14:48	17:56	3:07	NBFC ISSUED
434	9-Nov-18	MYSORE	66	SHANIVARASANTHE-MALLIPATNA	SANIVARASANTHE_66	16:24	16:25	0:01	LINE FAULT
435	9-Nov-18	MYSORE	66	SHANIVARASANTHE-YESSLUR	SANIVARASANTHE_66	16:17	16:26	0:09	LINE FAULT
436	9-Nov-18	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66	11:02	11:10	0:08	LINE FAULT
437	9-Nov-18	MYSORE	66	VAJMANGALA-BANNUR	BANNUR_66	14:21	17:29	3:07	LINE CLEAR AVAILED
438	10-Nov-18	MYSORE	66	HV1	JAKKANAHALLY_66	16:26	16:56	0:30	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
439	10-Nov-18	MYSORE	66	KADAKOLA-SARGURU 1	JAIPUR_66 HDKOTE_66 HAMPAPURA(K)_66 ANTHARSANTHE_66	19:45	19:50	0:04	LINE FAULT
440	10-Nov-18	MYSORE	66	KADAKOLA-SARGURU 1	JAIPUR_66 HDKOTE_66 HAMPAPURA(K)_66 ANTHARSANTHE_66	21:10	21:16	0:06	LINE FAULT
441	10-Nov-18	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	12:59	13:19	0:19	LINE CLEAR AVAILED
442	10-Nov-18	MYSORE	66	KIADB MANDYA-MADDUR	KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	12:59	13:19	0:19	LINE CLEAR AVAILED
443	10-Nov-18	MYSORE	66	KIADB MANDYA-MY SUGAR	KIADBMANDYA_66 MADDUR_66 K_HONNALGERE_66	12:59	13:19	0:19	LINE CLEAR AVAILED
444	10-Nov-18	MYSORE	66	KUSHALANAGAR 220-MYSORE 1	MIRLE_66 BILIKERE_66 GVGUDI_66 KRNAGARA_66	9:29	9:36	0:06	LINE FAULT
445	10-Nov-18	MYSORE	66	KUSHALANAGAR 220-MYSORE 1	MIRLE_66	12:30	12:36	0:05	LINE FAULT
446	10-Nov-18	MYSORE	66	MANDYA-M2	MALAVALLI_66 HADLI_66	8:32	8:40	0:07	LINE FAULT
447	11-Nov-18	MYSORE	66	HV2	JAKKANAHALLY_66	18:16	23:59	5:42	TRANSFORMER FAULT
448	11-Nov-18	MYSORE	66	KUSHALANAGAR 220-BYLUKUPPE	BYLUKUPPE_66	17:43	17:53	0:10	LINE FAULT
449	11-Nov-18	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 THUMBLA_66 TNARASIPURA_66	11:20	11:28	0:08	LINE FAULT
450	11-Nov-18	MYSORE	66	HV1	THALAKADU_66	4:51	4:57	0:06	HAND TRIPPED
451	11-Nov-18	MYSORE	66	HV2	THALAKADU_66	4:51	4:57	0:06	HAND TRIPPED
452	11-Nov-18	MYSORE	66	HV1	THALAKADU_66	6:58	7:02	0:04	HAND TRIPPED
453	11-Nov-18	MYSORE	66	HV2	THALAKADU_66	6:58	7:02	0:04	HAND TRIPPED
454	11-Nov-18	MYSORE	66	HV1	YELANDUR_66	10:20	14:55	4:35	LINE CLEAR AVAILED
455	11-Nov-18	MYSORE	66	HV1	YELANDUR_66	15:05	16:05	1:00	LINE CLEAR AVAILED
456	11-Nov-18	MYSORE	66	HV2	YELANDUR_66	10:40	16:55	6:15	LINE CLEAR AVAILED
457	12-Nov-18	MYSORE	66	HV1	BILIKERE_66	10:19	11:24	1:04	LINE CLEAR AVAILED
458	12-Nov-18	MYSORE	66	HV4	KUSHALNAGARA_220	14:38	15:00	0:21	LINE CLEAR AVAILED
459	12-Nov-18	MYSORE	66	HV2	MADDUR_66	11:44	13:32	1:48	LINE CLEAR AVAILED
460	12-Nov-18	MYSORE	66	MEGHALAPURA-SFC	BGPURA_66 CHIDRAVALLI_66 THUMBLA_66 TNARASIPURA_66	15:06	15:11	0:04	LINE CLEAR AVAILED
461	12-Nov-18	MYSORE	66	HV2	PANDAVAPURA_66	12:59	13:55	0:56	LINE CLEAR AVAILED
462	12-Nov-18	MYSORE	66	HV1	VAJAMANGALA_220	11:57	14:42	2:44	LINE CLEAR AVAILED
463	6-Nov-18	TUMKUR	220	TR-2	THALLAKK_220	13:02	13:09	0:06	TRANSFORMER FAULT
464	6-Nov-18	TUMKUR	66	TR-2	BAGUR_TMK_66	18:10	18:53	0:43	HAND TRIPPED
465	6-Nov-18	TUMKUR	66	DAVANGERE SRS- H- HOSPET	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:54	12:04	0:10	LINE FAULT
466	6-Nov-18	TUMKUR	66	DYAVARANAHALLI- RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:41	17:46	9:05	HAND TRIPPED
467	6-Nov-18	TUMKUR	66	TR-1	HALUVAGALU_66	15:28	16:20	0:52	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
468	6-Nov-18	TUMKUR	66	HANAGAL- GUDEKOTE	HANAGAL_66	13:16	13:23	0:07	HAND TRIPPED
469	6-Nov-18	TUMKUR	66	HANAGAL- RAMPURA	NAGASAMUDRA_66, RAMPURA_66	13:23	13:27	0:03	HAND TRIPPED
470	6-Nov-18	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	10:40	10:46	0:06	LINE FAULT
471	6-Nov-18	TUMKUR	66	KEMPANAHALLI - AGALAKOTE	AGALKOTE_66	17:25	18:28	1:03	LINE FAULT
472	6-Nov-18	TUMKUR	66	KEMPANAHALLI - AGALAKOTE	AGALKOTE_66	18:29	22:34	4:04	LINE FAULT
473	6-Nov-18	TUMKUR	66	Madhugiri 220kV- Koratagere	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	6:34	6:45	0:10	LINE FAULT
474	6-Nov-18	TUMKUR	66	MALLASANDRA- ANCHEPALYA	MALLASANDRA_66	4:07	4:14	0:07	LINE FAULT
475	6-Nov-18	TUMKUR	66	TR-1	MYLANAHALLI_66	17:17	18:00	0:42	LINE CLEAR AVAILED
476	6-Nov-18	TUMKUR	66	NEELAGUNDA 220kV- HARAPPANAHALLI	HARAPPANAHALLI_66	4:18	4:33	0:14	LINE FAULT
477	6-Nov-18	TUMKUR	66	NEELAGUNDA 220kV- HALUVAGALU	HALUVAGALU_66	6:13	6:25	0:12	LINE FAULT
478	6-Nov-18	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	13:02	13:11	0:09	HAND TRIPPED
479	6-Nov-18	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	13:02	13:14	0:11	HAND TRIPPED
480	6-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:08	13:21	0:13	LINE CLEAR AVAILED
481	7-Nov-18	TUMKUR	66	TR-2	BAGUR_TMK_66	14:08	14:17	0:08	HAND TRIPPED
482	7-Nov-18	TUMKUR	66	TR-2	BENNEHALLI_66	14:19	15:00	0:41	HAND TRIPPED
483	7-Nov-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	0:24	0:35	0:10	LINE FAULT
484	7-Nov-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	1:53	2:09	0:16	LINE FAULT
485	7-Nov-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	3:39	3:45	0:05	LINE FAULT
486	7-Nov-18	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	13:02	13:12	0:09	HAND TRIPPED
487	7-Nov-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:02	13:12	0:09	HAND TRIPPED
488	7-Nov-18	TUMKUR	66	DYAVARANAHALLI- RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:22	17:49	9:27	HAND TRIPPED
489	7-Nov-18	TUMKUR	66	KEMPANAHALLI - AGALAKOTE	AGALKOTE_66	12:17	12:57	0:39	HAND TRIPPED
490	7-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:09	8:32	0:23	LINE FAULT
491	7-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:53	11:03	0:09	LINE FAULT
492	7-Nov-18	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:09	8:27	0:18	LINE FAULT
493	7-Nov-18	TUMKUR	66	TR-2	RAMPURA_66	8:14	8:27	0:13	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
494	7-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:37	11:44	1:07	LINE FAULT
495	7-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:05	15:17	2:12	LINE FAULT
496	8-Nov-18	TUMKUR	220	TR-3(HV3)	HIRIYUR_220	5:40	5:47	0:07	TRANSFORMER FAULT
497	8-Nov-18	TUMKUR	66	HIRIYUR 220- ENERCON-1	ENERCON1_IPP_66	5:44	5:49	0:05	HAND TRIPPED
498	8-Nov-18	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	5:43	5:48	0:04	HAND TRIPPED
499	8-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP 1	HIRIYUR 220KV- RKP 1	5:45	5:49	0:03	HAND TRIPPED
500	8-Nov-18	TUMKUR	66	HIRIYUR 220KV- RKP 2	RKP2_IPP_66	5:45	5:49	0:03	HAND TRIPPED
501	8-Nov-18	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	5:40:12	5:48	#VALUE!	HAND TRIPPED
502	8-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	12:57	14:50	1:52	LINE FAULT
503	8-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	16:31	16:48	0:17	LINE FAULT
504	8-Nov-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:20	13:31	0:10	LINE FAULT
505	8-Nov-18	TUMKUR	66	DYAVARANAHALLI- RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:07	17:48	9:41	HAND TRIPPED
506	8-Nov-18	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	23:52	23:56	0:04	LINE FAULT
507	8-Nov-18	TUMKUR	66	TR-2	HULIYURDURGA_66	17:54	18:20	0:25	TRANSFORMER FAULT
508	8-Nov-18	TUMKUR	66	TR-2	MADHUGIRI_66	10:53	11:00	0:07	TRANSFORMER FAULT
509	8-Nov-18	TUMKUR	66	TR-1	MAVINAKATTE_66	3:03	3:08	0:05	TRANSFORMER FAULT
510	8-Nov-18	TUMKUR	66	TR-1	MYLANAHALLI_66	10:09	10:23	0:14	LINE CLEAR AVAILED
511	8-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:59	15:02	5:02	LINE FAULT
512	9-Nov-18	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	8:33	9:01	0:27	LINE CLEAR AVAILED
513	9-Nov-18	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	15:46	16:34	0:47	LINE CLEAR AVAILED
514	9-Nov-18	TUMKUR	220	TR-3	DAVANGERE_SRS_220	10:13	11:53	1:40	LINE CLEAR AVAILED
515	9-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	21:31	21:39	0:07	LINE FAULT
516	9-Nov-18	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	16:48	17:00	0:12	LINE FAULT
517	9-Nov-18	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:49	13:47	0:58	LINE CLEAR AVAILED
518	9-Nov-18	TUMKUR	66	DYAVARANAHALLI- RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:13	17:38	9:24	HAND TRIPPED
519	9-Nov-18	TUMKUR	66	TR-1	HANAGAL_66	12:02	12:13	0:10	LINE CLEAR AVAILED
520	9-Nov-18	TUMKUR	66	HOLALKERE- RAMGIRI 2	HOLALKERE_66	18:27	18:31	0:03	LINE FAULT
521	9-Nov-18	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66	0:02	0:15	0:13	LINE FAULT
522	9-Nov-18	TUMKUR	66	TR-2	HULIYURDURGA_66	6:07	9:08	3:01	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
523	9-Nov-18	TUMKUR	66	TR-2	IDHALLY_66	4:28	7:29	3:01	TRANSFORMER FAULT
524	9-Nov-18	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	10:05	10:20	0:15	LINE FAULT
525	9-Nov-18	TUMKUR	66	KUNDUR- HONNALI	HONNALI_66	7:37	11:47	4:10	HAND TRIPPED
526	9-Nov-18	TUMKUR	66	TR-1	MAVINAKATTE_66	5:01	5:05	0:03	TRANSFORMER FAULT
527	9-Nov-18	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:35	14:25	2:49	LINE FAULT
528	9-Nov-18	TUMKUR	66	SIRA- KALLAMBELLA	KALLAMBELLA_66	2:57	3:20	0:23	LINE FAULT
529	9-Nov-18	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	2:57	3:20	0:23	LINE FAULT
530	10-Nov-18	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	11:13	11:15	0:01	HAND TRIPPED
531	10-Nov-18	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	11:13	11:18	0:04	HAND TRIPPED
532	10-Nov-18	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	10:54	11:14	0:20	HAND TRIPPED
533	10-Nov-18	TUMKUR	220	THALLAK 220kV- BARC 1	BARC 1	10:34	15:05	4:30	LINE CLEAR AVAILED
534	10-Nov-18	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:00	8:14	0:13	LINE FAULT
535	10-Nov-18	TUMKUR	66	DYAVARANAHALLI- RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:26	18:15	9:48	HAND TRIPPED
536	10-Nov-18	TUMKUR	66	TR-1	HARAPPANAHALLI_66	12:41	12:48	0:07	TRANSFORMER FAULT
537	10-Nov-18	TUMKUR	66	HIRIYUR 220- ENERCON-1	ENERCON1_IPP_66	12:45	13:03	0:17	LINE FAULT
538	10-Nov-18	TUMKUR	66	NAGALAMADIKE- SUNDARRAJSOLAR_IPP_66	SUNDARRAJSOLAR_IPP_66	11:30	11:34	0:04	HAND TRIPPED
539	10-Nov-18	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	6:10	6:22	0:11	LINE FAULT
540	11-Nov-18	TUMKUR	110	TR-2	KADEHALLI_110	13:04	13:06	0:02	TRANSFORMER FAULT
541	11-Nov-18	TUMKUR	220	TR-1	THALLAKK_220	11:45	11:50	0:04	TRANSFORMER FAULT
542	11-Nov-18	TUMKUR	220	TR-2	THALLAKK_220	11:38	11:49	0:11	TRANSFORMER FAULT
543	11-Nov-18	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	8:46	11:32	2:45	LINE FAULT
544	11-Nov-18	TUMKUR	66	DYAVARANAHALLI- RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	8:03	17:50	9:47	HAND TRIPPED
545	11-Nov-18	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	8:43	8:54	0:10	LINE FAULT
546	11-Nov-18	TUMKUR	66	TR-2	HULIYURDURGA_66	7:10	8:06	0:55	TRANSFORMER FAULT
547	11-Nov-18	TUMKUR	66	TR-1	KATTIGE_66	9:03	9:08	0:04	TRANSFORMER FAULT
548	11-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:01	10:12	0:10	LINE FAULT
549	11-Nov-18	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:13	12:25	0:11	LINE FAULT
550	11-Nov-18	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:13	12:24	0:11	LINE FAULT

	Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
	551	11-Nov-18	TUMKUR	66	MALLASANDRA- ANCHEPALYA	MALLASANDRA_66	2:08	2:21	0:13	LINE FAULT
1-Nov-18   TUMKUR   66   UCHANGIDURGA-PALLAGATTE   PALLAGATTE_66   19:53   20:16   0:22   LINE FAULT	552	11-Nov-18	TUMKUR	66	TR-1	MALLASANDRA_66	2:19	2:21	0:02	HAND TRIPPED
S55   11-Nov-18   TUMKUR   66   THALLAK 220KY-CHALLAKERE   CHALLAKERE   66, SANIKERE   66   11:38   12:50   1:12   LINE FAULT	553	11-Nov-18	TUMKUR	66	TR-2	MALLASANDRA_66	2:19	2:21	0:02	HAND TRIPPED
11-Nov-18	554	11-Nov-18	TUMKUR	66	UCHANGIDURGA- PALLAGATTE	PALLAGATTE_66	19:53	20:16	0:22	LINE FAULT
This   Tunkur   First   Tunkur   First   Tunkur   First   Fi	555	11-Nov-18	TUMKUR	66	THALLAK 220kV- CHALLAKERE	CHALLAKERE_66, SANIKERE_66	11:38	12:50	1:12	LINE FAULT
TIMBUR   11-NOV-18   TUMKUR   66   THAILAK 220KV-WELSPUN   SOLAR1   IPP_66   11:44   11:59   0:14   LINE FAULT	556	11-Nov-18	TUMKUR	66	TR-1(LV1 SIDE	THALLAKK_220	11:45	11:51	0:06	TRANSFORMER FAULT
11-Nov-18   TUMKUR   66   SIRA-MADHUGIRI 2   BUKKAPATNA_66, KALLAMBELLA_66   8.43   8.58   0.15   LINE FAULT	557	11-Nov-18	TUMKUR	66	TR-2(LV2 SIDE	THALLAKK_220	11:38	11:53	0:14	TRANSFORMER FAULT
The first content of the fir	558	11-Nov-18	TUMKUR	66		WELSPUNSOLAR1_IPP_66	11:44	11:59	0:14	LINE FAULT
561   12-Nov-18   TUMKUR   110   TR-2   AMMASANDRA_110   12:30   12:48   0:18   LINE CLEAR AVAILED   562   12-Nov-18   TUMKUR   110   TR-3   AMMASANDRA_110   12:57   13:18   0:20   LINE CLEAR AVAILED   563   12-Nov-18   TUMKUR   110   TR-1   BANDIHALIL_110   12:00   13:13   1:13   LINE CLEAR AVAILED   564   12-Nov-18   TUMKUR   110   KALLUR-NITTUR   KALLUR_110   12:18   13:24   1:05   LINE CLEAR AVAILED   565   12-Nov-18   TUMKUR   220   TR-1(100MVA)   THALLAKK_220   16:28   17:39   1:10   LINE CLEAR AVAILED   567   12-Nov-18   TUMKUR   66   TR-2   ANTHRASANAHALLI_220   10:29   10:52   0:23   LINE CLEAR AVAILED   567   12-Nov-18   TUMKUR   66   TR-3   AVAREGERE_66   10:08   12:00   1:51   LINE CLEAR AVAILED   568   12-Nov-18   TUMKUR   66   TR-1   BENNEHALLI_66   16:32   17:22   0:50   LINE CLEAR AVAILED   569   12-Nov-18   TUMKUR   66   TR-2   BENNEHALLI_66   16:32   17:22   0:50   LINE CLEAR AVAILED   570   12-Nov-18   TUMKUR   66   TR-2   BENNEHALLI_66   17:22   18:21   0:58   LINE CLEAR AVAILED   570   12-Nov-18   TUMKUR   66   TR-2   BENNEHALLI_66   17:22   18:21   0:58   LINE CLEAR AVAILED   571   12-Nov-18   TUMKUR   66   CHITRADURGA 220kV- SUZLON   SUZLON 1_IPP_66, SUZLON 2_IPP_66   11:07   18:05   6:58   LINE CLEAR AVAILED   572   12-Nov-18   TUMKUR   66   TR-2   DAVANGERE_66   13:12   13:39   0:27   LINE CLEAR AVAILED   573   12-Nov-18   TUMKUR   66   DAVANGERE SRS- H- HOSPET   BANUVALIL_66, NANDIGUD _ 66   8:36   8:41   0:04   LOAD CURTAILMENT   575   12-Nov-18   TUMKUR   66   DAVANGERE SRS- H- HOSPET   BANUVALIL_66, NANDIGUD _ 66   8:36   8:41   0:04   LOAD CURTAILMENT   576   12-Nov-18   TUMKUR   66   TR-1   MYLANHALL_66   10:38   11:00   0:21   TRANSFORMER FAULT   578   12-Nov-18   TUMKUR   66   TR-1   MYLANHALL_66   9:57   17:36   7:39   LINE CLEAR AVAILED   577   12-Nov-18   TUMKUR   66   TR-1   MYLANHALL_66   9:57   17:37   7:40   LINE CLEAR AVAILED   578   12-Nov-18   TUMKUR   66   TR-1   MYLANHALL_66   9:57   17:37   7:40   LINE CLEAR AVAILED   579   12-Nov-18   TUMKUR   66   TR-1   MYLANHA	559	11-Nov-18	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	8:43	8:58	0:15	LINE FAULT
TUMKUR	560	12-Nov-18	TUMKUR	110	TR-1	AMMASANDRA_110	12:44	13:02	0:18	LINE CLEAR AVAILED
563         12-Nov-18         TUMKUR         110         TR-1         BANDIHALLI_110         12:00         13:13         1:13         LINE CLEAR AVAILED           564         12-Nov-18         TUMKUR         110         KALLUR-NITTUR         KALLUR_110         12:18         13:24         1:05         LINE CLEAR AVAILED           565         12-Nov-18         TUMKUR         220         16:28         17:39         1:10         LINE CLEAR AVAILED           566         12-Nov-18         TUMKUR         66         TR-2         ANTHRASANAHALLI_220         10:29         10:52         0:23         LINE CLEAR AVAILED           567         12-Nov-18         TUMKUR         66         TR-3         AVAREGERE_66         10:08         12:00         1:51         LINE CLEAR AVAILED           569         12-Nov-18         TUMKUR         66         TR-1         BENNEHALL_66         16:32         17:22         0:50         LINE CLEAR AVAILED           570         12-Nov-18         TUMKUR         66         TR-2         BRAHMASANDRA_66         23:07         23:33         0:26         LINE CLEAR AVAILED           571         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- SUZLON1         SUZLON1_IPP-66, SUZLON2_IPP-66	561	12-Nov-18	TUMKUR	110	TR-2	AMMASANDRA_110	12:30	12:48	0:18	LINE CLEAR AVAILED
564         12-Nov-18         TUMKUR         110         KALLUR-NITTUR         KALLUR_110         12:18         13:24         1:05         LINE CLEAR AVAILED           565         12-Nov-18         TUMKUR         220         TR-1(100MVA)         THALLAKK_220         16:28         17:39         1:10         LINE CLEAR AVAILED           566         12-Nov-18         TUMKUR         66         TR-2         ANTHRASANAHALLI_220         10:29         10:52         0:23         LINE CLEAR AVAILED           567         12-Nov-18         TUMKUR         66         TR-3         AVAREGRE 66         10:08         12:00         1:51         LINE CLEAR AVAILED           568         12-Nov-18         TUMKUR         66         TR-1         BENNEHALLI_66         16:32         17:22         0:50         LINE CLEAR AVAILED           569         12-Nov-18         TUMKUR         66         TR-2         BENNEHALLI_66         17:22         18:21         0:58         LINE CLEAR AVAILED           570         12-Nov-18         TUMKUR         66         TR-2         BRAHMASANDRA_66         23:07         23:33         0:26         LINE CLEAR AVAILED           571         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- SUZLON1	562	12-Nov-18	TUMKUR	110	TR-3	AMMASANDRA_110	12:57	13:18	0:20	LINE CLEAR AVAILED
565         12-Nov-18         TUMKUR         220         TR-1(100MVA)         THALLAKK_220         16:28         17:39         1:10         LINE CLEAR AVAILED           566         12-Nov-18         TUMKUR         66         TR-2         ANTHRASANAHALLI_220         10:29         10:52         0:23         LINE CLEAR AVAILED           567         12-Nov-18         TUMKUR         66         TR-3         AVAREGERE_66         10:08         12:00         1:51         LINE CLEAR AVAILED           568         12-Nov-18         TUMKUR         66         TR-1         BENNEHALLI_66         16:32         17:22         0:50         LINE CLEAR AVAILED           569         12-Nov-18         TUMKUR         66         TR-2         BENNEHALLI_66         17:22         18:21         0:58         LINE CLEAR AVAILED           570         12-Nov-18         TUMKUR         66         TR-2         BRAHMASANDRA_66         23:07         23:33         0:26         LINE CLEAR AVAILED           571         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- SUZLON1         SUZLON1_IPP_66, SUZLON2_IPP_66         11:07         18:05         6:58         LINE CLEAR AVAILED           572         12-Nov-18         TUMKUR         66         T	563	12-Nov-18	TUMKUR	110	TR-1	BANDIHALLI_110	12:00	13:13	1:13	LINE CLEAR AVAILED
566         12-Nov-18         TUMKUR         66         TR-2         ANTHRASANAHALLI_220         10:29         10:52         0:23         LINE CLEAR AVAILED           567         12-Nov-18         TUMKUR         66         TR-3         AVAREGERE_66         10:08         12:00         1:51         LINE CLEAR AVAILED           568         12-Nov-18         TUMKUR         66         TR-1         BENEHALLI_66         16:32         17:22         0:50         LINE CLEAR AVAILED           570         12-Nov-18         TUMKUR         66         TR-2         BENNEHALLI_66         17:22         18:21         0:58         LINE CLEAR AVAILED           570         12-Nov-18         TUMKUR         66         TR-2         BRAHMASANDRA_66         23:07         23:33         0:26         LINE CLEAR AVAILED           571         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- SUZLON1         SUZLON1_IPP_66, SUZLON2_IPP_66         11:07         18:05         6:58         LINE CLEAR AVAILED           572         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- HIRIYUR         IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66         12:48         13:34         0:45         LINE CLEAR AVAILED           573         12-Nov-18         TUMKU	564	12-Nov-18	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	12:18	13:24	1:05	LINE CLEAR AVAILED
567         12-Nov-18         TUMKUR         66         TR-3         AVAREGERE_66         10:08         12:00         1:51         LINE CLEAR AVAILED           568         12-Nov-18         TUMKUR         66         TR-1         BENNEHALLI_66         16:32         17:22         0:50         LINE CLEAR AVAILED           569         12-Nov-18         TUMKUR         66         TR-2         BENNEHALLI_66         17:22         18:21         0:58         LINE CLEAR AVAILED           570         12-Nov-18         TUMKUR         66         TR-2         BRAHMASANDRA_66         23:07         23:33         0:26         LINE CLEAR AVAILED           571         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- SUZLON 1         SUZLON1_IPP_66, SUZLON2_IPP_66         11:07         18:05         6:58         LINE CLEAR AVAILED           572         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- HIRIYUR         IMANGALA_66, ENERCON1_IPP_66, SUZLON2_IPP_66         12:48         13:34         0:45         LINE CLEAR AVAILED           573         12-Nov-18         TUMKUR         66         TR-2         DAVANAGERE FACH         13:12         13:39         0:27         LINE CLEAR AVAILED           574         12-Nov-18         TUM	565	12-Nov-18	TUMKUR	220	TR-1(100MVA)	THALLAKK_220	16:28	17:39	1:10	LINE CLEAR AVAILED
568         12-Nov-18         TUMKUR         66         TR-1         BENNEHALLI_66         16:32         17:22         0:50         LINE CLEAR AVAILED           569         12-Nov-18         TUMKUR         66         TR-2         BENNEHALLI_66         17:22         18:21         0:58         LINE CLEAR AVAILED           570         12-Nov-18         TUMKUR         66         TR-2         BRAHMASANDRA_66         23:07         23:33         0:26         LINE CLEAR AVAILED           571         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- SUZLON 1         SUZLON1_IPP_66, SUZLON2_IPP_66         11:07         18:05         6:58         LINE CLEAR AVAILED           572         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- HIRIYUR         IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66         12:48         13:34         0:45         LINE CLEAR AVAILED           573         12-Nov-18         TUMKUR         66         TR-2         DAVANAGERE 66         13:12         13:39         0:27         LINE CLEAR AVAILED           574         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR-66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         8:36         8:41         0:04         LOAD CURTAILMENT	566	12-Nov-18	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	10:29	10:52	0:23	LINE CLEAR AVAILED
569         12-Nov-18         TUMKUR         66         TR-2         BENNEHALLI_66         17:22         18:21         0:58         LINE CLEAR AVAILED           570         12-Nov-18         TUMKUR         66         TR-2         BRAHMASANDRA_66         23:07         23:33         0:26         LINE CLEAR AVAILED           571         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- SUZLON 1         SUZLON1_IPP_66, SUZLON2_IPP_66         11:07         18:05         6:58         LINE CLEAR AVAILED           572         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- HIRIYUR         IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66         12:48         13:34         0:45         LINE CLEAR AVAILED           573         12-Nov-18         TUMKUR         66         TR-2         DAVANAGERE_66         13:12         13:39         0:27         LINE CLEAR AVAILED           574         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR-66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         8:36         8:41         0:04         LOAD CURTAILMENT           576         12-Nov-18         TUMKUR         66         TR-1 &2         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         10:37         14:57         4:20         LINE	567	12-Nov-18	TUMKUR	66	TR-3	AVAREGERE_66	10:08	12:00	1:51	LINE CLEAR AVAILED
570         12-Nov-18         TUMKUR         66         TR-2         BRAHMASANDRA_66         23:07         23:33         0:26         LINE CLEAR AVAILED           571         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- SUZLON 1 &2         SUZLON1_IPP_66, SUZLON2_IPP_66         11:07         18:05         6:58         LINE CLEAR AVAILED           572         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- HIRIYUR         IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66         12:48         13:34         0:45         LINE CLEAR AVAILED           573         12-Nov-18         TUMKUR         66         TR-2         DAVANAGERE_66         13:12         13:39         0:27         LINE CLEAR AVAILED           574         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         8:36         8:41         0:04         LOAD CURTAILMENT           575         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         10:37         14:57         4:20         LINE CLEAR AVAILED           576         12-Nov-18         TUMKUR         66         TR-1         MYLANAHALL_66         10:39         13:34         2:55 </th <th>568</th> <td>12-Nov-18</td> <td>TUMKUR</td> <td>66</td> <td>TR-1</td> <td>BENNEHALLI_66</td> <td>16:32</td> <td>17:22</td> <td>0:50</td> <td>LINE CLEAR AVAILED</td>	568	12-Nov-18	TUMKUR	66	TR-1	BENNEHALLI_66	16:32	17:22	0:50	LINE CLEAR AVAILED
571         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- SUZLON 1 & SUZLON1_IPP_66, SUZLON2_IPP_66         11:07         18:05         6:58         LINE CLEAR AVAILED           572         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- HIRIYUR         IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66         12:48         13:34         0:45         LINE CLEAR AVAILED           573         12-Nov-18         TUMKUR         66         TR-2         DAVANAGERE_66         13:12         13:39         0:27         LINE CLEAR AVAILED           574         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         8:36         8:41         0:04         LOAD CURTAILMENT           575         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         10:37         14:57         4:20         LINE CLEAR AVAILED           576         12-Nov-18         TUMKUR         66         TR-1 & MYLANAHALL_66         10:39         13:34         2:55         LINE CLEAR AVAILED           578         12-Nov-18         TUMKUR         66         TR-1         MYLANAHALL_66         9:57         17:36         7:39         LINE CLEAR AVAILED </th <th>569</th> <td>12-Nov-18</td> <td>TUMKUR</td> <td>66</td> <td>TR-2</td> <td>BENNEHALLI_66</td> <td>17:22</td> <td>18:21</td> <td>0:58</td> <td>LINE CLEAR AVAILED</td>	569	12-Nov-18	TUMKUR	66	TR-2	BENNEHALLI_66	17:22	18:21	0:58	LINE CLEAR AVAILED
571         12-Nov-16         TUMKUR         66         S2         SUZLONI_IPP_66, SUZLONI_IPP_66         11:07         16:05         6:58         LINE CLEAR AVAILED           572         12-Nov-18         TUMKUR         66         CHITRADURGA 220kV- HIRIYUR         IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66         12:48         13:34         0:45         LINE CLEAR AVAILED           573         12-Nov-18         TUMKUR         66         TR-2         DAVANAGERE_66         13:12         13:39         0:27         LINE CLEAR AVAILED           574         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         8:36         8:41         0:04         LOAD CURTAILMENT           575         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         10:37         14:57         4:20         LINE CLEAR AVAILED           576         12-Nov-18         TUMKUR         66         TR-1 &2         HARIHAR_66         10:39         13:34         2:55         LINE CLEAR AVAILED           577         12-Nov-18         TUMKUR         66         TR-1         MYLANAHALLI_66         9:57         17:36         7:39         LINE CLEAR AVA	570	12-Nov-18	TUMKUR	66	TR-2	BRAHMASANDRA_66	23:07	23:33	0:26	LINE CLEAR AVAILED
572         12-Nov-16         TOMKOR         66         CHIRADORGA 220KY-HIKTOR         HIRIYUR_66         12:48         13:34         0:43         LINE CLEAR AVAILED           573         12-Nov-18         TUMKUR         66         TR-2         DAVANAGERE_66         13:12         13:39         0:27         LINE CLEAR AVAILED           574         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         8:36         8:41         0:04         LOAD CURTAILMENT           575         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         10:37         14:57         4:20         LINE CLEAR AVAILED           576         12-Nov-18         TUMKUR         66         TR-1 &2         HARIHAR_66         10:39         13:34         2:55         LINE CLEAR AVAILED           577         12-Nov-18         TUMKUR         66         TR-1         MYLANAHALLI_66         10:38         11:00         0:21         TRANSFORMER FAULT           578         12-Nov-18         TUMKUR         66         SAVALANGA-HONNALLI         SAVALANGA_66         9:57         17:36         7:39         LINE CLEAR AVAILED	571	12-Nov-18	TUMKUR	66		SUZLON1_IPP_66, SUZLON2_IPP_66	11:07	18:05	6:58	LINE CLEAR AVAILED
574         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         8:36         8:41         0:04         LOAD CURTAILMENT           575         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         10:37         14:57         4:20         LINE CLEAR AVAILED           576         12-Nov-18         TUMKUR         66         TR-1 &2         HARIHAR_66         10:39         13:34         2:55         LINE CLEAR AVAILED           577         12-Nov-18         TUMKUR         66         TR-1         MYLANAHALLI_66         10:38         11:00         0:21         TRANSFORMER FAULT           578         12-Nov-18         TUMKUR         66         SAVALANGA-HONNALLI         SAVALANGA_66         9:57         17:36         7:39         LINE CLEAR AVAILED           579         12-Nov-18         TUMKUR         66         TR-1         SAVALANGA_66         9:57         17:37         7:40         LINE CLEAR AVAILED	572	12-Nov-18	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR		12:48	13:34	0:45	LINE CLEAR AVAILED
574         12-Nov-16         TUMKUR         66         DAVANGERE SRS- H- HOSPET         BANUVALLI_66, NANDIGUDI_66         65         8:41         0:04         LOAD CORTALIMENT           575         12-Nov-18         TUMKUR         66         DAVANGERE SRS- H- HOSPET         HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66         10:37         14:57         4:20         LINE CLEAR AVAILED           576         12-Nov-18         TUMKUR         66         TR-1 &         MYLANAHALLI_66         10:39         13:34         2:55         LINE CLEAR AVAILED           577         12-Nov-18         TUMKUR         66         TR-1         MYLANAHALLI_66         10:38         11:00         0:21         TRANSFORMER FAULT           578         12-Nov-18         TUMKUR         66         SAVALANGA_66         9:57         17:36         7:39         LINE CLEAR AVAILED           579         12-Nov-18         TUMKUR         66         TR-1         SAVALANGA_66         9:57         17:37         7:40         LINE CLEAR AVAILED	573	12-Nov-18	TUMKUR	66	TR-2	DAVANAGERE_66	13:12	13:39	0:27	LINE CLEAR AVAILED
575         12-Nov-16         TOMKOR         66         DAVANGERE SR3- H- HOSPET         BANUVALLI_66, NANDIGUDI_66         10:37         14:37         4:20         LINE CLEAR AVAILED           576         12-Nov-18         TUMKUR         66         TR-1 &2         HARIHAR_66         10:39         13:34         2:55         LINE CLEAR AVAILED           577         12-Nov-18         TUMKUR         66         TR-1         MYLANAHALLI_66         10:38         11:00         0:21         TRANSFORMER FAULT           578         12-Nov-18         TUMKUR         66         SAVALANGA-HONNALLI         SAVALANGA_66         9:57         17:36         7:39         LINE CLEAR AVAILED           579         12-Nov-18         TUMKUR         66         TR-1         SAVALANGA_66         9:57         17:37         7:40         LINE CLEAR AVAILED	574	12-Nov-18	TUMKUR	66	DAVANGERE SRS- H- HOSPET		8:36	8:41	0:04	LOAD CURTAILMENT
577         12-Nov-18         TUMKUR         66         TR-1         MYLANAHALLI_66         10:38         11:00         0:21         TRANSFORMER FAULT           578         12-Nov-18         TUMKUR         66         SAVALANGA-HONNALLI         SAVALANGA_66         9:57         17:36         7:39         LINE CLEAR AVAILED           579         12-Nov-18         TUMKUR         66         TR-1         SAVALANGA_66         9:57         17:37         7:40         LINE CLEAR AVAILED	575	12-Nov-18	TUMKUR	66	DAVANGERE SRS- H- HOSPET	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:37	14:57	4:20	LINE CLEAR AVAILED
577         12-Nov-18         TUMKUR         66         TR-1         -         10:38         11:00         0:21         TRANSFORMER FAULT           578         12-Nov-18         TUMKUR         66         SAVALANGA-HONNALLI         SAVALANGA_66         9:57         17:36         7:39         LINE CLEAR AVAILED           579         12-Nov-18         TUMKUR         66         TR-1         SAVALANGA_66         9:57         17:37         7:40         LINE CLEAR AVAILED	576	12-Nov-18	TUMKUR	66	TR-1 &2	HARIHAR_66	10:39	13:34	2:55	LINE CLEAR AVAILED
579         12-Nov-18         TUMKUR         66         TR-1         SAVALANGA_66         9:57         17:37         7:40         LINE CLEAR AVAILED	577	12-Nov-18	TUMKUR	66	TR-1	MYLANAHALLI_66	10:38	11:00	0:21	TRANSFORMER FAULT
	578	12-Nov-18	TUMKUR	66	SAVALANGA- HONNALLI	SAVALANGA_66	9:57	17:36	7:39	LINE CLEAR AVAILED
580         12-Nov-18         TUMKUR         66         HANAGAL- AVADASOLAR_IPP_66         AVADASOLAR_IPP_66         11:12         11:30         0:17         LINE FAULT	579	12-Nov-18	TUMKUR	66	TR-1	SAVALANGA_66	9:57	17:37	7:40	LINE CLEAR AVAILED
	580	12-Nov-18	TUMKUR	66	HANAGAL- AVADASOLAR_IPP_66	AVADASOLAR_IPP_66	11:12	11:30	0:17	LINE FAULT