

400/220/110/66 kV TRANSMISSION OUTAGES FROM 07.09.2021 TO 13.09.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	7-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
2	7-Sep-2021	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	17:30	17:37	0:07	TRANSFORMER FAULT
3	7-Sep-2021	BAGALKOT	110	110/11KV, HV1	DEVANAGOAN_110	11:35	12:00	0:25	LINE CLEAR AVAILED
4	7-Sep-2021	BAGALKOT	110	110/11KV, HV1	DEVANAGOAN_110	16:10	17:10	1:00	LINE CLEAR AVAILED
5	7-Sep-2021	BAGALKOT	110	110/11KV, HV1	NAGNUR_110	5:05	5:15	0:10	MAIN SUPPLY FAILURE
6	7-Sep-2021	BAGALKOT	110	110/11KV, HV1&HV2	LAKKMANHALLI_110	10:04	14:05	4:01	LINE CLEAR AVAILED
7	7-Sep-2021	BAGALKOT	110	110/11KV, HV1A	JAMKHANDI_110	9:08	10:14	1:06	LINE CLEAR AVAILED
8	7-Sep-2021	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	15:25	16:05	0:40	LINE CLEAR AVAILED
9	7-Sep-2021	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	10:20	11:05	0:45	LINE CLEAR AVAILED
10	7-Sep-2021	BAGALKOT	110	110/11KV, HV2	DEVANAGOAN_110	16:10	17:10	1:00	LINE CLEAR AVAILED
11	7-Sep-2021	BAGALKOT	110	110/11KV, HV2	NAGNUR_110	5:05	5:15	0:10	MAIN SUPPLY FAILURE
12	7-Sep-2021	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	9:08	10:14	1:06	LINE CLEAR AVAILED
13	7-Sep-2021	BAGALKOT	110	110/11KV, HV4	VODAGOAN_110	10:04	10:58	0:54	LINE CLEAR AVAILED
14	7-Sep-2021	BAGALKOT	110	110/11KV, HV4	VODAGOAN_110	12:47	19:22	6:35	LINE CLEAR AVAILED
15	7-Sep-2021	BAGALKOT	110	110/11KV,HV1	ALABAL_110	16:41	17:07	0:26	HAND TRIPPED
16	7-Sep-2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:12 (29.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
17	7-Sep-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR CITY_110	19:59	20:03	0:04	TRANSFORMER FAULT
18	7-Sep-2021	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR_33	10:04	16:40	6:36	LINE CLEAR AVAILED
19	7-Sep-2021	BAGALKOT	110	110/33KV, HV4	KANABARGI LAYOUT_110, KAKATI_33, SUZLON_33	12:15	12:43	0:28	LINE CLEAR AVAILED
20	7-Sep-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
21	7-Sep-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
22	7-Sep-2021	BAGALKOT	110	BAGALKOT-KATARKI(NEERBUDIHAL)	NEERBUDIHAL_110	23:31	23:44	0:13	LINE FAULT
23	7-Sep-2021	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA 1&2	GHATAPRABHA_110	10:40	18:57	8:17	LINE CLEAR AVAILED
24	7-Sep-2021	BAGALKOT	110	GHATAPRABHA220-PG HUNASYAL	PG HUNSYAL_110	5:06	5:13	0:07	LINE FAULT
25	7-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
26	7-Sep-2021	BAGALKOT	110	ITANAL(MUGALKOD)- RAIBAG	RAIBAG_110	12:01	12:17	0:16	HAND TRIPPED
27	7-Sep-2021	BAGALKOT	110	KUD DHARWAD- LAKMANHALLI	LAKMANHALLI_110	10:45	13:48	3:03	LINE CLEAR AVAILED
28	7-Sep-2021	BAGALKOT	110	MUGALKOD- ITANAL1	ITANAL_110	10:17	12:17	2:00	LINE CLEAR AVAILED
29	7-Sep-2021	BAGALKOT	110	MUGALKOD2- RAIBAG	RAIBAG_110	12:01	12:17	0:16	HAND TRIPPED
30	7-Sep-2021	BAGALKOT	110	NAGNUR- MUDALGI	MUDALGI_110	5:05	5:15	0:10	MAIN SUPPLY FAILURE
31	7-Sep-2021	BAGALKOT	110	PG HUNSHYAL- NAGNUR	NAGNUR_110	5:05	5:15	0:10	MAIN SUPPLY FAILURE
32	7-Sep-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
33	7-Sep-2021	BAGALKOT	110	RON- HIREHAL	HIREHAL_110	23:07	23:28	0:21	LINE FAULT
34	7-Sep-2021	BAGALKOT	110	SATTI- RABAKAVI	SATTI_110	21:38	21:48	0:10	HAND TRIPPED
35	7-Sep-2021	BAGALKOT	110	SAVANUR- ASF SOLAR	SAVANUR_110	16:32	16:41	0:09	LINE FAULT
36	7-Sep-2021	BAGALKOT	110	SINDAGI- CHANDKAVATE	CHANDKAVATE_110	7:30	7:45	0:15	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
37	7-Sep-2021	BAGALKOT	110	SIRAGUPPI-BILAGI	BILAGI_110,GIRISAGAR_110 ,TOLAMATTI_110,BISANAL_110	10:30	10:35	0:05	LINE CLEAR AVOIDED
38	7-Sep-2021	BAGALKOT	110	TADASINKOPPA- GAMANGATTI	TADASINKOPPA_110	12:22	16:44	4:22	LINE CLEAR AVOIDED
39	7-Sep-2021	BAGALKOT	110	VAJRAMATTI-LOKAPUR	LOKAPUR_110	6:30	7:30	1:00	LINE FAULT
40	7-Sep-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN,LINE FAULT
41	7-Sep-2021	BAGALKOT	220	GADAG-HARTI1	STATION NOT AFFECTED GADAG_220	9:52 (24.08.2021)			LINE OPEN,LINE FAULT
42	7-Sep-2021	BAGALKOT	220	HUBLI- NARENDRA2	HUBLI_220	11:22	14:42	3:20	LINE CLEAR AVOIDED
43	7-Sep-2021	BAGALKOT	220	HUBLI- SIRSI1&2	HUBLI_220	11:31	15:42	4:11	NFBC ISSUED
44	7-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
45	7-Sep-2021	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	15:15	20:05	4:50	LINE FAULT
46	7-Sep-2021	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	11:24	14:40	3:16	LINE CLEAR AVOIDED
47	7-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
48	7-Sep-2021	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	17:59 (30.08.2021)			LINE OPEN,LINE CLEAR AVOIDED
49	7-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
50	7-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
51	7-Sep-2021	BENGALURU	66	CHINTAMANI 66 - SM MANGALA	SM MANGALA	5:57	7:00	1:03	LINE FAULT
52	7-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA, ADUGODI, BOSCH(EHT)	10:11	10:22	0:11	HAND TRIPPED
53	7-Sep-2021	BENGALURU	66	HV1	DODDABELAVANGALA	8:34	10:03	1:28	TRANSFORMER FAULT
54	7-Sep-2021	BENGALURU	66	HV1	MULBAGLU	16:38	16:45	0:06	TRANSFORMER FAULT
55	7-Sep-2021	BENGALURU	66	HV2	DODDABELAVANGALA	0:07(3-9-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
56	7-Sep-2021	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	NO STATION AFFECTED	5:52	6:29	0:36	LINE FAULT
57	7-Sep-2021	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	8:21	8:45	0:24	LINE FAULT
58	7-Sep-2021	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	11:10	11:15	0:05	HAND TRIPPED
59	7-Sep-2021	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	11:10	11:15	0:05	HAND TRIPPED
60	7-Sep-2021	BENGALURU	66	KODIGEHALLI - ANCHEPALYA 220	KODIGEHALLI, TAVAREKERE	16:16	16:25	0:09	LOAD CHANGE OVER
61	7-Sep-2021	BENGALURU	66	KODIGEHALLI - BYDRAHALLI	KODIGEHALLI, TAVAREKERE	6:52	7:10	0:18	LOAD CHANGE OVER
62	7-Sep-2021	BENGALURU	66	KOLAR 220 - PGCIL AUX	PGCIL, SUGUTUR	6:58	7:02	0:04	LOAD CHANGE OVER
63	7-Sep-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	10:30	10:35	0:05	LOAD CHANGE OVER
64	7-Sep-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	15:00	15:05	0:05	HAND TRIPPED
65	7-Sep-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	7:08	7:48	0:40	MAIN SUPPLY FAILURE
66	7-Sep-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	7:08	9:24	2:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
67	7-Sep-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	9:28	9:34	0:06	LINE CLEAR AVAILED
68	7-Sep-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), BANGARPETE	7:08	7:48	0:40	MAIN SUPPLY FAILURE
69	7-Sep-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), BANGARPETE	9:00	9:06	0:05	LINE CLEAR AVAILED
70	7-Sep-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), BANGARPETE	9:28	9:34	0:06	LINE CLEAR AVAILED
71	7-Sep-2021	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	5:25	5:35	0:09	LINE FAULT
72	7-Sep-2021	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	9:28	9:30	0:02	LOAD CHANGE OVER
73	7-Sep-2021	BENGALURU	66	SM MANGALA - KOLAR 220	SM MANGALA	8:50	9:08	0:18	LOAD CHANGE OVER
74	7-Sep-2021	BENGALURU	66	SOMENAHALLI - AFTL SOLAR (IPP)	NO STATION AFFECTED	5:25	5:26	0:01	LINE FAULT
75	7-Sep-2021	BENGALURU	66	SOMENAHALLI - AFTL SOLAR (IPP)	NO STATION AFFECTED	8:24	8:28	0:04	LINE FAULT
76	7-Sep-2021	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	6:34	6:40	0:06	LOAD CHANGE OVER
77	7-Sep-2021	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, SRIGANDA KAVALU	7:00	15:59	8:59	LINE CLEAR AVAILED
78	7-Sep-2021	BENGALURU	220	HOODY 220 - RAILWAYS 2 220	NO STATION AFFECTED	20:05	21:33	1:28	LINE FAULT
79	7-Sep-2021	BENGALURU	220	HV1	MALUR 220	7:08	7:45	0:37	TRANSFORMER FAULT
80	7-Sep-2021	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 1	RAILWAY TRACTION (EHT)	20:02	20:12	0:10	LINE FAULT
81	7-Sep-2021	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 1	RAILWAY TRACTION (EHT)	20:12(7-9-2021)			LINE OPEN,LINE FAULT
82	7-Sep-2021	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 2	RAILWAY TRACTION (EHT)	23:34(7-9-2021)			LINE OPEN,LINE CLEAR AVAILED
83	7-Sep-2021	BENGALURU	220	LV1	MALUR 220	7:08	7:46	0:38	TRANSFORMER FAULT
84	7-Sep-2021	BENGALURU	400	NELAMANGALA 400 - HASAN 400	NO STATION AFFECTED	0:12	11:33	11:20	LINE FAULT
85	7-Sep-2021	GULBARGA	110	BISIHALLI-BELLARY NORTH	BISIHALLI_110	10:17	10:41	0:24	MAIN SUPPLY FAILURE
86	7-Sep-2021	GULBARGA	110	BISIHALLI-BELLARY NORTH	BISIHALLI_110	13:06	13:14	0:08	MAIN SUPPLY FAILURE
87	7-Sep-2021	GULBARGA	110	GULBARGASOUTH-GULBARGA UNIVERSITY	GULBARGAUNIVERSITY_110	18:35(30.07.2021)	16:30(7.09.2021)	957:55 HRS	LINE CHARGED
88	7-Sep-2021	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
89	7-Sep-2021	GULBARGA	110	HV3	VALKAMDINNI_110	18:38	18:45	0:07	TRANSFORMER FAULT
90	7-Sep-2021	GULBARGA	110	MASKI-SINDHANOOR	HATTI_110,MASKI_110	5:29	5:34	0:05	LINE FAULT
91	7-Sep-2021	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUT_110	15:52	15:56	0:04	MAIN SUPPLY FAILURE
92	7-Sep-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	6:10	6:20	0:10	LINE FAULT
93	7-Sep-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	9:18	9:25	0:07	LINE FAULT
94	7-Sep-2021	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	9:18	9:25	0:07	LINE FAULT
95	7-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	4:14	4:20	0:06	LINE FAULT
96	7-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:14	4:20	0:06	LINE FAULT
97	7-Sep-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	18:50(08.09.2021)			LINE OPEN,LINE FAULT
98	7-Sep-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	6:33	6:43	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
99	7-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
100	7-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
101	7-Sep-2021	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	6:05	6:15	0:10	LINE FAULT
102	7-Sep-2021	GULBARGA	110	SINDHANOOR-THUVIHAL	THURVIHAL_110	19:25	19:40	0:15	LINE FAULT
103	7-Sep-2021	GULBARGA	110	SINDHANOOR-THUVIHAL	THURVIHAL_110	23:10	23:20	0:10	LINE FAULT
104	7-Sep-2021	GULBARGA	110	SINDHANOOR-THUVIHAL	THURVIHAL_110	23:40	23:50	0:10	LINE FAULT
105	7-Sep-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:40	17:30	2:50	LINE CLEAR AVAILED
106	7-Sep-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR220	VALKAMDINNI_110,MUDD APURA_110,KAVITHAL_110	23:30	23:40	0:10	MAIN SUPPLY FAILURE
107	7-Sep-2021	GULBARGA	110	YELBURGA-TALT_SLR	YELBURGA_110	19:10	21:23	2:13	LINE CLEAR AVAILED
108	7-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
109	7-Sep-2021	GULBARGA	220	MALLAT-RTPS	RTPS_220	21:07(06.09.2021)			LINE OPEN,LINE FAULT
110	7-Sep-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:24	9:30	0:06	LINE FAULT
111	7-Sep-2021	HASSAN	66	HV1	RAMPURA_66	8:03	8:20	0:17	LINE CLEAR AVAILED
112	7-Sep-2021	HASSAN	66	HV1	HOLALUR_66	10:08	17:45	7:37	LINE CLEAR AVAILED
113	7-Sep-2021	HASSAN	66	HV2	HOLALUR_66	10:08	17:45	7:37	LINE CLEAR AVAILED
114	7-Sep-2021	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	5:55	6:30	0:35	LINE FAULT
115	7-Sep-2021	HASSAN	110	HOSUR-BALIGAVI	HOSUR_110	10:00	17:45	7:45	LINE CLEAR AVAILED
116	7-Sep-2021	HASSAN	110	HV1	HOSUR_110	10:00	17:45	7:45	LINE CLEAR AVAILED
117	7-Sep-2021	HASSAN	110	HV2	NERALAKERE_110	8:30	8:50	0:20	TRANSFORMER FAULT
118	7-Sep-2021	HASSAN	110	HV4	PUTUR_110	8:01	9:38	1:37	LINE CLEAR AVAILED
119	7-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.8.2021)			LINE OPEN,LINE CLEAR AVAILED
120	7-Sep-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	8:48	8:52	0:04	HAND TRIPPED
121	7-Sep-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	9:55	12:55	3:00	LINE CLEAR AVAILED
122	7-Sep-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	17:15	17:18	0:03	HAND TRIPPED
123	7-Sep-2021	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	11:36	13:30	1:54	LINE CLEAR AVAILED
124	7-Sep-2021	HASSAN	220	KEMAR-UPCL	KEMAR_220	9:32	20:51	11:19	NFBC ISSUED
125	7-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
126	7-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:29	13:28	1:59	LINE CLEAR AVAILED
127	7-Sep-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	11:37	13:30	1:53	LINE CLEAR AVAILED
128	7-Sep-2021	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	11:29	13:28	1:59	LINE CLEAR AVAILED
129	7-Sep-2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	9:32	20:51	11:19	LINE CLEAR AVAILED
130	7-Sep-2021	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	23:56(6.9.2021)	7:47(07.09.2021)	7:52hrs	LINE CHARGED
131	7-Sep-2021	HASSAN	400	TALGU-NELAMANGALA#2	TALAGUPPA_400	14:48	15:38	0:50	LINE CLEAR AVAILED
132	7-Sep-2021	MYSURU	66	C RNAGAR-PANEDHUNDI	HEMARGALA_66 KARYA_66 PANNEDUNDI_66	13:07	13:14	0:06	LINE FAULT
133	7-Sep-2021	MYSURU	66	C RNAGAR-PANEDHUNDI	HEMARGALA_66 KARYA_66 PANNEDUNDI_66	16:39	16:58	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
134	7-Sep-2021	MYSURU	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20 (19/08/2021)			LINE OPEN,LINE CLEAR AVAILED
135	7-Sep-2021	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN,LINE CLEAR AVAILED
136	7-Sep-2021	MYSURU	66	HOOTGALLY-ELVALA	ELVALA_66 GAWADAGERE_66	0:13	0:32	0:19	LINE FAULT
137	7-Sep-2021	MYSURU	66	HOOTGALLY-HUNSUR	BANNIKUPPE & HOSUR GATE STATIONS INTERRUPTED.	0:13	0:32	0:19	LINE FAULT
138	7-Sep-2021	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
139	7-Sep-2021	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
140	7-Sep-2021	MYSURU	66	HV1	KADAKOLA_66	11:27	12:44	1:17	LINE CLEAR AVAILED
141	7-Sep-2021	MYSURU	66	HV2	HD KOTE_66	7:48	8:53	1:05	LINE CLEAR AVAILED
142	7-Sep-2021	MYSURU	66	HV2	KADAKOLA_66	21:52	22:00	0:08	TRANSFORMER FAULT
143	7-Sep-2021	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA	11:17	12:47	1:30	LINE FAULT
144	7-Sep-2021	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN,LINE CLEAR AVAILED
145	7-Sep-2021	MYSURU	220	KR PETE220-TUBINAKERE	NO STATIONS EFFECTED	10:46	16:36	5:49	LINE CLEAR AVAILED
146	7-Sep-2021	MYSURU	220	TUBINAKERE-KOTHIPURA2	NO STATIONS EFFECTED	10:46	14:50	4:03	LINE CLEAR AVAILED
147	7-Sep-2021	TUMKUR	66	BHARAMAGIRI-MATHOD	BHARAMAGIRI-MATHOD	10:06	17:05	6:58	LINE CLEAR AVAILED
148	7-Sep-2021	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA 1	CHITRADURGA_66	10:35	10:55	0:20	LINE FAULT
149	7-Sep-2021	TUMKUR	66	CHITRADURGA 66kV- DAVANAGERE2	CHITRADURGA_66	10:40	10:57	0:17	HAND TRIPPED
150	7-Sep-2021	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	10:40	11:06	0:26	LINE FAULT
151	7-Sep-2021	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	10:40	11:06	0:26	LINE FAULT
152	7-Sep-2021	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	10:10	10:17	0:06	LINE CLEAR AVAILED
153	7-Sep-2021	TUMKUR	66	GULIGENAHALLI- SIRA	SIRA_66	14:00	14:02	0:02	LINE CLEAR AVAILED
154	7-Sep-2021	TUMKUR	66	H D PURA- CHITRADURGA	HDPURA_66	11:00	11:18	0:18	MAIN SUPPLY FAILURE
155	7-Sep-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	11:25	11:45	0:20	LINE FAULT
156	7-Sep-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	4:51	5:11	0:20	LINE FAULT
157	7-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:00	10:10	0:10	HAND TRIPPED
158	7-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKO NDA_66,SASALUHALLA_66	10:10	10:20	0:10	HAND TRIPPED
159	7-Sep-2021	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	10:00	10:03	0:03	LINE FAULT
160	7-Sep-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	10:00	16:45	6:45	LINE CLEAR AVAILED
161	7-Sep-2021	TUMKUR	66	PATTNAYAKANAHALLI66-SIRA66	PATTNAYAKANAHALLI_66	10:10	10:40	0:30	MAIN SUPPLY FAILURE
162	7-Sep-2021	TUMKUR	66	TR1	HARIYABBE_66	15:54	15:59	0:05	TRANSFORMER FAULT
163	7-Sep-2021	TUMKUR	66	TR1	KANCHIPURA_66	10:00	17:30	7:30	LINE CLEAR AVAILED
164	7-Sep-2021	TUMKUR	66	TR1	MADADKERE_66	10:05	17:00	6:55	LINE CLEAR AVAILED
165	7-Sep-2021	TUMKUR	66	TR1	SOKKE_66	14:30	14:36	0:06	HAND TRIPPED
166	7-Sep-2021	TUMKUR	66	TR1	THOVINAKERE_66	15:58	17:10	1:12	LINE CLEAR AVAILED
167	7-Sep-2021	TUMKUR	66	TR-1	AMRUTHUR_66	14:25	14:48	0:23	LINE CLEAR AVAILED
168	7-Sep-2021	TUMKUR	66	TR-1	CHALLAKERE_66	16:55	17:44	0:49	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
169	7-Sep-2021	TUMKUR	66	TR-1	CHITRADURGA_66	10:40	10:57	0:17	MAIN SUPPLY FAILURE
170	7-Sep-2021	TUMKUR	66	TR-1	GOWRASAMUDRA_66	10:14	15:26	5:11	LINE CLEAR AVAILED
171	7-Sep-2021	TUMKUR	66	TR2	MADADKERE_66	10:05	17:00	6:55	LINE CLEAR AVAILED
172	7-Sep-2021	TUMKUR	66	TR2	THOVINAKERE_66	15:58	17:10	1:12	LINE CLEAR AVAILED
173	7-Sep-2021	TUMKUR	66	TR-2	AMRUTHUR_66	14:30	14:40	0:10	LINE CLEAR AVAILED
174	7-Sep-2021	TUMKUR	66	TR-2	CHALLAKERE_66	17:48	18:16	0:28	LINE CLEAR AVAILED
175	7-Sep-2021	TUMKUR	66	TR-2	CHITRADURGA_66	10:40	10:57	0:17	MAIN SUPPLY FAILURE
176	7-Sep-2021	TUMKUR	110	TR-1	KALLUR_110	12:20	13:57	1:37	LINE CLEAR AVAILED
177	7-Sep-2021	TUMKUR	110	TR-1	TURUVEKERE_110	15:59	17:16	1:16	LINE CLEAR AVAILED
178	7-Sep-2021	TUMKUR	110	TR-2	KADABA_110	15:11	15:22	0:11	TRANSFORMER FAULT
179	8-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
180	8-Sep-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
181	8-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
182	8-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
183	8-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
184	8-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
185	8-Sep-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
186	8-Sep-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVAILED
187	8-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
188	8-Sep-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN,LINE FAULT
189	8-Sep-2021	BAGALKOT	220	GADAG-HARTI1	STATION NOT AFFECTED GADAG_220	9:52 (24.08.2021)			LINE OPEN,LINE FAULT
190	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:12 (29.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
191	8-Sep-2021	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	17:59 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
192	8-Sep-2021	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	10:10	18:02	7:52	LINE CLEAR AVAILED
193	8-Sep-2021	BAGALKOT	110	GADAG-LAXMESHVAR	LAXMESHVAR_110	10:15	17:29	7:14	LINE CLEAR AVAILED
194	8-Sep-2021	BAGALKOT	110	GHATAPRABHA220-PG HUNSHYAL	PG HUNSHYAL_110	21:25	21:35	0:10	LINE FAULT
195	8-Sep-2021	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	4:45	6:02	1:17	LINE FAULT
196	8-Sep-2021	BAGALKOT	110	HAVER220-HAVERI	HAVERI_110	10:08	17:52	7:44	LINE CLEAR AVAILED
197	8-Sep-2021	BAGALKOT	220	HUBLI-SIRSI1&2	HUBLI_220	10:25	18:09	7:44	LINE CLEAR AVAILED
198	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	15:58	16:10	0:12	HAND TRIPPED
199	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	ANANDANAGAR_110	11:34	12:44	1:10	LINE CLEAR AVAILED
200	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	15:16	15:25	0:09	HAND TRIPPED
201	8-Sep-2021	BAGALKOT	110	BELGAUM220- VODAGOAN	VODAGOAN_110	4:15	4:26	0:11	LINE CLEAR AVAILED
202	8-Sep-2021	BAGALKOT	110	110/11KV, HV1	TUMMINKATTI_110	15:46	16:23	0:37	LINE CLEAR AVAILED
203	8-Sep-2021	BAGALKOT	110	110/33KV, HV1	TIKOTA_110, BIJJARAGI_33	16:01	16:05	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
204	8-Sep-2021	BAGALKOT	110	SIRSI110- KUMTA2	SIRSI_110	15:31	21:48	6:17	LINE CLEAR AVAILED
205	8-Sep-2021	BAGALKOT	110	SIRSI110- JOG	SIRSI_110	19:30	21:39	2:09	LINE CLEAR AVAILED
206	8-Sep-2021	BAGALKOT	110	SADALAGA- BORAGOAN	BORAGOAN_110	5:50	6:34	0:44	LINE FAULT
207	8-Sep-2021	BAGALKOT	110	110/11KV, HV1	SADALAGA_110	12:20	14:10	1:50	LINE CLEAR AVAILED
208	8-Sep-2021	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	15:41	16:01	0:20	TRANSFORMER FAULT
209	8-Sep-2021	BAGALKOT	110	110/33KV,HV3	LAXMESHWAR_110, MMCL_33,SSM_33	10:05	18:03	7:58	LINE CLEAR AVAILED
210	8-Sep-2021	BAGALKOT	110	KERUR- KONNUR (KULGERI CROSS)	KULGERI CROSS_110	15:35	16:35	1:00	LINE CLEAR AVAILED
211	8-Sep-2021	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	11:11	11:20	0:09	LINE CLEAR AVAILED
212	8-Sep-2021	BAGALKOT	110	110/11KV,HV4	HIDIKAL_110, ALAGWADI_33	11:51	13:09	1:18	LINE CLEAR AVAILED
213	8-Sep-2021	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	HIDIKAL_110	12:23	19:13	6:50	LINE CLEAR AVAILED
214	8-Sep-2021	BAGALKOT	110	ITANAL- HIDIKAL	HIDIKAL_110	13:04	13:09	0:05	HAND TRIPPED
215	8-Sep-2021	BAGALKOT	110	110/11KV, HV1	KULGERI CROSS_110	17:20	17:46	0:26	LINE CLEAR AVAILED
216	8-Sep-2021	BAGALKOT	110	110/11KV, HV2	KULGERI CROSS_110	17:20	17:46	0:26	LINE CLEAR AVAILED
217	8-Sep-2021	BAGALKOT	110	110/11KV,HV1	NAGANUR_110	21:30	21:40	0:10	TRANSFORMER FAULT
218	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	NAGANUR_110	21:30	21:40	0:10	TRANSFORMER FAULT
219	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	HALIYAL_110	12:16	12:23	0:07	TRANSFORMER FAULT
220	8-Sep-2021	BAGALKOT	110	LAXMESHWAR-SHIRAHATTI	LAXMESHWAR_110	10:30	17:45	7:15	LINE CLEAR AVAILED
221	8-Sep-2021	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	10:10	10:42	0:32	LINE CLEAR AVAILED
222	8-Sep-2021	BAGALKOT	110	110/11KV,HV1	LAXMESHWAR_110	10:05	17:42	7:37	LINE CLEAR AVAILED
223	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	LAXMESHWAR_110	10:05	17:42	7:37	LINE CLEAR AVAILED
224	8-Sep-2021	BAGALKOT	110	110/11KV,HV1	BELLATTI_110	10:10	17:43	7:33	LINE CLEAR AVAILED
225	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	BELLATTI_110	10:10	17:43	7:33	LINE CLEAR AVAILED
226	8-Sep-2021	BAGALKOT	110	110/33KV,HV3	BELLATTI_110	10:10	17:43	7:33	LINE CLEAR AVAILED
227	8-Sep-2021	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	12:16	19:10	6:54	LINE CLEAR AVAILED
228	8-Sep-2021	BAGALKOT	220	220/110KV,HV3&LV3	MAHALINGAPUR_220	12:19	17:55	5:36	LINE CLEAR AVAILED
229	8-Sep-2021	BAGALKOT	110	MAHALINGAPUR-ITNAL	MAHALINGAPUR_220	14:00	18:15	4:15	LINE CLEAR AVAILED
230	8-Sep-2021	BAGALKOT	220	RANEENNUR-GUTTUR	RANEENNUR_220	12:57	18:47	5:50	LINE CLEAR AVAILED
231	8-Sep-2021	BAGALKOT	110	SOUDATTI220-SOUDATTI	SOUDATTI_220	4:45	5:35	0:50	LINE FAULT
232	8-Sep-2021	BAGALKOT	110	MK HUBLI-KITTUR	KITTUR_110	10:30	17:30	7:00	NFBC ISSUED
233	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	KATARAKI_110	11:15	11:55	0:40	LINE CLEAR AVAILED
234	8-Sep-2021	BAGALKOT	110	110/11KV,HV1	KATARAKI_110	14:30	14:45	0:15	LINE CLEAR AVAILED
235	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	MAREGUDDI_110	14:00	14:15	0:15	HAND TRIPPED
236	8-Sep-2021	BAGALKOT	110	PG HUNSHYAL -NAGANUR	NAGANUR_110	21:30	21:40	0:10	MAIN SUPPLY FAILURE
237	8-Sep-2021	BAGALKOT	110	NAGANUR-MUDALAGI	MUDALAGI_110	21:30	21:40	0:10	MAIN SUPPLY FAILURE
238	8-Sep-2021	BAGALKOT	110	110/11KV,HV1&2	NAGANUR_110	21:30	21:40	0:10	MAIN SUPPLY FAILURE
239	8-Sep-2021	BAGALKOT	110	110/11KV,HV2	KHADAKLAT_110	12:15	12:55	0:40	LINE CLEAR AVAILED
240	8-Sep-2021	BAGALKOT	110	SIRSI110- SIDDAPUR	SIDDAPUR_110	16:10 (08.09.2021)			LINE OPEN,LINE FAULT
241	8-Sep-2021	BAGALKOT	110	SIRSI110- KUMATA1	SIRSI_110	15:31	21:48	6:17	LINE CLEAR AVAILED
242	8-Sep-2021	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	MANDIKALLU, D PALYA, GUDIBANDE	14:27	14:32	0:05	MAIN SUPPLY FAILURE
243	8-Sep-2021	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	14:27	14:32	0:05	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
244	8-Sep-2021	BENGALURU	66	GOWRIBIDANUR 220 - AFTL (EHT)	AFTL (EHT)	14:27	14:32	0:05	MAIN SUPPLY FAILURE
245	8-Sep-2021	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	MANDIKALLU, D PALYA, GUDIBANDE	17:15	18:12	0:57	MAIN SUPPLY FAILURE
246	8-Sep-2021	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	17:15	18:12	0:57	MAIN SUPPLY FAILURE
247	8-Sep-2021	BENGALURU	66	GOWRIBIDANUR 220 - AFTL (EHT)	AFTL (EHT)	17:15	18:12	0:57	MAIN SUPPLY FAILURE
248	8-Sep-2021	BENGALURU	66	CHIKKENAHALLI - ALLIMARADANAHALLI	CHIKKENAHALLI, VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	11:02	11:05	0:03	LINE FAULT
249	8-Sep-2021	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	8:36	8:40	0:04	LINE CLEAR AVAILED
250	8-Sep-2021	BENGALURU	220	ITI 20 - MANYATHA TECH PARK 220	NO STATION AFFECTED	11:21	13:23	2:01	LINE FAULT
251	8-Sep-2021	BENGALURU	66	SHOBHA FOREST VIEW - SUBRAMANYAPURA 220	SHOBHA FOREST VIEW	15:21	15:28	0:07	LOAD CHANGE OVER
252	8-Sep-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	14:41	15:04	0:23	LINE FAULT
253	8-Sep-2021	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	14:25	15:12	0:47	LINE CLEAR AVAILED
254	8-Sep-2021	BENGALURU	66	HV3	ADUGODI	5:45	5:55	0:09	TRANSFORMER FAULT
255	8-Sep-2021	BENGALURU	66	HV1	EDC 220	8:32	8:42	0:10	LINE CLEAR AVAILED
256	8-Sep-2021	BENGALURU	66	HV2	SRS PEENYA 220	11:17	12:26	1:09	TRANSFORMER FAULT
257	8-Sep-2021	BENGALURU	66	HV1	PATH PALYA	11:01	12:50	1:48	LINE CLEAR AVAILED
258	8-Sep-2021	BENGALURU	220	HV3	GOWRIBIDANUR 220	14:27	14:32	0:05	LINE CLEAR AVAILED
259	8-Sep-2021	BENGALURU	220	HV3	GOWRIBIDANUR 220	17:15	18:12	0:57	LINE CLEAR AVAILED
260	8-Sep-2021	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	11:00	11:10	0:10	LINE CLEAR AVAILED
261	8-Sep-2021	BENGALURU	66	AKKURMOLE - TK HALLI 220	AKKURMOLE	8:50	18:35	9:45	LINE CLEAR AVAILED
262	8-Sep-2021	BENGALURU	66	IGGALURU - TK HALLI 220	IGGALURU	8:48	9:05	0:17	LOAD CHANGE OVER
263	8-Sep-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	11:10	11:15	0:05	LOAD CHANGE OVER
264	8-Sep-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	11:40	11:45	0:05	LOAD CHANGE OVER
265	8-Sep-2021	BENGALURU	66	HV2	KACHMARANAHALLI	0:21	0:28	0:06	TRANSFORMER FAULT
266	8-Sep-2021	BENGALURU	66	KANAKAPURA 220 - CHANNAPATNA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	13:50	14:40	0:49	LINE CLEAR AVAILED
267	8-Sep-2021	BENGALURU	66	HV1	CHANDAPURA	11:19:24	11:30	0:49	LINE CLEAR AVAILED
268	8-Sep-2021	BENGALURU	66	HV2	DODDABELAVANGALA	0:07(3-9-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
269	8-Sep-2021	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 1	RAILWAY TRACTION (EHT)	20:12(7-9-2021)	1:36(8.9.21)	5:23hrs	LINE CHARGED
270	8-Sep-2021	BENGALURU	220	KOLAR 220 - RAILWAY TRACTION (EHT) 2	RAILWAY TRACTION (EHT)	23:34(7-9-2021)	1:36(8.9.21)	2:01hrs	LINE CHARGED
271	8-Sep-2021	GULBARGA	220	MALLAT-RTPS	RTPS _220	21:07(06.09.2021)			LINE OPEN,LINE FAULT
272	8-Sep-2021	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR _220	2:11	6:44	4:33	LINE CLEAR AVAILED
273	8-Sep-2021	GULBARGA	220	KUSHTAGI-SUZLON1_IPP	KUSHTAGI _220	19:22	20:02	0:40	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
274	8-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
275	8-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
276	8-Sep-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	18:50(07.09.2021)			LINE OPEN,LINE FAULT
277	8-Sep-2021	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
278	8-Sep-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR2(IDLE LINE)	SINDHANOOR_110	10:20	13:45	3:25	LINE CLEAR AVAILED
279	8-Sep-2021	GULBARGA	110	SINDHANOOR-ADVIAMARESHWAR	ADAVI AMARESHWAR_110	10:20	13:40	3:20	LINE CLEAR AVAILED
280	8-Sep-2021	GULBARGA	110	MASKI-SINDHANOOR	HATTI_110,MASKI_110	1:39	1:46	0:07	LINE FAULT
281	8-Sep-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR220	VALKAMDINNI_110,MUDD APURA_110,KAVITHAL_110	5:20	5:30	0:10	MAIN SUPPLY FAILURE
282	8-Sep-2021	GULBARGA	110	MASKI-RENEWSLR	MASKI_110	9:03	9:20	0:17	LINE FAULT
283	8-Sep-2021	GULBARGA	110	HV1	BISIHALLI_110	9:30	9:38	0:08	TRANSFORMER FAULT
284	8-Sep-2021	GULBARGA	110	HV2	KAVITHAL_110	15:45	15:55	0:10	TRANSFORMER FAULT
285	8-Sep-2021	GULBARGA	110	HV2	HJATTI_110	11:34	11:40	0:06	TRANSFORMER FAULT
286	8-Sep-2021	GULBARGA	110	HV1	MANVI_110	6:39	6:49	0:10	TRANSFORMER FAULT
287	8-Sep-2021	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110	5:03	5:07	0:04	LINE FAULT
288	8-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:25	5:32	0:07	LINE FAULT
289	8-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	5:25	5:35	0:10	LINE FAULT
290	8-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	5:40	6:03	0:23	LINE FAULT
291	8-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	5:40	6:00	0:20	LINE FAULT
292	8-Sep-2021	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	9:35	10:15	0:40	LINE CLEAR AVAILED
293	8-Sep-2021	GULBARGA	66	MUNIRABAD-VYSANAKERE1	DONIMALAI_110	9:05	15:35	6:30	LINE CLEAR AVAILED
294	8-Sep-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	14:40	15:00	0:20	TRANSFORMER FAULT
295	8-Sep-2021	GULBARGA	66	HV1	TAMBRAHALLI_66	12:20	13:05	0:45	LINE CLEAR AVAILED
296	8-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.8.2021)			LINE OPEN,LINE CLEAR AVAILED
297	8-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
298	8-Sep-2021	HASSAN	110	HV2	ANAVATTI_110	12:50	13:18	0:28	TRANSFORMER FAULT
299	8-Sep-2021	HASSAN	110	HV1	DMKURKe_110	11:25	12:25	1:00	LINE CLEAR AVAILED
300	8-Sep-2021	HASSAN	110	JOG-NK1	mghe_gen	16:10	16:30	0:20	LINE FAULT
301	8-Sep-2021	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	12:30	13:29	0:59	LINE CLEAR AVAILED
302	8-Sep-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:26	13:02	0:36	LINE FAULT
303	8-Sep-2021	HASSAN	66	CHANNARA-CRPATNA1	CHANNARAYAPATNA_66	15:49	16:04	0:15	LINE CLEAR AVAILED
304	8-Sep-2021	HASSAN	66	HV2	HOLALUR_66	11:20	13:52	2:32	LINE CLEAR AVAILED
305	8-Sep-2021	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	9:47	10:34	0:47	LINE FAULT
306	8-Sep-2021	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:44	13:54	3:10	LINE CLEAR AVAILED
307	8-Sep-2021	HASSAN	66	SAKALE-HANBAL	SAKALESHUPURA_66	12:19	12:31	0:12	HAND TRIPPED
308	8-Sep-2021	HASSAN	66	TAVAREC-HONALLI	TAVARECHATNAHALLY_66	9:50	10:35	0:45	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
309	8-Sep-2021	HASSAN	66	TAVAREC-HONALLI	TAVARECHATNAHALLY_66	10:40	14:00	3:20	MAIN SUPPLY FAILURE
310	8-Sep-2021	MYSURU	66	HV1	AKKIHEBBAL_66	10:30	12:03	1:33	LINE CLEAR AVAILED
311	8-Sep-2021	MYSURU	66	HV2	AKKIHEBBAL_66	12:00	13:59	1:59	LINE CLEAR AVAILED
312	8-Sep-2021	MYSURU	66	HV2	BASARALU_66	14:11	14:45	0:33	LINE CLEAR AVAILED
313	8-Sep-2021	MYSURU	66	HV2	BETTADHAPURA_66	10:29	10:47	0:17	LINE CLEAR AVAILED
314	8-Sep-2021	MYSURU	66	HV1	BYLUKUPPE_66	12:35	15:00	2:24	LINE CLEAR AVAILED
315	8-Sep-2021	MYSURU	66	DR PETE-CR NAGARA 1	NO STATIONS EFFECTED	13:42	13:47	0:04	LINE FAULT
316	8-Sep-2021	MYSURU	66	DR PETE-KUNTHUR	NO STATIONS EFFECTED	9:43	9:54	0:11	LINE FAULT
317	8-Sep-2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	11:27	12:50	1:22	LINE CLEAR AVAILED
318	8-Sep-2021	MYSURU	66	HV2	HOOTAGALLY_220	15:59	12:46	20:47	TRANSFORMER FAULT
319	8-Sep-2021	MYSURU	66	HADLI-HEBBANI	HADLI_66	9:30	14:30	4:59	LINE CLEAR AVAILED
320	8-Sep-2021	MYSURU	66	MALLAVALLI-TKHALLI	MALAVALLI_66	11:06	18:24	7:17	LINE CLEAR AVAILED
321	8-Sep-2021	MYSURU	66	HV2	PANDAVAPURA_66	17:44	18:25	0:40	TRANSFORMER FAULT
322	8-Sep-2021	MYSURU	66	TUBINKERE-M-2	NO STATIONS EFFECTED	11:01	11:50	0:49	LINE CLEAR AVAILED
323	8-Sep-2021	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN,LINE CLEAR AVAILED
324	8-Sep-2021	MYSURU	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20 (19/08/2021)			LINE OPEN,LINE CLEAR AVAILED
325	8-Sep-2021	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
326	8-Sep-2021	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
327	8-Sep-2021	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN,LINE CLEAR AVAILED
328	8-Sep-2021	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	11:29	11:43	0:14	HAND TRIPPED
329	8-Sep-2021	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	11:04	11:08	0:04	HAND TRIPPED
330	8-Sep-2021	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	11:11	13:23	2:11	MAIN SUPPLY FAILURE
331	8-Sep-2021	TUMKUR	66	TR-1	CHALLAKERE_66	12:21	12:58	0:36	LINE CLEAR AVAILED
332	8-Sep-2021	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	5:49	6:40	0:50	LINE FAULT
333	8-Sep-2021	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:57	15:01	4:03	LINE CLEAR AVAILED
334	8-Sep-2021	TUMKUR	66	TR-2	GULIGENAHALLI_66	12:03	12:20	0:17	HAND TRIPPED
335	8-Sep-2021	TUMKUR	66	TR-1	HANAGAL_66	13:40	13:47	0:06	HAND TRIPPED
336	8-Sep-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	11:52	12:08	0:15	HAND TRIPPED
337	8-Sep-2021	TUMKUR	66	TR-1	HONNALLI_220	12:21	13:05	0:43	HAND TRIPPED
338	8-Sep-2021	TUMKUR	66	TR-2	HONNALLI_220	12:21	13:05	0:44	HAND TRIPPED
339	8-Sep-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	6:31	6:51	0:20	LINE FAULT
340	8-Sep-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:51	19:07	0:15	LINE FAULT
341	8-Sep-2021	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR IPP_66	BPCLSOLAR_IPP_66	13:25	13:47	0:21	HAND TRIPPED
342	8-Sep-2021	TUMKUR	66	TR-2	MATHOD_66	15:11	15:23	0:11	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
343	8-Sep-2021	TUMKUR	66	TR-2	MATHOD_66	15:58	16:11	0:13	TRANSFORMER FAULT
344	8-Sep-2021	TUMKUR	66	TR-1	MYLONAHALLI_66	8:34	8:44	0:09	TRANSFORMER FAULT
345	8-Sep-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	13:13	13:31	0:18	HAND TRIPPED
346	8-Sep-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	13:13	13:31	0:18	HAND TRIPPED
347	8-Sep-2021	TUMKUR	66	THALLAK 220KV- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	11:41	12:17	0:36	LINE CLEAR AVOIDED
348	9-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVOIDED
349	9-Sep-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
350	9-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
351	9-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
352	9-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
353	9-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
354	9-Sep-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
355	9-Sep-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
356	9-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
357	9-Sep-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN,LINE FAULT
358	9-Sep-2021	BAGALKOT	220	GADAG-HARTI1	STATION NOT AFFECTED GADAG_220	9:52 (24.08.2021)			LINE OPEN,LINE FAULT
359	9-Sep-2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:12 (29.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
360	9-Sep-2021	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	17:59 (30.08.2021)			LINE OPEN,LINE CLEAR AVOIDED
361	9-Sep-2021	BAGALKOT	110	110/11KV,HV1	ALBAL_110	15:50	16:08	0:18	HAND TRIPPED
362	9-Sep-2021	BAGALKOT	110	110/33KV,HV3	SURUNAGI_33 , HOTE ITAGI_33 ,RWSSJALAWADAGI_33, STATION NOT AFFECTED BELLATTI_110	1:59	14:38	12:39	TRANSFORMER FAULT
363	9-Sep-2021	BAGALKOT	110	ITANAL-SULTANPUR(HIDIKAL)	SULTANPUR_110	11:41	12:45	1:04	LINE CLEAR AVOIDED
364	9-Sep-2021	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KAVALWADA_110	12:20	12:32	0:12	LINE FAULT
365	9-Sep-2021	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KAVALWADA_110	12:32	12:41	0:09	LINE FAULT
366	9-Sep-2021	BAGALKOT	110	LAXMESHVAR-BELLATTI	BELLATTI_110	1:59	2:40	0:41	LINE FAULT
367	9-Sep-2021	BAGALKOT	110	NARENDRA-KUD DHARWAD1	STATION NOT AFFECTED NARENDRA_220	11:57	15:03	3:06	LINE CLEAR AVOIDED
368	9-Sep-2021	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	13:05	13:11	0:06	HAND TRIPPED
369	9-Sep-2021	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	STATION NOT AFFECTED AMBEWADI_220	12:01	13:05	1:04	LINE FAULT
370	9-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI1&2	STATION NOT AFFECTED SIRSI_110	18:50	19:38	0:48	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
371	9-Sep-2021	BAGALKOT	220	400/220KV, ICT1	STATION NOT AFFECTED DHONI_400	10:49	16:42	5:53	LINE CLEAR AVAILED
372	9-Sep-2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	10:36	15:43	5:07	LINE CLEAR AVAILED
373	9-Sep-2021	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	10:36	15:44	5:08	LINE CLEAR AVAILED
374	9-Sep-2021	BAGALKOT	220	GHATAPRABHA-NARENDRA1	STATION NOT AFFECTED GHATAPRABHA_220	11:24	12:59	1:35	NFBC ISSUED
375	9-Sep-2021	BAGALKOT	400	400/220KV, ICT1	STATION NOT AFFECTED DHONI_400	10:50	16:38	5:48	LINE CLEAR AVAILED
376	9-Sep-2021	BAGALKOT	110	SIRSI110- SIDDAPUR	SIDDAPUR_110	16:10 (08.09.2021)	14:45 (09.09.2021)	22:35hrs	LINE CHARGED
377	9-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	15:20	20:05	4:45	NFBC ISSUED
378	9-Sep-2021	BAGALKOT	110	110/11KV,HV1	MALLIGERI_110	12:20	13:20	1:00	LINE CLEAR AVAILED
379	9-Sep-2021	BAGALKOT	220	GHATAPRABHA-NARENDRA1	STATION NOT AFFECTED GHATAPRABHA_220	11:24	12:59	1:35	NFBC ISSUED
380	9-Sep-2021	BAGALKOT	220	220/110KV,HV1	SIRSI_220	18:50	19:10	0:20	TRANSFORMER FAULT
381	9-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
382	9-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	18:50	19:39	0:49	LINE FAULT
383	9-Sep-2021	BENGALURU	66	HANUMATHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	2:20	3:10	0:50	MAIN SUPPLY FAILURE
384	9-Sep-2021	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	6:53	7:11	0:18	LINE FAULT
385	9-Sep-2021	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	8:54	8:56	0:02	LOAD CHANGE OVER
386	9-Sep-2021	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	13:19	13:23	0:04	LINE CLEAR AVAILED
387	9-Sep-2021	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI BWSSB (EHT)	HAROHALLI BWSSB (EHT), KANAKAPURA 220	2:17	2:53	0:36	LINE FAULT
388	9-Sep-2021	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	2:17	2:53	0:36	MAIN SUPPLY FAILURE
389	9-Sep-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELI, BIJJALALLI	2:17	2:53	0:36	MAIN SUPPLY FAILURE
390	9-Sep-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	2:17	2:53	0:36	MAIN SUPPLY FAILURE
391	9-Sep-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	2:17	2:53	0:36	MAIN SUPPLY FAILURE
392	9-Sep-2021	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	2:17	2:53	0:36	MAIN SUPPLY FAILURE
393	9-Sep-2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HONNIGANAHALLI, ACHALU, HALAGURU,DODDALAHALLI	2:20	3:10	0:50	MAIN SUPPLY FAILURE
394	9-Sep-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	15:26	15:58	0:32	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
395	9-Sep-2021	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	15:58	16:14	0:16	LINE FAULT
396	9-Sep-2021	BENGALURU	66	ELECTRONIC CITY P2 S2 - ELECTRONIC CITY	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	20:07	20:17	0:10	LOAD CHANGE OVER
397	9-Sep-2021	BENGALURU	66	HV1	NAGNATHPURA 220	15:26	15:34	0:08	TRANSFORMER FAULT
398	9-Sep-2021	BENGALURU	66	HV1	ATTIBELE	19:42	19:45	0:03	LOAD CHANGE OVER
399	9-Sep-2021	BENGALURU	66	HV2	CB PURA URBAN	1:48	3:30	1:42	TRANSFORMER FAULT
400	9-Sep-2021	BENGALURU	66	HV1	DODDABELAVANGALA	9:31	9:42	0:11	TRANSFORMER FAULT
401	9-Sep-2021	BENGALURU	66	AKKURMOLE - TK HALLI 220	AKKURMOLE	8:50	18:35	9:45	LINE CLEAR AVAILED
402	9-Sep-2021	BENGALURU	66	IGGALURU - TK HALLI 220	IGGALURU	8:48	9:05	0:17	LOAD CHANGE OVER
403	9-Sep-2021	BENGALURU	66	HV1	TADIGOLU	17:17	17:34	0:17	LINE CLEAR AVAILED
404	9-Sep-2021	BENGALURU	66	HV2	TADIGOLU	17:17	17:34	0:16	LINE CLEAR AVAILED
405	9-Sep-2021	BENGALURU	66	HV2	SIDDALAGATTA	20:05	20:10	0:05	LINE CLEAR AVAILED
406	9-Sep-2021	BENGALURU	66	HV2	MANCHENAHALLI	17:23	17:40	0:16	LINE CLEAR AVAILED
407	9-Sep-2021	BENGALURU	66	HV3	KGF	17:23	17:30	0:07	TRANSFORMER FAULT
408	9-Sep-2021	BENGALURU	66	HV2	DODDABELAVANGALA	0:07(3-9-2021)	18:06(9-9-2021)	161:58hrs	TRANSFORMER CHARGED
409	9-Sep-2021	GULBARGA	220	MALLAT-RTPS	RTPS_220	21:07(06.09.2021)	11:37(09.09.2021)	62:30HRS	LINE CHARGED
410	9-Sep-2021	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	11:37	16:24	4:47	NFBC ISSUED
411	9-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
412	9-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
413	9-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
414	9-Sep-2021	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
415	9-Sep-2021	GULBARGA	110	MARGUTTI-CLEAN SOLAR_IPP	MARGUTTI_110	20:15 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
416	9-Sep-2021	GULBARGA	110	NALWAR-CLEAN SOLAR	NALWAR_110	2:48	3:07	0:19	LINE FAULT
417	9-Sep-2021	GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	4:39	4:47	0:08	LINE FAULT
418	9-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:16	20:29	0:13	LINE FAULT
419	9-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	20:16	20:28	0:12	LINE FAULT
420	9-Sep-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	3:24	3:32	0:08	LINE FAULT
421	9-Sep-2021	GULBARGA	110	MALLAT-BYGWAT2(IDLE LINE)	ADAVI AMARESHWAR_110	2:10	4:10	2:00	LINE FAULT
422	9-Sep-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	1:03	1:18	0:15	LINE FAULT
423	9-Sep-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	4:30	4:40	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
424	9-Sep-2021	GULBARGA	110	BEVOOR-KUSTAGI	BEVOOR_110	10:10	12:00	1:50	LINE CLEAR AVAILED
425	9-Sep-2021	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	18:35	18:43	0:08	LINE FAULT
426	9-Sep-2021	GULBARGA	110	HV1	KAMALANAGAR_110	18:23	18:31	0:08	TRANSFORMER FAULT
427	9-Sep-2021	GULBARGA	110	HV1	MUDDAPUR_110	14:54	15:02	0:08	TRANSFORMER FAULT
428	9-Sep-2021	GULBARGA	110	HV3	CHICKSUGUR_110	8:06	8:24	0:18	TRANSFORMER FAULT
429	9-Sep-2021	GULBARGA	110	HV1	CHICKSUGUR_110	13:50	16:14	2:24	LINE CLEAR AVAILED
430	9-Sep-2021	GULBARGA	110	KAPNOOR-GULBARGA NORTH1	GULBARGA UNIVERSITY_110,GULBARG A NORTH_110,GULBARGA SOUTH_110	14:27	14:45	0:18	LINE FAULT
431	9-Sep-2021	GULBARGA	110	KAPNOOR-GULBARGA NORTH1	GULBARGA UNIVERSITY_110,GULBARG A NORTH_110,GULBARGA SOUTH_110	14:27	14:45	0:18	LINE FAULT
432	9-Sep-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	1:42	1:50	0:08	LINE FAULT
433	9-Sep-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	2:32	2:40	0:08	LINE FAULT
434	9-Sep-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	12:22	15:34	3:12	LINE CLEAR AVAILED
435	9-Sep-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	3:58	4:17	0:19	LINE FAULT
436	9-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.8.2021)			LINE OPEN,LINE CLEAR AVAILED
437	9-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
438	9-Sep-2021	HASSAN	220	UPCL-KEMAR2	upcl_gen	9:15	16:59	7:44	LINE CLEAR AVAILED
439	9-Sep-2021	HASSAN	220	KEMAR-UPCL2	KEMAR_220	9:15	16:59	7:44	NFBC ISSUED
440	9-Sep-2021	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	12:14	14:10	1:56	LINE FAULT
441	9-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	12:53	18:45	5:52	LINE CLEAR AVAILED
442	9-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:53	18:46	5:53	LINE CLEAR AVAILED
443	9-Sep-2021	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	12:53	18:45	5:52	LINE CLEAR AVAILED
444	9-Sep-2021	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:53	18:46	5:53	LINE CLEAR AVAILED
445	9-Sep-2021	HASSAN	110	HV1	ALKOLA_110	9:36	10:13	0:37	LINE CLEAR AVAILED
446	9-Sep-2021	HASSAN	110	HV2	ANAVATTI_110	14:00	15:10	1:10	TRANSFORMER FAULT
447	9-Sep-2021	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:59	12:21	1:22	LINE CLEAR AVAILED
448	9-Sep-2021	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	12:19	13:48	1:29	LINE CLEAR AVAILED
449	9-Sep-2021	HASSAN	110	HV1	JAVAGAL_110	10:48	13:20	2:32	LINE CLEAR AVAILED
450	9-Sep-2021	HASSAN	110	JOG-NK2	mghejog_gen	8:45	12:30	3:45	LINE CLEAR AVAILED
451	9-Sep-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:20	14:24	4:04	LINE FAULT
452	9-Sep-2021	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	18:55	19:10	0:15	MAIN SUPPLY FAILURE
453	9-Sep-2021	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	18:40	19:02	0:22	MAIN SUPPLY FAILURE
454	9-Sep-2021	HASSAN	66	HV2	HALEBEEDU_66	13:13	13:20	0:07	HAND TRIPPED
455	9-Sep-2021	HASSAN	66	HV1 CB	NAGARTHI_66	13:50	14:10	0:20	TRANSFORMER FAULT
456	9-Sep-2021	HASSAN	66	HV1 CB	NAGARTHI_66	17:05	18:45	1:40	TRANSFORMER FAULT
457	9-Sep-2021	MYSURU	66	HV1	BOOKANAKERE_66	9:46	18:51	9:05	LINE CLEAR AVAILED
458	9-Sep-2021	MYSURU	66	HV2	BOOKANAKERE_66	9:46	18:51	9:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
459	9-Sep-2021	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	17:04	17:13	0:09	HAND TRIPPED
460	9-Sep-2021	MYSURU	66	HV1	DEVANOORMYS_66	12:11	13:02	0:51	LINE CLEAR AVAILED
461	9-Sep-2021	MYSURU	66	HV2	DEVANOORMYS_66	10:48	12:14	1:26	LINE CLEAR AVAILED
462	9-Sep-2021	MYSURU	66	HV2	HAMPAPURA_66	14:06	14:47	0:40	LINE CLEAR AVAILED
463	9-Sep-2021	MYSURU	66	HV2	KADAKOLA_220	13:37	15:07	1:30	LINE CLEAR AVAILED
464	9-Sep-2021	MYSURU	66	TUBINKERE-NAGAMGALA1	ADDIHALLI_66 HARADANAHALLI_66 BG NAGARA_66 AC GIRI_66 VADERALLI_66 BASARALU_66 KESALGERE_66	11:50	11:53	0:03	LINE FAULT
465	9-Sep-2021	MYSURU	66	TUBINKERE-ARKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	15:19	15:29	0:10	HAND TRIPPED
466	9-Sep-2021	MYSURU	220	VAJMANGLA-TK HALLI	NO STATIONS EFFECTED	6:52	18:13	11:20	NFBC ISSUED
467	9-Sep-2021	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN,LINE CLEAR AVAILED
468	9-Sep-2021	MYSURU	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20 (19/08/2021)			LINE OPEN,LINE CLEAR AVAILED
469	9-Sep-2021	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
470	9-Sep-2021	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
471	9-Sep-2021	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN,LINE CLEAR AVAILED
472	9-Sep-2021	TUMKUR	220	TR2	KIADBNP_220	11:04	12:22	1:18	LINE CLEAR AVAILED
473	9-Sep-2021	TUMKUR	220	TR2	KIADBNP_220	14:21	14:26	0:05	LINE CLEAR AVAILED
474	9-Sep-2021	TUMKUR	220	TR2	KIADBNP_220	15:52	16:01	0:08	LINE CLEAR AVAILED
475	9-Sep-2021	TUMKUR	220	TR2	KIADBNP_220	14:58	15:20	0:21	LINE CLEAR AVAILED
476	9-Sep-2021	TUMKUR	220	TR1	KIADBNP_220	14:32	14:38	0:05	LINE CLEAR AVAILED
477	9-Sep-2021	TUMKUR	110	TR-1	MAYASANDRA_110	10:32	11:11	0:38	TRANSFORMER FAULT
478	9-Sep-2021	TUMKUR	110	TR-1	HALKURKI_110	15:29	16:02	0:32	TRANSFORMER FAULT
479	9-Sep-2021	TUMKUR	66	TR-1	AMRUTHUR_66	13:00	13:28	0:27	LINE CLEAR AVAILED
480	9-Sep-2021	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	13:10	13:16	0:06	LINE FAULT
481	9-Sep-2021	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	13:33	13:37	0:03	LINE FAULT
482	9-Sep-2021	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	18:22	18:31	0:09	LINE FAULT
483	9-Sep-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	9:01	9:05	0:04	MAIN SUPPLY FAILURE
484	9-Sep-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	5:50	5:58	0:08	MAIN SUPPLY FAILURE
485	9-Sep-2021	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	17:22	17:59	0:37	LINE FAULT
486	9-Sep-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	14:08	14:17	0:08	HAND TRIPPED
487	9-Sep-2021	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	5:42	6:03	0:21	LINE FAULT
488	9-Sep-2021	TUMKUR	66	TR2	KIADBNP_220	11:04	12:22	1:18	LINE CLEAR AVAILED
489	9-Sep-2021	TUMKUR	66	TR2	KORA_66	15:53	16:09	0:16	TRANSFORMER FAULT
490	9-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:52	13:55	0:02	LINE FAULT
491	10-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
492	10-Sep-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
493	10-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
494	10-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
495	10-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
496	10-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
497	10-Sep-2021	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	9:52 (22.06.2021)	18:34 (10.09.2021)	1208:42hrs	LINE CHARGED
498	10-Sep-2021	BAGALKOT	110	AMBEWADI-HALIYAL(NK1)	STATION NOT AFFECTED AMBEWADI_220	9:54 (22.06.2021)	18:34 (10.09.2021)	1208:40hrs	LINE CHARGED
499	10-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
500	10-Sep-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN,LINE FAULT
501	10-Sep-2021	BAGALKOT	220	GADAG-HARTI1	STATION NOT AFFECTED GADAG_220	9:52 (24.08.2021)			LINE OPEN,LINE FAULT
502	10-Sep-2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:12 (29.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
503	10-Sep-2021	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	17:59 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
504	10-Sep-2021	BAGALKOT	110	66/33KV,HV4	STATION NOT AFFECTED HARIHAR HOSPET_66KV	12:10	12:12	0:02	LINE CLEAR AVAILED
505	10-Sep-2021	BAGALKOT	110	CHIKKODI 220 -SANKESHWAR	SANKESHWAR_110	20:50	21:01	0:11	LINE FAULT
506	10-Sep-2021	BAGALKOT	110	CHIKKODI 220 -SANKESHWAR	SANKESHWAR_110	21:52	22:10	0:18	LINE FAULT
507	10-Sep-2021	BAGALKOT	110	CHIKKODI 220 -SANKESHWAR	SANKESHWAR_110	22:24	22:37	0:13	LINE FAULT
508	10-Sep-2021	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110, IPP_110	21:09	21:12	0:03	MAIN SUPPLY FAILURE
509	10-Sep-2021	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110, IPP_110	22:19	22:24	0:05	MAIN SUPPLY FAILURE
510	10-Sep-2021	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110, IPP_110	22:44 (10.09.2021)			LINE OPEN,LINE FAULT
511	10-Sep-2021	BAGALKOT	110	HUKKERI-HATARGI	HATTARAGI_110	22:44	23:06	0:22	HAND TRIPPED
512	10-Sep-2021	BAGALKOT	110	110/11KV,HV1	KAGAWAD_110	12:24	12:50	0:26	LINE CLEAR AVAILED
513	10-Sep-2021	BAGALKOT	110	KUMTA-RAILWAY(KRCL)	STATION NOT AFFECTED KUMTA_110	13:06	13:54	0:48	LINE CLEAR AVAILED
514	10-Sep-2021	BAGALKOT	110	110/11KV,HV2	MUDDEBIHAL_110	23:39	23:48	0:09	HAND TRIPPED
515	10-Sep-2021	BAGALKOT	110	220/110KV,LV1&LV2	MK HUBLI_220	23:04 (10.09.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
516	10-Sep-2021	BAGALKOT	110	110/11KV,HV1	MUNDUGANUR_110	9:04	9:33	0:29	HAND TRIPPED
517	10-Sep-2021	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED SAVANUR_110	6:08	11:08	5:00	LINE FAULT
518	10-Sep-2021	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	5:35	5:55	0:20	LINE FAULT
519	10-Sep-2021	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	10:44	11:13	0:29	HAND TRIPPED
520	10-Sep-2021	BAGALKOT	220	AMBEWADI-PONDA1(XELDOM)	STATION NOT AFFECTED AMBEWADI_220	13:17	18:32	5:15	LINE FAULT
521	10-Sep-2021	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	12:06	13:43	1:37	LINE FAULT
522	10-Sep-2021	BAGALKOT	110	110/11KV,HV1	KUDUCHI_220	3:35	19:15	15:40	TRANSFORMER FAULT
523	10-Sep-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TADASINAKOPPA_110	3:02	7:43	4:41	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
524	10-Sep-2021	BAGALKOT	110	BAGEWADI220-MAMDAPUR1	MAMDAPUR_110	3:47	4:07	0:20	LINE FAULT
525	10-Sep-2021	BAGALKOT	110	BAGEWADI220-MAMDAPUR2	MAMDAPUR_110	3:47	4:10	0:23	LINE FAULT
526	10-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED SIRSI_220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
527	10-Sep-2021	BAGALKOT	220	220/110KV,HV1	STATION NOT AFFECTED SIRSI_220	8:54	9:25	0:31	TRANSFORMER FAULT
528	10-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	STATION NOT AFFECTED SIRSI_220	8:54 (10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
529	10-Sep-2021	BAGALKOT	110	HAVERI220-BYADAGI	HAVERI_220	10:26	12:45	2:19	LINE CLEAR AVAILED
530	10-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	8:54	14:15	5:21	LINE FAULT
531	10-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	8:54	14:15	5:21	LINE CLEAR AVAILED
532	10-Sep-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110,HUKKER I_110,HATTARAGI_110,DAD DI_110	20:50	21:00	0:10	LINE FAULT
533	10-Sep-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110,HUKKER I_110,HATTARAGI_110,DAD DI_110	21:55	22:10	0:15	LINE FAULT
534	10-Sep-2021	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110,HUKKER I_110,HATTARAGI_110,DAD DI_110	22:25	22:40	0:15	LINE FAULT
535	10-Sep-2021	BAGALKOT	110	HUKKERI-VSL COGEN	HUKKERI_110	20:50	21:15	0:25	LINE FAULT
536	10-Sep-2021	BAGALKOT	110	HUKKERI-VSL COGEN	HUKKERI_110	21:55	22:25	0:30	LINE FAULT
537	10-Sep-2021	BAGALKOT	110	110/11KV,HV2	MUNDUGANUR_110	8:45	9:45	1:00	LINE CLEAR AVAILED
538	10-Sep-2021	BENGALURU	66	HV1	DODDABELAVANGALA	10:06	10:18	0:12	TRANSFORMER FAULT
539	10-Sep-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	0:56	1:04	0:08	LINE FAULT
540	10-Sep-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	8:24	8:33	0:09	LINE FAULT
541	10-Sep-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	5:49	6:01	0:12	LINE FAULT
542	10-Sep-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	11:05	11:08	0:02	LINE CLEAR AVAILED
543	10-Sep-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), BANGARPETE	11:05	11:08	0:02	LINE CLEAR AVAILED
544	10-Sep-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	17:34(10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
545	10-Sep-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	21:52(09.09.2021)	8:16(10.09.2021)	10:24hrs	LINE CHARGED
546	10-Sep-2021	GULBARGA	220	MALLAT-RTPS	RTPS_220	10:09	18:05	7:56	LINE CLEAR AVAILED
547	10-Sep-2021	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	21:40(10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
548	10-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
549	10-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	3:48	4:00	0:12	LINE FAULT
550	10-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	3:48	3:58	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
551	10-Sep-2021	GULBARGA	110	RAICHUR-APMC1,2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	4:55	5:05	0:10	LINE FAULT
552	10-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
553	10-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
554	10-Sep-2021	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
555	10-Sep-2021	GULBARGA	110	SINDHANOOR-ADVIAAMARESHWAR	ADAVI AMARESHWAR_110	17:05	17:15	0:10	LINE FAULT
556	10-Sep-2021	GULBARGA	110	MARGUTTI-CLEAN SOLAR_IPP	MARGUTTI_110	20:15 (09.09.2021)	4:05 (10.09.2021)	7:50HRS	LINE CHARGED
557	10-Sep-2021	GULBARGA	110	HV2	YEDRAMI_110	21:40	21:50	0:10	TRANSFORMER FAULT
558	10-Sep-2021	GULBARGA	110	HV2	TEKKALKOTE_110	16:40	16:50	0:10	TRANSFORMER FAULT
559	10-Sep-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	21:49	22:27	0:38	MAIN SUPPLY FAILURE
560	10-Sep-2021	GULBARGA	110	HV1	MUDDAPUR_110	13:09	13:18	0:09	TRANSFORMER FAULT
561	10-Sep-2021	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	1:34	1:38	0:04	LINE FAULT
562	10-Sep-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	18:50(07.09.2021)	17:45(10.09.2021)	70:55HRS	LINE CHARGED
563	10-Sep-2021	GULBARGA	110	HV4	DEODURGA_110	10:55	11:30	0:35	LINE CLEAR AVAILED
564	10-Sep-2021	GULBARGA	110	HV2	DEODURGA_110	12:00	12:55	0:55	LINE CLEAR AVAILED
565	10-Sep-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	5:26	5:33	0:07	LINE FAULT
566	10-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.8.2021)			LINE OPEN,LINE CLEAR AVAILED
567	10-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
568	10-Sep-2021	HASSAN	220	GER SOPA-TALGUPA1	gerusoppa_gen	17:26(10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
569	10-Sep-2021	HASSAN	110	HV2	MRSMSG_220	8:52	13:11	4:19	LINE CLEAR AVAILED
570	10-Sep-2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	9:56	10:54	0:58	LINE FAULT
571	10-Sep-2021	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	6:07	6:54	0:47	MAIN SUPPLY FAILURE
572	10-Sep-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	6:38	6:52	0:14	LINE FAULT
573	10-Sep-2021	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	6:10	6:50	0:40	LINE FAULT
574	10-Sep-2021	MYSURU	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	18:33	18:40	0:06	LINE FAULT
575	10-Sep-2021	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	8:22	8:30	0:07	LINE FAULT
576	10-Sep-2021	MYSURU	66	PERIAPTNA-HUNSUR	KAMPLAPURA_66 HUNSUR_66	2:14	2:29	0:14	LINE FAULT
577	10-Sep-2021	MYSURU	220	VAJMANGLA-TK HALLI	NO STATIONS EFFECTED	7:08	19:18	12:09	NFBC ISSUED
578	10-Sep-2021	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN,LINE CLEAR AVAILED
579	10-Sep-2021	MYSURU	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20 (19/08/2021)			LINE OPEN,LINE CLEAR AVAILED
580	10-Sep-2021	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
581	10-Sep-2021	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
582	10-Sep-2021	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN,LINE CLEAR AVAILED
583	10-Sep-2021	TUMKUR	220	GUTTUR 400KV- GUTTUR2	DAVANGERE_SRS_220	3:53	13:27	9:34	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
584	10-Sep-2021	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP_66	GOLDEN HATCHERIES IPP_66	12:19	12:29	0:10	LINE FAULT
585	10-Sep-2021	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP_66	GOLDEN HATCHERIES IPP_66	12:33	12:50	0:17	LINE FAULT
586	10-Sep-2021	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	17:42	18:20	0:38	LINE CLEAR AVAILED
587	10-Sep-2021	TUMKUR	66	TR-1	RAMPURA_66	10:17	10:28	0:11	TRANSFORMER FAULT
588	10-Sep-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:56	6:05	0:09	LINE FAULT
589	10-Sep-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:43	11:01	0:18	LINE FAULT
590	10-Sep-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:12	9:25	0:13	LINE FAULT
591	11-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
592	11-Sep-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
593	11-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
594	11-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
595	11-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
596	11-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
597	11-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
598	11-Sep-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN,LINE FAULT
599	11-Sep-2021	BAGALKOT	220	GADAG-HARTI1	STATION NOT AFFECTED GADAG_220	9:52 (24.08.2021)			LINE OPEN,LINE FAULT
600	11-Sep-2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:12 (29.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
601	11-Sep-2021	BAGALKOT	220	SIRSI-HUBLI 1	SIRSI_220	17:59 (30.08.2021)	14:58 (11.09.2021)	284:59hrs	LINE CHARGED
602	11-Sep-2021	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110, IPP_110	22:44 (10.09.2021)	05:00 (11.09.2021)	6:16hrs	LINE CHARGED
603	11-Sep-2021	BAGALKOT	110	220/110KV,LV1&LV2	MK HUBLI_220	23:04 (10.09.2021)	07:0 (11.09.2021)	7:56hrs	TRANSFORMER CHARGED
604	11-Sep-2021	BAGALKOT	110	110/11KV,HV2	AKSHYA COLONY_110	11:27	13:45	2:18	LINE CLEAR AVAILED
605	11-Sep-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	12:10	12:35	0:25	HAND TRIPPED
606	11-Sep-2021	BAGALKOT	110	ALBAL-SAIPRIYASUGARS (SPRS)	ALBAL_110	14:51	16:12	1:21	LINE CLEAR AVAILED
607	11-Sep-2021	BAGALKOT	110	CHIKKODI 220-SANKESHWAR	SANKESHWAR_110	3:59	4:00	0:01	LINE FAULT
608	11-Sep-2021	BAGALKOT	110	SANKESHWAR-HUKKERI	SANKESHWAR_110_110	3:45	4:00	0:15	LINE FAULT
609	11-Sep-2021	BAGALKOT	110	HUKKERI-KOTABAGI	HUKKERI_110	4:07	5:19	1:12	LINE FAULT
610	11-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
611	11-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
612	11-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	15:18 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
613	11-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	15:18 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
614	11-Sep-2021	BAGALKOT	110	VAJJRAMATTI220-BILAGI	BILAGI_110,SHIRAGUPPI_1 10,GIRISAGAR_110,BISNAL_ 110,TOLAMATTI_110	21:00	21:05	0:05	LINE FAULT
615	11-Sep-2021	BAGALKOT	110	TODALBAGI-MAMDAPUR	STATION NOT AFFECTED TODALABAGI_110	10:20	10:51	0:31	HAND TRIPPED
616	11-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TUMMINAKATTI_110	16:16	17:24	1:08	LINE CLEAR AVAILED
617	11-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RANNABELAGALI_110	15:47	16:32	0:45	LINE CLEAR AVAILED
618	11-Sep-2021	BAGALKOT	110	110/11KV, HV1	MUDDEBIHAL_110	16:24	18:05	1:41	LINE CLEAR AVAILED
619	11-Sep-2021	BAGALKOT	110	BAGEWADI220-MUDDEBIHAL	MUDDEBIHAL_110	16:25	18:05	1:40	LINE CLEAR AVAILED
620	11-Sep-2021	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	16:30	17:30	1:00	TRANSFORMER FAULT
621	11-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUDDEBIHAL_110	20:03	20:15	0:12	TRANSFORMER FAULT
622	11-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	9:56	17:50	7:54	LINE CLEAR AVAILED
623	11-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	9:56	17:50	7:54	LINE CLEAR AVAILED
624	11-Sep-2021	BAGALKOT	220	220/110KV, HV1	KUDACHI_220	13:32	13:40	0:08	HAND TRIPPED
625	11-Sep-2021	BAGALKOT	220	220/110KV, HV2	KUDACHI_220	13:36	13:55	0:19	HAND TRIPPED
626	11-Sep-2021	BAGALKOT	220	KUDACHI-CHIKKODI1	KUDACHI_220	13:54	16:20	2:26	LINE CLEAR AVAILED
627	11-Sep-2021	BAGALKOT	220	KUDACHI-CHIKKODI2	KUDACHI_220	14:07	14:49	0:42	HAND TRIPPED
628	11-Sep-2021	BAGALKOT	220	KUDACHI-MAHALINGAPUR	KUDACHI_220	14:35	14:52	0:17	HAND TRIPPED
629	11-Sep-2021	BAGALKOT	220	KUDACHI-ATHANI	KUDACHI_220	15:03	15:07	0:04	HAND TRIPPED
630	11-Sep-2021	BAGALKOT	110	220/110KV, LV1	KUDACHI_220	13:32	13:35	0:03	HAND TRIPPED
631	11-Sep-2021	BAGALKOT	110	220/110KV, LV2	KUDACHI_220	15:03	16:00	0:57	HAND TRIPPED
632	11-Sep-2021	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	12:53	13:05	0:12	HAND TRIPPED
633	11-Sep-2021	BAGALKOT	110	KUDACHI220-TERADAL	TERADAL_110, & MORAB_110	13:15	13:19	0:04	HAND TRIPPED
634	11-Sep-2021	BAGALKOT	110	KUDACHI220-KUDACHI	KUDACHI_110	13:24	14:30	1:06	LINE CLEAR AVAILED
635	11-Sep-2021	BAGALKOT	110	KUDACHI220-AINAPUR	AINAPUR_110	13:25	14:30	1:05	LINE CLEAR AVAILED
636	11-Sep-2021	BAGALKOT	110	KUDACHI220-UGARKHUD	UGARKHUD_110	12:45	13:05	0:20	HAND TRIPPED
637	11-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	SIRSI_220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
638	11-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	SIRSI_220	8:54 (10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
639	11-Sep-2021	BAGALKOT	110	SINDAGI-CHANDKAVATE	CHANDAKAVATE_110	0:00	9:35	9:35	MAIN SUPPLY FAILURE
640	11-Sep-2021	BAGALKOT	110	CHANDAKAVTE-ALMEL	ALMEL_110	0:00	9:40	9:40	MAIN SUPPLY FAILURE
641	11-Sep-2021	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI	12:15	12:50	0:35	MAIN SUPPLY FAILURE
642	11-Sep-2021	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	9:13	9:22	0:09	MAIN SUPPLY FAILURE
643	11-Sep-2021	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	10:17	10:18	0:01	MAIN SUPPLY FAILURE
644	11-Sep-2021	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	11:20	11:26	0:06	MAIN SUPPLY FAILURE
645	11-Sep-2021	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	9:13	9:22	0:09	LINE CLEAR AVAILED
646	11-Sep-2021	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	11:20	11:26	0:06	LINE CLEAR AVAILED
647	11-Sep-2021	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	10:17	10:18	0:01	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
648	11-Sep-2021	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	9:13	9:22	0:09	LINE CLEAR AVAILED
649	11-Sep-2021	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	11:20	11:26	0:06	LINE CLEAR AVAILED
650	11-Sep-2021	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	10:17	10:18	0:01	LINE CLEAR AVAILED
651	11-Sep-2021	BENGALURU	66	BYADRAHALLI - SRS PEENYA 220	BYADRAHALLI, SRIGANDAKAVALU	11:19	11:30	0:11	MAIN SUPPLY FAILURE
652	11-Sep-2021	BENGALURU	66	BYADRAHALLI - SRS PEENYA 220	BYADRAHALLI, SRIGANDAKAVALU	11:37	12:00	0:23	MAIN SUPPLY FAILURE
653	11-Sep-2021	BENGALURU	66	CESSNA - HSR LAYOUT 220	CESSNA	12:15	12:55	0:40	MAIN SUPPLY FAILURE
654	11-Sep-2021	BENGALURU	66	CESSNA - VIKAS TECH PARK 220	CESSNA	14:00	14:05	0:05	LOAD CHANGE OVER
655	11-Sep-2021	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	HSR LAYOUT 220	12:15	13:01	0:46	LINE FAULT
656	11-Sep-2021	BENGALURU	66	EXORA - HSR LAYOUT 220	EXORA	12:15	12:57	0:42	MAIN SUPPLY FAILURE
657	11-Sep-2021	BENGALURU	66	EXORA - VIKAS TECH PARK 220	EXORA	14:00	14:08	0:08	LOAD CHANGE OVER
658	11-Sep-2021	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	HSR LAYOUT 220	12:15	13:01	0:46	LINE FAULT
659	11-Sep-2021	BENGALURU	220	HSR LAYOUT 220 - SOMANAHALLI 220	HSR LAYOUT 220	12:15	13:01	0:46	LINE FAULT
660	11-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	12:15	13:01	0:46	LINE CLEAR AVAILED
661	11-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	12:15	13:01	0:46	LINE CLEAR AVAILED
662	11-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	12:15	13:01	0:46	LINE CLEAR AVAILED
663	11-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	JAKKASANDRA	12:15	13:12	0:57	MAIN SUPPLY FAILURE
664	11-Sep-2021	BENGALURU	66	SRS PEENYA 220 - NRS 220	NRS 220	9:09	9:51	0:42	LINE FAULT
665	11-Sep-2021	BENGALURU	66	HV3	SRS PEENYA 220	11:19	11:30	0:11	TRANSFORMER FAULT
666	11-Sep-2021	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, SRIGANDAKALVU	11:19	11:31	0:12	MAIN SUPPLY FAILURE
667	11-Sep-2021	BENGALURU	66	SRS PEENYA 220 - NRS 220	NRS 220	11:14	11:31	0:17	LINE FAULT
668	11-Sep-2021	BENGALURU	66	SRS PEENYA 220 - NRS 220	NO STATION AFFECTED	12:51	17:16	4:25	LINE FAULT
669	11-Sep-2021	BENGALURU	66	HV3	SRS PEENYA 220	11:37	11:43	0:06	TRANSFORMER FAULT
670	11-Sep-2021	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, SRIGANDAKALVU	11:37	11:51	0:14	MAIN SUPPLY FAILURE
671	11-Sep-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	9:09	10:02	0:53	MAIN SUPPLY FAILURE
672	11-Sep-2021	BENGALURU	66	HV3	NRS 220	9:09	9:55	0:46	MAIN SUPPLY FAILURE
673	11-Sep-2021	BENGALURU	66	HV4	NRS 220	9:09	9:55	0:46	MAIN SUPPLY FAILURE
674	11-Sep-2021	BENGALURU	66	NRS 220 - MAHALAKSHMI LAYOUT	NO STATION AFFECTED	9:09	10:01	0:52	MAIN SUPPLY FAILURE
675	11-Sep-2021	BENGALURU	66	HV2	NRS 220	9:09	10:02	0:53	MAIN SUPPLY FAILURE
676	11-Sep-2021	BENGALURU	66	HV1	NRS 220	9:09	10:02	0:53	MAIN SUPPLY FAILURE
677	11-Sep-2021	BENGALURU	66	HV5	NRS 220	9:09	10:02	0:53	MAIN SUPPLY FAILURE
678	11-Sep-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	9:09	10:02	0:53	MAIN SUPPLY FAILURE
679	11-Sep-2021	BENGALURU	66	HV2	NRS 220	10:37	10:42	0:05	LOAD CHANGE OVER
680	11-Sep-2021	BENGALURU	220	HV1	NRS 220	9:09	9:53	0:44	MAIN SUPPLY FAILURE
681	11-Sep-2021	BENGALURU	220	HV2	NRS 220	9:09	9:53	0:44	MAIN SUPPLY FAILURE
682	11-Sep-2021	BENGALURU	220	HV1	NRS 220	11:14	11:35	0:21	MAIN SUPPLY FAILURE
683	11-Sep-2021	BENGALURU	220	HV2	NRS 220	11:14	11:35	0:21	MAIN SUPPLY FAILURE
684	11-Sep-2021	BENGALURU	66	HV1	NRS 220	11:14	11:42	0:28	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
685	11-Sep-2021	BENGALURU	66	HV2	NRS 220	11:14	11:42	0:28	MAIN SUPPLY FAILURE
686	11-Sep-2021	BENGALURU	66	HV3	NRS 220	11:14	11:42	0:28	MAIN SUPPLY FAILURE
687	11-Sep-2021	BENGALURU	66	HV4	NRS 220	11:14	11:46	0:32	MAIN SUPPLY FAILURE
688	11-Sep-2021	BENGALURU	66	HV5	NRS 220	11:14	11:42	0:28	MAIN SUPPLY FAILURE
689	11-Sep-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	11:14	11:41	0:27	MAIN SUPPLY FAILURE
690	11-Sep-2021	BENGALURU	66	HV2	NRS 220	12:00	12:01	0:01	LOAD CHANGE OVER
691	11-Sep-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	11:14	11:49	0:35	MAIN SUPPLY FAILURE
692	11-Sep-2021	BENGALURU	66	HV2	DODDAKARI	15:35	15:45	0:10	TRANSFORMER FAULT
693	11-Sep-2021	BENGALURU	66	HV2	HONNIGANAHALLI	19:40	19:45	0:05	TRANSFORMER FAULT
694	11-Sep-2021	BENGALURU	66	HV2	BAGHMANE WTP	11:05	11:10	0:05	LINE CLEAR AVAILED
695	11-Sep-2021	BENGALURU	66	HV3	NELEMANGALA 66	3:29	3:56	0:27	TRANSFORMER FAULT
696	11-Sep-2021	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTURU	5:35	5:40	0:05	LINE FAULT
697	11-Sep-2021	BENGALURU	66	SM MANGALA - CHINTAMANI 66	NO STATION AFFECTED	17:41	18:22	0:40	LINE CLEAR AVAILED
698	11-Sep-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	17:34(10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
699	11-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
700	11-Sep-2021	GULBARGA	220	HV1 & HV2	ITTAGI_220	12:40	12:48	0:08	TRANSFORMER FAULT
701	11-Sep-2021	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	21:40(10.09.2021)	6:27(11.09.2021)	8:47HRS	LINE CHARGED
702	11-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:15	4:20	0:05	LINE FAULT
703	11-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	4:15	4:20	0:05	LINE FAULT
704	11-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
705	11-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
706	11-Sep-2021	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
707	11-Sep-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	4:08	4:14	0:06	LINE FAULT
708	11-Sep-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDINAGAR_110	3:03	3:13	0:10	LINE FAULT
709	11-Sep-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDINAGAR_110	2:08	2:28	0:20	LINE FAULT
710	11-Sep-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110,GANDINAGAR_110	14:10	14:20	0:10	LINE FAULT
711	11-Sep-2021	GULBARGA	110	HV2	TEKKALKOTE_110	16:20	16:45	0:25	TRANSFORMER FAULT
712	11-Sep-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	1:35	2:00	0:25	MAIN SUPPLY FAILURE
713	11-Sep-2021	GULBARGA	110	HV1	MUDDAPUR_110	9:00	10:05	1:05	TRANSFORMER FAULT
714	11-Sep-2021	GULBARGA	110	PD HALLI-ALIPUR	PD HALLI_110	3:45	7:00	3:15	LINE FAULT
715	11-Sep-2021	GULBARGA	110	PD HALLI-ALIPUR	PD HALLI_110	9:15	9:20	0:05	LINE FAULT
716	11-Sep-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	4:55	5:25	0:30	MAIN SUPPLY FAILURE
717	11-Sep-2021	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110	7:05	12:45	5:40	NFBC ISSUED
718	11-Sep-2021	GULBARGA	110	HV1	HATTI_110	16:43 (11.09.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
719	11-Sep-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPU R_110,NSL SUGARS FACTORY	22:40	22:47	0:07	LINE FAULT
720	11-Sep-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	9:44	9:53	0:09	LINE FAULT
721	11-Sep-2021	GULBARGA	110	HUMNABAD-MANEKHALI	MANEKHALI_110	9:45	9:52	0:07	LINE FAULT
722	11-Sep-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	4:18	4:25	0:07	LINE FAULT
723	11-Sep-2021	GULBARGA	66	ITTAGI-RENEWSOLAR1_IPP	ITTAGI_220	7:10	7:25	0:15	LINE FAULT
724	11-Sep-2021	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	17:50	18:05	0:15	MAIN SUPPLY FAILURE
725	11-Sep-2021	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGLI_66,SOVENHA LLI_66,GIRIYAPUR_66,MAG ALA_66,TUNGABHADRA_IP P	18:25	18:32	0:07	LINE FAULT
726	11-Sep-2021	GULBARGA	66	HV1	ITTAGI_220	18:45	18:52	0:07	TRANSFORMER FAULT
727	11-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.8.2021)			LINE OPEN,LINE CLEAR AVAILED
728	11-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
729	11-Sep-2021	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	20:51(11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
730	11-Sep-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	17:26(10.09.2021)	7:15(11.09.2021)	13:48 hrs	LINE CHARGED
731	11-Sep-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	16:59	18:36	1:37	LINE CLEAR AVAILED
732	11-Sep-2021	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	12:20	13:04	0:44	LINE FAULT
733	11-Sep-2021	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	16:53	18:36	1:43	LINE CLEAR AVAILED
734	11-Sep-2021	HASSAN	110	BARANG-SHR220	BARANGI_110	13:30	15:25	1:55	LINE CLEAR AVAILED
735	11-Sep-2021	HASSAN	110	JOG-JST2	mghejog_gen	15:38	15:50	0:12	LINE FAULT
736	11-Sep-2021	HASSAN	66	CRPATNA-KIKKERI	CRPATNA_220	10:15	16:53	6:38	LINE CLEAR AVAILED
737	11-Sep-2021	MYSURU	66	HV1	ADDIHALLI_66	10:21	12:40	2:19	LINE CLEAR AVAILED
738	11-Sep-2021	MYSURU	66	HV2	ADDIHALLI_66	10:21	12:40	2:19	LINE CLEAR AVAILED
739	11-Sep-2021	MYSURU	66	CHUNCHUNKATTE-KR NAGARA	NO STATIONS EFFECTED	16:36	16:50	0:14	LINE CLEAR AVAILED
740	11-Sep-2021	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	5:54	6:20	0:25	LINE FAULT
741	11-Sep-2021	MYSURU	66	FTS-RAJEEVNAGAR	NO STATIONS EFFECTED	18:34	20:31	1:56	NFBC ISSUED
742	11-Sep-2021	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	18:34	20:30	1:56	LINE CLEAR AVAILED
743	11-Sep-2021	MYSURU	66	HV2	HAMPAPURA_66	10:05	14:20	4:15	LINE CLEAR AVAILED
744	11-Sep-2021	MYSURU	66	HV2	HOOTAGALLY_220	10:05	14:20	4:15	LINE CLEAR AVAILED
745	11-Sep-2021	MYSURU	66	HV1	HOOTAGALLY_220	14:15	14:20	0:05	LINE CLEAR AVAILED
746	11-Sep-2021	MYSURU	66	HV1	HOOTAGALLY_220	14:45	14:50	0:05	HAND TRIPPED
747	11-Sep-2021	MYSURU	66	HV1	HOOTAGALLY_220	14:45	14:50	0:05	HAND TRIPPED
748	11-Sep-2021	MYSURU	66	HUNSUR - PERIYAPATNA	NO STATIONS EFFECTED	17:19	9:50	16:30	LINE CLEAR AVAILED
749	11-Sep-2021	MYSURU	66	JYOTHINAGARA-FTS	NO STATIONS EFFECTED	16:05	16:18	0:12	LINE FAULT
750	11-Sep-2021	MYSURU	66	HV2	KADAKOLA_220	9:58	10:09	0:11	TRANSFORMER FAULT
751	11-Sep-2021	MYSURU	66	KIKKERI-KR PETE	KIKKERI_66	10:05	17:11	7:06	LINE CLEAR AVAILED
752	11-Sep-2021	MYSURU	66	KIRUGAVALU-SFC	MALIYURU_66	5:38	5:46	0:08	LINE FAULT
753	11-Sep-2021	MYSURU	66	KUSHALNAGARA -MYSORE1	MIRLE_66	15:19	16:49	1:29	LINE CLEAR AVAILED
754	11-Sep-2021	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	7:07	18:43	11:35	NFBC ISSUED
755	11-Sep-2021	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN,LINE CLEAR AVAILED
756	11-Sep-2021	MYSURU	66	CHUNKANAKATTE-KR NAGARA	NO STATIONS EFFECTED	8:20 (19/08/2021)	8:45 (11.09.2021)	552:54HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
757	11-Sep-2021	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
758	11-Sep-2021	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
759	11-Sep-2021	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN,LINE CLEAR AVAILED
760	11-Sep-2021	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN,LINE CLEAR AVAILED
761	11-Sep-2021	TUMKUR	220	GUTTUR 400KV- GUTTUR1	DAVANGERE_SRS_220	10:04	16:10	6:06	LINE CLEAR AVAILED
762	11-Sep-2021	TUMKUR	220	TR-1	KIADBVNP_220	12:56	18:01	5:05	LINE CLEAR AVAILED
763	11-Sep-2021	TUMKUR	220	TR-2	KIADBVNP_220	13:13	18:01	4:48	LINE CLEAR AVAILED
764	11-Sep-2021	TUMKUR	110	TR-1	KATHRIKEHAL_110	18:28	19:32	1:03	LINE CLEAR AVAILED
765	11-Sep-2021	TUMKUR	66	KDBVNP- TMTP	TMTP_66	13:00	18:24	5:24	LINE CLEAR AVAILED
766	11-Sep-2021	TUMKUR	66	TR-1	KIADBVNP_220	17:01	18:05	1:03	LINE CLEAR AVAILED
767	11-Sep-2021	TUMKUR	66	TR-2	KIADBVNP_220	17:01	18:12	1:11	LINE CLEAR AVAILED
768	11-Sep-2021	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:53	11:27	0:33	LINE FAULT
769	11-Sep-2021	TUMKUR	66	TR-2	BALENAHALI_66	23:01	23:09	0:07	TRANSFORMER FAULT
770	11-Sep-2021	TUMKUR	66	TR-2	BALENAHALI_66	23:10	23:14	0:04	TRANSFORMER FAULT
771	11-Sep-2021	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	10:52	10:56	0:04	HAND TRIPPED
772	11-Sep-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKWADA_66	9:29	9:31	0:01	LINE FAULT
773	12-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
774	12-Sep-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
775	12-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
776	12-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
777	12-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
778	12-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
779	12-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
780	12-Sep-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN,LINE FAULT
781	12-Sep-2021	BAGALKOT	220	GADAG-HARTI1	STATION NOT AFFECTED GADAG_220	9:52 (24.08.2021)			LINE OPEN,LINE FAULT
782	12-Sep-2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:12 (29.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
783	12-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
784	12-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
785	12-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	15:18 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
786	12-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	15:18 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
787	12-Sep-2021	BAGALKOT	110	MAHALINGAPUR-GSML1	MAHALINGAPUR_220	8:25	17:50	9:25	LINE CLEAR AVAILED
788	12-Sep-2021	BAGALKOT	110	MAHALINGAPUR-GSML2	MAHALINGAPUR_220	8:25	17:50	9:25	LINE CLEAR AVAILED
789	12-Sep-2021	BAGALKOT	110	MAHALINGAPUR-GSML1	MAHALINGAPUR_220	22:24	22:53	0:29	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
790	12-Sep-2021	BAGALKOT	110	MAHALINGAPUR-GSML2	MAHALINGAPUR_220	17:55	17:57	0:02	LINE FAULT
791	12-Sep-2021	BAGALKOT	220	KUDUCHI-MAHALINGAPUR	MAHALINGAPUR_220	22:24	23:08	0:44	LINE FAULT
792	12-Sep-2021	BAGALKOT	110	220/110KV, LV1&LV2	MK HUBLI_220	21:21 (12.09.2021)			TRANSFORMER OPEN LINE CLEAR AVALIED
793	12-Sep-2021	BAGALKOT	220	CHIKKODI- KUDUCHI1(GHATAPRABHA)	CHIKKODI_220	22:24	23:14	0:50	LINE FAULT
794	12-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MUDDABIHAL 110	0:04	0:10	0:06	TRANSFORMER FAULT
795	12-Sep-2021	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MANALI SUGARS_110 STATION NOT AFFECTED MALGHAN(S) 110	12:35	14:10	1:35	LINE CLEAR AVALIED
796	12-Sep-2021	BAGALKOT	110	MAMADAPUR(B)-BELGAUM SOLAR	BELGAUM SOLAR_110 STATION NOT AFFECTED MAMADAPUR(B) 110	20:55	23:44	2:49	LINE CLEAR AVALIED
797	12-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED ITNAL 110	11:19	11:37	0:18	TRANSFORMER FAULT
798	12-Sep-2021	BAGALKOT	110	HALIYAL-ALNAVAR(GMR)	ALNAVAR_110	6:05	6:19	0:14	LINE FAULT
799	12-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET 66	10:22 (12.09.2021)			TRANSFORMER OPEN LINE CLEAR AVALIED
800	12-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET 66	10:23 (12.09.2021)			TRANSFORMER OPEN LINE CLEAR AVALIED
801	12-Sep-2021	BAGALKOT	220	KUDACHI-ATHANI	KUDACHI_220	22:24 (12.09.2021)			LINE OPEN, LINE FAULT
802	12-Sep-2021	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KUDACHI 220	22:42	23:19	0:37	HAND TRIPPED
803	12-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	SIRSI_220	19:05 (09.09.2021)			LINE OPEN, LINE CLEAR AVALIED
804	12-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	SIRSI_220	09:06 (10.09.2021)			LINE OPEN, LINE CLEAR AVALIED
805	12-Sep-2021	BAGALKOT	220	CHIKKODI-KUDUCHI2	CHIKKODI_220	22:24	23:15	0:51	LINE FAULT
806	12-Sep-2021	BENGALURU	66	BYADRAHALLI - SRS PEENYA 220	BYADRAHALLI, SRIGANDAKAVALU	10:03	10:10	0:07	MAIN SUPPLY FAILURE
807	12-Sep-2021	BENGALURU	66	BYADRAHALLI - SRS PEENYA 220	BYADRAHALLI, SRIGANDAKAVALU	18:10	18:15	0:05	MAIN SUPPLY FAILURE
808	12-Sep-2021	BENGALURU	66	CESSNA - HSR LAYOUT 220	CESSNA	11:45	11:55	0:10	MAIN SUPPLY FAILURE
809	12-Sep-2021	BENGALURU	66	CESSNA - HSR LAYOUT 220	CESSNA	18:30	18:37	0:07	MAIN SUPPLY FAILURE
810	12-Sep-2021	BENGALURU	66	EXORA - HSR LAYOUT 220	EXORA	11:51	11:59	0:08	MAIN SUPPLY FAILURE
811	12-Sep-2021	BENGALURU	66	EXORA - HSR LAYOUT 220	EXORA	18:29	18:39	0:10	MAIN SUPPLY FAILURE
812	12-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	11:51	12:01	0:10	HAND TRIPPED
813	12-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	11:51	12:01	0:10	HAND TRIPPED
814	12-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	11:51	12:01	0:10	HAND TRIPPED
815	12-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	18:29	18:38	0:09	HAND TRIPPED
816	12-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	18:29	18:38	0:09	HAND TRIPPED
817	12-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	18:29	18:38	0:09	HAND TRIPPED
818	12-Sep-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	8:54	8:58	0:04	LOAD CHANGE OVER
819	12-Sep-2021	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	18:26	18:31	0:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
820	12-Sep-2021	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	8:48	8:55	0:07	LOAD CHANGE OVER
821	12-Sep-2021	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	18:26	18:32	0:06	LOAD CHANGE OVER
822	12-Sep-2021	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	23:08	23:12	0:04	LOAD CHANGE OVER
823	12-Sep-2021	BENGALURU	66	RMV - SRS PEENYA 220	RMV	9:07	9:10	0:03	LOAD CHANGE OVER
824	12-Sep-2021	BENGALURU	66	RMV - HEBBAL 220	RMV	18:25	18:28	0:03	LOAD CHANGE OVER
825	12-Sep-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	6:20	6:31	0:11	LINE FAULT
826	12-Sep-2021	BENGALURU	66	HV2	BAGHMANE WTP	10:45	10:50	0:05	LINE CLEAR AVAILED
827	12-Sep-2021	BENGALURU	66	HOSKOTE 220 - BOODIGERE	NO STATION AFFECTED	18:47	19:03	0:15	LINE FAULT
828	12-Sep-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	15:41	16:21	0:40	LINE FAULT
829	12-Sep-2021	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTURU	GUNDLU KOTTURU	22:55	23:09	0:13	LINE FAULT
830	12-Sep-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	17:34(10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
831	12-Sep-2021	GULBARGA	400	RTPS-BTPS	RTPS_400	23:58(12.09.2021)			LINE OPEN,LINE CLEAR AVAILED
832	12-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
833	12-Sep-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	0:50	6:45	5:55	LINE CLEAR AVAILED
834	12-Sep-2021	GULBARGA	220	SHAHAPUR-RTPS2	RTPS_220	9:22	12:20	2:58	LINE CLEAR AVAILED
835	12-Sep-2021	GULBARGA	110	RAICHUR-APMC1,2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	9:14	9:22	0:08	LINE FAULT
836	12-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
837	12-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
838	12-Sep-2021	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
839	12-Sep-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	0:49	0:59	0:10	LINE FAULT
840	12-Sep-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	1:51	2:01	0:10	LINE FAULT
841	12-Sep-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	5:04	5:24	0:20	LINE FAULT
842	12-Sep-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110,GANGAVATHI_110,VENKATAGIRI_110	3:21	3:26	0:05	LINE FAULT
843	12-Sep-2021	GULBARGA	110	HV1	HATTI_110	16:43 (11.09.2021)	11:15(12.09.2021)	18:32 HRS	TRANSFORMER CHARGED
844	12-Sep-2021	GULBARGA	110	HV1	HATTI_110	13:11	13:47	0:36	LINE CLEAR AVAILED
845	12-Sep-2021	GULBARGA	110	MADIYAL-NSL IPP	MADIYAL_110	12:11	12:25	0:14	LINE CLEAR AVAILED
846	12-Sep-2021	GULBARGA	110	MADIYAL-NSL IPP	MADIYAL_110	7:25	15:27	8:02	LINE CLEAR AVAILED
847	12-Sep-2021	GULBARGA	110	HV2	YEDRAMI_110	6:20	6:30	0:10	TRANSFORMER FAULT
848	12-Sep-2021	GULBARGA	110	HV1	MUDDAPUR_110	7:28	7:34	0:06	TRANSFORMER FAULT
849	12-Sep-2021	GULBARGA	110	HV1,HV2	RAJESHWAR_110	16:09	16:30	0:21	LINE CLEAR AVAILED
850	12-Sep-2021	GULBARGA	66	HV1	HANASI_66	16:05	16:10	0:05	LINE CLEAR AVAILED
851	12-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.8.2021)			LINE OPEN,LINE CLEAR AVAILED
852	12-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
853	12-Sep-2021	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	20:51(11.09.2021)	11:14(12.09.2021)	14:22 hrs	LINE CHARGED
854	12-Sep-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	9:13	11:12	1:59	LINE CLEAR AVAILED
855	12-Sep-2021	HASSAN	110	HV2	ANAVATTI_110	6:35	6:55	0:20	MAIN SUPPLY FAILURE
856	12-Sep-2021	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:35	12:00	1:25	LINE CLEAR AVAILED
857	12-Sep-2021	HASSAN	110	HV2	ANAVATTI_110	10:00	12:00	2:00	TRANSFORMER FAULT
858	12-Sep-2021	HASSAN	66	HV1	KUDLIGERE_66	15:54	17:21	1:27	TRANSFORMER FAULT
859	12-Sep-2021	MYSURU	66	CR NAGAR-YALANDUR	NO STATIONS EFFECTED	22:16	22:22	0:06	LINE FAULT
860	12-Sep-2021	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	17:15	9:48	16:32	LINE CLEAR AVAILED
861	12-Sep-2021	MYSURU	220	KUSHALNAGARA-BASTIPURA1	KUSHALNAGARA_220	11:40	16:35	4:55	LINE CLEAR AVAILED
862	12-Sep-2021	MYSURU	220	KUSHALNAGARA-BASTIPURA2	KUSHALNAGARA_220	11:40	16:35	4:55	LINE CLEAR AVAILED
863	12-Sep-2021	MYSURU	66	MADHUVANALLI-MAMBALLI	MAMBALLI_66	6:10	6:15	0:04	LINE FAULT
864	12-Sep-2021	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	SUNTIKOPPA_66	10:03	17:26	7:22	LINE CLEAR AVAILED
865	12-Sep-2021	MYSURU	66	SUNTIKOPPA-MADIKERI	MADIKERI_66	10:03	17:26	7:23	LINE CLEAR AVAILED
866	12-Sep-2021	MYSURU	220	VAJMANGALA-TKHALLI	NO STATIONS EFFECTED	6:56	19:05	12:09	NFBC ISSUED
867	12-Sep-2021	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
868	12-Sep-2021	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
869	12-Sep-2021	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN,LINE CLEAR AVAILED
870	12-Sep-2021	TUMKUR	66	TR-2	BALENAHALLI_66	13:59	14:05	0:06	TRANSFORMER FAULT
871	12-Sep-2021	TUMKUR	66	TR-2	BALENAHALLI_66	11:06	11:21	0:15	TRANSFORMER FAULT
872	12-Sep-2021	TUMKUR	66	TR-2	BELLAVI_66	10:13	17:23	7:10	LINE CLEAR AVAILED
873	12-Sep-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66	17:01	17:31	0:30	LINE CLEAR AVAILED
874	12-Sep-2021	TUMKUR	66	KANCHIPURA-MATHOD 66	KANCHIPURA_66	17:04	17:15	0:10	LINE CLEAR AVAILED
875	12-Sep-2021	TUMKUR	66	TR-1	GARAGA_66	15:35	16:07	0:32	MAIN SUPPLY FAILURE
876	12-Sep-2021	TUMKUR	66	TR-2	GARAGA_66	15:35	16:07	0:32	MAIN SUPPLY FAILURE
877	12-Sep-2021	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	18:12	18:34	0:21	HAND TRIPPED
878	12-Sep-2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	16:27	16:58	0:30	HAND TRIPPED
879	12-Sep-2021	TUMKUR	66	TR-1	MATHOD_66	12:13	12:33	0:19	HAND TRIPPED
880	12-Sep-2021	TUMKUR	66	TR-2	MATHOD_66	13:20	14:02	0:42	HAND TRIPPED
881	12-Sep-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI	15:38	16:04	0:25	HAND TRIPPED
882	12-Sep-2021	TUMKUR	66	MATHOD-RAMCO CEMENT EHT_66	PANCHANAHALLI_66, GARAGA_66	17:05	17:16	0:10	HAND TRIPPED
883	12-Sep-2021	TUMKUR	66	TR-1	PATTNAYAKANAHALLI_66	13:57	14:10	0:13	LINE CLEAR AVAILED
884	12-Sep-2021	TUMKUR	66	TR-2	PATTNAYAKANAHALLI_66	13:57	14:10	0:13	LINE CLEAR AVAILED
885	13-Sep-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN,LINE CLEAR AVAILED
886	13-Sep-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN,LINE FAULT
887	13-Sep-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
888	13-Sep-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
889	13-Sep-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17(23.02.2021)			LINE OPEN,LINE FAULT
890	13-Sep-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
891	13-Sep-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
892	13-Sep-2021	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	18:43 (01.08.2021)			LINE OPEN,LINE FAULT
893	13-Sep-2021	BAGALKOT	220	GADAG-HARTI1	STATION NOT AFFECTED GADAG_220	9:52(24.08.2021)	17:24 (13.09.2021)	487:32HRS	LINE CHARGED
894	13-Sep-2021	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:12 (29.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
895	13-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
896	13-Sep-2021	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	14:58 (11.09.2021)			LINE OPEN,LINE CLEAR AVAILED
897	13-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI1	STATION NOT AFFECTED SIRSI_220	15:18 (11.09.2021)	15:26 (13.09.2021)	48:08HRS	LINE CHARGED
898	13-Sep-2021	BAGALKOT	110	SIRSI220-SIRSI2	STATION NOT AFFECTED SIRSI_220	15:18 (11.09.2021)	15:26 (13.09.2021)	48:08HRS	LINE CHARGED
899	13-Sep-2021	BAGALKOT	110	220/110KV&LV2	MK HUBLI_220	21:21 (12.09.2021)	8:06 (13.09.2021)	10:45HRS	TRANSFORMER CHARGED
900	13-Sep-2021	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
901	13-Sep-2021	BAGALKOT	66	66/33KV, HV4	STATION NOT AFFECTED HARIHAR HOSPET_66	10:23 (12.09.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
902	13-Sep-2021	BAGALKOT	220	KUDACHI-ATHANI	KUDACHI_220	22:24 (12.09.2021)	08.:00 (13.09.2021)	9:36HRS	LINE CHARGED
903	13-Sep-2021	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	11:10	16:35	5:25	NFBC ISSUED
904	13-Sep-2021	BAGALKOT	220	MUGALKHOD-GHATAPRABHA2	MUGALKHOD_220	10:59	13:26	2:27	LINE CLEAR AVAILED
905	13-Sep-2021	BAGALKOT	220	GHATAPRABHA-MUGALKHOD2	GHATAPRABHA_220	10:55	13:33	2:38	NFBC ISSUED
906	13-Sep-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:11	16:35	5:24	LINE CLEAR AVAILED
907	13-Sep-2021	BAGALKOT	220	220/110KV,HV2,LV2	BIJAPUR_220	10:36	17:33	6:57	LINE CLEAR AVAILED
908	13-Sep-2021	BAGALKOT	110	BIJAPUR-BIJAPUR	BIJAPUR CUTY_110	18:43	18:51	0:08	LINE FAULT
909	13-Sep-2021	BAGALKOT	110	GHATAPRABHA-KABBUR	KABBUR_110	6:20	6:33	0:13	LINE FAULT
910	13-Sep-2021	BAGALKOT	110	HAVERI220-HANAGAL(TILUVALI)	HANAGAL_110	5:59	6:18	0:19	LINE FAULT
911	13-Sep-2021	BAGALKOT	220	KUDUCHI-CHIKKODI1	KUDUCHI_220	13:40	17:51	4:11	LINE CLEAR AVAILED
912	13-Sep-2021	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 TAKKALAKI_110	13:31	13:32	0:01	HAND TRIPPED
913	13-Sep-2021	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 TAKKALAKI_110	13:31	13:32	0:01	HAND TRIPPED
914	13-Sep-2021	BAGALKOT	110	NARENDRA220-UAS DHARWAD	STATION NOT AFFECTED NARENDRA_220	11:28	14:53	3:25	LINE CLEAR AVAILED
915	13-Sep-2021	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MANALI SUGARS_110 STATION NOT AFFECTED MALAGHAN(S)_110	6:01	6:33	0:32	LINE FAULT
916	13-Sep-2021	BAGALKOT	110	MUDEDEBIHAL-BAGEWADI220	MUDEDEBIHAL_110	14:57	15:58	1:01	LINE FAULT
917	13-Sep-2021	BAGALKOT	110	MUDEDEBIHAL-BALAJI SUGARS	BALAJI SUGARS_110 MUDEDEBIHAL_110	14:57	16:02	1:05	LINE FAULT
918	13-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALAGHAN(B)_110	16:17	16:29	0:12	TRANSFORMER FAULT
919	13-Sep-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MALAGHAN(B)_110	18:00	18:06	0:06	TRANSFORMER FAULT
920	13-Sep-2021	BAGALKOT	110	110/11KV, HV3 (HV4)	STATION NOT AFFECTED KULIGOD_110	15:43	16:18	0:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
921	13-Sep-2021	BAGALKOT	220	220/110KV, HV2 (HV1) & LV2	STATION NOT AFFECTED GADAG_220	17:43	19:27	1:44	LINE CLEAR AVAILED
922	13-Sep-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED KERUR_110	20:24	20:36	0:12	HAND TRIPPED
923	13-Sep-2021	BAGALKOT	110	BAGEWADI220- MUDEDEBIHAL(ACHANUR)	MUDEDEBIHAL_110	14:58	15:17	0:19	LINE FAULT
924	13-Sep-2021	BAGALKOT	110	SIRSI220-KAVALWADA	SIRSI_220	19:05 (09.09.2021)			LINE OPEN,LINE CLEAR AVAILED
925	13-Sep-2021	BAGALKOT	110	SIRSI220-UMMACHAGI	SIRSI_220	09:06 (10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
926	13-Sep-2021	BAGALKOT	110	KUDUCHI-SHIRAGUPPI	SHIRAGUPPI_110	5:30	5:45	0:15	MAIN SUPPLY FAILURE
927	13-Sep-2021	BAGALKOT	110	110/11KV,HV1	MORAB_110	16:00	17:15	1:15	LINE CLEAR AVAILED
928	13-Sep-2021	BAGALKOT	110	MANTUR-MAREGUDDI	MANTUR_110	13:00	13:10	0:10	LINE FAULT
929	13-Sep-2021	BAGALKOT	110	MANTUR-VAJRAMATTI2	MANTUR_110	13:00	13:10	0:10	LINE FAULT
930	13-Sep-2021	BAGALKOT	220	220/110KV, HV1 & LV1	STATION NOT AFFECTED GADAG_220	10:34	17:42	7:08	LINE CLEAR AVAILED
931	13-Sep-2021	BENGALURU	66	HV1	AMAR JYOTHI	20:21	20:27	0:06	LOAD CHANGE OVER
932	13-Sep-2021	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	12:33	12:50	0:17	MAIN SUPPLY FAILURE
933	13-Sep-2021	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	18:38	18:58	0:20	LOAD CHANGE OVER
934	13-Sep-2021	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	12:33	13:10	0:37	MAIN SUPPLY FAILURE
935	13-Sep-2021	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	18:38	19:03	0:25	MAIN SUPPLY FAILURE
936	13-Sep-2021	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	8:12	8:18	0:06	HAND TRIPPED
937	13-Sep-2021	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	19:18	19:28	0:10	LOAD CHANGE OVER
938	13-Sep-2021	BENGALURU	66	KENGERI SATELLITE TOWN - VRISHABHAVATHI 220	KENGERI SATELLITE TOWN	12:33	13:12	0:39	MAIN SUPPLY FAILURE
939	13-Sep-2021	BENGALURU	66	KENGERI SATELLITE TOWN - VRISHABHAVATHI 220	KENGERI SATELLITE TOWN	18:37	19:19	0:42	MAIN SUPPLY FAILURE
940	13-Sep-2021	BENGALURU	66	MANYATHA 220 - HOSKOTE 2	SHOBHA CITY, HENNUR CROSS	14:57	15:10	0:13	LINE FAULT
941	13-Sep-2021	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	7:35	8:17	0:42	MAIN SUPPLY FAILURE
942	13-Sep-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	7:35	8:27	0:52	LINE CLEAR AVAILED
943	13-Sep-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	7:35	8:27	0:52	LINE CLEAR AVAILED
944	13-Sep-2021	BENGALURU	66	NRS 220 - VICTORIA	VICTORIA	7:35	8:01	0:26	LINE CLEAR AVAILED
945	13-Sep-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	7:35	8:17	0:42	LINE CLEAR AVAILED
946	13-Sep-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	19:46	19:51	0:05	HAND TRIPPED
947	13-Sep-2021	BENGALURU	66	HV2	REMCO	12:33	13:10	0:37	MAIN SUPPLY FAILURE
948	13-Sep-2021	BENGALURU	66	HV2	REMCO	18:37	18:55	0:18	MAIN SUPPLY FAILURE
949	13-Sep-2021	BENGALURU	66	SOBHA FOREST - SOMANAHALLI 220	SOBHA FOREST	20:21	20:38	0:17	LOAD CHANGE OVER
950	13-Sep-2021	BENGALURU	220	SRS PEENYA 220 - NRS 220	NRS 220	7:35	8:18	0:43	LINE FAULT
951	13-Sep-2021	BENGALURU	66	HV2	SRS PEENYA 220	7:35	7:45	0:10	TRANSFORMER FAULT
952	13-Sep-2021	BENGALURU	66	HV2	TK HALLI 220	14:31	14:35	0:04	LINE CLEAR AVAILED
953	13-Sep-2021	BENGALURU	66	HV2	TK HALLI 220	20:11	20:15	0:04	LINE CLEAR AVAILED
954	13-Sep-2021	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220	VRISHABHAVATHI 220	12:33	12:58	0:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
955	13-Sep-2021	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220	VRISHABHAVATHI 220	18:38	18:53	0:15	MAIN SUPPLY FAILURE
956	13-Sep-2021	BENGALURU	66	HV1	NGEF	8:10	10:25	2:15	LINE CLEAR AVAILED
957	13-Sep-2021	BENGALURU	66	HV2	NGEF	8:10	10:25	2:15	LINE CLEAR AVAILED
958	13-Sep-2021	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	8:48	8:52	0:04	LOAD CHANGE OVER
959	13-Sep-2021	BENGALURU	66	BAGMANE WTP - ITI 220	BAGMANE WTP	22:34	22:39	0:05	LOAD CHANGE OVER
960	13-Sep-2021	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	20:14	20:20	0:06	LOAD CHANGE OVER
961	13-Sep-2021	BENGALURU	66	YEDUMADU - HANUMANTHNAGAR	HANUMANTHNAGAR	8:00	13:18	5:18	LINE FAULT
962	13-Sep-2021	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU, HANUMANTHNAGAR	8:00	8:20	0:20	LINE FAULT
963	13-Sep-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	11:40	11:43	0:03	LINE FAULT
964	13-Sep-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	11:40	11:43	0:03	LINE FAULT
965	13-Sep-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	15:55	16:01	0:05	LINE FAULT
966	13-Sep-2021	BENGALURU	66	HV1	PILLAGUMPA	22:58(12-9-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
967	13-Sep-2021	BENGALURU	66	HV1	PILLAGUMPA	22:58(12-9-2021)	11:50(13-9-2021)	12:51HRS	TRANSFORMER CHARGED
968	13-Sep-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	NO STATION AFFECTED	20:37(13-9-2021)			LINE OPEN,LINE CLEAR AVAILED
969	13-Sep-2021	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	19:04(13/09/2021)			LINE OPEN,LINE FAULT
970	13-Sep-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	17:34(10.09.2021)			LINE OPEN,LINE CLEAR AVAILED
971	13-Sep-2021	GULBARGA	400	RTPS-BTPS	RTPS_400	23:58(12.09.2021)	07:40(13.09.2021)	07:42HRS	LINE CHARGED
972	13-Sep-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
973	13-Sep-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
974	13-Sep-2021	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN,LINE CLEAR AVAILED
975	13-Sep-2021	GULBARGA	110	HV2	VALKAMDINNI_110	11:15(31.08.2021)			TRANSFORMER OPEN LINE CLEAR AVAILED
976	13-Sep-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	5:35	6:00	0:25	MAIN SUPPLY FAILURE
977	13-Sep-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	DHADESUGUR_110,SIRGUP PA_110,TEKKALKOTE_110, NSL SUGAR IPP	1:45	1:55	0:10	LINE FAULT
978	13-Sep-2021	GULBARGA	110	MALLAT-BYGWAT2	ADAVI AMARESHWAR_110	18:25	19:18	0:53	LINE FAULT
979	13-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:14	4:21	0:07	LINE FAULT
980	13-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110,	4:14	4:21	0:07	LINE FAULT
981	13-Sep-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:15	4:20	0:05	LINE FAULT
982	13-Sep-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAP UR_110,MANVI_110	14:37	14:41	0:04	LINE FAULT
983	13-Sep-2021	GULBARGA	110	RAICHUR-APMC1,2	APMC_110,CHIKKASUGUR_110,SHAKTHINAGA_110	19:08	19:16	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
984	13-Sep-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_110,UGAR SUGAR IPP	22:12	22:19	0:07	LINE FAULT
985	13-Sep-2021	GULBARGA	110	HV3	VALKAMDINNI_110	16:52	17:09	0:17	TRANSFORMER FAULT
986	13-Sep-2021	GULBARGA	110	HV3	VALKAMDINNI_110	16:29	16:40	0:11	TRANSFORMER FAULT
987	13-Sep-2021	GULBARGA	110	HV3	MANTHAL	9:23	9:32	0:09	LINE CLEAR AVAILED
988	13-Sep-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	18:22	18:36	0:14	LINE FAULT
989	13-Sep-2021	HASSAN	110	LPH-MGHE 1	lph_gen	11:13 (20.08.2021)			LINE OPEN,LINE CLEAR AVAILED
990	13-Sep-2021	HASSAN	220	MRSSHM-DVG2	MRSMSG_220	17:08 (30.08.2021)			LINE OPEN,LINE CLEAR AVAILED
991	13-Sep-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	19:56(13.09.2021)			LINE OPEN,LINE FAULT
992	13-Sep-2021	HASSAN	220	CRPATNA-HUYGNH	CRPATNA_220	11:21	16:30	5:09	LINE CLEAR AVAILED
993	13-Sep-2021	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	18:19	20:03	1:44	LINE CLEAR AVAILED
994	13-Sep-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	18:20	20:03	1:43	NFBC ISSUED
995	13-Sep-2021	HASSAN	110	AJAMPU-SHIVNI	AJAMPURA_110	12:30	12:45	0:15	LINE FAULT
996	13-Sep-2021	HASSAN	110	MADHUVKUNDAPURA	MADHUVANA_110	17:12	17:37	0:25	LINE FAULT
997	13-Sep-2021	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	17:37	20:57	3:20	LINE FAULT
998	13-Sep-2021	HASSAN	110	HV3	MRSMSG_220	9:30	12:26	2:56	LINE CLEAR AVAILED
999	13-Sep-2021	HASSAN	66	HV1	HALLYMYSORE_66	21:02	21:18	0:16	TRANSFORMER FAULT
1000	13-Sep-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	16:54	18:51	1:57	LINE CLEAR AVAILED
1001	13-Sep-2021	MYSURU	66	BESAGRALLI-DUDDENHALLY	NO STATIONS EFFECTED	13:34	13:52	0:17	LINE CLEAR AVAILED
1002	13-Sep-2021	MYSURU	66	HV1	DUNDANALLI_66	12:10	13:01	0:50	LINE CLEAR AVAILED
1003	13-Sep-2021	MYSURU	66	HV2	HAMPAPURA_66	13:00	15:47	2:47	LINE CLEAR AVAILED
1004	13-Sep-2021	MYSURU	220	HV3	HOOTAGALLI_66	9:57	13:45	3:48	LINE CLEAR AVAILED
1005	13-Sep-2021	MYSURU	66	KHB STATION-BILIKERE	NO STATIONS EFFECTED	13:53	16:37	2:43	LINE CLEAR AVAILED
1006	13-Sep-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:13	9:22	0:08	LINE FAULT
1007	13-Sep-2021	MYSURU	220	KR PETE 220-CR PATNA	NO STATIONS EFFECTED	11:55	16:50	4:55	LINE CLEAR AVAILED
1008	13-Sep-2021	MYSURU	66	HV1	KR PETE_220	10:14	13:43	3:28	LINE CLEAR AVAILED
1009	13-Sep-2021	MYSURU	66	HV2	KR PETE_220	10:14	17:42	7:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1010	13-Sep-2021	MYSURU	220	KR PETE 220-TUBINAKERE	KRPET_220 AKKIHEBBAL_66 ANEGOLAL_66 BANANGADI_66 BOGADHI MANDYA_66 BOOKANAKERE_66 CHINAKURALI_66 G MALLIGERE_66 GANJIGERE_66 GUDDENAHALLI_66 HARIYALDAMMATAMPLE_6 6 JAKKANAHALLY_66 KIKKERI_66 KRISHNAPURA_66 KRPET_66 MADESWARAPURA_66 NAGAMANGALA_66 SANTHEBACHALLI_66 SHEELUNERE_66,	11:50	11:59	0:09	LINE FAULT
1011	13-Sep-2021	MYSURU	220	KR PETE 220-TUBINAKERE	KRPET_220 AKKIHEBBAL_66 ANEGOLAL_66 BANANGADI_66 BOGADHI MANDYA_66 BOOKANAKERE_66 CHINAKURALI_66 G MALLIGERE_66 GANJIGERE_66 GUDDENAHALLI_66 HARIYALDAMMATAMPLE_6 6 JAKKANAHALLY_66 KIKKERI_66 KRISHNAPURA_66 KRPET_66 MADESWARAPURA_66 NAGAMANGALA_66 SANTHEBACHALLI_66 SHEELUNERE_66,	12:04	12:08	0:03	LINE FAULT
1012	13-Sep-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YALANDUR_66	5:55	6:00	0:04	LINE FAULT
1013	13-Sep-2021	MYSURU	220	HV1	MADHUVANAHALLI_220	13:33	15:09	1:35	LINE CLEAR AVAILED
1014	13-Sep-2021	MYSURU	66	MEGALAPURA-HEBBANI	TUMBLA_66VYASARAJAPUR A_66 GARGESHWARI_66CHIDRAV ALLI_66 BG PURA_66	5:26	5:51	0:24	LINE FAULT
1015	13-Sep-2021	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	7:22	18:51	11:29	NFBC ISSUED
1016	13-Sep-2021	MYSURU	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	9:24 (3/9/2021)			LINE OPEN,LINE CLEAR AVAILED
1017	13-Sep-2021	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED
1018	13-Sep-2021	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	14:03 (18/8/2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1019	13-Sep-2021	MYSURU	66	KR NAGARA-MYSORE-1	NO STATIONS EFFECTED	20:02 18/08/2021)			LINE OPEN,LINE CLEAR AVAILED
1020	13-Sep-2021	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1021	13-Sep-2021	MYSURU	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	16:50 (13.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1022	13-Sep-2021	MYSURU	66	KR NAGARA-CHUNCHUNKATTE	NO STATIONS EFFECTED	16:41 (13.09.2021)			LINE OPEN,LINE CLEAR AVAILED
1023	13-Sep-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	10:29	14:58	4:29	LINE CLEAR AVAILED
1024	13-Sep-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	23:10	23:29	0:19	LINE FAULT
1025	13-Sep-2021	TUMKUR	220	TR-1	KIADB V N PURA_220	17:46	18:07	0:21	LINE CLEAR AVAILED
1026	13-Sep-2021	TUMKUR	220	TR-2	KIADB V N PURA_220	22:01	23:02	1:01	LINE CLEAR AVAILED
1027	13-Sep-2021	TUMKUR	220	NITTUR 220-NELAMANGALA	NITTUR_220	19:35	20:18	0:43	LINE CLEAR AVAILED
1028	13-Sep-2021	TUMKUR	66	TR-2	BALENAHALLI_66	12:38	12:50	0:12	TRANSFORMER FAULT
1029	13-Sep-2021	TUMKUR	66	TR-2	BALENAHALLI_66	13:01	13:10	0:09	TRANSFORMER FAULT
1030	13-Sep-2021	TUMKUR	66	TR-1	BHARAMAGIRI_66	15:01	15:08	0:07	TRANSFORMER FAULT
1031	13-Sep-2021	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66,SOKKE_66	18:09	18:22	0:12	LINE FAULT
1032	13-Sep-2021	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMU DRA_66	18:34	18:49	0:15	LINE FAULT
1033	13-Sep-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	7:13	7:25	0:11	MAIN SUPPLY FAILURE
1034	13-Sep-2021	TUMKUR	66	TR-1	HIRIYUR_66	13:13	13:30	0:17	LINE CLEAR AVAILED
1035	13-Sep-2021	TUMKUR	66	TR-2	HIRIYUR_66	12:04	12:41	0:36	LINE CLEAR AVAILED
1036	13-Sep-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	11:56	12:05	0:08	LINE FAULT
1037	13-Sep-2021	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	22:44	22:54	0:10	LINE FAULT
1038	13-Sep-2021	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	7:08	7:27	0:18	MAIN SUPPLY FAILURE
1039	13-Sep-2021	TUMKUR	66	TR-2	KOLALA_66	12:15	15:08	2:52	LINE CLEAR AVAILED
1040	13-Sep-2021	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	18:52	18:56	0:03	MAIN SUPPLY FAILURE
1041	13-Sep-2021	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	18:24	18:25	0:00	LINE FAULT
1042	13-Sep-2021	TUMKUR	66	KIADB V N PURA_220-TMTP_66	TMTP_66	10:43	18:11	7:28	LINE CLEAR AVAILED
1043	13-Sep-2021	TUMKUR	66	TR-1(LV-1)	KIADB V N PURA_220	17:43	18:42	0:59	LINE CLEAR AVAILED
1044	13-Sep-2021	TUMKUR	66	TR-2(LV SIDE)	KIADB V N PURA_220	19:32	22:01	2:29	LINE CLEAR AVAILED
1045	13-Sep-2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	13:37	16:34	2:57	LINE CLEAR AVAILED