400/220/110/66 kV TRANSMISSION OUTAGES FROM 05.07.22 to 11.07.22

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_at	Duration	REASON
1	5-Jul-22	BAGALKOT	110	VAJRAMATTI 220- LOKAPUR(IDLE LINE)	VAJRAMATTI_220	15:37	15:42	0:05	LINE FAULT
2	5-Jul-22	BAGALKOT	110	VAJRAMATTI 220- MELLIGERI	VAJRAMATTI_220	15:31	15:36	0:05	LINE FAULT
3	5-Jul-22	BAGALKOT	110	VAJRAMATTI 220- MUDHOL	VAJRAMATTI_220	15:42	15:45	0:03	LINE FAULT
4	5-Jul-22	BAGALKOT	110	VAJRAMATTI220 - BILAGI	VAJRAMATTI_220	14:53	15:03	0:10	LINE FAULT
5	5-Jul-22	BAGALKOT	110	VAJRAMATTI220 -VAJRAMATTI	VAJRAMATTI_220	14:26	14:37	0:11	HAND TRIPPED
6	5-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED BELGAUM_110	11:35	12:05	0:30	LINE CLEAR AVAILED
7	5-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HALIYAL_110	11:30 (04.07.2022)	11:00 (05.07.2022)	23:30 hrs	TRANSFORMER CHARGED
8	5-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HALIYAL_110	0:00	11:00	11:00	TRANSFORMER FAULT
9	5-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED JAMAKHANDI_110	16:17	18:36	2:19	LINE CLEAR AVAILED
10	5-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KUDACHI_220	6:37	6:41	0:04	TRANSFORMER FAULT
11	5-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED KULIGOD_110	15:08	19:03	3:55	LINE CLEAR AVAILED
12	5-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED MUDDEBIHAL_110	17:19	18:18	0:59	TRANSFORMER FAULT
13	5-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED UMMACHAGI_110	17:10	17:40	0:30	LINE CLEAR AVAILED
14	5-Jul-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED HALIYAL_110	21:23	21:30	0:07	TRANSFORMER FAULT
15	5-Jul-22	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	10:39	10:46	0:07	LINE CLEAR AVAILED
16	5-Jul-22	BAGALKOT	110	110/11KV,HV1	NAVANAGAR (H)	9:52	14:41	4:49	TRANSFORMER FAULT
17	5-Jul-22	BAGALKOT	110	110/11KV,HV1	SIRSI_220	16:30	18:12	1:42	LINE CLEAR AVAILED
18	5-Jul-22	BAGALKOT	110	110/33KV, HV1	STATION NOT AFFECTED JAMAKHANDI_110	6:15	10:31	4:16	LINE CLEAR AVAILED
19	5-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
20	5-Jul-22	BAGALKOT	110	110/33KV,HV3	NANDI KURALI_33 ANKALI_110	16:04	16:31	0:27	LINE CLEAR AVAILED
21	5-Jul-22	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	7:04	7:24	0:20	LINE FAULT
22	5-Jul-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
23	5-Jul-22	BAGALKOT	110	ANKOLA-ARGA	ANKOLA_110	6:53	6:56	0:03	MAIN SUPPLY FAILURE
24	5-Jul-22	BAGALKOT	110	ANMOD-GOA-2	ANMOD_110	23:14 (05.07.2022)			LINE OPEN:LINE FAULT
25	5-Jul-22	BAGALKOT	110	ANMOD-GOA-2	STATION NOT AFFECTED ANMOD_110	19:35	21:00	1:25	LINE FAULT
26	5-Jul-22	BAGALKOT	110	BELGAUM110-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED
27	5-Jul-22	BAGALKOT	110	BELLATTI-AB-SLR	BELLATTI_110	0:55	1:16	0:21	HAND TRIPPED
28	5-Jul-22	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	0:55	1:15	0:20	HAND TRIPPED
29	5-Jul-22	BAGALKOT	110	HIDIKAL DAM-ANKALAGI	STATION NOT AFFECTED ANKOLA_110	6:10	6:17	0:07	LINE FAULT
30	5-Jul-22	BAGALKOT	110	HUNGUND-BAGEWADI(KUDAL SANGAM)	KUDAL SANGAM_110	5:30	5:41	0:11	LINE FAULT

31	5-Jul-22	BAGALKOT	110	KARWAR-ARGA	ARGA_110	6:53	6:56	0:03	MAIN SUPPLY FAILURE
32	5-Jul-22	BAGALKOT	110	KUMTA-SIRSI-1	STATION NOT AFFECTED KUMTA_110	12:19	12:26	0:07	HAND TRIPPED
33	5-Jul-22	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	0:51	1:12	0:21	LINE FAULT
34	5-Jul-22	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	0:50	1:11	0:21	LINE FAULT
35	5-Jul-22	BAGALKOT	110	NARENDRA220-BELUR1	NARENDRA_220	4:48	7:11	2:23	LINE FAULT
36	5-Jul-22	BAGALKOT	110	NARENDRA220-BELUR2	NARENDRA_220	4:48	7:12	2:24	LINE FAULT
37	5-Jul-22	BAGALKOT	110	NARENDRA220-KU DHARWAD	STATION NOT AFFECTED KU DHARWAD_110	5:48	21:01	15:13	LINE CLEAR AVAILED
38	5-Jul-22	BAGALKOT	110	NARENDRA220-KUD1	NARENDRA_220	4:48	20:37	15:49	LINE FAULT
39	5-Jul-22	BAGALKOT	110	NARENDRA220-Mrithjayngr2	NARENDRA_220	4:48	20:39	15:51	LINE FAULT
40	5-Jul-22	BAGALKOT	110	NARENDRA220-MRUTYUNJAYNAGAR-1	STATION NOT AFFECTED MRUTYUNJAYNAGAR_110	4:51	20:35	15:44	LINE CLEAR AVAILED
41	5-Jul-22	BAGALKOT	110	NARENDRA220-MRUTYUNJAYNAGAR-2	STATION NOT AFFECTED MRUTYUNJAYNAGAR_110	4:51	5:13	0:22	HAND TRIPPED
42	5-Jul-22	BAGALKOT	110	NARENDRA-GARAG	STATION NOT AFFECTED GARAG_110	4:50	7:05	2:15	LINE CLEAR AVAILED
43	5-Jul-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
44	5-Jul-22	BAGALKOT	110	SAVANU-ASF CBreaker	SAVANUR_110	19:58	20:13	0:15	LINE FAULT
45	5-Jul-22	BAGALKOT	110	TADASINAKOPPA-KUD DHARWAD (NARENDRA)	TADASINAKOPPA_110	4:48	23:01	18:13	MAIN SUPPLY FAILURE
46	5-Jul-22	BAGALKOT	110	TADASINAKOPPA-TARIHAL (GHAMANAGHATTI)	TADASINAKOPPA_110	5:11	23:00	17:49	MAIN SUPPLY FAILURE
47	5-Jul-22	BAGALKOT	110	UAS-F1CBreaker(NARENDRA)	UAS DHARWAD_110	5:12	20:44	15:32	LINE CLEAR AVAILED
48	5-Jul-22	BAGALKOT	220	VAJRAMATTI - KUDAGI 1	VAJRAMATTI_220	17:17	19:19	2:02	LINE CLEAR AVAILED
49	5-Jul-22	BAGALKOT	220	220/110KV,HV1	NARENDRA_220	4:48	20:16	15:28	TRANSFORMER FAULT
50	5-Jul-22	BAGALKOT	220	220/110KV,HV1,LV1	AHERI_220	12:35	17:11	4:36	LINE CLEAR AVAILED
51	5-Jul-22	BAGALKOT	220	220/110KV,HV1,LV1	AHERI_220	18:57	19:11	0:14	TRANSFORMER FAULT
52	5-Jul-22	BAGALKOT	220	220/110KV,HV1,LV2	AHERI_220	19:20	20:17	0:57	LINE CLEAR AVAILED
53	5-Jul-22	BAGALKOT	220	220/110KV,HV2	NARENDRA_220	4:58	20:23	15:25	TRANSFORMER FAULT
54	5-Jul-22	BAGALKOT	220	220/110KV,LV2	NARENDRA_220	4:58	20:24	15:26	TRANSFORMER FAULT
55	5-Jul-22	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	19:58 (05.07.2022)			LINE OPEN:LINE FAULT
56	5-Jul-22	BAGALKOT	220	DHONI-LINGAPUR-1	STATION NOT AFFECTED DHONI_400	7:11 (05.07.2022)			LINE OPEN:LINE CLEAR AVAILED
57	5-Jul-22	BAGALKOT	220	DHONI-LINGAPUR-2	STATION NOT AFFECTED DHONI_400	7:09 (05.07.2022)			LINE OPEN:LINE CLEAR AVAILED
58	5-Jul-22	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI_220	19:58 (05.07.2022)			LINE OPEN:LINE FAULT
59	5-Jul-22	BAGALKOT	220	KUDACHI-CHIKKODI-1	STATION NOT AFFECTED KUDACHI_220	5:45	5:55	0:10	LINE FAULT
60	5-Jul-22	BAGALKOT	220	NARENDRA-AMBEWADI 1 &2	NARENDRA_220	4:48	20:05	15:17	LINE FAULT
61	5-Jul-22	BAGALKOT	220	NARENDRA-HAVERI	NARENDRA_220	4:48	20:14	15:26	LINE FAULT
62	5-Jul-22	BAGALKOT	220	NARENDRA-HUBLI1 & 2	NARENDRA_220	4:48	20:06	15:18	LINE FAULT
63	5-Jul-22	BAGALKOT	220	NARENDRA-KNBRG1 & 2	NARENDRA_220	4:48	20:08	15:20	LINE FAULT
64	5-Jul-22	Bagalkot	220	SHVTY1-SIRSI	SIRSI_220	9:47	16:14	6:27	LINE CLEAR AVAILED
65	5-Jul-22	BAGALKOT	220	SIRSI220-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:54 (23.06.2022)	6:20 (05.07.2022)	278:26 hrs	LINE CHARGED

66	5-Jul-22	BAGALKOT	220	SIRSI220-HUBLI2	STATION NOT AFFECTED	15:54	6:20	278:26 hrs	LINE CHARGED
					SIRSI_220 STATION NOT AFFECTED	(23.06.2022)	(05.07.2022)		
67	5-Jul-22	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	6:42	10:23	3:41	LINE CLEAR AVAILED
68	5-Jul-22	BENGALURU	66	BANGARPETE - KOLAR 220	BANGARPETE	18:45	18:50	0:05	LOAD CHANGE OVER
69	5-Jul-22	BENGALURU	66	BANGARPETE - MALUR 220	BANGARPETE	14:25	14:30	0:05	LOAD CHANGE OVER
70	5-Jul-22	BENGALURU	66	HV1	CHATRA	12:15	13:30	1:15	TRANSFORMER FAULT
71	5-Jul-22	BENGALURU	66	HV1	CHATRA	19:15	19:35	0:20	TRANSFORMER FAULT
72	5-Jul-22	BENGALURU	66	HV1	CHATRA	22:40	22:45	0:05	TRANSFORMER FAULT
73	5-Jul-22	BENGALURU	66	HV1	JAKKASANDRA	13:05	14:03	0:58	LINE CLEAR AVAILED
74	5-Jul-22	BENGALURU	66	HV1	TK HALLI 220	11:02	11:06	0:04	TRANSFORMER FAULT
75	5-Jul-22	BENGALURU	66	HV1	VANDARGUPPE	10:55	11:35	0:40	LINE CLEAR AVAILED
76	5-Jul-22	BENGALURU	66	HV2	AMAR JYOTHI	11:37	11:47	0:10	LOAD CHANGE OVER
77	5-Jul-22	BENGALURU	66	HV2	AMAR JYOTHI	14:45	14:57	0:12	LOAD CHANGE OVER
78	5-Jul-22	BENGALURU	66	HV2	CHANDAPURA	16:20	16:55	0:35	LINE CLEAR AVAILED
79	5-Jul-22	BENGALURU	66	HV2	MAASTHI	22:05	22:49	0:44	TRANSFORMER FAULT
80	5-Jul-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	13:35	13:39	0:04	LINE CLEAR AVAILED
81	5-Jul-22	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	12:59	13:26	0:27	LINE FAULT
82	5-Jul-22	GULBARGA	66	BENNEHALLI-ITTAGGI	BENNEHALLI_66,KOTTUR_66	5:40	5:57	0:17	LINE FAULT
83	5-Jul-22	GULBARGA	66	HV1&HV2	GUDEKOTE_66	17:10	17:25	0:15	LINE CLEAR AVAILED
84	5-Jul-22	GULBARGA	66	HV2	PUNABGHATA_66	14:10	14:15	0:05	TRANSFORMER FAULT
85	5-Jul-22	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66, KOTTUR_66, UJJAINI_66	5:39	5:44	0:05	LINE FAULT
86	5-Jul-22	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJ AINI_66	13:20	13:25	0:05	LINE FAULT
87	5-Jul-22	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJ AINI_66	15:35	15:45	0:10	LINE FAULT
88	5-Jul-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	ADAVI AMRESHWAR_110	1:53	2:18	0:25	MAIN SUPPLY FAILURE
89	5-Jul-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110	4:55	5:00	0:05	MAIN SUPPLY FAILURE
90	5-Jul-22	GULBARGA	110	HATTI-SOMANAMARDI	HATTI_110	8:36	18:17	9:41	LINE CLEAR AVAILED
91	5-Jul-22	GULBARGA	110	HV1	GANDHINAGAR_110	12:15	12:40	0:25	LINE CLEAR AVAILED
92	5-Jul-22	GULBARGA	110	HV1	GULBARGA UNIVERCITY_110	7:25	7:30	0:05	TRANSFORMER FAULT
93	5-Jul-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	0:24	0:36	0:12	LINE FAULT
94	5-Jul-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	2:48	3:01	0:13	LINE FAULT
95	5-Jul-22	GULBARGA	110	MARGUTTI-KAPNOOR	MARGUTTI_110	12:12	13:58	1:46	NFBC ISSUED

96	5-Jul-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	21:20	21:30	0:10	LINE FAULT
97	5-Jul-22	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	20:50	21:30	0:40	LINE FAULT
98	5-Jul-22	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	19:10	19:15	0:05	LINE FAULT
99	5-Jul-22	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	20:45	20:55	0:10	LINE FAULT
100	5-Jul-22	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	21:10	21:40	0:30	LINE FAULT
101	5-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	18:42	18:46	0:35	LINE FAULT
102	5-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
103	5-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
104	5-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
105	5-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	1:12	1:17	0:05	LINE FAULT
106	5-Jul-22	GULBARGA	110	SINDANOOR-MUNIRABADII	MUKUNDA_110,KAMPLI_110,YERDONA_ 110,SRNAGAR_110,MALLAPURA_110	1:45	1:55	0:10	LINE FAULT
107	5-Jul-22	GULBARGA	110	YAKATAPUR-KAMTHANA	YAKATAPUR_110	0:05	0:20	0:15	MAIN SUPPLY FAILURE
108	5-Jul-22	GULBARGA	110	YEREDONA-SINDHANOOR	YEREDONA_110	1:45	1:55	0:10	MAIN SUPPLY FAILURE
109	5-Jul-22	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12	10:15	3:03	LINE CLEAR AVAILED
110	5-Jul-22	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45	10:15	2:30	LINE CLEAR AVAILED
111	5-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
112	5-Jul-22	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	13:34	14:10	0:36	LINE FAULT
113	5-Jul-22	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_66	13:38	13:48	0:10	LINE FAULT
114	5-Jul-22	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	10:20	11:11	0:51	MAIN SUPPLY FAILURE
115	5-Jul-22	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	10:18	19:34	9:16	LINE CLEAR AVAILED
116	5-Jul-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	10:19	19:34	9:15	LINE CLEAR AVAILED
117	5-Jul-22	HASSAN	66	HV1	DODDAHALLY_66	10:23	11:31	1:08	MAIN SUPPLY FAILURE
118	5-Jul-22	HASSAN	66	HV1	DODDAHALLY_66	19:26	19:43	0:17	HAND TRIPPED
119	5-Jul-22	HASSAN	66	HV1	DODDAKADANUR_66	10:31	11:28	0:57	MAIN SUPPLY FAILURE
120	5-Jul-22	HASSAN	66	HV1	SALAGAME_66	11:47	14:16	2:29	LINE CLEAR AVAILED
121	5-Jul-22	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
122	5-Jul-22	HASSAN	66	HV1	NAGARTHI_66	10:19	19:35	9:16	MAIN SUPPLY FAILURE
123	5-Jul-22	HASSAN	66	HV2	CHANNARAYAPATNA_66	15:43	16:18	0:35	LINE CLEAR AVAILED
124	5-Jul-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
125	5-Jul-22	HASSAN	66	HV2	SALAGAME_66	11:47	14:16	2:29	LINE CLEAR AVAILED
126	5-Jul-22	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	0:44	1:14	0:30	LINE FAULT
127	5-Jul-22	HASSAN	66	NGRTHI-L1	NAGARTHI_66	10:19	19:35	9:16	MAIN SUPPLY FAILURE
128	5-Jul-22	HASSAN	66	NGRTHI-L2	NAGARTHI_66	10:19	19:35	9:16	MAIN SUPPLY FAILURE
129	5-Jul-22	HASSAN	66	SAKALE-HASSAN2	SAKLESHPURA_66	13:35	14:05	0:30	LINE FAULT
130	5-Jul-22	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	10:45	12:55	2:10	LINE CLEAR AVAILED
131	5-Jul-22	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	11:50	14:13	2:23	LINE CLEAR AVAILED
132	5-Jul-22	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	11:50	14:15	2:25	LINE CLEAR AVAILED
133	5-Jul-22	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	12:00	14:13	2:13	LINE CLEAR AVAILED
134	5-Jul-22	HASSAN	110	HV1	HOSANGADI_110	17:17	18:40	1:23	TRANSFORMER FAULT
	-			•	•				•

				1					
135	5-Jul-22	HASSAN	110	HV2	BAIKAMPADY_110	15:11	15:15	0:04	TRANSFORMER FAULT
136	5-Jul-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
137	5-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
138	5-Jul-22	HASSAN	110	LV2	SHIRALKOPPA_220	8:22	13:20	4:58	LINE CLEAR AVAILED
139	5-Jul-22	HASSAN	220	HV2	SHIRALKOPPA_220	8:22	13:20	4:58	LINE CLEAR AVAILED
140	5-Jul-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	12:06	17:46	5:40	LINE FAULT
141	5-Jul-22	HASSAN	220	SHRAVTY-SHIMOGA4	sharavthy_gen	12:05	17:45	5:40	LINE FAULT
142	5-Jul-22	HASSAN	220	SHRAVTY-SIRISI 2	sharavthy_gen	3:11(05.07.2022)			LINE OPEN:LINE CLEAR AVAILED
143	5-Jul-22	MYSURU	66	AJJIPURA-COWDALLI	COWDALLI_66 RAMAPURA_MYS_66MARTAHALLI_66	7:00	7:05	0:05	LINE FAULT
144	5-Jul-22	MYSURU	66	BG PURA-HEBBANI	PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66BGPURA_66	11:55	12:20	0:25	LINE CLEAR AVAILED
145	5-Jul-22	MYSURU	66	DEVNUR(MYS)-RAJEEV NAGARA	NO STATIONS EFFECTED	10:22	18:43	8:20	LINE CLEAR AVAILED
146	5-Jul-22	MYSURU	66	DK MAIDANA-VAJAMANGALA	NO STATIONS EFFECTED	10:36	19:14	8:37	LINE CLEAR AVAILED
147	5-Jul-22	MYSURU	66	DR PETE-CR NAGARA 2	NO STATIONS EFFECTED	11:15	15:15	3:59	LINE CLEAR AVAILED
148	5-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
149	5-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
150	5-Jul-22	MYSURU	66	HV1	HALGUR_66	12:15	13:30	1:15	LINE CLEAR AVAILED
151	5-Jul-22	MYSURU	66	HV2	BYLUKUPPE_66	12:15	12:30	0:15	LINE CLEAR AVAILED
152	5-Jul-22	MYSURU	66	HV2	HALGUR_66	10:00	11:55	1:55	LINE CLEAR AVAILED
153	5-Jul-22	MYSURU	66	HV2	METAGALLI_66	7:23	7:33	0:09	TRANSFORMER FAULT
154	5-Jul-22	MYSURU	66	KHB-BILIKERE	DMG_HALLI_66KHBCOLONY_66	10:17	17:05	6:48	LINE CLEAR AVAILED
155	5-Jul-22	MYSURU	66	KHB-HOOTAGALLI	NO STATIONS EFFECTED	10:29	16:38	6:09	LINE CLEAR AVAILED
156	5-Jul-22	MYSURU	66	KUSHALANAGARA-SUNTIKOPPA	MADIKERI_66SUNTIKOPPA_66	10:08	13:58	3:50	LINE CLEAR AVAILED
157	5-Jul-22	MYSURU	66	KUSHALNAGARA-MERCERA	NO STATIONS EFFECTED	22:09:00 (4.7.2022)	13:58:00 (5.7.2022)	15:49 hrs	LINE CHARGED
158	5-Jul-22	MYSURU	66	MANDGERE-H N PURA	MANDGERE_66	10:20	19:35	9:15	MAIN SUPPLY FAILURE
159	5-Jul-22	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66PONNAMPET_66VIRAJPE T_66	11:09	11:17	0:07	LINE FAULT
160	5-Jul-22	MYSURU	66	VAJAMANGALA-DEVANUR MYSORE	DEVANOORMYS_66	10:24	18:36	8:12	LINE CLEAR AVAILED
161	5-Jul-22	MYSURU	66	VAJAMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	18:55	19:00	0:05	LINE FAULT
162	5-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
163	5-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	13:15	13:25	0:10	MAIN SUPPLY FAILURE
164	5-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	15:40	15:45	0:05	MAIN SUPPLY FAILURE
165	5-Jul-22	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	16:26	18:35	2:09	LINE CLEAR AVAILED
166	5-Jul-22	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	19:11	19:28	0:16	LINE FAULT
167	5-Jul-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	16:18	16:22	0:04	LINE FAULT
168	5-Jul-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	2:15	2:20	0:05	LINE FAULT
169	5-Jul-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	4:20	4:30	0:10	LINE FAULT

	170	5-Jul-22	TUMKUR	66	HONNALLI 220kV-	DEVARAHALLI_66, LINGADAHALLI_66,	5:36	5:47	0:11	LINE FAULT
172	170	3 34. 22	1011111011		CHANNAGIRI(NALLUR)	NALLUR_66, GOPPENAHALLI_66	5.50	5	0.11	
127 5-10-22 TUMBUR 66 MONANDEZ 2000- NAVAMORI 5000	171	5-Jul-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI		1:28	1:39	0:11	LINE FAULT
174 S. Jul 22 TUMKUR 66 MSARCHER MORSHAME MSARCHER MORS 12:38 0	172	5-Jul-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI		6:02	6:23	0:21	LINE FAULT
177 5.JU-122 TUMKUR 66 JAVAGONDANAHALLI BEVINAHAUL JAVAGONDANAHALLI 68 7.11 7.31 0.20 UNE FAULT	173	5-Jul-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI		14:04	14:19	0:15	LINE FAULT
1776	174	5-Jul-22	TUMKUR	66	HOSAKRE66-MEDIGESHI66	HOSAKRE_66	12:30	12:38	0:08	LINE FAULT
177 S. Jul 22 TUMKUR 66 PATTNAYAKANAHALU C REFEIL CERTELS PROTE 65 11:20 12:10 0.50 UNE FAULT 178 S. Jul 22 TUMKUR 66 PATTNAYAKANAHALU 66 11:20 12:10 0.50 UNE FAULT 179 S. Jul 22 TUMKUR 66 POKOTE AZURE SOLAR AZURE SOLAR AZURE SOLAR AZURE SOLAR 10:02 18:49 8:46 UNE FAULT 18:03 S. Jul 22 TUMKUR 66 POKOTE AZURE SOLAR AZURE SOLAR 10:02 18:49 8:46 UNE FAULT 18:03 S. Jul 22 TUMKUR 66 POKOTE AZURE SOLAR AZURE SOLAR 10:02 18:49 8:46 UNE FAULT 18:04 S. Jul 22 TUMKUR 66 POKOTE AZURE SOLAR AZURE SOLAR 10:02 18:49 8:46 UNE FAULT 18:04 S. Jul 22 TUMKUR 66 POKOTE AZURE SOLAR S. Jul 22 TUMKUR 66 TR. 1 S. SALUHALLA 66 T. S. S. Jul 22 TUMKUR 66 TR. 1 S. SALUHALLA 66 T. S. S. S. Jul 22 TUMKUR 66 TR. 1 S. SALUHALLA 66 TR. 1 S. S. S. Jul 22 TUMKUR 66 TR. 1 S. SALUHALLA 66 TR. 1 S. S. Jul 22 TUMKUR 66 TR. 1 S. SALUHALLA 66 TR. 2 S. JUL 22 TUMKUR 66 TR	175	5-Jul-22	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	7:11	7:31	0:20	LINE FAULT
170 170	176	5-Jul-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	14:26	14:30	0:04	LINE FAULT
178 5-Jul-22 TUMKUR 66 POKOTE-AZUR SOLAR AZURE SOLAR LICAR SOLAR S	177	5-Jul-22	TUMKUR	66	PATTNAYAKANAHALLI-C B KERE(L2)		11:20	12:10	0:50	LINE FAULT
180 5-Jul-22 TUMKUR 66 POKOTE-CLEAR SOLAR CLEAR SOLAR 10:02 18:47 8:44 LINE FAULT	178	5-Jul-22	TUMKUR	66		PATTNAYAKANAHALLI_66	11:20	12:10	0:50	LINE FAULT
181 5-Jul-22 TUMKUR 66 POKOTE-SALOTOR SOLAR SOLITAIR SOLAR 10.02 18-88 8-45 UNE FAULT	179	5-Jul-22	TUMKUR	66	PDKOTE-AZURE SOLAR	AZURE SOLAR_66	10:02	18:49	8:46	LINE FAULT
182 S-Jul-22 TUMKUR 66 PINOTE-SALOTOR SOLAR SOLITAINE SOLAR 10.02 18.48 8.45 LINE FAULT 183 S-Jul-22 TUMKUR 66 SIRA-KALLAMBELIA KALLAMBELIA KALLAMBELIA 6 7.09 7.18 0.08 LINE FAULT 184 S-Jul-22 TUMKUR 66 TR1 BHARAMAGIRI. 66 1.50 1.52 0.01 TRANSFORMER FAULT 185 S-Jul-22 TUMKUR 66 TR1 SASALIHALIA. 66 13.00[28.06.2022) TRANSFORMER OPENTRANSFORMER FAULT 186 S-Jul-22 TUMKUR 66 TR-1 PATNAYAKANAHALI. 66 11.20 11.20 0.50 LINE CLEAR AVAILED 187 S-Jul-22 TUMKUR 66 TR-1 POROTE_66 10.08 18.36 8.27 LINE CLEAR AVAILED 188 S-Jul-22 TUMKUR 66 TR-1 POROTE_66 10.08 18.36 8.27 LINE CLEAR AVAILED 188 S-Jul-22 TUMKUR 66 TR-1 POROTE_66 10.08 18.36 8.27 LINE CLEAR AVAILED 189 S-Jul-22 TUMKUR 66 TR-2 BHARAMAGIRI. 66 6.34 6.34 0.05 TRANSFORMER FAULT 190 S-Jul-22 TUMKUR 66 TR-2 BHARAMAGIRI. 66 6.34 6.30 0.07 TRANSFORMER FAULT 191 S-Jul-22 TUMKUR 66 TR-2 CHANNAGIRI. 66 6.62 6.23 6.30 0.07 TRANSFORMER FAULT 191 S-Jul-22 TUMKUR 66 TR-2 CHANNAGIRI. 66 10.08 18.36 8.27 LINE CLEAR AVAILED 192 S-Jul-22 TUMKUR 66 TR-2 CHANNAGIRI. 66 10.00 10.45 0.15 LINE CLEAR AVAILED 193 S-Jul-22 TUMKUR 66 TR-2 CHANNAGIRI. 66 10.00 18.36 8.27 LINE CLEAR AVAILED 194 S-Jul-22 TUMKUR 66 TR-2 CHANNAGIRI. 66 10.00 18.36 8.27 LINE CLEAR AVAILED 194 S-Jul-22 TUMKUR 10 TR-2 SAMPIGE_110 10.00 18.35 8.27 LINE CLEAR AVAILED 195 S-Jul-22 TUMKUR 10 TR-2 SAMPIGE_110 10.00 18.35 15.54 LINE CLEAR AVAILED 195 S-Jul-22 TUMKUR 10 TR-2 SAMPIGE_110 10.00 18.35 15.54 LINE CLEAR AVAILED 195 S-Jul-22 BAGALKOT 110 110/11KV, HV1 MUDELBRA LINE CLEAR AVAILED 196 S-Jul-22 BAGALKOT 110 110/11KV, HV2 MUDELBRA LIND 110 11.00 11.00 11.00 11.00 11.00 11.00 11.00	180	5-Jul-22	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	10:02	18:47	8:44	LINE FAULT
183 5-Jul-22 TUMKUR 66 SRA - KALLAMBELLA KALLAMBELLA 66 7.09 7.18 0.08 UNE FAULT	181	5-Jul-22	TUMKUR	66	PDKOTE-HARIYABBE	PDKOTE_66	10:08	18:35	8:26	LINE FAULT
184 S-Jul-22 TUMKUR 66 TR1	182	5-Jul-22	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	10:02	18:48	8:45	LINE FAULT
TRANSFORMER OPEN:TRANSFORMER TRANSFORMER	183	5-Jul-22	TUMKUR	66	SIRA - KALLAMBELLA	KALLAMBELLA_66	7:09	7:18	0:08	LINE FAULT
185 5-Jul-22 TUMKUR 66 TR-1	184	5-Jul-22	TUMKUR	66	TR1	BHARAMAGIRI_66	1:50	1:52	0:01	TRANSFORMER FAULT
187 S-Jul-22 TUMKUR 66 TR-1	185	5-Jul-22	TUMKUR	66	TR1	SASALUHALLA_66	13:00(28.06.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
188 5-Jul-22 TUMKUR 66 TR-1(LV SIDE) DAVANGERE_SRS_220 16:16 19:12 2:56 LINE CLEAR AVAILED 189 5-Jul-22 TUMKUR 66 TR-2 BHARAMAGIR_66 6:34 6:40 0:05 TRANSFORMER FAULT 190 5-Jul-22 TUMKUR 66 TR-2 CHANNAGIR_66 6:23 6:30 0:07 TRANSFORMER FAULT 191 5-Jul-22 TUMKUR 66 TR-2 CHANNAGIR_66 10:30 10:45 0:15 LINE CLEAR AVAILED 192 5-Jul-22 TUMKUR 66 TR-2 CHANNAGIR_66 10:30 10:45 0:15 LINE CLEAR AVAILED 193 5-Jul-22 TUMKUR 66 TR-2 PDKOTE_66 10:08 18:36 8:27 LINE CLEAR AVAILED 194 5-Jul-22 TUMKUR 66 TR-2 MALEBENNUR_66 15:58 16:04 0:05 TRANSFORMER FAULT 194 5-Jul-22 TUMKUR 110 TR2 SAMPIGE_110 10:02 14:37 4:34 LINE CLEAR AVAILED 1 6-Jul-22 BAGALKOT 110 110/11KV,HV1 STATION NOT AFFECTED BABALESHWAR_110 16:01 16:08 0:07 HAND TRIPPED 2 6-Jul-22 BAGALKOT 110 110/11KV,HV1 HIREKERUR_110 11:06 11:16 0:10 TRANSFORMER FAULT 3 6-Jul-22 BAGALKOT 110 110/11KV,HV1 SIRS_1 10 18:51 18:57 0:06 LINE CLEAR AVAILED 4 6-Jul-22 BAGALKOT 110 110/11KV,HV1 MIDDEBIHAL_110 16:30 17:01 0:31 HAND TRIPPED 4 6-Jul-22 BAGALKOT 110 110/11KV,HV1 MIDDEBIHAL_110 10:05 19:18 9:13 LINE CLEAR AVAILED 5 6-Jul-22 BAGALKOT 110 110/11KV,HV3 JAMAKHANDI_110 10:05 19:18 9:13 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 JAMAKHANDI_110 10:05 19:13 9:08 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:00 18:07 0:07 HAND TRIPPED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:00 18:07 0:07 HAND TRIPPED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18	186	5-Jul-22	TUMKUR	66	TR-1	PATNAYAKANAHALLI_66	11:20	12:10	0:50	LINE CLEAR AVAILED
189 5-Jul-22 TUMKUR 66 TR2 BHARAMAGIRI_66 6:34 6:40 0.05 TRANSFORMER FAULT	187	5-Jul-22	TUMKUR	66	TR-1	PDKOTE_66	10:08	18:36	8:27	LINE CLEAR AVAILED
190 5-Jul-22 TUMKUR 66 TR-2 CHANNAGIRI 66 6:23 6:30 0:07 TRANSFORMER FAULT 191 5-Jul-22 TUMKUR 66 TR-2 CHANNAGIRI 66 10:30 10:45 0:15 LINE CLEAR AVAILED 192 5-Jul-22 TUMKUR 66 TR-2 PDKOTE 66 10:08 18:36 8:27 LINE CLEAR AVAILED 193 5-Jul-22 TUMKUR 66 TR-2 MALEBENNUR 66 15:58 16:04 0:05 TRANSFORMER FAULT 194 5-Jul-22 TUMKUR 110 TR2 SAMPIGE 110 10:02 14:37 4:34 LINE CLEAR AVAILED 1 6-Jul-22 BAGALKOT 110 110/11KV, HV2 BABALESHWAR 110 16:01 16:08 0:07 HAND TRIPPED 2 6-Jul-22 BAGALKOT 110 110/11KV, HV1 HIREKERUR 110 11:06 11:16 0:10 TRANSFORMER FAULT 3 6-Jul-22 BAGALKOT 110 110/11KV, HV1 SIRSI 110 18:51 18:57 0:06 LINE CLEAR AVAILED 4 6-Jul-22 BAGALKOT 110 110/11KV, HV2 MUDDEBIHAL 110 16:30 17:01 0:31 HAND TRIPPED 5 6-Jul-22 BAGALKOT 110 110/11KV, HV2 JAMAKHANDI 110 10:05 19:18 9:13 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV, HV3 JAMAKHANDI 110 10:05 19:13 9:08 LINE CLEAR AVAILED 7 6-Jul-22 BAGALKOT 110 110/11KV, HV3 SAVALAGI 110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV, HV3 SAVALAGI 110 18:20 TRANSFORMER FAULT 9 6-Jul-22 BAGALKOT 110 110/13KV, HV3 SAVALAGI 110 18:20 TRANSFORMER FAULT 9 6-Jul-22 BAGALKOT 110 110/13KV, HV3 SAVALAGI 110 18:20 TRANSFORMER FAULT 10 6-Jul-22 BAGALKOT 110 110/33KV, HV3 SAVALAGI 110 18:20 TRANSFORMER FAULT 10 6-Jul-22 BAGALKOT 110 110/33KV, HV3 SAVALAGI 110 10:05 19:23 9:18 LINE CLEAR AVAILED 10 6-Jul-22 BAGALKOT 110 110/33KV, HV3 SAVALAGI 110 10:05 19:23 9:18 LINE CLEAR AVAILED 10 6-Jul-22 BAGALKOT 110 110/33KV, HV3 SAVALAGI 110 10:05 19:23 9:18 LINE CLEAR AVAILED 10 6-Jul-22 BAGALKOT 110 110/33KV, HV3 SAVALAGI 110 10:05 19:23 9:18 LINE CL	188	5-Jul-22	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	16:16	19:12	2:56	LINE CLEAR AVAILED
191 5-Jul-22 TUMKUR 66 TR-2 CHANNAGIRI 66 10:30 10:45 0:15 LINE CLEAR AVAILED	189	5-Jul-22	TUMKUR	66	TR2	BHARAMAGIRI_66	6:34	6:40	0:05	TRANSFORMER FAULT
192 5-Jul-22 TUMKUR 66 TR-2 PDKOTE_66 10:08 18:36 8:27 LINE CLEAR AVAILED 193 5-Jul-22 TUMKUR 66 TR-2 MALEBENNUR_66 15:58 16:04 0:05 TRANSFORMER FAULT 194 5-Jul-22 TUMKUR 110 TR2 SAMPIGE_110 10:02 14:37 4:34 LINE CLEAR AVAILED 1 6-Jul-22 BAGALKOT 110 110/11KV, HV2 STATION NOT AFFECTED BABALESHWAR_110 16:01 16:08 0:07 HAND TRIPPED 2 6-Jul-22 BAGALKOT 110 110/11KV, HV1 HIREKERUR_110 11:06 11:16 0:10 TRANSFORMER FAULT 3 6-Jul-22 BAGALKOT 110 110/11KV, HV1 SIRS_110 18:51 18:57 0:06 LINE CLEAR AVAILED 4 6-Jul-22 BAGALKOT 110 110/11KV, HV2 MUDDEBIHAL_110 16:30 17:01 0:31 HAND TRIPPED 5 6-Jul-22 BAGALKOT 110 110/11KV, HV2 MUDDEBIHAL_110 10:05 19:18 9:13 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV, HV3 JAMAKHANDI_110 10:05 19:13 9:08 LINE CLEAR AVAILED 7 6-Jul-22 BAGALKOT 110 110/11KV, HV3 SAVALAG_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV, HV3 SAVALAG_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/13KV, HV3 STATION NOT AFFECTED 18:20 TRANSFORMER FAULT TRANSFORMER FAULT TRANSFORMER FAULT TRANSFORMER FAULT TRANSFORMER OPEN:TRANSFORMER FAULT 10 6-Jul-22 BAGALKOT 110 110/33KV, HV3 STATION NOT AFFECTED 18:20 TRANSFORMER FAULT TRANSFORMER FAU	190	5-Jul-22	TUMKUR	66	TR-2	CHANNAGIRI_66	6:23	6:30	0:07	TRANSFORMER FAULT
193 5-Jul-22 TUMKUR 66 TR-2 MALEBENNUR_66 15:58 16:04 0:05 TRANSFORMER FAULT 194 5-Jul-22 TUMKUR 110 TR2 SAMPIGE_110 10:02 14:37 4:34 LINE CLEAR AVAILED 1 6-Jul-22 BAGALKOT 110 110/11KV, HV2 STATION NOT AFFECTED BABALESHWAR_110 16:08 0:07 HAND TRIPPED 2 6-Jul-22 BAGALKOT 110 110/11KV,HV1 HIREKERUR_110 11:06 11:16 0:10 TRANSFORMER FAULT 3 6-Jul-22 BAGALKOT 110 110/11KV,HV1 SIRSI_110 18:51 18:57 0:06 LINE CLEAR AVAILED 4 6-Jul-22 BAGALKOT 110 110/11KV,HV2 MUDDEBIHAL_110 16:30 17:01 0:31 HAND TRIPPED 5 6-Jul-22 BAGALKOT 110 110/11KV,HV2 JAMAKHANDI_110 10:05 19:18 9:13 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 JAMAKHANDI_110 10:05 19:13 9:08 LINE CLEAR AVAILED 7 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/31KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/31KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/33KV,HV3 STATION NOT AFFECTED 18:20 TRANSFORMER OPEN:TRANSFORMER FAULT TRANSFORMER OPEN:TRANSFORMER FAULT 10:05 19:23 9:18 LINE CLEAR AVAILED	191	5-Jul-22	TUMKUR	66	TR-2	CHANNAGIRI_66	10:30	10:45	0:15	LINE CLEAR AVAILED
194 5-Jul-22 TUMKUR 110 TR2 SAMPIGE_110 10:02 14:37 4:34 LINE CLEAR AVAILED	192	5-Jul-22	TUMKUR	66	TR-2	PDKOTE_66	10:08	18:36	8:27	LINE CLEAR AVAILED
1 6-Jul-22 BAGALKOT 110 110/11KV, HV2 STATION NOT AFFECTED BABALESHWAR_110 16:01 16:08 0:07 HAND TRIPPED 2 6-Jul-22 BAGALKOT 110 110/11KV,HV1 HIREKERUR_110 11:06 11:16 0:10 TRANSFORMER FAULT 3 6-Jul-22 BAGALKOT 110 110/11KV,HV1 SIRSI_110 18:51 18:57 0:06 LINE CLEAR AVAILED 4 6-Jul-22 BAGALKOT 110 110/11KV,HV1(HV2) MUDDEBIHAL_110 16:30 17:01 0:31 HAND TRIPPED 5 6-Jul-22 BAGALKOT 110 110/11KV,HV1(HV2) MUDDEBIHAL_110 10:05 19:18 9:13 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 JAMAKHANDI_110 10:05 19:18 9:13 LINE CLEAR AVAILED 7 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/13KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HA	193	5-Jul-22	TUMKUR	66	TR-2	MALEBENNUR_66	15:58	16:04	0:05	TRANSFORMER FAULT
1 6-Jul-22 BAGALKOT 110 110/11KV, HV2 BABALESHWAR_110 16:01 16:08 0:07 HAND TRIPPED 2 6-Jul-22 BAGALKOT 110 110/11KV, HV1 HIREKERUR_110 11:06 11:16 0:10 TRANSFORMER FAULT 3 6-Jul-22 BAGALKOT 110 110/11KV, HV1 SIRSI_110 18:51 18:57 0:06 LINE CLEAR AVAILED 4 6-Jul-22 BAGALKOT 110 110/11KV, HV2 MUDDEBIHAL_110 16:30 17:01 0:31 HAND TRIPPED 5 6-Jul-22 BAGALKOT 110 110/11KV, HV2 MUDDEBIHAL_110 10:05 19:18 9:13 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV, HV3 JAMAKHANDI_110 10:05 19:13 9:08 LINE CLEAR AVAILED 7 6-Jul-22 BAGALKOT 110 110/11KV, HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV, HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED <td>194</td> <td>5-Jul-22</td> <td>TUMKUR</td> <td>110</td> <td>TR2</td> <td>SAMPIGE_110</td> <td>10:02</td> <td>14:37</td> <td>4:34</td> <td>LINE CLEAR AVAILED</td>	194	5-Jul-22	TUMKUR	110	TR2	SAMPIGE_110	10:02	14:37	4:34	LINE CLEAR AVAILED
3 6-Jul-22 BAGALKOT 110 110/11KV,HV1 SIRSI_110 18:51 18:57 0:06 LINE CLEAR AVAILED 4 6-Jul-22 BAGALKOT 110 110/11KV,HV1(HV2) MUDDEBIHAL_110 16:30 17:01 0:31 HAND TRIPPED 5 6-Jul-22 BAGALKOT 110 110/11KV,HV2A JAMAKHANDI_110 10:05 19:18 9:13 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 JAMAKHANDI_110 10:05 19:13 9:08 LINE CLEAR AVAILED 7 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/3KV, HV3 STATION NOT AFFECTED 18:20 TRANSFORMER OPEN:TRANSFORMER FAULT 10 6-Jul-22 BAGALKOT 110 110/33KV, HV3 JAMAKHANDI_110 10:05 19:23 9:18 LINE CLEAR AVAILED	1	6-Jul-22	BAGALKOT	110	110/11KV, HV2		16:01	16:08	0:07	HAND TRIPPED
4 6-Jul-22 BAGALKOT 110 110/11KV,HV1(HV2) MUDDEBIHAL_110 16:30 17:01 0:31 HAND TRIPPED 5 6-Jul-22 BAGALKOT 110 110/11KV,HV2A JAMAKHANDI_110 10:05 19:18 9:13 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 JAMAKHANDI_110 10:05 19:13 9:08 LINE CLEAR AVAILED 7 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/35KV, HV3 STATION NOT AFFECTED 18:20 TRANSFORMER OPEN:TRANSFORMER OPEN	2	6-Jul-22	BAGALKOT	110	110/11KV,HV1	HIREKERUR_110	11:06	11:16	0:10	TRANSFORMER FAULT
5 6-Jul-22 BAGALKOT 110 110/11KV,HV2A JAMAKHANDI_110 10:05 19:18 9:13 LINE CLEAR AVAILED 6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 JAMAKHANDI_110 10:05 19:13 9:08 LINE CLEAR AVAILED 7 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/33KV, HV3 STATION NOT AFFECTED YELPARAHATTI_110 18:20 (21.04.2022) TRANSFORMER PAULT 10 6-Jul-22 BAGALKOT 110 110/33KV, HV3 JAMAKHANDI_110 10:05 19:23 9:18 LINE CLEAR AVAILED	3	6-Jul-22	BAGALKOT	110	110/11KV,HV1	SIRSI_110	18:51	18:57	0:06	LINE CLEAR AVAILED
6 6-Jul-22 BAGALKOT 110 110/11KV,HV3 JAMAKHANDI_110 10:05 19:13 9:08 LINE CLEAR AVAILED 7 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/33KV, HV3 STATION NOT AFFECTED 18:20 TRANSFORMER OPEN:TRANSFORMER FAULT 10 6-Jul-22 BAGALKOT 110 110/33KV, HV3 JAMAKHANDI_110 10:05 19:23 9:18 LINE CLEAR AVAILED	4	6-Jul-22	BAGALKOT	110	110/11KV,HV1(HV2)	MUDDEBIHAL_110	16:30	17:01	0:31	HAND TRIPPED
7 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/33KV, HV3 STATION NOT AFFECTED 18:20 TRANSFORMER OPEN:TRANSFORMER	5	6-Jul-22	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	10:05	19:18	9:13	LINE CLEAR AVAILED
7 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 15:52 17:52 2:00 LINE CLEAR AVAILED 8 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/33KV, HV3 STATION NOT AFFECTED YELPARAHATTI_110 18:20 (21.04.2022) TRANSFORMER OPEN:TRANSFORMER FAULT 10 6-Jul-22 BAGALKOT 110 110/33KV, HV1 JAMAKHANDI_110 10:05 19:23 9:18 LINE CLEAR AVAILED	6	6-Jul-22	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	10:05	19:13	9:08	LINE CLEAR AVAILED
8 6-Jul-22 BAGALKOT 110 110/11KV,HV3 SAVALAGI_110 18:00 18:07 0:07 HAND TRIPPED 9 6-Jul-22 BAGALKOT 110 110/33KV, HV3 STATION NOT AFFECTED YELPARAHATTI_110 18:20 (21.04.2022) TRANSFORMER OPEN:TRANSFORMER FAULT 10 6-Jul-22 BAGALKOT 110 110/33KV, HV1 JAMAKHANDI_110 10:05 19:23 9:18 LINE CLEAR AVAILED	7	6-Jul-22	BAGALKOT	110	110/11KV,HV3	_	15:52	17:52	2:00	LINE CLEAR AVAILED
9 6-Jul-22 BAGALKOT 110 110/33KV, HV3 STATION NOT AFFECTED 18:20 TRANSFORMER OPEN:TRANSFORMER OPEN:TRANSFORM	8		BAGALKOT	110		_	18:00		0:07	HAND TRIPPED
10 6-Jul-22 BAGALKOT 110 110/33KV,HV1 JAMAKHANDI_110 10:05 19:23 9:18 LINE CLEAR AVAILED						STATION NOT AFFECTED	18:20			TRANSFORMER OPEN:TRANSFORMER
	10	6-Jul-22	BAGALKOT	110	110/33KV,HV1	_	·	19:23	9:18	
11 6-Jul-22 BAGALKOI 110 110/33KV,HV2 JAMAKHANDI 110 10:05 19:26 9:21 ILINE CLEAR AVAILED	11	6-Jul-22	BAGALKOT	110	110/33KV,HV2	JAMAKHANDI 110	10:05	19:26	9:21	LINE CLEAR AVAILED

	1				Interior was a sessored			ı	
12	6-Jul-22	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED GHATAPRABHA_220	14:56	17:01	2:03	LINE CLEAR AVAILED
13	6-Jul-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI 220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
14	6-Jul-22	BAGALKOT	110	ANKOLA-KUMTA-2	STATION NOT AFFECTED ANKOLA 110	9:55	17:18	7:23	NFBC ISSUED
15	6-Jul-22	BAGALKOT	110	ANMOD-GOA-2	ANMOD_110	23:14 (05.07.2022)	19:35 (06.07.2022)	20:21 hrs	LINE CHARGED
16	6-Jul-22	BAGALKOT	110	BAGEWADI220-MAMADAPUR-1	STATION NOT AFFECTED MAMADAPUR 110	22:47	23:04	0:17	LINE FAULT
17	6-Jul-22	BAGALKOT	110	BELGAUM110-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED
18	6-Jul-22	BAGALKOT	110	BELLATTI-ADITTYA BIRLA SOLAR	ADITTYA BIRLA SOLAR_110 BELLATTI_110	19:39	20:00	0:21	MAIN SUPPLY FAILURE
19	6-Jul-22	BAGALKOT	110	BELLATTI-ENERCON-2	ENERCON_110 BELLATTI_110	19:39	20:00	0:21	MAIN SUPPLY FAILURE
20	6-Jul-22	BAGALKOT	110	HUKKER-KOTAWAGI	KOTWAGI_LIS STATION NOT AFFECTED HUKKERI_110	21:00:00 (06.07.2022)			LINE OPEN:LINE FAULT
21	6-Jul-22	BAGALKOT	110	HUKKER-VS (VISHWANATH SUGARS)	VISHWANATH SUGARS IPP_110 STATION NOT AFFECTED HUKKERI_110	21:00:00 (06.07.2022)			LINE OPEN:LINE FAULT
22	6-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN:LINE FAULT
23	6-Jul-22	BAGALKOT	110	KIRUVATTI-SIRSI(KAVALWADA)	STATION NOT AFFECTED KIRUVATTI_110	7:00 (06.05.2022)	13:27 (06.07.2022)	1470:27 hrs	LINE CHARGED
24	6-Jul-22	BAGALKOT	110	KIRUVATTI-SIRSI(KAVALWADA)	STATION NOT AFFECTED KIRUVATTI_110	13:28	13:34	0:06	HAND TRIPPED
25	6-Jul-22	BAGALKOT	110	KIRUVATTI-SIRSI(KAVALWADA)	STATION NOT AFFECTED KIRUVATTI_110	13:34 (06.07.2022)			LINE OPEN:LINE FAULT
26	6-Jul-22	BAGALKOT	110	LAKMESWR-BELLATTI	BELATTI_110 ,LAXMESHWAR_110	19:37	19:59	0:22	LINE FAULT
27	6-Jul-22	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI 110	19:36	20:06	0:30	MAIN SUPPLY FAILURE
28	6-Jul-22	BAGALKOT	110	NVLGI-F1CBreaker(JKD)	JAMAKHANDI_110, STATION NOT AFFECTED NAVALAGI 110	10:05	19:08	9:03	NFBC ISSUED
29	6-Jul-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
30	6-Jul-22	BAGALKOT	110	TODALBAGI-JAMKHANDI	JAMKHANDI_110	22:46	22:55	0:09	LINE FAULT
31	6-Jul-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED GHATAPRABHA 220	14:56	17:00	2:03	LINE CLEAR AVAILED
32	6-Jul-22	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL 220	19:58 (05.07.2022)			LINE OPEN:LINE FAULT
33	6-Jul-22	BAGALKOT	220	BIDNAL-NARENDRA	STATION NOT AFFECTED BIDNAL_220	14:07	14:44	0:37	HAND TRIPPED
34	6-Jul-22	BAGALKOT	220	CHIKKODI-MUGALKHOD-1	STATION NOT AFFECTED CHIKKODI_220	11:30	12:50	1:20	LINE CLEAR AVAILED
35	6-Jul-22	BAGALKOT	220	CHIKKODI-MUGALKHOD-2	STATION NOT AFFECTED CHIKKODI_220	12:52 (06.07.2022)			LINE OPEN:LINE CLEAR AVAILED
36	6-Jul-22	BAGALKOT	220	DHONI-LINGAPUR-1	STATION NOT AFFECTED DHONI_400	7:11 (05.07.2022)			LINE OPEN:LINE CLEAR AVAILED
37	6-Jul-22	BAGALKOT	220	DHONI-LINGAPUR-2	STATION NOT AFFECTED DHONI_400	7:09 (05.07.2022)			LINE OPEN:LINE CLEAR AVAILED
38	6-Jul-22	BAGALKOT	220	HAVERI-BIDNAL	STATION NOT AFFECTED HAVERI_220	19:58 (05.07.2022)			LINE OPEN:LINE FAULT

39	6-Jul-22	Bagalkot	220	KUDACHI-CHIKKODI 1	STATION NOT AFFECTED KUDACHI 220	5:40	5:54	0:14	LINE FAULT
40	6-Jul-22	BAGALKOT	220	MUGALKHOD CHIKKODI-1	STATION NOT AFFECTED MUGALKHOD 220	11:25	12:50	1:25	LINE CLEAR AVAILED
41	6-Jul-22	BAGALKOT	220	MUGALKHOD-CHIKKODI-2	STATION NOT AFFECTED MUGALKHOD 220	12:52 (06.07.2022)			LINE OPEN:LINE CLEAR AVAILED
42	6-Jul-22	BAGALKOT	220	SHARAVATHI-SIRSI-1	STATION NOT AFFECTED SIRSI 220	3:42	15:01	11:19	LINE CLEAR AVAILED
43	6-Jul-22	BAGALKOT	220	SHARAVATHI-SIRSI-2	STATION NOT AFFECTED SIRSI_220	3:11	15:02	11:51	LINE FAULT
44	6-Jul-22	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, ALAMIC(EHT)	11:56	12:03	0:07	MAIN SUPPLY FAILURE
45	6-Jul-22	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, ALAMIC(EHT)	12:38	12:43	0:05	MAIN SUPPLY FAILURE
46	6-Jul-22	BENGALURU	66	HV1	A STATION 66	19:48	19:50	0:02	LINE CLEAR AVAILED
47	6-Jul-22	BENGALURU	66	HV1	BAGEPALLI	11:30	11:35	0:05	LINE CLEAR AVAILED
48	6-Jul-22	BENGALURU	66	HV1	CHATRA	11:40	12:34	0:54	LINE CLEAR AVAILED
49	6-Jul-22	BENGALURU	66	HV1	DODALAHALLI	1:38	1:43	0:04	TRANSFORMER FAULT
50	6-Jul-22	BENGALURU	66	HV1	HAROBELE KANAKPURA	12:25	12:30	0:05	LINE CLEAR AVAILED
51	6-Jul-22	BENGALURU	66	HV1	SHOBHA FOREST	15:47	17:16	1:29	TRANSFORMER FAULT
52	6-Jul-22	BENGALURU	66	HV2	CHATRA	11:40	12:34	0:54	LINE CLEAR AVAILED
53	6-Jul-22	BENGALURU	66	HV2	EPIP 220	11:56	12:03	0:07	MAIN SUPPLY FAILURE
54	6-Jul-22	BENGALURU	66	HV2	EPIP 220	12:38	12:43	0:05	MAIN SUPPLY FAILURE
55	6-Jul-22	BENGALURU	66	HV2	HAROBELE KANAKPURA	14:15	14:20	0:05	LINE CLEAR AVAILED
56	6-Jul-22	BENGALURU	66	HV2	NANDAGUDI	8:10	8:15	0:04	TRANSFORMER FAULT
57	6-Jul-22	BENGALURU	66	JADIGENAHALLI - HOSKOTE 220	JADIGENAHALLI	14:50	14:55	0:05	LOAD CHANGE OVER
58	6-Jul-22	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, URAGAHALLI	11:46	11:54	0:08	LINE FAULT
59	6-Jul-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	11:53	13:00	1:07	LINE FAULT
60	6-Jul-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	10:30	10:36	0:06	MAIN SUPPLY FAILURE
61	6-Jul-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	10:30	10:36	0:06	MAIN SUPPLY FAILURE
62	6-Jul-22	BENGALURU	66	SHOBHA FOREST - BRIGADE MEADOWS	SHOBHA FOREST	15:47	17:16	1:29	LINE CLEAR AVAILED
63	6-Jul-22	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	8:06	8:21	0:15	LINE FAULT
64	6-Jul-22	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	10:30	12:35	2:05	LINE CLEAR AVAILED
65	6-Jul-22	BENGALURU	220	HV2	EPIP 220	11:56	12:03	0:07	TRANSFORMER FAULT
-									

66	6-Jul-22	BENGALURU	220	HV2	EPIP 220	12:38	12:43	0:05	TRANSFORMER FAULT
67	6-Jul-22	BENGALURU	220	HV2	KUMBALAGODU 220	7:30(06/07/2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
68	6-Jul-22	BENGALURU	220	HV2	MITTEMARI 220	10:30	13:11	2:41	MAIN SUPPLY FAILURE
69	6-Jul-22	BENGALURU	220	LV2	MITTEMARI 220	10:30	13:14	2:44	MAIN SUPPLY FAILURE
70	6-Jul-22	BENGALURU	220	MITTERMARI 220 - GOWRIBIDANUR 2	MITTEMARI 220	10:30	13:08	2:38	LINE CLEAR AVAILED
71	6-Jul-22	GULBARGA	66	HALVAGALU-NEELAGUNDA	HALVAGALU_66,HARVI_66	11:15	11:45	0:30	MAIN SUPPLY FAILURE
72	6-Jul-22	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66, HOLAGUNDI_66	5:54	6:05	0:11	LINE FAULT
73	6-Jul-22	GULBARGA	66	ITTAGI-RENEWSOLAR1&2	ITTAGI_220	19:25(06.07.2022)			LINE OPEN:LINE CLEAR AVAILED
74	6-Jul-22	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJ AINI_66	21:55	22:00	0:05	LINE FAULT
75	6-Jul-22	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJ AINI_66	22:25	22:30	0:05	LINE FAULT
76	6-Jul-22	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJ AINI_66	23:00	23:10	0:10	LINE FAULT
77	6-Jul-22	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJ AINI_66	23:35	23:40	0:05	LINE FAULT
78	6-Jul-22	GULBARGA	66	PUNABGATTA-UCHCHANGIDURGA	UCHCHANGIDURGA_66,BILCHOD_66,UJJ AINI_66	23:40	23:50	0:10	LINE CLEAR AVAILED
79	6-Jul-22	GULBARGA	66	TELAGI-KURUBRAHALLI	KURUBRAHALLI_66	11:05	12:00	0:55	LINE FAULT
80	6-Jul-22	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI_66,KURUBRAHALLI_66	11:05	11:50	0:45	MAIN SUPPLY FAILURE
81	6-Jul-22	GULBARGA	110	ADAVI AMARESHWAR-JAWALGERA	ADAVI AMRESHWAR_110	19:50	20:07	0:17	MAIN SUPPLY FAILURE
82	6-Jul-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	20:30	20:34	0:04	LINE FAULT
83	6-Jul-22	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH2	GULBARGA SOUTH_110	5:50	6:02	0:12	LINE FAULT
84	6-Jul-22	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	12:50	13:00	0:10	LINE FAULT
85	6-Jul-22	GULBARGA	110	GURMITKAL-KONKAL	KONKAL_110	22:45	22:50	0:05	LINE FAULT
86	6-Jul-22	GULBARGA	110	HATTI-SOMANAMARDI	HATTI_110	7:50	17:52	10:02	LINE CLEAR AVAILED
87	6-Jul-22	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,MAN THAL_110	12:10	13:36	1:26	LINE CLEAR AVAILED
88	6-Jul-22	GULBARGA	110	HV1	GULBARGA UNIVERCITY_110	8:30	8:40	0:10	TRANSFORMER FAULT
89	6-Jul-22	GULBARGA	110	HV1	MYLAR_110	16:20	16:25	0:05	TRANSFORMER FAULT
90	6-Jul-22	GULBARGA	110	HV2	TEKKALKOTE_110	14:50	15:20	0:30	TRANSFORMER FAULT
91	6-Jul-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSL SUGAR FACTORY_IPP, CHOUDAPUR_110.	5:45	5:51	0:06	LINE FAULT
92	6-Jul-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSL SUGAR FACTORY_IPP, CHOUDAPUR_110.	5:34	5:40	0:06	LINE FAULT
93	6-Jul-22	GULBARGA	110	LADHA-RNWSLR	LADHA_110	16:10	16:35	0:25	LINE FAULT
94	6-Jul-22	GULBARGA	110	LADHA-SASTHAPUR	LADHA_110	2:00	3:30	1:30	MAIN SUPPLY FAILURE
95	6-Jul-22	GULBARGA	110	LINGASUGUR-KAREPOWER	CHAYADEVI_IPP,KAREPOWER_IPP	9:14	12:40	3:26	LINE CLEAR AVAILED
96	6-Jul-22	GULBARGA	110	LINGASUGUR-KAREPOWER	CHAYADEVI_IPP,KAREPOWER_IPP	20:22	20:36	0:14	LINE FAULT

97	6-Jul-22	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110	0:33	4:10	3:37	MAIN SUPPLY FAILURE
98	6-Jul-22	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110	4:16	5:41	1:25	MAIN SUPPLY FAILURE
99	6-Jul-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:37	21:43	0:06	LINE FAULT
100	6-Jul-22	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHICKSUGUR_110,SHAKTINA GAR_110	9:45	14:42	4:57	LINE CLEAR AVAILED
101	6-Jul-22	GULBARGA	110	RAICHUR-SHAHAPUR1&2, MATAMARI,MALIYABAD,SINDHNOOR2	GABBUR_110,DEODURGA_110,GOOGAL _110,YARAGERA_110,YAPALDINNI_110, VADAVATTI_110,MALIYABAD_110,KURD ICROSS_110,MADLAPUR_110,MANVI_11 0	9:45	14:39	4:54	LINE CLEAR AVAILED
102	6-Jul-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGAL_110	20:44	20:53	0:09	LINE FAULT
103	6-Jul-22	GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110	9:45	18:10	8:25	LINE CLEAR AVAILED
104	6-Jul-22	GULBARGA	110	RAJESHWAR-HUMNABAD	RAJESHWAR_110	3:22	13:02	9:40	MAIN SUPPLY FAILURE
105	6-Jul-22	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORAWAR_110	6:10	6:15	0:05	LINE FAULT
106	6-Jul-22	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	0:10	0:25	0:15	LINE FAULT
107	6-Jul-22	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	3:15	3:25	0:10	LINE FAULT
108	6-Jul-22	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	5:50	16:42	10:52	LINE FAULT
109	6-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
110	6-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
111	6-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
112	6-Jul-22	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110, NALWAR_110, JEWARGI_110	2:48	2:55	0:07	LINE FAULT
113	6-Jul-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERDONA_110,BENNUR _110,BTPS WATER WORKS,KAMPLI_110	20:12	20:22	0:10	LINE FAULT
114	6-Jul-22	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	NIRLOOTI_IPP	21:05	21:15	0:10	LINE FAULT
115	6-Jul-22	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAPUR_110,MA SKI_110,VALAKAMADINNI_110	1:21	1:31	0:10	LINE FAULT
116	6-Jul-22	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SUZLON_IPP	21:05	21:15	0:10	LINE FAULT
117	6-Jul-22	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	21:35	21:40	0:05	MAIN SUPPLY FAILURE
118	6-Jul-22	GULBARGA	110	YEREGERA-SINDHANOOR	YEREGERA_110	20:13	20:20	0:07	MAIN SUPPLY FAILURE
119	6-Jul-22	GULBARGA	220	HV1	NEELGUNDA_220	14:45	15:15	0:30	LINE CLEAR AVAILED
120	6-Jul-22	GULBARGA	220	HV1	SEDAM_220	15:08	15:40	0:32	LINE CLEAR AVAILED
121	6-Jul-22	GULBARGA	220	HV1 & HV2	RAICHUR_220	9:46	14:20	4:34	LINE CLEAR AVAILED
122	6-Jul-22	GULBARGA	220	LINGASUGUR-MALLAT	MALLAT_220	1:09	1:21	0:12	LINE FAULT
123	6-Jul-22	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	2:50	3:08	0:18	LINE FAULT
124	6-Jul-22	GULBARGA	220	SHAHABAD-KAPNOOR	KAPNOOR_220	6:16	6:28	0:12	LINE FAULT
125	6-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
126	6-Jul-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	0:10	0:20	0:10	MAIN SUPPLY FAILURE
127	6-Jul-22	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	4:20	4:45	0:25	MAIN SUPPLY FAILURE
128	6-Jul-22	HASSAN	66	HV1	GORUR_66	10:35	11:13	0:38	LINE CLEAR AVAILED
129	6-Jul-22	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
130	6-Jul-22	HASSAN	66	HV2	BALEHONNUR_66	1:50	2:09	0:19	TRANSFORMER FAULT
131	6-Jul-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)	_		TRANSFORMER OPEN:LINE CLEAR AVAILED

132	6-Jul-22	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	12:55	16:21	3:26	LINE CLEAR AVAILED
133	6-Jul-22	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	9:45	10:05	0:20	LINE FAULT
134	6-Jul-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	0:10	0:20	0:10	LINE FAULT
135	6-Jul-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	4:20	4:45	0:25	LINE FAULT
136	6-Jul-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
137	6-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
138	6-Jul-22	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	23:40	23:47	0:07	HAND TRIPPED
139	6-Jul-22	HASSAN	110	SHRLKP-BARANGI	SHIARALKOPPA_220	19:16	20:00	0:44	LINE FAULT
140	6-Jul-22	HASSAN	110	SHRLKP-KITTADALI	SHIARALKOPPA_220	19:16	19:32	0:16	LINE FAULT
141	6-Jul-22	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:45	13:55	4:10	NFBC ISSUED
142	6-Jul-22	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	7:40	13:39	5:59	LINE FAULT
143	6-Jul-22	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	7:40	13:39	5:59	LINE FAULT
144	6-Jul-22	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	13:26(05.07.2022)	3:11(06.07.2022)	13:44 hrs	NFBC ISSUED
145	6-Jul-22	HASSAN	220	SHRAVTY-SIRISI 2	sharavthy_gen	3:11(05.07.2022)	15:03(06.07.2022)	35:52HRS	NFBC ISSUED
146	6-Jul-22	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:45	13:55	4:10	NFBC ISSUED
147	6-Jul-22	MYSURU	66	C R NAGARA-HONGANURU	HONAGANURU_66 YELANDUR_66	9:01	9:06	0:05	LINE FAULT
148	6-Jul-22	MYSURU	66	C R NAGARA-HONGANURU	HONAGANURU_66 YELANDUR_66	11:04	11:10	0:06	LINE FAULT
149	6-Jul-22	MYSURU	66	DEVANURU MYSORE-RAJEEV NAGARA	NO STATIONS EFFECTED	13:05	14:57	1:51	LINE CLEAR AVAILED
150	6-Jul-22	MYSURU	66	HAMPAPURA K-KADKOLA	HAMPAPURA(K)_66	10:50	18:30	7:40	LINE CLEAR AVAILED
151	6-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
152	6-Jul-22	MYSURU	66	HEBBANI-SATHEGALA	NO STATIONS EFFECTED	13:45	14:32	0:47	LINE CLEAR AVAILED
153	6-Jul-22	MYSURU	66	HEBBANI-SFC8	NO STATIONS EFFECTED	12:54	14:22	1:28	LINE CLEAR AVAILED
154	6-Jul-22	MYSURU	66	HEBBANI-SFC9	NO STATIONS EFFECTED	12:54	14:42	1:48	LINE CLEAR AVAILED
155	6-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
156	6-Jul-22	MYSURU	66	HV1	ARAKERE_66	12:55	13:00	0:05	HAND TRIPPED
157	6-Jul-22	MYSURU	66	HV1	ARAKERE_66	13:50	14:22	0:32	LINE CLEAR AVAILED
158	6-Jul-22	MYSURU	66	HV1	AYRALLI_66	16:40	16:50	0:10	TRANSFORMER FAULT
159	6-Jul-22	MYSURU	66	HV1	BANNUR_66	11:25	13:06	1:41	LINE CLEAR AVAILED
160	6-Jul-22	MYSURU	66	HV1	COWDALLI_66	6:30	10:00	3:30	LINE CLEAR AVAILED
161	6-Jul-22	MYSURU	66	HV1	HANAGODU_66	19:04	19:10	0:05	TRANSFORMER FAULT
162	6-Jul-22	MYSURU	66	HV2	BANNUR_66	13:13	14:50	1:37	LINE CLEAR AVAILED
163	6-Jul-22	MYSURU	66	HV2	MANDYA_66	20:18	21:11	0:53	TRANSFORMER FAULT
164	6-Jul-22	MYSURU	66	HV2	SHEELUNERE_66	6:20	6:25	0:05	TRANSFORMER FAULT
165	6-Jul-22	MYSURU	66	K R PETE-S B HALLI 2	NO STATIONS EFFECTED	18:14	18:24	0:10	LINE FAULT
166	6-Jul-22	MYSURU	66	KMDODDI-SCSL	NO STATIONS EFFECTED	12:58	13:29	0:31	LINE CLEAR AVAILED
167	6-Jul-22	MYSURU	66	KUSHALANAGARA-HARANGI	NO STATIONS EFFECTED	5:12	5:17	0:05	LINE FAULT
168	6-Jul-22	MYSURU	66	MALAVALLI-SHIMSHA	HADLI_66 KADKOTHANAHALLI_66 MALAVALLI 66	8:06	8:19	0:13	MAIN SUPPLY FAILURE
169	6-Jul-22	MYSURU	66	SATHEGALA-SFC	NO STATIONS EFFECTED	12:14	14:32	2:18	LINE CLEAR AVAILED
170	6-Jul-22	MYSURU	66	THALAKADU-PARINAMIPURA	PARINAMIPURA_66	4:40	4:51	0:10	LINE FAULT
				•	. –				

				T				I	TRANSCORIATE ORDINATION AND
171	6-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
172	6-Jul-22	TUMKUR	66	ANCHEPALYA 66kV-ANCHEPALYA 1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	12:48	12:54	0:06	LINE CLEAR AVAILED
173	6-Jul-22	TUMKUR	66	ANCHEPALYA 66kV-HEBBUR66	HEBBUR_66,THIMMASANDRA_66,HONN ENAHALLI_66	12:14	12:29	0:15	LINE FAULT
174	6-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	14:35	17:35	3:00	MAIN SUPPLY FAILURE
175	6-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	21:55	22:00	0:05	MAIN SUPPLY FAILURE
176	6-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	22:25	22:40	0:15	MAIN SUPPLY FAILURE
177	6-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	23:00	23:05	0:05	MAIN SUPPLY FAILURE
178	6-Jul-22	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP 66	GOLDEN HATCHERIES_IPP_66	14:08	15:49	1:41	LINE CLEAR AVAILED
179	6-Jul-22	TUMKUR	66	HARIYABBE-PD KOTE	HARIYABBE_66	10:04	17:15	7:10	LINE CLEAR AVAILED
180	6-Jul-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	10:03	17:20	7:16	NFBC ISSUED
181	6-Jul-22	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	10:03	17:19	7:15	NFBC ISSUED
182	6-Jul-22	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	10:03	17:25	7:21	NFBC ISSUED
183	6-Jul-22	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	10:04	17:13	7:08	NFBC ISSUED
184	6-Jul-22	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	11:47	12:24	0:37	LINE FAULT
185	6-Jul-22	TUMKUR	66	TR-1	KIADB V N PURA 220	11:03	13:41	2:37	LINE CLEAR AVAILED
186	6-Jul-22	TUMKUR	66	TR-1	PD KOTE_66	10:04	17:15	7:10	NFBC ISSUED
187	6-Jul-22	TUMKUR	66	TR-1	SASALUHALLA_66	13:00:00 PM(28.06.2022			TRANSFORMER OPEN:TRANSFORMER FAULT
188	6-Jul-22	TUMKUR	66	TR-2	BUKKAPATNA_66	14:17	15:48	1:31	LINE CLEAR AVAILED
189	6-Jul-22	TUMKUR	66	TR-2	HOLALKERE 66	11:51	12:34	0:43	LINE CLEAR AVAILED
190	6-Jul-22	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	12:50	13:01	0:10	LINE CLEAR AVAILED
191	6-Jul-22	TUMKUR	66	TR-2	PD KOTE_66	10:04	17:15	7:10	NFBC ISSUED
192	6-Jul-22	TUMKUR	110	TR-2(HV SIDE)	KBCROSS_220	16:52	17:04	0:12	LINE CLEAR AVAILED
193	6-Jul-22	TUMKUR	220	TR-1	KIADB V N PURA_220	11:03	13:41	2:37	LINE CLEAR AVAILED
194	6-Jul-22	TUMKUR	220	TR-2	KIADB V N PURA_220	11:03	15:55	4:51	LINE CLEAR AVAILED
195	6-Jul-22	TUMKUR	220	TR-2(HV SIDE)	KBCROSS 220	16:52	17:04	0:12	LINE CLEAR AVAILED
1	7-Jul-22	BAGALKOT	110	110/11KV, HV1	HALAKI_110(STATION NOT AFFECTED)	13:00	13:10	0:10	TRANSFORMER FAULT
2	7-Jul-22	BAGALKOT	110	110/11KV, HV1	HAVERI_110(STATION NOT AFFECTED)	10:00	13:20	3:20	LINE CLEAR AVAILED
3	7-Jul-22	BAGALKOT	110	110/11KV, HV1	HAVERI_110(STATION NOT AFFECTED)	23:50(7.7.22)			TRANSFORMER OPEN:TRANSFORMER FAULT
4	7-Jul-22	BAGALKOT	110	110/11KV, HV1	KATAKOL_110(STATION NOT AFFECTED)	12:00	14:20	2:20	LINE CLEAR AVAILED
5	7-Jul-22	BAGALKOT	110	110/11KV, HV1	TILUVALLI_110(STATION NOT AFFECTED)	15:15	16:55	1:40	LINE CLEAR AVAILED
6	7-Jul-22	BAGALKOT	110	110/11KV, HV2	BYADAGI_110(STATION NOT AFFECTED)	14:05	15:00	0:55	LINE CLEAR AVAILED
7	7-Jul-22	BAGALKOT	110	110/11KV, HV2	KATAKOL_110(STATION NOT AFFECTED)	14:10	14:20	0:10	LINE CLEAR AVAILED

	7-Jul-22	BAGALKOT	110	110/11/07 11/0	KATAKOL 110/STATION NOT ASSECTED	14:10	14:20	0:10	LINE CLEAR AVAILED
8			110	110/11KV, HV2	KATAKOL_110(STATION NOT AFFECTED)				
9	7-Jul-22	BAGALKOT	110	110/11KV, HV3 (HV2)	RATTIHALLI_110	12:02	12:07	0:05	TRANSFORMER FAULT
10	7-Jul-22	BAGALKOT	110	110/11KV,HV1	HALKI_110	12:59	13:12	0:13	TRANSFORMER FAULT
11	7-Jul-22	BAGALKOT	110	110/11KV,HV1	TILUVALI_110	15:14	17:07	1:53	LINE CLEAR AVAILED
12	7-Jul-22	BAGALKOT	110	110/11KV,HV1(HV4)	GOPPANAKOPPA_110	11:54	12:31	0:37	LINE CLEAR AVAILED
13	7-Jul-22	BAGALKOT	110	110/11KV,HV2	BABLESHWAR_110	7:44	8:20	0:36	LINE CLEAR AVAILED
14	7-Jul-22	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	14:10	15:09	0:59	LINE CLEAR AVAILED
15	7-Jul-22	BAGALKOT	110	110/11KV,HV2	KAMBAGI_110	14:35	14:45	0:10	TRANSFORMER FAULT
16	7-Jul-22	BAGALKOT	110	110/11KV,HV2	NAVALGUND_110	10:34	11:40	1:06	LINE CLEAR AVAILED
17	7-Jul-22	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	0:53	2:05	1:12	TRANSFORMER FAULT
18	7-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED	18:20			TRANSFORMER OPEN:TRANSFORMER
19	7-Jul-22	BAGALKOT	110	110/33KV,HV3	YELPARAHATTI_110 RUSTUMPUR LIS_33,BELGAUM W/S 1_33,BELGAUM W/S 3&4_33,GODACHINA MALKI LIS_33 HIDIKAL DAM_110	(21.04.2022) 20:15	23:15	3:00	FAULT TRANSFORMER FAULT
20	7-Jul-22	BAGALKOT	110	110/33V,HV2	STATION NOT AFFECTED HUBLI 220	10:41	11:45	1:04	LINE CLEAR AVAILED
21	7-Jul-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
22	7-Jul-22	BAGALKOT	110	ARGA-ANKOLA	STATION NOT AFFECTED ANKOLA_110	11:37	16:35	4:58	LINE CLEAR AVAILED
23	7-Jul-22	BAGALKOT	110	BAGALKOT220-RAMDURG	RAMDURG_110	5:49	6:12	0:23	LINE FAULT
24	7-Jul-22	BAGALKOT	110	BELGAUM110-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED
25	7-Jul-22	BAGALKOT	110	HAVERI220-TILUVALLI	STATION NOT AFFECTED HAVERI_220	6:00	8:05	2:05	LINE FAULT
26	7-Jul-22	BAGALKOT	110	HAVERI220-TILUVALLI	TILUVALLI_110	8:20	8:25	0:05	HAND TRIPPED
27	7-Jul-22	BAGALKOT	110	HUKKER-KOTAWAGI	KOTWAGI_LIS STATION NOT AFFECTED HUKKERI_110	21:00:00 (06.07.2022)	9:30 (07.07.2022)	12:30 hrs	LINE CHARGED
28	7-Jul-22	BAGALKOT	110	HUKKER-KOTAWAGI LIS	KOTWAGI_LIS STATION NOT AFFECTED HUKKERI_110	21:32 (07.07.2022)			LINE OPEN:LINE FAULT
29	7-Jul-22	BAGALKOT	110	HUKKER-VS (VISHWANATH SUGARS)	VISHWANATH SUGARS IPP_110 STATION NOT AFFECTED HUKKERI_110	21:00:00 (06.07.2022)	9:20 (07.07.2022)	12:20 hrs	LINE CHARGED
30	7-Jul-22	BAGALKOT	110	HUKKER-VS (VISHWANATH SUGARS)	VISHWANATH SUGARS IPP_110 STATION NOT AFFECTED HUKKERI_110	21:00	21:49	0:49	LINE FAULT
31	7-Jul-22	BAGALKOT	110	HUNGUND-BAGEWADI(KUDALA SANGAM)	STATION NOT AFFECTED HUNGUND_110	12:01	16:44	4:43	LINE CLEAR AVAILED
32	7-Jul-22	BAGALKOT	110	HUNGUND-KBJNL	KBJNL_110 STATION NOT AFFECTED HUNGUND_110	9:00	11:49	2:49	LINE CLEAR AVAILED
33	7-Jul-22	BAGALKOT	110	HUNGUND-KUDALASANGAM	KUDALA SANGAM_110	12:19	16:49	4:30	LINE CLEAR AVAILED
34	7-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN:LINE FAULT
35	7-Jul-22	BAGALKOT	110	KIRUVATTI-SIRSI(KAVALWADA)	STATION NOT AFFECTED KIRUVATTI_110	13:34 (06.07.2022)	10:15 (07.07.2022)	20:41 hrs	LINE CHARGED

				PG HUNSHYAL-MUDALAGI	STATION NOT AFFECTED	16:13	1		
36	7-Jul-22	BAGALKOT	110	(NAGANUR)	PG HUNSHYAL 110	(04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
37	7-Jul-22	BAGALKOT	110	VAJJARMATTI220-KD JAMBAGI	KD JAMABAGI 110	3:40	3:45	0:05	LINE FAULT
	7 301 22	B/ (G/ LEKO)	110	V/63/11/0//11/220 ND 3/11/1D/10/	KATARKI 110	3.40	3.43	0.03	EINE FAGE
38	7-Jul-22	BAGALKOT	110	VAJRA220-KATARKI	STATION NOT AFFECTED	4:35	4:45	0:10	LINE FAULT
30	7 301 22	B/ (G/ LEKO)	110	7,610,1220,10,11,11,11	VAJRAMATTI 220	4.33	4.45	0.10	LINE TAGE!
					KATARKI 110				
39	7-Jul-22	BAGALKOT	110	VAJRA220-KATARKI	STATION NOT AFFECTED	6:24	6:29	0:05	LINE FAULT
					VAJRAMATTI 220				
					MUDHOL_110				
40	7-Jul-22	BAGALKOT	110	VAJRA220-MANTUR(MUDHOL)	STATION NOT AFFECTED	1:14	1:20	0:06	LINE FAULT
					VAJRAMATTI_220				
41	7-Jul-22	BAGALKOT	110	VAJRAMATTI220 -KATARAKI	KATARKI_110	4:35	4:45	0:10	LINE FAULT
42	7-Jul-22	BAGALKOT	110	VAJRAMATTI220 -KATARAKI	KATARKI 110	6:24	6:29	0:05	LINE FAULT
				VAJRAMATTI220 -MUDHOL(KD	KD JAMBAGI 110				
43	7-Jul-22	BAGALKOT	110	JAMBAGI)	MUDHOL 110	1:13	1:18	0:05	LINE FAULT
				,	STATION NOT AFFECTED				_
44	7-Jul-22	BAGALKOT	220	220/110KV, HV2 & LV2	BELAGAVI_220	11:35	17:47	6:12	LINE CLEAR AVAILED
45	7 1.1 22	DACALKOT	220	220/440/04 10/2	STATION NOT AFFECTED	0.44/06.07.2022)	22.50/07.07.2022)	20.40 h	TRANSFORMER CHARGER
45	7-Jul-22	BAGALKOT	220	220/110KV, HV3	ATHANI_220	9:41(06.07.2022)	23:59(07.07.2022)	38:18 hrs	TRANSFORMER CHARGED
46	7-Jul-22	BAGALKOT	220	220/110KV,HV1,LV1	MAHALINGAPUR_220	13:46	14:55	1:09	LINE CLEAR AVAILED
					RABAKAVI 110,HIDIKAL 110				
47	7-Jul-22	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220	12:40	13:10	0:30	LINE CLEAR AVAILED
48	7-Jul-22	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED	19:58	13:25(07.07.2022)	41:27 hrs	LINE CHARGED
48	/-Jul-22	BAGALKUT	220	BIDNAL-HAVERI	BIDNAL_220	(05.07.2022)	13:25(07.07.2022)	41:27 Hrs	LINE CHARGED
49	7-Jul-22	BAGALKOT	220	CHIKKODI-MUGALKHOD-2	STATION NOT AFFECTED	12:52	13:26	24:34 hrs	LINE CHARGED
43	7-Jul-22	BAGALKOT	220	CHIKKODI-WIOGALKITOD-2	CHIKKODI_220	(06.07.2022)	(07.07.2022)	24.541113	LIVE CHARGED
50	7-Jul-22	BAGALKOT	220	DHONI-LINGAPUR-1(HALVARTHI1)	STATION NOT AFFECTED	7:11	10:15	3:06 hrs	LINE CHARGED
				,	DHONI_400	(05.07.2022)	(05.07.2022)		
51	7-Jul-22	BAGALKOT	220	DHONI-LINGAPUR-2(HALVARTHI2)	STATION NOT AFFECTED	7:09	10:15	3:06 hrs	LINE CHARGED
				· ·	DHONI_400	(05.07.2022) 19:58	(05.07.2022)		
52	7-Jul-22	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_110(STATION NOT AFFECTED)	19:58 (05.07.2022)	13:25 (07.07.2022)	41:27 hrs	LINE CHARGED
							(07.07.2022)		
53	7-Jul-22	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_110(STATION NOT AFFECTED)	9:32	13:20	3:48	LINE CLEAR AVAILED
					STATION NOT AFFECTED				
54	7-Jul-22	BAGALKOT	220	MK HUBLI-NARENDRA-2	MK HUBLI 220	13:01	19:20	6:19	LINE FAULT
					STATION NOT AFFECTED	12:52	13:26		
55	7-Jul-22	BAGALKOT	220	MUGALKHOD-CHIKKODI-2	MUGALKHOD_220	(06.07.2022)	(07.07.2022)	24:34 hrs	LINE CHARGED
56	7-Jul-22	BAGALKOT	220	NARENDRA-BIDNAL	STATION NOT AFFECTED	20:22			LINE OPEN:LINE CLEAR AVAILED
30	/-Jul-22	BAGALKOT	220	NAKENDKA-BIDINAL	NARENDRA_220	(05.07.2022)			LINE OF LINE CLEAR AVAILED
57	7-Jul-22	BAGALKOT	220	NARENDRA-HAVERI-1	STATION NOT AFFECTED	9:32	13:20	3:48	NFBC ISSUED
٥,	7 301 22	B/(G/(EKO)	220	TO MENDIO CIDA CENTE	NARENDRA_220	3.32	13.20	3.40	W De 1990ED
58	7-Jul-22	BENGALURU	66	BIDADI 220 - COCO COLA (EHT)	COCO COLA (EHT)	11:09	11:24	0:15	LINE FAULT
				,	,				
59	7-Jul-22	BENGALURU	66	BIDADI 220 - HEJJALA	NO STATION AFFECTED	11:09	12:23	1:14	LINE FAULT
-									
60	7-Jul-22	BENGALURU	66	BIDADI 220 - TPIPL (EHT)	TPIPL (EHT)	14:54	15:38	0:44	LINE CLEAR AVAILED
\vdash									
61	7-Jul-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	17:07	17:26	0:18	LINE FAULT
62	7-Jul-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	17:26	19:07	1:40	LINE FAULT
63	7-Jul-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	18:44	19:07	0:23	LINE CLEAR AVAILED
US	/-Jul-22	BLINGALUNU	UÜ	DADOSFET 220 - ITAIVIAGUNDALU	TIAWAGGINDALO, I DEGUN	10.44	15.07	0.23	LINE CLEAN AVAILED

66 7-36-72 RENGALURU 66 COMMIRIOANUR 201-PERESANDRA PERESANDRA 12-20 12-30 0.13 UNIFICALIT										
BO 7-7-12-72 BENGALURU BO BODWINGHOUND 220 - PELINA BIDADI NO STATION APPETED 11:09 12:38 12:1 UNE FAULT	64	7-Jul-22	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	12:30	12:58	0:28	LINE FAULT
For 7-3	65	7-Jul-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA		12:30	12:43	0:13	LINE FAULT
66 7-10-122 BENGALURU 66 N/2 AVERANALU 16:55 17:05 0.10 TRANSFORME FAULT	66	7-Jul-22	BENGALURU	66	HEJJALA - BIDADI 1	NO STATION AFFECTED	11:09	12:30	1:21	LINE FAULT
For Paril Paril	67	7-Jul-22	BENGALURU	66	HEJJALA - KUMBALAGODU 220	HEJJALA	11:09	11:30	0:21	LINE FAULT
70 7-Jul-22 BENGALURU 66 HV2 SUBAMANYAPURA 66 11:15 11:22 0.07 TRANSFORMER FAULT	68	7-Jul-22	BENGALURU	66	HV2	AVERAHALLI	16:55	17:05	0:10	TRANSFORMER FAULT
72 7-Jul-22 SENGALURU 66 MAGADI 220 - MAGADI 66 HOSPALIYA CIRCLE 10-26 17-58 7-32 LINE CLEAR AVAILED	69	7-Jul-22	BENGALURU	66	HV2	AVERAHALLI	17:20	17:30	0:10	TRANSFORMER FAULT
73 7-30-22 BENGALURU 66 MANDIKAL - GOWIBBIDANUR 220 PATA, GUDIBANDE, MANDIKAL, PERESANDRA 14-00 14-05 0.005 COAD CHANGE OVER	70	7-Jul-22	BENGALURU	66	HV2		11:15	11:22	0:07	TRANSFORMER FAULT
73 7-Jul-22 BENGALURU 66 MANDIKAL - GOVINIBONNOR 220 PERESANDRA 17:00 17:15 0:15 LOAD CHANGE OVER 74 7-Jul-22 BENGALURU 66 MANDIKAL - MITTEMARI 220 PERESANDRA 17:00 17:15 0:15 LOAD CHANGE OVER 75 7-Jul-22 BENGALURU 20 PV2 RUMBALAGODU 220 7:30(6)(07/7022) 17:29(07/07/7022) 33:59HBS TRANSFORMER CHARGED 75 7-Jul-22 GUIBARGA 66 HARAPANAHALLI-NEELAGUNDA HARAPANAHALLI, BE	71	7-Jul-22	BENGALURU	66	MAGADI 220 - MAGADI 66		10:26	17:58	7:32	LINE CLEAR AVAILED
73	72	7-Jul-22	BENGALURU	66	MANDIKAL - GOWRIBIDANUR 220		14:00	14:05	0:05	LOAD CHANGE OVER
7-4 7-Jul-22 BENGALURU 66 TADIGOLU CROSS - CHINTAMANI 220 GOWNPALLI, SOMAYAJANAHALLI, SOMAYAJANAHALI, SOMAYAJANAHANAHALI,	73	7-Jul-22	BENGALURU	66	MANDIKAL - MITTEMARI 220		17:00	17:15	0:15	LOAD CHANGE OVER
76 7-Jul-22 GULBARGA 66 HARAPANAHALLI-NELAGUNDA HARAPANAHALLI-66 12:30 17:25 4:55 MAIN SUPPLY FAILURE	74	7-Jul-22	BENGALURU	66	TADIGOLU CROSS - CHINTAMANI 220	GOWNPALLI, SOMAYAJANAHALLI,	16:55	17:10	0:15	LINE FAULT
77 7-Jul-22 GULBARGA 66 HV1	75	7-Jul-22	BENGALURU	220	HV2	KUMBALAGODU 220	7:30(06/07/2022)	17:29(07/07/2022)	33:59HRS	TRANSFORMER CHARGED
7-8 7-Jul-22 GULBARGA 66 ITTAGI-RENEWSOLAR182 ITTAGI_220 19:25(66.07.2022) 00:25(07.07.2022) 5:00HRS LINE CHARGED	76	7-Jul-22	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66	12:30	17:25	4:55	MAIN SUPPLY FAILURE
79 7-Jul-22 GUBARGA 66 UCCHANGIDURGA-NELAGUNDA UCCHANGIDURGA_66,BILCHOD_66 12:25 12:45 0:20 MAIN SUPPLY FAILURE 80 7-Jul-22 GULBARGA 110 CHOWDAPUR-AFZALPUR AFZALPUR_110 1:55 2:03 0:08 LINE FAULT 81 7-Jul-22 GULBARGA 110 GANDHINAGAR-TURVIHAL TURVIHAL_110 1:54 2:00 0:06 LINE FAULT 82 7-Jul-22 GULBARGA 110 GANDHINAGAR-TURVIHAL TURVIHAL_110 3:50 3:53 0:03 LINE FAULT 84 7-Jul-22 GULBARGA 110 GATTHARGA-AFZALPUR GATTHARAGA_110,AFZALPUR_110 2:00 2:08 0:08 UNE FAULT 85 7-Jul-22 GULBARGA 110 GURMITKAL-KONKAL GURMITKAL_110 4:45 4:50 0:05 LINE FAULT 86 7-Jul-22 GULBARGA 110 HATTI-110 7:55 17:00 9:05 LINE CLEAR AVAILED 87 7-Jul-22 GULBARGA 110 HV2	77	7-Jul-22	GULBARGA	66	HV1	HALVAGALU_66	7:45	8:20	0:35	LINE CLEAR AVAILED
80 7-Jul-22 GULBARGA 110 CHOWDAPUR-AFZALPUR AFZALPUR 110 1:55 2:03 0:08 LINE FAULT	78	7-Jul-22	GULBARGA	66	ITTAGI-RENEWSOLAR1&2	ITTAGI_220	19:25(06.07.2022)	00:25(07.07.2022)	5:00HRS	LINE CHARGED
81 7-Jul-22 GULBARGA 110 GANDHINAGAR-TURVIHAL TURVIHAL_110 1:54 2:00 0:06 LINE FAULT 82 7-Jul-22 GULBARGA 110 GANDHINAGAR-TURVIHAL TURVIHAL_110 3:50 3:53 0:03 LINE FAULT 83 7-Jul-22 GULBARGA 110 GATTHARAGA-AFZALPUR GATTHARAGA_110,AFZALPUR_110 2:00 2:08 0:08 LINE FAULT 84 7-Jul-22 GULBARGA 110 GURMITKAL-KONKAL GURMITKAL_110 4:45 4:50 0:05 LINE FAULT 85 7-Jul-22 GULBARGA 110 HATTI-SOMANAMARDI HATTI_110 7:55 17:00 9:05 LINE CLEAR AVAILED 86 7-Jul-22 GULBARGA 110 HV1 MATAMARI_110 10:25 14:20 3:55 LINE CLEAR AVAILED 87 7-Jul-22 GULBARGA 110 HV2 MATAMARI_110 11:08 11:15 0:07 TRANSFORMER FAULT 88 7-Jul-22 GULBARGA 110 HV2	79	7-Jul-22	GULBARGA	66	UCCHANGIDURGA-NEELAGUNDA	UCCHANGIDURGA_66,BILCHOD_66	12:25	12:45	0:20	MAIN SUPPLY FAILURE
82 7-Jul-22 GULBARGA 110 GANDHINAGAR-TURVIHAL TURVIHAL_110 3:50 3:53 0:03 LINE FAULT 83 7-Jul-22 GULBARGA 110 GATTHARAGA-AFZALPUR GATTHARAGA_110,AFZALPUR_110 2:00 2:08 0:08 LINE FAULT 84 7-Jul-22 GULBARGA 110 GURMITKAL-KONKAL GURMITKAL_110 4:45 4:50 0:05 LINE FAULT 85 7-Jul-22 GULBARGA 110 HATTI-SOMANAMARDI HATTI_110 7:55 17:00 9:05 LINE CLEAR AVAILED 86 7-Jul-22 GULBARGA 110 HV1 MATAMARI_110 10:25 14:20 3:55 LINE CLEAR AVAILED 87 7-Jul-22 GULBARGA 110 HV2 MATAMARI_110 11:08 11:15 0:07 TRANSFORMER FAULT 88 7-Jul-22 GULBARGA 110 HV3 VALKAMDINNI_110 11:08 11:15 0:07 TRANSFORMER FAULT 89 7-Jul-22 GULBARGA 110 HV3 <	80	7-Jul-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	AFZALPUR _110	1:55	2:03	0:08	LINE FAULT
83 7-Jul-22 GULBARGA 110 GATTHARAGA_FZALPUR GATTHARAGA_110,AFZALPUR_110 2:00 2:08 0:08 LINE FAULT 84 7-Jul-22 GULBARGA 110 GURMITKAL_KONKAL GURMITKAL_110 4:45 4:50 0:05 LINE FAULT 85 7-Jul-22 GULBARGA 110 HATTI-SOMANAMARDI HATTI_110 7:55 17:00 9:05 LINE CLEAR AVAILED 86 7-Jul-22 GULBARGA 110 HV1 MATAMAR_110 10:25 14:20 3:55 LINE CLEAR AVAILED 87 7-Jul-22 GULBARGA 110 HV2 MATAMAR_110 11:08 11:15 0:07 TRANSFORMER FAULT 88 7-Jul-22 GULBARGA 110 HV3 VALKAMDINNI_110 11:08 11:15 0:07 TRANSFORMER FAULT 89 7-Jul-22 GULBARGA 110 JEEWARGI_110 3:45 3:50 0:05 LINE FAULT 90 7-Jul-22 GULBARGA 110 KAPNOOR-MADIYAL MADIYAL_110, CHOUDAPUR_110	81	7-Jul-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	1:54	2:00	0:06	LINE FAULT
84 7-Jul-22 GULBARGA 110 GURMITKAL-KONKAL GURMITKAL_110 4:45 4:50 0:05 LINE FAULT 85 7-Jul-22 GULBARGA 110 HATTI-SOMANAMARDI HATTL_110 7:55 17:00 9:05 LINE CLEAR AVAILED 86 7-Jul-22 GULBARGA 110 HV1 MATAMARI_110 10:25 14:20 3:55 LINE CLEAR AVAILED 87 7-Jul-22 GULBARGA 110 HV2 MATAMARI_110 11:08 11:15 0:07 TRANSFORMER FAULT 88 7-Jul-22 GULBARGA 110 HV3 VALKAMDINNI_110 11:08 11:15 0:07 TRANSFORMER FAULT 89 7-Jul-22 GULBARGA 110 JEEWARGI_110 3:45 3:50 0:05 LINE FAULT 90 7-Jul-22 GULBARGA 110 KAPNOOR-MADIYAL MADIYAL_110, CHOUDAPUR_110 5:45 5:47 0:02 MAIN SUPPLY FAILURE 91 7-Jul-22 GULBARGA 110 MALKAT-ALKOD ALKOD_110,GALAG_110 <td>82</td> <td>7-Jul-22</td> <td>GULBARGA</td> <td>110</td> <td>GANDHINAGAR-TURVIHAL</td> <td>TURVIHAL_110</td> <td>3:50</td> <td>3:53</td> <td>0:03</td> <td>LINE FAULT</td>	82	7-Jul-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	3:50	3:53	0:03	LINE FAULT
85 7-Jul-22 GULBARGA 110 HATTI_SOMANAMARDI HATTI_110 7:55 17:00 9:05 LINE CLEAR AVAILED 86 7-Jul-22 GULBARGA 110 HV1 MATAMARI_110 10:25 14:20 3:55 LINE CLEAR AVAILED 87 7-Jul-22 GULBARGA 110 HV2 MATAMARI_110 11:08 11:15 0:07 TRANSFORMER FAULT 88 7-Jul-22 GULBARGA 110 HV3 VALKAMDINNI_110 11:08 11:15 0:07 TRANSFORMER FAULT 89 7-Jul-22 GULBARGA 110 JEEWARGI-NALWAR JEEWARGI_110 3:45 3:50 0:05 LINE FAULT 90 7-Jul-22 GULBARGA 110 KAPNOOR-MADIYAL MADIYAL_110, CHOUDAPUR_110 5:45 5:47 0:02 MAIN SUPPLY FAILURE 91 7-Jul-22 GULBARGA 110 MALLAT-ALKOD ALKOD_110, GALAG_110 3:05 3:15 0:10 LINE FAULT 92 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOL	83	7-Jul-22	GULBARGA	110	GATTHARAGA-AFZALPUR	GATTHARAGA_110,AFZALPUR _110	2:00	2:08	0:08	LINE FAULT
86 7-Jul-22 GULBARGA 110 HV1 MATAMARI_110 10:25 14:20 3:55 LINE CLEAR AVAILED 87 7-Jul-22 GULBARGA 110 HV2 MATAMARI_110 14:20 17:00 2:40 LINE CLEAR AVAILED 88 7-Jul-22 GULBARGA 110 HV3 VALKAMDINNI_110 11:08 11:15 0:07 TRANSFORMER FAULT 89 7-Jul-22 GULBARGA 110 JEEWARGI_NALWAR JEEWARGI_110 3:45 3:50 0:05 LINE FAULT 90 7-Jul-22 GULBARGA 110 KAPNOOR-MADIYAL MADIYAL_110, CHOUDAPUR_110 5:45 5:47 0:02 MAIN SUPPLY FAILURE 91 7-Jul-22 GULBARGA 110 MALLAT-ALKOD ALKOD_110,GALAG_110 3:05 3:15 0:10 LINE FAULT 92 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 4:20 4:30 0:10 LINE FAULT 94 7-Jul-22 GULBARGA 110 NALWAR-SHAHABAD2 <td>84</td> <td>7-Jul-22</td> <td>GULBARGA</td> <td>110</td> <td>GURMITKAL-KONKAL</td> <td>GURMITKAL_110</td> <td>4:45</td> <td>4:50</td> <td>0:05</td> <td>LINE FAULT</td>	84	7-Jul-22	GULBARGA	110	GURMITKAL-KONKAL	GURMITKAL_110	4:45	4:50	0:05	LINE FAULT
87 7-Jul-22 GULBARGA 110 HV2 MATAMARI_110 14:20 17:00 2:40 LINE CLEAR AVAILED	85	7-Jul-22	GULBARGA	110	HATTI-SOMANAMARDI	HATTI_110	7:55	17:00	9:05	LINE CLEAR AVAILED
88 7-Jul-22 GULBARGA 110 HV3 VALKAMDINNI_110 11:08 11:15 0:07 TRANSFORMER FAULT 89 7-Jul-22 GULBARGA 110 JEEWARGI_NALWAR JEEWARGI_110 3:45 3:50 0:05 LINE FAULT 90 7-Jul-22 GULBARGA 110 KAPNOOR-MADIYAL MADIYAL_110, CHOUDAPUR_110 5:45 5:47 0:02 MAIN SUPPLY FAILURE 91 7-Jul-22 GULBARGA 110 MALLAT-ALKOD ALKOD_110,GALAG_110 3:05 3:15 0:10 LINE FAULT 92 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 4:20 4:30 0:10 LINE FAULT 94 7-Jul-22 GULBARGA 110 NALWAR-SHAHABAD2 JEWARGI_110 3:45 3:50 0:05 LINE FAULT 95 7-Jul-22 GULBARGA 110 NALWAR-SHAHABAD2 JEWARGI_110 3:45 3:50 0:05 LINE FAULT 95 7-Jul-22 GULBARGA 110 SEDAM-VICTSAGAR	86	7-Jul-22	GULBARGA	110	HV1	MATAMARI_110	10:25	14:20	3:55	LINE CLEAR AVAILED
89 7-Jul-22 GULBARGA 110 JEEWARGI-NALWAR JEEWARGI_110 3:45 3:50 0:05 LINE FAULT 90 7-Jul-22 GULBARGA 110 KAPNOOR-MADIYAL MADIYAL_110, CHOUDAPUR_110 5:45 5:47 0:02 MAIN SUPPLY FAILURE 91 7-Jul-22 GULBARGA 110 MALLAT-ALKOD ALKOD_110,GALAG_110 3:05 3:15 0:10 LINE FAULT 92 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 4:20 4:30 0:10 LINE FAULT 93 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 20:05 20:20 0:15 LINE FAULT 94 7-Jul-22 GULBARGA 110 NALWAR-SHAHABAD2 JEWARGI_110 3:45 3:50 0:05 LINE FAULT 95 7-Jul-22 GULBARGA 110 SEDAM-VICTSAGAR_IPP VICATSAGARCEMNETS 20:10 20:34 0:24 LINE FAULT 96 7-Jul-22 GULBARGA 110 SHAHABAD-CHITAPUR CHITAPUR_110,KORAWAR_110 11:30(23/06/2022) LINE GPEN:LINE CLEAR AVAILED	87	7-Jul-22	GULBARGA	110	HV2	MATAMARI_110	14:20	17:00	2:40	LINE CLEAR AVAILED
90 7-Jul-22 GULBARGA 110 KAPNOOR-MADIYAL MADIYAL_110, CHOUDAPUR_110 5:45 5:47 0:02 MAIN SUPPLY FAILURE 91 7-Jul-22 GULBARGA 110 MALLAT-ALKOD ALKOD_110,GALAG_110 3:05 3:15 0:10 LINE FAULT 92 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 4:20 4:30 0:10 LINE FAULT 93 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 20:05 20:20 0:15 LINE FAULT 94 7-Jul-22 GULBARGA 110 NALWAR-SHAHABAD2 JEWARGI_110 3:45 3:50 0:05 LINE FAULT 95 7-Jul-22 GULBARGA 110 SEDAM-VICTSAGAR_IPP VICATSAGARCEMNETS 20:10 20:34 0:24 LINE FAULT 96 7-Jul-22 GULBARGA 110 SHAHABAD-CHITAPUR CHITAPUR_110,KORAWAR_110 11:30(23/06/2022) LINE OPEN:LINE CLEAR AVAILED	88	7-Jul-22	GULBARGA	110	HV3	VALKAMDINNI_110	11:08	11:15	0:07	TRANSFORMER FAULT
91 7-Jul-22 GULBARGA 110 MALLAT-ALKOD ALKOD_110,GALAG_110 3:05 3:15 0:10 LINE FAULT 92 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 4:20 4:30 0:10 LINE FAULT 93 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 20:05 20:20 0:15 LINE FAULT 94 7-Jul-22 GULBARGA 110 NALWAR-SHAHABAD2 JEWARGI_110 3:45 3:50 0:05 LINE FAULT 95 7-Jul-22 GULBARGA 110 SEDAM-VICTSAGAR_IPP VICATSAGARCEMNETS 20:10 20:34 0:24 LINE FAULT 96 7-Jul-22 GULBARGA 110 SHAHABAD-CHITAPUR CHITAPUR_110,KORAWAR_110 11:30(23/06/2022) LINE OPEN:LINE CLEAR AVAILED	89	7-Jul-22	GULBARGA	110	JEEWARGI-NALWAR	JEEWARGI_110	3:45	3:50	0:05	LINE FAULT
92 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 4:20 4:30 0:10 LINE FAULT 93 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 20:05 20:20 0:15 LINE FAULT 94 7-Jul-22 GULBARGA 110 NALWAR-SHAHABAD2 JEWARGI_110 3:45 3:50 0:05 LINE FAULT 95 7-Jul-22 GULBARGA 110 SEDAM-VICTSAGAR_IPP VICATSAGARCEMNETS 20:10 20:34 0:24 LINE FAULT 96 7-Jul-22 GULBARGA 110 SHAHABAD-CHITAPUR CHITAPUR_110,KORAWAR_110 11:30(23/06/2022) LINE OPEN:LINE CLEAR AVAILED	90	7-Jul-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, CHOUDAPUR_110	5:45	5:47	0:02	MAIN SUPPLY FAILURE
93 7-Jul-22 GULBARGA 110 NALWAR-CLEAN SOLAR_IPP NALWAR_110 20:05 20:20 0:15 LINE FAULT 94 7-Jul-22 GULBARGA 110 NALWAR-SHAHABAD2 JEWARGI_110 3:45 3:50 0:05 LINE FAULT 95 7-Jul-22 GULBARGA 110 SEDAM-VICTSAGAR_IPP VICATSAGARCEMNETS 20:10 20:34 0:24 LINE FAULT 96 7-Jul-22 GULBARGA 110 SHAHABAD-CHITAPUR CHITAPUR_110,KORAWAR_110 11:30(23/06/2022) LINE OPEN:LINE CLEAR AVAILED	91	7-Jul-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	3:05	3:15	0:10	LINE FAULT
94 7-Jul-22 GULBARGA 110 NALWAR-SHAHABAD2 JEWARGI_110 3:45 3:50 0:05 LINE FAULT 95 7-Jul-22 GULBARGA 110 SEDAM-VICTSAGAR_IPP VICATSAGARCEMNETS 20:10 20:34 0:24 LINE FAULT 96 7-Jul-22 GULBARGA 110 SHAHABAD-CHITAPUR CHITAPUR_110,KORAWAR_110 11:30(23/06/2022) LINE OPEN:LINE CLEAR AVAILED	92	7-Jul-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	4:20	4:30	0:10	LINE FAULT
95 7-Jul-22 GULBARGA 110 SEDAM-VICTSAGAR_IPP VICATSAGARCEMNETS 20:10 20:34 0:24 LINE FAULT 96 7-Jul-22 GULBARGA 110 SHAHABAD-CHITAPUR CHITAPUR_110,KORAWAR_110 11:30(23/06/2022) LINE OPEN:LINE CLEAR AVAILED	93	7-Jul-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	20:05	20:20	0:15	LINE FAULT
96 7-Jul-22 GULBARGA 110 SHAHABAD-CHITAPUR CHITAPUR_110,KORAWAR_110 11:30(23/06/2022) LINE OPEN:LINE CLEAR AVAILED	94	7-Jul-22	GULBARGA	110	NALWAR-SHAHABAD2	JEWARGI_110	3:45	3:50	0:05	LINE FAULT
	95	7-Jul-22	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	20:10	20:34	0:24	LINE FAULT
97 7-Jul-22 GULBARGA 110 SHAHABAD-RAICHUR1 JEWARGI_110 12:15(15/06/2022) LINE OPEN:LINE CLEAR AVAILED	96	7-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
	_	7 101 22	GUIRARGA	110	SHAHABAD-RAICHUR1	JEWARGI 110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
98 7-Jul-22 GULBARGA 110 SHAHABAD-RAICHUR2 NALWAR_110 15:10(14/06/2022) LINE OPEN:LINE CLEAR AVAILED	97	7-Jul-22	GOLDANIOA			· - ·	- (- / /			

99	7-Jul-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	3:43	3:53	0:10	LINE FAULT
100	7-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	2:15	2:19	0:04	LINE FAULT
101	7-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:34	20:39	0:05	LINE FAULT
102	7-Jul-22	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	15:30	15:45	0:15	LINE FAULT
103	7-Jul-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	12:08	12:57	0:49	LINE CLEAR AVAILED
104	7-Jul-22	GULBARGA	110	YEARAGERA-MALIYABAD	MALIYABAD_110	14:27	15:24	0:57	MAIN SUPPLY FAILURE
105	7-Jul-22	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12(7.7.22)			LINE OPEN:LINE CLEAR AVAILED
106	7-Jul-22	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45(77.22)			LINE OPEN:LINE CLEAR AVAILED
107	7-Jul-22	GULBARGA	220	HV1	HALBARGA_220	5:38	6:17	0:39	TRANSFORMER FAULT
108	7-Jul-22	GULBARGA	220	HV1	NEELGUNDA_220	12:30	15:35	3:05	LINE CLEAR AVAILED
109	7-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
110	7-Jul-22	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	18:53	19:05	0:12	LINE FAULT
111	7-Jul-22	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	19:03	19:06	0:03	LINE FAULT
112	7-Jul-22	HASSAN	66	HV1	HNPURA_66	18:54	19:07	0:13	MAIN SUPPLY FAILURE
113	7-Jul-22	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
114	7-Jul-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
115	7-Jul-22	HASSAN	66	HV2	HNPURA_66	18:54	19:06	0:12	MAIN SUPPLY FAILURE
116	7-Jul-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	15:48	17:01	1:13	LINE CLEAR AVAILED
117	7-Jul-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	9:10	9:15	0:05	MAIN SUPPLY FAILURE
118	7-Jul-22	HASSAN	110	BARANG-ANVATTI	BARANGI_110	6:58	7:15	0:17	HAND TRIPPED
119	7-Jul-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	9:57	11:15	1:18	LINE CLEAR AVAILED
120	7-Jul-22	HASSAN	110	HV1	KADUR_220	11:03	11:53	0:50	TRANSFORMER FAULT
121	7-Jul-22	HASSAN	110	HV1	SHIKARIPURA_110	12:28	13:00	0:32	LINE CLEAR AVAILED
122	7-Jul-22	HASSAN	110	HV2	BHADRAVATHI_110	20:35	21:25	0:50	TRANSFORMER FAULT
123	7-Jul-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
124	7-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
125	7-Jul-22	HASSAN	110	LV1	SHIRALKOPPA_220	11:30	16:14	4:44	LINE CLEAR AVAILED
126	7-Jul-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:46	12:59	0:13	HAND TRIPPED
127	7-Jul-22	HASSAN	220	HV1	SHIRALKOPPA_220	11:30	16:14	4:44	LINE CLEAR AVAILED
128	7-Jul-22	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	11:00	17:32	6:32	NFBC ISSUED
129	7-Jul-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:00	17:32	6:32	LINE CLEAR AVAILED
130	7-Jul-22	MYSURU	66	CHUNCHANAKATTE-RAVANDUR	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	17:21	17:35	0:13	LINE FAULT
131	7-Jul-22	MYSURU	66	CHUNCHANAKATTE-RAVANDUR	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	18:35	20:42	2:07	NFBC ISSUED
132	7-Jul-22	MYSURU	66	DEVNUR(MYS)-VAJMANGALA	NO STATIONS EFFECTED	11:07	12:49	1:41	LINE CLEAR AVAILED
133	7-Jul-22	MYSURU	66	DEVNUR(N'GUD)-BANNARI 1	NO STATIONS EFFECTED	12:50	13:58	1:08	LINE CLEAR AVAILED
134	7-Jul-22	MYSURU	66	DEVNUR(N'GUD)-BANNARI 2	NO STATIONS EFFECTED	12:50	13:58	1:08	LINE CLEAR AVAILED
135	7-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
136	7-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
137	7-Jul-22	MYSURU	66	HV1	BGPURA_66	11:25	19:49	8:24	LINE CLEAR AVAILED

138	7-Jul-22	MYSURU	66	HV1	DEVANOORMYS_66	13:01	15:43	2:42	LINE CLEAR AVAILED
139	7-Jul-22	MYSURU	66	HV1	DEVANOORNGUDU_66	13:17	13:58	0:41	LINE CLEAR AVAILED
140	7-Jul-22	MYSURU	66	HV1	HOOTAGALLY_220	10:07	14:47	4:40	LINE CLEAR AVAILED
141	7-Jul-22	MYSURU	66	HV2	DEVANOORMYS_66	15:46	17:51	2:05	LINE CLEAR AVAILED
142	7-Jul-22	MYSURU	66	HV2	DEVANOORNGUDU_66	13:17	13:58	0:41	LINE CLEAR AVAILED
143	7-Jul-22	MYSURU	66	HV2	HOOTAGALLY_220	13:05	14:47	1:42	LINE CLEAR AVAILED
144	7-Jul-22	MYSURU	66	KUSHALNAGARA-BETTADAPURA	BETTADHAPURA_66	15:38	18:15	2:37	LINE FAULT
145	7-Jul-22	MYSURU	66	KUSHALNAGARA-BETTADAPURA	NO STATIONS EFFECTED	18:15	20:45	2:30	LINE CLEAR AVAILED
146	7-Jul-22	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	17:34	17:40	0:05	LINE FAULT
147	7-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
148	7-Jul-22	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	T G HALLI_66,HOSAPALYA_66,SOLUR_66,MA GADI_66,V G DODDI_66	7:45	8:00	0:15	LINE FAULT
149	7-Jul-22	TUMKUR	66	BILCHODU66-UCHANGIDURGA66	BILCHODU_66	12:25	12:40	0:15	LINE CLEAR AVAILED
150	7-Jul-22	TUMKUR	66	BILCHODU66-UCHANGIDURGA66	BILCHODU_66	17:05	17:25	0:20	HAND TRIPPED
151	7-Jul-22	TUMKUR	66	BRAHMASANDRA- SIRA(ANKASANDRA)	BRAHMASANDRA_66	6:35	6:45	0:10	LINE FAULT
152	7-Jul-22	TUMKUR	66	HAGALWADI66-ANCHEPALYA220	HAGALWADI_66	16:35	17:24	0:48	LINE CLEAR AVAILED
153	7-Jul-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	6:39	6:47	0:08	MAIN SUPPLY FAILURE
154	7-Jul-22	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	6:39	6:47	0:08	MAIN SUPPLY FAILURE
155	7-Jul-22	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	6:39	6:47	0:08	MAIN SUPPLY FAILURE
156	7-Jul-22	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	10:10	17:05	6:55	LINE CLEAR AVAILED
157	7-Jul-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	23:54	23:56	0:01	TRANSFORMER FAULT
158	7-Jul-22	TUMKUR	66	TR-1	HAGALWADI_66	16:35	17:24	0:48	LINE CLEAR AVAILED
159	7-Jul-22	TUMKUR	66	TR-1	KORATAGERE_66	13:46	15:00	1:13	LINE CLEAR AVAILED
160	7-Jul-22	TUMKUR	66	TR-1	LINGADAHALLY_66	13:44	14:15	0:31	LINE CLEAR AVAILED
161	7-Jul-22	TUMKUR	66	TR-1	SASALUHALLA_66	13:00:00 PM(28.06.2022			TRANSFORMER OPEN:TRANSFORMER FAULT
162	7-Jul-22	TUMKUR	66	TR-2	CHANNAGIRI_66	16:51	17:18	0:27	LINE CLEAR AVAILED
163	7-Jul-22	TUMKUR	66	TR-3 (LV SIDE	CHITRADURGA_220	3:00	3:30	0:30	TRANSFORMER FAULT
164	7-Jul-22	TUMKUR	220	TR-3 (HV SIDE	CHITRADURGA_220	2:58	3:12	0:13	TRANSFORMER FAULT
1	8-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HAVERI_110	23:50 (07.07.2022)	00:40 (08.07.2022)	50:00 hrs	TRANSFORMER CHARGED
2	8-Jul-22	BAGALKOT	110	110/11KV, HV2	SHIRABUR_110	8:31	8:48	0:17	TRANSFORMER FAULT
3	8-Jul-22	BAGALKOT	110	110/11KV, HV5	STATION NOT AFFECTED HANAGAL_110	12:45	13:30	0:45	LINE CLEAR AVAILED
4	8-Jul-22	BAGALKOT	110	110/11KV,HV1	AHERI_220	15:32	16:31	0:59	LINE CLEAR AVAILED
5	8-Jul-22	BAGALKOT	110	110/11KV,HV1	HIDIKAL DAM_110	0:30	1:09	0:39	TRANSFORMER FAULT
6	8-Jul-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	18:11	18:15	0:04	TRANSFORMER FAULT
7	8-Jul-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	21:49	22:09	0:20	HAND TRIPPED
8	8-Jul-22	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	8:17	8:29	0:12	TRANSFORMER FAULT
9	8-Jul-22	BAGALKOT	110	110/11KV,HV1	KALAGHATAGII_110	13:54	14:04	0:10	TRANSFORMER FAULT
10	8-Jul-22	BAGALKOT	110	110/11KV,HV1	KAMBAGI_110	20:09	20:14	0:05	TRANSFORMER FAULT
11	8-Jul-22	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	11:24	20:05	8:41	LINE CLEAR AVAILED

12	8-Jul-22	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	16:02	16:05	0:03	HAND TRIPPED
13	8-Jul-22	BAGALKOT	110	110/33KV, HV3	MUNAVALLI_33, MALLUR_33 STATION NOT AFFECTED MUNAVALL 110,	12:20	18:36	6:16	LINE CLEAR AVAILED
14	8-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
15	8-Jul-22	BAGALKOT	110	110/33KV,HV1	HIREKERUR_110	13:59	17:44	3:45	LINE CLEAR AVAILED
16	8-Jul-22	BAGALKOT	110	110/33KV,HV3	SINADAGI_110	10:13	12:51	2:38	LINE CLEAR AVAILED
17	8-Jul-22	BAGALKOT	110	220/110KV ,HV2&LV 2	AHERI_220	16:31	18:58	2:27	TRANSFORMER FAULT
18	8-Jul-22	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED GHATAPRABHA_220	13:48	18:26	4:38	LINE CLEAR AVAILED
19	8-Jul-22	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED BELGAVI_220	11:48	17:44	5:56	LINE CLEAR AVAILED
20	8-Jul-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
21	8-Jul-22	BAGALKOT	110	BELGAUM110-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED
22	8-Jul-22	BAGALKOT	110	BIDNAL-NARENDRA	BIDNAL_220	19:02	19:11	0:09	HAND TRIPPED
23	8-Jul-22	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	5:14	9:23	4:09	LINE FAULT
24	8-Jul-22	BAGALKOT	110	HUKKERI-KOTAWAGI	HUKKERI_110	13:25	13:45	0:20	LINE CLEAR AVAILED
25	8-Jul-22	BAGALKOT	110	HUKKER-KOTAWAGI LIS	KOTWAGI_LIS STATION NOT AFFECTED HUKKERI_110	21:32 (07.07.2022)	9:17 (8.7.2022)	11:45	LINE CHARGED
26	8-Jul-22	BAGALKOT	110	INDI220- HIREMASALI	HIREMASALI_110 ATHARGA_110 D-HIPPARGI_110	21:40	21:45	0:05	LINE FAULT
27	8-Jul-22	BAGALKOT	110	INDI-HIREMASALI	HIREMASALI_110	21:37	21:51	0:14	LINE FAULT
28	8-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN:LINE FAULT
29	8-Jul-22	BAGALKOT	110	MUNDARGI-VIJAYA SUGARS	VIJAYA SUGARS_IPP STATION NOT AFFECTED MUNDARGI_100	6:23	7:26	1:03	LINE FAULT
30	8-Jul-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
31	8-Jul-22	BAGALKOT	110	SAVANUR-ASF Cbreaker	ASF_IPP SAVANUR_110	5:49	6:05	0:16	MAIN SUPPLY FAILURE
32	8-Jul-22	BAGALKOT	110	SAVANUR-SHIGGAON	SHIGGAON_110	5:15	5:40	0:25	MAIN SUPPLY FAILURE
33	8-Jul-22	BAGALKOT	110	SIRSI-JOG1	STATION NOT AFFECTED SIRSI_110	17:05	19:18	2:13	LINE FAULT
34	8-Jul-22	BAGALKOT	110	VAJRA220-BILAGI	BILAGI_110	20:42	20:57	0:15	LINE FAULT
35	8-Jul-22	BAGALKOT	110	VAJRA220-KATARKI	KATARKI_110	17:34	17:43	0:09	HAND TRIPPED
36	8-Jul-22	BAGALKOT	110	VAJRAMATTI220-KATARAKI	KATARAKI_110	17:34	17:43	0:09	HAND TRIPPED
37	8-Jul-22	BAGALKOT	110	VAJRAMATTI220-SHIRAGUPPI	SHIRAGUPPI_110, BILAGI_110 GIRISAGAR_110, TOLAMATTI_110, BISNAL_110.	20:42	20:57	0:15	LINE FAULT
38	8-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED GHATAPRABHA_220	13:49	18:23	4:34	LINE CLEAR AVAILED
39	8-Jul-22	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED BELGAVI_220	11:48	17:43	5:55	LINE CLEAR AVAILED
40	8-Jul-22	BAGALKOT	220	MUGALKHOD-GHATAPRABHA-1	STATION OT AFFECTED MUGALKHOD_220	10:23	11:52	1:29	NFBC ISSUED

				1	STATION OT AFFECTED			I	
41	8-Jul-22	BAGALKOT	220	MUGALKHOD-GHATAPRABHA-2	MUGALKHOD_220	11:56	13:16	1:20	NFBC ISSUED
42	8-Jul-22	BAGALKOT	220	NARENDRA-BIDNAL	STATION NOT AFFECTED NARENDRA_220	20:22 (05.07.2022)	19:12 (08.07.2022)	70:50 hrs	LINE CHARGED
43	8-Jul-22	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	8:58	9:06	0:07	LINE FAULT
44	8-Jul-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	6:55	7:09	0:14	LINE FAULT
45	8-Jul-22	BENGALURU	66	DALASANUR - SRINIVASPURA	YELDUR	13:21	13:37	0:16	LINE CLEAR AVAILED
46	8-Jul-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	11:51	11:57	0:06	MAIN SUPPLY FAILURE
47	8-Jul-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:51	11:57	0:06	MAIN SUPPLY FAILURE
48	8-Jul-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	17:24	17:28	0:04	LOAD CHANGE OVER
49	8-Jul-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT), DODDABELAVANGALA	11:51	11:57	0:06	MAIN SUPPLY FAILURE
50	8-Jul-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	17:24	17:28	0:04	LOAD CHANGE OVER
51	8-Jul-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	11:51	11:57	0:06	MAIN SUPPLY FAILURE
52	8-Jul-22	BENGALURU	66	ELITA PROMENENDE - KHODAYS 220	ELITA PROMENENDE	7:57	8:02	0:05	LOAD CHANGE OVER
53	8-Jul-22	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA, YEDUMADU	13:30	13:35	0:05	LOAD CHANGE OVER
54	8-Jul-22	BENGALURU	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	10:22	10:36	0:14	MAIN SUPPLY FAILURE
55	8-Jul-22	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	10:53	11:04	0:11	LINE FAULT
56	8-Jul-22	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	10:22	10:36	0:14	MAIN SUPPLY FAILURE
57	8-Jul-22	BENGALURU	66	HV1	CHATRA	7:56	8:26	0:30	TRANSFORMER FAULT
58	8-Jul-22	BENGALURU	66	HV1	CHATRA	11:05	11:10	0:05	TRANSFORMER FAULT
59	8-Jul-22	BENGALURU	66	HV1	HONNIGANAHALLI	14:35	18:48	4:13	LINE CLEAR AVAILED
60	8-Jul-22	BENGALURU	66	HV1	HULLENAHALLI	14:10	14:15	0:05	LINE CLEAR AVAILED
61	8-Jul-22	BENGALURU	66	HV2	HONNIGANAHALLI	18:12	18:48	0:35	LINE CLEAR AVAILED
62	8-Jul-22	BENGALURU	66	HV2	HUKUNDA	14:06	14:20	0:13	TRANSFORMER FAULT
63	8-Jul-22	BENGALURU	66	HV2	HULLENAHALLI	9:52	9:57	0:05	TRANSFORMER FAULT
64	8-Jul-22	BENGALURU	66	HV2	HULLENAHALLI	11:05	11:10	0:05	TRANSFORMER FAULT
65	8-Jul-22	BENGALURU	66	HV2	HULLENAHALLI	12:38	12:43	0:05	TRANSFORMER FAULT
66	8-Jul-22	BENGALURU	66	HV2	YEDUMADU	23:12	23:19	0:06	TRANSFORMER FAULT
67	8-Jul-22	BENGALURU	66	HV3	NRS 220	12:13	12:33	0:20	LINE CLEAR AVAILED

	T				T			т	1
68	8-Jul-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	8:58	9:06	0:08	LINE FAULT
69	8-Jul-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	8:47	9:10	0:23	LINE FAULT
70	8-Jul-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	8:36	10:25	1:48	LINE CLEAR AVAILED
71	8-Jul-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	7:55	7:58	0:03	LOAD CHANGE OVER
72	8-Jul-22	BENGALURU	66	SOMENAHALLI - AFTL (IPP)	NO STATION AFFECTED	15:17	15:24	0:07	LINE FAULT
73	8-Jul-22	BENGALURU	66	TADIGOLU CROSS - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	10:05	10:15	0:10	LINE FAULT
74	8-Jul-22	BENGALURU	220	HV2	HSR LAYOUT 220	10:22	13:26	3:04	TRANSFORMER FAULT
75	8-Jul-22	BENGALURU	220	LV2	DB PURA 220	11:51	11:56	0:05	MAIN SUPPLY FAILURE
76	8-Jul-22	GULBARGA	66	HV2	HALVAGALU_66	12:40	12:50	0:10	TRANSFORMER FAULT
77	8-Jul-22	GULBARGA	66	HV2	HALVAGALU_66	14:15	14:20	0:05	TRANSFORMER FAULT
78	8-Jul-22	GULBARGA	66	ITTAGI-RENEWSOLAR12 IPP	ITTAGI 220	8:15	8:22	0:07	LINE FAULT
79	8-Jul-22	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJ AINI_66	10:35	10:40	0:05	LINE FAULT
80	8-Jul-22	GULBARGA	66	PUNABGATTA-NEELGUNDA	PUNABGATTA_66, UCHCHANGIDURGA_66,BILCHOD_66,UJJ AINI_66	12:00	12:15	0:15	LINE CLEAR AVAILED
81	8-Jul-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110,KAMALA NAGAR_110	3:20	3:30	0:10	MAIN SUPPLY FAILURE
82	8-Jul-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110,KAMALA NAGAR_110	4:05	4:10	0:05	MAIN SUPPLY FAILURE
83	8-Jul-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110,KAMALA NAGAR_110	4:45	4:50	0:05	MAIN SUPPLY FAILURE
84	8-Jul-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BH ALKI SUGAR_IPP	5:48 (08/07/2022)			LINE OPEN:LINE FAULT
85	8-Jul-22	GULBARGA	110	HATTI-SOMANAMARADI	HATTI_110	8:37	17:24	8:47	LINE CLEAR AVAILED
86	8-Jul-22	GULBARGA	110	HV2	HATTI_110	12:28	12:35	0:07	TRANSFORMER FAULT
87	8-Jul-22	GULBARGA	110	HV2	HATTI_110	13:33	13:36	0:03	TRANSFORMER FAULT
88	8-Jul-22	GULBARGA	110	HV2	HATTI_110	18:14	18:18	0:04	TRANSFORMER FAULT
89	8-Jul-22	GULBARGA	110	HV2	MATAMARI_110	15:40	15:45	0:05	TRANSFORMER FAULT
90	8-Jul-22	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	3:48	3:53	0:05	LINE FAULT
91	8-Jul-22	GULBARGA	110	KAPNOOR-ALAND	ALAND 110,KADAGANCHI 110	6:24	6:31	0:07	LINE FAULT
92	8-Jul-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSL SUGAR FACTORY_IPP, CHOWDAPUR_110CHOUDAPUR_110.	5:54	6:04	0:10	LINE FAULT
93	8-Jul-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110, NSL SUGAR FACTORY_IPP, CHOWDAPUR_110CHOUDAPUR_110.	23:08	23:14	0:06	LINE FAULT
94	8-Jul-22	GULBARGA	110	LINGASUGUR-KPRL_IPP	LINGASUGUR_220	9:20	13:40	4:20	LINE CLEAR AVAILED
95	8-Jul-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	3:05	3:15	0:10	LINE FAULT

96	8-Jul-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	20:48	20:58	0:10	LINE FAULT
97	8-Jul-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:34	20:44	0:10	LINE FAULT
98	8-Jul-22	GULBARGA	110	MUDDAPUR-MASKI	MUDDAPUR_110	0:06	0:12	0:06	LINE FAULT
99	8-Jul-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	9:20	9:30	0:10	LINE FAULT
100	8-Jul-22	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	23:15	23:30	0:15	LINE FAULT
101	8-Jul-22	GULBARGA	110	NANDOOR-SHAHBAD	NANDOOR_110	8:02	8:13	0:11	MAIN SUPPLY FAILURE
102	8-Jul-22	GULBARGA	110	SASTHAPUR-LADHA	SASTHAPUR_110	5:05	5:20	0:15	MAIN SUPPLY FAILURE
103	8-Jul-22	GULBARGA	110	SASTHAPUR-LADHA	SASTHAPUR_110	6:20	7:10	0:50	MAIN SUPPLY FAILURE
104	8-Jul-22	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	20:55	21:15	0:20	LINE FAULT
105	8-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVAN GAON_110,RENUKA_IPP,AFZALPUR_110, KARAJAGI_110	23:50	23:59	0:09	LINE FAULT
106	8-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	20:37	20:42	0:05	LINE FAULT
107	8-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
108	8-Jul-22	GULBARGA	110	SHAHABAD-FARATHABAD	FARTHABAD_110,GULBARGA SOUTH_110	8:00	8:10	0:10	LINE FAULT
109	8-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
110	8-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
111	8-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:55	22:01	0:06	LINE FAULT
112	8-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:40	23:48	0:08	LINE FAULT
113	8-Jul-22	GULBARGA	110	SINDNOOR_MUNIRABAD2	MUKUNDA_110,YARADONA_110,BENNU R_110,BTPS WATER WORK,KAMPLI_110	3:30	3:40	0:10	LINE FAULT
114	8-Jul-22	GULBARGA	110	SINDNOOR_MUNIRABAD2	MUKUNDA_110,YARADONA_110,BENNU R_110,BTPS WATER WORK,KAMPLI_110	23:50(08.07.022)			LINE OPEN:LINE FAULT
115	8-Jul-22	GULBARGA	110	SINDNOOR_SUZALON _IPP	SINDHANOOR_220	2:35	2:50	0:15	LINE FAULT
116	8-Jul-22	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	8:15	8:45	0:30	MAIN SUPPLY FAILURE
117	8-Jul-22	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	20:34	20:44	0:10	MAIN SUPPLY FAILURE
118	8-Jul-22	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	6:05	6:25	0:20	MAIN SUPPLY FAILURE
119	8-Jul-22	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	6:35	6:55	0:20	MAIN SUPPLY FAILURE
120	8-Jul-22	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	3:25	3:40	0:15	MAIN SUPPLY FAILURE
121	8-Jul-22	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12			LINE OPEN:LINE CLEAR AVAILED
122	8-Jul-22	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45			LINE OPEN:LINE CLEAR AVAILED
123	8-Jul-22	GULBARGA	220	HV1 & HV2	HALBARGA_220	5:48	6:15	0:27	TRANSFORMER FAULT
124	8-Jul-22	GULBARGA	220	HV1 & HV2	HALBARGA_220	6:20	6:40	0:20	TRANSFORMER FAULT
125	8-Jul-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	1:48	2:05	0:17	LINE FAULT
126	8-Jul-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	5:14	5:26	0:12	LINE FAULT
127	8-Jul-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	22:35	22:50	0:15	LINE FAULT
128	8-Jul-22	HASSAN	66	HV1	RAMESHWARNAGAR_66	10:37	16:51	6:14	LINE CLEAR AVAILED
129	8-Jul-22	HASSAN	66	HV1	SALGAME_66	10:41	11:58	1:17	LINE CLEAR AVAILED
130	8-Jul-22	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
131	8-Jul-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
132	8-Jul-22	HASSAN	66	HV2	MATTANAVILE_66	15:20	15:33	0:13	LINE CLEAR AVAILED

133	8-Jul-22	HASSAN	66	HV2	RAMESHWARNAGAR_66	10:37	14:42	4:05	LINE CLEAR AVAILED
134	8-Jul-22	HASSAN	66	HV2	RAMESHWARNAGAR_66	16:45	18:03	1:18	LINE CLEAR AVAILED
135	8-Jul-22	HASSAN	66	HV2	S.BELAGOLA_66	14:18	14:37	0:19	LINE CLEAR AVAILED
136	8-Jul-22	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	10:36	14:27	3:51	LINE CLEAR AVAILED
137	8-Jul-22	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	10:38	14:29	3:51	LINE CLEAR AVAILED
138	8-Jul-22	HASSAN	66	SALAGAM-HIREMANGLUR	SALGAME_66	10:44	11:57	1:13	LINE CLEAR AVAILED
139	8-Jul-22	HASSAN	66	SALAGAM-UDURKOPPLU	SALGAME_66	10:44	11:54	1:10	LINE CLEAR AVAILED
140	8-Jul-22	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	10:40	13:26	2:46	LINE CLEAR AVAILED
141	8-Jul-22	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	11:07	11:56	0:49	LINE CLEAR AVAILED
142	8-Jul-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	7:32	7:50	0:18	LINE FAULT
143	8-Jul-22	HASSAN	110	HV2	BARANGI_110	12:00	15:07	3:07	LINE CLEAR AVAILED
144	8-Jul-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
145	8-Jul-22	HASSAN	110	HV2	KAVOOR_220	10:08	17:29	7:21	LINE CLEAR AVAILED
146	8-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
147	8-Jul-22	HASSAN	110	JOG-JST2	mghejog_gen	5:45	6:26	0:41	LINE FAULT
148	8-Jul-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	7:32	7:49	0:17	LINE FAULT
149	8-Jul-22	HASSAN	110	LV2	SHIRALKOPPA_220	6:39	16:48	10:09	LINE CLEAR AVAILED
150	8-Jul-22	HASSAN	110	MRSSHM-SS1	MRSMG_220	17:55	18:15	0:20	HAND TRIPPED
151	8-Jul-22	HASSAN	220	GERSOPA-STRP1	gerusoppa_gen	22:00(09.07.2022)			LINE OPEN:LINE FAULT
152	8-Jul-22	HASSAN	220	HGUNJE-Varahi1	HEGGUNJE_220	7:57	18:54	10:57	LINE FAULT
153	8-Jul-22	HASSAN	220	HV2	SHIRALKOPPA_220	6:39	16:48	10:09	LINE CLEAR AVAILED
154	8-Jul-22	HASSAN	220	MRSSHM-GEROSOPPA1	MRSMG_220	22:00 (8.07.2022)			LINE OPEN:LINE FAULT
155	8-Jul-22	HASSAN	220	VARAHI-KEMAR3	varahi_gen	7:57	18:54	10:57	LINE FAULT
156	8-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
157	8-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
158	8-Jul-22	MYSURU	66	HV1	AYRALLI_66	23:30	23:40	0:10	TRANSFORMER FAULT
159	8-Jul-22	MYSURU	66	HV1	COWDALLI_66	9:35	13:20	3:45	LINE CLEAR AVAILED
160	8-Jul-22	MYSURU	66	HV1	LOKKANAHALLI_66	14:40	17:15	2:35	LINE CLEAR AVAILED
161	8-Jul-22	MYSURU	66	HV1	PGPALYA_66	10:31	17:24	6:52	LINE CLEAR AVAILED
162	8-Jul-22	MYSURU	66	HV2	COWDALLI_66	9:35	10:15	0:40	LINE CLEAR AVAILED
163	8-Jul-22	MYSURU	66	HV2	SATHEGALA_66	14:37	18:22	3:45	LINE CLEAR AVAILED
164	8-Jul-22	MYSURU	66	LOKKANAHALLI-PG PALYA	PGPALYA_66	15:05	15:20	0:15	LINE CLEAR AVAILED
165	8-Jul-22	MYSURU	66	LOKKANAHALLI-PG PALYA	PGPALYA_66	17:00	17:15	0:15	LINE CLEAR AVAILED
166	8-Jul-22	MYSURU	66	VYASARAJAPURA-TUMBLA	GARGESHWARI_66 VYSARAJAPURA_66 TNARASIPURA_66	3:11	3:32	0:21	LINE FAULT
167	8-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
168	8-Jul-22	MYSURU	66	HV1	BGPURA_66	12:29	12:44	0:15	HAND TRIPPED
169	8-Jul-22	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	10:11	10:33	0:22	MAIN SUPPLY FAILURE
170	8-Jul-22	TUMKUR	66	GARAGA66-MATHOD66	GARAGA_66	12:51	13:12	0:21	LINE FAULT

171	8-Jul-22	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66,	12:42	14:15	1:33	LINE CLEAR AVAILED
172	8-Jul-22	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KARGIL_EHT_66 KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE 66	12:42	14:15	1:33	LINE CLEAR AVAILED
173	8-Jul-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	11:37	11:50	0:13	LINE FAULT
174	8-Jul-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	10:06	18:09	8:02	LINE CLEAR AVAILED
175	8-Jul-22	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	10:06	18:09	8:02	LINE CLEAR AVAILED
176	8-Jul-22	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	10:06	18:09	8:02	LINE CLEAR AVAILED
177	8-Jul-22	TUMKUR	66	PDKOTE66-HIRIYUR_66	PD KOTE_66	10:08	17:31	7:22	LINE CLEAR AVAILED
178	8-Jul-22	TUMKUR	66	TR-1	PD KOTE_66	10:07	17:40	7:32	LINE CLEAR AVAILED
179	8-Jul-22	TUMKUR	66	TR-1	SASALUHALLA_66	13:00:00 PM(28.06.2022			TRANSFORMER OPEN:TRANSFORMER FAULT
180	8-Jul-22	TUMKUR	66	TR-2	PD KOTE_66	10:07	17:40	7:32	LINE CLEAR AVAILED
181	9-Jul-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED ANKALI_110	11:40	12:30	0:50	TRANSFORMER FAULT
182	9-Jul-22	BAGALKOT	110	110/11KV, HV5	STATION NO AFFECTED UMMACHAGI_110	16:50	17:20	0:30	LINE CLEAR AVAILED
183	9-Jul-22	BAGALKOT	110	110/11KV,HV1	DEVAR GENNUR_110	7:04	7:18	0:14	HAND TRIPPED
184	9-Jul-22	BAGALKOT	110	110/11KV,HV1	KAMBAGI_110	21:09	21:31	0:22	TRANSFORMER FAULT
185	9-Jul-22	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	12:14	12:45	0:31	LINE CLEAR AVAILED
186	9-Jul-22	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	17:39	17:48	0:09	TRANSFORMER FAULT
187	9-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
188	9-Jul-22	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	12:18	12:23	0:05	HAND TRIPPED
189	9-Jul-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
190	9-Jul-22	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	3:37	3:46	0:09	LINE CLEAR AVAILED
191	9-Jul-22	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	6:04	6:28	0:24	LINE FAULT
192	9-Jul-22	BAGALKOT	110	BELGAUM110-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED
193	9-Jul-22	BAGALKOT	110	GHATAPRABHA220-SOEPL(SURYODAYA SOLAR)	SURYODAYA SOLAR_110 STATION NOT AFFECTED GHATAPRABHA_220	5:45	7:10	1:25	LINE FAULT
194	9-Jul-22	BAGALKOT	110	GHATAPRABHA220-SOEPL(SURYODAYA SOLAR)	SURYODAYA SOLAR_110 STATION NOT AFFECTED GHATAPRABHA_220	10:49	10:58	0:09	LINE FAULT
195	9-Jul-22	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	5:55	6:13	0:18	LINE FAULT
196	9-Jul-22	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	5:55	6:13	0:18	LINE FAULT
197	9-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN:LINE FAULT
198	9-Jul-22	BAGALKOT	110	KUDACHI220-KUDACHI (AINAPUR)	KUDACHI_220	10:40	12:15	1:35	LINE CLEAR AVAILED
199	9-Jul-22	BAGALKOT	110	KUDHARWAD-LAKKAMANAHALLI	KUD DHARWAD_110 LAKKAMANAHALLI_110	15:45	16:28	0:43	MAIN SUPPLY FAILURE
200	9-Jul-22	BAGALKOT	110	KUDHARWAD-LAKKAMANAHALLI	LAKKAMANAHALLI_110	15:15	16:27	1:12	LINE FAULT
201	9-Jul-22	BAGALKOT	110	MUGALKHOD220-SULTANPUR	SULTANPUR_110	4:40	4:54	0:14	LINE FAULT
202	9-Jul-22	BAGALKOT	110	NARENDRA220-KUDHARWAD	KUDHARWAD_110 LAKKAMANAHALLI_110	15:15	15:40	0:25	LINE FAULT
203	9-Jul-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED

204	9-Jul-22	BAGALKOT	110	SAVANUR-SHIGGAON	SHIGGAON_110	5:55	6:15	0:20	LINE FAULT
205	9-Jul-22	BAGALKOT	110	SIRSI-KUMATA2	KUMATA_110	12:53	13:37	0:44	LINE FAULT
206	9-Jul-22	BAGALKOT	220	BAGALKOT - ADPH-1	STATION NOT AFFECTED BAGALKOT_220	11:47	12:12	0:25	HAND TRIPPED
207	9-Jul-22	BAGALKOT	220	HUBLI-NAGAZARI-2	STATION NOT AFFECTED HUBLI_220	12:53	13:51	0:58	LINE FAULT
208	9-Jul-22	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	14:40	14:50	0:10	LINE FAULT
209	9-Jul-22	BENGALURU	66	HV1	CHANDRAPPA CIRCLE	17:00	17:05	0:05	TRANSFORMER FAULT
210	9-Jul-22	BENGALURU	66	HV2	KADUGODI	14:06	14:08	0:02	LINE CLEAR AVAILED
211	9-Jul-22	BENGALURU	66	HV2	KONDASPURA	14:12	14:35	0:23	LINE CLEAR AVAILED
212	9-Jul-22	BENGALURU	66	HV2	YELDUR	11:15	12:00	0:45	LINE CLEAR AVAILED
213	9-Jul-22	GULBARGA	66	HV2	HALVAGALU_66	13:05	13:10	0:05	TRANSFORMER FAULT
214	9-Jul-22	GULBARGA	66	UJJAINI-BREIPL_IPP	UJJAINI_66	14:28	14:40	0:12	LINE CLEAR AVAILED
215	9-Jul-22	GULBARGA	110	AURAD-DONGARGOA	DONGARGOA_110,KAMALANAGAR_110	6:20	6:30	0:10	LINE FAULT
216	9-Jul-22	GULBARGA	110	AURAD-DONGARGOA	DONGARGOA_110,KAMALANAGAR_110	12:50	12:55	0:05	LINE FAULT
217	9-Jul-22	GULBARGA	110	AURAD-DONGARGOA	DONGARGOA_110,KAMALANAGAR_110	13:05	13:40	0:35	LINE FAULT
218	9-Jul-22	GULBARGA	110	AURAD-DONGARGOA	DONGARGOA_110,KAMALANAGAR_110	14:05	14:40	0:35	LINE FAULT
219	9-Jul-22	GULBARGA	110	AURAD-DONGARGOA	DONGARGOA_110,KAMALANAGAR_110	18:25	18:40	0:15	LINE FAULT
220	9-Jul-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	0:56	1:00	0:04	LINE FAULT
221	9-Jul-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	3:07	3:10	0:03	LINE FAULT
222	9-Jul-22	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	3:34	3:50	0:16	LINE FAULT
223	9-Jul-22	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	4:54	4:59	0:05	LINE FAULT
224	9-Jul-22	GULBARGA	110	HATTI-SOMANAMARADI	HATTI_110	10:00	13:56	3:56	LINE CLEAR AVAILED
225	9-Jul-22	GULBARGA	110	HUMANABAD-MANEKAHALLI	MANEKAHALLI_110	5:44	11:40	5:56	LINE FAULT
226	9-Jul-22	GULBARGA	110	HUMANABAD-MANEKAHALLI	MANEKAHALLI_110	23:27	23:32	0:05	LINE FAULT
227	9-Jul-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	4:53(09.7.2022)			LINE OPEN:LINE FAULT
228	9-Jul-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	3:45	3:50	0:05	LINE FAULT
229	9-Jul-22	GULBARGA	110	HV1	MADIYAL_110	18:00(09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
230	9-Jul-22	GULBARGA	110	HV1,HV2	SHAKTINAGAR_110	14:30	15:57	1:27	LINE CLEAR AVAILED
231	9-Jul-22	GULBARGA	110	HV2	DEODURGA_110	12:05	12:15	0:10	TRANSFORMER FAULT
232	9-Jul-22	GULBARGA	110	LV3	MUNIRABAD_220	12:35	14:53	0.10	LINE CLEAR AVAILED
233	9-Jul-22	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	5:15	5:20	0:05	LINE FAULT
234	9-Jul-22	GULBARGA	110	RACIHUR-SHAHAPUR2	GOOGAL_110	19:03	19:10	0:07	LINE FAULT
235	9-Jul-22	GULBARGA	110	RACIHUR-SINDHNOOR1	SIRWAR_110	0:45	1:00	0:15	LINE FAULT
236	9-Jul-22	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	5:45	5:55	0:10	LINE FAULT
237	9-Jul-22	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	5:50	6:00	0:10	LINE FAULT

				I	MADEWAL 110,MORATAGI 110,DEVAN				
238	9-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI1	GAON_110,RENUKA_IPP,AFZALPUR_110, KARAJAGI_110	5:45	5:50	0:05	LINE FAULT
239	9-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	2:12	2:15	0:03	LINE FAULT
240	9-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
241	9-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
242	9-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
243	9-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	22:05	22:11	0:06	LINE FAULT
244	9-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:30	21:38	0:08	LINE FAULT
245	9-Jul-22	GULBARGA	110	SINDNOOR_MUNIRABAD2	MUKUNDA_110,YARADONA_110,BENNU R_110,BTPS WATER WORK,KAMPLI_110	23:50(08.07.022)	00:15(09.07.2022)	00:25HRS	LINE CHARGED
246	9-Jul-22	GULBARGA	110	SINDNOOR_SUZALON _IPP	SINDHANOOR_220	0:30	0:40	0:10	LINE FAULT
247	9-Jul-22	GULBARGA	110	SINDNOOR_SUZALON_IPP	SINDHANOOR_220	1:30	1:45	0:15	LINE FAULT
248	9-Jul-22	GULBARGA	110	SINDNOOR_SUZALON _IPP	SINDHANOOR_220	20:56	21:16	0:20	LINE FAULT
249	9-Jul-22	GULBARGA	110	WAJRABANDI-YELBURGA	YELBURGA_110,KUKUNOOR_110	8:40	11:53	3:13	LINE CLEAR AVAILED
250	9-Jul-22	GULBARGA	110	YELBURGA- TALAKUTAI_IPP,PARAMPOOJYA_IPP	YELBURGA_110	8:40	12:18	3:38	LINE CLEAR AVAILED
251	9-Jul-22	GULBARGA	110	YERADONA-MASKI	YERADONA_110	23:59	0:15	0:15	MAIN SUPPLY FAILURE
252	9-Jul-22	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12			LINE OPEN:LINE CLEAR AVAILED
253	9-Jul-22	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45			LINE OPEN:LINE CLEAR AVAILED
254	9-Jul-22	GULBARGA	220	HV1	HALBARGA_220	14:10	14:32	0:22	TRANSFORMER FAULT
255	9-Jul-22	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	1:31	1:51	0:20	LINE FAULT
256	9-Jul-22	GULBARGA	220	SHAHABAD-KAPNOOR	SHAHABAD_220	5:55	6:20	0:25	LINE FAULT
257	9-Jul-22	GULBARGA	400	BTPS-RTPS	BTPS_400	4:14(09.07.2022)			LINE OPEN:LINE FAULT
258	9-Jul-22	GULBARGA	400	BTPS-RTPS	BTPS_400	4:14(09.07.2022)	11:38(11.07.2022)	55:23HRS	LINE CHARGED
259	9-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
260	9-Jul-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	12:57	13:10	0:13	LINE FAULT
261	9-Jul-22	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
262	9-Jul-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
263	9-Jul-22	HASSAN	66	HV2	UDAYAPURA_66	23:09	23:34	0:25	TRANSFORMER FAULT
264	9-Jul-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	13:11	13:38	0:27	LINE FAULT
265	9-Jul-22	HASSAN	110	ANANDA-SHIMOGA	ANANDPURA_110	17:55	18:15	0:20	LINE CLEAR AVAILED
266	9-Jul-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
267	9-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
268	9-Jul-22	HASSAN	220	GERSOPA-STRP1	gerusoppa_gen	22:00(09.07.2022)			LINE OPEN:LINE FAULT
269	9-Jul-22	HASSAN	220	HV3	KAVOOR_220	20:10	20:29	0:19	TRANSFORMER FAULT
270	9-Jul-22	HASSAN	220	HV3	KAVOOR_220	23:12	23:18	0:06	TRANSFORMER FAULT
271	9-Jul-22	HASSAN	220	KAVOOR-MSEZ1	KAVOOR_220	23:12(09.07.2022)			LINE OPEN:LINE CLEAR AVAILED
272	9-Jul-22	HASSAN	220	MRSSHM-GEROSOPPA1	MRSMG_220	22:00 (8.07.2022)			LINE OPEN:LINE FAULT
	9-Jul-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	23:12(09.07.2022)	I		LINE OPEN:LINE FAULT

274	9-Jul-22	MYSURU	66	CR NAGAR-HONNAHALLI	HONNALLIO_66 ARAKALAVADI_66 ATTIGULIPURA 66	12:01	12:13	0:11	LINE FAULT
275	9-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
276	9-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
277	9-Jul-22	MYSURU	66	HV1	DODAINDUVADI_66	12:07	14:03	1:55	LINE CLEAR AVAILED
278	9-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	9:00	9:55	0:55	TRANSFORMER FAULT
279	9-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	9:55	12:33	2:38	LINE CLEAR AVAILED
280	9-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	13:31	13:58	0:27	TRANSFORMER FAULT
281	9-Jul-22	MYSURU	66	HV1	MADHUVANAHALLI_66	10:15	16:00	5:45	LINE CLEAR AVAILED
282	9-Jul-22	MYSURU	66	HV2	GUNDLUPETE_66	9:55	12:33	2:38	LINE CLEAR AVAILED
283	9-Jul-22	MYSURU	66	HV2	GUNDLUPETE_66	12:55	13:05	0:10	HAND TRIPPED
284	9-Jul-22	MYSURU	66	HV2	GUNDLUPETE_66	13:30	14:00	0:30	TRANSFORMER FAULT
285	9-Jul-22	MYSURU	66	HV2	MADHUVANAHALLI_66	14:02	19:48	5:46	LINE CLEAR AVAILED
286	9-Jul-22	MYSURU	66	JAKKANAHALLLI-NAGMANGLA	GMALLIGERE_66	7:20	7:25	0:04	LINE FAULT
287	9-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
288	9-Jul-22	MYSURU	220	KUSHALNAGARA-BASTIPURA1	NO STATIONS EFFECTED	10:51	11:25	0:34	HAND TRIPPED
289	9-Jul-22	MYSURU	220	KUSHALNAGARA-BASTIPURA1	NO STATIONS EFFECTED	11:25	16:38	5:13	LINE CLEAR AVAILED
290	9-Jul-22	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	10:10	16:41	6:31	LINE CLEAR AVAILED
291	9-Jul-22	TUMKUR	66	HIRIYUR 220KV-PARSHAMPURA_66	HIRIYUR_220	14:45	15:01	0:16	LINE FAULT
292	9-Jul-22	TUMKUR	66	HIRIYUR 220KV-PARSHAMPURA_66	HIRIYUR_220	3:01:00 PM(09.07.2022)			LINE OPEN:LINE FAULT
293	9-Jul-22	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE_66	6:43	6:54	0:11	LINE FAULT
294	9-Jul-22	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66,HOLAVINAHALLY_66	18:38	18:49	0:11	LINE FAULT
295	9-Jul-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	13:53	14:08	0:15	LINE FAULT
296	9-Jul-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	7:25	7:35	0:10	TRANSFORMER FAULT
297	9-Jul-22	TUMKUR	66	TR-1	SASALUHALLA_66	13:00:00 PM(28.06.2022			TRANSFORMER OPEN:TRANSFORMER FAULT
298	9-Jul-22	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	10:35	14:05	3:30	LINE CLEAR AVAILED
299	9-Jul-22	TUMKUR	66	TR-2	CHANNAGIRI_66	14:07	14:14	0:06	TRANSFORMER FAULT
300	10-Jul-22	BAGALKOT	110	110/11KV, HV1	SAMBAPUR_110	2:06	9:25	7:19	TRANSFORMER FAULT
301	10-Jul-22	BAGALKOT	110	110/11KV,HV1	KADAKLAT_110	15:03	15:31	0:28	TRANSFORMER FAULT
302	10-Jul-22	BAGALKOT	110	110/11KV,HV1	KADAKLAT_110	15:44 (10.7.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
303	10-Jul-22	BAGALKOT	110	110/11KV,HV1	KAMBAGI_110	18:28	18:40	0:12	TRANSFORMER FAULT
304	10-Jul-22	BAGALKOT	110	110/11KV,HV1	UCHAGOAN_110	9:11	10:07	0:56	LINE CLEAR AVAILED
305	10-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
306	10-Jul-22	BAGALKOT	110	110/33KV, HV4	STATION NOT AFFECTED MACHE_110	13:40	13:47	0:07	LINE CLEAR AVAILED
307	10-Jul-22	BAGALKOT	110	110/33KV,HV1	CHIKKODI_110 &KABBUUR_33	21:13	21:19	0:06	TRANSFORMER FAULT
308	10-Jul-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
309	10-Jul-22	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED

310	10-Jul-22	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	21:27	21:39	0:12	LINE FAULT
311	10-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN:LINE FAULT
312	10-Jul-22	BAGALKOT	110	KULAGERI-KONNUR	KULGERI CROSS_110	11:27	11:31	0:04	HAND TRIPPED
313	10-Jul-22	BAGALKOT	110	MKHUBLI220-KHANAPUR	KHANAPUR_110	8:32	9:03	0:31	LINE FAULT
314	10-Jul-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
315	10-Jul-22	BAGALKOT	110	SAVANUR-ASF Cbreaker	ASF_IPP SAVANUR_110	6:19	6:26	0:07	MAIN SUPPLY FAILURE
316	10-Jul-22	BAGALKOT	110	SAVANUR-ASF Cbreaker	ASF_IPP SAVANUR_110	6:19	6:26	0:07	MAIN SUPPLY FAILURE
317	10-Jul-22	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110 GIRISAGAR_110, TOLAMATTI_110, BISNAL_110.	1:35	1:45	0:10	LINE FAULT
318	10-Jul-22	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED ATHANI_220	9:41 (06.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
319	10-Jul-22	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)			LINE OPEN:LINE CLEAR AVAILED
320	10-Jul-22	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)			LINE OPEN:LINE CLEAR AVAILED
321	10-Jul-22	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	9:23	9:25	0:02	LOAD CHANGE OVER
322	10-Jul-22	BENGALURU	66	HV1	JIGANI 220	12:05	12:47	0:42	LINE CLEAR AVAILED
323	10-Jul-22	BENGALURU	66	HV1	SM MANGALA	9:42	10:04	0:21	TRANSFORMER FAULT
324	10-Jul-22	BENGALURU	66	HV2	GOWRIBIDANUR 220	14:08	14:16	0:08	TRANSFORMER FAULT
325	10-Jul-22	BENGALURU	66	HV2	MAASTHI	22:05	22:12	0:07	LINE CLEAR AVAILED
326	10-Jul-22	BENGALURU	66	HV2	MULABAGALU	2:02	3:04	1:02	TRANSFORMER FAULT
327	10-Jul-22	BENGALURU	66	KORMANGALA 220 - GOLF LINK HAL 1	NO STATION AFFECTED	12:02	12:23	0:21	LINE CLEAR AVAILED
328	10-Jul-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	15:17	15:22	0:04	LINE FAULT
329	10-Jul-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	11:09	11:24	0:15	LINE CLEAR AVAILED
330	10-Jul-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	5:55	6:06	0:11	LINE FAULT
331	10-Jul-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	17:56	18:10	0:14	LINE FAULT
332	10-Jul-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	14:07	14:22	0:15	LINE FAULT
333	10-Jul-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:56	18:16	0:20	LINE FAULT
334	10-Jul-22	BENGALURU	66	YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	9:22	9:32	0:10	LOAD CHANGE OVER
335	10-Jul-22	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	NO STATION AFFECTED	4:13	4:34	0:21	LINE FAULT
336	10-Jul-22	GULBARGA	110	AURAD-DONGARGOA	DONGARGOA_110,KAMALANAGAR_110	15:00	15:15	0:15	LINE FAULT
337	10-Jul-22	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARGOA_110,KAMALA NAGAR_110	18:50	18:55	0:05	MAIN SUPPLY FAILURE

338	10-Jul-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	8:02	8:05	0:03	LINE FAULT
339	10-Jul-22	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	5:49	6:10	0:21	LINE FAULT
340	10-Jul-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIG GI_110	18:50	18:56	0:06	LINE FAULT
341	10-Jul-22	GULBARGA	110	HATTI-SOMANAMARADI	HATTI_110	10:00	13:56	3:56	LINE CLEAR AVAILED
342	10-Jul-22	GULBARGA	110	HUMNABAD-HALIKED	HALIKED_110	5:51	5:59	0:08	LINE FAULT
343	10-Jul-22	GULBARGA	110	HV1	GALAG_110	10:20	10:45	0:25	TRANSFORMER FAULT
344	10-Jul-22	GULBARGA	110	HV1	GALAG_110	22:10	22:20	0:10	TRANSFORMER FAULT
345	10-Jul-22	GULBARGA	110	HV1	MADIYAL_110	18:00(09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
346	10-Jul-22	GULBARGA	110	HV2	SREERAMNAGAR_110	20:20	20:30	0:10	TRANSFORMER FAULT
347	10-Jul-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	22:10	22:20	0:10	LINE FAULT
348	10-Jul-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	19:24	19:34	0:10	LINE FAULT
349	10-Jul-22	GULBARGA	110	MUDDAPUR-SINDHANOOR	MUDDAPUR_110	0:40	0:45	0:05	MAIN SUPPLY FAILURE
350	10-Jul-22	GULBARGA	110	MUNIRABAD-HAGRI	SANKLAPUR_110,HAGRI_110,KAMALAP UR_110,RBSNN	18:13	18:23	0:10	LINE FAULT
351	10-Jul-22	GULBARGA	110	SEDAM-VICTSAGAR_IPP	VICATSAGARCEMNETS	5:05	5:15	0:10	LINE FAULT
352	10-Jul-22	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVAN GAON_110,RENUKA_IPP,AFZALPUR_110, KARAJAGI_110	19:45	19:52	0:07	LINE FAULT
353	10-Jul-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
354	10-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
355	10-Jul-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
356	10-Jul-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	1:32	1:41	0:09	LINE FAULT
357	10-Jul-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	18:14	18:23	0:09	LINE FAULT
358	10-Jul-22	GULBARGA	110	YERADONA-BENNUR	YERADONA_110	11:25	13:20	1:55	LINE CLEAR AVAILED
359	10-Jul-22	GULBARGA	220	HALAWARTHY-DHONI1	HALAWARTHY_220	7:12			LINE OPEN:LINE CLEAR AVAILED
360	10-Jul-22	GULBARGA	220	HALAWARTHY-DHONI2	HALAWARTHY_220	7:45			LINE OPEN:LINE CLEAR AVAILED
361	10-Jul-22	GULBARGA	220	HUMANABAD-KAPNOOR	HUMNABAD_220	1:17	7:06	5:49	LINE CLEAR AVAILED
362	10-Jul-22	GULBARGA	220	HV1	HALBARGA_220	2:40	5:05	2:25	TRANSFORMER FAULT
363	10-Jul-22	GULBARGA	220	HV1	HALBARGA_220	5:56	7:56	2:00	TRANSFORMER FAULT
364	10-Jul-22	GULBARGA	220	SHAHABAD-KAPNOOR	SHAHABAD_220	5:55	6:20	0:25	LINE FAULT
365	10-Jul-22	GULBARGA	400	BTPS-RTPS	BTPS_400	4:14(09.07.2022)	11:38(11.07.2022)	55:23HRS	LINE CHARGED
366	10-Jul-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
367	10-Jul-22	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	21:44(10.7.2022)			LINE OPEN:LINE CLEAR AVAILED
368	10-Jul-22	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
369	10-Jul-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
370	10-Jul-22	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	10:47(10.07.2022)			LINE OPEN:LINE FAULT
371	10-Jul-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
372	10-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
373	10-Jul-22	HASSAN	220	GERSOPA-STRP1	gerusoppa_gen	22:00(09.07.2022)			LINE OPEN:LINE FAULT
374	10-Jul-22	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	8:01	11:52	3:51	LINE CLEAR AVAILED

375	10-Jul-22	HASSAN	220	KAVOOR-MSEZ1	KAVOOR_220	23:12(09.07.2022)	12:41(10.07.2022)	13:29HRS	LINE CHARGED
376	10-Jul-22	HASSAN	220	KEMAR-Varahi1	KEMAR_220	9:12	13:26	4:14	LINE FAULT
377	10-Jul-22	HASSAN	220	MRSSHM-GEROSOPPA1	MRSMG_220	22:00 (8.07.2022)			LINE OPEN:LINE FAULT
378	10-Jul-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	23:12(09.07.2022)	12:41(10.07.2022)	13:29HRS	LINE CHARGED
379	10-Jul-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	8:05	11:51	3:46	NFBC ISSUED
380	10-Jul-22	HASSAN	220	VARAHI-KEMAR1	varahi_gen	9:12	13:26	4:14	LINE FAULT
381	10-Jul-22	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:28(10.07.2022)			LINE OPEN:LINE CLEAR AVAILED
382	10-Jul-22	HASSAN	400	UPCL-HASSAN2	upcl_gen	1:31	7:38	6:07	LINE CLEAR AVAILED
383	10-Jul-22	MYSURU	66	DOORA-CHANDRAVADI	HULLALLI_66 HURA_66	6:45	6:50	0:05	LINE FAULT
384	10-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
385	10-Jul-22	MYSURU	66	HEBBANI-SATTEGALA	NO STATIONS EFFECTED	18:57	19:04	0:07	LINE FAULT
386	10-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
387	10-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	10:05:00 (10.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
388	10-Jul-22	MYSURU	66	HV1	THANDYA_66	7:30	12:51	5:21	TRANSFORMER FAULT
389	10-Jul-22	MYSURU	66	HV2	GUNDLUPETE_66	10:25	13:05	2:40	LINE CLEAR AVAILED
390	10-Jul-22	MYSURU	66	HV2	THANDYA_66	10:13	11:33	1:19	LINE CLEAR AVAILED
391	10-Jul-22	MYSURU	66	K HONNALAGERE-HV1	KHONNALAGERE_66 IGLURU_66	14:05	14:25	0:20	HAND TRIPPED
392	10-Jul-22	MYSURU	66	K M DODDI-K K DODDI	KOLKARANADODDI_66	17:44	18:15	0:31	LINE FAULT
393	10-Jul-22	MYSURU	66	K M DODDI-T K HALLI	KMDODDI_66	17:45	18:15	0:30	HAND TRIPPED
394	10-Jul-22	MYSURU	66	TALAGAVADI-MANDYA	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 SOMANAHALLI_66 TUMBEKERE _66 MADDUR_66	17:53	18:13	0:20	LINE FAULT
395	10-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
396	10-Jul-22	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	16:04			LINE OPEN:LINE CLEAR AVAILED
397	10-Jul-22	TUMKUR	66	HANAGAL-THALLAK	HANAGAL_66	21:45	22:10	0:25	LINE FAULT
398	10-Jul-22	TUMKUR	66	HANGAL66-RAMPURA	RAMPURA_66,NAGASAMUDRA_66	21:55	22:03	0:08	LINE FAULT
399	10-Jul-22	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	10:08	15:30	5:22	LINE CLEAR AVAILED
400	10-Jul-22	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	HIRIYUR_220	5:59	6:06	0:07	LINE FAULT
401	10-Jul-22	TUMKUR	66	HIRIYUR 220KV-PARSHAMPURA_66	HIRIYUR_220	3:01:00 PM(09.07.2022)	20:30(10.07.2022)	29:29	LINE CHARGED
402	10-Jul-22	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	12:11	12:21	0:10	LINE FAULT
403	10-Jul-22	TUMKUR	66	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE_66	12:37	12:50	0:13	LINE FAULT
404	10-Jul-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	18:04	18:16	0:12	LINE FAULT
405	10-Jul-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	18:30	18:40	0:10	LINE FAULT
406	10-Jul-22	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	18:41	20:51	2:10	LINE FAULT
407	10-Jul-22	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	12:50	12:55	0:05	LINE FAULT
408	10-Jul-22	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	13:54	13:58	0:04	LINE FAULT

409	10-Jul-22	TUMKUR	66	PULAMGHATTA_66-MADHUGIRI220	MADHUGIRI_220	18:55	19:25	0:30	LINE FAULT
410	10-Jul-22	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	21:44	21:55	0:11	LINE FAULT
411	10-Jul-22	TUMKUR	66	THALLAK 220kV -BGKERE 2	HANAGAL_66,BGKERE_66	21:44	22:08	0:24	LINE FAULT
412	10-Jul-22	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	11:10	14:01	2:51	LINE CLEAR AVAILED
413	10-Jul-22	TUMKUR	66	TR-1	SASALUHALLA_66	13:00(28.06.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
414	10-Jul-22	TUMKUR	66	TR-2	CHANNAGIRI_66	13:58	14:15	0:16	TRANSFORMER FAULT
415	10-Jul-22	TUMKUR	66	TR-3	ANTHRASANAHALLI_220	23:44	23:53	0:09	TRANSFORMER FAULT
416	11-Jul-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED BYADAGI_110	16:00	16:10	0:10	LINE CLEAR AVAILED
417	11-Jul-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TOLAMATTI_110	12:55	13:10	0:15	LINE CLEAR AVAILED
418	11-Jul-22	BAGALKOT	110	110/11KV, HV2	KADKLAT_110	18:48	20:48	2:00	TRANSFORMER FAULT
419	11-Jul-22	BAGALKOT	110	110/11KV,HV1	AHERI_220	16:15	16:40	0:25	LINE CLEAR AVAILED
420	11-Jul-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED DEVAR GENNUR_110	11:54	12:35	0:41	LINE CLEAR AVAILED
421	11-Jul-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED HIREMASALI_110	4:10	4:34	0:24	TRANSFORMER FAULT
422	11-Jul-22	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED HIREMASALI_110	6:11	17:10	10:59	TRANSFORMER FAULT
423	11-Jul-22	BAGALKOT	110	110/11KV,HV1&2	STATION NOT AFFECTED GULEDGUDD_110	16:28	18:23	1:55	LINE CLEAR AVAILED
424	11-Jul-22	BAGALKOT	110	110/11KV,HV1(HV2)	KADAKLAT_110	15:44 (10.7.2022)	13:04 (11.07.2022)	21:20	TRANSFORMER CHARGED
425	11-Jul-22	BAGALKOT	110	110/33KV, HV3	STATION NOT AFFECTED YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
426	11-Jul-22	BAGALKOT	110	110/33KV,HV3 &KAMATAGI,SHIRUR_33	STATION NOT AFFECTED GULEDGUDD_110	16:28	18:23	1:55	LINE CLEAR AVAILED
427	11-Jul-22	BAGALKOT	110	ALMEL-KPR SUGAR	ALMEL_110	4:59	5:02	0:03	HAND TRIPPED
428	11-Jul-22	BAGALKOT	110	ALMEL-KPR SUGAR	ALMEL_110	4:59	5:02	0:03	HAND TRIPPED
429	11-Jul-22	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:55 (23.05.2022)			LINE OPEN:LINE CLEAR AVAILED
430	11-Jul-22	BAGALKOT	110	ATHANI220-BALIGERI	BALIGERI_110	15:39	17:31	1:52	LINE CLEAR AVAILED
431	11-Jul-22	BAGALKOT	110	BAGALKOT220-GULEDGUDDA	GULEDGUDDA_110	14:02	14:15	0:13	HAND TRIPPED
432	11-Jul-22	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	10:50 (26.03.2022)			LINE OPEN:LINE CLEAR AVAILED
433	11-Jul-22	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA-2	STATION NOT AFFECTED GHATAPRABHA_220	11:14	11:40	0:26	LINE FAULT
434	11-Jul-22	BAGALKOT	110	ISMPR-F1CBreaker(ANKALAGI)	STATION NOT AFFECTED SLAMPUR_110	13:25 (01.07.2022)	13:03 (11.07.2022)	23:38	LINE CHARGED
435	11-Jul-22	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	8:50 (06.07.2022)			LINE OPEN:LINE FAULT
436	11-Jul-22	BAGALKOT	110	KUDACHI220-TERDAL (MORAB)	MORAB_110	4:37	4:49	0:12	LINE FAULT
437	11-Jul-22	BAGALKOT	110	KUDACHI220-TERDAL (MORAB)	MORAB_110	23:59 (11.07.2022)			LINE OPEN:LINE FAULT
438	11-Jul-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN:LINE CLEAR AVAILED
439	11-Jul-22	BAGALKOT	110	SIRSI-JOG2	STATION NOT AFFECTED SIRSI_110	9:30 (04.04.2022)	13:13 (11.07.2022)	2355:43 hrs	LINE CHARGED

		1		T				ı	
440	11-Jul-22	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI 220	20:00 (09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
					STATION NOT AFFECTED	9:41			TRANSFORMER OPEN:LINE CLEAR
441	11-Jul-22	BAGALKOT	220	220/110KV, HV3	ATHANI 220	(06.07.2022)			AVAILED
442	11-Jul-22	BAGALKOT	220	220/110KV, HV-4	STATION NOT AFFECTED GADAG_220	8:13	17:58	9:45	LINE CLEAR AVAILED
443	11-Jul-22	BAGALKOT	220	220/110KV,HV1 & LV1	STATION NOT AFFECTED KUDACHI_220	13:07	13:44	0:37	LINE CLEAR AVAILED
444	11-Jul-22	BAGALKOT	220	HUBLI-NAGZARI-1	STATION NOT AFFECTED HUBLI_220	8:59	9:50	0:51	LINE FAULT
445	11-Jul-22	BAGALKOT	220	HUBLI-NAGZARI-1	STATION NOT AFFECTED HUBLI_220	9:50	18:39	8:49	LINE FAULT
446	11-Jul-22	BAGALKOT	220	HUBLI-NAGZARI-1	STATION NOT AFFECTED HUBLI_220	18:40 (11.07.2022)			LINE OPEN:LINE FAULT
447	11-Jul-22	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)			LINE OPEN:LINE CLEAR AVAILED
448	11-Jul-22	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:46 (10.07.2022)			LINE OPEN:LINE CLEAR AVAILED
449	11-Jul-22	BAGALKOT	220	NARENDRA-HAVERI1 (BIDNAL)	STATION NOT AFFECTED NARENDRA_220	9:23	11:28	2:05	LINE FAULT
450	11-Jul-22	BENGALURU	66	BANGARPETE - MALUR 220	BANGARPETE	13:20	13:30	0:10	LINE CLEAR AVAILED
451	11-Jul-22	BENGALURU	66	BYADRAHALLI - TG HALLI	KODIGEHALLI	12:11	12:19	0:08	LINE FAULT
452	11-Jul-22	BENGALURU	66	HSR LAYOUT 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	10:45	10:50	0:05	LOAD CHANGE OVER
453	11-Jul-22	BENGALURU	66	HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	10:52	10:58	0:06	LOAD CHANGE OVER
454	11-Jul-22	BENGALURU	66	HV1	C STATION	11:36	11:37	0:01	LINE CLEAR AVAILED
455	11-Jul-22	BENGALURU	66	HV1	SOMANTHPURA	12:55	17:10	4:15	LINE CLEAR AVAILED
456	11-Jul-22	BENGALURU	66	HV1	YENIGADALE	13:10	13:30	0:20	TRANSFORMER FAULT
457	11-Jul-22	BENGALURU	66	HV2	BAIRAKURU	17:25	17:57	0:31	LINE CLEAR AVAILED
458	11-Jul-22	BENGALURU	66	HV2	KOLAR 220	9:43	10:38	0:55	TRANSFORMER FAULT
459	11-Jul-22	BENGALURU	66	HV2	Maasti	15:51	16:14	0:23	TRANSFORMER FAULT
460	11-Jul-22	BENGALURU	66	HV2	Maasti	16:55	18:22	1:26	LINE CLEAR AVAILED
461	11-Jul-22	BENGALURU	66	HV2	NANDAGUDI	11:38	11:57	0:19	LINE CLEAR AVAILED
462	11-Jul-22	BENGALURU	66	HV2	TALAGWARA	12:10	12:25	0:15	TRANSFORMER FAULT
463	11-Jul-22	BENGALURU	66	HV3	CHIKKABALLAPURA I/A	15:39	15:52	0:13	TRANSFORMER FAULT
464	11-Jul-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	6:21	6:35	0:14	LINE FAULT
465	11-Jul-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	7:26	7:32	0:06	LOAD CHANGE OVER
466	11-Jul-22	BENGALURU	66	SOMANTHPURA - MITTEMARI 220	SOMANTHPURA, CHELUR, CHAKAVELU	18:15	18:35	0:20	LINE CLEAR AVAILED
467	11-Jul-22	BENGALURU	66	SOMANTHPURA - YENIGADALE	SOMANTHPURA, CHELUR, CHAKAVELU	17:50	17:55	0:05	LOAD CHANGE OVER

468 11-Jul-	-22 BENGALURU	66	T G HALLI - TAVAREKERE	TAVAREKERE	13:30	13:46	0:16	LINE CLEAR AVAILED
469 11-Jul-	-22 BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:30	16:26	3:56	LINE CLEAR AVAILED
470 11-Jul-	-22 BENGALURU	66	YENIGADALE - SOMANTHPURA	SOMANTHPURA, CHELUR, CHAKAVELU	13:30	15:18	1:48	LINE CLEAR AVAILED
471 11-Jul-	-22 GULBARGA	66	HV2	HARAPANAHALLI_66	4:00	4:10	0:10	TRANSFORMER FAULT
472 11-Jul-	-22 GULBARGA	110	HATTI-SOMANAMARADI	HATTI_110	8:38	17:36	8:58	LINE CLEAR AVAILED
473 11-Jul-	-22 GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BSS K_IPP	2:45	2:52	0:07	LINE FAULT
474 11-Jul-	-22 GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BSS K_IPP	2:45	2:52	0:07	LINE FAULT
475 11-Jul-	-22 GULBARGA	110	HV1	BENNUR_110	9:50	10:00	0:10	TRANSFORMER FAULT
476 11-Jul-	-22 GULBARGA	110	HV1	MADIYAL_110	18:00(09.07.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
477 11-Jul-	-22 GULBARGA	110	HV2	GHATARGA_110	14:00	14:10	0:10	LINE CLEAR AVAILED
478 11-Jul-	-22 GULBARGA	110	HV3	CHICKSUGUR_110	12:51	14:31	1:40	TRANSFORMER FAULT
479 11-Jul-	-22 GULBARGA	110	LINGASUGUR-CHAYADEVI	CHAYADEVI_IPP,KAREPOWER_IPP	19:17	19:40	0:23	LINE FAULT
480 11-Jul-	-22 GULBARGA	110	LINGASUGUR-CHAYADEVI	CHAYADEVI_IPP,KAREPOWER_IPP	19:17	19:40	0:23	LINE FAULT
481 11-Jul-	-22 GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	0:53	0:58	0:05	LINE FAULT
482 11-Jul-	-22 GULBARGA	110	MUDDAPUR-MASKI	MASKI_110	4:43	4:48	0:05	LINE FAULT
483 11-Jul-	-22 GULBARGA	110	RAICHUR-SINDHNOOR1	SIRWAR_110	10:45	15:23	4:38	LINE CLEAR AVAILED
484 11-Jul-	-22 GULBARGA	110	SEDAM-MALKHED RAILWAY TRACTION	MALKHED RAILWAY TRACTION_110	13:40	22:35	8:55	LINE FAULT
485 11-Jul-	-22 GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	3:05	3:10	0:05	LINE FAULT
486 11-Jul-	-22 GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR_110	11:30(23/06/2022)			LINE OPEN:LINE CLEAR AVAILED
487 11-Jul-	-22 GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN:LINE CLEAR AVAILED
488 11-Jul-	-22 GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN:LINE CLEAR AVAILED
489 11-Jul-	-22 GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YARADONA_110,BENNU R_110,BTPS WATER WORK,KAMPLI_110	21:20	21:30	0:10	LINE FAULT
490 11-Jul-	-22 GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YARADONA_110,BENNU R_110,BTPS WATER WORK,KAMPLI_110	22:20	22:30	0:10	LINE FAULT
491 11-Jul-	-22 GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YARADONA_110,BENNU R_110,BTPS WATER WORK,KAMPLI_110	21:20	21:30	0:10	LINE FAULT
492 11-Jul-	-22 GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YARADONA_110,BENNU R_110,BTPS WATER WORK,KAMPLI_110	22:20	22:30	0:10	LINE FAULT
493 11-Jul-	-22 GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	21:25	21:35	0:10	MAIN SUPPLY FAILURE
494 11-Jul-	-22 GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110	22:20	22:30	0:10	MAIN SUPPLY FAILURE
495 11-Jul-	-22 GULBARGA	400	BTPS-RTPS	BTPS_400	4:14(09.07.2022)	11:38(11.07.2022)	55:23HRS	LINE CHARGED
496 11-Jul-	-22 GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN:LINE CLEAR AVAILED
497 11-Jul-	-22 HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	8:23	8:28	0:05	HAND TRIPPED
498 11-Jul-	-22 HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	21:44(10.7.2022)	8:15(11.7.2022)	10:31HRS	LINE CHARGED
499 11-Jul-	-22 HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	17:30	17:45	0:15	LINE FAULT
499 11-Jul-								

501	11-Jul-22	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	12:06	14:27	2:21	MAIN SUPPLY FAILURE
502	11-Jul-22	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	12:05	14:22	2:17	LINE CLEAR AVAILED
503	11-Jul-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	12:05	14:22	2:17	LINE CLEAR AVAILED
504	11-Jul-22	HASSAN	66	HV1	DODDAHALLY_66	12:06	14:27	2:21	MAIN SUPPLY FAILURE
505	11-Jul-22	HASSAN	66	HV1	DODDAKADANUR_66	12:06	14:27	2:21	MAIN SUPPLY FAILURE
506	11-Jul-22	HASSAN	66	HV1	HIREMANGALUR_66	15:40	16:10	0:30	LINE CLEAR AVAILED
507	11-Jul-22	HASSAN	66	HV1	SINGAPURA_66	13:26(05.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
508	11-Jul-22	HASSAN	66	HV1	NAGARTHI_66	12:06	14:26	2:20	MAIN SUPPLY FAILURE
509	11-Jul-22	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
510	11-Jul-22	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATANA_66	17:12	17:21	0:09	LINE FAULT
511	11-Jul-22	HASSAN	66	NGRTHI-L1	NAGARTHI_66	12:06	14:26	2:20	MAIN SUPPLY FAILURE
512	11-Jul-22	HASSAN	66	NGRTHI-L2	NAGARTHI_66	12:06	14:26	2:20	MAIN SUPPLY FAILURE
513	11-Jul-22	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	10:47(10.07.2022)	13:57(11.7.2022)	27:10HRS	LINE CHARGED
514	11-Jul-22	HASSAN	110	HV1	SHIRALKOPPA_220	15:07	17:33	2:26	LINE CLEAR AVAILED
515	11-Jul-22	HASSAN	110	HV1	TOGARSI_110	16:20	18:37	2:17	LINE CLEAR AVAILED
516	11-Jul-22	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
517	11-Jul-22	HASSAN	110	HV2	NERALAKERE_110	11:59	13:40	1:41	LINE CLEAR AVAILED
518	11-Jul-22	HASSAN	110	HV2	SHIRALKOPPA_220	10:40	14:05	3:25	LINE CLEAR AVAILED
519	11-Jul-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
520	11-Jul-22	HASSAN	110	HV5	KAVOOR_220	9:48	16:43	6:55	LINE CLEAR AVAILED
521	11-Jul-22	HASSAN	110	HV5	PUTTUR_220	14:29	14:38	0:09	HAND TRIPPED
522	11-Jul-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:04	13:47	0:43	LINE FAULT
523	11-Jul-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	18:16	18:26	0:10	HAND TRIPPED
524	11-Jul-22	HASSAN	220	GERSOPA-STRP1	gerusoppa_gen	22:00(09.07.2022)			LINE OPEN:LINE FAULT
525	11-Jul-22	HASSAN	220	HV1	PUTTUR_220	14:43	14:52	0:09	HAND TRIPPED
526	11-Jul-22	HASSAN	220	MRSSHM-GEROSOPPA1	MRSMG_220	22:00 (8.07.2022)			LINE OPEN:LINE FAULT
527	11-Jul-22	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	12:02	16:25	4:23	LINE FAULT
528	11-Jul-22	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	12:02	16:25	4:23	LINE FAULT
529	11-Jul-22	HASSAN	400	UPCL-HASSAN2	upcl_gen	21:28(10.07.2022)	6:22(11.7.2022)	8:54HRS	LINE CHARGED
530	11-Jul-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN:LINE CLEAR AVAILED
531	11-Jul-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN:LINE CLEAR AVAILED
532	11-Jul-22	MYSURU	66	HV1	CHUNCHUNKATTE_66	17:25	17:47	0:22	LINE CLEAR AVAILED
533	11-Jul-22	MYSURU	66	HV1	COWDALLI_66	11:39	14:29	2:50	LINE CLEAR AVAILED
534	11-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	19:52 (11.07.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
535	11-Jul-22	MYSURU	66	HV1	GUNDLUPETE_66	10:05:00 (10.07.2022)	15:42:14 (11.07.2022)	29:37 HRS	TRANSFORMER CHARGED
536	11-Jul-22	MYSURU	66	HV1	LOKKANAHALLI_66	8:45	9:25	0:40	LINE CLEAR AVAILED
537	11-Jul-22	MYSURU	66	HV1	MANDGERE_66	12:10	14:31	2:21	MAIN SUPPLY FAILURE
538	11-Jul-22	MYSURU	66	HV1	MANDGERE_66	12:10	14:31	2:21	MAIN SUPPLY FAILURE
539	11-Jul-22	MYSURU	66	HV2	BEGUR_66	12:55	13:15	0:20	LINE CLEAR AVAILED

540	11-Jul-22	MYSURU	66	HV2	SANIVARASANTHE_66	12:20	17:00	4:40	LINE CLEAR AVAILED
541	11-Jul-22	MYSURU	66	LOKKANAHALLY-MADHUVANAHALLY	LOKKANAHALLI_66 PGPALYA_66	8:45	9:25	0:40	LINE CLEAR AVAILED
542	11-Jul-22	MYSURU	66	LOKKANAHALLY-P G PALYA	LOKKANAHALLI_66 PGPALYA_66	8:45	9:25	0:40	LINE CLEAR AVAILED
543	11-Jul-22	MYSURU	66	PERIAPATNA-KAMPLAPURA	KAMPALAPURA_66	6:43	6:50	0:06	LINE FAULT
544	11-Jul-22	MYSURU	66	SANIVARSANTHE-MALLIPATNA	SANIVARASANTHE_66	17:13	17:22	0:08	LINE FAULT
545	11-Jul-22	MYSURU	66	SANIVARSANTHE-YESSLUR	SANIVARASANTHE_66	17:13	17:29	0:16	LINE FAULT
546	11-Jul-22	MYSURU	220	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN:TRANSFORMER FAULT
547	11-Jul-22	TUMKUR	66	BILCHODU_66-PALLAGHATTA-66	BILCHODU_66	9:25	9:35	0:10	LINE FAULT
548	11-Jul-22	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR(HGML)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	4:04:00 PM(10.07.2022)	19:00(11.07.2022)	38:56 hrs	LINE CHARGED
549	11-Jul-22	TUMKUR	66	HIRIYUR 220KV-PARSHAMPURA_66	HIRIYUR_220	12:20	13:35	1:15	LINE FAULT
550	11-Jul-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:25	6:30	0:05	LINE FAULT
551	11-Jul-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:50	10:00	0:10	LINE FAULT
552	11-Jul-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	12:20	12:30	0:10	MAIN SUPPLY FAILURE
553	11-Jul-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	12:45	12:55	0:10	MAIN SUPPLY FAILURE
554	11-Jul-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	18:52	18:57	0:05	LINE FAULT
555	11-Jul-22	TUMKUR	66	KUNDUR- SUZLON_IPP_66	SUZLON_IPP_66	18:40	19:00	0:20	LINE FAULT
556	11-Jul-22	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66,HOLAVINAHALLY_66	12:23	12:37	0:14	LINE CLEAR AVAILED
557	11-Jul-22	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	11:45	12:18	0:33	LINE FAULT
558	11-Jul-22	TUMKUR	66	MADHUGIRI 220kV- MEDIGESHI 1	MEDIGESHI_66,I D HALLI_66,KODIGENAHALLI_66,HOSKERE _66	11:45	12:19	0:34	LINE FAULT
559	11-Jul-22	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	SIRA_66,GULIGENAHALLI_66	18:56	19:03	0:07	LINE FAULT
560	11-Jul-22	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	11:45	12:17	0:32	LINE FAULT
561	11-Jul-22	TUMKUR	66	NITRAHALLI66 -MADHUGIRI	NITRAHALLI_66	11:45	12:19	0:34	LINE FAULT
562	11-Jul-22	TUMKUR	66	PAVAGADA_ 220KV-SHYLAPURA_66	PAVAGADA_220	14:20	14:58	0:38	LINE FAULT
563	11-Jul-22	TUMKUR	66	PDKOTE-HARIYABBE	PDKOTE_66	10:15	13:40	3:25	NFBC ISSUED
564	11-Jul-22	TUMKUR	66	PUNABHAGATTA(neelagunda)- UCHCHANGIDURGA_66	BILCHODU_66	19:10	19:30	0:20	MAIN SUPPLY FAILURE
565	11-Jul-22	TUMKUR	66	PUNABHAGATTA(neelagunda)- UCHCHANGIDURGA_66	BILCHODU_66	10:55	11:15	0:20	LINE FAULT
566	11-Jul-22	TUMKUR	66	TR1	BUKKAPATNA_66	4:25	4:30	0:05	TRANSFORMER FAULT
567	11-Jul-22	TUMKUR	66	TR1	SAVALANGA_66	9:40	10:30	0:50	LINE CLEAR AVAILED
568	11-Jul-22	TUMKUR	66	TR1	SAVALANGA_66	15:00	15:45	0:45	LINE CLEAR AVAILED
569	11-Jul-22	TUMKUR	66	TR1	SAVALANGA_66	3:45(11.07.2022)			LINE OPEN:LINE CLEAR AVAILED
570	11-Jul-22	TUMKUR	66	TR-1	SASALUHALLA_66	13:00(28.06.2022)	20:00(11.07.2022)	319:00 hrs	TRANSFORMER CHARGED
571	11-Jul-22	TUMKUR	66	TR2	HOLALKERE_66	12:20	12:30	0:10	TRANSFORMER FAULT
572	11-Jul-22	TUMKUR	66	TR2	SHYLAPURA_66	13:15	15:30	2:15	LINE CLEAR AVAILED
573	11-Jul-22	TUMKUR	220	TR1	MADHUGIRI_220	12:23	12:35	0:12	LINE CLEAR AVAILED
574	11-Jul-22	TUMKUR	220	TR2	MADHUGIRI_220	11:45	12:16	0:31	LINE CLEAR AVAILED