

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 14.06.22 to 20.06.22

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1	14-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGAR)	STATION NOT AFFECTEDPG HUN	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
2	14-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTEDLAXMES	17:55(28.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
3	14-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTEDDAMBEW	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
4	14-Jun-2022	BAGALKOT	220	CHIKKODI- KOLAHPUR2 (MUDASHI)	STATION NOT AFFECTEDCHIKKODI	15:50 (08.06.2022)	:54 (14.06.2022)	150:04HRS	LINE CHARGED
5	14-Jun-2022	BAGALKOT	220	BELGAUM- CHIKKODI2(AEQU2)	STATION NOT AFFECTEDBELGAU	12:02 (13.06.2022)			LINE OPEN, LINE CLEAR AVAILED
6	14-Jun-2022	BAGALKOT	220	AEQUS- CHIKKODI1	STATION NOT AFFECTEDAEQUS_	12:04 (13.06.2022)			LINE OPEN, LINE CLEAR AVAILED
7	14-Jun-2022	BAGALKOT	220	AEQUS- BELGAUM1	STATION NOT AFFECTEDAEQUS_	17:18	17:30	0:12	HAND TRIPPED
8	14-Jun-2022	BAGALKOT	220	220/110KV, HV2& LV2	STATION NOT AFFECTEDGHATAP	9:42	10:09	0:27	TRANSFORMER FAULT
9	14-Jun-2022	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA	STATION NOT AFFECTEDGHATAP	9:58	13:01	3:03	HAND TRIPPED
10	14-Jun-2022	BAGALKOT	220	VAJRAMATTI-MAHALINGPUR 2	STATION NOT AFFECTEDVAJRAM	9:39	10:12	0:33	LINE FAULT
11	14-Jun-2022	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTEDHUBLI_2	11:31	11:34	0:03	LINE CLEAR AVAILED
12	14-Jun-2022	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTEDHUBLI_2	11:37 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
13	14-Jun-2022	BAGALKOT	110	110/11KV, HV1	TERDAL_110	12:43	13:27	0:44	LINE CLEAR AVAILED
14	14-Jun-2022	BAGALKOT	110	SIRSI- KUMTA2	STATION NOT AFFECTEDSIRSI_11	9:50	16:47	6:57	LINE FAULT
15	14-Jun-2022	BAGALKOT	110	110/11KV, HV2	SHIRABUR_110	15:23	15:30	0:07	TRANSFORMER FAULT
16	14-Jun-2022	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	11:15	12:35	1:20	LINE CLEAR AVAILED
17	14-Jun-2022	BAGALKOT	110	SAMBAPUR ROAD- RAILWAY LINE	STATION NOT AFFECTEDSAMBAP	15:21	15:36	0:15	LINE FAULT
18	14-Jun-2022	BAGALKOT	110	110/33KV, HV3	RANEENNUR_220, HALKERI_33	17:43	17:53	0:10	HAND TRIPPED
19	14-Jun-2022	BAGALKOT	110	110/33KV, HV4	RANEENNUR_220, HALKERI_33	17:43	17:53	0:10	HAND TRIPPED
20	14-Jun-2022	BAGALKOT	110	RANEENNUR- RATTIHALI (TUMM)	STATION NOT AFFECTEDRANEBE	17:42	18:16	0:34	HAND TRIPPED
21	14-Jun-2022	BAGALKOT	110	NARAGUND- BPCL	STATION NOT AFFECTEDNARAGU	13:56	14:52	0:56	LINE FAULT
22	14-Jun-2022	BAGALKOT	110	110/11KV, HV1	NANADI_110	10:15	12:00	1:45	LINE CLEAR AVAILED
23	14-Jun-2022	BAGALKOT	110	MAMADAPUR(B)- BELGAUM SOLAR	STATION NOT AFFECTEDMAMAD	12:59	13:02	0:03	LINE FAULT
24	14-Jun-2022	BAGALKOT	110	MAMADAPUR(B)- BELGAUM SOLAR	STATION NOT AFFECTEDMAMAD	17:56	18:29	0:33	LINE FAULT
25	14-Jun-2022	BAGALKOT	110	KUMATA- SIRSI1	STATION NOT AFFECTEDKUMATA	10:14	16:55	6:41	NFBC ISSUED
26	14-Jun-2022	BAGALKOT	110	110/11KV, HV2	RANEENNUR_220	17:43	17:53	0:10	HAND TRIPPED
27	14-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDAIGALI_	14:00	14:45	0:45	LINE CLEAR AVAILED
28	14-Jun-2022	BAGALKOT	110	AKSHAY COLONY-SRS(TARIHAL)	ANANDANAGAR_110AKSHAY CO	10:15	17:27	7:12	NFBC ISSUED
29	14-Jun-2022	BAGALKOT	110	110/11KV, HV2	ANANDANAGAR_110	10:03	17:29	7:26	LINE CLEAR AVAILED
30	14-Jun-2022	BAGALKOT	110	110/11KV, HV1	ANANDANAGAR_110	10:04	17:29	7:25	LINE CLEAR AVAILED
31	14-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDANKALA	15:14	15:36	0:22	HAND TRIPPED
32	14-Jun-2022	BAGALKOT	110	HALIYAL-GMR(ALNAVAR)	ALNAVAR_110	6:20	6:34	0:14	LINE FAULT
33	14-Jun-2022	BAGALKOT	110	HALIYAL-GMR(ALNAVAR)	ALNAVAR_110	12:06	12:20	0:14	LINE FAULT
34	14-Jun-2022	BAGALKOT	110	110/11KV, HV2(HV1)	STATION NOT AFFECTEDHALIYAL	11:04	11:57	0:53	LINE CLEAR AVAILED
35	14-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDHATTAR	13:25	16:28	3:03	LINE CLEAR AVAILED
36	14-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTEDHIREKEP	12:09	13:22	1:13	LINE CLEAR AVAILED
37	14-Jun-2022	BAGALKOT	110	110/11KV,HV3	RATTIHALI_110	9:32	9:42	0:10	TRANSFORMER FAULT
38	14-Jun-2022	BAGALKOT	110	ILKAL-AVADA SOLAR	AVADA SOLAR_110STATION NOT	18:42	20:00	1:18	LINE CLEAR AVAILED
39	14-Jun-2022	BAGALKOT	110	110/33KV, HV2	CHINCHALI_33STATION NOT AFF	17:00	18:42	1:42	TRANSFORMER FAULT
40	14-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
41	14-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
42	14-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
43	14-Jun-2022	BAGALKOT	110	110/11KV, HV1	BELUR_110	13:50	13:57	0:07	TRANSFORMER FAULT
44	14-Jun-2022	BAGALKOT	110	110/11KV, HV1	RANEENNUR_220	17:43	17:53	0:10	HAND TRIPPED
45	14-Jun-2022	BAGALKOT	110	ATHANI220- BALIGERI	ATHANI_220	3:59	4:08	0:09	LINE FAULT
46	14-Jun-2022	BAGALKOT	110	SIRSI- KUMTA1	STATION NOT AFFECTEDSIRSI_11	10:40	16:50	6:10	NFBC ISSUED
47	14-Jun-2022	BAGALKOT	110	KUMATA- SIRSI2	STATION NOT AFFECTEDKUMATA	9:48	16:50	7:02	LINE FAULT
48	14-Jun-2022	BENGALURU	66	DEVARABISANAHALLI - HSR LAYOU	DEVARABISANAHALLI, GLOBAL T	11:05	11:10	0:05	LOAD CHANGE OVER
49	14-Jun-2022	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI, GLOBAL T	13:18	13:28	0:10	LOAD CHANGE OVER
50	14-Jun-2022	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	19:57	20:14	0:17	LINE FAULT
51	14-Jun-2022	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	20:32	20:35	0:03	LOAD CHANGE OVER
52	14-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	11:04	11:20	0:16	LINE CLEAR AVAILED
53	14-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALURA	TAYALUR, NG HULKUR, MALLAN	23:20	23:37	0:17	LINE FAULT
54	14-Jun-2022	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	17:46	17:56	0:10	LINE FAULT
55	14-Jun-2022	BENGALURU	66	BUDIKOTE - TEKAL	BUDIKOTE	16:05	17:05	1:00	LINE CLEAR AVAILED
56	14-Jun-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	5:35	5:46	0:11	LINE FAULT
57	14-Jun-2022	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	3:49	3:59	0:10	LINE FAULT
58	14-Jun-2022	BENGALURU	66	HV2	THAYALUR	15:42	16:09	0:26	TRANSFORMER FAULT
59	14-Jun-2022	BENGALURU	66	HV1	TADIGOLU CROSS	17:09	18:18	1:09	LINE CLEAR AVAILED
60	14-Jun-2022	BENGALURU	66	HV2	SARIJAPURA 220	22:14	22:33	0:18	TRANSFORMER FAULT
61	14-Jun-2022	BENGALURU	66	HV1	HUKUNDA	15:12	16:20	1:07	LINE CLEAR AVAILED
62	14-Jun-2022	BENGALURU	66	HV2	HUKUNDA	13:57	15:10	1:12	LINE CLEAR AVAILED
63	14-Jun-2022	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI LINK ROAD	15:31	15:40	0:09	LOAD CHANGE OVER
64	14-Jun-2022	BENGALURU	220	HV1	JIGANI 220	17:14	17:49	0:35	LINE CLEAR AVAILED
65	14-Jun-2022	BENGALURU	66	HV1	JIGANI 220	17:14	17:50	0:36	MAIN SUPPLY FAILURE
66	14-Jun-2022	BENGALURU	66	HV2	JIGANI 220	17:14	17:50	0:36	MAIN SUPPLY FAILURE
67	14-Jun-2022	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BANGANDO	17:14	17:51	0:37	MAIN SUPPLY FAILURE
68	14-Jun-2022	BENGALURU	66	JIGANI 220 - JIGANI 66	JIGANI 66	16:18	16:21	0:03	LINE CLEAR AVAILED
69	14-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALURA	TAYALUR, NG HULKUR, MALLAN	23:46:00(14/06/2022)			LINE OPEN, LINE FAULT
70	14-Jun-2022	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGH	HIMAT SINGHA FACTORY (EHT)	22:51:27(14-6-2022)			LINE OPEN, LINE FAULT
71	14-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN, LINE FAULT
72	14-Jun-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
73	14-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN, LINE FAULT
74	14-Jun-2022	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
75	14-Jun-2022	GULBARGA	220	RAICHUR-RTPS_2	RAICHUR_220	16:36 (9.06.2022)	8:30 (14.05.2022)	121:54 HRS	LINE CHARGED
76	14-Jun-2022	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	0:30	0:52	0:22	LINE CLEAR AVAILED
77	14-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
78	14-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	12:45(14/06/2022)			LINE OPEN, LINE CLEAR AVAILED
79	14-Jun-2022	GULBARGA	110	HV4	YELBURGA_110	16:23	16:31	0:08	TRANSFORMER FAULT
80	14-Jun-2022	GULBARGA	110	HV3	VALKAMDINNI_110	9:28	9:31	0:03	TRANSFORMER FAULT
81	14-Jun-2022	GULBARGA	110	HV3	VALKAMDINNI_110	12:35	12:40	0:05	TRANSFORMER FAULT
82	14-Jun-2022	GULBARGA	110	HV3	VALKAMDINNI_110	16:42	16:46	0:04	TRANSFORMER FAULT
83	14-Jun-2022	GULBARGA	110	HV1&HV2	VAJRABANDI_110	14:40	15:45	1:05	LINE CLEAR AVAILED
84	14-Jun-2022	GULBARGA	110	HV2	KUSTAGI_220	21:17	21:32	0:15	TRANSFORMER FAULT
85	14-Jun-2022	GULBARGA	110	HV2	KUSTAGI_220	21:33	21:50	0:17	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
86	14-Jun-2022	GULBARGA	110	HV1	SHAHAPUR_220	11:13	14:22	3:09	LINE CLEAR AVAILED
87	14-Jun-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,KH	5:27	5:33	0:06	LINE FAULT
88	14-Jun-2022	GULBARGA	110	NEELGUNDA-HARAPANAHALLI	HARAPANAHALLI_110	5:23	5:33	0:10	LINE FAULT
89	14-Jun-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	4:12	4:20	0:08	LINE FAULT
90	14-Jun-2022	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	11:05	11:10	0:05	LINE FAULT
91	14-Jun-2022	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	11:45	11:55	0:10	LINE FAULT
92	14-Jun-2022	GULBARGA	110	BYAGWAT-ACMESOLAR_IPP	BYAGWAT_110	11:15	11:20	0:05	LINE CLEAR AVAILED
93	14-Jun-2022	GULBARGA	110	CHILAHAMUKI-BEVOOR	CHILAHAMUKI_110	11:15	14:15	3:00	LINE CLEAR AVAILED
94	14-Jun-2022	GULBARGA	110	NALWAR-CLEAN SOLAR_IPP	NALWAR_110	12:10	12:50	0:40	LINE CLEAR AVAILED
95	14-Jun-2022	GULBARGA	110	NALWAR-WARAD SOLAR_IPP	NALWAR_110	12:05	14:55	2:50	LINE CLEAR AVAILED
96	14-Jun-2022	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	5:30	5:40	0:10	LINE FAULT
97	14-Jun-2022	GULBARGA	110	CHOWDAPUR-KPR_FACTORY	KPR_FACTORY_110	5:30	5:45	0:15	LINE FAULT
98	14-Jun-2022	GULBARGA	110	NEELGUNDA-HARAPANAHALLI	HARAPANAHALLI_110	19:08	19:15	0:07	LINE FAULT
99	14-Jun-2022	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI	7:49	8:02	0:13	LINE FAULT
100	14-Jun-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN	2:48	2:49	0:01	LINE FAULT
101	14-Jun-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN	3:26	3:30	0:04	LINE FAULT
102	14-Jun-2022	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK	5:56	6:05	0:09	LINE FAULT
103	14-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	15:25	15:35	0:10	LINE FAULT
104	14-Jun-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR_2	NALWAR_110	11:31	15:24	3:53	NFBC ISSUED
105	14-Jun-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR_2	NALWAR_110	15:25	18:34	3:09	LINE FAULT
106	14-Jun-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110,NALWAR_110	11:58	12:22	0:24	LINE CLEAR AVAILED
107	14-Jun-2022	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110,SAIDAPUR_110,KH	16:56	18:37	1:41	LINE CLEAR AVAILED
108	14-Jun-2022	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY N	20:12	20:25	0:13	LINE FAULT
109	14-Jun-2022	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	14:12	14:27	0:15	LINE FAULT
110	14-Jun-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR_1	VENKATAGIRI_110,GANGAVATH	10:30	15:55	5:25	LINE CLEAR AVAILED
111	14-Jun-2022	GULBARGA	110	LINGASUGUR-KAREPOWER	CHAYADEVI_IPP,KAREPOWER_IP	7:35	10:44	3:09	LINE CLEAR AVAILED
112	14-Jun-2022	GULBARGA	66	ITTAGI-CLEAN MAX SOLAR_1_IPP	ITTAGI_220	19:37 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
113	14-Jun-2022	GULBARGA	66	HV1	UCCHANGIDURGA_66	9:20	10:20	1:00	LINE CLEAR AVAILED
114	14-Jun-2022	GULBARGA	66	HV1	BADELADUKU_220	9:00	9:25	0:25	TRANSFORMER FAULT
115	14-Jun-2022	GULBARGA	66	UCCHANGIDURGA-NEELAGUNDA	UCCHANGIDURGA_66	17:40	17:42	0:02	MAIN SUPPLY FAILURE
116	14-Jun-2022	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	5:30	5:45	0:15	LINE FAULT
117	14-Jun-2022	GULBARGA	66	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66	17:40	17:45	0:05	LINE FAULT
118	14-Jun-2022	GULBARGA	66	UCCHANGIDURGA-NEELAGUNDA	UCCHANGIDURGA_66	18:25	18:35	0:10	MAIN SUPPLY FAILURE
119	14-Jun-2022	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)	7:35(31.05.2022)	1535:09HRS	LINE CHARGED
120	14-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
121	14-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
122	14-Jun-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
123	14-Jun-2022	HASSAN	110	HV2	KARAYA_110	9:00(09.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
124	14-Jun-2022	HASSAN	110	HV2	KARAYA_110	9:00(09.06.2022)	8:20(14.06.2022)	129:20HRS	TRANSFORMER CHARGED
125	14-Jun-2022	HASSAN	110	BARANG-SHR220	BARANGI_110	9:34(12.6.2022)	0:09(14.06.2022)	48:35HRS	LINE CHARGED
126	14-Jun-2022	HASSAN	220	ARSK2-SHMG	ARSIKERE_220	11:52	14:01	2:09	NFBC ISSUED
127	14-Jun-2022	HASSAN	220	KADUR-SHIMOGA	KADUR_220	12:53	15:35	2:42	NFBC ISSUED
128	14-Jun-2022	HASSAN	220	MRSSH-HASSAN	MRSMSG_220	11:52	14:00	2:08	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
129	14-Jun-2022	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	12:53	15:35	2:42	LINE CLEAR AVAILED
130	14-Jun-2022	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	21:09	23:25	2:16	LINE FAULT
131	14-Jun-2022	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:17	15:54	6:37	LINE FAULT
132	14-Jun-2022	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavthy	21:09	23:25	2:16	LINE FAULT
133	14-Jun-2022	HASSAN	220	VARAHI-SHIMOGA2	Ggen_varahi	9:17	15:54	6:37	LINE FAULT
134	14-Jun-2022	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	11:00	17:10	6:10	LINE CLEAR AVAILED
135	14-Jun-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:00	18:30	8:30	LINE CLEAR AVAILED
136	14-Jun-2022	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	10:00	18:30	8:30	LINE CLEAR AVAILED
137	14-Jun-2022	HASSAN	110	BARANG-ANVATTI	BARANGI_110	10:00	18:35	8:35	LINE CLEAR AVAILED
138	14-Jun-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	10:45	12:04	1:19	LINE CLEAR AVAILED
139	14-Jun-2022	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	12:04	13:54	1:50	LINE CLEAR AVAILED
140	14-Jun-2022	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	9:24	13:45	4:21	LINE CLEAR AVAILED
141	14-Jun-2022	HASSAN	110	HV1 CB	JADE_110	10:00	18:40	8:40	MAIN SUPPLY FAILURE
142	14-Jun-2022	HASSAN	110	HV2 CB	JADE_110	10:00	18:40	8:40	MAIN SUPPLY FAILURE
143	14-Jun-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	7:50	13:00	5:10	LINE CLEAR AVAILED
144	14-Jun-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:45	12:04	1:19	LINE CLEAR AVAILED
145	14-Jun-2022	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	12:04	13:54	1:50	LINE CLEAR AVAILED
146	14-Jun-2022	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	9:24	13:45	4:21	NFBC ISSUED
147	14-Jun-2022	HASSAN	110	HV1	MSEZ_220	10:32	13:58	3:26	LINE CLEAR AVAILED
148	14-Jun-2022	HASSAN	110	HV2	MSEZ_220	14:14	17:10	2:56	LINE CLEAR AVAILED
149	14-Jun-2022	HASSAN	66	HV1	BALLUPETE_66	16:20	16:30	0:10	LINE CLEAR AVAILED
150	14-Jun-2022	HASSAN	66	HV2	HALLYMYSORE_66	19:30	20:00	0:30	TRANSFORMER FAULT
151	14-Jun-2022	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	10:40	16:05	5:25	LINE CLEAR AVAILED
152	14-Jun-2022	HASSAN	66	MOSALEH-BIOMASS	MOSALEHOSAHALLI_66	10:50	16:00	5:10	HAND TRIPPED
153	14-Jun-2022	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	10:50	16:05	5:15	NFBC ISSUED
154	14-Jun-2022	HASSAN	66	HV1	MOSALEHOSAHALLI_66	10:40	10:50	0:10	HAND TRIPPED
155	14-Jun-2022	HASSAN	66	HV1	MOSALEHOSAHALLI_66	15:57	16:05	0:08	HAND TRIPPED
156	14-Jun-2022	MYSURU	66	HV1	ADDIHALLI_66	9:55	16:15	6:19	LINE CLEAR AVAILED
157	14-Jun-2022	MYSURU	66	HV2	ADDIHALLI_66	9:55	16:15	6:19	LINE CLEAR AVAILED
158	14-Jun-2022	MYSURU	66	B MATTGERE-BEGUR	B MATKERE_66	11:00	17:15	6:15	NFBC ISSUED
159	14-Jun-2022	MYSURU	66	B MATTGERE-SANTHE SARGURU	B MATKERE_66	11:00	17:20	6:20	LINE CLEAR AVAILED
160	14-Jun-2022	MYSURU	66	CR NAGARA-DR PETE 1	DODDARAYAPET_66	12:57	17:14	4:16	HAND TRIPPED
161	14-Jun-2022	MYSURU	66	CR NAGARA-DR PETE 2	DODDARAYAPET_66	12:57	17:15	4:18	HAND TRIPPED
162	14-Jun-2022	MYSURU	220	HV2	CRNAGAR_220	12:52	13:50	0:57	TRANSFORMER FAULT
163	14-Jun-2022	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	14:23	14:29	0:06	LINE FAULT
164	14-Jun-2022	MYSURU	66	HV1	CRNAGAR_220	12:55	13:50	0:55	HAND TRIPPED
165	14-Jun-2022	MYSURU	220	HV2	SHIVASAMUDRA_220	11:00	11:09	0:09	LINE CLEAR AVAILED
166	14-Jun-2022	MYSURU	66	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 G	18:42	18:54	0:12	LINE FAULT
167	14-Jun-2022	MYSURU	66	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 G	19:05	20:22	1:17	LINE FAULT
168	14-Jun-2022	MYSURU	220	KADAKOLA-HOOTAGALLY	NO STATIONS EFFECTED	8:57	11:20	2:22	NFBC ISSUED
169	14-Jun-2022	MYSURU	66	HV1	KMDODDI_66	10:15	19:05	8:50	LINE CLEAR AVAILED
170	14-Jun-2022	MYSURU	66	HV2	KMDODDI_66	10:06	19:10	9:03	LINE CLEAR AVAILED
171	14-Jun-2022	MYSURU	66	KUNTHUR-DR PETE	JANNUR_66 MUGUR_66 THAYU	12:52	13:57	1:04	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
172	14-Jun-2022	MYSURU	66	HV1	PGPALYA_66	10:11	12:25	2:13	LINE CLEAR AVAILED
173	14-Jun-2022	MYSURU	66	HV2	PGPALYA_66	12:00	14:00	2:00	HAND TRIPPED
174	14-Jun-2022	MYSURU	66	HV1	SUTTUR_66	11:15	13:32	2:17	LINE CLEAR AVAILED
175	14-Jun-2022	MYSURU	66	HV2	SUTTUR_66	13:27	15:54	2:27	LINE CLEAR AVAILED
176	14-Jun-2022	MYSURU	66	RK NAGARA-KADAKOLA	NO STATIONS EFFECTED	12:05:59 (04/06/2022)			LINE OPEN, LINE CLEAR AVAILED
177	14-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
178	14-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
179	14-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
180	14-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	5:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
181	14-Jun-2022	TUMKUR	400	ICT-2	JAGLUR_400	11:00	15:25	4:25	LINE CLEAR AVAILED
182	14-Jun-2022	TUMKUR	400	GUTTUR_400-400KV NARENDRA LI	GUTTUR_400	23:57(14.6.22)			LINE OPEN, LINE CLEAR AVAILED
183	14-Jun-2022	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	15:00(14.6.22)			LINE OPEN, LINE FAULT
184	14-Jun-2022	TUMKUR	220	ANANTHRASANAHAHALI_220- 220KV	ANTHRASANAHAHALI_220	16:42	17:21	0:39	LINE CLEAR AVAILED
185	14-Jun-2022	TUMKUR	220	TR1	ANTHRASANAHAHALI_220	10:45	11:20	0:35	LINE CLEAR AVAILED
186	14-Jun-2022	TUMKUR	220	TR2	ANTHRASANAHAHALI_220	11:55	12:33	0:38	LINE CLEAR AVAILED
187	14-Jun-2022	TUMKUR	220	TR3	ANTHRASANAHAHALI_220	13:01	13:40	0:39	LINE CLEAR AVAILED
188	14-Jun-2022	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOL	AZURE POWER SOLAR_IPP_66	15:30	15:38	0:08	LINE FAULT
189	14-Jun-2022	TUMKUR	220	TR3	HIRIYUR_220	16:30	21:10	4:40	TRANSFORMER FAULT
190	14-Jun-2022	TUMKUR	220	TR3	HIRIYUR_220	20:10	21:10	1:00	LINE CLEAR AVAILED
191	14-Jun-2022	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOL	AZURE POWER SOLAR_IPP_66	17:10	22:30	5:20	LINE FAULT
192	14-Jun-2022	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOL	AZURE POWER SOLAR_IPP_66	23:30(14.6.22)			LINE OPEN, LINE FAULT
193	14-Jun-2022	TUMKUR	220	BUSCOUPLER	GUTTUR_400	11:27	12:10	0:43	HAND TRIPPED
194	14-Jun-2022	TUMKUR	220	GUTTUR 400KV- RANIBENNUR 220	GUTTUR_400	16:27(11.06.2022)			LOAD CURTAILMENT
195	14-Jun-2022	TUMKUR	110	220KV KB CROSS-110 CHIKKANAYAK	KBCROSS_220	17:05	17:40	0:35	HAND TRIPPED
196	14-Jun-2022	TUMKUR	110	220KV KB CROSS-110 CHIKKANAYAK	KBCROSS_220	9:52	10:32	0:40	LINE CLEAR AVAILED
197	14-Jun-2022	TUMKUR	110	TR1	KATRIKEHAL_110	9:45	17:40	7:55	MAIN SUPPLY FAILURE
198	14-Jun-2022	TUMKUR	110	TR1	KATRIKEHAL_110	21:15	21:35	0:20	MAIN SUPPLY FAILURE
199	14-Jun-2022	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, T	10:06	16:50	6:44	LINE CLEAR AVAILED
200	14-Jun-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110	9:45	10:30	0:45	MAIN SUPPLY FAILURE
201	14-Jun-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	10:53:00AM (10.06.2022)	0:43(14.06.2022)	95:49HRS	LINE CHARGED
202	14-Jun-2022	TUMKUR	66	CTA LINE-1	DAVANGERE_SRS_220	9:14	9:25	0:11	LINE FAULT
203	14-Jun-2022	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HAF	YARAGUNTA_66, OBAJJIHALI_6	10:14	10:42	0:28	LINE CLEAR AVAILED
204	14-Jun-2022	TUMKUR	66	CTA LINE-1	DAVANGERE_SRS_220	10:15	10:43	0:28	LINE CLEAR AVAILED
205	14-Jun-2022	TUMKUR	66	HIRIYUR_220-66KV THALLAK LINE	HIRIYUR_220	16:30(14.6.22)			LINE OPEN, LINE FAULT
206	14-Jun-2022	TUMKUR	66	HIRIYUR_220-66KV PARSHAMPUR	HIRIYUR_220	16:30(14.6.22)			LINE OPEN, LINE FAULT
207	14-Jun-2022	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:27	18:41	0:14	LINE FAULT
208	14-Jun-2022	TUMKUR	66	220KV SIRA -66KV BUKKAPATANA	SIRA_220	11:43	13:00	1:17	LINE CLEAR AVAILED
209	14-Jun-2022	TUMKUR	66	220KV SIRA -66KV MADHUGIRI LINE	SIRA_220	19:12	19:33	0:21	LINE FAULT
210	14-Jun-2022	TUMKUR	66	220KV SIRA -66KV MADHUGIRI LINE	SIRA_220	19:12	19:34	0:22	LINE FAULT
211	14-Jun-2022	TUMKUR	66	220 THALLAK -66KV CHALKERE LINE	THALLAK_220	19:31	19:35	0:04	LINE FAULT
212	14-Jun-2022	TUMKUR	66	66KV KUNDUR LINE-HONNALI_220	HONNALI_220	16:25	16:36	0:11	LINE FAULT
213	14-Jun-2022	TUMKUR	66	66KV KUNDUR LINE-HONNALI_220	HONNALI_220	16:36	17:26	0:50	LINE FAULT
214	14-Jun-2022	TUMKUR	66	66KV KUNDUR LINE-HONNALI_220	HONNALI_220	17:26	20:11	2:45	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
215	14-Jun-2022	TUMKUR	66	TR1	KORA_66	5:53	11:55	6:02	TRANSFORMER FAULT
216	14-Jun-2022	TUMKUR	66	TR1 AND TR2	KORA_66	12:57	13:47	0:50	MAIN SUPPLY FAILURE
217	14-Jun-2022	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66,	12:57	13:47	0:50	MAIN SUPPLY FAILURE
218	14-Jun-2022	TUMKUR	66	TR2	HDPURA_66	6:15	6:20	0:05	TRANSFORMER FAULT
219	14-Jun-2022	TUMKUR	66	TR2	HDPURA_66	14:15	14:18	0:03	TRANSFORMER FAULT
220	14-Jun-2022	TUMKUR	66	TR2	HDPURA_66	15:57	16:00	0:03	TRANSFORMER FAULT
221	14-Jun-2022	TUMKUR	66	TR1	HIRIYUR_66	19:40	20:15	0:35	TRANSFORMER FAULT
222	14-Jun-2022	TUMKUR	66	TR1	HOLALKERE_66	11:30	12:30	1:00	LINE CLEAR AVAILED
223	14-Jun-2022	TUMKUR	66	TR3	HARIYABBE_66	16:35	16:45	0:10	TRANSFORMER FAULT
224	14-Jun-2022	TUMKUR	66	TR3	HARIYABBE_66	19:10(14.6.22)			TRANSFORMER OPEN, LINE CLEAR AVAILED
225	14-Jun-2022	TUMKUR	66	TR1	NEERGUNDA_66	4:00	4:10	0:10	TRANSFORMER FAULT
226	14-Jun-2022	TUMKUR	66	TR1	PD KOTE_66	11:40	11:45	0:05	TRANSFORMER FAULT
227	14-Jun-2022	TUMKUR	66	TR1	PD KOTE_66	12:20	12:25	0:05	TRANSFORMER FAULT
228	14-Jun-2022	TUMKUR	66	TR1	PD KOTE_66	12:50	12:55	0:05	TRANSFORMER FAULT
229	14-Jun-2022	TUMKUR	66	TR1	HONNALI_66	12:05	12:20	0:15	TRANSFORMER FAULT
230	14-Jun-2022	TUMKUR	66	TR1	KADAJJI_66	18:20	18:25	0:05	TRANSFORMER FAULT
231	14-Jun-2022	TUMKUR	66	TR1	KADAJJI_66	19:00	19:05	0:05	TRANSFORMER FAULT
232	14-Jun-2022	TUMKUR	66	TR1 AND TR2	BUKKAPATANA_66	11:45	13:20	1:35	MAIN SUPPLY FAILURE
233	14-Jun-2022	TUMKUR	66	TR2	NITRAHALLI_66	17:35	17:55	0:20	LINE CLEAR AVAILED
234	14-Jun-2022	TUMKUR	66	KUKKAWADA_66- SUGARAS2_66	KUKKAWADA	9:00	14:25	5:25	LINE CLEAR AVAILED
235	15-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGAN	STATION NOT AFFECTEDPG HUN	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
236	15-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTEDLAXMES	17:55(28.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
237	15-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTEDDAMBEW	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
238	15-Jun-2022	BAGALKOT	220	BELGAUM- CHIKKODI2(AEQU52)	STATION NOT AFFECTEDBELGAU	12:02 (13.06.2022)			LINE OPEN, LINE CLEAR AVAILED
239	15-Jun-2022	BAGALKOT	220	AEQU5- CHIKKODI1	STATION NOT AFFECTEDAEQU5_	12:04 (13.06.2022)			LINE OPEN, LINE CLEAR AVAILED
240	15-Jun-2022	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTEDHUBLI_2	11:37 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
241	15-Jun-2022	BAGALKOT	110	110/11KV,HV2	AREMALLAPUR_110	10:22	18:50	8:28	LINE CLEAR AVAILED
242	15-Jun-2022	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	KIADB BIJAPUR_110	10:21	17:36	7:15	LINE CLEAR AVAILED
243	15-Jun-2022	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(SAME	KIADB BIJAPUR_110	11:37	11:53	0:16	LINE CLEAR AVAILED
244	15-Jun-2022	BAGALKOT	110	110/33KV,HV3	HONNUTAGI_33,NAGATHAN_33	11:53	17:36	5:43	LINE CLEAR AVAILED
245	15-Jun-2022	BAGALKOT	110	110/33KV,HV1	HANAGAL_110	16:0(15.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
246	15-Jun-2022	BAGALKOT	110	110/33KV,HV2	HANAGAL_110	18:25	18:52	0:27	LINE CLEAR AVAILED
247	15-Jun-2022	BAGALKOT	110	110/11KV,HV3	HANAGAL_110	16:00	19:10	3:10	LINE CLEAR AVAILED
248	15-Jun-2022	BAGALKOT	110	BADAMI-HIREHAL	HIREHAL_110	9:44	17:13	7:29	LINE CLEAR AVAILED
249	15-Jun-2022	BAGALKOT	110	110/33KV,HV2	KARADI_33,AMINAGADA_33,MY	10:02	15:29	5:27	LINE CLEAR AVAILED
250	15-Jun-2022	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	10:05	17:36	7:31	LINE CLEAR AVAILED
251	15-Jun-2022	BAGALKOT	110	110/11KV,HV1	HIPPARAGI_33JAMAKHANDI_11	17:36	19:00	1:24	LINE CLEAR AVAILED
252	15-Jun-2022	BAGALKOT	110	110/11KV,HV2	HIPPARAGI_33JAMAKHANDI_11	17:36	19:01	1:25	LINE CLEAR AVAILED
253	15-Jun-2022	BAGALKOT	110	KERUR-BADAMI	KERUR_110	17:56	19:06	1:10	LINE CLEAR AVAILED
254	15-Jun-2022	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	17:56	19:06	1:10	LINE CLEAR AVAILED
255	15-Jun-2022	BAGALKOT	110	KERUR-KULAGERI CROSS	KERUR_110	9:35	19:05	9:30	LINE CLEAR AVAILED
256	15-Jun-2022	BAGALKOT	110	KERUR-KULAGERI CROSS	STATION NOT AFFECTEDKULIGER	9:19	17:42	8:23	LINE CLEAR AVAILED
257	15-Jun-2022	BAGALKOT	110	LAXMESHWAR-SHIRAHATTI	STATION NOT AFFECTEDSHIRAH	10:15	18:13	7:58	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
258	15-Jun-2022	BAGALKOT	110	BAGALKOT-LOKAPUR	STATION NOT AFFECTEDLOKAPU	9:59	18:50	8:51	LINE CLEAR AVAILED
259	15-Jun-2022	BAGALKOT	110	YELLAMMANAVADI-SAVALAGI	SAVALAGI_110	9:57	18:43	8:46	LINE CLEAR AVAILED
260	15-Jun-2022	BAGALKOT	110	TAKKALAKI-THORVI	TAKKALAKI_110	14:18	14:20	0:02	HAND TRIPPED
261	15-Jun-2022	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	14:20	14:21	0:01	HAND TRIPPED
262	15-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTEDSULTANA	12:39	12:59	0:20	LINE CLEAR AVAILED
263	15-Jun-2022	BAGALKOT	110	SHIRHATTI-BPCL1	BPCL_110SHIRHATTI_110	10:00	18:41	8:41	LINE CLEAR AVAILED
264	15-Jun-2022	BAGALKOT	110	SHIRHATTI-BPCL2	BPCL_110SHIRHATTI_110	10:00	18:56	8:56	LINE CLEAR AVAILED
265	15-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDSHIRBUR	8:37	8:48	0:11	TRANSFORMER FAULT
266	15-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTEDDRAMANA	10:54	19:36	8:42	LINE CLEAR AVAILED
267	15-Jun-2022	BAGALKOT	110	LAXMESHWAR-SHIRHATTI	SHIRHATTI_110	10:15	18:13	7:58	NFBC ISSUED
268	15-Jun-2022	BAGALKOT	110	NEERABUDIHAL-KATARKI	NEERABUDIHAL_110	10:48	17:00	6:12	LINE CLEAR AVAILED
269	15-Jun-2022	BAGALKOT	110	VAJRAMATTI220 -JK CEMENT	STATION NOT AFFECTEDVAJRAM	17:14	17:41	0:27	LINE FAULT
270	15-Jun-2022	BAGALKOT	220	HUBLI- SIRS1	STATION NOT AFFECTEDHUBLI_2	10:18	18:14	7:56	LINE CLEAR AVAILED
271	15-Jun-2022	BAGALKOT	220	HUBLI- SIRS2	STATION NOT AFFECTEDHUBLI_2	10:17	18:09	7:52	LINE CLEAR AVAILED
272	15-Jun-2022	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTEDHUBLI_2	13:27	18:06	4:39	LINE CLEAR AVAILED
273	15-Jun-2022	BAGALKOT	220	AMBEWADI- NARENDRA1	STATION NOT AFFECTEDAMBEW	10:13 (15.06.2022)			LINE OPEN, LINE CLEAR AVAILED
274	15-Jun-2022	BAGALKOT	220	AMBEWADI- NAGJHARI2	STATION NOT AFFECTEDAMBEW	11:18	15:16	3:58	LINE CLEAR AVAILED
275	15-Jun-2022	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTEDAMBEW	11:47	16:21	4:34	LINE CLEAR AVAILED
276	15-Jun-2022	BAGALKOT	220	AMBEWADI- NARENDRA2	STATION NOT AFFECTEDAMBEW	11:52	15:39	3:47	LINE CLEAR AVAILED
277	15-Jun-2022	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTEDNAREND	10:05 (15.06.2022)			LINE OPEN, LINE CLEAR AVAILED
278	15-Jun-2022	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTEDNAREND	11:52	15:39	3:47	LINE CLEAR AVAILED
279	15-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTEDKUDACH	7:18	7:22	0:04	TRANSFORMER FAULT
280	15-Jun-2022	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTEDKUDACH	11:21	17:36	6:15	LINE CLEAR AVAILED
281	15-Jun-2022	BAGALKOT	220	KARWAR- KADRA1	STATION NOT AFFECTEDKARWAR	8:42	11:14	2:32	NFBC ISSUED
282	15-Jun-2022	BAGALKOT	110	BAGALKOT220- BAGALKOT2	BAGALKOT_220	0:05	0:25	0:20	LINE FAULT
283	15-Jun-2022	BAGALKOT	110	BAGALKOT220- BAGALKOT2	BAGALKOT_220	7:20	8:20	1:00	LINE CLEAR AVAILED
284	15-Jun-2022	BAGALKOT	110	BAGALKOT220- BAGALKOT2	BAGALKOT_220	10:10	16:37	6:27	LINE CLEAR AVAILED
285	15-Jun-2022	BAGALKOT	110	BAGALKOT220- NAVANAGAR1	BAGALKOT_220	9:17	16:37	7:20	LINE CLEAR AVAILED
286	15-Jun-2022	BAGALKOT	110	BAGALKOT220- NAVANAGAR2	BAGALKOT_220	9:17	16:37	7:20	LINE CLEAR AVAILED
287	15-Jun-2022	BAGALKOT	110	BAGALKOT220- GULEDAGUDDA	BAGALKOT_220	9:18	17:35	8:17	LINE CLEAR AVAILED
288	15-Jun-2022	BAGALKOT	110	BAGALKOT220- KERUR	BAGALKOT_220	9:19	19:00	9:41	LINE CLEAR AVAILED
289	15-Jun-2022	BAGALKOT	110	BAGALKOT220- RAMDURGA	BAGALKOT_220	9:18	17:37	8:19	LINE CLEAR AVAILED
290	15-Jun-2022	BAGALKOT	110	BAGALKOT220-LOKAPUR	BAGALKOT_220	9:19	18:45	9:26	LINE CLEAR AVAILED
291	15-Jun-2022	BAGALKOT	110	BAGALKOT220- KATARAKI (NEERAB	BAGALKOT_220	9:19	16:51	7:32	LINE CLEAR AVAILED
292	15-Jun-2022	BAGALKOT	110	BAGALKOT220-KALADAGI	BAGALKOT_220	9:19	18:45	9:26	LINE CLEAR AVAILED
293	15-Jun-2022	BAGALKOT	220	220/110KV, HV1	BAGALKOT_220	9:26	16:05	6:39	LINE CLEAR AVAILED
294	15-Jun-2022	BAGALKOT	110	220/110KV, LV1	BAGALKOT_220	9:26	16:08	6:42	LINE CLEAR AVAILED
295	15-Jun-2022	BAGALKOT	220	220/110KV, HV2	BAGALKOT_220	9:25	16:05	6:40	LINE CLEAR AVAILED
296	15-Jun-2022	BAGALKOT	110	220/110KV, LV2	BAGALKOT_220	9:25	18:27	9:02	LINE CLEAR AVAILED
297	15-Jun-2022	BAGALKOT	220	220/110KV, HV3	BAGALKOT_220	9:27	16:06	6:39	LINE CLEAR AVAILED
298	15-Jun-2022	BAGALKOT	110	220/110KV, LV3	BAGALKOT_220	9:27	16:08	6:41	LINE CLEAR AVAILED
299	15-Jun-2022	BAGALKOT	110	110/33KV, HV3	BAGALKOT_220	9:24	17:06	7:42	LINE CLEAR AVAILED
300	15-Jun-2022	BAGALKOT	110	110/11KV, HV1	BAGALKOT_220	9:25	12:10	2:45	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
301	15-Jun-2022	BAGALKOT	110	110/11KV, HV2	BAGALKOT_220	12:10	16:10	4:00	LINE CLEAR AVAILED
302	15-Jun-2022	BAGALKOT	220	220/110KV, HV1&LV1(HV2&LV2)	STATION NOT AFFECTEDGADAG	11:04	20:04	9:00	LINE CLEAR AVAILED
303	15-Jun-2022	BAGALKOT	110	GADAG220- SHIRAHATTI	STATION NOT AFFECTEDGADAG	10:06	18:25	8:19	LINE CLEAR AVAILED
304	15-Jun-2022	BAGALKOT	110	HAVERI220- TILUVALLI (HANGAL)	STATION NOT AFFECTEDHAVERI	10:15	18:18	8:03	LINE CLEAR AVAILED
305	15-Jun-2022	BAGALKOT	220	MAHALINGAPUR- NARENDRA1	STATION NOT AFFECTEDMAHALI	18:35	21:59	3:24	LINE FAULT
306	15-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
307	15-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
308	15-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
309	15-Jun-2022	BAGALKOT	110	VAJRAMATTI220 -KD JAMBAGI	KD JAMBAGI_110, MUDHOL_110	17:14	17:24	0:10	LINE FAULT
310	15-Jun-2022	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA	GHATAPRABHA_220	15:35	17:20	1:45	LINE CLEAR AVAILED
311	15-Jun-2022	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	13:26	16:05	2:39	LINE CLEAR AVAILED
312	15-Jun-2022	BAGALKOT	110	110/11KV, HV2	RANEBENNUR_220	12:32	14:04	1:32	LINE CLEAR AVAILED
313	15-Jun-2022	BAGALKOT	110	110/11KV , HV4	ANKALI_110	17:45	18:25	0:40	TRANSFORMER FAULT
314	15-Jun-2022	BAGALKOT	220	KARWAR- KADRA2	KARWAR_220	11:25	12:37	1:12	NFBC ISSUED
315	15-Jun-2022	BAGALKOT	110	KAVALWADA- HALIYAL	HALIYAL_110	6:20	6:33	0:13	LINE FAULT
316	15-Jun-2022	BAGALKOT	110	KAVALWADA- HALIYAL	HALIYAL_110	12:07	12:20	0:13	LINE FAULT
317	15-Jun-2022	BAGALKOT	110	BAGALKOT220-KALADAGI	BAGALKOT_220	9:19	18:45	9:26	LINE CLEAR AVAILED
318	15-Jun-2022	BAGALKOT	220	220/110KV, HV3	BAGALKOT_220	9:27	16:06	6:39	LINE CLEAR AVAILED
319	15-Jun-2022	BAGALKOT	110	220/110KV, LV3	BAGALKOT_220	9:27	16:08	6:41	LINE CLEAR AVAILED
320	15-Jun-2022	BAGALKOT	220	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	18:35 (15.06.2022)			LINE OPEN, LINE FAULT
321	15-Jun-2022	BENGALURU	66	HV1	AMAR JYOTHI	12:50	13:15	0:25	TRANSFORMER FAULT
322	15-Jun-2022	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	17:56	18:02	0:06	MAIN SUPPLY FAILURE
323	15-Jun-2022	BENGALURU	66	A STATION 220 - A STATION 2 66	A STATION 2 66	17:56	18:02	0:06	MAIN SUPPLY FAILURE
324	15-Jun-2022	BENGALURU	66	A STATION 220 - KANTEERAVA	KANTEERAVA	17:56	18:03	0:07	MAIN SUPPLY FAILURE
325	15-Jun-2022	BENGALURU	66	GOKULA - SRS PEENYA 1 & 2 220	GOKULA, BEL (EHT), HMT (EHT)	17:56	18:21	0:25	MAIN SUPPLY FAILURE
326	15-Jun-2022	BENGALURU	66	GOKULA - HEBALA 220	GOKULA, BEL (EHT), HMT (EHT)	18:50	18:53	0:03	LOAD CHANGE OVER
327	15-Jun-2022	BENGALURU	66	HV2	HOODY 220	2:53	4:22	1:29	TRANSFORMER FAULT
328	15-Jun-2022	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	20:01	21:06	1:05	LINE FAULT
329	15-Jun-2022	BENGALURU	220	HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	20:01	21:05	1:04	LINE FAULT
330	15-Jun-2022	BENGALURU	220	HV1	KOTHIPURA 220	17:25	17:38	0:13	TRANSFORMER FAULT
331	15-Jun-2022	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKA	17:25	20:14	2:49	LINE FAULT
332	15-Jun-2022	BENGALURU	66	KOTHIPURA 220 - MELLAHALLI	KEMPANAHALLI, MELEHALLI, JAL	17:25	18:11	0:46	LINE FAULT
333	15-Jun-2022	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	17:56	18:06	0:10	MAIN SUPPLY FAILURE
334	15-Jun-2022	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	19:00	19:04	0:04	LOAD CHANGE OVER
335	15-Jun-2022	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	17:56	19:01	1:05	MAIN SUPPLY FAILURE
336	15-Jun-2022	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	17:56	18:36	0:40	MAIN SUPPLY FAILURE
337	15-Jun-2022	BENGALURU	66	HV2	VIJAYANAGARA	17:56	18:24	0:28	MAIN SUPPLY FAILURE
338	15-Jun-2022	BENGALURU	66	HV1	VIJAYANAGARA	18:19	18:24	0:05	LINE CLEAR AVAILED
339	15-Jun-2022	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	17:56	18:36	0:40	MAIN SUPPLY FAILURE
340	15-Jun-2022	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	17:56	18:36	0:40	MAIN SUPPLY FAILURE
341	15-Jun-2022	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	17:56	18:02	0:06	MAIN SUPPLY FAILURE
342	15-Jun-2022	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	22:18	22:22	0:04	LOAD CHANGE OVER
343	15-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:50	14:55	2:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
344	15-Jun-2022	BENGALURU	220	SAHAKARI NAGAR 220 - SRS PEENYA	SAHAKARI NAGAR 220	17:56	18:32	0:36	MAIN SUPPLY FAILURE
345	15-Jun-2022	BENGALURU	220	SAHAKARI NAGAR 220 - CPRI 220	CPRI 220	17:56	18:32	0:36	MAIN SUPPLY FAILURE
346	15-Jun-2022	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 2	SRS PEENYA 220	17:56	18:33	0:37	LINE FAULT
347	15-Jun-2022	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	SRS PEENYA 220	17:56	18:33	0:37	LINE FAULT
348	15-Jun-2022	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 5	SRS PEENYA 220	17:56	18:25	0:29	MAIN SUPPLY FAILURE
349	15-Jun-2022	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 4	SRS PEENYA 220	17:56	18:42	0:46	LINE FAULT
350	15-Jun-2022	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	17:56	18:37	0:41	MAIN SUPPLY FAILURE
351	15-Jun-2022	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	17:56	18:42	0:46	MAIN SUPPLY FAILURE
352	15-Jun-2022	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC	17:56	18:46	0:50	MAIN SUPPLY FAILURE
353	15-Jun-2022	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, KODIGEHALI, SR	17:56	18:58	1:02	MAIN SUPPLY FAILURE
354	15-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALURA	TAYALUR, NG HULKUR, MALLAN	0:12	3:34	3:22	LINE FAULT
355	15-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALURA	TAYALUR, NG HULKUR, MALLAN	3:34	4:13	0:39	LINE CLEAR AVAIED
356	15-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALURA	TAYALUR, NG HULKUR, MALLAN	6:03	7:48	1:45	LINE CLEAR AVAIED
357	15-Jun-2022	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MA	10:37	10:48	0:11	LINE FAULT
358	15-Jun-2022	BENGALURU	66	LR BANDE - HBR LAYOUT 220	LR BANDE	14:25	14:30	0:05	LOAD CHANGE OVER
359	15-Jun-2022	BENGALURU	66	LR BANDE - HEBBALA 220	LR BANDE	18:10	18:20	0:10	LOAD CHANGE OVER
360	15-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	5:53	6:27	0:34	LINE FAULT
361	15-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	5:53	6:28	0:35	LINE FAULT
362	15-Jun-2022	BENGALURU	66	HV1	YARANDANAHALLI 220	12:47	13:02	0:15	TRANSFORMER FAULT
363	15-Jun-2022	BENGALURU	66	HV2	YARANDANAHALLI 220	12:47	13:02	0:15	TRANSFORMER FAULT
364	15-Jun-2022	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	NO STATION AFFECTED	11:08	11:42	0:34	LINE FAULT
365	15-Jun-2022	BENGALURU	66	SURYANAGAR - YARANDANAHALLI	SURYANAGAR, ANEKAL, ATTIBEL	5:54	6:29	0:35	LINE FAULT
366	15-Jun-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHAL	13:57	14:00	0:02	LINE CLEAR AVAIED
367	15-Jun-2022	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHAL	17:56	18:39	0:43	MAIN SUPPLY FAILURE
368	15-Jun-2022	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAK	17:56	18:39	0:43	MAIN SUPPLY FAILURE
369	15-Jun-2022	BENGALURU	220	HV1	MAGADI 220	17:56	18:38	0:42	MAIN SUPPLY FAILURE
370	15-Jun-2022	BENGALURU	220	HV2	MAGADI 220	17:56	18:38	0:42	MAIN SUPPLY FAILURE
371	15-Jun-2022	BENGALURU	66	HV1	MAGADI 220	17:56	18:39	0:43	MAIN SUPPLY FAILURE
372	15-Jun-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	17:47	17:58	0:11	LINE FAULT
373	15-Jun-2022	BENGALURU	66	HV1	JANGAMKOTE	18:14	18:35	0:21	TRANSFORMER FAULT
374	15-Jun-2022	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	17:56	18:23	0:27	MAIN SUPPLY FAILURE
375	15-Jun-2022	BENGALURU	66	DABUSPET 220 - JINDAL (EHT)	JINDAL (EHT)	17:56	18:20	0:24	MAIN SUPPLY FAILURE
376	15-Jun-2022	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	17:56	18:23	0:27	MAIN SUPPLY FAILURE
377	15-Jun-2022	BENGALURU	66	DABUSPET 220 - SK STEEL (EHT)	SK STEEL (EHT)	17:56	18:26	0:30	MAIN SUPPLY FAILURE
378	15-Jun-2022	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	17:56	18:22	0:26	MAIN SUPPLY FAILURE
379	15-Jun-2022	BENGALURU	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI	17:56	18:26	0:30	MAIN SUPPLY FAILURE
380	15-Jun-2022	BENGALURU	66	HV1	DABUSPETE 220	17:56	18:21	0:25	MAIN SUPPLY FAILURE
381	15-Jun-2022	BENGALURU	66	HV2	DABUSPETE 220	17:56	18:21	0:25	MAIN SUPPLY FAILURE
382	15-Jun-2022	BENGALURU	220	DABUSPETE 220 - KADUR 220	DABUSPETE 220	17:56	18:14	0:18	MAIN SUPPLY FAILURE
383	15-Jun-2022	BENGALURU	220	HV1	DABUSPETE 220	17:56	18:21	0:25	MAIN SUPPLY FAILURE
384	15-Jun-2022	BENGALURU	220	HV2	DABUSPETE 220	17:56	18:21	0:25	MAIN SUPPLY FAILURE
385	15-Jun-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	20:07	20:14	0:06	LINE FAULT
386	15-Jun-2022	BENGALURU	66	SARIJAPURA 220 - ATTIBELE	ATTIBELE	18:53	19:32	0:39	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
387	15-Jun-2022	BENGALURU	220	NELAMANGALA 400 - DB PURA 2	NO STATION AFFECTED	17:55	18:33	0:38	LINE FAULT
388	15-Jun-2022	BENGALURU	400	BUS BAR	NELAMANGALA 400	17:55	18:21	0:26	LINE FAULT
389	15-Jun-2022	BENGALURU	400	NELAMANGALA 400 - DEVANAHALLI	NO STATION AFFECTED	17:55	18:21	0:26	MAIN SUPPLY FAILURE
390	15-Jun-2022	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 400	NO STATION AFFECTED	17:55	18:21	0:26	MAIN SUPPLY FAILURE
391	15-Jun-2022	BENGALURU	400	NELAMANGALA 400 - MYSORE 1	NO STATION AFFECTED	17:55	18:21	0:26	MAIN SUPPLY FAILURE
392	15-Jun-2022	BENGALURU	400	NELAMANGALA 400 - MYSORE 2	NO STATION AFFECTED	17:55	18:21	0:26	MAIN SUPPLY FAILURE
393	15-Jun-2022	BENGALURU	400	NELAMANGALA 400 - BIDADI 2	NO STATION AFFECTED	17:55	18:21	0:26	MAIN SUPPLY FAILURE
394	15-Jun-2022	BENGALURU	400	NELAMANGALA 400 - SINGANAYAK	NO STATION AFFECTED	17:55	18:21	0:26	MAIN SUPPLY FAILURE
395	15-Jun-2022	BENGALURU	220	ANCHEPALYA 220 - NELAMANGALA	NO STATION AFFECTED	17:55	18:21	0:26	MAIN SUPPLY FAILURE
396	15-Jun-2022	BENGALURU	220	MAGADI 220 - NELAMANGALA 400	MAGADI 220	17:56	18:38	0:42	MAIN SUPPLY FAILURE
397	15-Jun-2022	BENGALURU	220	DABUSPETE 220 - NELAMANGALA 400	DABUSPETE 220	17:56	18:39	0:43	MAIN SUPPLY FAILURE
398	15-Jun-2022	BENGALURU	66	HV1	DIBBURALLI	8:08	8:35	0:27	TRANSFORMER FAULT
399	15-Jun-2022	BENGALURU	66	HV1	CHINTAMANI 66	11:08	11:34	0:26	LINE CLEAR AVAILED
400	15-Jun-2022	BENGALURU	66	SADLI - MITTEMARI 220	SADLI, DIBBURALLI	23:20	23:25	0:05	LINE FAULT
401	15-Jun-2022	BENGALURU	66	HV1	DIBBURALLI	23:18	23:25	0:07	TRANSFORMER FAULT
402	15-Jun-2022	BENGALURU	220	HV2	BRINDAVANA 220	17:55(15/06/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
403	15-Jun-2022	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGH	HIMAT SINGHA FACTORY (EHT)	22:51:27(14-6-2022)			LINE OPEN, LINE FAULT
404	15-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALURA	TAYALUR, NG HULKUR, MALLAN	23:46:00(14/06/2022)	0:12(15/06/2022)	00:26HRS	LINE CHARGED
405	15-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN, LINE FAULT
406	15-Jun-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
407	15-Jun-2022	GULBARGA	400	RTPS-BTPS	RTPS_400	20:29 (15.06.2022)			LINE OPEN, LINE FAULT
408	15-Jun-2022	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
409	15-Jun-2022	GULBARGA	220	KAPNOOR-HUMNABAD_2	KAPNOOR_220	10:18	15:15	4:57	LINE CLEAR AVAILED
410	15-Jun-2022	GULBARGA	220	HALWARTHY-LINGAPUR	HALWARTHY_220,DRUVADESH_	9:09	17:44	8:35	LINE CLEAR AVAILED
411	15-Jun-2022	GULBARGA	220	SHAHAPUR-RTPS_2	SHAHAPUR_220	2:25	2:41	0:16	LINE FAULT
412	15-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN, LINE FAULT
413	15-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
414	15-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN, LINE CLEAR AVAILED
415	15-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN, LINE CLEAR AVAILED
416	15-Jun-2022	GULBARGA	110	HV3	HATTI_110	13:27	13:37	0:10	TRANSFORMER FAULT
417	15-Jun-2022	GULBARGA	110	HV3	YELBURGA_110	10:36	14:54	4:18	LINE CLEAR AVAILED
418	15-Jun-2022	GULBARGA	110	HV4	YELBURGA_110	10:50	13:49	2:59	LINE CLEAR AVAILED
419	15-Jun-2022	GULBARGA	110	HV1	YELBURGA_110	15:34	19:48	4:14	LINE CLEAR AVAILED
420	15-Jun-2022	GULBARGA	110	HV1	YELBURGA_110	20:34	21:06	0:32	TRANSFORMER FAULT
421	15-Jun-2022	GULBARGA	110	HV2	YELBURGA_110	12:13	13:52	1:39	LINE CLEAR AVAILED
422	15-Jun-2022	GULBARGA	110	HV1	YAKATPUR_110	10:45	13:30	2:45	LINE CLEAR AVAILED
423	15-Jun-2022	GULBARGA	110	HV2	YAKATPUR_110	15:20	18:25	3:05	LINE CLEAR AVAILED
424	15-Jun-2022	GULBARGA	110	HV1 & HV2	MUDAGAL_110	10:15	17:35	7:20	LINE CLEAR AVAILED
425	15-Jun-2022	GULBARGA	110	HV3	MUDAGAL_110	16:00	17:35	1:35	LINE CLEAR AVAILED
426	15-Jun-2022	GULBARGA	110	HV1	HANUMANAL_110	16:50	18:30	1:40	LINE CLEAR AVAILED
427	15-Jun-2022	GULBARGA	110	LV1	SHAHAPUR_220	20:08	20:19	0:11	TRANSFORMER FAULT
428	15-Jun-2022	GULBARGA	110	HV2	KUSTAGI_220	11:34	11:37	0:03	TRANSFORMER FAULT
429	15-Jun-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110	4:40	4:44	0:04	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
430	15-Jun-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	4:12	4:20	0:08	LINE FAULT
431	15-Jun-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	21:42	21:47	0:05	LINE FAULT
432	15-Jun-2022	GULBARGA	110	KEMBHAVI-ASKI	ASKI_110	13:15	13:40	0:25	LINE CLEAR AVAILED
433	15-Jun-2022	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	13:25	13:30	0:05	LINE CLEAR AVAILED
434	15-Jun-2022	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110,AZALPUR_110	11:10	16:20	5:10	LINE CLEAR AVAILED
435	15-Jun-2022	GULBARGA	110	NALWAR-SHAHPUR(SHAHABAD)2	JEWARGI_110	20:05	20:30	0:25	LINE FAULT
436	15-Jun-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR_2	NALWAR_110,JEWARGI_110	20:08	20:23	0:15	LINE FAULT
437	15-Jun-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110	20:08	20:22	0:14	LINE FAULT
438	15-Jun-2022	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110	17:49	17:56	0:07	LINE FAULT
439	15-Jun-2022	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	21:40	22:05	0:25	LINE FAULT
440	15-Jun-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD_2	MUKUNDA_110,YARADONA_110	4:10	4:25	0:15	LINE FAULT
441	15-Jun-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD_2	MUKUNDA_110,YARADONA_110	21:12	21:42	0:30	LINE FAULT
442	15-Jun-2022	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI	4:30	4:38	0:08	LINE FAULT
443	15-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	10:40	12:00	1:20	LINE CLEAR AVAILED
444	15-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110	16:25	17:54	1:29	LINE CLEAR AVAILED
445	15-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:09	11:15	0:06	LINE FAULT
446	15-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	16:25	17:52	1:27	LINE CLEAR AVAILED
447	15-Jun-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR_2	KAMPLI_110,MUKUNDA_110,KE	5:25	5:32	0:07	LINE FAULT
448	15-Jun-2022	GULBARGA	110	MUDDAPUR-SINDHNOOR	MUDDAPUR_110	2:40	2:47	0:07	LINE FAULT
449	15-Jun-2022	GULBARGA	110	MUDDAPUR-SINDHNOOR	MUDDAPUR_110	14:04	14:36	0:32	LINE FAULT
450	15-Jun-2022	GULBARGA	66	HV1	UJJAINI_66	18:40	18:43	0:03	TRANSFORMER FAULT
451	15-Jun-2022	GULBARGA	66	NEELGUNDA-TELIGI	TELAGI_66,KURBHAHALLI_66,YE	8:47	8:58	0:11	LINE FAULT
452	15-Jun-2022	GULBARGA	66	ITTAGI-CLEAN MAX SOLAR_1_IPP	ITTAGI_220	19:37 (14.06.2022)	17 (15.06.2022)	5:40 HRS	LINE CHARGED
453	15-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
454	15-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
455	15-Jun-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
456	15-Jun-2022	HASSAN	220	SHRAVITY-SHIMOGA4	gen_sharavaty	10:30	12:06	1:36	LINE CLEAR AVAILED
457	15-Jun-2022	HASSAN	220	VARAH1-KEMAR1	gen_varahi	20:27	21:17	0:50	LINE FAULT
458	15-Jun-2022	HASSAN	220	VARAH2-KEMAR2	gen_varahi	20:27	21:30	1:03	LINE FAULT
459	15-Jun-2022	HASSAN	220	KADUR-DABUSET	KADUR_220	10:07	13:13	3:06	LINE CLEAR AVAILED
460	15-Jun-2022	HASSAN	220	HV2	KADUR_220	17:56	18:30	0:34	TRANSFORMER FAULT
461	15-Jun-2022	HASSAN	110	LV2	KADUR_220	17:56	18:30	0:34	TRANSFORMER FAULT
462	15-Jun-2022	HASSAN	220	KEMAR-Varahi1	KEMAR_220	20:27	21:17	0:50	LINE FAULT
463	15-Jun-2022	HASSAN	220	KEMAR-Varahi2	KEMAR_220	20:27	21:30	1:03	LINE FAULT
464	15-Jun-2022	HASSAN	110	KEMAR_Guruvykere1	KEMAR_220	13:14	13:36	0:22	LINE FAULT
465	15-Jun-2022	HASSAN	110	KEMAR_Guruvykere2	KEMAR_220	13:14	13:26	0:12	LINE FAULT
466	15-Jun-2022	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	12:13	14:45	2:32	LINE CLEAR AVAILED
467	15-Jun-2022	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	12:13	14:46	2:33	LINE CLEAR AVAILED
468	15-Jun-2022	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	12:13	14:46	2:33	LINE CLEAR AVAILED
469	15-Jun-2022	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	12:13	14:46	2:33	LINE CLEAR AVAILED
470	15-Jun-2022	HASSAN	66	LV1	MRSMSG_220	12:13	14:46	2:33	LINE CLEAR AVAILED
471	15-Jun-2022	HASSAN	110	HV1	MRSMSG_220	12:13	14:44	2:31	LINE CLEAR AVAILED
472	15-Jun-2022	HASSAN	110	HV4	MRSMSG_220	12:13	14:44	2:31	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
473	15-Jun-2022	HASSAN	110	LV3	MRSMSG_220	12:13	14:44	2:31	LINE CLEAR AVAILED
474	15-Jun-2022	HASSAN	110	HV1	ESSUR_110	10:05	14:45	4:40	MAIN SUPPLY FAILURE
475	15-Jun-2022	HASSAN	110	HV2	ESSUR_110	10:05	14:45	4:40	MAIN SUPPLY FAILURE
476	15-Jun-2022	HASSAN	110	GURUVAY-KEMAR1	GURUVAYANKERE_110	13:15	13:37	0:22	MAIN SUPPLY FAILURE
477	15-Jun-2022	HASSAN	110	GURUVAY-KEMAR2	GURUVAYANKERE_110	13:15	13:26	0:11	MAIN SUPPLY FAILURE
478	15-Jun-2022	HASSAN	110	GURUVAY-SLVPWR	GURUVAYANKERE_110	13:15	13:26	0:11	MAIN SUPPLY FAILURE
479	15-Jun-2022	HASSAN	110	HV2	HIRIYADKA_110	7:53	8:06	0:13	TRANSFORMER FAULT
480	15-Jun-2022	HASSAN	110	HV2	HOSANGADI_110	20:29	21:21	0:52	TRANSFORMER FAULT
481	15-Jun-2022	HASSAN	110	HV1	KONAJE_110	10:17	14:10	3:53	LINE CLEAR AVAILED
482	15-Jun-2022	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	11:13	15:50	4:37	NFBC ISSUED
483	15-Jun-2022	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:39	15:54	5:15	NFBC ISSUED
484	15-Jun-2022	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	10:05	14:45	4:40	LINE CLEAR AVAILED
485	15-Jun-2022	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	10:39	15:54	5:15	LINE CLEAR AVAILED
486	15-Jun-2022	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:05	13:15	2:10	NFBC ISSUED
487	15-Jun-2022	HASSAN	66	HV1	BALLUPETE_66	14:00	14:20	0:20	LINE CLEAR AVAILED
488	15-Jun-2022	HASSAN	66	HV1	BALLUPETE_66	14:30	15:25	0:55	LINE CLEAR AVAILED
489	15-Jun-2022	HASSAN	66	BHADRA-LINGADAHALLI	gen_bhadra	12:13	13:00	0:47	MAIN SUPPLY FAILURE
490	15-Jun-2022	HASSAN	66	BHADRA-LINGADAHALLI	gen_bhadra	14:17	14:48	0:31	HAND TRIPPED
491	15-Jun-2022	HASSAN	66	BHADRA-SHMGA 1	gen_bhadra	12:13	14:44	2:31	MAIN SUPPLY FAILURE
492	15-Jun-2022	HASSAN	66	BHADRA-SHMGA 2	gen_bhadra	12:13	14:44	2:31	MAIN SUPPLY FAILURE
493	15-Jun-2022	HASSAN	66	HV1	DODDAKADNUR_66	15:15	18:15	3:00	LINE CLEAR AVAILED
494	15-Jun-2022	HASSAN	66	HV2	HALLYMYSORE_66	8:55	9:15	0:20	LINE CLEAR AVAILED
495	15-Jun-2022	HASSAN	66	HV2	HALLYMYSORE_66	9:25	12:35	3:10	LINE CLEAR AVAILED
496	15-Jun-2022	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	13:13	14:57	1:44	LINE CLEAR AVAILED
497	15-Jun-2022	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:47	16:11	0:24	LINE FAULT
498	15-Jun-2022	HASSAN	66	HV1	KUDLIGERE_66	9:30	15:40	6:10	LINE CLEAR AVAILED
499	15-Jun-2022	HASSAN	66	HV2	KUDLIGERE_66	9:30	11:50	2:20	LINE CLEAR AVAILED
500	15-Jun-2022	HASSAN	66	HV2	KUDLIGERE_66	12:00	16:05	4:05	LINE CLEAR AVAILED
501	15-Jun-2022	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	12:10	15:00	2:50	MAIN SUPPLY FAILURE
502	15-Jun-2022	HASSAN	66	HV1	SIGEBAGI_66	9:00	15:20	6:20	LINE CLEAR AVAILED
503	15-Jun-2022	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	13:10	14:35	1:25	LINE CLEAR AVAILED
504	15-Jun-2022	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	15:00	15:35	0:35	HAND TRIPPED
505	15-Jun-2022	MYSURU	66	HV1	BESAGARAHALLI_66	13:12	15:04	1:51	LINE CLEAR AVAILED
506	15-Jun-2022	MYSURU	66	HV1	BESAGARAHALLI_66	19:50	20:58	1:07	HAND TRIPPED
507	15-Jun-2022	MYSURU	66	HV1	BGNAGARA_66	16:10	17:12	1:01	LINE CLEAR AVAILED
508	15-Jun-2022	MYSURU	66	HV2	BGNAGARA_66	10:40	17:19	6:39	LINE CLEAR AVAILED
509	15-Jun-2022	MYSURU	66	HV1	DODDINADUVADI_66	10:05	15:35	5:30	LINE CLEAR AVAILED
510	15-Jun-2022	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	9:16	15:36	6:19	NFBC ISSUED
511	15-Jun-2022	MYSURU	66	KM DODDI-MANDYA	KOLKARANADODDI_66KIADBMA	10:35	11:04	0:29	LINE FAULT
512	15-Jun-2022	MYSURU	66	HV2	SUTTUR_66	6:56	7:58	1:01	LINE CLEAR AVAILED
513	15-Jun-2022	MYSURU	66	BEGUR 220KV-HARVEY	HARVEY_66	6:27	6:42	0:15	LINE FAULT
514	15-Jun-2022	MYSURU	220	HV2	NAGAMANGALA_220	18:17	18:55	0:38	TRANSFORMER FAULT
515	15-Jun-2022	MYSURU	66	HV 2	BESAGARAHALLI_66	17:55	18:55	1:00	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
516	15-Jun-2022	MYSURU	66	RK NAGARA-KADAKOLA	NO STATIONS EFFECTED	12:05:59 (04/06/2022)			LINE OPEN, LINE CLEAR AVAILED
517	15-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
518	15-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
519	15-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
520	15-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	5:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
521	15-Jun-2022	TUMKUR	400	GUTTUR_400-400KV NARENDRA LI	GUTTUR_400	11:57:00 PM(14.06.2022)	6:26(15.06.2022)	6:29HRS	LINE CHARGED
522	15-Jun-2022	TUMKUR	400	400KV NELMANGLA-220KV ANCHE	ANCHEPALYA_220	17:56	18:56	1:00	MAIN SUPPLY FAILURE
523	15-Jun-2022	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	3:00:00 PM(14.06.2022)			LINE OPEN, LINE FAULT
524	15-Jun-2022	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOL	AZURE POWER SOLAR_IPP_66	10:30:00 PM(14.06.2022)	6:20(15.06.2022)	7:50HRS	LINE CHARGED
525	15-Jun-2022	TUMKUR	220	GUTTUR 400KV- RANIBENNUR 220	GUTTUR_400	16:27(11.06.2022)	5:06(15.06.2022)	85:39HRS	LINE CHARGED
526	15-Jun-2022	TUMKUR	220	GUTTUR 400KV- VISHWIND1(JOGIH	GUTUR_400	12:00	18:20	6:20	LINE CLEAR AVAILED
527	15-Jun-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	16:35	17:54	1:19	HAND TRIPPED
528	15-Jun-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	10:31	14:59	4:28	NFBC ISSUED
529	15-Jun-2022	TUMKUR	220	220BARC-1-THALLAK_220	THALLAK_220	5:16	5:56	0:40	LINE FAULT
530	15-Jun-2022	TUMKUR	220	THALLAK 220kv- CHITRADURGA_22	THALLAK_220	5:16	5:50	0:34	LINE FAULT
531	15-Jun-2022	TUMKUR	220	THALLAK_220-220KV HM HOLE LIN	THALLAK_220	5:16	5:48	0:32	LINE FAULT
532	15-Jun-2022	TUMKUR	220	TR1(HV SIDE)	THALLAK_220	5:16	5:50	0:34	TRANSFORMER FAULT
533	15-Jun-2022	TUMKUR	220	TR1(LV SIDE)	THALLAK_220	5:16	5:52	0:36	TRANSFORMER FAULT
534	15-Jun-2022	TUMKUR	220	TR2(HV SIDE)	THALLAK_220	5:16	5:50	0:34	TRANSFORMER FAULT
535	15-Jun-2022	TUMKUR	220	TR2(LV SIDE)	THALLAK_220	5:16	5:52	0:36	TRANSFORMER FAULT
536	15-Jun-2022	TUMKUR	220	220KV BUS COUPLER	THALLAK_220	5:16	5:53	0:37	LINE FAULT
537	15-Jun-2022	TUMKUR	220	ANCHEPALYA 220kv- NELMANGALA	ANCHEPALYA_220	17:58	18:31	0:33	MAIN SUPPLY FAILURE
538	15-Jun-2022	TUMKUR	220	ANCHEPALYA 220kv- MAGDI_220	ANCHEPALYA_220	17:58	18:32	0:34	MAIN SUPPLY FAILURE
539	15-Jun-2022	TUMKUR	220	TR1(HV SIDE)	ANCHEPALYA_220	17:58	18:35	0:37	TRANSFORMER FAULT
540	15-Jun-2022	TUMKUR	220	TR1(LV SIDE)	ANCHEPALYA_220	17:58	18:36	0:38	TRANSFORMER FAULT
541	15-Jun-2022	TUMKUR	220	TR2(HV SIDE)	ANCHEPALYA_220	17:58	18:44	0:46	TRANSFORMER FAULT
542	15-Jun-2022	TUMKUR	220	TR2(LV SIDE)	ANCHEPALYA_220	17:58	18:45	0:47	TRANSFORMER FAULT
543	15-Jun-2022	TUMKUR	220	220KV NAGAMANGALA-220KV ANC	ANCHEPALYA_220	17:58	18:50	0:52	MAIN SUPPLY FAILURE
544	15-Jun-2022	TUMKUR	220	220KV NAGAMANGALA-220KV ANC	ANCHEPALYA_220	17:58	18:50	0:52	MAIN SUPPLY FAILURE
545	15-Jun-2022	TUMKUR	220	TR3(HV SIDE)	HIRIYUR_220	15:57	16:22	0:25	TRANSFORMER FAULT
546	15-Jun-2022	TUMKUR	220	TR3(LV SIDE)	HIRIYUR_220	15:57	16:24	0:27	TRANSFORMER FAULT
547	15-Jun-2022	TUMKUR	220	NITTUR 220-NELAMANGALA	NITTUR_220	17:56	20:05	2:09	LINE FAULT
548	15-Jun-2022	TUMKUR	220	ANTHRASANAHALLI 220KV- KB CRO	ANTHRASANAHALLI_220	15:20	17:04	1:44	LINE CLEAR AVAILED
549	15-Jun-2022	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	2:40	6:00	3:20	LINE FAULT
550	15-Jun-2022	TUMKUR	220	ANTHRASANAHALLI 220KV- KB CRO	KBCROSS_220	15:25	16:55	1:30	LINE CLEAR AVAILED
551	15-Jun-2022	TUMKUR	110	TR2	BANDIHALLI_110	10:25	12:00	1:35	LINE CLEAR AVAILED
552	15-Jun-2022	TUMKUR	110	TR1	BANDIHALLI_110	12:35	13:30	0:55	LINE CLEAR AVAILED
553	15-Jun-2022	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TI	2:15	2:35	0:20	HAND TRIPPED
554	15-Jun-2022	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TI	8:40	9:20	0:40	LINE CLEAR AVAILED
555	15-Jun-2022	TUMKUR	66	HIRIYUR_220-66KV THALLAK LINE	HIRIYUR_220	4:30:00 PM(14.06.2022)	8:25(15.06.2022)	15:55HRS	LINE CHARGED
556	15-Jun-2022	TUMKUR	66	HIRIYUR_220-66KV PARSHAMPUR	HIRIYUR_220	4:30:00 PM(14.06.2022)	8:30(15.06.2022)	16:00HRS	LINE CHARGED
557	15-Jun-2022	TUMKUR	66	TR3	HARIYABBE_66	7:10:00 PM(14.06.2022)	8:50(15.06.2022)	13:40HRS	TRANSFORMER CHARGED
558	15-Jun-2022	TUMKUR	66	ANCHEPALYA 220kv- KUNIGAL66	KUNIGAL	17:58	18:58	1:00	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
559	15-Jun-2022	TUMKUR	66	ANCHEPALYA 220kv- ANCHEPALYA	ANCHEPALYA_66, BHAKTHARAH	17:58	18:55	0:57	MAIN SUPPLY FAILURE
560	15-Jun-2022	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,S	17:58	18:58	1:00	MAIN SUPPLY FAILURE
561	15-Jun-2022	TUMKUR	66	ANCHEPALYA 220- HULIYURDURGA	ANCHEPALYA_220	17:58	18:58	1:00	MAIN SUPPLY FAILURE
562	15-Jun-2022	TUMKUR	66	ANCHEPALYA 220- BG NAGARA	ANCHEPALYA_220	17:58	18:58	1:00	MAIN SUPPLY FAILURE
563	15-Jun-2022	TUMKUR	66	ANCHEPALYA 66kv-HEBBUR66	ANTHRASANAHALLI_220	17:58	18:59	1:01	MAIN SUPPLY FAILURE
564	15-Jun-2022	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMAVATT	17:58	18:59	1:01	MAIN SUPPLY FAILURE
565	15-Jun-2022	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAH	KEMPANAHALLI_66, AGALKOTE	17:58	18:59	1:01	MAIN SUPPLY FAILURE
566	15-Jun-2022	TUMKUR	66	ANCHEPALYA 220kv- VIJAYA STEEL	ANCHEPALYA_220	17:58	19:00	1:02	MAIN SUPPLY FAILURE
567	15-Jun-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_6	9:54	19:35	9:41	LINE CLEAR AVAILED
568	15-Jun-2022	TUMKUR	66	CHITRADURGA 66kv- CHITRADURG	CHITRADURGA_66	11:53	13:05	1:12	LINE CLEAR AVAILED
569	15-Jun-2022	TUMKUR	66	CHITRADURGA 66kv- CHITRADURG	CHITRADURGA_66	11:53	13:05	1:12	LINE CLEAR AVAILED
570	15-Jun-2022	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66, HANAGAL_66, NAG	5:38	5:58	0:20	HAND TRIPPED
571	15-Jun-2022	TUMKUR	66	THALLAK 220kv -BGKERE 2		5:38	5:58	0:20	HAND TRIPPED
572	15-Jun-2022	TUMKUR	66	THALLAK 220kv- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLA	5:38	6:01	0:23	HAND TRIPPED
573	15-Jun-2022	TUMKUR	66	THALLAK 220kv- GOWRASAMUDRA		5:38	5:57	0:19	HAND TRIPPED
574	15-Jun-2022	TUMKUR	66	THALLAK 220kv- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	5:38	6:00	0:22	HAND TRIPPED
575	15-Jun-2022	TUMKUR	66	THALLAK 220kv- CHALLAKERE 2		5:38	6:00	0:22	HAND TRIPPED
576	15-Jun-2022	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOL	SEI DIAMOND SOLAR_IPP_66	5:38	5:59	0:21	HAND TRIPPED
577	15-Jun-2022	TUMKUR	66	THALLAK 220kv- SEI VENUS DIAMO	SEI VENUS DIAMOND_IPP_66	5:38	5:59	0:21	HAND TRIPPED
578	15-Jun-2022	TUMKUR	66	THALLAK 220-THALLAK66	THALLAK_66	5:38	5:53	0:15	HAND TRIPPED
579	15-Jun-2022	TUMKUR	66	HIRIYUR220-BEVINAHALLI66	BEVINAHALLI_66,JAVAGONDANA	14:01	14:25	0:24	HAND TRIPPED
580	15-Jun-2022	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	18:57	19:04	0:07	LINE FAULT
581	15-Jun-2022	TUMKUR	66	TR2	HIRIYUR_220	11:30	12:05	0:35	LINE CLEAR AVAILED
582	15-Jun-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HA	8:30	18:14	9:44	LINE CLEAR AVAILED
583	15-Jun-2022	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	8:10	8:15	0:05	LINE FAULT
584	15-Jun-2022	TUMKUR	66	TR1	SIRA_220	1:45	1:55	0:10	TRANSFORMER FAULT
585	15-Jun-2022	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NA	DEVARAHALLI_66, LINGADAHALL	19:17	20:26	1:09	HAND TRIPPED
586	15-Jun-2022	TUMKUR	66	TR1	BHARAMAGIRI_66	8:40	8:45	0:05	TRANSFORMER FAULT
587	15-Jun-2022	TUMKUR	66	TR1	BHARAMAGIRI_66	20:40	20:45	0:05	TRANSFORMER FAULT
588	15-Jun-2022	TUMKUR	66	TR1	BHARAMAGIRI_66	21:05	21:10	0:05	TRANSFORMER FAULT
589	15-Jun-2022	TUMKUR	66	BEVINAHALLI- JAVAGONDANAHALL	BEVINAHALLI_66	14:00	14:25	0:25	MAIN SUPPLY FAILURE
590	15-Jun-2022	TUMKUR	66	BEVINAHALLI- AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	19:05	19:25	0:20	LINE FAULT
591	15-Jun-2022	TUMKUR	66	TR1	BUKKAPATANA_66	15:55	17:30	1:35	LINE CLEAR AVAILED
592	15-Jun-2022	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 1	MEGMICON 1_IPP_66	16:31	17:47	1:16	LINE CLEAR AVAILED
593	15-Jun-2022	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 2	MEGMICON 2_IPP_66	16:31	17:47	1:16	LINE CLEAR AVAILED
594	15-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	0:00	0:05	0:05	LINE FAULT
595	15-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:35	5:40	0:05	LINE FAULT
596	15-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:20	17:25	0:05	LINE FAULT
597	15-Jun-2022	TUMKUR	66	TR1 AND TR2	PD KOTE_66	11:18	11:25	0:07	MAIN SUPPLY FAILURE
598	15-Jun-2022	TUMKUR	66	TR1	KUNDUR_66	8:25	8:35	0:10	TRANSFORMER FAULT
599	15-Jun-2022	TUMKUR	66	TR1	KUNDUR_66	8:30	9:25	0:55	LINE CLEAR AVAILED
600	15-Jun-2022	TUMKUR	66	TR1 ,TR2 AND TR3	KUKKAWADA_66	10:00	17:30	7:30	LINE CLEAR AVAILED
601	15-Jun-2022	TUMKUR	66	TR1	MATHOD_66	18:20	18:30	0:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
602	15-Jun-2022	TUMKUR	66	TR1	MYLANAHALLI_66	16:30	17:15	0:45	LINE CLEAR AVAILED
603	15-Jun-2022	TUMKUR	66	TR1 AND TR2	THALLAK_66	5:15	5:53	0:38	MAIN SUPPLY FAILURE
604	16-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGAN	STATION NOT AFFECTEDPG HUN	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
605	16-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTEDLAXMES	17:55(28.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
606	16-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTEDAMBEW	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
607	16-Jun-2022	BAGALKOT	220	BELGAUM- CHIKKODI2(AEQU2)	STATION NOT AFFECTEDBELGAU	12:02 (13.06.2022)			LINE OPEN, LINE CLEAR AVAILED
608	16-Jun-2022	BAGALKOT	220	AEQUS- CHIKKODI1	STATION NOT AFFECTEDAEQU	12:04 (13.06.2022)			LINE OPEN, LINE CLEAR AVAILED
609	16-Jun-2022	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTEDHUBLI_2	11:37 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
610	16-Jun-2022	BAGALKOT	110	110/33KV,HV1	HANAGAL_110	16:0(15.06.2022)	8:42(16.06.2022)	26:42HRS	TRANSFORMER CHARGED
611	16-Jun-2022	BAGALKOT	220	AMBEWADI- NARENDRA1	STATION NOT AFFECTEDAMBEW	10:13 (15.06.2022)			LINE OPEN, LINE CLEAR AVAILED
612	16-Jun-2022	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTEDNAREND	10:05 (15.06.2022)			LINE OPEN, LINE CLEAR AVAILED
613	16-Jun-2022	BAGALKOT	110	BANAHATTI- JAMKHADI(NAVALAGI	STATION NOT AFFECTEDBANAHA	10:08	14:18	4:10	LINE CLEAR AVAILED
614	16-Jun-2022	BAGALKOT	110	110/11KV, HV2	BIDNAL_220	11:15	19:12	7:57	LINE CLEAR AVAILED
615	16-Jun-2022	BAGALKOT	110	THORVI- BHUTANAL	THORVI_110	5:59	6:08	0:09	HAND TRIPPED
616	16-Jun-2022	BAGALKOT	110	110/11KV, HV1	THORVI_110	10:35	10:40	0:05	TRANSFORMER FAULT
617	16-Jun-2022	BAGALKOT	110	ATHANI220- F1 (HALIYAL(ATHN))	HALIYAL(ATHANI)_110	13:00	13:20	0:20	LINE FAULT
618	16-Jun-2022	BAGALKOT	110	HALIYAL(ATHN)- F2(LIS)	STATION NOT AFFECTEDHALIYAL	13:00	13:40	0:40	LINE FAULT
619	16-Jun-2022	BAGALKOT	110	HALIYAL(ATHN)- F2(LIS)	STATION NOT AFFECTEDHALIYAL	13:55 (16.06.2022)			LINE OPEN, LINE FAULT
620	16-Jun-2022	BAGALKOT	110	110/11KV, HV1	HATTARAGI_110	13:30	14:16	0:46	LINE CLEAR AVAILED
621	16-Jun-2022	BAGALKOT	110	HIDAKAL DAM-ANKALGI	ANKALGI_110	13:40	13:48	0:08	HAND TRIPPED
622	16-Jun-2022	BAGALKOT	110	YELLAMANAWADI-SAVALALAGI	SAVALAGI_110	13:13	13:22	0:09	HAND TRIPPED
623	16-Jun-2022	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	23:52(16.06.2022)			LINE OPEN, LINE FAULT
624	16-Jun-2022	BAGALKOT	110	THORVI-TAKKALAKI	TAKKALAKI_110	11:37	11:38	0:01	HAND TRIPPED
625	16-Jun-2022	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	11:38	11:41	0:03	HAND TRIPPED
626	16-Jun-2022	BAGALKOT	110	110/11KV,HV1	SULTANPUR_110	11:45	13:36	1:51	LINE CLEAR AVAILED
627	16-Jun-2022	BAGALKOT	110	SAVALAGI-AIGALI	SAVALAGI_110	6:09	8:05	1:56	HAND TRIPPED
628	16-Jun-2022	BAGALKOT	110	SAVALAGI-AIGALI	SAVALAGI_110	9:57	12:18	2:21	HAND TRIPPED
629	16-Jun-2022	BAGALKOT	110	RON-NAREGAL	NAREGAL_110	12:46	17:46	5:00	LINE CLEAR AVAILED
630	16-Jun-2022	BAGALKOT	110	SATTI-RABAKAVI	SATTI_110	12:33	12:35	0:02	HAND TRIPPED
631	16-Jun-2022	BAGALKOT	110	110/11KV,HV1	RAMANAKOPPA_110	10:56	17:23	6:27	LINE CLEAR AVAILED
632	16-Jun-2022	BAGALKOT	110	NAVALAGI-JAMAKHANDI	NAVALAGI_110	10:06	14:20	4:14	LINE CLEAR AVAILED
633	16-Jun-2022	BAGALKOT	110	BANAHATTI-NAVALAGI	NAVALAGI_110	16:29	17:18	0:49	LINE CLEAR AVAILED
634	16-Jun-2022	BAGALKOT	110	BANAHATTI-NAVALAGI	NAVALAGI_110	10:06	14:20	4:14	LINE CLEAR AVAILED
635	16-Jun-2022	BAGALKOT	110	110/11KV,HV1&HV2	NAVALAGI_110	10:07	14:20	4:13	LINE CLEAR AVAILED
636	16-Jun-2022	BAGALKOT	110	NAREGAL-BETAGERI	NAREGAL_110	12:50	17:52	5:02	LINE CLEAR AVAILED
637	16-Jun-2022	BAGALKOT	110	MAMADAPUR-TODALBAGI(KAMBA	KAMBAGI_110	12:07	13:33	1:26	LINE CLEAR AVAILED
638	16-Jun-2022	BAGALKOT	220	220/110KV,HV3,LV3	STATION NOT AFFECTEDMAHALI	12:35	13:05	0:30	LINE CLEAR AVAILED
639	16-Jun-2022	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	9:58	19:05	9:07	LINE CLEAR AVAILED
640	16-Jun-2022	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	STATION NOT AFFECTEDRABAKA	12:31	13:19	0:48	LINE CLEAR AVAILED
641	16-Jun-2022	BAGALKOT	220	MAHALINGAPUR- NARENDRA2	STATION NOT AFFECTEDMAHALI	17:45	22:57	5:12	LINE CLEAR AVAILED
642	16-Jun-2022	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTEDKUMTA	15:00	18:39	3:39	LINE FAULT
643	16-Jun-2022	BAGALKOT	110	MAHALINGAPUR(NAVALAGI)-JAMA	JAMAKHANDI_110	10:21	17:22	7:01	LINE CLEAR AVAILED
644	16-Jun-2022	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	8:38	17:22	8:44	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
645	16-Jun-2022	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	10:14	16:38	6:24	LINE CLEAR AVAILED
646	16-Jun-2022	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	10:14	16:41	0:05	LINE CLEAR AVAILED
647	16-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
648	16-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
649	16-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
650	16-Jun-2022	BAGALKOT	220	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	18:35 (15.06.2022)	2:57(16.06.2022)	28:22HRS	LINE CHARGED
651	16-Jun-2022	BAGALKOT	110	220/110KV, LV1	ATHANI_220	11:33	12:11	0:38	TRANSFORMER FAULT
652	16-Jun-2022	BAGALKOT	220	220/110KV, HV2	ATHANI_220	11:33	12:08	0:35	TRANSFORMER FAULT
653	16-Jun-2022	BAGALKOT	110	220/110KV, LV2	ATHANI_220	11:33	12:11	0:38	TRANSFORMER FAULT
654	16-Jun-2022	BAGALKOT	110	110/11KV, HV1	ATHANI_220	11:33	12:12	0:39	TRANSFORMER FAULT
655	16-Jun-2022	BAGALKOT	110	220ATHANI- AIGALI	AIGALI_110	11:33	12:15	0:42	LINE FAULT
656	16-Jun-2022	BAGALKOT	110	220ATHANI- ATHANI	ATHANI_110	11:33	12:11	0:38	HAND TRIPPED
657	16-Jun-2022	BAGALKOT	110	220ATHANI- BALIGERI	BALIGERI_110	11:33	12:11	0:38	HAND TRIPPED
658	16-Jun-2022	BAGALKOT	110	220ATHANI- KARIMASUTI	KARIMASUTI_110ATHANI_220	11:33	12:11	0:38	HAND TRIPPED
659	16-Jun-2022	BAGALKOT	110	220ATHANI- HALYAL	HALAYAL_110	11:33	12:11	0:38	HAND TRIPPED
660	16-Jun-2022	BAGALKOT	110	220ATHANI- KSSKN	KSSKN_110ATHANI_220	11:33	12:11	0:38	HAND TRIPPED
661	16-Jun-2022	BAGALKOT	110	220ATHANI- AIGALI	AIGALI_110	12:43	12:48	0:05	LINE FAULT
662	16-Jun-2022	BAGALKOT	110	220/110KV, LV1	ATHANI_220	12:59	13:09	0:10	TRANSFORMER FAULT
663	16-Jun-2022	BAGALKOT	220	220/110KV, HV2	ATHANI_220	12:59	13:08	0:09	TRANSFORMER FAULT
664	16-Jun-2022	BAGALKOT	110	220/110KV, LV2	ATHANI_220	12:59	13:09	0:10	TRANSFORMER FAULT
665	16-Jun-2022	BAGALKOT	110	110/11KV, HV1	ATHANI_220	12:59	13:09	0:10	HAND TRIPPED
666	16-Jun-2022	BAGALKOT	110	220ATHANI- AIGALI	AIGALI_110	12:59	13:10	0:11	HAND TRIPPED
667	16-Jun-2022	BAGALKOT	110	220ATHANI- ATHANI	ATHANI_110	12:59	13:10	0:11	HAND TRIPPED
668	16-Jun-2022	BAGALKOT	110	220ATHANI- BALIGERI	BALIGERI_110	12:59	13:09	0:10	HAND TRIPPED
669	16-Jun-2022	BAGALKOT	110	220ATHANI- KARIMASUTI	KARIMASUTI_110ATHANI_220	12:59	13:09	0:10	HAND TRIPPED
670	16-Jun-2022	BAGALKOT	110	220ATHANI- HALYAL	ATHANI_220	12:59	13:09	0:10	HAND TRIPPED
671	16-Jun-2022	BAGALKOT	110	220ATHANI- KSSKN	KSSKN_110ATHANI_220	12:59	13:09	0:10	HAND TRIPPED
672	16-Jun-2022	BAGALKOT	110	220ATHANI- SATTI	ATHANI_220	11:33	12:21	0:48	LINE FAULT
673	16-Jun-2022	BAGALKOT	110	110/11KV, HV1	BIDNAL_220	11:13	14:34	3:21	LINE CLEAR AVAILED
674	16-Jun-2022	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTEDSATTI_11	13:10	13:20	0:10	HAND TRIPPED
675	16-Jun-2022	BAGALKOT	110	SATTI-RABAKAVI	SATTI_110	13:35	13:45	0:10	HAND TRIPPED
676	16-Jun-2022	BAGALKOT	110	ATHANI-SATTI	SATTI_110	13:40	13:50	0:10	HAND TRIPPED
677	16-Jun-2022	BAGALKOT	110	SATTI-RABAKAVI	SATTI_110	18:45	18:50	0:05	HAND TRIPPED
678	16-Jun-2022	BAGALKOT	110	ATHANI-SATTI	SATTI_110	18:35	18:48	0:13	HAND TRIPPED
679	16-Jun-2022	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	17:30	17:35	0:05	LOAD CHANGE OVER
680	16-Jun-2022	BENGALURU	66	HV1	KADUBISANAHALLI	6:44	10:48	4:04	LINE CLEAR AVAILED
681	16-Jun-2022	BENGALURU	66	HV1	KOTHIPURA 220	10:38	11:43	1:05	TRANSFORMER FAULT
682	16-Jun-2022	BENGALURU	66	HV1	KORAMANGALA 220	13:23	14:48	1:25	LINE CLEAR AVAILED
683	16-Jun-2022	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	7:02	7:08	0:06	LOAD CHANGE OVER
684	16-Jun-2022	BENGALURU	66	HV2	SOLDEVANAHALLI	11:05	11:06	0:01	LINE CLEAR AVAILED
685	16-Jun-2022	BENGALURU	66	HV1	SOLDEVANAHALLI	12:37	12:39	0:02	LINE CLEAR AVAILED
686	16-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	22:31	22:41	0:10	LINE FAULT
687	16-Jun-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	11:21	11:35	0:14	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
688	16-Jun-2022	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	10:03	10:24	0:21	LINE FAULT
689	16-Jun-2022	BENGALURU	66	HV2	SIR MV LAYOUT	19:16	19:30	0:14	TRANSFORMER FAULT
690	16-Jun-2022	BENGALURU	66	HV1	RMV	12:19	12:28	0:09	TRANSFORMER FAULT
691	16-Jun-2022	BENGALURU	66	HV2	VOLVO	14:22	14:24	0:02	TRANSFORMER FAULT
692	16-Jun-2022	BENGALURU	66	HV2	VOLVO	11:24	11:30	0:05	LINE CLEAR AVAILED
693	16-Jun-2022	BENGALURU	66	HV1	TUBUGERE	7:00	7:20	0:20	LINE CLEAR AVAILED
694	16-Jun-2022	BENGALURU	66	HV2	TEKAL	15:02	15:37	0:35	LINE CLEAR AVAILED
695	16-Jun-2022	BENGALURU	66	HV1	SIRIGIRIPURA	7:55	8:07	0:11	TRANSFORMER FAULT
696	16-Jun-2022	BENGALURU	66	HV1	ATTIBELE	7:25	9:50	2:25	TRANSFORMER FAULT
697	16-Jun-2022	BENGALURU	66	HV1	ATTIBELE	14:12	15:03	0:51	LINE CLEAR AVAILED
698	16-Jun-2022	BENGALURU	66	HV2	ATTIBELE	3:45	4:40	0:55	TRANSFORMER FAULT
699	16-Jun-2022	BENGALURU	66	HV2	ATTIBELE	13:05	13:55	0:50	LINE CLEAR AVAILED
700	16-Jun-2022	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	15:20	15:53	0:33	LINE CLEAR AVAILED
701	16-Jun-2022	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAH	ID HALLI, KODIGENAHALLI	12:08	12:22	0:14	LINE CLEAR AVAILED
702	16-Jun-2022	BENGALURU	66	DALASANUR - SRINIVASPURA	YELDUR	10:34	13:09	2:34	LINE CLEAR AVAILED
703	16-Jun-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHA	NANDIGANAHALLI	0:43	0:51	0:07	LINE FAULT
704	16-Jun-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHA	NANDIGANAHALLI	1:45	2:43	0:58	LINE FAULT
705	16-Jun-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHA	NANDIGANAHALLI	3:09	6:44	3:34	LINE FAULT
706	16-Jun-2022	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHA	NANDIGANAHALLI	13:15	15:49	2:33	LINE CLEAR AVAILED
707	16-Jun-2022	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	23:37:36(16-6-2022)			LINE OPEN, LINE FAULT
708	16-Jun-2022	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGH	HIMAT SINGHA FACTORY (EHT)	22:51:27(14-6-2022)	2:00(16/06/2022)	47:07hrs	LINE CHARGED
709	16-Jun-2022	BENGALURU	220	HV2	BRINDAVANA 220	17:55(15/06/2022)	0:30(16/06/2022)	26:35HRS	TRANSFORMER CHARGED
710	16-Jun-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
711	16-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)			LINE OPEN, LINE FAULT
712	16-Jun-2022	GULBARGA	400	RTPS-BTPS	RTPS_400	20:29 (15.06.2022)	5:06 (16.06.2022)	18:37 HRS	LINE CHARGED
713	16-Jun-2022	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
714	16-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN, LINE FAULT
715	16-Jun-2022	GULBARGA	220	HV2	ITTAGI_220	17:10	17:22	0:12	TRANSFORMER FAULT
716	16-Jun-2022	GULBARGA	220	HV1	KUSTAGI_220	11:15	18:50	7:35	LINE CLEAR AVAILED
717	16-Jun-2022	GULBARGA	220	HV1	MUNIRABAD_220	9:40	16:30	6:50	LINE CLEAR AVAILED
718	16-Jun-2022	GULBARGA	220	MALLAT-RTPS	MALLAT_220	4:50	5:10	0:20	LINE FAULT
719	16-Jun-2022	GULBARGA	220	KUSTAGI-SULEKAL	KUSTAGI_220	17:40	20:00	2:20	LINE CLEAR AVAILED
720	16-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
721	16-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN, LINE CLEAR AVAILED
722	16-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN, LINE CLEAR AVAILED
723	16-Jun-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN	10:40(16/06/2022)			LINE OPEN, LINE CLEAR AVAILED
724	16-Jun-2022	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK	10:55(16/06/2022)			LINE OPEN, LINE CLEAR AVAILED
725	16-Jun-2022	GULBARGA	110	LV1,LV2	SHAHAPUR_220	4:10	4:20	0:10	TRANSFORMER FAULT
726	16-Jun-2022	GULBARGA	110	HV1	NIRNA_110	17:25	18:25	1:00	LINE CLEAR AVAILED
727	16-Jun-2022	GULBARGA	110	HV1	KADAGANCHI_110	9:30	13:50	4:20	TRANSFORMER FAULT
728	16-Jun-2022	GULBARGA	110	HV1	MARGUTTI_110	11:20	14:18	2:58	LINE CLEAR AVAILED
729	16-Jun-2022	GULBARGA	110	LV1,LV2	ITTAGI_220	17:10	17:20	0:10	TRANSFORMER FAULT
730	16-Jun-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	0:45	0:50	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
731	16-Jun-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR_1	SHAHAPUR_110	4:10	4:24	0:14	LINE FAULT
732	16-Jun-2022	GULBARGA	110	SHAHAPUR-SHAHAPUR_2	NALWAR_110,JEWARGI_110	4:10	4:26	0:16	LINE FAULT
733	16-Jun-2022	GULBARGA	110	NALWAR-WARAD_SOLAR_IPP	NALWAR_110,JEWARGI_110	14:40	23:59	9:19	LINE CLEAR AVAILED
734	16-Jun-2022	GULBARGA	110	KAVITHAL-MALLAT	KAVITHAL_110	22:20	22:25	0:05	MAIN SUPPLY FAILURE
735	16-Jun-2022	GULBARGA	110	NALWAR-SHAHAPUR1	NALWAR_110	4:05	4:25	0:20	LINE FAULT
736	16-Jun-2022	GULBARGA	110	NALWAR-SHAHAPUR2	NALWAR_110,JEWARGI_110	4:05	4:25	0:20	LINE FAULT
737	16-Jun-2022	GULBARGA	110	CHINCHOLI-SEDAM1	CHINCHOLI_110	12:54	13:20	0:26	LINE CLEAR AVAILED
738	16-Jun-2022	GULBARGA	110	MARGUTTI-KAPNOOR	MARGUTTI_110	10:50	11:58	1:08	NFBC ISSUED
739	16-Jun-2022	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	4:15	4:25	0:10	MAIN SUPPLY FAILURE
740	16-Jun-2022	GULBARGA	110	RAICHUR-SHAHAPUR_2	GOOGLE_110	0:51	0:57	0:06	LINE FAULT
741	16-Jun-2022	GULBARGA	110	SINDHANOOR-SINDHANOOR_1	SINDHANOOR_110,MUDDAPUR	4:40	4:45	0:05	LINE FAULT
742	16-Jun-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD_2	MUKUNDA_110,YARADONA_110	9:30	9:35	0:05	LINE CLEAR AVAILED
743	16-Jun-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD_2	MUKUNDA_110,YARADONA_110	16:55	17:02	0:07	LINE CLEAR AVAILED
744	16-Jun-2022	GULBARGA	110	SINDHANOOR-SINDHANOOR_2	SINDHANOOR_110,VALKAMDIN	12:05	12:16	0:11	LINE FAULT
745	16-Jun-2022	GULBARGA	110	SINDHANOOR-SIRAGUPPA	TEKKALAKOTE_110, SIRIGUPPA	23:30	23:40	0:10	LINE FAULT
746	16-Jun-2022	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY N	13:23	13:35	0:12	LINE FAULT
747	16-Jun-2022	GULBARGA	110	MUNIRABAD-SINDHANOOR_1	VENKATAGIRI_110,GANGAVATH	9:21	11:03	1:42	LINE CLEAR AVAILED
748	16-Jun-2022	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	12:09	12:51	0:42	LINE CLEAR AVAILED
749	16-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	10:39	10:46	0:07	LINE FAULT
750	16-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:10	11:17	0:07	LINE FAULT
751	16-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110	16:25	17:54	1:29	LINE CLEAR AVAILED
752	16-Jun-2022	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	22:20	22:24	0:04	LINE FAULT
753	16-Jun-2022	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	10:55	12:58	2:03	LINE CLEAR AVAILED
754	16-Jun-2022	GULBARGA	110	SEDAM-VASAVADATTA_IPP	SEDAM_220	11:19	11:25	0:06	LINE FAULT
755	16-Jun-2022	GULBARGA	66	HV2	UJJAINI_66	17:10	17:15	0:05	TRANSFORMER FAULT
756	16-Jun-2022	GULBARGA	66	PUNABGHATA-UCHANGIDURGA	UCHANGIDURGA_66,BILCHOD_66	10:50	11:05	0:15	LINE FAULT
757	16-Jun-2022	GULBARGA	66	PUNABGHATA-UCHANGIDURGA	UCHANGIDURGA_66,BILCHOD_66	11:10	11:25	0:15	LINE FAULT
758	16-Jun-2022	GULBARGA	66	PUNABGHATA-UCHANGIDURGA	UCHANGIDURGA_66,BILCHOD_66	12:20	13:00	0:40	LINE FAULT
759	16-Jun-2022	GULBARGA	66	PUNABGHATA-UCHANGIDURGA	UCHANGIDURGA_66,BILCHOD_66	13:50	14:40	0:50	LINE FAULT
760	16-Jun-2022	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCHCHANGID	17:41	17:52	0:11	LINE FAULT
761	16-Jun-2022	GULBARGA	66	ITTAGI-HAGRIBOMMANHALLI	HAGRIBOMMANHALLI_66,UPAN	17:10	18:32	1:22	LINE FAULT
762	16-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
763	16-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
764	16-Jun-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
765	16-Jun-2022	HASSAN	220	HV1	HOLENARASIPURA_220	10:12	12:48	2:36	LINE CLEAR AVAILED
766	16-Jun-2022	HASSAN	66	LV1	HOLENARASIPURA_220	10:12	12:50	2:38	LINE CLEAR AVAILED
767	16-Jun-2022	HASSAN	220	KEMAR-UPCL1	KEMAR_220	9:45	18:48	9:03	LINE CLEAR AVAILED
768	16-Jun-2022	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:35	13:36	3:01	LINE CLEAR AVAILED
769	16-Jun-2022	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	10:07	13:57	3:50	LINE CLEAR AVAILED
770	16-Jun-2022	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	11:40	12:17	0:37	LINE FAULT
771	16-Jun-2022	HASSAN	220	UPCL-KEMAR1	upcl_gen	9:45	18:48	9:03	NFBC ISSUED
772	16-Jun-2022	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:36	13:35	2:59	NFBC ISSUED
773	16-Jun-2022	HASSAN	110	HV1	MSEZ_220	11:28	13:56	2:28	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
774	16-Jun-2022	HASSAN	110	HV4	PUTTUR_220	9:06	14:00	4:54	LINE CLEAR AVAILED
775	16-Jun-2022	HASSAN	66	HV2	ARAKALGUD_66	5:11	5:53	0:42	TRANSFORMER FAULT
776	16-Jun-2022	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	11:27	13:32	2:05	NFBC ISSUED
777	16-Jun-2022	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	11:22	13:40	2:18	LINE CLEAR AVAILED
778	16-Jun-2022	HASSAN	66	HV1	RAMESHWARNAGARA_66	11:22	17:40	6:18	LINE CLEAR AVAILED
779	16-Jun-2022	HASSAN	66	HV2	RAMESHWARNAGARA_66	10:10	14:00	3:50	LINE CLEAR AVAILED
780	16-Jun-2022	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	15:17	15:37	0:20	LINE FAULT
781	16-Jun-2022	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	11:27	13:32	2:05	NFBC ISSUED
782	16-Jun-2022	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	9:30	10:00	0:30	LINE FAULT
783	16-Jun-2022	MYSURU	66	HV1	ARAKERE_66	14:52	15:14	0:22	LINE CLEAR AVAILED
784	16-Jun-2022	MYSURU	66	HV2	CHANDAKAVADI_66	14:34	15:06	0:32	LINE CLEAR AVAILED
785	16-Jun-2022	MYSURU	66	HV1	CHUNCHUNKATTE_66	21:09	21:33	0:24	TRANSFORMER FAULT
786	16-Jun-2022	MYSURU	66	HV2	DEVANOORMYS_66	11:18	13:03	1:44	LINE CLEAR AVAILED
787	16-Jun-2022	MYSURU	66	HV1	JAKKANAHALLY_66	10:13	11:17	1:03	LINE CLEAR AVAILED
788	16-Jun-2022	MYSURU	220	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	22:14	22:44	0:30	LINE FAULT
789	16-Jun-2022	MYSURU	66	TALAKADU-PARINAMIPURA	PARINAMIPURA_66	4:32	4:37	0:05	LINE FAULT
790	16-Jun-2022	MYSURU	66	HEBBANI-SHIMSHA	MALAVALLI_66HADLI_66	10:00	10:20	0:20	LINE FAULT
791	16-Jun-2022	MYSURU	66	HEBBANI-MEGALAPURA	TNARASIPURA_66BGPURA_66CH	12:20	12:28	0:08	LINE FAULT
792	16-Jun-2022	MYSURU	220	HEBBANI-TK HALLI-1	NO STATIONS EFFECTED	22:13	22:16	0:03	LINE FAULT
793	16-Jun-2022	MYSURU	220	HV1	HEBBANI_220	22:13	22:50	0:37	TRANSFORMER FAULT
794	16-Jun-2022	MYSURU	220	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	22:40	22:43	0:03	HAND TRIPPED
795	16-Jun-2022	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORMYS_66SUTTUR_66	0:05	0:11	0:05	LINE FAULT
796	16-Jun-2022	MYSURU	66	KR PETE 220-BOOKANAKERE	CHINAKURALI_66 BANANGADI_66	19:35	19:41	0:06	LINE FAULT
797	16-Jun-2022	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	6:00	6:05	0:05	LINE FAULT
798	16-Jun-2022	MYSURU	66	HALAGUR-HV2	NO STATIONS EFFECTED	10:00	12:40	2:40	LINE CLEAR AVAILED
799	16-Jun-2022	MYSURU	66	RK NAGARA-KADAKOLA	NO STATIONS EFFECTED	12:05:59 (04/06/2022)			LINE OPEN, LINE CLEAR AVAILED
800	16-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
801	16-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
802	16-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
803	16-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	5:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
804	16-Jun-2022	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	3:00:00 PM(14.06.2022)			LINE OPEN, LINE FAULT
805	16-Jun-2022	TUMKUR	400	ICT-1	GUTTUR_400	10:10	19:12	9:02	LINE CLEAR AVAILED
806	16-Jun-2022	TUMKUR	220	ANTHARASANAHALLI_220 -KB CROSS	ANTHARASANAHALLI_220	12:30	17:05	4:35	LINE CLEAR AVAILED
807	16-Jun-2022	TUMKUR	66	CHITRADURGA 220KV- TURUVANUR	MADANAYAKANAHALLI_66, TUR	10:14	18:53	8:39	LINE CLEAR AVAILED
808	16-Jun-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66	9:52	19:35	9:43	LINE CLEAR AVAILED
809	16-Jun-2022	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NAGAR)	DEVARAHALLI_66, LINGADAHALLI	9:38	9:54	0:16	LINE FAULT
810	16-Jun-2022	TUMKUR	66	220 KV HOSADURGA-66_BAGUR	220_HOSADURGA	6:30	19:30	13:00	LINE CLEAR AVAILED
811	16-Jun-2022	TUMKUR	66	220 KV HOSADURGA-66_NEERGUND	220_HOSADURGA	6:30	7:50	1:20	LINE CLEAR AVAILED
812	16-Jun-2022	TUMKUR	66	220_HOSADURGA-66_HOSADURGA	220_HOSADURGA	6:30	6:45	0:15	LINE CLEAR AVAILED
813	16-Jun-2022	TUMKUR	66	TR1	HARIYABBE_66	12:55	13:20	0:25	MAIN SUPPLY FAILURE
814	16-Jun-2022	TUMKUR	66	TR2	HARIYABBE_66	12:55	13:20	0:25	MAIN SUPPLY FAILURE
815	16-Jun-2022	TUMKUR	66	TR3	HARIYABBE_66	12:55	13:20	0:25	MAIN SUPPLY FAILURE
816	16-Jun-2022	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	4:10	4:15	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
817	16-Jun-2022	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	12:18	14:00	1:42	LINE CLEAR AVAILED
818	16-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA	12:55	14:00	1:05	LINE CLEAR AVAILED
819	16-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA	14:10	14:15	0:05	HAND TRIPPED
820	16-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:45	18:00	0:15	LINE FAULT
821	16-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:07	19:20	0:13	LINE FAULT
822	16-Jun-2022	TUMKUR	66	TR2	HOSADURGA_66	20:35	20:40	0:05	TRANSFORMER FAULT
823	16-Jun-2022	TUMKUR	66	TR1	NEERGUNDA_66	6:40	8:10	1:30	MAIN SUPPLY FAILURE
824	16-Jun-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66	9:50	10:05	0:15	MAIN SUPPLY FAILURE
825	16-Jun-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66	10:05	19:40	9:35	LINE CLEAR AVAILED
826	16-Jun-2022	TUMKUR	66	TR1	LOKIKERE_66	9:50	10:00	0:10	MAIN SUPPLY FAILURE
827	16-Jun-2022	TUMKUR	66	66_KUKKAWADA-LOKIKERE_66	LOKIKERE_66	10:00	19:40	9:40	LINE CLEAR AVAILED
828	16-Jun-2022	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	10:15	11:04	0:49	MAIN SUPPLY FAILURE
829	16-Jun-2022	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	11:09	12:13	1:04	MAIN SUPPLY FAILURE
830	16-Jun-2022	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	12:20	13:40	1:20	MAIN SUPPLY FAILURE
831	16-Jun-2022	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	13:56	15:07	1:11	MAIN SUPPLY FAILURE
832	16-Jun-2022	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	16:02	16:04	0:02	MAIN SUPPLY FAILURE
833	16-Jun-2022	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	17:40	18:05	0:25	MAIN SUPPLY FAILURE
834	16-Jun-2022	TUMKUR	66	TR1 AND TR2	MADANAYAKANAHALLI_66	18:18	18:55	0:37	MAIN SUPPLY FAILURE
835	16-Jun-2022	TUMKUR	66	TR1	PANDARAHALLI_66	12:20	13:08	0:48	HAND TRIPPED
836	17-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGAN	STATION NOT AFFECTEDPG HUN	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
837	17-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTEDLAXMES	17:55(28.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
838	17-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTEDAMBEW	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
839	17-Jun-2022	BAGALKOT	220	BELGAUM- CHIKKODI2(AEQUS2)	STATION NOT AFFECTEDBELGAU	12:02 (13.06.2022)	18:14(17.06.2022)	97:12HRS	LINE CHARGED
840	17-Jun-2022	BAGALKOT	220	AEQUS- CHIKKODI1	STATION NOT AFFECTEDAEQUS_	12:04 (13.06.2022)	18:40 (17.06.2022)	96:36HRS	LINE CHARGED
841	17-Jun-2022	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTEDHUBLI_2	11:37 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
842	17-Jun-2022	BAGALKOT	220	AMBEWADI- NARENDRA1	STATION NOT AFFECTEDAMBEW	10:13 (15.06.2022)			LINE OPEN, LINE CLEAR AVAILED
843	17-Jun-2022	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTEDNAREND	10:05 (15.06.2022)			LINE OPEN, LINE CLEAR AVAILED
844	17-Jun-2022	BAGALKOT	110	HALIYAL(ATHN)- F2(HALIYAL LIS)	STATION NOT AFFECTEDHALIYAL	13:55 (16.06.2022)			LINE OPEN, LINE FAULT
845	17-Jun-2022	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	23:52(16.06.2022)	09:09(17.06.2022)	0:17HRS	LINE CHARGED
846	17-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDALAMEL	15:30	15:41	0:11	TRANSFORMER FAULT
847	17-Jun-2022	BAGALKOT	110	110/11KV, HV2	ALABAL_110	7:46	11:26	3:40	NFBC ISSUED
848	17-Jun-2022	BAGALKOT	110	LABAL-SAIPRIYA SUGARS	SAIPRIYA SUGARS_110ALABAL_1	7:46	11:26	3:40	NFBC ISSUED
849	17-Jun-2022	BAGALKOT	110	LABAL-RAYSOLAR	RAY SOLAR_110ALABAL_110	7:46	11:26	3:40	NFBC ISSUED
850	17-Jun-2022	BAGALKOT	110	ANKOLA-KUMTA-2	STATION NOT AFFECTEDANKOLA	16:04	17:34	1:30	NFBC ISSUED
851	17-Jun-2022	BAGALKOT	110	AEQUS220-HATTARGI	HATTARGI_110	17:38	17:42	0:04	HAND TRIPPED
852	17-Jun-2022	BAGALKOT	110	BELLATTI-ENERCON2	ENERCON2_110BELLATTI_110	12:11	13:51	1:40	HAND TRIPPED
853	17-Jun-2022	BAGALKOT	110	BELLATTI-AB SOLAR	AB SOLAR_110BELLATTI_110	12:11	13:53	1:42	HAND TRIPPED
854	17-Jun-2022	BAGALKOT	110	GHATAPRABHA-HIDKAL DAM	STATION NOT AFFECTEDGHATAP	16:42	18:08	1:26	NFBC ISSUED
855	17-Jun-2022	BAGALKOT	110	HIREHAL-MYFAR SOLAR	MYFAR SOLAR_110HIREHAL_110	9:54	10:10	0:16	HAND TRIPPED
856	17-Jun-2022	BAGALKOT	110	110/11KV, HV1	HALKI_110	11:00	16:27	5:27	LINE CLEAR AVAILED
857	17-Jun-2022	BAGALKOT	110	110/11KV, HV1	ISLAMPUR_110	15:27	17:41	2:14	LINE CLEAR AVAILED
858	17-Jun-2022	BAGALKOT	110	ISLAMPUR-GHATAPRABHA220	ISLAMPUR_110	15:27	17:41	2:14	LINE CLEAR AVAILED
859	17-Jun-2022	BAGALKOT	110	110/33KV, HV1	STATION NOT AFFECTEDJAMAKH	15:24	18:37	3:13	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
860	17-Jun-2022	BAGALKOT	110	HIDAKAL DAM-GHATAPRABHA220	HIDAKAL DAM_110	15:20	16:50	1:30	NFBC ISSUED
861	17-Jun-2022	BAGALKOT	110	110/33KV, HV3	BELAGUMWS STG 1,2 73_33RUS	10:20	17:51	7:31	LINE CLEAR AVAILED
862	17-Jun-2022	BAGALKOT	110	KD JAMBAGI-MUDHOL	KD JAMBAGI_110	10:58	16:27	5:29	LINE CLEAR AVAILED
863	17-Jun-2022	BAGALKOT	110	110/11KV,HV2	ZALKI_110	12:00	12:15	0:15	HAND TRIPPED
864	17-Jun-2022	BAGALKOT	110	YELLAMANAWADI-ALBAL	YELLAMANAWADI_110	11:03	11:24	0:21	LINE CLEAR AVAILED
865	17-Jun-2022	BAGALKOT	110	YELLAMANAWADI-ALBAL	YELLAMANAWADI_110	16:25	19:45	3:20	LINE CLEAR AVAILED
866	17-Jun-2022	BAGALKOT	110	110/11KV,HV1	UAS_110	21:45	22:12	0:27	TRANSFORMER FAULT
867	17-Jun-2022	BAGALKOT	110	110/11KV,HV2	TILUVALI_110	10:20	19:57	9:37	LINE CLEAR AVAILED
868	17-Jun-2022	BAGALKOT	110	SIRSI-KUMTA2	SIRSI_110	15:13	16:46	1:33	LINE CLEAR AVAILED
869	17-Jun-2022	BAGALKOT	110	RON-HIREHAL	RON_110	10:00	22:06	12:06	HAND TRIPPED
870	17-Jun-2022	BAGALKOT	110	110/11KV,HV2	RON_110	19:10	19:23	0:13	TRANSFORMER FAULT
871	17-Jun-2022	BAGALKOT	110	110/11KV,HV1	NAVALAGI_110	11:23	11:27	0:04	TRANSFORMER FAULT
872	17-Jun-2022	BAGALKOT	110	110/11KV,HV1	NAVALAGI_110	12:43	12:52	0:09	TRANSFORMER FAULT
873	17-Jun-2022	BAGALKOT	110	110/11KV,HV1	NAVALAGI_110	12:58	13:05	0:07	TRANSFORMER FAULT
874	17-Jun-2022	BAGALKOT	110	NAGANUR-MUGALKHOD	NAGANUR_110	11:06	11:35	0:29	LINE CLEAR AVAILED
875	17-Jun-2022	BAGALKOT	110	NAGANUR-MUDALAGI	NAGANUR_110	11:31	11:36	0:05	LINE CLEAR AVAILED
876	17-Jun-2022	BAGALKOT	110	110/11KV,HV2	MUNDARAGI_110	18:20	18:34	0:14	LINE CLEAR AVAILED
877	17-Jun-2022	BAGALKOT	110	110/33KV,HV3	MUNDARAGI_110	18:20	18:53	0:33	LINE CLEAR AVAILED
878	17-Jun-2022	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	16:41	17:19	0:38	LINE CLEAR AVAILED
879	17-Jun-2022	BAGALKOT	110	GHATAPRABHA-SHIRGOAN	SHIRGOAN_110	10:46	11:01	0:15	HAND TRIPPED
880	17-Jun-2022	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	12:17	13:49	1:32	LINE CLEAR AVAILED
881	17-Jun-2022	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	12:47	14:50	2:03	LINE CLEAR AVAILED
882	17-Jun-2022	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	19:05	19:12	0:07	TRANSFORMER FAULT
883	17-Jun-2022	BAGALKOT	110	MUGALKHOD- NAGANUR	STATION NOT AFFECTEDMUGAL	10:24	11:32	01:08	LINE CLEAR AVAILED
884	17-Jun-2022	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA	STATION NOT AFFECTEDGHATAP	15:21	17:33	02:12	LINE CLEAR AVAILED
885	17-Jun-2022	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTEDNAREND	11:25 (17.06.2022)			LINE OPEN, LINE CLEAR AVAILED
886	17-Jun-2022	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTEDNAREND	11:25 (17.06.2022)			LINE OPEN, LINE CLEAR AVAILED
887	17-Jun-2022	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTEDNAREND	12:37	13:34	00:57	LINE FAULT
888	17-Jun-2022	BAGALKOT	220	NARENDRA- BELGAUM1	STATION NOT AFFECTEDNAREND	16:38	20:12	03:34	MAIN SUPPLY FAILURE
889	17-Jun-2022	BAGALKOT	110	RANEBENNUR-HONNATTI	STATION NOT AFFECTEDRANEBE	19:12	19:25	00:13	LINE FAULT
890	17-Jun-2022	BAGALKOT	110	RANEBENNUR- BYADAGI(GUTTAL)	STATION NOT AFFECTEDRANEBE	19:12	19:33	00:21	LINE FAULT
891	17-Jun-2022	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTEDHUBLI_2	13:36	20:02	06:26	LINE FAULT
892	17-Jun-2022	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTEDHUBLI_2	11:28 (17.06.2022)			LINE OPEN, LINE CLEAR AVAILED
893	17-Jun-2022	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTEDHUBLI_2	11:29 (17.06.2022)			LINE OPEN, LINE CLEAR AVAILED
894	17-Jun-2022	BAGALKOT	220	220/110KV, HV1,LV1	STATION NOT AFFECTEDHUBLI_2	14:34	17:35	03:01	LINE CLEAR AVAILED
895	17-Jun-2022	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTEDSOUDAT	18:36 (17.06.2022)			LINE OPEN, LINE FAULT
896	17-Jun-2022	BAGALKOT	220	NARENDRA- BELGAUM2	BELGAUM_220	12:37	13:24	00:47	LINE FAULT
897	17-Jun-2022	BAGALKOT	220	NARENDRA- BELGAUM2	BELGAUM_220	13:28	19:23	05:55	LINE FAULT
898	17-Jun-2022	BAGALKOT	220	NARENDRA- BELGAUM1	BELGAUM_220	12:37	13:27	00:50	LINE FAULT
899	17-Jun-2022	BAGALKOT	110	AEQUS- BC(HATTARAGI)	STATION NOT AFFECTEDAEQUS_	17:38	17:42	0:04	HAND TRIPPED
900	17-Jun-2022	BAGALKOT	220	BAGEWADI- FORTUNE FIVE2	STATION NOT AFFECTEDBAGEWA	15:57	16:07	0:10	HAND TRIPPED
901	17-Jun-2022	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTEDBIDNAL	18:37 (17.06.2022)			LINE OPEN, LINE FAULT
902	17-Jun-2022	BAGALKOT	220	CHIKKODI- AEQUS2	CHIKKODI_220	13:29	14:05	00:36	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
903	17-Jun-2022	BAGALKOT	400	DHONI- GUTTUR	DHONI_400	16:51	19:04	02:13	LINE FAULT
904	17-Jun-2022	BAGALKOT	220	DHONI- LINGAPUR2 (HALVARTI)	DHONI_400	10:42	13:33	02:51	NFBC ISSUED
905	17-Jun-2022	BAGALKOT	220	220/110KV, HV2	MAHALINGAPUR_220	11:19	11:25	00:06	HAND TRIPPED
906	17-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
907	17-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
908	17-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
909	17-Jun-2022	BAGALKOT	110	LABAL-YELLAMMANAWADI	ALABAL_110	7:46	11:27	3:41	NFBC ISSUED
910	17-Jun-2022	BAGALKOT	110	BASAVANAKATTI-HAVERI220	STATION NOT AFFECTEDBASAVA	11:40	15:56	4:16	NFBC ISSUED
911	17-Jun-2022	BAGALKOT	110	110/11KV,HV1	ZALKI_110	18:52	18:55	0:03	TRANSFORMER FAULT
912	17-Jun-2022	BAGALKOT	110	SIRSI-KUMTA1	SIRSI_110	12:45	14:50	2:05	LINE CLEAR AVAILED
913	17-Jun-2022	BAGALKOT	110	110/11KV, HV1&HV2	KD JAMBAGI_110	11:15	16:45	05:30	LINE CLEAR AVAILED
914	17-Jun-2022	BAGALKOT	220	NARENDRA- BELGAUM2	STATION NOT AFFECTEDNAREND	12:37	13:24	00:47	LINE FAULT
915	17-Jun-2022	BAGALKOT	220	NARENDRA- BELGAUM2	STATION NOT AFFECTEDNAREND	13:27	20:11	06:44	LINE FAULT
916	17-Jun-2022	BAGALKOT	110	RANEBENNUR- HIREKERUR	STATION NOT AFFECTEDRANEBE	04:01	04:07	00:06	LINE FAULT
917	17-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDHUBLI_2	10:23	14:00	03:37	LINE CLEAR AVAILED
918	17-Jun-2022	BAGALKOT	110	BELGAUM220- NEHRU NAGAR	NEHRU NAGAR_110	12:37	12:46	00:09	MAIN SUPPLY FAILURE
919	17-Jun-2022	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	12:37	12:46	00:09	MAIN SUPPLY FAILURE
920	17-Jun-2022	BAGALKOT	110	BELGAUM220- MACHE	MACHE_110	12:37	12:46	00:09	MAIN SUPPLY FAILURE
921	17-Jun-2022	BAGALKOT	110	BELGAUM220- KANABARGI LAYOUT	KANABARGI LAYOUT_110	12:37	12:46	00:09	MAIN SUPPLY FAILURE
922	17-Jun-2022	BAGALKOT	220	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	10:36	10:39	00:03	HAND TRIPPED
923	17-Jun-2022	BAGALKOT	220	MAHALINGAPUR- ATHANI	MAHALINGAPUR_220	10:43	10:57	00:14	HAND TRIPPED
924	17-Jun-2022	BAGALKOT	220	MAHALINGAPUR- KUDACHI	MAHALINGAPUR_220	10:46	10:58	00:12	HAND TRIPPED
925	17-Jun-2022	BAGALKOT	220	MAHALINGAPUR- VAJRAMATTI1	MAHALINGAPUR_220	11:13	11:15	00:02	HAND TRIPPED
926	17-Jun-2022	BAGALKOT	110	MAHALINGAPUR- DAVLESHWAR	MAHALINGAPUR_220	11:18	11:28	00:10	HAND TRIPPED
927	17-Jun-2022	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVA	CHANDRA LAYOUT	5:48	5:52	0:04	LOAD CHANGE OVER
928	17-Jun-2022	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	22:03	22:07	0:04	LOAD CHANGE OVER
929	17-Jun-2022	BENGALURU	220	HV2	EPIP 220	4:01	4:47	0:46	TRANSFORMER FAULT
930	17-Jun-2022	BENGALURU	66	EPIP 220 - HOODY 2	NO STATION AFFECTED	4:01	10:00	5:59	LINE FAULT
931	17-Jun-2022	BENGALURU	66	EPIP 220 - HOODY 2	NO STATION AFFECTED	10:00	11:55	1:55	LINE CLEAR AVAILED
932	17-Jun-2022	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE OR	4:01	4:26	0:25	MAIN SUPPLY FAILURE
933	17-Jun-2022	BENGALURU	66	HV2	EPIP 220	4:01	4:18	0:17	MAIN SUPPLY FAILURE
934	17-Jun-2022	BENGALURU	66	HV1	RR NAGAR	7:38	7:53	0:15	TRANSFORMER FAULT
935	17-Jun-2022	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	18:45	19:10	0:25	MAIN SUPPLY FAILURE
936	17-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PRO	PRIMAL PROJECT	18:45	19:10	0:25	MAIN SUPPLY FAILURE
937	17-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TEC	GLOBAL TECH PARK	18:45	19:10	0:25	MAIN SUPPLY FAILURE
938	17-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	18:45	19:29	0:44	MAIN SUPPLY FAILURE
939	17-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - EXORA	EXORA	18:45	19:10	0:25	MAIN SUPPLY FAILURE
940	17-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY T	EMBASSY TECH VILLAGE	18:45	19:10	0:25	MAIN SUPPLY FAILURE
941	17-Jun-2022	BENGALURU	66	VIJAYANAGARA - VRISHABHAVATHI	VIJAYANAGARA	22:04	22:11	0:07	LOAD CHANGE OVER
942	17-Jun-2022	BENGALURU	66	HV2	CHANDRA LAYOUT	11:12	11:15	0:03	LINE CLEAR AVAILED
943	17-Jun-2022	BENGALURU	66	HV1	CHANDRA LAYOUT	13:07	13:14	0:07	LINE CLEAR AVAILED
944	17-Jun-2022	BENGALURU	66	HV1	DIBBURAHALLI	18:52	19:00	0:08	TRANSFORMER FAULT
945	17-Jun-2022	BENGALURU	66	KANASWADI - YELAHANKA 220	KANASWADI	15:10	18:50	3:40	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
946	17-Jun-2022	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	2:23	2:31	0:08	LINE FAULT
947	17-Jun-2022	BENGALURU	66	SOMENHALLI -PERESANDRA	PERESANDRA	2:23	2:32	0:09	LINE FAULT
948	17-Jun-2022	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA	CHIKKABALLAPURA I/A, CHIKKABALLAPURA	1:10	1:26	0:16	LINE FAULT
949	17-Jun-2022	BENGALURU	66	KIADB DB PURA 220 - APPEAREL PARK	APPEAREL PARK	6:39	7:04	0:24	LINE FAULT
950	17-Jun-2022	BENGALURU	66	DALASANUR - SRINIVASPURA	YELDUR	12:46	13:50	1:04	LINE CLEAR AVAILED
951	17-Jun-2022	BENGALURU	66	DALASANUR - SRINIVASPURA	YELDUR	13:50	16:09	2:19	LINE FAULT
952	17-Jun-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	3:00	3:29	0:28	LINE FAULT
953	17-Jun-2022	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	3:00	3:29	0:28	LINE FAULT
954	17-Jun-2022	BENGALURU	66	HV3	NELAMANGALA 66	14:07	14:33	0:25	TRANSFORMER FAULT
955	17-Jun-2022	BENGALURU	66	HV2	KANAKAPURA 66	11:28	11:32	0:03	LINE CLEAR AVAILED
956	17-Jun-2022	BENGALURU	66	HV1	KANAKAPURA 66	12:49	12:55	0:05	LINE CLEAR AVAILED
957	17-Jun-2022	BENGALURU	66	HV2	HUKUNDA	3:11	3:20	0:08	TRANSFORMER FAULT
958	17-Jun-2022	BENGALURU	66	DALSANUR - MALLASANDRA	DALSANUR, YELDUR	14:25	14:40	0:15	LINE CLEAR AVAILED
959	17-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	20:58	21:28	0:30	LINE FAULT
960	17-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	20:51	20:58	0:07	LINE CLEAR AVAILED
961	17-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	18:08	18:20	0:12	LINE CLEAR AVAILED
962	17-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:13	16:30	0:17	LINE FAULT
963	17-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:08	16:13	0:05	LINE CLEAR AVAILED
964	17-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	1:22	2:00	0:38	LINE FAULT
965	17-Jun-2022	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	1:10	1:26	0:16	MAIN SUPPLY FAILURE
966	17-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	1:10	1:26	0:16	MAIN SUPPLY FAILURE
967	17-Jun-2022	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	1:10	1:26	0:16	MAIN SUPPLY FAILURE
968	17-Jun-2022	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	1:10	1:26	0:16	MAIN SUPPLY FAILURE
969	17-Jun-2022	BENGALURU	220	LV1	DB PURA 220	1:10	1:26	0:16	TRANSFORMER FAULT
970	17-Jun-2022	BENGALURU	66	GANJIGUNTE - CHINTAMANI 1	GANJIGUNTE, PALLICHERLU	3:00	3:29	0:28	LINE FAULT
971	17-Jun-2022	BENGALURU	66	GANJIGUNTE - CHINTAMANI 2	GANJIGUNTE, PALLICHERLU	3:00	3:29	0:28	LINE FAULT
972	17-Jun-2022	BENGALURU	66	HV1	GANJIGUNTE	5:30	6:30	1:00	TRANSFORMER FAULT
973	17-Jun-2022	BENGALURU	66	SARIJAPURA 220 - CHANDAPURA	CHANDAPURA	18:45	19:25	0:40	MAIN SUPPLY FAILURE
974	17-Jun-2022	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:45	19:40	0:55	MAIN SUPPLY FAILURE
975	17-Jun-2022	BENGALURU	66	SARIJAPURA 220 - ATTIBELE	ATTIBELE	18:45	19:30	0:45	MAIN SUPPLY FAILURE
976	17-Jun-2022	BENGALURU	66	HV1	SARIJAPURA 220	18:45	19:37	0:52	MAIN SUPPLY FAILURE
977	17-Jun-2022	BENGALURU	66	HV2	SARIJAPURA 220	18:45	19:38	0:53	MAIN SUPPLY FAILURE
978	17-Jun-2022	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	23:37:36(16-6-2022)	0:25(17-6-2022)	0:46hrs	LINE CHARGED
979	17-Jun-2022	BENGALURU	220	MALUR 220 - SARIJAPURA 220	SARIJAPURA 220, VIKAS TECH PARK	18:45(17-6-2022)			LINE OPEN, LINE FAULT
980	17-Jun-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
981	17-Jun-2022	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	16:12(08.05.2022)	3:21 (17.06.2022)	957:09 HRS	LINE CHARGED
982	17-Jun-2022	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
983	17-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN, LINE FAULT
984	17-Jun-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	9:24	19:42	10:18	LINE CLEAR AVAILED
985	17-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
986	17-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN, LINE CLEAR AVAILED
987	17-Jun-2022	GULBARGA	110	HV1	YELBURGA_110	15:55(17.06.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
988	17-Jun-2022	GULBARGA	110	HV1	GANDHINAGAR_110	10:25	13:15	2:50	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
989	17-Jun-2022	GULBARGA	110	HV2	MUDAGAL_110	6:55	10:30	3:35	TRANSFORMER FAULT
990	17-Jun-2022	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGARS	2:51	2:56	0:05	LINE FAULT
991	17-Jun-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	3:32	3:35	0:03	LINE FAULT
992	17-Jun-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	4:18	4:32	0:14	LINE CLEAR AVAILED
993	17-Jun-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	0:47	0:50	0:03	LINE FAULT
994	17-Jun-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	23:18	23:25	0:07	LINE FAULT
995	17-Jun-2022	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110,CHOPWDAPUR_1	11:43	11:50	0:07	MAIN SUPPLY FAILURE
996	17-Jun-2022	GULBARGA	110	NANDUR-SHAHABAD	NANDUR_110	21:24	21:29	0:05	LINE FAULT
997	17-Jun-2022	GULBARGA	110	MYLAR-GUTTAL	MYLAR_110	19:12	19:22	0:10	MAIN SUPPLY FAILURE
998	17-Jun-2022	GULBARGA	110	MYLAR-GUTTAL	MYLAR_110	23:22	23:27	0:05	MAIN SUPPLY FAILURE
999	17-Jun-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	3:54	3:59	0:05	LINE FAULT
1000	17-Jun-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN	10:40(16/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1001	17-Jun-2022	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK	10:55(16/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1002	17-Jun-2022	GULBARGA	110	HALBARGA-HUMNABAD	HUMNABAD_110	23:30	23:36	0:06	LINE FAULT
1003	17-Jun-2022	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	23:29	23:32	0:03	LINE FAULT
1004	17-Jun-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	23:53	23:59	0:06	LINE FAULT
1005	17-Jun-2022	GULBARGA	110	KAPNOOR-HUMNABAD_2	ALAND_110,KADAGANCHI_110	23:48	23:55	0:07	LINE FAULT
1006	17-Jun-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD_2	MUKUNDA_110,YARADONA_110	7:05	10:27	3:22	LINE CLEAR AVAILED
1007	17-Jun-2022	GULBARGA	110	SINDHANOOR-SIRAGUPPA	TEKKALAKOTE_110,SIRIGUPPA	11:05	11:15	0:10	LINE FAULT
1008	17-Jun-2022	GULBARGA	110	ALIPUR-BELLARY SOUTH_2	BELLARY SOUTH_110,HALKUNDI	5:33	5:49	0:16	LINE FAULT
1009	17-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:42	11:50	0:08	LINE FAULT
1010	17-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:30	11:34	0:04	LINE FAULT
1011	17-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:37	11:39	0:02	LINE FAULT
1012	17-Jun-2022	GULBARGA	110	SHAHABAD-CHITAPUR	KORWAR TEMPLE_110	21:25	21:32	0:07	LINE FAULT
1013	17-Jun-2022	GULBARGA	66	HV2	TELAGI_66	13:30	13:40	0:10	TRANSFORMER FAULT
1014	17-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	13:06	13:28	0:22	LINE FAULT
1015	17-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	13:47	14:14	0:27	LINE FAULT
1016	17-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	14:26	14:37	0:11	LINE FAULT
1017	17-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	15:03	16:19	1:16	LINE FAULT
1018	17-Jun-2022	GULBARGA	66	MADIYAL-CHOWDAPUR	CHOPWDAPUR_110,AFZALPUR	11:31	11:42	0:11	LINE FAULT
1019	17-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	4:05	4:10	0:05	LINE FAULT
1020	17-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	6:41	6:45	0:04	LINE FAULT
1021	17-Jun-2022	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	13:10	13:20	0:10	LINE FAULT
1022	17-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1023	17-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1024	17-Jun-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1025	17-Jun-2022	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	13:02	15:12	2:10	LINE CLEAR AVAILED
1026	17-Jun-2022	HASSAN	110	KEMAR-Manipal1	KEMAR_220	10:25	12:54	2:29	LINE CLEAR AVAILED
1027	17-Jun-2022	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	17:40	18:00	0:20	LINE FAULT
1028	17-Jun-2022	HASSAN	110	BARANG-ANVATTI	BARANGI_110	18:47	19:09	0:22	HAND TRIPPED
1029	17-Jun-2022	HASSAN	110	BARANG-SHR220	BARANGI_110	9:40	10:10	0:30	HAND TRIPPED
1030	17-Jun-2022	HASSAN	110	GURUVA-SLPWR	GURUVAYANAKERE_110	10:50	11:35	0:45	LINE CLEAR AVAILED
1031	17-Jun-2022	HASSAN	110	HV1	KAVOOR_220	10:05	16:00	5:55	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1032	17-Jun-2022	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:25	12:54	2:29	NFBC ISSUED
1033	17-Jun-2022	HASSAN	110	HV1	SAGARA_110	8:55	9:15	0:20	LINE CLEAR AVAILED
1034	17-Jun-2022	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	10:45	12:26	1:41	NFBC ISSUED
1035	17-Jun-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	9:33	18:33	9:00	LINE CLEAR AVAILED
1036	17-Jun-2022	HASSAN	66	HV1	BALLUPETE_66	12:19	13:39	1:20	LINE CLEAR AVAILED
1037	17-Jun-2022	HASSAN	66	HV1	CHIKMAGALUR_66	12:03	14:26	2:23	MAIN SUPPLY FAILURE
1038	17-Jun-2022	HASSAN	66	HV2	CHIKMAGALUR_66	12:03	14:26	2:23	MAIN SUPPLY FAILURE
1039	17-Jun-2022	HASSAN	66	HADAVAN-HNPURA	HADAVANAHALLY_66	12:28	13:13	0:45	LINE CLEAR AVAILED
1040	17-Jun-2022	HASSAN	66	HV2	HALLYMYSORE_66	13:30	15:55	2:25	LINE CLEAR AVAILED
1041	17-Jun-2022	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMAGALUR_66	12:03	14:26	2:23	MAIN SUPPLY FAILURE
1042	17-Jun-2022	HASSAN	66	HIREMAN-CKM220	HIREMAGALUR_66	12:03	14:26	2:23	MAIN SUPPLY FAILURE
1043	17-Jun-2022	HASSAN	66	HV1	HIREMAGALUR_66	12:03	14:27	2:24	LINE CLEAR AVAILED
1044	17-Jun-2022	HASSAN	66	HIREMAN-RDL	HIREMAGALUR_66	12:03	14:27	2:24	LINE CLEAR AVAILED
1045	17-Jun-2022	HASSAN	66	HV1	KUDLIGERE_66	18:12	19:25	1:13	LINE CLEAR AVAILED
1046	17-Jun-2022	MYSURU	66	BG NAGARA-HIRISAVE	KADABALLY_66	11:42	14:59	3:17	LINE CLEAR AVAILED
1047	17-Jun-2022	MYSURU	66	HV1	CHUNCHUNKATTE_66	22:35	22:45	0:09	TRANSFORMER FAULT
1048	17-Jun-2022	MYSURU	66	COWDALLI-MARTHALLI	MARTAHALLI_66RAMAPURA_M	19:03	19:16	0:12	LINE FAULT
1049	17-Jun-2022	MYSURU	66	CR NAGARA-HONNAHALLI	ATTIGULIPURA_66 HONNALLY_M	1:47	1:56	0:08	LINE FAULT
1050	17-Jun-2022	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	15:28	15:36	0:07	LINE FAULT
1051	17-Jun-2022	MYSURU	66	DR PETE -CR NAGARA 2	NO STATIONS EFFECTED	10:34	11:03	0:29	LINE FAULT
1052	17-Jun-2022	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	15:51	16:36	0:44	HAND TRIPPED
1053	17-Jun-2022	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	15:51	16:36	0:44	HAND TRIPPED
1054	17-Jun-2022	MYSURU	220	KADAKOLA-BEGUR 1	NO STATIONS EFFECTED	10:32	17:42	7:09	LINE CLEAR AVAILED
1055	17-Jun-2022	MYSURU	66	KADAKOLA-MANTAKALLI	NO STATIONS EFFECTED	17:04	19:53	2:49	LINE CLEAR AVAILED
1056	17-Jun-2022	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	10:26	10:32	0:05	LINE FAULT
1057	17-Jun-2022	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	14:02	23:59	9:56	HAND TRIPPED
1058	17-Jun-2022	MYSURU	66	HV1	MADHUVANAHALLI_220	11:07	14:31	3:23	LINE CLEAR AVAILED
1059	17-Jun-2022	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	10:36	10:42	0:05	LINE FAULT
1060	17-Jun-2022	MYSURU	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	11:04	12:02	0:58	LINE CLEAR AVAILED
1061	17-Jun-2022	MYSURU	66	HV1	PONNAMPETE_66	13:29	13:36	0:07	TRANSFORMER FAULT
1062	17-Jun-2022	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	15:50	16:38	0:48	HAND TRIPPED
1063	17-Jun-2022	MYSURU	66	RK NAGARA-MANTAKALLI	NO STATIONS EFFECTED	16:38	17:03	0:25	HAND TRIPPED
1064	17-Jun-2022	MYSURU	220	TUBINKERE-HUYGONAHALLI	NO STATIONS EFFECTED	10:40	13:51	3:11	LINE CLEAR AVAILED
1065	17-Jun-2022	MYSURU	220	BEGUR 220-CR NAGARA 1	NO STATIONS EFFECTED	10:33	11:09	0:36	HAND TRIPPED
1066	17-Jun-2022	MYSURU	220	BEGUR 220-KADAKOLA 1	NO STATIONS EFFECTED	17:37	17:45	0:08	HAND TRIPPED
1067	17-Jun-2022	MYSURU	66	HV1	AJJIPURA_66	17:45	18:00	0:15	HAND TRIPPED
1068	17-Jun-2022	MYSURU	66	GAMANAHALLY-TUBINKERE	GAMANAHALLY_66	16:20	17:35	1:15	LINE CLEAR AVAILED
1069	17-Jun-2022	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	6:20	6:26	0:06	LINE FAULT
1070	17-Jun-2022	MYSURU	66	RK NAGARA-KADAKOLA	NO STATIONS EFFECTED	12:05:59 (04/06/2022)	50:06 (17/06/2022)	75:44hrs	LINE CHARGED
1071	17-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1072	17-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1073	17-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
1074	17-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	5:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1075	17-Jun-2022	TUMKUR	400	BUS COUPLER	GUTTUR_400	16:51	18:53	2:02	LINE FAULT
1076	17-Jun-2022	TUMKUR	400	ICT-2	GUTTUR_400	16:51	18:57	2:06	TRANSFORMER FAULT
1077	17-Jun-2022	TUMKUR	400	400KV DONI	GUTTUR_400	16:51	19:03	2:12	LINE FAULT
1078	17-Jun-2022	TUMKUR	400	400KV NARENDRA LINE-2	GUTTUR_400	16:51	19:36	2:45	LINE FAULT
1079	17-Jun-2022	TUMKUR	400	400KV KIGA LINE-2	GUTTUR_400	16:51	19:38	2:47	LINE FAULT
1080	17-Jun-2022	TUMKUR	400	ICT-1	JAGLUR_400	11:51	15:20	3:29	LINE CLEAR AVAILED
1081	17-Jun-2022	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:57	15:04	3:07	LINE FAULT
1082	17-Jun-2022	TUMKUR	220	GUTTUR 400- 220 RANIBENNURE	GUTTUR_400	16:19(17.6.22)			LINE OPEN, LINE CLEAR AVAILED
1083	17-Jun-2022	TUMKUR	220	PAVAGADA220-MADHUGIRI 1	PAVAGADA_220	1:35	8:00	6:25	LINE FAULT
1084	17-Jun-2022	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:57	15:01	3:04	LINE FAULT
1085	17-Jun-2022	TUMKUR	220	220_KB CROSS-ANTHRASANAHALI	KB CROSS_220	1:08	10:30	9:22	LINE FAULT
1086	17-Jun-2022	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	18:00(14.06.2022)			LINE OPEN, LINE FAULT
1087	17-Jun-2022	TUMKUR	220	TR3	KB CROSS_220	8:00	11:40	3:40	LINE CLEAR AVAILED
1088	17-Jun-2022	TUMKUR	110	TR-1	KEREKODI_110	10:03	14:47	4:44	LINE CLEAR AVAILED
1089	17-Jun-2022	TUMKUR	110	TR1 AND TR2	MAYASANDRA_110	13:08	14:25	1:17	MAIN SUPPLY FAILURE
1090	17-Jun-2022	TUMKUR	66	THALLAK 220kv- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	0:08	0:09	0:01	LINE FAULT
1091	17-Jun-2022	TUMKUR	66	THALLAK 220kv- CHALLAKERE1	CHALLAKERE_66, SANIKERE_66	5:34	5:42	0:08	LINE FAULT
1092	17-Jun-2022	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:37	9:46	0:09	LINE FAULT
1093	17-Jun-2022	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUN SOLAR2	9:37	9:46	0:09	LINE FAULT
1094	17-Jun-2022	TUMKUR	66	ANTHRASANAHALI 220KV- KORA	KORA_66, BRAHMASANDRA_66,	6:10	6:27	0:17	LINE FAULT
1095	17-Jun-2022	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENNAHALI_66,S	7:22	7:38	0:16	LINE FAULT
1096	17-Jun-2022	TUMKUR	66	ANCHEPALYA 220- BG NAGARA	ANCHEPALYA_220	9:16	9:33	0:17	LINE FAULT
1097	17-Jun-2022	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET	12:37	12:47	0:10	LINE FAULT
1098	17-Jun-2022	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:45	13:56	0:11	LINE FAULT
1099	17-Jun-2022	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66,HOLAVINAHAL	2:55	3:05	0:10	LINE FAULT
1100	17-Jun-2022	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66,HOLAVINAHAL	4:40	5:10	0:30	LINE FAULT
1101	17-Jun-2022	TUMKUR	66	TR-1	BRAHMASANDRA_66	12:38	13:27	0:49	LINE CLEAR AVAILED
1102	17-Jun-2022	TUMKUR	66	TR-2	BRAHMASANDRA_66	12:12	12:54	0:42	LINE CLEAR AVAILED
1103	17-Jun-2022	TUMKUR	66	BRAHMASANDRA- THOVINKERE(KO	THOVINAKERE_66, KORA_66	6:10	6:35	0:25	LINE FAULT
1104	17-Jun-2022	TUMKUR	66	BRAHMASANDRA- SIRA	BRAHMASANDRA_66	17:57	18:16	0:18	LINE FAULT
1105	17-Jun-2022	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	11:25	11:31	0:05	LINE FAULT
1106	17-Jun-2022	TUMKUR	66	TR-1	HIREHALI_66	8:03	8:40	0:36	HAND TRIPPED
1107	17-Jun-2022	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:38	11:42	0:03	LINE FAULT
1108	17-Jun-2022	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66,	6:31	6:33	0:02	MAIN SUPPLY FAILURE
1109	17-Jun-2022	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HON	KUKKAWADA_66	12:03	12:08	0:04	HAND TRIPPED
1110	17-Jun-2022	TUMKUR	66	TR-1	MYLANAHALLI_66	8:55	9:03	0:07	TRANSFORMER FAULT
1111	17-Jun-2022	TUMKUR	66	TR-2	NAYAKANHATTI_66	15:46	17:29	1:42	LINE CLEAR AVAILED
1112	18-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGAN	STATION NOT AFFECTEDPG HUN	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1113	18-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTEDLAXMES	17:55(28.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1114	18-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTEDDAMBEW	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1115	18-Jun-2022	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTEDHUBLI_2	11:37 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1116	18-Jun-2022	BAGALKOT	220	AMBEWADI- NARENDRA1	STATION NOT AFFECTEDDAMBEW	10:13 (15.06.2022)	1:35 (18.06.2022)	77:22HRS	LINE CHARGED
1117	18-Jun-2022	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTEDNAREND	10:05 (15.06.2022)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1118	18-Jun-2022	BAGALKOT	110	HALIYAL(ATHN)- F2(HALIYAL LIS)	STATION NOT AFFECTEDHALIYAL	13:55 (16.06.2022)			LINE OPEN, LINE FAULT
1119	18-Jun-2022	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTEDNAREND	11:25 (17.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1120	18-Jun-2022	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTEDNAREND	11:25 (17.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1121	18-Jun-2022	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTEDHUBLI_2	11:28 (17.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1122	18-Jun-2022	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTEDHUBLI_2	11:29 (17.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1123	18-Jun-2022	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTEDSOUDAT	18:36 (17.06.2022)			LINE OPEN, LINE FAULT
1124	18-Jun-2022	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTEDBIDNAL	18:37 (17.06.2022)			LINE OPEN, LINE FAULT
1125	18-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDTILUVAL	11:25	11:48	0:23	HAND TRIPPED
1126	18-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTEDSIRSI_11	17:58	18:01	0:03	LINE CLEAR AVAILED
1127	18-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTEDNAVALA	9:30	9:37	0:07	TRANSFORMER FAULT
1128	18-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTEDMALGHA	15:21	15:53	0:32	LINE CLEAR AVAILED
1129	18-Jun-2022	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTEDKUMTA_	10:02	10:58	0:56	LINE CLEAR AVAILED
1130	18-Jun-2022	BAGALKOT	110	ARGA-ANKOLA	STATION NOT AFFECTEDANKOLA	11:46	13:37	1:51	HAND TRIPPED
1131	18-Jun-2022	BAGALKOT	110	110/11KV,HV1	ARGA_110	11:23	14:00	2:37	LINE CLEAR AVAILED
1132	18-Jun-2022	BAGALKOT	110	110/11KV,HV1	GADDAG_110	10:10	18:23	8:13	LINE CLEAR AVAILED
1133	18-Jun-2022	BAGALKOT	110	110/11KV,HV2	GADDAG_110	10:10	18:23	8:13	LINE CLEAR AVAILED
1134	18-Jun-2022	BAGALKOT	110	110/33KV,HV(HV1)	GADDAG_110	10:10	18:23	8:13	LINE CLEAR AVAILED
1135	18-Jun-2022	BAGALKOT	110	110/33KV,HV4(HV2)	GADDAG_110	10:10	18:23	8:13	LINE CLEAR AVAILED
1136	18-Jun-2022	BAGALKOT	110	GADAG-ANNIGERI	GADDAG_110	9:32	19:50	10:18	LINE CLEAR AVAILED
1137	18-Jun-2022	BAGALKOT	110	110/33KV,HV3	RUSTUMPUR LIS_33,BGM W/S1	17:13	17:36	0:23	TRANSFORMER FAULT
1138	18-Jun-2022	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	23:08	23:12	0:04	TRANSFORMER FAULT
1139	18-Jun-2022	BAGALKOT	220	220/110KV, HV3,LV3	CHIKKODI_220	11:34	12:42	1:08	LINE CLEAR AVAILED
1140	18-Jun-2022	BAGALKOT	220	220/110KV, HV1,LV1	CHIKKODI_220	12:42	13:40	0:58	LINE CLEAR AVAILED
1141	18-Jun-2022	BAGALKOT	110	110/11KV, HV1	CHIKKODI_220	16:14	16:26	0:12	TRANSFORMER FAULT
1142	18-Jun-2022	BAGALKOT	220	220/110KV, HV2,LV2	CHIKKODI_220	17:55 (18.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1143	18-Jun-2022	BAGALKOT	110	GHATAPRABHA- GHATAPRABHA2	GHATAPRABHA_220	05:48	06:13	0:25	LINE FAULT
1144	18-Jun-2022	BAGALKOT	110	KARWAR220-KUMTA(KWR-ARGA)	KARWAR_220	11:54	13:15	1:21	LINE CLEAR AVAILED
1145	18-Jun-2022	BAGALKOT	220	BELGAUM- AEQUS2	STATION NOT AFFECTEDBELGAU	6:48	15:28	8:40	HAND TRIPPED
1146	18-Jun-2022	BAGALKOT	220	BELGAUM- AEQUS1	STATION NOT AFFECTEDBELGAU	15:30 (18.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1147	18-Jun-2022	BAGALKOT	110	GADAG220-GADAG	GADAG_110	11:02	18:09		LINE OPEN, LINE CLEAR AVAILED
1148	18-Jun-2022	BAGALKOT	220	HAVERI-NARENDRA	STATION NOT AFFECTEDHAVERI_	10:27	10:53		LINE OPEN, LINE CLEAR AVAILED
1149	18-Jun-2022	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTEDHAVERI_	10:28	10:53		LINE OPEN, LINE CLEAR AVAILED
1150	18-Jun-2022	BAGALKOT	220	HAVERI-HANAGAL	STATION NOT AFFECTEDHAVERI_	4:13	4:25		LINE OPEN, LINE FAULT
1151	18-Jun-2022	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTEDHUBLI_2	11:14	17:26		LINE OPEN, LINE CLEAR AVAILED
1152	18-Jun-2022	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTEDHUBLI_2	11:14	17:26		LINE OPEN, LINE CLEAR AVAILED
1153	18-Jun-2022	BAGALKOT	220	HUBLI-NAGJIHARI3	STATION NOT AFFECTEDHUBLI_2	11:21	19:29		LINE OPEN, LINE CLEAR AVAILED
1154	18-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1155	18-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1156	18-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1157	18-Jun-2022	BAGALKOT	220	220/110KV/HV2	STATION NOT AFFECTEDBELGAU	11:38	13:42	2:04HRS	TRANSFORMER CHARGED
1158	18-Jun-2022	BENGALURU	66	HV2	AMAR JYOTHI	9:12	9:24	0:12	LINE CLEAR AVAILED
1159	18-Jun-2022	BENGALURU	66	HV2	AMAR JYOTHI	10:45	10:56	0:11	LOAD CHANGE OVER
1160	18-Jun-2022	BENGALURU	66	HV1	AMAR JYOTHI	10:47	10:56	0:09	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1161	18-Jun-2022	BENGALURU	66	HV1	AMAR JYOTHI	13:28	13:32	0:04	LOAD CHANGE OVER
1162	18-Jun-2022	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	9:50	9:55	0:05	LOAD CHANGE OVER
1163	18-Jun-2022	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	18:18	18:22	0:04	LOAD CHANGE OVER
1164	18-Jun-2022	BENGALURU	66	HV2	CHANDRA LAYOUT	15:25	15:28	0:03	LINE CLEAR AVAILED
1165	18-Jun-2022	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVA	CHANDRA LAYOUT	16:59	17:02	0:03	LOAD CHANGE OVER
1166	18-Jun-2022	BENGALURU	220	EAST DIVISION COMPOUND 220 - HV1	EAST DIVISION COMPOUND 220	11:01	17:43	6:42	LINE CLEAR AVAILED
1167	18-Jun-2022	BENGALURU	220	HV1	EAST DIVISION COMPOUND 220	11:01	17:43	6:42	LINE CLEAR AVAILED
1168	18-Jun-2022	BENGALURU	220	HV2	EAST DIVISION COMPOUND 220	11:01	17:43	6:42	LINE CLEAR AVAILED
1169	18-Jun-2022	BENGALURU	66	HV1	EPIP 220	9:39	9:50	0:11	TRANSFORMER FAULT
1170	18-Jun-2022	BENGALURU	66	GOKULA - SRS PEENYA 220 1 & 2	GOKULA	15:13	15:30	0:17	MAIN SUPPLY FAILURE
1171	18-Jun-2022	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA	16:37	16:43	0:06	LOAD CHANGE OVER
1172	18-Jun-2022	BENGALURU	66	GOLF LINK - KORAMANGALA 220	GOLF LINK	10:45	10:51	0:06	LOAD CHANGE OVER
1173	18-Jun-2022	BENGALURU	220	HOODY 400 - SOMANAHALLI 220	NO STATION AFFECTED	1:08	3:37	2:29	LINE FAULT
1174	18-Jun-2022	BENGALURU	66	HOODY 220 - HAL 2	NO STATION AFFECTED	1:08	3:05	1:57	LINE FAULT
1175	18-Jun-2022	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANISATION	ARMY WELFARE ORGANISATION	7:05	7:18	0:13	LINE FAULT
1176	18-Jun-2022	BENGALURU	66	KORAMANGALA 220 -GOLF LINK HAL 2	NO STATION AFFECTED	17:06	21:45	4:39	LINE FAULT
1177	18-Jun-2022	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	15:13	15:25	0:12	MAIN SUPPLY FAILURE
1178	18-Jun-2022	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	16:44	16:49	0:05	LOAD CHANGE OVER
1179	18-Jun-2022	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	15:13	15:21	0:08	MAIN SUPPLY FAILURE
1180	18-Jun-2022	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	16:48	16:52	0:04	LOAD CHANGE OVER
1181	18-Jun-2022	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	15:13	15:34	0:21	MAIN SUPPLY FAILURE
1182	18-Jun-2022	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	16:26	16:31	0:05	LOAD CHANGE OVER
1183	18-Jun-2022	BENGALURU	66	NATIONAL COLLEGE - BMTC	NATIONAL COLLEGE	9:48	9:55	0:07	LOAD CHANGE OVER
1184	18-Jun-2022	BENGALURU	66	NATIONAL COLLEGE - PADMANABH	NATIONAL COLLEGE	18:42	18:50	0:08	LOAD CHANGE OVER
1185	18-Jun-2022	BENGALURU	66	HV1	PADMANABHANAGARA	12:19	12:20	0:01	LINE CLEAR AVAILED
1186	18-Jun-2022	BENGALURU	66	HV1	PADMANABHANAGARA	12:38	12:39	0:01	LOAD CHANGE OVER
1187	18-Jun-2022	BENGALURU	66	VIJAYANAGARA - NRS 220	VIJAYANAGARA	13:21	13:28	0:07	LOAD CHANGE OVER
1188	18-Jun-2022	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	15:13	15:17	0:04	MAIN SUPPLY FAILURE
1189	18-Jun-2022	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	17:28	17:31	0:03	LOAD CHANGE OVER
1190	18-Jun-2022	BENGALURU	220	HV2	SRS PEENYA 220	15:13	16:20	1:07	TRANSFORMER FAULT
1191	18-Jun-2022	BENGALURU	220	HV3	SRS PEENYA 220	15:13	16:41	1:28	TRANSFORMER FAULT
1192	18-Jun-2022	BENGALURU	220	HV4	SRS PEENYA 220	15:13	16:20	1:07	TRANSFORMER FAULT
1193	18-Jun-2022	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC	15:13	15:39	0:26	LINE FAULT
1194	18-Jun-2022	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	15:13	16:23	1:10	MAIN SUPPLY FAILURE
1195	18-Jun-2022	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	15:13	15:21	0:08	MAIN SUPPLY FAILURE
1196	18-Jun-2022	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	15:13	15:25	0:12	MAIN SUPPLY FAILURE
1197	18-Jun-2022	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, BEL (EHT), HMT (EHT)	15:13	15:30	0:17	MAIN SUPPLY FAILURE
1198	18-Jun-2022	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, BEL (EHT), HMT (EHT)	15:13	15:30	0:17	MAIN SUPPLY FAILURE
1199	18-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLAN	14:02	14:18	0:16	LINE FAULT
1200	18-Jun-2022	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	14:02	14:18	0:16	LINE FAULT
1201	18-Jun-2022	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	15:57	16:40	0:43	LINE FAULT
1202	18-Jun-2022	BENGALURU	220	HV2	TK HALLI 220	15:57	16:13	0:16	TRANSFORMER FAULT
1203	18-Jun-2022	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	15:57	16:46	0:49	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1204	18-Jun-2022	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	16:06	16:13	0:07	MAIN SUPPLY FAILURE
1205	18-Jun-2022	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHA	16:06	16:13	0:07	MAIN SUPPLY FAILURE
1206	18-Jun-2022	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MA	16:06	16:13	0:07	MAIN SUPPLY FAILURE
1207	18-Jun-2022	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MA	16:06	16:13	0:07	MAIN SUPPLY FAILURE
1208	18-Jun-2022	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, IND	16:06	16:13	0:07	MAIN SUPPLY FAILURE
1209	18-Jun-2022	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, D	16:06	16:13	0:07	MAIN SUPPLY FAILURE
1210	18-Jun-2022	BENGALURU	220	VIKAS TECH PARK 220 - DEVARABIS	VIKAS TECH PARK 220	5:31	5:42	0:11	LOAD CHANGE OVER
1211	18-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PRO	PRIMAL PROJECT	5:31	5:42	0:11	LOAD CHANGE OVER
1212	18-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TEC	GLOBAL TECH PARK	5:31	5:42	0:11	LOAD CHANGE OVER
1213	18-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	5:31	5:42	0:11	LOAD CHANGE OVER
1214	18-Jun-2022	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY T	EMBASSY TECH VILLAGE	5:31	5:42	0:11	LOAD CHANGE OVER
1215	18-Jun-2022	BENGALURU	66	HV1	SHOBHA CITY	12:55	12:56	0:01	LINE CLEAR AVAILED
1216	18-Jun-2022	BENGALURU	66	HV2	SHOBHA CITY	11:15	11:24	0:09	LINE CLEAR AVAILED
1217	18-Jun-2022	BENGALURU	66	HV1	SARIJAPURA 220	5:35	5:42	0:07	LOAD CHANGE OVER
1218	18-Jun-2022	BENGALURU	66	HV2	SARIJAPURA 220	5:35	5:42	0:07	LOAD CHANGE OVER
1219	18-Jun-2022	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	5:50	6:00	0:10	LOAD CHANGE OVER
1220	18-Jun-2022	BENGALURU	66	CHANDAPURA - YERANDANAHALLI	CHANDAPURA	6:40	6:50	0:10	LOAD CHANGE OVER
1221	18-Jun-2022	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	5:35	5:50	0:15	LOAD CHANGE OVER
1222	18-Jun-2022	BENGALURU	66	HV1	NELAMANGALA 66	4:39	5:34	0:55	TRANSFORMER FAULT
1223	18-Jun-2022	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	15:16	16:26	1:10	LINE FAULT
1224	18-Jun-2022	BENGALURU	66	TEKAL - TORALAKKI	TORALAKKI	17:10	18:00	0:50	LINE FAULT
1225	18-Jun-2022	BENGALURU	66	HV2	TEKAL	15:00	15:35	0:35	LINE CLEAR AVAILED
1226	18-Jun-2022	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU,	16:59	17:59	0:59	LINE CLEAR AVAILED
1227	18-Jun-2022	BENGALURU	220	MALUR 220 - HOODY 400	NO STATION AFFECTED	8:41	10:10	1:28	LINE CLEAR AVAILED
1228	18-Jun-2022	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:54	14:07	0:12	LINE FAULT
1229	18-Jun-2022	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)/V	GRINDWELL (EHT), HOSKOTE 66	14:58	15:02	0:03	LINE CLEAR AVAILED
1230	18-Jun-2022	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	5:46	5:53	0:06	LINE FAULT
1231	18-Jun-2022	BENGALURU	66	HV1	TUBUGERE	15:24	16:02	0:37	LINE CLEAR AVAILED
1232	18-Jun-2022	BENGALURU	66	HV1	TYAMAGONDLU	7:15	7:20	0:05	LINE CLEAR AVAILED
1233	18-Jun-2022	BENGALURU	66	HV1	KYALANUR	0:02	0:09	0:07	TRANSFORMER FAULT
1234	18-Jun-2022	BENGALURU	66	HV1	KYALANUR	9:30	9:50	0:19	TRANSFORMER FAULT
1235	18-Jun-2022	BENGALURU	66	HV1	HULLENAHALLI	5:10	5:25	0:15	TRANSFORMER FAULT
1236	18-Jun-2022	BENGALURU	66	ARMY WELFARE ORGANISATION - K	ARMY WELFARE ORGANISATION	8:05	8:12	0:07	LOAD CHANGE OVER
1237	18-Jun-2022	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR, BIEC	17:57	18:00	0:03	LOAD CHANGE OVER
1238	18-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	8:10	8:21	0:11	LINE CLEAR AVAILED
1239	18-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:10	11:15	0:05	LINE CLEAR AVAILED
1240	18-Jun-2022	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:16	11:21	0:05	LINE CLEAR AVAILED
1241	18-Jun-2022	BENGALURU	220	MALUR 220 - SARIJAPURA 220	SARIJAPURA 220, VIKAS TECH PA	18:45(17-6-2022)	5:26(18-6-2022)	10:40HRS	LINE CHARGED
1242	18-Jun-2022	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	15:13:00(18/06/2022)			LINE OPEN, LINE FAULT
1243	18-Jun-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1244	18-Jun-2022	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1245	18-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN, LINE FAULT
1246	18-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1247	18-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1248	18-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1249	18-Jun-2022	GULBARGA	110	HV1	YELBURGA_110	15:55(17.06.2022)	0:20(18.06.2022)	18:25HRS	TRANSFORMER CHARGED
1250	18-Jun-2022	GULBARGA	110	HV1	DEODURGA_110	9:35	14:40	5:05	LINE CLEAR AVAILED
1251	18-Jun-2022	GULBARGA	110	HV1	KUSTAGI_220	9:22	9:40	0:18	TRANSFORMER FAULT
1252	18-Jun-2022	GULBARGA	110	HV3	VALKAMDINNI_110	15:30	15:34	0:04	TRANSFORMER FAULT
1253	18-Jun-2022	GULBARGA	110	KEMBHAVI-ASKI	ASKI_110	6:50	7:00	0:10	LINE FAULT
1254	18-Jun-2022	GULBARGA	110	AURAD-SANTHAPUR	AURAD_110,DONGARAGOA_110	13:00	13:05	0:05	MAIN SUPPLY FAILURE
1255	18-Jun-2022	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	11:16	11:18	0:02	LINE FAULT
1256	18-Jun-2022	GULBARGA	110	NIRNA-RENEW SOLAR1	NIRNA_110	19:35(18.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1257	18-Jun-2022	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGAR FACT	22:48	22:57	0:09	LINE FAULT
1258	18-Jun-2022	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	13:07	15:27	2:20	LINE CLEAR AVAILED
1259	18-Jun-2022	GULBARGA	110	SINDHANOOR-SIRAGUPPA	TEKKALAKOTE_110, SIRIGUPPA	14:20	14:30	0:10	LINE FAULT
1260	18-Jun-2022	GULBARGA	110	NANDUR-GULBARGAUNIVERSITY	NANDUR_110	5:18	5:28	0:10	LINE FAULT
1261	18-Jun-2022	GULBARGA	110	MUDDAPUR-SINDHNOOR	MUDDAPUR_110	5:40	5:55	0:15	LINE FAULT
1262	18-Jun-2022	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110, AFZALPUR_11	10:40	10:45	0:05	MAIN SUPPLY FAILURE
1263	18-Jun-2022	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110, AFZALPUR_11	22:48	22:53	0:05	MAIN SUPPLY FAILURE
1264	18-Jun-2022	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110, ADVIAMRESH	1:40	2:00	0:20	MAIN SUPPLY FAILURE
1265	18-Jun-2022	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110, ADVIAMRESH	23:15	23:55	0:40	MAIN SUPPLY FAILURE
1266	18-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	10:45	10:48	0:03	LINE FAULT
1267	18-Jun-2022	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEM	5:19	5:26	0:07	LINE CLEAR AVAILED
1268	18-Jun-2022	GULBARGA	110	HALBARGA-KOLHAR1 & 2	KOLHAR_110,JANAWADA_110,N	12:59	13:08	0:09	LINE FAULT
1269	18-Jun-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN	10:40(16/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1270	18-Jun-2022	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK	10:55(16/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1271	18-Jun-2022	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110,MASKI_110,KAVITHA	5:20	5:24	0:04	LINE FAULT
1272	18-Jun-2022	GULBARGA	66	HV2	UJJAINI_66	18:32	18:47	0:15	TRANSFORMER FAULT
1273	18-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	18:53	19:00	0:07	LINE FAULT
1274	18-Jun-2022	GULBARGA	66	MAGALA-HIREHADAGALI	MAGALA_66	8:45	9:00	0:15	MAIN SUPPLY FAILURE
1275	18-Jun-2022	GULBARGA	66	MAGALA-HIREHADAGALI	KNNL_66	8:45	13:00	4:15	LINE FAULT
1276	18-Jun-2022	GULBARGA	66	BADELADAKU(KUDLIGI)-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOS	18:57	19:08	0:11	LINE FAULT
1277	18-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1278	18-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1279	18-Jun-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1280	18-Jun-2022	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1281	18-Jun-2022	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	10:07	13:32	3:25	LINE CLEAR AVAILED
1282	18-Jun-2022	HASSAN	220	HASSN22-CHIKMAGALUR	HASSAN_220	9:55	13:18	3:23	NFBC ISSUED
1283	18-Jun-2022	HASSAN	220	HV2	HOLENARASIPURA_220	10:20	12:45	2:25	LINE CLEAR AVAILED
1284	18-Jun-2022	HASSAN	220	HV1	KAVOOR_220	10:51	15:45	4:54	LINE CLEAR AVAILED
1285	18-Jun-2022	HASSAN	110	LV1	KAVOOR_220	10:51	15:45	4:54	LINE CLEAR AVAILED
1286	18-Jun-2022	HASSAN	220	MRSSHM-ARSK2 B4	MRSMSG_220	10:08	13:32	3:24	NFBC ISSUED
1287	18-Jun-2022	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	1:58	2:15	0:17	LINE FAULT
1288	18-Jun-2022	HASSAN	110	JOG110-AMBTR1	JOG_110	9:30	11:40	2:10	LINE CLEAR AVAILED
1289	18-Jun-2022	HASSAN	110	JOG110-AMBTR2	JOG_110	11:40	13:00	1:20	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1290	18-Jun-2022	HASSAN	110	KADUR-AJAMPURA	KADUR_220	11:04	11:40	0:36	HAND TRIPPED
1291	18-Jun-2022	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	1:58	2:15	0:17	LINE FAULT
1292	18-Jun-2022	HASSAN	110	HV1	KULASHEKARA_110	4:43	8:02	3:19	TRANSFORMER FAULT
1293	18-Jun-2022	HASSAN	110	HV2	NERALAKERE_110	10:40	13:32	2:52	LINE CLEAR AVAILED
1294	18-Jun-2022	HASSAN	66	HV1	BALLUPETE_66	12:06	13:36	1:30	LINE CLEAR AVAILED
1295	18-Jun-2022	HASSAN	66	HV	CHIKKABOMMENAHALLI_66	16:36	17:15	0:39	TRANSFORMER FAULT
1296	18-Jun-2022	HASSAN	66	HV2	HALLYMYSORE_66	13:20	13:30	0:10	LINE CLEAR AVAILED
1297	18-Jun-2022	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	20:50	22:00	1:10	LINE CLEAR AVAILED
1298	18-Jun-2022	HASSAN	66	Lv2	HOLENARASIPURA_220	10:20	12:46	2:26	LINE CLEAR AVAILED
1299	18-Jun-2022	HASSAN	66	HV1	HOLALUR_66	11:37	13:29	1:52	NFBC ISSUED
1300	18-Jun-2022	HASSAN	66	HV2	HOLALUR_66	11:37	13:29	1:52	NFBC ISSUED
1301	18-Jun-2022	HASSAN	66	HV1	MALLAPURA_66	11:36	13:57	2:21	MAIN SUPPLY FAILURE
1302	18-Jun-2022	HASSAN	66	HV2	MALLAPURA_66	11:36	13:57	2:21	MAIN SUPPLY FAILURE
1303	18-Jun-2022	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	11:36	13:57	2:21	MAIN SUPPLY FAILURE
1304	18-Jun-2022	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	14:10	14:21	0:11	LINE FAULT
1305	18-Jun-2022	HASSAN	66	HV1	MOSALEHOSAHALLI_66	19:56	20:03	0:07	HAND TRIPPED
1306	18-Jun-2022	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	11:10	12:08	0:58	LINE CLEAR AVAILED
1307	18-Jun-2022	HASSAN	66	HV1	SALAGAME_66	11:10	12:08	0:58	LINE CLEAR AVAILED
1308	18-Jun-2022	HASSAN	66	HV2	SALAGAME_66	11:10	12:08	0:58	LINE CLEAR AVAILED
1309	18-Jun-2022	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	11:10	12:08	0:58	LINE CLEAR AVAILED
1310	18-Jun-2022	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	11:31	13:27	1:56	LINE CLEAR AVAILED
1311	18-Jun-2022	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	11:18	12:07	0:49	NFBC ISSUED
1312	18-Jun-2022	HASSAN	66	HV1	YESLUR_66	14:11	14:23	0:12	MAIN SUPPLY FAILURE
1313	18-Jun-2022	MYSURU	66	BANNUR-VAJAMANGALA	NO STATIONS EFFECTED	17:08	18:40	1:31	HAND TRIPPED
1314	18-Jun-2022	MYSURU	66	CRNAGAR-HONNALLY	TTIGULIPURA_66 ARAKALAWAD	12:22	12:28	0:06	LINE FAULT
1315	18-Jun-2022	MYSURU	66	HDKOTE-TARAKA	NO STATIONS EFFECTED	16:00	16:12	0:12	LINE FAULT
1316	18-Jun-2022	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	6:30	6:35	0:04	LINE FAULT
1317	18-Jun-2022	MYSURU	220	KADAKOLA-BASTIPURA2	NO STATIONS EFFECTED	15:26	16:33	1:06	NFBC ISSUED
1318	18-Jun-2022	MYSURU	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	10:05	11:54	1:48	LINE CLEAR AVAILED
1319	18-Jun-2022	MYSURU	66	KADAKOLA-RKNAGAR	NO STATIONS EFFECTED	10:32	13:01	2:28	LINE CLEAR AVAILED
1320	18-Jun-2022	MYSURU	66	KADAKOLA-SARGUR2	DOORA_66 HURA_66 HULLALI	15:58	16:08	0:09	LINE FAULT
1321	18-Jun-2022	MYSURU	66	KADAKOLA-SRGUR1	JAYAPURA_66 HAMAMPURA_66	15:58	16:07	0:09	LINE FAULT
1322	18-Jun-2022	MYSURU	66	HOOTGALLY-KHB	NO STATIONS EFFECTED	9:39	11:05	1:26	LINE CLEAR AVAILED
1323	18-Jun-2022	MYSURU	66	HOOTGALLY-VIJAYNAGARA	VIJAYANAGARA_66	10:09	17:03	6:54	LINE CLEAR AVAILED
1324	18-Jun-2022	MYSURU	66	HOOTGALLY-BHOGADHI	BHOGADHI_66	11:14	17:01	5:47	LINE CLEAR AVAILED
1325	18-Jun-2022	MYSURU	66	KIADB MANDYA-HV1	KIADB MANDYA_66 MADDUR_66	15:58	16:13	0:15	HAND TRIPPED
1326	18-Jun-2022	MYSURU	66	KIRUGAVALU-MALIYUR	MALIYUR_66	11:59	12:06	0:06	LINE FAULT
1327	18-Jun-2022	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	10:15	13:08	2:53	LINE CLEAR AVAILED
1328	18-Jun-2022	MYSURU	220	VAJAMANGALA-TK HALLI	NO STATIONS EFFECTED	15:57	16:36	0:39	LINE FAULT
1329	18-Jun-2022	MYSURU	220	VAJAMANGALA-TK HALLI	NO STATIONS EFFECTED	16:40	22:05	5:25	LINE FAULT
1330	18-Jun-2022	MYSURU	220	VAJAMANGALA-HV1	BANNUR_66 MEGHALAPURA_66	16:40	18:22	1:42	HAND TRIPPED
1331	18-Jun-2022	MYSURU	66	HV1	VAJAMANGALA_66	16:40	18:30	1:50	HAND TRIPPED
1332	18-Jun-2022	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	15:57	16:33	0:36	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1333	18-Jun-2022	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	16:57	18:21	1:24	NFBC ISSUED
1334	18-Jun-2022	MYSURU	66	BEGUR 220-BEGUR 1	BEGUR_66	15:57	16:07	0:10	LINE FAULT
1335	18-Jun-2022	MYSURU	66	BEGUR 220-BEGUR 2	B MATTAKERE_66	15:57	16:07	0:10	LINE FAULT
1336	18-Jun-2022	MYSURU	66	BEGUR 220-HARVE	HARAVE_66	15:57	16:08	0:11	LINE FAULT
1337	18-Jun-2022	MYSURU	66	BEGUR 220-SANTHESARGUR	SATHESARGUR_66 YEREHALLI H	15:57	16:09	0:12	LINE FAULT
1338	18-Jun-2022	MYSURU	66	VYASARAJUPURA-THUMBLA	VYSARAJAPURA_66 GARGESHW	9:30	15:32	6:02	LINE CLEAR AVAILED
1339	18-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	18:10 (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1340	18-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1341	18-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	18:26 (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
1342	18-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1343	18-Jun-2022	TUMKUR	220	GUTTUR 400- 220 RANIBENNURE	GUTTUR_400	16:19(17.06.2022)	16:46 (18.06.2022)	16:27HRS	LINE CHARGED
1344	18-Jun-2022	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	15:00(14.06.2022)	13:42(18.6.22)	48:42HRS	LINE CHARGED
1345	18-Jun-2022	TUMKUR	400	GUTTUR 400KV- HAVERI 1	HAVERI_220	10:28	10:54	0:26	HAND TRIPPED
1346	18-Jun-2022	TUMKUR	400	TR-1	GUTTUR_400	13:29	14:36	1:07	LINE CLEAR AVAILED
1347	18-Jun-2022	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	11:15	13:45	2:29	LINE CLEAR AVAILED
1348	18-Jun-2022	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SR	HONNALLI_220	11:11	16:21	5:09	HAND TRIPPED
1349	18-Jun-2022	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	4:52	5:16	0:23	LINE FAULT
1350	18-Jun-2022	TUMKUR	220	TR-1	PAVAGADA_220	0:24	0:32	0:08	TRANSFORMER FAULT
1351	18-Jun-2022	TUMKUR	220	TR-2	PAVAGADA_220	0:24	0:37	0:12	TRANSFORMER FAULT
1352	18-Jun-2022	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 2	PAVAGADA_220	1:08	1:10	0:01	LINE FAULT
1353	18-Jun-2022	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110, TI	4:52	5:35	0:43	LINE FAULT
1354	18-Jun-2022	TUMKUR	110	KB CROSS 220kV-ANTHARASANAHA	KB CROSS_220	4:54	5:50	0:56	MAIN SUPPLY FAILURE
1355	18-Jun-2022	TUMKUR	110	KB CROSS 220kV-AMMASANDRA	AMMASANDRA_110, HEIDELBER	4:54	5:50	0:56	MAIN SUPPLY FAILURE
1356	18-Jun-2022	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI	4:54	5:50	0:56	MAIN SUPPLY FAILURE
1357	18-Jun-2022	TUMKUR	110	TR-1	KB CROSS_220	4:54	5:50	0:56	MAIN SUPPLY FAILURE
1358	18-Jun-2022	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKAN	CHIKKANAYAKANAHALLI_110, SI	4:54	5:20	0:26	LINE FAULT
1359	18-Jun-2022	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDUR	HULIYURDURGA_66, CHAWANA	3:58	4:10	0:12	LINE FAULT
1360	18-Jun-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, AN	6:40	7:10	0:29	LINE FAULT
1361	18-Jun-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, AN	7:24	16:30	9:06	LINE CLEAR AVAILED
1362	18-Jun-2022	TUMKUR	66	TR-2	BENKIKERE_66	15:09	15:11	0:02	TRANSFORMER FAULT
1363	18-Jun-2022	TUMKUR	66	TR-1	CHANNAGIRI_66	22:20	22:46	0:26	HAND TRIPPED
1364	18-Jun-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	15:55	16:41	0:45	TRANSFORMER FAULT
1365	18-Jun-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	16:41	17:06	0:25	TRANSFORMER FAULT
1366	18-Jun-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	17:06	19:02	1:56	LINE CLEAR AVAILED
1367	18-Jun-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	21:51	22:46	0:54	LINE CLEAR AVAILED
1368	18-Jun-2022	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	16:29	16:34	0:05	LINE FAULT
1369	18-Jun-2022	TUMKUR	66	TR-2	HOLALKERE_66	4:46	4:50	0:03	TRANSFORMER FAULT
1370	18-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:30	12:37	0:07	LINE FAULT
1371	18-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:37	13:40	1:03	NFBC ISSUED
1372	18-Jun-2022	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA	13:08	13:40	0:32	NFBC ISSUED
1373	18-Jun-2022	TUMKUR	66	HONNALLI - KUNDUR	HONNALLI_66	10:33	10:44	0:10	LINE FAULT
1374	18-Jun-2022	TUMKUR	66	HONNALLI - KUNDUR	HONNALLI_66	13:54	15:24	1:29	LINE FAULT
1375	18-Jun-2022	TUMKUR	66	HONNALLI - KUNDUR	HONNALLI_66	20:27	20:58	0:30	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1376	18-Jun-2022	TUMKUR	66	HONNALLI - KUNDUR	HONNALLI_66	21:21	21:40	0:19	LINE FAULT
1377	18-Jun-2022	TUMKUR	66	HONNALLI 220KV- LINGADAHALLI	DEVARAHALLI_66, LINGADAHALLI_66	10:41	10:50	0:09	LINE FAULT
1378	18-Jun-2022	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	11:09	11:12	0:02	HAND TRIPPED
1379	18-Jun-2022	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	14:36	14:39	0:02	LINE FAULT
1380	18-Jun-2022	TUMKUR	66	KUNDUR- HONNALLI	KUNDUR_66,MALEBENNUR_66	15:12	15:37	0:25	LINE FAULT
1381	18-Jun-2022	TUMKUR	66	KUNDUR- HONNALLI	KUNDUR_66,MALEBENNUR_66	20:50	21:24	0:33	LINE FAULT
1382	18-Jun-2022	TUMKUR	66	KUNDUR- HONNALLI	KUNDUR_66,MALEBENNUR_66	21:34	22:57	1:22	LINE FAULT
1383	18-Jun-2022	TUMKUR	66	TR-1	MAVINAKATTE_66	18:14	18:16	0:01	TRANSFORMER FAULT
1384	18-Jun-2022	TUMKUR	66	MADANAYAKANAHALLI-CHITRADUR	MADANAYAKANAHALLI_66,	10:41	11:40	0:58	LINE CLEAR AVAILED
1385	18-Jun-2022	TUMKUR	66	TR-1(LV-1)	PAVAGADA_220	0:24	0:34	0:09	TRANSFORMER FAULT
1386	18-Jun-2022	TUMKUR	66	TR-2(LV-2)	PAVAGADA_220	0:24	0:36	0:12	TRANSFORMER FAULT
1387	18-Jun-2022	TUMKUR	66	TR-2	THALLAK_220	16:34	17:24	0:50	LINE CLEAR AVAILED
1388	18-Jun-2022	TUMKUR	66	THALLAK 220KV- SEI DIAMOND SOL	MYLANAHALLI_66, DYAVARANA	4:22	4:34	0:11	LINE FAULT
1389	19-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGAN	STATION NOT AFFECTEDPG HUN	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1390	19-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTEDLAXMES	17:55(28.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1391	19-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTEDAMBEW	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1392	19-Jun-2022	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTEDHUBLI_2	11:37 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1393	19-Jun-2022	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTEDNAREND	10:05 (15.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1394	19-Jun-2022	BAGALKOT	110	HALIYAL(ATHN)- F2(HALIYAL LIS)	STATION NOT AFFECTEDHALIYAL	13:55 (16.06.2022)	8:30(19.06.2022)	76:35HRS	LINE CHARGED
1395	19-Jun-2022	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTEDNAREND	11:25 (17.06.2022)	7:45 (19.06.2022)	56:20HRS	LINE CHARGED
1396	19-Jun-2022	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTEDNAREND	11:25 (17.06.2022)	7:45 (19.06.2022)	56:20HRS	LINE CHARGED
1397	19-Jun-2022	BAGALKOT	220	HUBLI- NARENDRA1	STATION NOT AFFECTEDHUBLI_2	11:28 (17.06.2022)	7:45 (19.06.2022)	56:17HRS	LINE CHARGED
1398	19-Jun-2022	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTEDHUBLI_2	11:29 (17.06.2022)	7:45 (19.06.2022)	56:16HRS	LINE CHARGED
1399	19-Jun-2022	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTEDSOUDAT	18:36 (17.06.2022)	7:04 (19.06.2022)	41:28HRS	LINE CHARGED
1400	19-Jun-2022	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTEDBIDNAL	18:37 (17.06.2022)	7:04(19.06.2022)	41:27HRS	LINE CHARGED
1401	19-Jun-2022	BAGALKOT	220	220/110KV, HV2,LV2	CHIKKODI_220	17:55 (18.06.2022)	7:32 (19.06.2022)	21:37HRS	TRANSFORMER CHARGED
1402	19-Jun-2022	BAGALKOT	220	BELGAUM- AEQU51	STATION NOT AFFECTEDBELGAU	15:30 (18.06.2022)	7:27(19.06.2022)	25:57HRS	LINE CHARGED
1403	19-Jun-2022	BAGALKOT	110	110/11KV, HV1	YARAGATTI_110	10:15	18:18	8:03	LINE CLEAR AVAILED
1404	19-Jun-2022	BAGALKOT	110	110/11KV, HV2	YARAGATTI_110	10:15	18:17	8:02	LINE CLEAR AVAILED
1405	19-Jun-2022	BAGALKOT	110	YARAGATTI-SOUDATTI220	YARAGATTI_110	14:25	18:18	3:53	LINE CLEAR AVAILED
1406	19-Jun-2022	BAGALKOT	110	YARAGATTI-KATAKOL (BENAKATTI)	BENAKATTI_110	14:25	19:10	4:45	LINE CLEAR AVAILED
1407	19-Jun-2022	BAGALKOT	110	VADAGAON-BELAUM220	STATION NOT AFFECTEDVADAGA	5:58	8:58	3:00	NFBC ISSUED
1408	19-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDTILUVAL	16:31	17:01	0:30	LINE CLEAR AVAILED
1409	19-Jun-2022	BAGALKOT	110	110/11KV, HV1	SUVARNSOUDHA_110	9:25	16:22	6:57	LINE CLEAR AVAILED
1410	19-Jun-2022	BAGALKOT	110	110/11KV, HV2	SUVARNSOUDHA_110	9:25	16:23	6:58	LINE CLEAR AVAILED
1411	19-Jun-2022	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTEDSATTI_1	17:00	17:05	0:05	HAND TRIPPED
1412	19-Jun-2022	BAGALKOT	110	KANABARGI LAYOUT-BELGAUM220	KANABARGI LAYOUT_110	10:17	13:00	2:43	NFBC ISSUED
1413	19-Jun-2022	BAGALKOT	110	110/11KV, HV1 & HV2	KANABARGI LAYOUT_110	10:52	13:10	2:18	LINE CLEAR AVAILED
1414	19-Jun-2022	BAGALKOT	110	110/33KV, HV3 & HV4	BALEKUNDARGI_33, KAKTI_33SU	10:52	13:20	2:28	LINE CLEAR AVAILED
1415	19-Jun-2022	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTEDJAMAKH	20:12	20:24	0:12	TRANSFORMER FAULT
1416	19-Jun-2022	BAGALKOT	110	110/33KV,HV3	NANDI KURALI_33ANKALI_110	10:19	17:45	7:26	LINE CLEAR AVAILED
1417	19-Jun-2022	BAGALKOT	110	110/11KV,HV1	ANKALI_110	10:19	17:45	7:26	LINE CLEAR AVAILED
1418	19-Jun-2022	BAGALKOT	110	110/11KV,HV1	BISNAL_110	6:51	9:30	2:39	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1419	19-Jun-2022	BAGALKOT	110	110/11KV,HV2	BISNAL_110	6:51	9:30	2:39	LINE CLEAR AVAILED
1420	19-Jun-2022	BAGALKOT	110	THORVI-BHUTNAL	STATION NOT AFFECTEDTHORVI	5:57	8:02	2:05	LINE CLEAR AVAILED
1421	19-Jun-2022	BAGALKOT	110	110/11KV,HV1	BENAKATTI_110	10:30	18:14	7:44	LINE CLEAR AVAILED
1422	19-Jun-2022	BAGALKOT	110	110/11KV,HV2	BENAKATTI_110	10:30	18:14	7:44	LINE CLEAR AVAILED
1423	19-Jun-2022	BAGALKOT	110	SOUDATTI220-BENAKATTI	BENAKATTI_110	14:33	18:13	3:40	LINE CLEAR AVAILED
1424	19-Jun-2022	BAGALKOT	110	BENAKATTI-YERAGATTI	BENAKATTI_110	14:34	18:13	3:39	LINE CLEAR AVAILED
1425	19-Jun-2022	BAGALKOT	110	BYDAGI-SUZLON	BYADAGI_110	11:48	12:03	0:15	LINE CLEAR AVAILED
1426	19-Jun-2022	BAGALKOT	110	DAMBAL-MUNDARGI	DAMBAL_110	12:50	14:00	1:10	LINE CLEAR AVAILED
1427	19-Jun-2022	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	18:25	18:28	0:03	TRANSFORMER FAULT
1428	19-Jun-2022	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	18:50	18:52	0:02	TRANSFORMER FAULT
1429	19-Jun-2022	BAGALKOT	110	HUNGUND-B BAGEWADI(KUDAL SA	KUDAL SANGAM_110	10:39	15:58	5:19	LINE CLEAR AVAILED
1430	19-Jun-2022	BAGALKOT	110	ATHANI220- SATTI	STATION NOT AFFECTEDATHANI	9:20	16:16	6:56	NFBC ISSUED
1431	19-Jun-2022	BAGALKOT	110	MK HUBLI220-BIDI	STATION NOT AFFECTEDMK HUB	9:48	17:05	7:17	LINE CLEAR AVAILED
1432	19-Jun-2022	BAGALKOT	220	220/110KV, HV2,LV2	STATION NOT AFFECTEDSOUDAT	10:07	15:48	5:41	LINE CLEAR AVAILED
1433	19-Jun-2022	BAGALKOT	110	SOUDATTI220- YARAGATTI(BENAKA	STATION NOT AFFECTEDSOUDAT	14:21	18:11	3:50	LINE CLEAR AVAILED
1434	19-Jun-2022	BAGALKOT	220	220/110KV, HV1,LV1	STATION NOT AFFECTEDSOUDAT	17:37	18:30	0:53	LINE CLEAR AVAILED
1435	19-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTEDMUGALI	17:07	18:22	1:15	TRANSFORMER FAULT
1436	19-Jun-2022	BAGALKOT	220	KARWAR- KADRA2	STATION NOT AFFECTEDKARWAR	22:42 (19.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1437	19-Jun-2022	BAGALKOT	220	NARENDRA- BELGAUM2	STATION NOT AFFECTEDNAREND	15:10	15:36	0:26	LINE FAULT
1438	19-Jun-2022	BAGALKOT	110	VAJRAMATTI220- MELLIGERI	STATION NOT AFFECTEDVAJRAM	13:54	18:22	4:28	LINE CLEAR AVAILED
1439	19-Jun-2022	BAGALKOT	110	110/11KV, HV2	MANTUR(B)_110	20:10	20:15	0:05	TRANSFORMER FAULT
1440	19-Jun-2022	BAGALKOT	110	GHATAPRABHA-PG HUNSHYAL	PG HUNSHYAL_110	10:08	11:56		LINE OPEN, LINE CLEAR AVAILED
1441	19-Jun-2022	BAGALKOT	110	VAJRAMATTI220- MELLIGERI	STATION NOT AFFECTEDVAJRAM	12:12	12:30	0:18	HAND TRIPPED
1442	19-Jun-2022	BAGALKOT	110	CHIKKODI220- ANKALI	STATION NOT AFFECTEDCHIKKOD	11:15	17:27	6:12	LINE CLEAR AVAILED
1443	19-Jun-2022	BAGALKOT	220	CHIKKODI- BELGAUM(AEQU52)	STATION NOT AFFECTEDCHIKKOD	17:42 (19.06.2022)			LINE OPEN, LINE FAULT
1444	19-Jun-2022	BAGALKOT	220	CHIKKODI- GHATAPRABHA2(KUDAL	STATION NOT AFFECTEDCHIKKOD	18:08	18:17	0:09	LINE FAULT
1445	19-Jun-2022	BAGALKOT	220	CHIKKODI- MUGALKHOD2	STATION NOT AFFECTEDCHIKKOD	18:08	18:19	0:11	LINE FAULT
1446	19-Jun-2022	BAGALKOT	220	CHIKKODI- KOLAH PURA1(TALANDA	STATION NOT AFFECTEDCHIKKOD	18:08	18:19	0:11	LINE FAULT
1447	19-Jun-2022	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTEDBELGAU	13:48	15:05	1:17	LINE CLEAR AVAILED
1448	19-Jun-2022	BAGALKOT	220	BELGAUM- AEQU52	STATION NOT AFFECTEDBELGAU	17:41	18:04	0:23	LINE FAULT
1449	19-Jun-2022	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTEDBELGAU	15:10	15:36	0:26	LINE FAULT
1450	19-Jun-2022	BAGALKOT	110	BELGAUM-VADAGOAN	STATION NOT AFFECTEDBELGAU	06:18	08:57	2:39	LINE CLEAR AVAILED
1451	19-Jun-2022	BAGALKOT	110	BELGAUM-MACHE	STATION NOT AFFECTEDBELGAU	08:55	09:05	0:10	HAND TRIPPED
1452	19-Jun-2022	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTEDBELGAU	10:15	13:02	02:47	LINE CLEAR AVAILED
1453	19-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1454	19-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1455	19-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1456	19-Jun-2022	BAGALKOT	110	SATTI-RABAKAVI	SATTI_110	9:50	16:15	6:25	NFBC ISSUED
1457	19-Jun-2022	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	14:35	14:40	0:05	TRANSFORMER FAULT
1458	19-Jun-2022	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	3:47	3:56	0:09	MAIN SUPPLY FAILURE
1459	19-Jun-2022	BENGALURU	66	A STATION 220 - A STATION 2 66	A STATION 66	3:47	3:56	0:09	MAIN SUPPLY FAILURE
1460	19-Jun-2022	BENGALURU	66	A STATION 220 - KANTEERAVA	KANTEERAVA	3:47	3:56	0:09	MAIN SUPPLY FAILURE
1461	19-Jun-2022	BENGALURU	66	CHANDRA LAYOUT - NRS 220	CHANDRA LAYOUT	3:47	4:04	0:17	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1462	19-Jun-2022	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CIT	ELECTRONIC CITY, INFOSYS (EHT	8:24	8:30	0:06	LOAD CHANGE OVER
1463	19-Jun-2022	BENGALURU	66	ELECTRONIC CITY - YARANDANAHAN	ELECTRONIC CITY, INFOSYS (EHT	17:36	17:42	0:06	LOAD CHANGE OVER
1464	19-Jun-2022	BENGALURU	66	HV3	EPIP 220	10:33	13:13	2:40	LINE CLEAR AVAILED
1465	19-Jun-2022	BENGALURU	66	GOKULA - SRS PEENYA 220 1 & 2	GOKULA, BEL (EHT), HMT (EHT)	4:40	4:54	0:14	LOAD CHANGE OVER
1466	19-Jun-2022	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	6:11	6:14	0:03	LOAD CHANGE OVER
1467	19-Jun-2022	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	4:37	4:42	0:05	LOAD CHANGE OVER
1468	19-Jun-2022	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	6:15	6:19	0:04	LOAD CHANGE OVER
1469	19-Jun-2022	BENGALURU	220	NRS 220 - SRS PEENYA 220	NRS 220	3:47	4:01	0:14	MAIN SUPPLY FAILURE
1470	19-Jun-2022	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	3:47	4:01	0:14	MAIN SUPPLY FAILURE
1471	19-Jun-2022	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	3:47	4:01	0:14	MAIN SUPPLY FAILURE
1472	19-Jun-2022	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	4:38	4:42	0:04	LOAD CHANGE OVER
1473	19-Jun-2022	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	18:13	18:17	0:04	LOAD CHANGE OVER
1474	19-Jun-2022	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI (E	NO STATION AFFECTED	13:58	14:21	0:23	LINE FAULT
1475	19-Jun-2022	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI	NO STATION AFFECTED	13:58	16:10	2:12	LINE FAULT
1476	19-Jun-2022	BENGALURU	220	HV2	SRS PEENYA 220	3:47	5:05	1:18	TRANSFORMER FAULT
1477	19-Jun-2022	BENGALURU	220	HV3	SRS PEENYA 220	3:47	5:21	1:34	TRANSFORMER FAULT
1478	19-Jun-2022	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3	SRS PEENYA 220	3:47	4:54	1:07	LINE FAULT
1479	19-Jun-2022	BENGALURU	220	SRS PEENYA 220 - NRS 220	SRS PEENYA 220	3:47	4:01	0:14	LINE FAULT
1480	19-Jun-2022	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	3:27	3:58	0:31	MAIN SUPPLY FAILURE
1481	19-Jun-2022	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	4:16	4:18	0:02	MAIN SUPPLY FAILURE
1482	19-Jun-2022	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	3:27	3:39	0:12	MAIN SUPPLY FAILURE
1483	19-Jun-2022	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	4:40	4:44	0:04	LOAD CHANGE OVER
1484	19-Jun-2022	BENGALURU	66	HV1	VICTORIA	10:49	10:50	0:01	LINE CLEAR AVAILED
1485	19-Jun-2022	BENGALURU	66	HV2	VICTORIA	12:47	12:49	0:02	LINE CLEAR AVAILED
1486	19-Jun-2022	BENGALURU	66	HV1	GOKULA	10:06	10:10	0:04	TRANSFORMER FAULT
1487	19-Jun-2022	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	19:36	20:35	0:59	MAIN SUPPLY FAILURE
1488	19-Jun-2022	BENGALURU	66	VEMGAL - KOLAR 220	VEMGAL	22:28	23:34	1:06	MAIN SUPPLY FAILURE
1489	19-Jun-2022	BENGALURU	66	VEMGAL - KOLAR 220	VEMGAL	21:20	21:25	0:05	LINE FAULT
1490	19-Jun-2022	BENGALURU	66	VEMGAL - KOLAR 220	VEMGAL	21:17	21:20	0:03	LINE CLEAR AVAILED
1491	19-Jun-2022	BENGALURU	66	VEMGAL - KOLAR 220	VEMGAL	21:05	21:10	0:05	LINE FAULT
1492	19-Jun-2022	BENGALURU	66	VEMGAL - KOLAR 220	VEMGAL	21:00	21:05	0:05	LINE CLEAR AVAILED
1493	19-Jun-2022	BENGALURU	66	VEMGAL - KOLAR 220	VEMGAL, KYALANUR	19:55	20:10	0:15	LINE FAULT
1494	19-Jun-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNU	10:12	16:20	6:08	LINE CLEAR AVAILED
1495	19-Jun-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNU	19:36	19:50	0:14	LINE FAULT
1496	19-Jun-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL	22:28	22:47	0:19	LINE FAULT
1497	19-Jun-2022	BENGALURU	66	YELAHANKA 220 - LINE3	WHEELS & AXLE(EHT), ESCORTS	3:27	4:02	0:34	LINE FAULT
1498	19-Jun-2022	BENGALURU	66	YELAHANKA 220 - LINE4/DG4	SAHAKARINAGAR, ESCORTS(EHT	3:57	4:17	0:20	LINE FAULT
1499	19-Jun-2022	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	8:38	9:37	0:59	LINE CLEAR AVAILED
1500	19-Jun-2022	BENGALURU	66	ANEKAL - YARANDANAHALLI 220	ANEKAL	12:15	12:31	0:16	LINE CLEAR AVAILED
1501	19-Jun-2022	BENGALURU	66	HV2	TUBUGERE	13:25	13:34	0:08	LINE CLEAR AVAILED
1502	19-Jun-2022	BENGALURU	66	HV1	TUBUGERE	13:25	13:34	0:08	LINE CLEAR AVAILED
1503	19-Jun-2022	BENGALURU	66	HV2	SARIJAPURA 220	14:45	15:51	1:06	LINE CLEAR AVAILED
1504	19-Jun-2022	BENGALURU	66	HV2	SARIJAPURA 220	15:54	16:11	0:16	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1505	19-Jun-2022	BENGALURU	66	HV2	CB PURA I/A	8:45	9:15	0:30	TRANSFORMER FAULT
1506	19-Jun-2022	BENGALURU	66	HV2	CB PURA I/A	9:15	9:20	0:05	TRANSFORMER FAULT
1507	19-Jun-2022	BENGALURU	66	HV2	CHAKAVELU	8:55	9:16	0:20	LINE CLEAR AVAILED
1508	19-Jun-2022	BENGALURU	66	HV3	BANGARPET	21:45	22:00	0:15	LINE CLEAR AVAILED
1509	19-Jun-2022	BENGALURU	66	HV1	BANGARPET	22:00	22:10	0:10	LINE CLEAR AVAILED
1510	19-Jun-2022	BENGALURU	66	HV2	BANGARPET	22:10	22:20	0:10	LINE CLEAR AVAILED
1511	19-Jun-2022	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	4:40	4:43	0:03	LOAD CHANGE OVER
1512	19-Jun-2022	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, BIEC	11:45	12:00	0:15	LOAD CHANGE OVER
1513	19-Jun-2022	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR, BIEC	23:37	23:43	0:06	LOAD CHANGE OVER
1514	19-Jun-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA	22:47(19-6-2022)			LINE OPEN, LINE FAULT
1515	19-Jun-2022	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	15:13:00(18/06/2022)			LINE OPEN, LINE FAULT
1516	19-Jun-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1517	19-Jun-2022	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1518	19-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN, LINE FAULT
1519	19-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN, LINE FAULT
1520	19-Jun-2022	GULBARGA	220	RAICHUR-SHAHAPUR_2	GOOGLE_110	1:22	1:30	0:08	LINE FAULT
1521	19-Jun-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	7:46	17:45	9:59	LINE CLEAR AVAILED
1522	19-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1523	19-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1524	19-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1525	19-Jun-2022	GULBARGA	110	HV1	PD HALLI_110	15:17	19:20	4:03	LINE CLEAR AVAILED
1526	19-Jun-2022	GULBARGA	110	HV1	KUSTAGI_220	3:10	3:20	0:10	TRANSFORMER FAULT
1527	19-Jun-2022	GULBARGA	110	LV1	HALBARGA_220	15:43	16:43	1:00	LINE CLEAR AVAILED
1528	19-Jun-2022	GULBARGA	110	HV1	MARGUTTI_110	17:08	17:20	0:12	TRANSFORMER FAULT
1529	19-Jun-2022	GULBARGA	110	MADIYAL-CHOWDPUR	APUR_110,AFZALPUR_110,KAPR	11:40	11:45	0:05	LINE FAULT
1530	19-Jun-2022	GULBARGA	110	PD HALLI-ALLIPUR	PD HALLI_110,JANKI_IPP,BASIA	8:00	8:21	0:21	LINE CLEAR AVAILED
1531	19-Jun-2022	GULBARGA	110	PD HALLI-ALLIPUR	PD HALLI_110,JANKI_IPP,BASIA	9:35	15:17	5:42	LINE CLEAR AVAILED
1532	19-Jun-2022	GULBARGA	110	YELBURGA-TALKUTAI_IPP	YELBURGA_110	11:15	17:41	6:26	LINE CLEAR AVAILED
1533	19-Jun-2022	GULBARGA	110	NIRNA-RENEW SOLAR1	NIRNA_110	19:35(18.06.2022)	8:00(19.06.2022)	7:25HRS	LINE CHARGED
1534	19-Jun-2022	GULBARGA	110	KAPNOOR-HUMNABAD_2	ALAND_110,KADAGANCHI_110	3:25	3:33	0:08	LINE FAULT
1535	19-Jun-2022	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGAR FACT	11:48	11:55	0:07	LINE FAULT
1536	19-Jun-2022	GULBARGA	110	SINDHANOOR-MUNIRABAD_2	MUKUNDA_110,YARADONA_110	15:02	15:12	0:10	LINE FAULT
1537	19-Jun-2022	GULBARGA	110	KUSTAGI-VAJRABANDI	VAJRABANDI_110,YELBURGA_110	7:47	15:35	7:48	LINE CLEAR AVAILED
1538	19-Jun-2022	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY N	5:56	6:10	0:14	LINE FAULT
1539	19-Jun-2022	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORWAR TEMP	5:25	5:32	0:07	LINE FAULT
1540	19-Jun-2022	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110, AFZALPUR_110	10:38	10:42	0:04	MAIN SUPPLY FAILURE
1541	19-Jun-2022	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110, AFZALPUR_110	11:41	11:45	0:04	MAIN SUPPLY FAILURE
1542	19-Jun-2022	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110, AFZALPUR_110	11:48	11:53	0:05	MAIN SUPPLY FAILURE
1543	19-Jun-2022	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110, AFZALPUR_110	11:57	12:16	0:19	MAIN SUPPLY FAILURE
1544	19-Jun-2022	GULBARGA	110	MUDDAPUR-SINDHNOOR	MUDDAPUR_110	12:43	12:51	0:08	MAIN SUPPLY FAILURE
1545	19-Jun-2022	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	0:15	0:55	0:40	LINE FAULT
1546	19-Jun-2022	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	JAWALGERA_110	4:05	4:15	0:10	MAIN SUPPLY FAILURE
1547	19-Jun-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	22:09	22:19	0:10	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1548	19-Jun-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:30	20:40	0:10	LINE FAULT
1549	19-Jun-2022	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	4:05	4:15	0:10	LINE FAULT
1550	19-Jun-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	3:57	4:07	0:10	LINE FAULT
1551	19-Jun-2022	GULBARGA	110	HALBARGA-HALLIKHED	HALLIKHED_110	15:42	16:44	1:02	LINE CLEAR AVAILED
1552	19-Jun-2022	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN	10:40(16/06/2022)	5:46(19/06/2022)	78:06 HRS	LINE CHARGED
1553	19-Jun-2022	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK	10:55(16/06/2022)	5:45(19/06/2022)	77:50HRS	LINE CHARGED
1554	19-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	10:38	10:42	0:04	LINE FAULT
1555	19-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:42	11:44	0:02	LINE FAULT
1556	19-Jun-2022	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:58	12:00	0:02	LINE FAULT
1557	19-Jun-2022	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	3:46	7:19	3:33	LINE FAULT
1558	19-Jun-2022	GULBARGA	66	HV2	UJJAINI_66	17:55	17:57	0:02	TRANSFORMER FAULT
1559	19-Jun-2022	GULBARGA	66	HV2	UJJAINI_66	18:44	18:49	0:05	TRANSFORMER FAULT
1560	19-Jun-2022	GULBARGA	66	HV2	UJJAINI_66	20:44	20:46	0:02	TRANSFORMER FAULT
1561	19-Jun-2022	GULBARGA	66	HV2	UJJAINI_66	22:16	22:19	0:03	TRANSFORMER FAULT
1562	19-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	11:15	11:20	0:05	LINE FAULT
1563	19-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	13:33	13:39	0:06	LINE FAULT
1564	19-Jun-2022	GULBARGA	66	UJJAINI-BREIPL	UJJAINI_66	19:35	20:00	0:25	LINE FAULT
1565	19-Jun-2022	GULBARGA	66	NEELGUNDA-TELIGI	TELAGI_66,KURBHAHALLI_66,YE	11:35	11:43	0:08	LINE FAULT
1566	19-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1567	19-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1568	19-Jun-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1569	19-Jun-2022	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1570	19-Jun-2022	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	10:01	14:20	4:19	LINE CLEAR AVAILED
1571	19-Jun-2022	HASSAN	110	MRSSHM-BADRAVATY3	MRSMG_220	9:24	13:24	4:00	LINE CLEAR AVAILED
1572	19-Jun-2022	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	11:30	12:50	1:20	LINE CLEAR AVAILED
1573	19-Jun-2022	HASSAN	110	HV1	BAIKAMPADY_110	10:00	14:28	4:28	NFBC ISSUED
1574	19-Jun-2022	HASSAN	110	HV2	BAIKAMPADY_110	10:00	14:28	4:28	NFBC ISSUED
1575	19-Jun-2022	HASSAN	110	HV3	BAIKAMPADY_110	10:00	14:28	4:28	NFBC ISSUED
1576	19-Jun-2022	HASSAN	110	HV4	BAIKAMPADY_110	10:00	14:28	4:28	NFBC ISSUED
1577	19-Jun-2022	HASSAN	110	BAIKAM-KAVOOR	BAIKAMPADY_110	10:00	14:28	4:28	NFBC ISSUED
1578	19-Jun-2022	HASSAN	110	BAIKAM-KAVOOR2	BAIKAMPADY_110	10:00	14:28	4:28	NFBC ISSUED
1579	19-Jun-2022	HASSAN	110	BARANG-ANVATTI	BARANGI_110	19:24	19:47	0:23	HAND TRIPPED
1580	19-Jun-2022	HASSAN	110	HV3	BHADRAVATHI_110	9:25	17:00	7:35	LINE CLEAR AVAILED
1581	19-Jun-2022	HASSAN	110	HV1	ESSUR_110	15:10	15:57	0:47	LINE CLEAR AVAILED
1582	19-Jun-2022	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	10:58	11:11	0:13	HAND TRIPPED
1583	19-Jun-2022	HASSAN	110	HV1	NITTUR_110	3:55	5:41	1:46	TRANSFORMER FAULT
1584	19-Jun-2022	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:03	19:44	9:41	LINE CLEAR AVAILED
1585	19-Jun-2022	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	11:00	11:07	0:07	LINE FAULT
1586	19-Jun-2022	HASSAN	66	HV1	HOLALUR_66	10:17	19:13	8:56	LINE CLEAR AVAILED
1587	19-Jun-2022	HASSAN	66	HV2	HOLALUR_66	10:18	19:05	8:47	LINE CLEAR AVAILED
1588	19-Jun-2022	HASSAN	66	HV1	MATTANAVILE_66	10:25	11:35	1:10	LINE CLEAR AVAILED
1589	19-Jun-2022	MYSURU	66	HV1	BILIKERE_66	10:53	11:07	0:14	TRANSFORMER FAULT
1590	19-Jun-2022	MYSURU	66	C R NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	9:21	16:49	7:28	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1591	19-Jun-2022	MYSURU	66	C R NAGARA-GUNDLUPETE	TERAKANAMBI_66	9:37	14:55	5:18	LINE CLEAR AVAILED
1592	19-Jun-2022	MYSURU	66	C R NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	16:40	16:51	0:11	LINE FAULT
1593	19-Jun-2022	MYSURU	66	KUSHALANAGARA-PERIAPATNA 2	BYLUKUPPE_66	14:48	21:56	7:07	LINE FAULT
1594	19-Jun-2022	MYSURU	66	KUSHALANAGARA-PERIPATNA-1	PERIYAPATNA_66	17:49	21:56	4:07	LINE CLEAR AVAILED
1595	19-Jun-2022	MYSURU	66	KUSHALANAGARA-MADIKERI 1	NO STATIONS EFFECTED	18:31	21:48	3:17	LINE CLEAR AVAILED
1596	19-Jun-2022	MYSURU	66	SUNTIKOPPA-MADIKERI	MADIKERI_66	18:39	18:49	0:10	HAND TRIPPED
1597	19-Jun-2022	MYSURU	66	THALAKADU-CHANDALLY	THALAKADU_66 PARINAMIPURA	9:36	16:48	7:12	LINE CLEAR AVAILED
1598	19-Jun-2022	MYSURU	66	ALUR SIDDAPURA-CB HALLI	ALUR SIDDAPUR_66	11:43	12:15	0:32	HAND TRIPPED
1599	19-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1600	19-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1601	19-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
1602	19-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	5:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1603	19-Jun-2022	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	3:11	10:00	6:48	LOAD CURTAILMENT
1604	19-Jun-2022	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	0:05	7:12	7:07	LOAD CURTAILMENT
1605	19-Jun-2022	TUMKUR	220	PAVAGADA 220kv- MADHUGIRI 1	PAVAGADA_220	1:57	10:30	8:32	LOAD CURTAILMENT
1606	19-Jun-2022	TUMKUR	220	TR-1	HONNALLI_220	12:32	14:35	2:02	LINE CLEAR AVAILED
1607	19-Jun-2022	TUMKUR	110	TR-2	KADEHALLI_110	19:44	20:01	0:16	TRANSFORMER FAULT
1608	19-Jun-2022	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66	16:00	16:10	0:10	LINE FAULT
1609	19-Jun-2022	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	8:28	8:32	0:04	LINE FAULT
1610	19-Jun-2022	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	14:47	14:51	0:04	LINE FAULT
1611	19-Jun-2022	TUMKUR	66	HIREHALLI - BADDIHALLI(MELEKOTE)	MELEKOTE_66, BADDIHALLI_66	5:53	6:57	1:03	LINE FAULT
1612	19-Jun-2022	TUMKUR	66	HIREHALLI - BADDIHALLI(MELEKOTE)	MELEKOTE_66, BADDIHALLI_66	7:51	9:48	1:56	LINE CLEAR AVAILED
1613	19-Jun-2022	TUMKUR	66	HONNALLI - KUNDUR	HONNALLI_66	3:22	3:38	0:15	LINE FAULT
1614	19-Jun-2022	TUMKUR	66	HONNALLI - KUNDUR	HONNALLI_66	3:38	7:45	4:07	LINE FAULT
1615	19-Jun-2022	TUMKUR	66	TR-1(LV-1)	HONNALLI_66	12:29	14:38	2:09	HAND TRIPPED
1616	19-Jun-2022	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	11:54	11:59	0:05	LINE FAULT
1617	19-Jun-2022	TUMKUR	66	TR-1	KORA_66	16:18	17:27	1:08	LINE CLEAR AVAILED
1618	19-Jun-2022	TUMKUR	66	TR-2	KORA_66	10:20	10:44	0:23	TRANSFORMER FAULT
1619	19-Jun-2022	TUMKUR	66	TR-2	KUKKAWADA_66	7:16	7:25	0:08	TRANSFORMER FAULT
1620	19-Jun-2022	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	ENERCON1_IPP_66	20:06	20:13	0:07	LINE FAULT
1621	19-Jun-2022	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	10:42	10:52	0:10	LINE FAULT
1622	19-Jun-2022	TUMKUR	66	TR-2	PAVAGADA_66	15:44	16:19	0:34	LINE CLEAR AVAILED
1623	19-Jun-2022	TUMKUR	66	PKOTE-HARIYABBE	PKOTE_66	18:36	18:39	0:03	MAIN SUPPLY FAILURE
1624	19-Jun-2022	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	18:41	19:23	0:41	MAIN SUPPLY FAILURE
1625	19-Jun-2022	TUMKUR	66	PKOTE-AZURE SOLAR	AZURE SOLAR_66	18:41	19:18	0:36	MAIN SUPPLY FAILURE
1626	19-Jun-2022	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	18:41	19:20	0:38	MAIN SUPPLY FAILURE
1627	20-Jun-2022	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGARA)	STATION NOT AFFECTEDPG HUN	16:13(04.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1628	20-Jun-2022	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTEDLAXMES	17:55(28.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1629	20-Jun-2022	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTEDAMBEW	8:55(23.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1630	20-Jun-2022	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTEDHUBLI_2	11:37 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1631	20-Jun-2022	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTEDNAREND	10:05 (15.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1632	20-Jun-2022	BAGALKOT	220	KARWAR- KADRA2	STATION NOT AFFECTEDKARWAR	22:42 (19.06.2022)	2:14(20.06.2022)	13:32HRS	LINE CHARGED
1633	20-Jun-2022	BAGALKOT	220	CHIKKODI- BELGAUM(AEQU2)	STATION NOT AFFECTEDCHIKKOD	17:42 (19.06.2022)	1:50(20.06.2022)	10:08HRS	LINE CHARGED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1634	20-Jun-2022	BAGALKOT	110	110/11KV,HV2	BABLESHWAR_110	10:37	18:50	8:13	LINE CLEAR AVAILED
1635	20-Jun-2022	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	STATION NOT AFFECTEDKIADB B	6:07	15:42	9:35	LINE CLEAR AVAILED
1636	20-Jun-2022	BAGALKOT	110	BJCTY(THORVI)-BHUTNAL	STATION NOT AFFECTEDTHORVI	10:12	10:13	0:01	HAND TRIPPED
1637	20-Jun-2022	BAGALKOT	110	110/11KV,HV1	DEVARAGENNUR_110	17:45	17:58	0:13	TRANSFORMER FAULT
1638	20-Jun-2022	BAGALKOT	110	110/33KV,HV4(HV2)	GOPANAKOPPA_110	11:53	12:02	0:09	TRANSFORMER FAULT
1639	20-Jun-2022	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	7:15	7:20	0:05	TRANSFORMER FAULT
1640	20-Jun-2022	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	8:40	9:11	0:31	LINE CLEAR AVAILED
1641	20-Jun-2022	BAGALKOT	110	GADAG-LAXMESHVAR	LAXMESHVAR_110	11:22	17:40	6:18	LINE CLEAR AVAILED
1642	20-Jun-2022	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	STATION NOT AFFECTEDMAHALI	7:15	12:03	4:48	LINE CLEAR AVAILED
1643	20-Jun-2022	BAGALKOT	110	MAMADAPUR-BABLESHWAR	BABLESHWAR_110	6:41	7:37	0:56	LINE CLEAR AVAILED
1644	20-Jun-2022	BAGALKOT	110	MAMADAPUR-BABLESHWAR	BABLESHWAR_110	15:58	18:23	2:25	LINE CLEAR AVAILED
1645	20-Jun-2022	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	14:40	21:10	6:30	LINE CLEAR AVAILED
1646	20-Jun-2022	BAGALKOT	110	UMMACHAGI-KIRUVATTI	KIRUVATTI_110	8:59	16:45	7:46	NFBC ISSUED
1647	20-Jun-2022	BAGALKOT	110	RANNABELAGALI-MAHALINGAPUR	RANNABELAGALI_110	6:57	12:04	5:07	LINE CLEAR AVAILED
1648	20-Jun-2022	BAGALKOT	110	RANNABELAGALI-MUDHOL	RANNABELAGALI_110	6:58	12:07	5:09	LINE CLEAR AVAILED
1649	20-Jun-2022	BAGALKOT	110	110/11KV, HV1	RANNABELAGALI_110	6:59	12:04	5:05	HAND TRIPPED
1650	20-Jun-2022	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	6:59	12:04	5:05	HAND TRIPPED
1651	20-Jun-2022	BAGALKOT	220	CHIKKODI- BELGAUM(AEQU52)	STATION NOT AFFECTEDCHIKKODI	08:50	10:55	2:05	LINE CLEAR AVAILED
1652	20-Jun-2022	BAGALKOT	220	HUBLI-SRSI-1	STATION NOT AFFECTEDHUBLI_2	11:02	14:44	3:42	LINE CLEAR AVAILED
1653	20-Jun-2022	BAGALKOT	220	HUBLI-SRSI-2	STATION NOT AFFECTEDHUBLI_2	15:18	17:58	2:40	LINE CLEAR AVAILED
1654	20-Jun-2022	BAGALKOT	220	HUBLI-NAGIJHARI-1	STATION NOT AFFECTEDHUBLI_2	12:29	15:06	2:37	LINE CLEAR AVAILED
1655	20-Jun-2022	BAGALKOT	220	HUBLI-NAGIJHARI-3	STATION NOT AFFECTEDHUBLI_2	16:26	18:14	1:48	HAND TRIPPED
1656	20-Jun-2022	BAGALKOT	110	110/33KV, HV3	CHINCHANUR_33, KATAKOL_33S	17:35	18:16	0:41	LINE CLEAR AVAILED
1657	20-Jun-2022	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1658	20-Jun-2022	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTEDSIRSI_22	15:26 (13.05.2022)			LINE OPEN, LINE CLEAR AVAILED
1659	20-Jun-2022	BAGALKOT	110	110/33KV, HV3	YELPARAHATTI_110	18:20 (21.04.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1660	20-Jun-2022	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTEDMUGALI	17:30	19:08	1:38	LINE CLEAR AVAILED
1661	20-Jun-2022	BENGALURU	66	CESSNA -SHOBHA APARTMENT	CESSNA, EXORA	8:20	8:30	0:10	LOAD CHANGE OVER
1662	20-Jun-2022	BENGALURU	66	HV1	HOODY 220	23:39	23:53	0:14	MAIN SUPPLY FAILURE
1663	20-Jun-2022	BENGALURU	66	HV2	VRISHABHAVATHI 220	10:46	10:51	0:05	TRANSFORMER FAULT
1664	20-Jun-2022	BENGALURU	66	KYALANUR - TALAGWARA	KYALANUR	11:55	11:58	0:03	LOAD CHANGE OVER
1665	20-Jun-2022	BENGALURU	66	VEMGAL - KYALANUR	VEMGAL	1:18	1:21	0:03	LOAD CHANGE OVER
1666	20-Jun-2022	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	7:01	7:11	0:09	LINE FAULT
1667	20-Jun-2022	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:34	6:44	0:10	LINE FAULT
1668	20-Jun-2022	BENGALURU	66	VIDYANAGAR - HOSKOTE 220	NO STATION AFFECTED	12:51	14:10	1:19	LINE FAULT
1669	20-Jun-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL	10:22	11:29	1:06	LINE CLEAR AVAILED
1670	20-Jun-2022	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	14:49	14:56	0:06	LINE CLEAR AVAILED
1671	20-Jun-2022	BENGALURU	66	MELUR - DB PURA 220	SIDLAGHATTA, MELUR	18:49	18:53	0:04	LOAD CHANGE OVER
1672	20-Jun-2022	BENGALURU	66	HV2	VIDHURASHWATHA	9:02	9:10	0:07	TRANSFORMER FAULT
1673	20-Jun-2022	BENGALURU	66	HV1	KOLAR 220	11:24	11:28	0:03	LINE CLEAR AVAILED
1674	20-Jun-2022	BENGALURU	66	HV2	HUKUNDA	3:10	3:15	0:05	TRANSFORMER FAULT
1675	20-Jun-2022	BENGALURU	66	HV2	HUKUNDA	9:35	10:00	0:24	TRANSFORMER FAULT
1676	20-Jun-2022	BENGALURU	66	HV1	H GOLLAHALLI	9:45	17:25	7:40	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1677	20-Jun-2022	BENGALURU	220	HV2	GOWRIBIDANUR 220	11:30	12:23	0:53	LINE CLEAR AVAILED
1678	20-Jun-2022	BENGALURU	220	HV1	GOWRIBIDANUR 220	12:30	12:58	0:28	LINE CLEAR AVAILED
1679	20-Jun-2022	BENGALURU	66	HV1	GOWRIBIDANUR 220	12:36	12:55	0:19	TRANSFORMER FAULT
1680	20-Jun-2022	BENGALURU	66	HV1	GANJIGUNTE	11:50	11:55	0:05	LINE CLEAR AVAILED
1681	20-Jun-2022	BENGALURU	66	HV2	GANJIGUNTE	13:03	13:07	0:03	LINE CLEAR AVAILED
1682	20-Jun-2022	BENGALURU	66	HV3	BANGARPET	10:25	10:55	0:30	LINE CLEAR AVAILED
1683	20-Jun-2022	BENGALURU	66	HV2	BANGARPET	11:05	11:45	0:40	LINE CLEAR AVAILED
1684	20-Jun-2022	BENGALURU	66	HV1	BANGARPET	12:03	12:48	0:45	LINE CLEAR AVAILED
1685	20-Jun-2022	BENGALURU	66	HV2	BANGARPET	16:55	17:25	0:30	LINE CLEAR AVAILED
1686	20-Jun-2022	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO	6:59	7:13	0:14	LINE FAULT
1687	20-Jun-2022	BENGALURU	66	IRGAMPALLI - CHINTAMANI 220	IRGAMPALLI, M GOLLAHALLI, BU	18:25	18:30	0:05	LINE CLEAR AVAILED
1688	20-Jun-2022	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA	22:47(19-6-2022)	0:14(20-6-2022)	1:26HRS	LINE CHARGED
1689	20-Jun-2022	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGH	HIMAT SINGHA FACTORY (EHT)	10:43(20-6-2022)			LINE OPEN, LINE FAULT
1690	20-Jun-2022	BENGALURU	220	LV2	HOODY 220	23:39(20/06/2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1691	20-Jun-2022	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	23:39(20/06/2022)			MAIN SUPPLY FAILURE
1692	20-Jun-2022	BENGALURU	66	HOODY 220 - HP(EHT)	HP(EHT)	23:39(20/06/2022)			MAIN SUPPLY FAILURE
1693	20-Jun-2022	BENGALURU	66	HOODY 220 - PRESTIGE SHANTHINI	PRESTIGE SHANTHINIKETHAN	23:39(20/06/2022)			MAIN SUPPLY FAILURE
1694	20-Jun-2022	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	15:13:00(18/06/2022)			LINE OPEN, LINE FAULT
1695	20-Jun-2022	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	10:04 (14.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1696	20-Jun-2022	GULBARGA	220	HV2	BADELADUKU_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1697	20-Jun-2022	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	13:50 (10.06.2022)			LINE OPEN, LINE FAULT
1698	20-Jun-2022	GULBARGA	220	HV1	HUMNABAD_220	15:40	17:48	2:08	LINE CLEAR AVAILED
1699	20-Jun-2022	GULBARGA	220	HV2 & LV2	HUMNABAD_220	18:17	20:55	2:38	LINE CLEAR AVAILED
1700	20-Jun-2022	GULBARGA	220	HV1	SINDHANOOR_220	15:00	17:05	2:05	LINE CLEAR AVAILED
1701	20-Jun-2022	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	7:24	15:40	8:16	LINE CLEAR AVAILED
1702	20-Jun-2022	GULBARGA	220	RAICHUR-SHAHAPUR_2	GOOGLE_110	1:46	1:50	0:04	LINE FAULT
1703	20-Jun-2022	GULBARGA	220	RAICHUR-SHAHAPUR_2	GOOGLE_110	2:59	3:15	0:16	LINE FAULT
1704	20-Jun-2022	GULBARGA	220	BTPS-ALIPUR	ALIPUR_220	3:45	4:40	0:55	LINE FAULT
1705	20-Jun-2022	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110	10:55 (11.04.2022)			LINE OPEN, LINE CLEAR AVAILED
1706	20-Jun-2022	GULBARGA	110	HUMNABAD-MARGUTTI	MARGUTTI_110,MAHAGOAN_110	16:53(20/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1707	20-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR1	JEWARGI_110	12:15(15/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1708	20-Jun-2022	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	15:10(14/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1709	20-Jun-2022	GULBARGA	110	HV1,HV2	BAYYAPUR_110	10:00	17:20	7:20	LINE CLEAR AVAILED
1710	20-Jun-2022	GULBARGA	110	HV1	YERADONA_110	20:05	20:15	0:10	TRANSFORMER FAULT
1711	20-Jun-2022	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDTINI_110	18:11	18:19	0:08	LINE FAULT
1712	20-Jun-2022	GULBARGA	220	SHAHABAD-GULBARGA UNIVERSITY	GULBARGA UNIVERSITY 1_110	13:20	16:35	3:15	LINE CLEAR AVAILED
1713	20-Jun-2022	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:46	1:56	0:10	LINE FAULT
1714	20-Jun-2022	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	1:46	1:56	0:10	LINE FAULT
1715	20-Jun-2022	GULBARGA	66	HV2	HALVAGALU_66	8:55	9:00	0:05	TRANSFORMER FAULT
1716	20-Jun-2022	GULBARGA	66	HV2	HARAPANAHALLI_66	22:15	22:20	0:05	TRANSFORMER FAULT
1717	20-Jun-2022	GULBARGA	66	MUNIRABAD-MUNIRABAD	MUNIRABAD_66,VENKATAPURA	16:25	16:37	0:12	LINE FAULT
1718	20-Jun-2022	GULBARGA	66	HANSI-KUDALAGI_66	HANSI_66	14:50	15:10	0:20	MAIN SUPPLY FAILURE
1719	20-Jun-2022	GULBARGA	66	HANSI-KUDALAGI_66	HANSI_66	15:35	15:45	0:10	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1720	20-Jun-2022	GULBARGA	66	HANSI-KUDALAGI_66	HANSI_66	16:30	16:50	0:20	LINE CLEAR AVAILED
1721	20-Jun-2022	GULBARGA	66	HOSAHALLI-CJ HALLI	HOSAHALLI_66	19:10	19:25	0:15	MAIN SUPPLY FAILURE
1722	20-Jun-2022	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66,MORGERE_66	10:10	15:40	5:30	LINE CLEAR AVAILED
1723	20-Jun-2022	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN, LINE CLEAR AVAILED
1724	20-Jun-2022	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1725	20-Jun-2022	HASSAN	66	HV2	HASSAN_66	10:05 (6.06.2022)			TRANSFORMER OPEN, LINE CLEAR AVAILED
1726	20-Jun-2022	HASSAN	110	HV2	KARAYA_110	13:12(18.06.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1727	20-Jun-2022	HASSAN	400	UPCL-HASSAN2	gen_upcl	0:02	6:14	6:12	HAND TRIPPED
1728	20-Jun-2022	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:15	11:25	0:10	HAND TRIPPED
1729	20-Jun-2022	HASSAN	110	HV2	ANAVATTI_110	17:37	17:45	0:08	TRANSFORMER FAULT
1730	20-Jun-2022	HASSAN	110	BARANG-ANVATTI	BARANGi_110	11:18	11:20	0:02	HAND TRIPPED
1731	20-Jun-2022	HASSAN	110	KADUR-YGTI	KADUR_220	5:35	6:23	0:48	LINE FAULT
1732	20-Jun-2022	HASSAN	110	HV2	NERALAKERE_110	21:45	22:00	0:15	TRANSFORMER FAULT
1733	20-Jun-2022	HASSAN	110	HV1	SHIVAPURA_110	15:35	15:53	0:18	TRANSFORMER FAULT
1734	20-Jun-2022	HASSAN	66	HNPR2-RNPR2	HNPURA_220	19:14	19:22	0:08	LINE FAULT
1735	20-Jun-2022	HASSAN	66	HV1	SAKALESH PURA_66	8:30	10:10	1:40	LINE CLEAR AVAILED
1736	20-Jun-2022	HASSAN	66	HV2	SAKALESH PURA_66	8:30	10:10	1:40	LINE CLEAR AVAILED
1737	20-Jun-2022	MYSURU	66	CR NAGAR-KOLLEGALA	NO STATIONS EFFECTED	10:14	10:24	0:09	LINE FAULT
1738	20-Jun-2022	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	18:55	19:01	0:05	LINE FAULT
1739	20-Jun-2022	MYSURU	66	KOLLEGALA-THALAKADU	NO STATIONS EFFECTED	20:39	20:45	0:05	LINE FAULT
1740	20-Jun-2022	MYSURU	66	HV3	KUSHALANAGAR_66	15:06	15:40	0:34	LINE CLEAR AVAILED
1741	20-Jun-2022	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	6:08	6:14	0:05	LINE FAULT
1742	20-Jun-2022	MYSURU	66	HV1	YARAHALLI HANDPOST_66	16:45	16:55	0:10	TRANSFORMER FAULT
1743	20-Jun-2022	MYSURU	66	HV1	CHINAKURALI_66	12:25	14:15	1:50	LINE CLEAR AVAILED
1744	20-Jun-2022	MYSURU	66	HV2	CHINAKURALI_66	14:13	15:10	0:57	LINE CLEAR AVAILED
1745	20-Jun-2022	MYSURU	66	HV2	HARADANAHALLY_66	7:40	8:20	0:40	TRANSFORMER FAULT
1746	20-Jun-2022	MYSURU	66	HV1	HOSURGATE_66	11:00	11:20	0:20	LINE CLEAR AVAILED
1747	20-Jun-2022	MYSURU	66	DEVANUR NANJANGUDU-BAS1	NO STATIONS EFFECTED	6:10:00 PM (03/06/2022)			LINE OPEN, LINE CLEAR AVAILED
1748	20-Jun-2022	MYSURU	66	HV2	MADHUVANAHALLI_220	18:57:18 (31.5.2022)			TRANSFORMER OPEN, TRANSFORMER FAULT
1749	20-Jun-2022	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	6:26:00 PM (22/04/2022)			LINE OPEN, LINE CLEAR AVAILED
1750	20-Jun-2022	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	5:16:00 (08/12/2021)			LINE OPEN, LINE CLEAR AVAILED
1751	20-Jun-2022	MYSURU	66	MUGUR-THAYURU	NO STATIONS EFFECTED	9:40:00 (20.06.2022)			LINE OPEN, LINE CLEAR AVAILED
1752	20-Jun-2022	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	0:15:21 (20.06.2022)			LINE OPEN, LINE FAULT
1753	20-Jun-2022	TUMKUR	220	JAGALUR 400KV-KODLIGI	JAGALUR 400KV	1:51	7:32	5:41	LINE FAULT
1754	20-Jun-2022	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, AN	8:15	17:36	9:20	LINE CLEAR AVAILED
1755	20-Jun-2022	TUMKUR	66	TR-1	BHARAMAGIRI_66	18:50	18:54	0:03	TRANSFORMER FAULT
1756	20-Jun-2022	TUMKUR	66	TR-2	BRAHMASANDRA_66	12:23	13:25	1:01	LINE CLEAR AVAILED
1757	20-Jun-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	9:50	10:00	0:09	HAND TRIPPED
1758	20-Jun-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	10:57	11:05	0:07	HAND TRIPPED
1759	20-Jun-2022	TUMKUR	66	TR-2	CHANNAGIRI_66	16:36	17:48	1:11	HAND TRIPPED
1760	20-Jun-2022	TUMKUR	66	TR-2	CHIKKABANAGERE_66	13:20	14:21	1:00	LINE CLEAR AVAILED
1761	20-Jun-2022	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLU	DEVARAHALLI_66	12:45	15:51	3:06	LINE CLEAR AVAILED
1762	20-Jun-2022	TUMKUR	66	TR-2	HARAPPANAHALLI	22:13	22:20	0:07	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1763	20-Jun-2022	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	10:30	10:33	0:03	LINE FAULT
1764	20-Jun-2022	TUMKUR	66	TR-1	HAGALWADI_66	10:16	17:41	7:24	LINE CLEAR AVAILED
1765	20-Jun-2022	TUMKUR	66	HAGALWADI-ANTHARASANAHALI	HAGALWADI_66	10:16	17:41	7:24	LINE CLEAR AVAILED
1766	20-Jun-2022	TUMKUR	66	TR-2	HONNALLI_66	0:54	2:57	2:03	TRANSFORMER FAULT
1767	20-Jun-2022	TUMKUR	66	TR-2	HONNALLI_66	3:00	14:02	11:01	LINE CLEAR AVAILED
1768	20-Jun-2022	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	12:43	12:47	0:03	HAND TRIPPED
1769	20-Jun-2022	TUMKUR	66	MADHUGIRI 220kv- NITRAHALI	NITRAHALI_66	15:16	15:18	0:02	HAND TRIPPED
1770	20-Jun-2022	TUMKUR	66	PDKOTE-HARIYABBE	PDKOTE_66	19:02	19:41	0:38	MAIN SUPPLY FAILURE
1771	20-Jun-2022	TUMKUR	66	PDKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	19:03	19:47	0:43	MAIN SUPPLY FAILURE
1772	20-Jun-2022	TUMKUR	66	PDKOTE-AZURE SOLAR	AZURE SOLAR_66	19:03	19:48	0:44	MAIN SUPPLY FAILURE
1773	20-Jun-2022	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	19:03	19:45	0:41	MAIN SUPPLY FAILURE
1774	20-Jun-2022	TUMKUR	66	TR-1	PURUVARA_66	14:27	15:28	1:01	LINE CLEAR AVAILED
1775	20-Jun-2022	TUMKUR	66	TR-1	SANTEMAVATTUR_66	7:00	7:07	0:06	TRANSFORMER FAULT

