

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 12.03.2019 to 18.03.2019

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	12-Mar-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	0:00	16:28	16:28	LINE CLEAR AVAILED
2	12-Mar-19	BAGALKOT	220	AMBEWADI-NARENDRA 1	AMBEWADI_220	11:49	12:31	0:42	HAND TRIPPED
3	12-Mar-19	BAGALKOT	220	AMBEWADI-NAGJARI 1	AMBEWADI_220	11:50	12:31	0:41	HAND TRIPPED
4	12-Mar-19	BAGALKOT	110	110/33KV,HV3	BAGALKOT_220,KATAGERI_33	10:55	13:38	2:43	LINE CLEAR AVAILED
5	12-Mar-19	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	17:06	17:49	0:43	LINE CLEAR AVAILED
6	12-Mar-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	7:48	8:02	0:14	LINE CLEAR AVAILED
7	12-Mar-19	BAGALKOT	110	CHIKKODI220-NIPPANI	NIPPANI_110	19:01	19:26	0:25	LINE FAULT
8	12-Mar-19	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPANAKOPPA_110	8:39	23:59	15:20	LINE CLEAR AVAILED
9	12-Mar-19	BAGALKOT	110	GOPANAKOPPA-MRUTYUNJAY NAGAR 2	GOPANAKOPPA_110	7:48	8:39	0:51	LINE CLEAR AVAILED
10	12-Mar-19	BAGALKOT	110	110/33KV,HV2	HANGAL_110	6:07	6:33	0:26	TRANSFORMER FAULT
11	12-Mar-19	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	12:19	16:23	4:04	LINE FAULT
12	12-Mar-19	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	22:06	22:21	0:15	LINE FAULT
13	12-Mar-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	16:50	23:59	7:09	LINE FAULT
14	12-Mar-19	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	8:52	9:15	0:23	MAIN SUPPLY FAILURE
15	12-Mar-19	BAGALKOT	110	110/33KV,HV3	ZALKI_110,HORTI_33KV	14:40	15:47	1:07	LINE CLEAR AVAILED
16	12-Mar-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_33KV	15:52	16:46	0:54	LINE CLEAR AVAILED
17	12-Mar-19	BAGALKOT	110	110/11KV,HV1	ZALKI_110	16:42	20:37	3:55	LINE CLEAR AVAILED
18	12-Mar-19	BAGALKOT	110	VAJRAMATTI220-MELLIGERI	MELLIGERI_110	0:12	0:22	0:10	HAND TRIPPED
19	12-Mar-19	BAGALKOT	110	VAJRAMATTI220-MANTUR1	MANTUR_110	16:14	16:24	0:10	HAND TRIPPED
20	12-Mar-19	BAGALKOT	110	TARIHAL-TADASINAKOPPA	TADASINAKOPPA_110	12:44	12:48	0:04	HAND TRIPPED
21	12-Mar-19	BAGALKOT	110	TARIHAL-TADASINAKOPPA	TADASINAKOPPA_110	14:36	14:37	0:01	HAND TRIPPED
22	12-Mar-19	BAGALKOT	110	SOUDATTI110-ENERCON 1&2	SOUDATTI_110	14:23	18:55	4:32	LINE CLEAR AVAILED
23	12-Mar-19	BAGALKOT	220	HUBLI220-NARENDRA2	HUBLI_220	10:27	17:43	7:16	LINE CLEAR AVAILED
24	12-Mar-19	BAGALKOT	110	RON -HIREHAL	HIREHALLI_110	12:23	16:49	4:26	LINE CLEAR AVAILED
25	12-Mar-19	BAGALKOT	110	110/11KV,HV1	RATTIHAL_110	0:00	16:14	16:14	LINE CLEAR AVAILED
26	12-Mar-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	0:00	7:39	7:39	NFBC ISSUED
27	12-Mar-19	BAGALKOT	110	BIDNAL220-KONNUR	KONNUR_110	7:57	9:16	1:19	LINE CLEAR AVAILED
28	12-Mar-19	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	10:28	14:08	3:40	LINE CLEAR AVAILED
29	12-Mar-19	BAGALKOT	220	220/110KV,HV1,LV1,	NARENDRA_220	12:57	14:09	1:12	LINE CLEAR AVAILED
30	12-Mar-19	BAGALKOT	110	NARENDRA220-KUD DHARWAD	KUD DHARWAD_110	12:53	14:10	1:17	LINE CLEAR AVAILED
31	12-Mar-19	BAGALKOT	110	MAREGUDDI-MUNDUGANUR	MUNADUGANUR_110	16:55	18:07	1:12	LINE CLEAR AVAILED
32	12-Mar-19	BAGALKOT	110	MAMADAPUR(B)-SHIRBUR	SHIRBUR_110	2:22	2:35	0:13	LINE FAULT
33	12-Mar-19	BAGALKOT	110	MAMADAPUR(B)-SHIRBUR	SHIRBUR_110	2:35	2:42	0:07	LINE FAULT
34	12-Mar-19	BAGALKOT	110	MAMADAPUR(B)-SHIRBUR	SHIRBUR_110	2:42	9:01	6:19	LINE FAULT
35	12-Mar-19	BAGALKOT	110	110/33KV,HV2	KUDUCHI_110,YELPARATTI_33KV,CHINCHALI_33KV	13:00	14:20	1:20	LINE CLEAR AVAILED
36	12-Mar-19	BAGALKOT	110	KUDUCHI220-KUDUCHI110	KUDUCHI_110	13:18	13:58	0:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
37	12-Mar-19	BAGALKOT	110	220/110KV,LV3	MAHALINGAPUR_220	0:00	14:42	14:42	LINE CLEAR AVAILED
38	12-Mar-19	BANGALORE	66	HV1	BG ROAD	22:48	23:51	1:03	LINE CLEAR AVAILED
39	12-Mar-19	BANGALORE	66	HOODY 220 - ITI	ITI, BANASWADI	13:02	13:32	0:29	LINE FAULT
40	12-Mar-19	BANGALORE	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	13:02	13:32	0:29	LINE FAULT
41	12-Mar-19	BANGALORE	66	HV2	MATHIKERE	21:51	22:15	0:23	TRANSFORMER FAULT
42	12-Mar-19	BANGALORE	66	HV1	CHIKKABALLAPURA I/A	13:03	13:17	0:14	LINE CLEAR AVAILED
43	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	13:01	13:23	0:22	MAIN SUPPLY FAILURE
44	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	13:28	14:05	0:36	LOAD CURTAILMENT
45	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI	13:01	13:23	0:22	MAIN SUPPLY FAILURE
46	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	13:01	13:23	0:22	MAIN SUPPLY FAILURE
47	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	13:01	13:23	0:22	MAIN SUPPLY FAILURE
48	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	13:01	13:23	0:22	MAIN SUPPLY FAILURE
49	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI	13:28	13:46	0:18	LOAD CURTAILMENT
50	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	13:28	14:05	0:36	LOAD CURTAILMENT
51	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	13:01	13:23	0:22	MAIN SUPPLY FAILURE
52	12-Mar-19	BANGALORE	220	CHINTAMANI 220 - PGCIL 1 & 2	CHINTAMANI 220	13:01	13:23	0:22	MAIN SUPPLY FAILURE
53	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	13:01	13:23	0:22	MAIN SUPPLY FAILURE
54	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	13:01	13:23	0:22	MAIN SUPPLY FAILURE
55	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:01	13:23	0:22	MAIN SUPPLY FAILURE
56	12-Mar-19	BANGALORE	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	11:59	12:12	0:12	LINE CLEAR AVAILED
57	12-Mar-19	BANGALORE	66	HV1	D CROSS	18:19	18:31	0:11	TRANSFORMER FAULT
58	12-Mar-19	BANGALORE	66	HV1	HAROBELE	12:13	13:39	1:25	LINE CLEAR AVAILED
59	12-Mar-19	BANGALORE	66	HV1	HAROBELE	14:20	14:22	0:02	TRANSFORMER FAULT
60	12-Mar-19	BANGALORE	66	HV1	HAROBELE	14:46	14:48	0:01	TRANSFORMER FAULT
61	12-Mar-19	BANGALORE	66	HV2	HAROBELE	14:00	15:10	1:10	LINE CLEAR AVAILED
62	12-Mar-19	BANGALORE	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSUR RAMAPURA	11:00	11:10	0:10	LINE CLEAR AVAILED
63	12-Mar-19	BANGALORE	66	HV1	VG DODDI	16:01	17:00	0:59	LINE CLEAR AVAILED
64	12-Mar-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	9:12	9:25	0:12	LOAD CURTAILMENT
65	12-Mar-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:01	13:26	0:25	MAIN SUPPLY FAILURE
66	12-Mar-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	13:01	13:25	0:24	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
67	12-Mar-19	BANGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	13:01	13:26	0:25	MAIN SUPPLY FAILURE
68	12-Mar-19	BANGALORE	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR	13:01	13:26	0:25	MAIN SUPPLY FAILURE
69	12-Mar-19	BANGALORE	66	KOLAR 220 - BANGARPET 2	BANGARPET	13:01	13:26	0:25	MAIN SUPPLY FAILURE
70	12-Mar-19	BANGALORE	66	KOLAR 220 - RAILWAYS 1 & 2 (EHT)	BANGARPET RAILWAYS (EHT)	13:01	13:21	0:20	MAIN SUPPLY FAILURE
71	12-Mar-19	BANGALORE	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	13:01	13:27	0:26	MAIN SUPPLY FAILURE
72	12-Mar-19	BANGALORE	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	13:01	13:25	0:24	MAIN SUPPLY FAILURE
73	12-Mar-19	BANGALORE	220	KOLAR 220 - PGCIL 1 & 2	KOLAR 220	13:01	13:21	0:20	MAIN SUPPLY FAILURE
74	12-Mar-19	BANGALORE	66	KOLAR 220 - SRINIVASAPURA	TAMAKA, DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	13:01	13:27	0:26	MAIN SUPPLY FAILURE
75	12-Mar-19	BANGALORE	66	HV1	KOLAR 220	13:01	13:25	0:24	MAIN SUPPLY FAILURE
76	12-Mar-19	BANGALORE	66	HV2	KOLAR 220	13:01	13:25	0:24	MAIN SUPPLY FAILURE
77	12-Mar-19	BANGALORE	66	HV3	KOLAR 220	13:01	13:25	0:24	MAIN SUPPLY FAILURE
78	12-Mar-19	BANGALORE	66	HV1	KOLAR 220	13:01	13:25	0:24	MAIN SUPPLY FAILURE
79	12-Mar-19	BANGALORE	66	HV2	KOLAR 220	13:01	13:25	0:24	MAIN SUPPLY FAILURE
80	12-Mar-19	BANGALORE	66	KOLAR 220 - MULABAGAL	MULBAGAL, AVANI	13:01	13:26	0:25	MAIN SUPPLY FAILURE
81	12-Mar-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	13:01	13:38	0:37	MAIN SUPPLY FAILURE
82	12-Mar-19	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:01	13:38	0:37	MAIN SUPPLY FAILURE
83	12-Mar-19	BANGALORE	220	MALUR 220 - KOLAR 1	MALUR 220	13:01	13:28	0:27	MAIN SUPPLY FAILURE
84	12-Mar-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:01	13:28	0:27	MAIN SUPPLY FAILURE
85	12-Mar-19	BANGALORE	66	MALUR 220 - MALUR 66	MALUR 66	13:01	13:38	0:37	MAIN SUPPLY FAILURE
86	12-Mar-19	BANGALORE	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	13:01	13:39	0:38	MAIN SUPPLY FAILURE
87	12-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	13:01	13:39	0:38	MAIN SUPPLY FAILURE
88	12-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:01	13:39	0:38	MAIN SUPPLY FAILURE
89	12-Mar-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:20	12:25	0:05	LINE FAULT
90	12-Mar-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	13:40	13:46	0:06	LINE FAULT
91	12-Mar-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:01	13:48	0:47	MAIN SUPPLY FAILURE
92	12-Mar-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:01	13:48	0:47	MAIN SUPPLY FAILURE
93	12-Mar-19	BANGALORE	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	13:01	13:48	0:47	MAIN SUPPLY FAILURE
94	12-Mar-19	BANGALORE	66	HV1	SARJAPURA 220	13:01	13:48	0:47	MAIN SUPPLY FAILURE
95	12-Mar-19	BANGALORE	66	HV2	SARJAPURA 220	13:01	13:48	0:47	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
96	12-Mar-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:01	13:48	0:47	MAIN SUPPLY FAILURE
97	12-Mar-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	13:01	13:48	0:47	MAIN SUPPLY FAILURE
98	12-Mar-19	BANGALORE	220	HV1	VIKAS TECH PARK 220	13:01	13:48	0:47	MAIN SUPPLY FAILURE
99	12-Mar-19	BANGALORE	220	HV2	VIKAS TECH PARK 220	13:01	13:48	0:47	MAIN SUPPLY FAILURE
100	12-Mar-19	GULBARGA	220	RTPS-SHAHAPUR2	SHAHPUR_220	9:42	23:59	14:17	NFBC ISSUED
101	12-Mar-19	GULBARGA	220	LINGAPUR-JVSL1	JVSWL_220	9:04	18:31	9:27	NFBC ISSUED
102	12-Mar-19	GULBARGA	110	HV1	ALIPUR_220	10:53	12:33	1:40	LINE CLEAR AVAILED
103	12-Mar-19	GULBARGA	110	HV2	ALIPUR_220	12:36	15:38	3:02	LINE CLEAR AVAILED
104	12-Mar-19	GULBARGA	110	DHADESUGUR-VEPL_SLR	DHADESUGUR_110	18:03	19:29	1:26	LINE CLEAR AVAILED
105	12-Mar-19	GULBARGA	110	HV1	KAVITAL_110	16:31	16:47	0:16	TRANSFORMER FAULT
106	12-Mar-19	GULBARGA	110	KAVITAL-GAMESHA	KAVITAL_110	16:48	23:59	7:11	LINE CLEAR AVAILED
107	12-Mar-19	GULBARGA	110	HV1	KAVITAL_110	16:48	17:36	0:48	LINE CLEAR AVAILED
108	12-Mar-19	GULBARGA	110	HV1	KOLHAR_110	15:26	17:18	1:52	LINE CLEAR AVAILED
109	12-Mar-19	GULBARGA	110	KUSTAGI-ILKAL	ILKAL_110	19:32	19:43	0:11	LINE FAULT
110	12-Mar-19	GULBARGA	110	MALLAT-BYAGWAT	BYAGAWAT_110	5:55	6:25	0:30	LINE FAULT
111	12-Mar-19	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	16:30	16:40	0:10	LINE FAULT
112	12-Mar-19	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	16:48	17:18	0:30	LINE FAULT
113	12-Mar-19	GULBARGA	110	HV1	RAJESHWAR_110	16:04	16:30	0:26	LINE CLEAR AVAILED
114	12-Mar-19	GULBARGA	110	HV2	SHORAPUR_110	14:50	15:07	0:17	TRANSFORMER FAULT
115	12-Mar-19	GULBARGA	110	HV1	YELBURAG_110	9:17	9:30	0:13	TRANSFORMER FAULT
116	12-Mar-19	HASSAN	220	HV1	KAVOOR_220	3:31	3:51	0:20	LINE CLEAR AVAILED
117	12-Mar-19	HASSAN	220	HV2	KAVOOR_220	3:54	4:19	0:25	LINE CLEAR AVAILED
118	12-Mar-19	HASSAN	220	HV3	KAVOOR_220	2:45	3:30	0:45	LINE CLEAR AVAILED
119	12-Mar-19	HASSAN	220	HV1	MRSMSG_220	10:24	15:24	5:00	LINE CLEAR AVAILED
120	12-Mar-19	HASSAN	110	LV1	KAVOOR_220	3:31	3:52	0:21	LINE CLEAR AVAILED
121	12-Mar-19	HASSAN	110	LV2	KAVOOR_220	3:53	4:19	0:26	LINE CLEAR AVAILED
122	12-Mar-19	HASSAN	110	LV1	MRSMSG_220	10:24	15:25	5:01	LINE CLEAR AVAILED
123	12-Mar-19	HASSAN	110	HULICA-KVR	HULICAL_110	9:09	12:51	3:42	LINE CLEAR AVAILED
124	12-Mar-19	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:19	17:02	4:43	LINE CLEAR AVAILED
125	12-Mar-19	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	7:15	12:18	5:03	LINE CLEAR AVAILED
126	12-Mar-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:20	13:22	3:02	LINE CLEAR AVAILED
127	12-Mar-19	HASSAN	110	HV1	KONAJE_110	4:30	4:33	0:03	HAND TRIPPED
128	12-Mar-19	HASSAN	110	HV1	KONAJE_110	2:17	2:19	0:02	HAND TRIPPED
129	12-Mar-19	HASSAN	110	HV2	KONAJE_110	4:30	4:33	0:03	HAND TRIPPED
130	12-Mar-19	HASSAN	110	HV2	KONAJE_110	2:17	2:19	0:02	HAND TRIPPED
131	12-Mar-19	HASSAN	110	HV3	KONAJE_110	4:30	4:33	0:03	HAND TRIPPED
132	12-Mar-19	HASSAN	110	HV3	KONAJE_110	2:17	2:19	0:02	HAND TRIPPED
133	12-Mar-19	HASSAN	110	SAGARA-SORABA	SAGARA_110	0:00	9:46	9:46	LINE CLEAR AVAILED
134	12-Mar-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	8:12	8:19	0:07	LINE FAULT
135	12-Mar-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	9:50	10:00	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
136	12-Mar-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:29	10:49	0:20	MAIN SUPPLY FAILURE
137	12-Mar-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:00	13:00	2:00	MAIN SUPPLY FAILURE
138	12-Mar-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	9:50	10:00	0:10	MAIN SUPPLY FAILURE
139	12-Mar-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:29	10:49	0:20	MAIN SUPPLY FAILURE
140	12-Mar-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:00	13:00	2:00	MAIN SUPPLY FAILURE
141	12-Mar-19	HASSAN	66	HV2	BELUR_66	16:45	16:53	0:08	TRANSFORMER FAULT
142	12-Mar-19	HASSAN	66	HV2	BELUR_66	19:09	19:19	0:10	TRANSFORMER FAULT
143	12-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	16:37	17:25	0:48	LINE CLEAR AVAILED
144	12-Mar-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	11:00	12:57	1:57	LINE CLEAR AVAILED
145	12-Mar-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	12:23	12:32	0:09	LINE FAULT
146	12-Mar-19	MYSORE	66	HV1	DODDARAYAPET_66	9:06	23:59	14:52	LINE CLEAR AVAILED
147	12-Mar-19	MYSORE	66	GUNDULPETE-BEGUR	BEGUR_66 SINDHUVALLI_66	6:03	6:29	0:26	LINE FAULT
148	12-Mar-19	MYSORE	66	GUNDULPETE-KABBALLI	KABHALLY_66	6:03	6:28	0:25	LINE FAULT
149	12-Mar-19	MYSORE	66	HOOTAGALLI-ELWALA	ELAVALA_66 GAVADAGERE_66	12:35	12:41	0:06	LINE FAULT
150	12-Mar-19	MYSORE	66	HOOTAGALLI-ELWALA	ELAVALA_66 GAVADAGERE_66	13:46	13:53	0:06	LINE FAULT
151	12-Mar-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HANAGODU_66 HUNSUR_66 HOSURGATE_66	12:34	12:41	0:07	LINE FAULT
152	12-Mar-19	MYSORE	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HANAGODU_66 HUNSUR_66 HOSURGATE_66	13:44	17:36	3:51	LINE FAULT
153	12-Mar-19	MYSORE	66	JAKKANAHALLI-NAGAMANGALA	BOGADHI MANDYA_66, G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	8:25	8:48	0:23	LINE FAULT
154	12-Mar-19	MYSORE	66	KIADB MANDYA-TK HALLI	K_HONNALGERE_66, KIADBMANDYA_66 MADDUR_66 TUMBEKERE_66	10:15	10:25	0:10	LINE FAULT
155	12-Mar-19	MYSORE	66	KIADB MANDYA-TK HALLI	K_HONNALGERE_66, KIADBMANDYA_66 MADDUR_66 TUMBEKERE_66	10:58	11:09	0:11	LINE FAULT
156	12-Mar-19	MYSORE	66	HV2	KMDODDI_66	16:13	16:30	0:17	TRANSFORMER FAULT
157	12-Mar-19	MYSORE	66	MANDYA-CHIKKMANDYA	CHIKKA_MANDYA_66, BESAGARAHALLI_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	10:35	10:40	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
158	12-Mar-19	MYSORE	66	MANDYA-MC-4	CHIKKA_MANDYA_66, BESAGARAHALLI_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66 HADLI_66 MALAVALLI_66	13:35	13:46	0:11	HAND TRIPPED
159	12-Mar-19	MYSORE	66	HV1	RAMAPURA_MYS_66	12:31	13:25	0:54	LINE CLEAR AVAILED
160	12-Mar-19	MYSORE	66	HV2	RAMAPURA_MYS_66	13:00	13:20	0:20	LINE CLEAR AVAILED
161	12-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	9:15	21:35	12:20	LINE CLEAR AVAILED
162	12-Mar-19	MYSORE	66	HV3	SFCSHIVA_66	16:46	16:51	0:05	TRANSFORMER FAULT
163	12-Mar-19	MYSORE	66	TUBINAKERE-MC-2	MANDYA_66	13:36	13:47	0:10	LINE FAULT
164	12-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:15	5:17	0:01	LINE CLEAR AVAILED
165	12-Mar-19	TUMKUR	220	TR-2(HV SIDE)	MADHUGIRI_220	10:15	14:34	4:19	LINE CLEAR AVAILED
166	12-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:16	16:29	11:12	LINE CLEAR AVAILED
167	12-Mar-19	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	22:08	22:19	0:11	LINE FAULT
168	12-Mar-19	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	6:10	6:17	0:07	TRANSFORMER FAULT
169	12-Mar-19	TUMKUR	110	TR-1	GUBBI_110	19:12	19:18	0:06	TRANSFORMER FAULT
170	12-Mar-19	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66	9:22	9:56	0:33	HAND TRIPPED
171	12-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:21	11:30	1:09	LOAD CURTAILMENT
172	12-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:12	14:55	0:43	LINE CLEAR AVAILED
173	12-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	12:02	12:19	0:16	LINE FAULT
174	12-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	13:02	13:04	0:01	LINE FAULT
175	12-Mar-19	TUMKUR	66	BENKIKERE-CHANNAGIRI	BENKIKERE_66	14:25	19:09	4:44	LINE CLEAR AVAILED
176	12-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	7:02	8:08	1:06	LINE CLEAR AVAILED
177	12-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:46	17:56	10:10	LINE CLEAR AVAILED
178	12-Mar-19	TUMKUR	66	TR-2	HARIYABBE_66	18:18	18:28	0:10	TRANSFORMER FAULT
179	12-Mar-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	18:17	18:31	0:13	LINE FAULT
180	12-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	14:22	18:44	4:22	LINE CLEAR AVAILED
181	12-Mar-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	13:33	18:44	5:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
182	12-Mar-19	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	15:37	15:54	0:17	LINE CLEAR AVAILED
183	12-Mar-19	TUMKUR	66	TR-2(LV SIDE)	MADHUGIRI_220	10:15	14:47	4:32	LINE CLEAR AVAILED
184	12-Mar-19	TUMKUR	66	TR-2	NAGALMADIKE_66	17:16	17:58	0:42	LINE CLEAR AVAILED
185	12-Mar-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	8:34	8:39	0:04	TRANSFORMER FAULT
186	12-Mar-19	TUMKUR	66	NEELAGUNDA 220KV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPAN AHALLI_66,HALUVAGALU_66,TEL AGI_66	14:59	15:07	0:08	LINE FAULT
187	12-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	4:03	4:09	0:05	LINE FAULT
188	12-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	7:05	7:15	0:10	LINE FAULT
189	12-Mar-19	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	13:42	16:29	2:47	LINE FAULT
190	13-Mar-19	BAGALKOT	110	AMBEWADI220-KAVALWADA	KAVALWADA_110	9:49	12:11	2:22	LINE CLEAR AVAILED
191	13-Mar-19	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	9:06	9:20	0:14	LINE FAULT
192	13-Mar-19	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	9:36	17:32	7:56	LINE CLEAR AVAILED
193	13-Mar-19	BAGALKOT	110	110/33KV,HV2	JAMAKHANDI_110	14:21	17:08	2:47	LINE CLEAR AVAILED
194	13-Mar-19	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	5:36	7:43	2:07	LINE FAULT
195	13-Mar-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	0:00	12:05	12:05	LINE CLEAR AVAILED
196	13-Mar-19	BAGALKOT	110	110/33KV,HV3	KULIGOD_110,AREMALLATTI_33,T IGADI_33	19:03	19:17	0:14	TRANSFORMER FAULT
197	13-Mar-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	21:24	21:28	0:04	TRANSFORMER FAULT
198	13-Mar-19	BAGALKOT	110	110/33KV,HV2	MURDESHWARA_110	10:56	11:56	1:00	LINE CLEAR AVAILED
199	13-Mar-19	BAGALKOT	110	110/11KV,HV2	NANADI_110	12:11	13:43	1:32	LINE CLEAR AVAILED
200	13-Mar-19	BAGALKOT	66	HONNALI-HARIHAR HOSPET	HARIHAR HOSPET_66	10:59	14:54	3:55	LINE FAULT
201	13-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	9:45	9:57	0:12	HAND TRIPPED
202	13-Mar-19	BAGALKOT	110	SIRSI220-KAVALWADA	KAVALWADA_110	9:57	12:17	2:20	LINE CLEAR AVAILED
203	13-Mar-19	BAGALKOT	110	SIRSI110-KUMTA1	KUMTA_110	21:04	23:59	2:55	LINE FAULT
204	13-Mar-19	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	9:55	13:05	3:10	LINE CLEAR AVAILED
205	13-Mar-19	BAGALKOT	220	HUBLI-NAGJHARI2	HUBLI_220	13:10	13:27	0:17	HAND TRIPPED
206	13-Mar-19	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	10:21	17:39	7:18	NFBC ISSUED
207	13-Mar-19	BAGALKOT	110	RABKAVI-SATTI	SATTI_110	17:39	17:40	0:01	HAND TRIPPED
208	13-Mar-19	BAGALKOT	110	110/11KV,HV2	SATTI_110	18:56	19:00	0:04	TRANSFORMER FAULT
209	13-Mar-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	6:12	6:18	0:06	HAND TRIPPED
210	13-Mar-19	BAGALKOT	220	400/220KV,ICT2(LV SIDE)	DHONI_400	11:55	12:02	0:07	TRANSFORMER FAULT
211	13-Mar-19	BANGALORE	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, BEVOOR, SANKALGERE	11:22	12:44	1:22	MAIN SUPPLY FAILURE
212	13-Mar-19	BANGALORE	66	BIDADI 220 - HEJJALA	HEJJALA	11:22	12:44	1:22	MAIN SUPPLY FAILURE
213	13-Mar-19	BANGALORE	220	HV1	BIDADI 220	11:22	12:40	1:18	TRANSFORMER FAULT
214	13-Mar-19	BANGALORE	66	HV1	BIDADI 220	11:22	12:40	1:18	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
215	13-Mar-19	BANGALORE	66	HV2	BRINDAVANA	13:45	13:59	0:14	LINE CLEAR AVAILED
216	13-Mar-19	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	12:30	12:32	0:01	TRANSFORMER FAULT
217	13-Mar-19	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	7:20	7:35	0:15	TRANSFORMER FAULT
218	13-Mar-19	BANGALORE	66	HV1	RBI	11:30	11:35	0:05	LINE CLEAR AVAILED
219	13-Mar-19	BANGALORE	66	HV2	RBI	13:48	13:53	0:05	LINE CLEAR AVAILED
220	13-Mar-19	BANGALORE	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	5:50	5:55	0:05	LOAD CHANGEOVER
221	13-Mar-19	BANGALORE	66	SHOBHA APARTMENT - CESSONA TECH PARK	SHOBHA APARTMENT	8:45	8:50	0:05	LOAD CHANGEOVER
222	13-Mar-19	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENT	12:14	12:20	0:06	LOAD CHANGEOVER
223	13-Mar-19	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENT	14:27	14:40	0:13	LOAD CHANGEOVER
224	13-Mar-19	BANGALORE	66	GOKULA - HEBBAL 2	RMV, TATA INSTITUTE (EHT)	20:15	20:50	0:35	LINE CLEAR AVAILED
225	13-Mar-19	BANGALORE	66	HV1	BOODIGERE	13:30	13:35	0:05	TRANSFORMER FAULT
226	13-Mar-19	BANGALORE	66	HV1	AGALAKOTE	11:00	11:05	0:05	TRANSFORMER FAULT
227	13-Mar-19	BANGALORE	66	HV1	AGALAKOTE	20:50	20:56	0:05	TRANSFORMER FAULT
228	13-Mar-19	BANGALORE	66	HV1	ANDERSONPET	10:36	10:45	0:08	LINE CLEAR AVAILED
229	13-Mar-19	BANGALORE	220	GOWRIBIDANUR 220 - DB PURA 220	KIADB DB PURA 220	14:37	15:18	0:41	LINE FAULT
230	13-Mar-19	BANGALORE	66	HV1	KIADB DB PURA 220	14:37	15:18	0:41	MAIN SUPPLY FAILURE
231	13-Mar-19	BANGALORE	66	HV2	KIADB DB PURA 220	14:37	15:18	0:41	MAIN SUPPLY FAILURE
232	13-Mar-19	BANGALORE	66	KIADB DB PURA 220 - HSS (EHT)	HSS (EHT)	14:37	15:18	0:41	MAIN SUPPLY FAILURE
233	13-Mar-19	BANGALORE	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	14:37	15:18	0:41	MAIN SUPPLY FAILURE
234	13-Mar-19	BANGALORE	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	13:03	14:57	1:54	LINE CLEAR AVAILED
235	13-Mar-19	BANGALORE	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	16:22	16:27	0:05	LINE CLEAR AVAILED
236	13-Mar-19	BANGALORE	66	DB PURA 220 - DG 1	AIR (EHT)	15:51	15:53	0:02	LOAD CHANGEOVER
237	13-Mar-19	BANGALORE	66	DB PURA 220 - DG 1	AIR (EHT)	16:05	16:07	0:01	LOAD CHANGEOVER
238	13-Mar-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	15:15	15:53	0:38	LINE FAULT
239	13-Mar-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	16:05	16:07	0:01	LOAD CHANGEOVER
240	13-Mar-19	BANGALORE	66	HV1	MELUR	16:54	17:19	0:24	LINE CLEAR AVAILED
241	13-Mar-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	0:14	0:19	0:05	LINE FAULT
242	13-Mar-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	2:15	2:30	0:15	LINE FAULT
243	13-Mar-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	2:31	2:42	0:11	LINE FAULT
244	13-Mar-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	21:15	21:25	0:10	LINE FAULT
245	13-Mar-19	GULBARGA	220	HV1	KUSTAGI_220	6:10	6:30	0:20	TRANSFORMER FAULT
246	13-Mar-19	GULBARGA	220	HV1	KUSTAGI_220	6:37	6:50	0:13	TRANSFORMER FAULT
247	13-Mar-19	GULBARGA	220	HV1	KUSTAGI_220	7:05	7:35	0:30	TRANSFORMER FAULT
248	13-Mar-19	GULBARGA	220	LINGAPUR-JVSL1	LINGAPUR_220	9:07	17:18	8:11	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
249	13-Mar-19	GULBARGA	220	SHAHPUR1-RTPS	SHHAPUR_220	19:39	23:59	4:20	LINE FAULT
250	13-Mar-19	GULBARGA	220	KAPNOOR-SHAHPUR1	KAPNOOR_220	22:28	23:59	1:31	LINE CLEAR AVAILED
251	13-Mar-19	GULBARGA	220	HV1	SEDAM_220	15:07	15:21	0:14	TRANSFORMER FAULT
252	13-Mar-19	GULBARGA	110	HV2	BISIHALLI_110	11:49	13:23	1:34	LINE CLEAR AVAILED
253	13-Mar-19	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	6:19	6:51	0:32	LINE FAULT
254	13-Mar-19	GULBARGA	110	GURUMITAKAL-SEDAM	KONKAL	15:05	15:20	0:15	MAIN SUPPLY FAILURE
255	13-Mar-19	GULBARGA	110	KAVITAL-GAMESHA	KAVITAL_110	0:00	15:27	15:27	LINE CLEAR AVAILED
256	13-Mar-19	GULBARGA	110	KAVITAL-MALLAT	KAVITAL_110	12:50	13:10	0:20	HAND TRIPPED
257	13-Mar-19	GULBARGA	110	KUSTAGI-ILKAL1	ILKAL_110	6:37	7:40	1:03	LINE FAULT
258	13-Mar-19	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	18:57	20:13	1:16	LINE CLEAR AVAILED
259	13-Mar-19	GULBARGA	110	HV2	MADIYAL_110	19:18	19:28	0:10	TRANSFORMER FAULT
260	13-Mar-19	GULBARGA	110	HV1	BISIHALLI_110	14:41	17:23	2:42	LINE CLEAR AVAILED
261	13-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	10:05	12:30	2:25	LINE CLEAR AVAILED
262	13-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	12:40	12:45	0:05	TRANSFORMER FAULT
263	13-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	12:50	13:30	0:40	LINE CLEAR AVAILED
264	13-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	14:39	16:09	1:30	LINE FAULT
265	13-Mar-19	HASSAN	66	MRSSHM-DVG2	MRSMG_220	11:13	11:31	0:18	HAND TRIPPED
266	13-Mar-19	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	14:39	16:09	1:30	LINE FAULT
267	13-Mar-19	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	16:54	17:10	0:16	LINE FAULT
268	13-Mar-19	HASSAN	110	HALADY11-HOSANGADI	HALADY_110	9:54	12:52	2:58	LINE CLEAR AVAILED
269	13-Mar-19	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	9:51	12:52	3:01	LINE CLEAR AVAILED
270	13-Mar-19	HASSAN	110	HOSNGD-HULIKAL	HOSANGADI_110	9:51	12:52	3:01	LINE CLEAR AVAILED
271	13-Mar-19	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:45	11:57	1:12	LINE FAULT
272	13-Mar-19	HASSAN	110	HV2	KUNDAPURA_110	9:23	12:34	3:11	LINE CLEAR AVAILED
273	13-Mar-19	HASSAN	110	SAGARA-ALKLA	SAGARA_110	21:48	21:58	0:10	MAIN SUPPLY FAILURE
274	13-Mar-19	HASSAN	110	SAGARA-ALKLA	SAGARA_110	21:58	23:59	2:01	LINE FAULT
275	13-Mar-19	HASSAN	110	SAGARA-JST1	SAGARA_110	21:48	22:58	1:10	MAIN SUPPLY FAILURE
276	13-Mar-19	HASSAN	110	SAGARA-SAGAR	SAGARA_110	21:48	22:58	1:10	LINE FAULT
277	13-Mar-19	HASSAN	110	SAGARA-TAL	SAGARA_110	21:48	22:58	1:10	MAIN SUPPLY FAILURE
278	13-Mar-19	HASSAN	66	HV2	BELUR_66	6:56	7:01	0:05	TRANSFORMER FAULT
279	13-Mar-19	HASSAN	66	HV2	BELUR_66	7:39	7:44	0:05	TRANSFORMER FAULT
280	13-Mar-19	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	11:08	16:32	5:24	MAIN SUPPLY FAILURE
281	13-Mar-19	HASSAN	66	HV1	HAGARE_66	10:56	16:30	5:34	MAIN SUPPLY FAILURE
282	13-Mar-19	HASSAN	66	HV2	HOLEHONNUR_66	10:03	10:43	0:40	LINE CLEAR AVAILED
283	13-Mar-19	HASSAN	66	HV1	KALASAPURA_66	10:02	16:50	6:48	LINE CLEAR AVAILED
284	13-Mar-19	HASSAN	66	KALASAP-UDDRKPL	KALASAPURA_66	10:02	16:48	6:46	LINE CLEAR AVAILED
285	13-Mar-19	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	11:10	11:20	0:10	HAND TRIPPED
286	13-Mar-19	MYSORE	66	BANNUR - SFC	KIRUGAVALU_66 MALIYURU_66	11:15	14:52	3:37	NFBC ISSUED
287	13-Mar-19	MYSORE	66	GUNDULPETE - HANGLA	BHARGI_66 HANGLA_66	18:49	18:50	0:01	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
288	13-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	9:08	9:51	0:43	HAND TRIPPED
289	13-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	9:08	9:51	0:43	HAND TRIPPED
290	13-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	10:20	10:28	0:08	HAND TRIPPED
291	13-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	10:20	10:28	0:08	HAND TRIPPED
292	13-Mar-19	MYSORE	66	HV1	KIADBMANDYA_66	9:10	9:51	0:41	HAND TRIPPED
293	13-Mar-19	MYSORE	66	HV2	KIADBMANDYA_66	9:10	9:51	0:41	HAND TRIPPED
294	13-Mar-19	MYSORE	66	HV1	KIADBMANDYA_66	10:16	10:23	0:07	HAND TRIPPED
295	13-Mar-19	MYSORE	66	HV2	KIADBMANDYA_66	10:16	10:23	0:07	HAND TRIPPED
296	13-Mar-19	MYSORE	66	KR NAGARA - BILIKERE	BILIKERE_66 DMG_HALLI_66 GVGUDI_66	14:00	14:58	0:57	HAND TRIPPED
297	13-Mar-19	MYSORE	66	KR NAGARA - KUSHALANAGARA	KRNAGARA_66 BHERYA_66	13:49	14:06	0:17	LINE FAULT
298	13-Mar-19	MYSORE	66	KR NAGARA - CHUNCHUNKATTE	CHUNCHUNKATTE_66	13:49	14:06	0:17	LINE FAULT
299	13-Mar-19	MYSORE	66	HV1	KUSHALANAGARA_66	16:59	19:56	2:56	LINE CLEAR AVAILED
300	13-Mar-19	MYSORE	66	MIRLE - KR NAGARA	MIRLE_66	12:47	13:23	0:36	LINE CLEAR AVAILED
301	13-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	12:05	23:59	11:53	LINE CLEAR AVAILED
302	13-Mar-19	MYSORE	66	TUBINAKERE - NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 JAKKANAHALLY_66 SHIVALLY_66	7:36	7:50	0:13	LINE FAULT
303	13-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:32	12:17	6:45	LINE CLEAR AVAILED
304	13-Mar-19	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	23:31	23:40	0:08	HAND TRIPPED
305	13-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:33	12:17	6:43	LINE CLEAR AVAILED
306	13-Mar-19	TUMKUR	110	TR-1 & TR-2	TURUVEKERE_110	16:41	16:46	0:04	HAND TRIPPED
307	13-Mar-19	TUMKUR	110	TR-3	AMMASANDRA_110	8:05	13:06	5:01	LINE CLEAR AVAILED
308	13-Mar-19	TUMKUR	110	TR-1	GUBBI_110	18:51	19:00	0:09	TRANSFORMER FAULT
309	13-Mar-19	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	8:03	12:42	4:38	LINE CLEAR AVAILED
310	13-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:22	15:20	0:57	HAND TRIPPED
311	13-Mar-19	TUMKUR	66	CHANNAGIRI-(CHANNAGIRI(LINGDHLI))	CHANNAGIRI_66	14:55	15:02	0:06	LINE FAULT
312	13-Mar-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	8:56	9:02	0:05	HAND TRIPPED
313	13-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:07	6:16	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
314	13-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	8:15	8:20	0:05	HAND TRIPPED
315	13-Mar-19	TUMKUR	66	TR-2	HARIYABBE_66	0:09	0:16	0:06	TRANSFORMER FAULT
316	13-Mar-19	TUMKUR	66	HIREHALLI - MELEKOTE	HIREHALLY_66	12:07	16:48	4:40	LINE CLEAR AVAILED
317	13-Mar-19	TUMKUR	66	TR-2	HIREHALLY_66	10:36	16:40	6:03	LINE CLEAR AVAILED
318	13-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	0:31	0:39	0:08	LINE FAULT
319	13-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:31	8:42	0:10	HAND TRIPPED
320	13-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	19:27	19:33	0:05	LINE FAULT
321	13-Mar-19	TUMKUR	66	TR-1	LINGADAHALLY_66	17:30	18:32	1:02	LINE CLEAR AVAILED
322	13-Mar-19	TUMKUR	66	TR-1	LINGADAHALLY_66	0:24	0:47	0:22	LINE CLEAR AVAILED
323	13-Mar-19	TUMKUR	66	TR-2	MALEBENNUR_66	17:09	17:35	0:26	LINE CLEAR AVAILED
324	13-Mar-19	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	2:04	2:14	0:09	LINE FAULT
325	13-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	3:01	4:54	1:53	LINE FAULT
326	13-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	7:03	8:21	1:18	LINE FAULT
327	13-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	11:42	12:17	0:34	LINE FAULT
328	13-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:47	12:18	2:30	LINE FAULT
329	14-Mar-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALAGUND_110	11:16	13:17	2:01	LINE FAULT
330	14-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	11:19	23:59	12:40	LINE CLEAR AVAILED
331	14-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	11:19	19:06	7:47	LINE CLEAR AVAILED
332	14-Mar-19	BAGALKOT	110	GADAG ROAD-GOPANAKOPPA	GOPANAKOPPA_110	0:00	12:03	12:03	LINE CLEAR AVAILED
333	14-Mar-19	BAGALKOT	110	110/33KV,HV2	HANGAL_110,BELAGALPET_33,LA XMIPUR_33	9:19	9:37	0:18	TRANSFORMER FAULT
334	14-Mar-19	BAGALKOT	110	DSS SUGARS-HIREBEVANUR	HIREBEVANUR_110	13:23	14:03	0:40	LINE CLEAR AVAILED
335	14-Mar-19	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	10:19	16:35	6:16	LINE CLEAR AVAILED
336	14-Mar-19	BAGALKOT	220	HAVERI-NARENDRA	HAVERI_220	16:59	17:43	0:44	LINE CLEAR AVAILED
337	14-Mar-19	BAGALKOT	220	HAVERI-BIDNAL	HAVERI_220	10:21	16:40	6:19	LINE CLEAR AVAILED
338	14-Mar-19	BAGALKOT	220	HAVERI-GUTTUR 1	HAVERI_220	10:23	16:56	6:33	LINE CLEAR AVAILED
339	14-Mar-19	BAGALKOT	220	HAVERI-GUTTUR 2	HAVERI_220	10:23	16:58	6:35	LINE CLEAR AVAILED
340	14-Mar-19	BAGALKOT	220	220/110KV,HV2,LV2	HAVERI_220	10:11	16:39	6:28	LINE CLEAR AVAILED
341	14-Mar-19	BAGALKOT	220	220/110KV,HV1	HAVERI_220	10:11	17:04	6:53	LINE CLEAR AVAILED
342	14-Mar-19	BAGALKOT	110	HAVERI220-TILUVALLI	TILUVALLI_110	9:55	16:48	6:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
343	14-Mar-19	BAGALKOT	110	HAVERI220-KNNL	KNNL_110	10:25	16:52	6:27	LINE CLEAR AVAILED
344	14-Mar-19	BAGALKOT	110	HAVERI220-TILUVALI	TILUVALI_110	17:11	17:22	0:11	HAND TRIPPED
345	14-Mar-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	17:11	17:21	0:10	LINE FAULT
346	14-Mar-19	BAGALKOT	110	HUNGUND-ILKAL 1	ILKAL_110	12:06	16:18	4:12	LINE CLEAR AVAILED
347	14-Mar-19	BAGALKOT	110	ITANAL-SULTANPUR	SULTANPUR_110	11:22	12:58	1:36	LINE CLEAR AVAILED
348	14-Mar-19	BAGALKOT	110	VAJRAMATTI220-MUDHOL	MUDHOL_110	17:01	17:56	0:55	LINE CLEAR AVAILED
349	14-Mar-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	16:01	16:10	0:09	TRANSFORMER FAULT
350	14-Mar-19	BAGALKOT	220	HUBLI220-BIDNAL1	HUBLI_220	10:04	14:19	4:15	LINE CLEAR AVAILED
351	14-Mar-19	BAGALKOT	220	SOUDATTI220-MAHALINGAPUR	SOUDATTI_220	13:55	15:12	1:17	LINE FAULT
352	14-Mar-19	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	0:00	7:58	7:58	LINE CLEAR AVAILED
353	14-Mar-19	BAGALKOT	110	110/11KV,HV2	RANNABELAGALI_110	7:51	9:58	2:07	LINE CLEAR AVAILED
354	14-Mar-19	BAGALKOT	110	110/11KV,HV1	RANNABELAGALI_110	10:04	11:19	1:15	LINE CLEAR AVAILED
355	14-Mar-19	BAGALKOT	110	SHIRAHATTI-LAXMESWAR	LAXMESWAR_110	20:58	22:43	1:45	LINE FAULT
356	14-Mar-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	18:47	18:54	0:07	TRANSFORMER FAULT
357	14-Mar-19	BAGALKOT	110	NARENDRA-HUBLI2	NARENDRA_220	11:03	12:27	1:24	NFBC ISSUED
358	14-Mar-19	BAGALKOT	110	110/11KV,HV2	NAVANAGAR(B)_110	8:38	10:56	2:18	LINE CLEAR AVAILED
359	14-Mar-19	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110(STATION NOT INTERRUPTED)	12:41	16:31	3:50	LINE CLEAR AVAILED
360	14-Mar-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	0:11	0:16	0:05	TRANSFORMER FAULT
361	14-Mar-19	BAGALKOT	110	LAXMESWAR-BELLATTI	BELLATTI_110	20:58	22:48	1:50	LINE FAULT
362	14-Mar-19	BAGALKOT	110	VAJRAMATTI220-JAMBAGI	JUMBAGI_110	17:01	17:59	0:58	LINE CLEAR AVAILED
363	14-Mar-19	BAGALKOT	110	110/11KV,HV1	JAMBAGI_110	17:01	17:59	0:58	LINE CLEAR AVAILED
364	14-Mar-19	BAGALKOT	110	110/11KV,HV2A	JAMKHANDI_110	13:35	14:50	1:15	LINE CLEAR AVAILED
365	14-Mar-19	BAGALKOT	110	110/33KV,HV1	JAMKHANDI_110,HIPPARGI_33KV	15:44	17:46	2:02	LINE CLEAR AVAILED
366	14-Mar-19	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	14:21	14:29	0:08	LINE FAULT
367	14-Mar-19	BANGALORE	66	ABBIGERE - DG3	ABBIGERE	7:40	7:44	0:04	MAIN SUPPLY FAILURE
368	14-Mar-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD, JIGANI 66	10:35	10:55	0:20	LINE FAULT
369	14-Mar-19	BANGALORE	66	HV1	POTTERY ROAD	12:05	12:10	0:05	LINE CLEAR AVAILED
370	14-Mar-19	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:30	17:39	5:09	LINE CLEAR AVAILED
371	14-Mar-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	9:56	9:59	0:02	LINE CLEAR AVAILED
372	14-Mar-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	13:34	13:35	0:01	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
373	14-Mar-19	BANGALORE	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	15:29	15:38	0:08	LINE FAULT
374	14-Mar-19	BANGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	9:17	9:29	0:12	LOAD CURTAILMENT
375	14-Mar-19	BANGALORE	66	HV1	KOLAR 220	21:06	23:59	2:52	TRANSFORMER FAULT
376	14-Mar-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANGONDHI	8:08	8:18	0:10	LINE FAULT
377	14-Mar-19	BANGALORE	66	HV2	SULIBELE	10:40	13:25	2:45	TRANSFORMER FAULT
378	14-Mar-19	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	0:42	0:53	0:10	LINE FAULT
379	14-Mar-19	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	1:02	1:19	0:16	LINE FAULT
380	14-Mar-19	BANGALORE	66	SOLADEVANAHALLI - SRS PEENYA 220	SOLADEVANAHALLI	7:20	7:26	0:06	LOAD CHANGEOVER
381	14-Mar-19	BANGALORE	66	YELAHANKA 220 - LINE 4	SAHAKARINAGAR, RAILWAYS (EHT)	7:21	7:27	0:05	LINE FAULT
382	14-Mar-19	BANGALORE	66	YELAHANKA 220 - LINE 4	SAHAKARINAGAR, RAILWAYS (EHT)	10:24	10:32	0:07	LINE FAULT
383	14-Mar-19	BANGALORE	66	MANYATA TECH PARK - ATTUR YELAHANKA	MANYATA TECH PARK	7:40	7:50	0:10	LOAD CHANGEOVER
384	14-Mar-19	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:30	17:39	5:09	LINE CLEAR AVAILED
385	14-Mar-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	9:56	9:59	0:02	LINE CLEAR AVAILED
386	14-Mar-19	BANGALORE	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	13:34	13:35	0:01	LINE CLEAR AVAILED
387	14-Mar-19	BANGALORE	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	15:29	15:38	0:08	LINE FAULT
388	14-Mar-19	BANGALORE	66	KOLAR 220 - THAYALUR	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	9:17	9:29	0:12	LOAD CURTAILMENT
389	14-Mar-19	BANGALORE	66	HV1	KOLAR 220	21:06	23:59	2:52	TRANSFORMER FAULT
390	14-Mar-19	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANGONDHI	8:08	8:18	0:10	LINE FAULT
391	14-Mar-19	BANGALORE	66	HV2	SULIBELE	10:40	13:25	2:45	TRANSFORMER FAULT
392	14-Mar-19	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	0:42	0:53	0:10	LINE FAULT
393	14-Mar-19	BANGALORE	66	YELAHANKA 220 - LINE 6	SOLADEVANAHALLI	1:02	1:19	0:16	LINE FAULT
394	14-Mar-19	BANGALORE	66	SOLADEVANAHALLI - SRS PEENYA 220	SOLADEVANAHALLI	7:20	7:26	0:06	LOAD CHANGEOVER
395	14-Mar-19	BANGALORE	66	YELAHANKA 220 - LINE 4	SAHAKARINAGAR, RAILWAYS (EHT), ATTUR YELAHANKA	7:21	7:27	0:05	LINE FAULT
396	14-Mar-19	BANGALORE	66	YELAHANKA 220 - LINE 4	SAHAKARINAGAR, RAILWAYS (EHT), ATTUR YELAHANKA	10:24	10:32	0:07	LINE FAULT
397	14-Mar-19	BANGALORE	66	MANYATA TECH PARK - ATTUR YELAHANKA	MANYATA TECH PARK	7:40	7:50	0:10	LOAD CHANGEOVER
398	14-Mar-19	BANGALORE	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	7:27	7:44	0:17	MAIN SUPPLY FAILURE
399	14-Mar-19	BANGALORE	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	10:32	10:50	0:18	MAIN SUPPLY FAILURE
400	14-Mar-19	BANGALORE	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	8:24	8:26	0:02	LOAD CHANGEOVER
401	14-Mar-19	GULBARGA	220	LINGAPUR-JVSL-2	LINGAPUR_220	8:53	18:44	9:51	NFBC ISSUED
402	14-Mar-19	GULBARGA	220	LINGAPUR-GUDAHALLI-1	LINGAPUR_220	10:10	16:03	5:53	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
403	14-Mar-19	GULBARGA	220	RTPS-SHAHAPUR2	SHAHPUR_220	0:00	15:54	15:54	NFBC ISSUED
404	14-Mar-19	GULBARGA	110	HV3	BEVOOR_110	6:31	7:03	0:32	TRANSFORMER FAULT
405	14-Mar-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	6:01	8:26	2:25	LINE FAULT
406	14-Mar-19	GULBARGA	110	PDHALLI-BASASTEELS	PD_HALLI_110	4:55	4:59	0:04	LINE CLEAR AVAILED
407	14-Mar-19	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	8:43	10:43	2:00	LINE CLEAR AVAILED
408	14-Mar-19	GULBARGA	110	TEKKALKOTE-ABMN_SLR	TEKKALAKOTE_110	12:25	12:45	0:20	LINE FAULT
409	14-Mar-19	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	14:37	18:27	3:50	NFBC ISSUED
410	14-Mar-19	GULBARGA	110	KUSTAGI-SUZLONWIND1	KUSTAGI_220	18:53	19:12	0:19	LINE FAULT
411	14-Mar-19	GULBARGA	110	KUSTAGI-SUZLONWIND1	KUSTAGI_220	19:18	19:45	0:27	LINE FAULT
412	14-Mar-19	HASSAN	220	H1	KEMAR_220	4:15	5:32	1:17	LINE CLEAR AVAILED
413	14-Mar-19	HASSAN	220	HV2	KEMAR_220	5:40	6:47	1:07	LINE CLEAR AVAILED
414	14-Mar-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:10	17:57	7:47	LINE CLEAR AVAILED
415	14-Mar-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:10	17:57	7:47	NFBC ISSUED
416	14-Mar-19	HASSAN	110	HV1	AJJAMPU_110	11:21	12:42	1:21	TRANSFORMER FAULT
417	14-Mar-19	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	9:57	13:23	3:26	LINE CLEAR AVAILED
418	14-Mar-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	15:56	16:06	0:10	HAND TRIPPED
419	14-Mar-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	17:13	17:21	0:08	HAND TRIPPED
420	14-Mar-19	HASSAN	110	TOGARSI-BALIGAVI	TOGARSI_110	13:27	23:59	10:32	LINE CLEAR AVAILED
421	14-Mar-19	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	12:58	15:09	2:11	LINE CLEAR AVAILED
422	14-Mar-19	HASSAN	66	HV1	BYACHANAHALLY_66	13:01	13:15	0:14	TRANSFORMER FAULT
423	14-Mar-19	HASSAN	66	HV1	BYACHANAHALLY_66	15:44	15:56	0:12	TRANSFORMER FAULT
424	14-Mar-19	HASSAN	66	KUDLEGE-ANVRPP	KUDLIGERE_66	12:09	12:13	0:04	HAND TRIPPED
425	14-Mar-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	8:14	8:26	0:12	LINE FAULT
426	14-Mar-19	HASSAN	66	HV2	SATHENAHALLY_66	15:55	17:13	1:18	LINE CLEAR AVAILED
427	14-Mar-19	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	8:26	8:34	0:08	HAND TRIPPED
428	14-Mar-19	MYSORE	66	BANNUR-SFC	KIRUGAVALU_66 MALIYURU_66	9:30	9:52	0:22	HAND TRIPPED
429	14-Mar-19	MYSORE	66	BANNUR-VAJAMANGALA	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	7:10	7:15	0:05	LINE FAULT
430	14-Mar-19	MYSORE	66	BANNUR-VAJAMANGALA	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	7:50	7:55	0:05	LINE FAULT
431	14-Mar-19	MYSORE	66	BANNUR-VAJAMANGALA	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	8:15	9:25	1:10	LINE FAULT
432	14-Mar-19	MYSORE	66	HV1	K_HONNALGERE_66	6:28	6:49	0:20	HAND TRIPPED
433	14-Mar-19	MYSORE	66	HV2	K_HONNALGERE_66	6:28	6:49	0:20	HAND TRIPPED
434	14-Mar-19	MYSORE	66	K HONNALAGERE-MADDUR	K_HONNALGERE_66	15:42	16:53	1:10	LINE CLEAR AVAILED
435	14-Mar-19	MYSORE	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	11:43	11:50	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
436	14-Mar-19	MYSORE	66	MANDYA-CHIKK MANDYA	CHIKKA_MANDYA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	12:23	13:18	0:55	LINE FAULT
437	14-Mar-19	MYSORE	66	MANDYA-CHIKK MANDYA	CHIKKA_MANDYA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	16:17	16:29	0:12	LINE FAULT
438	14-Mar-19	MYSORE	66	MANDYA-CHIKK MANDYA	CHIKKA_MANDYA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	16:40	16:52	0:11	LINE FAULT
439	14-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	7:50	12:44	4:54	LINE CLEAR AVAILED
440	14-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	17:12	23:59	6:46	LINE CLEAR AVAILED
441	14-Mar-19	MYSORE	66	TARIPURA-TUBINAKERE	TARIPURA_66	3:02	3:15	0:13	LINE FAULT
442	14-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI	7:00	7:08	0:08	LINE FAULT
443	14-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI	7:39	7:51	0:12	LINE FAULT
444	14-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:23	16:06	10:43	LINE CLEAR AVAILED
445	14-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:26	16:09	10:42	LINE CLEAR AVAILED
446	14-Mar-19	TUMKUR	220	NITTUR 220kV- HASSAN	NITTUR_220	10:10	13:07	2:57	LOAD CURTAILMENT
447	14-Mar-19	TUMKUR	110	NITTUR 220kV- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	16:10	18:27	2:17	LINE CLEAR AVAILED
448	14-Mar-19	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	16:10	18:27	2:17	LINE CLEAR AVAILED
449	14-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:48	14:27	4:38	LINE FAULT
450	14-Mar-19	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIEMALLANAHOLE_66	8:36	12:53	4:16	LINE CLEAR AVAILED
451	14-Mar-19	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	6:31	6:45	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
452	14-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	6:33	7:15	0:41	LINE FAULT
453	14-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:22	11:32	1:10	LINE FAULT
454	14-Mar-19	TUMKUR	66	TR-1	BALENAHALLI_66	13:36	14:22	0:45	TRANSFORMER FAULT
455	14-Mar-19	TUMKUR	66	H D PURA- MMCLWINDMILL	MMCLWINDMILL_IPP_66	9:10	15:18	6:07	LINE CLEAR AVAILED
456	14-Mar-19	TUMKUR	66	TR-1	HULIYURDURGA_66	16:17	16:32	0:15	LINE CLEAR AVAILED
457	14-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:12	9:40	0:27	LINE FAULT
458	14-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:18	15:45	0:26	LINE FAULT
459	14-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:21	19:09	0:47	LINE FAULT
460	14-Mar-19	TUMKUR	66	TR-1	LINGADAHALLY_66	17:36	18:45	1:09	LINE CLEAR AVAILED
461	14-Mar-19	TUMKUR	66	TR-2	NAYAKANAHATTI_66	8:31	13:05	4:34	LINE CLEAR AVAILED
462	14-Mar-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	19:19	19:29	0:09	LINE FAULT
463	14-Mar-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:30	12:38	0:08	LINE FAULT
464	14-Mar-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	7:46	14:58	7:11	LINE CLEAR AVAILED
465	14-Mar-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:10	6:19	0:09	LINE FAULT
466	14-Mar-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:09	16:58	2:48	LINE CLEAR AVAILED
467	14-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	8:46	9:03	0:17	HAND TRIPPED
468	15-Mar-19	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	10:35	18:32	7:57	LINE CLEAR AVAILED
469	15-Mar-19	BAGALKOT	220	PONDA 1-AMBEWADI	AMBEWADI_220	12:23	17:09	4:46	LINE FAULT
470	15-Mar-19	BAGALKOT	110	AMBEWADI220-HALIYAL	HALIYAL_110	16:05	16:40	0:35	LINE CLEAR AVAILED
471	15-Mar-19	BAGALKOT	110	AMBEWADI220-HALIYAL	HALIYAL_110	17:36	17:46	0:10	LINE FAULT
472	15-Mar-19	BAGALKOT	110	AMBEWADI220-KAVALAWADA	KAVALAWADA_110	16:41	17:13	0:32	LINE CLEAR AVAILED
473	15-Mar-19	BAGALKOT	110	AMBEWADI220-KAVALAWADA	KAVALAWADA_110	17:37	17:46	0:09	LINE FAULT
474	15-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:00	19:23	19:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
475	15-Mar-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	10:45	19:22	8:37	LINE CLEAR AVAILED
476	15-Mar-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	16:30	18:21	1:51	LINE CLEAR AVAILED
477	15-Mar-19	BAGALKOT	110	ADITYA BIRLA-BELLATTI	BELLATTI_110	2:12	10:02	7:50	LINE CLEAR AVAILED
478	15-Mar-19	BAGALKOT	110	SUZLON-BYADAGI	BYADAGI_110	9:54	11:20	1:26	LINE FAULT
479	15-Mar-19	BAGALKOT	110	110/11KV,HV1	GADAG_110	14:26	14:29	0:03	TRANSFORMER FAULT
480	15-Mar-19	BAGALKOT	110	HUNGUND-ILKAL 1	ILKAL_110	12:35	15:57	3:22	LINE CLEAR AVAILED
481	15-Mar-19	BAGALKOT	110	110/11KV,HV1	BEDI_110	7:34	9:23	1:49	LINE CLEAR AVAILED
482	15-Mar-19	BAGALKOT	110	VADAGOAN-MACHE	MACHE_110	18:28	18:55	0:27	LINE CLEAR AVAILED
483	15-Mar-19	BAGALKOT	110	SIRSI110-KUMTA2	KUMTA_110	21:00	23:59	2:59	LINE FAULT
484	15-Mar-19	BAGALKOT	110	MAHALINGAPUR220-RANNABELAGALI	RANNABELAGALI_110	10:57	15:38	4:41	LINE CLEAR AVAILED
485	15-Mar-19	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	10:30	18:39	8:09	LINE CLEAR AVAILED
486	15-Mar-19	BAGALKOT	110	110/11KV,HV3	RAIBAG_110	21:22	21:27	0:05	TRANSFORMER FAULT
487	15-Mar-19	BAGALKOT	110	110/11KV,HV2	NANADI_110	10:15	12:54	2:39	LINE CLEAR AVAILED
488	15-Mar-19	BAGALKOT	110	MK HUBLI 110-KITTUR	KITTUR_110	11:33	12:21	0:48	LINE CLEAR AVAILED
489	15-Mar-19	BAGALKOT	110	GOPPANKOPPA-MRUTHYNJAY NAGAR	MRUTHYNJAY NAGAR_110	0:00	16:26	16:26	LINE CLEAR AVAILED
490	15-Mar-19	BAGALKOT	110	LAXMESWAR-BELLATTI	BELLATT_110	10:06	13:01	2:55	LINE CLEAR AVAILED
491	15-Mar-19	BAGALKOT	110	110/33KV,HV1	JAMKHANDI_110,HIPPARGI_33KV	14:28	16:00	1:32	LINE CLEAR AVAILED
492	15-Mar-19	BAGALKOT	110	110/11KV,HV3	JAMKHANDI_110	16:47	19:05	2:18	LINE CLEAR AVAILED
493	15-Mar-19	BAGALKOT	110	110/11KV,HV2A(HV2)	JAMKHANDI_110	18:05	18:15	0:10	TRANSFORMER FAULT
494	15-Mar-19	BAGALKOT	66	HOSPET 66-BANUVALLI	BANUVALLI_66	13:04	17:04	4:00	LINE CLEAR AVAILED
495	15-Mar-19	BANGALORE	66	HV1	TAVAREKERE	11:33	12:36	1:03	LINE CLEAR AVAILED
496	15-Mar-19	BANGALORE	66	HV2	TAVAREKERE	12:49	13:37	0:48	LINE CLEAR AVAILED
497	15-Mar-19	BANGALORE	66	TK HALLI 220 - BWSSB 2 (EHT)	BWSSB 2 (EHT)	13:52	14:21	0:28	LINE CLEAR AVAILED
498	15-Mar-19	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	9:15	9:22	0:07	TRANSFORMER FAULT
499	15-Mar-19	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	14:20	14:25	0:05	LINE CLEAR AVAILED
500	15-Mar-19	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	22:49	23:16	0:27	TRANSFORMER FAULT
501	15-Mar-19	BANGALORE	220	HV2	BIDADI 220	16:07	16:15	0:08	TRANSFORMER FAULT
502	15-Mar-19	BANGALORE	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	12:07	12:17	0:09	LOAD CHANGEOVER
503	15-Mar-19	BANGALORE	66	BIDADI 220 - HEJJALA	HEJJALA	12:07	12:17	0:09	LOAD CHANGEOVER
504	15-Mar-19	BANGALORE	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	16:07	16:17	0:10	MAIN SUPPLY FAILURE
505	15-Mar-19	BANGALORE	66	HV1	BIDADI 220	16:07	16:29	0:22	MAIN SUPPLY FAILURE
506	15-Mar-19	BANGALORE	66	HV2	BIDADI 220	16:07	16:24	0:17	MAIN SUPPLY FAILURE
507	15-Mar-19	BANGALORE	66	ADUGODI - HAL 2	K & C VALLEY, NAL (EHT)	11:15	11:31	0:16	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
508	15-Mar-19	BANGALORE	66	HV1	ANEKAL	14:10	15:30	1:20	LINE CLEAR AVAILED
509	15-Mar-19	BANGALORE	66	HV2	ANEKAL	12:20	14:05	1:45	LINE CLEAR AVAILED
510	15-Mar-19	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	2:31	2:36	0:05	LINE FAULT
511	15-Mar-19	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	18:04	18:08	0:04	LINE FAULT
512	15-Mar-19	BANGALORE	66	HV2	GUNDAMGERE	13:15	14:15	1:00	LINE CLEAR AVAILED
513	15-Mar-19	BANGALORE	66	HONNIGANAHALLI - KANAKAPURA 220	HONNIGANAHALLI	12:10	12:40	0:30	LINE CLEAR AVAILED
514	15-Mar-19	BANGALORE	66	HONNIGANAHALLI - HALAGUR	HALAGUR	12:09	12:40	0:30	LINE CLEAR AVAILED
515	15-Mar-19	BANGALORE	66	HV1	KOLAR 220	0:00	0:15	0:15	TRANSFORMER FAULT
516	15-Mar-19	BANGALORE	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	9:15	9:45	0:30	LOAD CURTAILMENT
517	15-Mar-19	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI	12:20	13:35	1:15	LINE CLEAR AVAILED
518	15-Mar-19	GULBARGA	220	BTPSG-LINGAPUR	LINGAPUR_220	11:46	15:05	3:19	LINE FAULT
519	15-Mar-19	GULBARGA	220	RTPS1-SHAHPUR1	SHAHPUR_220	0:00	1:18	1:18	LINE CLEAR AVAILED
520	15-Mar-19	GULBARGA	220	SHAHPUR-LINGASUGUR	SHAHPUR_220	23:14	23:27	0:13	LINE FAULT
521	15-Mar-19	GULBARGA	220	LINGAPUR-JVSL2	LINGAPUR_220	7:21	17:09	9:48	NFBC ISSUED
522	15-Mar-19	GULBARGA	110	HV1	ALIPUR_220	11:42	12:02	0:20	TRANSFORMER FAULT
523	15-Mar-19	GULBARGA	110	HV2	ALIPUR_220	11:42	12:25	0:43	TRANSFORMER FAULT
524	15-Mar-19	GULBARGA	110	HATTI-SOMANMARADI_IPP	HATTI_110	6:10	6:23	0:13	LINE FAULT
525	15-Mar-19	GULBARGA	110	HV2	HATTI_110	14:10	14:23	0:13	LINE CLEAR AVAILED
526	15-Mar-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	5:00	5:11	0:11	LINE FAULT
527	15-Mar-19	GULBARGA	110	HV1	KOLHAR_110	16:00	18:00	2:00	LINE CLEAR AVAILED
528	15-Mar-19	GULBARGA	110	HV2	KOLHAR_110	16:20	18:30	2:10	LINE CLEAR AVAILED
529	15-Mar-19	GULBARGA	110	HV1	KOLHAR_110	18:20	18:35	0:15	LINE CLEAR AVAILED
530	15-Mar-19	GULBARGA	220	BTPSG-LINGAPUR	LINGAPUR_220	11:46	15:05	3:19	LINE FAULT
531	15-Mar-19	GULBARGA	220	RTPS1-SHAHPUR1	SHAHPUR_220	0:00	1:18	1:18	LINE CLEAR AVAILED
532	15-Mar-19	GULBARGA	220	SHAHPUR-LINGASUGUR	SHAHPUR_220	23:14	23:27	0:13	LINE FAULT
533	15-Mar-19	GULBARGA	220	LINGAPUR-JVSL2	LINGAPUR_220	7:21	17:09	9:48	NFBC ISSUED
534	15-Mar-19	GULBARGA	110	HV1	ALIPUR_220	11:42	12:02	0:20	TRANSFORMER FAULT
535	15-Mar-19	GULBARGA	110	HV2	ALIPUR_220	11:42	12:25	0:43	TRANSFORMER FAULT
536	15-Mar-19	GULBARGA	110	HATTI-SOMANMARADI_IPP	HATTI_110	6:10	6:23	0:13	LINE FAULT
537	15-Mar-19	GULBARGA	110	HV2	HATTI_110	14:10	14:23	0:13	LINE CLEAR AVAILED
538	15-Mar-19	GULBARGA	110	SHAHPUR-YADGIR	YADGIR_110	5:00	5:11	0:11	LINE FAULT
539	15-Mar-19	GULBARGA	110	HV1	KOLHAR_110	16:00	18:00	2:00	LINE CLEAR AVAILED
540	15-Mar-19	GULBARGA	110	HV2	KOLHAR_110	16:20	18:30	2:10	LINE CLEAR AVAILED
541	15-Mar-19	GULBARGA	110	HV1	KOLHAR_110	18:20	18:35	0:15	LINE CLEAR AVAILED
542	15-Mar-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	8:31	18:03	9:32	LINE CLEAR AVAILED
543	15-Mar-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	8:03	8:32	0:29	NFBC ISSUED
544	15-Mar-19	HASSAN	110	HV1	KEMAR_220	11:08	15:24	4:16	LINE CLEAR AVAILED
545	15-Mar-19	HASSAN	110	HV1	AJJAMPURA_110	15:23	16:00	0:37	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
546	15-Mar-19	HASSAN	110	HV1	AJJAMPURA_110	16:09	17:08	0:59	LINE CLEAR AVAILED
547	15-Mar-19	HASSAN	110	HV1	GURUVAYANAKERE_110	18:57	19:03	0:06	TRANSFORMER FAULT
548	15-Mar-19	HASSAN	110	HV3	GURUVAYANAKERE_110	18:57	19:03	0:06	TRANSFORMER FAULT
549	15-Mar-19	HASSAN	110	KAVOOR-MRPL	KAVOOR_220	10:31	15:19	4:48	LINE CLEAR AVAILED
550	15-Mar-19	HASSAN	110	HV2	SORABA_110	13:07	14:01	0:54	LINE CLEAR AVAILED
551	15-Mar-19	HASSAN	110	TOGARSI-BALIGAVI	TOGARSI_110	10:10	22:40	12:30	LINE CLEAR AVAILED
552	15-Mar-19	HASSAN	66	HV2	BELUR_6666	14:06	14:12	0:06	TRANSFORMER FAULT
553	15-Mar-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:28	11:48	1:20	NFBC ISSUED
554	15-Mar-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:55	14:40	0:45	NFBC ISSUED
555	15-Mar-19	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	10:28	14:00	3:32	NFBC ISSUED
556	15-Mar-19	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	10:27	14:10	3:43	NFBC ISSUED
557	15-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	7:55	8:30	0:35	MAIN SUPPLY FAILURE
558	15-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	14:05	14:10	0:05	TRANSFORMER FAULT
559	15-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	14:25	14:35	0:10	TRANSFORMER FAULT
560	15-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	14:40	14:50	0:10	TRANSFORMER FAULT
561	15-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	15:25	15:40	0:15	TRANSFORMER FAULT
562	15-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	18:40	18:50	0:10	MAIN SUPPLY FAILURE
563	15-Mar-19	HASSAN	66	HV1	HOLALUR_66	14:47	15:40	0:53	TRANSFORMER FAULT
564	15-Mar-19	HASSAN	66	HV1	HOLALUR_66	16:04	16:29	0:25	TRANSFORMER FAULT
565	15-Mar-19	HASSAN	66	HV1	MATTANAVILE_66	11:52	14:55	3:03	LINE CLEAR AVAILED
566	15-Mar-19	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	10:30	14:09	3:39	LINE CLEAR AVAILED
567	15-Mar-19	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	10:28	14:09	3:41	LINE CLEAR AVAILED
568	15-Mar-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	7:55	8:30	0:35	LINE FAULT
569	15-Mar-19	HASSAN	66	HV2	RAMNATHPURA_66	10:45	18:24	7:39	TRANSFORMER FAULT
570	15-Mar-19	HASSAN	66	HV2	RAMNATHPURA_66	18:33	18:52	0:19	TRANSFORMER FAULT
571	15-Mar-19	HASSAN	66	HV2	RAMNATHPURA_66	19:09	19:29	0:20	TRANSFORMER FAULT
572	15-Mar-19	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	7:55	8:30	0:35	LINE FAULT
573	15-Mar-19	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	7:55	8:30	0:35	LINE FAULT
574	15-Mar-19	MYSORE	66	DB HALLI-TUBINAKERE	DODDABYADARAHALLI_66	10:02	15:09	5:07	LINE CLEAR AVAILED
575	15-Mar-19	MYSORE	66	HV1	ELAVALA_66	10:02	10:18	0:15	TRANSFORMER FAULT
576	15-Mar-19	MYSORE	66	HV1	ELAVALA_66	11:42	13:23	1:40	LINE CLEAR AVAILED
577	15-Mar-19	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KIADBMANDYA_66 K_HONNALGERE_66 MADDUR_66 TUMBEKERE_66	16:08	16:17	0:08	LINE FAULT
578	15-Mar-19	MYSORE	66	HV4	KUSHALNAGARA_220	15:08	17:02	1:53	LINE CLEAR AVAILED
579	15-Mar-19	MYSORE	66	MANDYA-CHIKK MANDYA	CHIKKA_MANDYA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	0:04	0:14	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
580	15-Mar-19	MYSORE	66	MANDYA-CHIKK MANDYA	CHIKKA_MANDYA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 HAMPAPURA_66 KOPPA_66	15:12	15:20	0:07	LINE FAULT
581	15-Mar-19	MYSORE	66	MEGHALAPURA-SFC	THUMLA_66 CHIDRAVALLI_66	6:20	6:30	0:10	LINE FAULT
582	15-Mar-19	MYSORE	66	HV1	PGPALYA_66	12:43	16:17	3:34	LINE CLEAR AVAILED
583	15-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	13:13	21:55	8:41	LINE CLEAR AVAILED
584	15-Mar-19	MYSORE	66	HV1	THALAKADU_66 BGPURA_66 PARINAMIPURA_66	8:01	8:12	0:11	HAND TRIPPED
585	15-Mar-19	MYSORE	66	HV2	THALAKADU_66 BGPURA_66 PARINAMIPURA_66	8:01	8:12	0:11	HAND TRIPPED
586	15-Mar-19	MYSORE	66	VAJAMANGALA-BANNUR	BANNUR_66 KIRUGAVALU_66 MALIYURU_66	15:08	15:24	0:16	LINE FAULT
587	15-Mar-19	TUMKUR	220	THALLAK 220kV- CHITRADURGA	CHITRADURGA_220	5:18	14:26	9:07	LINE CLEAR AVAILED
588	15-Mar-19	TUMKUR	220	NITTUR 220kV- HASSAN(ARASIKERE)	NITTUR_220	11:28	14:05	2:36	LINE CLEAR AVAILED
589	15-Mar-19	TUMKUR	110	TR-3	AMMASANDRA_110	16:08	16:37	0:29	TRANSFORMER FAULT
590	15-Mar-19	TUMKUR	110	TR-1	GUBBI_110	6:20	6:27	0:07	TRANSFORMER FAULT
591	15-Mar-19	TUMKUR	110	TR-1	KALLUR_110	11:44	14:44	2:59	LINE CLEAR AVAILED
592	15-Mar-19	TUMKUR	66	TR-2	HARIYABBE_66	15:39	16:34	0:55	LINE CLEAR AVAILED
593	15-Mar-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	5:05	5:10	0:05	LINE FAULT
594	15-Mar-19	TUMKUR	66	TR-1	KATTIGE_66	15:44	15:49	0:04	HAND TRIPPED
595	15-Mar-19	TUMKUR	66	TR-1	MATHOD_66	15:22	18:08	2:45	LINE CLEAR AVAILED
596	15-Mar-19	TUMKUR	66	PANDARAHALLI- HOLALKERE	PANDARAHALLI_66	16:15	16:51	0:36	LINE FAULT
597	15-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:36	11:22	1:45	LINE FAULT
598	15-Mar-19	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	17:29	17:47	0:17	LINE FAULT
599	15-Mar-19	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	22:21	22:43	0:21	MAIN SUPPLY FAILURE
600	15-Mar-19	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	4:59	5:09	0:10	LINE FAULT
601	16-Mar-19	BAGALKOT	110	110/11KV,HV-1	ANAND NAGAR_110	12:40	17:46	5:06	LINE CLEAR AVAILED
602	16-Mar-19	BAGALKOT	110	110/11KV,HV-1	BAGALKOT_110	12:35	12:44	0:09	LINE CLEAR AVAILED
603	16-Mar-19	BAGALKOT	110	110/11KV,HV-1	BAGALKOT_110	17:05	17:44	0:39	LINE CLEAR AVAILED
604	16-Mar-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	17:05	18:08	1:03	LINE CLEAR AVAILED
605	16-Mar-19	BAGALKOT	110	110/11KV,HV-2	BAGALKOT_110	18:09	18:10	0:01	TRANSFORMER FAULT
606	16-Mar-19	BAGALKOT	110	110/11KV,HV-2	BELGAUM_110	22:11	22:29	0:18	LINE CLEAR AVAILED
607	16-Mar-19	BAGALKOT	220	BELGAUM220-CHIKKODI1	BELGAUM_220	10:11	14:27	4:16	LINE CLEAR AVAILED
608	16-Mar-19	BAGALKOT	220	BELGAUM220-CHIKKODI2	BELGAUM_220	11:55	14:27	2:32	LINE CLEAR AVAILED
609	16-Mar-19	BAGALKOT	110	GADAG ROAD- GOPPANKOPPA	GOPPANKOPPA_110	10:23	10:28	0:05	LINE CLEAR AVAILED
610	16-Mar-19	BAGALKOT	110	GOPPANKOPPA-MRUTYUNJAY NAGAR 1&2	GOPPANKOPPA_110	10:28	10:33	0:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
611	16-Mar-19	BAGALKOT	110	110/33KV,HV2	GANESHGUDI_110,JOIDA_33KV	10:10	11:36	1:26	LINE CLEAR AVAILED
612	16-Mar-19	BAGALKOT	220	DHONI2-GADAG220	GADAG_220	12:20	13:13	0:53	LINE CLEAR AVAILED
613	16-Mar-19	BAGALKOT	110	HAVERI220-HANGAL	HANGAL_110	9:17	9:18	0:01	MAIN SUPPLY FAILURE
614	16-Mar-19	BAGALKOT	110	110/11KV,HV2	KALGATAGI_110	17:45	17:57	0:12	LINE CLEAR AVAILED
615	16-Mar-19	BAGALKOT	220	400/220KV,ICT2	DHONI_400	15:17	16:24	1:07	LINE CLEAR AVAILED
616	16-Mar-19	BAGALKOT	110	110/11KV, HV1	YARAGATTI_110	12:16	12:18	0:02	TRANSFORMER FAULT
617	16-Mar-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TARIHAL_110	10:35	10:38	0:03	LINE CLEAR AVAILED
618	16-Mar-19	BAGALKOT	110	TARIHAL-TADASINKOPPA	TARIHAL_110	17:40	19:31	1:51	LINE CLEAR AVAILED
619	16-Mar-19	BAGALKOT	110	110/33KV, HV1	SOUDATTI_110, CHULKI_33, UDAKERI_33, SUZLON_33,HDMC_33	10:01	18:32	8:31	LINE CLEAR AVAILED
620	16-Mar-19	BAGALKOT	110	110/11KV, HV2	SHIROL_110	14:24	14:59	0:35	LINE CLEAR AVAILED
621	16-Mar-19	BAGALKOT	110	RABKAVI-SATTI	SATTI_110	11:17	16:41	5:24	LINE CLEAR AVAILED
622	16-Mar-19	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	21:01	21:06	0:05	TRANSFORMER FAULT
623	16-Mar-19	BAGALKOT	110	SIRSI-KUMTA 2	KUMTA_110	9:25	13:54	4:29	LINE CLEAR AVAILED
624	16-Mar-19	BAGALKOT	220	HUBLI-NARENDRA 2	HUBLI_220	11:47	17:51	6:04	LINE CLEAR AVAILED
625	16-Mar-19	BAGALKOT	220	220/110KV,HV1&2,LV1&2	HUBLI_220,RAMAKOPPA_110,PH COMPOUND_110,AKSHAY COLONY_110,KADANAKOPPA_11 0,KALAGHATAGI_110	19:11	21:13	2:02	TRANSFORMER FAULT
626	16-Mar-19	BAGALKOT	110	HUBLI220-TARIHAL1	TARIHAL_110	19:11	23:59	4:48	LINE FAULT
627	16-Mar-19	BAGALKOT	110	HUBLI220-ANDANAGAR	ANAND NAGAR_110	19:29	19:33	0:04	HAND TRIPPED
628	16-Mar-19	BAGALKOT	110	HUBLI220-TARIHAL2	TARIHAL_110	23:45	23:59	0:14	LINE FAULT
629	16-Mar-19	BAGALKOT	110	110/33KV, HV1	HUBLI_220,LAXMESHWAR_33	19:36	19:44	0:08	HAND TRIPPED
630	16-Mar-19	BAGALKOT	110	110/33KV, HV2	HUBLI_220,MURAGOD_33,INDUS TRIAL ESTATE_33	19:38	19:44	0:06	HAND TRIPPED
631	16-Mar-19	BAGALKOT	110	110/11KV, HV3	HUBLI_220	19:42	19:50	0:08	HAND TRIPPED
632	16-Mar-19	BAGALKOT	110	110/11KV, HV4	HUBLI_220	19:42	19:47	0:05	HAND TRIPPED
633	16-Mar-19	BAGALKOT	220	220/110KV,HV2,LV2	NARENDRA_220	10:50	18:46	7:56	LINE CLEAR AVAILED
634	16-Mar-19	BAGALKOT	110	NARENDRA220-KUD DHARAWAD 1	KUD DHARAWAD_110	10:46	17:34	6:48	LINE CLEAR AVAILED
635	16-Mar-19	BAGALKOT	110	110/11KV, HV2	MUKARTHAL_110	6:23	7:50	1:27	LINE CLEAR AVAILED
636	16-Mar-19	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANAKOPPA 1&2	GOPANAKOPPA_110	10:29	23:59	13:30	LINE CLEAR AVAILED
637	16-Mar-19	BAGALKOT	66	HONNALLI-HARIHAR HOSPET	HARIHAR HOSPET_66	10:30	13:11	2:41	LINE CLEAR AVAILED
638	16-Mar-19	BAGALKOT	66	DAVANAGERE-HARIHAR HOSPET	HARIHAR HOSPET_66	13:11	23:59	10:48	LINE CLEAR AVAILED
639	16-Mar-19	BANGALORE	66	HV1	SHAMRAJ TECH PARK	11:20	11:25	0:04	LINE CLEAR AVAILED
640	16-Mar-19	BANGALORE	66	HV2	SHAMRAJ TECH PARK	12:14	12:20	0:05	LINE CLEAR AVAILED
641	16-Mar-19	BANGALORE	66	HV3	SHAMRAJ TECH PARK	10:10	10:15	0:05	LINE CLEAR AVAILED
642	16-Mar-19	BANGALORE	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	21:13	21:19	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
643	16-Mar-19	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	15:25	18:08	2:42	LINE FAULT
644	16-Mar-19	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	17:00	17:51	0:50	LINE CLEAR AVAILED
645	16-Mar-19	BANGALORE	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD, JIGANI 66	6:35	7:55	1:20	LINE FAULT
646	16-Mar-19	BANGALORE	66	AUSTIN TOWN - KORMANGALA	KORMANGALA	6:17	6:57	0:39	LINE FAULT
647	16-Mar-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	5:57	6:05	0:08	LINE FAULT
648	16-Mar-19	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	6:35	6:55	0:20	LINE FAULT
649	16-Mar-19	BANGALORE	66	HV1	PRESTIGE SHANTHINIKETHAN	13:10	13:50	0:40	LINE CLEAR AVAILED
650	16-Mar-19	BANGALORE	66	HV2	BANGARPET	13:54	14:34	0:40	LINE CLEAR AVAILED
651	16-Mar-19	BANGALORE	66	HV2	KIADB DB PURA 220	2:08	2:30	0:21	TRANSFORMER FAULT
652	16-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	16:36	17:52	1:15	LINE CLEAR AVAILED
653	16-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:36	17:53	1:17	LINE CLEAR AVAILED
654	16-Mar-19	GULBARGA	220	HV2	KUSTAGI_220	13:05	13:40	0:35	TRANSFORMER FAULT
655	16-Mar-19	GULBARGA	220	HV1	SEDAM_220	10:40	12:30	1:50	LINE CLEAR AVAILED
656	16-Mar-19	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	6:16	6:23	0:07	LINE FAULT
657	16-Mar-19	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	13:12	13:40	0:28	MAIN SUPPLY FAILURE
658	16-Mar-19	GULBARGA	110	LV1	RAICHUR_220	10:50	11:07	0:17	HAND TRIPPED
659	16-Mar-19	GULBARGA	110	HV2	RAICHUR_220	10:02	10:07	0:05	TRANSFORMER FAULT
660	16-Mar-19	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICKSUGUR_110,SH AKTINAGAR_110	8:14	11:24	3:10	LINE CLEAR AVAILED
661	16-Mar-19	GULBARGA	110	GURGUNTA-LJVL_IPP	GURGUNTA_110	18:16	23:59	5:43	LINE CLEAR AVAILED
662	16-Mar-19	GULBARGA	110	GURGUNTA-KHEL_IPP	GURGUNTA_110	18:07	23:59	5:52	LINE CLEAR AVAILED
663	16-Mar-19	GULBARGA	66	KOGALI-ATRSOLR	KOGALI_66	12:54	13:48	0:54	HAND TRIPPED
664	16-Mar-19	HASSAN	220	HASSN22-ARAKALGUD1	HASSAN_220	6:32	6:44	0:12	LINE FAULT
665	16-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:15	13:02	0:47	LINE CLEAR AVAILED
666	16-Mar-19	HASSAN	110	HV2	SORABA_110	13:51	14:47	0:56	LINE CLEAR AVAILED
667	16-Mar-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	10:39	16:46	6:07	LINE CLEAR AVAILED
668	16-Mar-19	HASSAN	110	SAGARA-ALKLA	SAGARA_110	15:45	16:03	0:18	LINE CLEAR AVAILED
669	16-Mar-19	HASSAN	66	HASSN22-HN PURA	HASSAN_220	2:30	2:40	0:10	LINE FAULT
670	16-Mar-19	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	8:12	8:18	0:06	LINE FAULT
671	16-Mar-19	HASSAN	66	GORUR-HASSAN	GORUR_66	6:43	6:46	0:03	MAIN SUPPLY FAILURE
672	16-Mar-19	HASSAN	66	HV1	HOLALUR_66	16:39	17:52	1:13	TRANSFORMER FAULT
673	16-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:18	9:01	0:43	HAND TRIPPED
674	16-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	21:08	21:18	0:10	LINE FAULT
675	16-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	21:43	21:57	0:14	LINE FAULT
676	16-Mar-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	13:45	15:28	1:43	LINE CLEAR AVAILED
677	16-Mar-19	HASSAN	66	HV2	RAMNATHPURA_66	0:51	1:11	0:20	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
678	16-Mar-19	HASSAN	66	HV2	RAMNATHPURA_66	10:38	11:13	0:35	LINE CLEAR AVAILED
679	16-Mar-19	HASSAN	66	HV2	RAMNATHPURA_66	13:06	17:00	3:54	TRANSFORMER FAULT
680	16-Mar-19	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	13:45	15:26	1:41	LINE CLEAR AVAILED
681	16-Mar-19	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	13:45	15:26	1:41	LINE CLEAR AVAILED
682	16-Mar-19	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	8:17	14:49	6:32	LINE CLEAR AVAILED
683	16-Mar-19	HASSAN	66	HV1	SINGAPURA_66	8:17	14:49	6:32	LINE CLEAR AVAILED
684	16-Mar-19	HASSAN	66	HV2	SINGAPURA_66	8:17	14:50	6:33	LINE CLEAR AVAILED
685	16-Mar-19	HASSAN	66	HV2	SINGAPURA_66	21:02	21:08	0:06	TRANSFORMER FAULT
686	16-Mar-19	HASSAN	66	HV2	BELUR_66	14:55	15:02	0:07	TRANSFORMER FAULT
687	16-Mar-19	HASSAN	66	HV2	BELUR_66	15:15	15:25	0:10	TRANSFORMER FAULT
688	16-Mar-19	HASSAN	66	HV2	BELUR_66	23:06	23:13	0:07	TRANSFORMER FAULT
689	16-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	11:56	18:20	6:24	LINE CLEAR AVAILED
690	16-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	19:22	19:31	0:09	TRANSFORMER FAULT
691	16-Mar-19	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	12:27	16:15	3:48	LINE CLEAR AVAILED
692	16-Mar-19	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:29	16:20	3:51	NFBC ISSUED
693	16-Mar-19	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	12:28	16:18	3:50	NFBC ISSUED
694	16-Mar-19	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	12:15	13:02	0:47	NFBC ISSUED
695	16-Mar-19	MYSORE	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	8:01	8:10	0:08	LINE FAULT
696	16-Mar-19	MYSORE	66	G UKKADA-TUBINAKERE	GARUDANAUKADDA_66 SRIRANGAPATNA_66	6:27	6:35	0:08	LINE FAULT
697	16-Mar-19	MYSORE	66	MIRLE-KR NAGARA	MIRLE_66	12:19	12:25	0:05	LINE CLEAR AVAILED
698	16-Mar-19	MYSORE	66	PANNYADAHUNDI-HEMMARGALA	KARYA_66	10:50	16:56	6:06	LINE CLEAR AVAILED
699	16-Mar-19	MYSORE	66	HV2	SALIGRAMA_66	17:37	17:43	0:06	TRANSFORMER FAULT
700	16-Mar-19	MYSORE	66	HV1	SANTHESARAGUR_66	9:16	9:28	0:11	TRANSFORMER FAULT
701	16-Mar-19	MYSORE	66	HV1	SANTHESARAGUR_66	12:00	12:06	0:05	TRANSFORMER FAULT
702	16-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	9:05	20:55	11:50	LINE CLEAR AVAILED
703	16-Mar-19	MYSORE	220	HV1	TUBINAKERE_220	14:09	14:16	0:06	TRANSFORMER FAULT
704	16-Mar-19	MYSORE	66	HV2	TUBINAKERE_220	14:12	14:22	0:09	HAND TRIPPED
705	16-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADICHUNCHANAGIRI_66 ADDIHALLI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	7:41	7:47	0:05	LINE FAULT
706	16-Mar-19	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	4:59	5:09	0:10	LINE FAULT
707	16-Mar-19	TUMKUR	220	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	5:20	14:24	9:04	LINE CLEAR AVAILED
708	16-Mar-19	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	7:10	17:53	10:43	LINE CLEAR AVAILED
709	16-Mar-19	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	17:40	17:53	0:12	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
710	16-Mar-19	TUMKUR	220	ANTHRASANAHALLI 220KV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	17:42	17:53	0:10	HAND TRIPPED
711	16-Mar-19	TUMKUR	66	TR-1	MADHUGIRI_220	16:23	17:49	1:25	LINE CLEAR AVAILED
712	16-Mar-19	TUMKUR	66	ANCHEPALYA 220KV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	6:13	6:24	0:10	LINE FAULT
713	16-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66	17:40	17:54	0:14	HAND TRIPPED
714	16-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	17:40	17:54	0:14	HAND TRIPPED
715	16-Mar-19	TUMKUR	66	TR-1 & TR-2	ANTHRASANAHALLI_220	7:10	17:53	10:43	LINE CLEAR AVAILED
716	16-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	7:09	7:19	0:10	HAND TRIPPED
717	16-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	17:40	17:54	0:14	HAND TRIPPED
718	16-Mar-19	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	17:40	17:54	0:13	HAND TRIPPED
719	16-Mar-19	TUMKUR	66	TR-2	BENKIKERE_66	16:07	16:26	0:18	TRANSFORMER FAULT
720	16-Mar-19	TUMKUR	66	TR-1	BHARAMASAGARA_66	11:24	13:47	2:22	LINE CLEAR AVAILED
721	16-Mar-19	TUMKUR	66	TR-2	CHIKKABANAGERE_66	11:20	12:30	1:10	LINE CLEAR AVAILED
722	16-Mar-19	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	9:21	9:34	0:12	LINE FAULT
723	16-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:36	18:09	10:33	LINE CLEAR AVAILED
724	16-Mar-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:25	13:08	2:42	LINE CLEAR AVAILED
725	16-Mar-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	10:25	12:26	2:00	LINE CLEAR AVAILED
726	16-Mar-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	13:51	13:53	0:01	MAIN SUPPLY FAILURE
727	16-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:45	12:55	0:10	LINE FAULT
728	16-Mar-19	TUMKUR	66	TR-1	MATHOD_66	0:01	0:03	0:02	TRANSFORMER FAULT
729	16-Mar-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:37	11:44	2:07	LINE FAULT
730	17-Mar-19	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	15:23	23:59	8:36	LINE CLEAR AVAILED
731	17-Mar-19	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	15:26	21:28	6:02	LINE CLEAR AVAILED
732	17-Mar-19	BAGALKOT	110	110/11KV,HV-1	ANAND NAGAR_110	10:26	17:41	7:15	LINE CLEAR AVAILED
733	17-Mar-19	BAGALKOT	220	BELGAUM220-CHICKKODI1 & 2	BELGAUM_220	8:59	11:33	2:34	LINE CLEAR AVAILED
734	17-Mar-19	BAGALKOT	220	BELGAUM220-NARENDRA1	BELGAUM_220	11:33	20:57	9:24	LINE CLEAR AVAILED
735	17-Mar-19	BAGALKOT	220	BELGAUM220-NARENDRA2	BELGAUM_220	9:03	20:57	11:54	LINE CLEAR AVAILED
736	17-Mar-19	BAGALKOT	220	220/110KV,HV1,LV1	BELGAUM_220	10:25	20:31	10:06	LINE CLEAR AVAILED
737	17-Mar-19	BAGALKOT	110	110/33KV,HV2	HANGAL_110	7:53	8:03	0:10	TRANSFORMER FAULT
738	17-Mar-19	BAGALKOT	110	110/33KV,HV2	HANGAL_110	10:49	11:03	0:14	TRANSFORMER FAULT
739	17-Mar-19	BAGALKOT	220	MK HUBLI220-MK HUBLI110	MK HUBLI_220	14:08	20:27	6:19	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
740	17-Mar-19	BAGALKOT	220	MK HUBLI220-NARENDRA1	MK HUBLI_220	7:29	14:04	6:35	LINE CLEAR AVAILED
741	17-Mar-19	BAGALKOT	220	MK HUBLI220-NARENDRA2	MK HUBLI_220	7:29	13:58	6:29	LINE CLEAR AVAILED
742	17-Mar-19	BAGALKOT	220	220/110KV,HV1,LV1	MK HUBLI_220	7:30	14:34	7:04	LINE CLEAR AVAILED
743	17-Mar-19	BAGALKOT	220	220/110KV,LV2	MK HUBLI_220	7:23	14:33	7:10	LINE CLEAR AVAILED
744	17-Mar-19	BAGALKOT	110	MK HUBLI220-BIDI	BIDI_110	14:26	17:15	2:49	LINE CLEAR AVAILED
745	17-Mar-19	BAGALKOT	110	MK HUBLI220-BAILHONGAL	BAILHONGAL_110	14:26	14:55	0:29	LINE CLEAR AVAILED
746	17-Mar-19	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	14:26	14:57	0:31	LINE CLEAR AVAILED
747	17-Mar-19	BAGALKOT	110	MK HUBLI220-KHANAPUR	KHANAPUR_110	14:26	15:00	0:34	LINE CLEAR AVAILED
748	17-Mar-19	BAGALKOT	110	110/11KV, HV1	UDYAMBAG_110	9:34	15:56	6:22	LINE CLEAR AVAILED
749	17-Mar-19	BAGALKOT	110	SHIRGUPPI-BILAGI	BILAGI_110	19:57	19:58	0:01	LINE FAULT
750	17-Mar-19	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	20:46	20:52	0:06	TRANSFORMER FAULT
751	17-Mar-19	BAGALKOT	110	HUBLI220-TARIHAL2	TARIHAL_110	0:00	3:19	3:19	LINE CLEAR AVAILED
752	17-Mar-19	BAGALKOT	110	HUBLI220-TARIHAL1	TARIHAL_110	0:00	3:12	3:12	LINE CLEAR AVAILED
753	17-Mar-19	BANGALORE	66	HV2	ABBIGERE	8:04	8:16	0:11	TRANSFORMER FAULT
754	17-Mar-19	BANGALORE	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	6:01	6:33	0:31	MAIN SUPPLY FAILURE
755	17-Mar-19	BANGALORE	66	A STATION 220 - A STATION 1	A STATION 66	6:01	6:33	0:31	MAIN SUPPLY FAILURE
756	17-Mar-19	BANGALORE	66	A STATION 220 - A STATION 2	A STATION 66	6:01	6:33	0:31	MAIN SUPPLY FAILURE
757	17-Mar-19	BANGALORE	66	A STATION 220 - VICTORIA	VICTORIA	6:01	6:33	0:31	MAIN SUPPLY FAILURE
758	17-Mar-19	BANGALORE	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	10:44	10:55	0:11	MAIN SUPPLY FAILURE
759	17-Mar-19	BANGALORE	66	A STATION 220 - A STATION 1	A STATION 66	10:44	10:51	0:07	MAIN SUPPLY FAILURE
760	17-Mar-19	BANGALORE	66	A STATION 220 - A STATION 2	A STATION 66	10:44	10:51	0:07	MAIN SUPPLY FAILURE
761	17-Mar-19	BANGALORE	66	A STATION 220 - VICTORIA	VICTORIA	10:44	10:58	0:14	MAIN SUPPLY FAILURE
762	17-Mar-19	BANGALORE	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	11:12	11:55	0:42	MAIN SUPPLY FAILURE
763	17-Mar-19	BANGALORE	66	A STATION 220 - A STATION 1	A STATION 66	11:12	11:26	0:13	MAIN SUPPLY FAILURE
764	17-Mar-19	BANGALORE	66	A STATION 220 - A STATION 2	A STATION 66	11:12	11:30	0:17	MAIN SUPPLY FAILURE
765	17-Mar-19	BANGALORE	66	A STATION 220 - VICTORIA	VICTORIA	11:12	11:55	0:42	MAIN SUPPLY FAILURE
766	17-Mar-19	BANGALORE	66	A STATION 220 - KANTEERAVA STADIUM	KANTEERAVA STADIUM	12:33	12:39	0:06	MAIN SUPPLY FAILURE
767	17-Mar-19	BANGALORE	66	A STATION 220 - A STATION 1	A STATION 66	12:25	12:49	0:24	MAIN SUPPLY FAILURE
768	17-Mar-19	BANGALORE	66	A STATION 220 - A STATION 2	A STATION 66	12:33	12:39	0:06	MAIN SUPPLY FAILURE
769	17-Mar-19	BANGALORE	220	A STATION 220 - NRS 220	A STATION 220	6:01	6:40	0:38	MAIN SUPPLY FAILURE
770	17-Mar-19	BANGALORE	220	A STATION 220 - NRS 220	A STATION 220	11:12	11:30	0:17	MAIN SUPPLY FAILURE
771	17-Mar-19	BANGALORE	220	BUS COUPLER	A STATION 220	12:33	12:39	0:06	LOAD CHANGE OVER
772	17-Mar-19	BANGALORE	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	7:11	7:20	0:08	LOAD CHANGE OVER
773	17-Mar-19	BANGALORE	66	BANASHANKARI - AREHALLI	BANASHANKARI	13:14	13:19	0:04	LOAD CHANGE OVER
774	17-Mar-19	BANGALORE	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	4:15	4:18	0:03	LOAD CHANGE OVER
775	17-Mar-19	BANGALORE	66	RMV - HEBBAL 20	RMV, TATA INSTITUTE (EHT)	14:16	14:20	0:04	LOAD CHANGE OVER
776	17-Mar-19	BANGALORE	66	HV2	BRINDAVAN	16:01	17:40	1:38	LINE CLEAR AVAILED
777	17-Mar-19	BANGALORE	220	HSR LAYOUT 220 - NIMHANS 220	NIMHANS 220, EDC 220, A STATION 220	10:44	10:59	0:15	LINE FAULT
778	17-Mar-19	BANGALORE	220	HV1	NIMHANS 220	10:44	11:03	0:19	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
779	17-Mar-19	BANGALORE	220	HV2	NIMHANS 220	10:44	11:04	0:20	MAIN SUPPLY FAILURE
780	17-Mar-19	BANGALORE	220	HV1	EDC 220	10:44	11:10	0:26	MAIN SUPPLY FAILURE
781	17-Mar-19	BANGALORE	220	HV2	EDC 220	10:44	11:11	0:27	MAIN SUPPLY FAILURE
782	17-Mar-19	BANGALORE	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	10:44	11:17	0:33	MAIN SUPPLY FAILURE
783	17-Mar-19	BANGALORE	66	EDC 220 - BMTC	BMTC	10:44	11:18	0:34	MAIN SUPPLY FAILURE
784	17-Mar-19	BANGALORE	66	HV1	EDC 220	10:44	11:20	0:36	MAIN SUPPLY FAILURE
785	17-Mar-19	BANGALORE	66	HV2	EDC 220	10:44	11:13	0:29	MAIN SUPPLY FAILURE
786	17-Mar-19	BANGALORE	220	BIDADI 220 - RAILWAYS (EHT)	RAILWAYS (EHT)	16:20	16:49	0:28	LINE FAULT
787	17-Mar-19	BANGALORE	66	NIMHANS 220 - JAYANAGARA	JAYANAGARA, NATIONAL COLLEGE, PADMANABHA NAGARA	10:44	11:03	0:19	MAIN SUPPLY FAILURE
788	17-Mar-19	BANGALORE	66	NIMHANS 220 - JAYADEVA	JAYADEVA, SARAKKI, ISRO LAYOUT	10:44	11:05	0:21	MAIN SUPPLY FAILURE
789	17-Mar-19	BANGALORE	66	NIMHANS 220 - ADUGODI	ADUGODI, BOSCH (EHT), K & C VALLEY, NAL (EHT)	10:44	11:08	0:24	MAIN SUPPLY FAILURE
790	17-Mar-19	BANGALORE	66	HV3	ADUGODI	9:20	9:30	0:10	LOAD CHANGEOVER
791	17-Mar-19	BANGALORE	66	HV1	NELEKADRINAHALLI	9:20	9:25	0:05	LINE CLEAR AVAILED
792	17-Mar-19	BANGALORE	66	MATHIKERE - GOKULA	MATHIKERE	4:25	4:30	0:05	LOAD CHANGEOVER
793	17-Mar-19	BANGALORE	66	MATHIKERE - HEBBAL 220	MATHIKERE	10:53	10:58	0:05	LOAD CHANGEOVER
794	17-Mar-19	BANGALORE	66	SARAKKI - JAYADEVA	SARAKKI	20:15	20:25	0:10	LOAD CHANGEOVER
795	17-Mar-19	BANGALORE	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	9:50	10:03	0:13	LOAD CHANGEOVER
796	17-Mar-19	BANGALORE	66	ISRO LAYOUT - SARAKKI	ISRO LAYOUT	20:10	20:20	0:09	LOAD CHANGEOVER
797	17-Mar-19	BANGALORE	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	10:13	10:20	0:06	LOAD CHANGEOVER
798	17-Mar-19	BANGALORE	66	HV2	HOODY 220	10:44	11:50	1:05	TRANSFORMER FAULT
799	17-Mar-19	BANGALORE	66	HV2	HOODY 220	16:28	16:36	0:08	LINE CLEAR AVAILED
800	17-Mar-19	BANGALORE	66	ELECTRONIC CITY P2 S1 - ELECTRONIC CITY	ELECTRONIC CITY P2 S1	11:04	11:09	0:04	LOAD CHANGEOVER
801	17-Mar-19	BANGALORE	66	HV1	NRS 220	11:12	13:21	2:08	MAIN SUPPLY FAILURE
802	17-Mar-19	BANGALORE	66	HV3	NRS 220	11:12	12:37	1:24	MAIN SUPPLY FAILURE
803	17-Mar-19	BANGALORE	66	HV4	NRS 220	11:12	12:36	1:24	MAIN SUPPLY FAILURE
804	17-Mar-19	BANGALORE	66	HV5	NRS 220	11:12	12:36	1:24	MAIN SUPPLY FAILURE
805	17-Mar-19	BANGALORE	66	VRISHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRALAYOUT	11:12	12:06	0:53	MAIN SUPPLY FAILURE
806	17-Mar-19	BANGALORE	66	NRS 220 - MYSORE ROAD 2	VIJAYANAGARA	11:12	12:37	1:24	MAIN SUPPLY FAILURE
807	17-Mar-19	BANGALORE	66	NRS 220 - TELECOM LAYOUT	TELECOM	11:12	12:36	1:23	MAIN SUPPLY FAILURE
808	17-Mar-19	BANGALORE	220	HV1	NRS 220	11:38	12:32	0:54	TRANSFORMER FAULT
809	17-Mar-19	BANGALORE	220	HV2	NRS 220	11:38	12:32	0:54	TRANSFORMER FAULT
810	17-Mar-19	BANGALORE	220	NRS 220 - SRS PEENYA 220	NRS 220	11:38	12:25	0:47	LINE FAULT
811	17-Mar-19	BANGALORE	220	NRS 220 - SRS PEENYA 220	NRS 220	6:01	6:40	0:38	MAIN SUPPLY FAILURE
812	17-Mar-19	BANGALORE	220	NRS 220 - VRISHBHAVATHI 220	NRS 220	11:12	12:25	1:12	MAIN SUPPLY FAILURE
813	17-Mar-19	BANGALORE	66	VRISHBHAVATHI 220 - REMCO	REMCO	11:12	12:01	0:48	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
814	17-Mar-19	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	4:56	5:14	0:17	LINE FAULT
815	17-Mar-19	BANGALORE	66	SRS PEENYA 220 - NANDINI LAYOUT	NANDINI LAYOUT	5:52	5:54	0:01	LOAD CHANGEOVER
816	17-Mar-19	BANGALORE	66	SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	5:52	5:54	0:01	LOAD CHANGEOVER
817	17-Mar-19	BANGALORE	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	5:52	5:54	0:01	LOAD CHANGEOVER
818	17-Mar-19	BANGALORE	220	SRS PEENYA 220 - NELAMANGALA 4	SRS PEENYA 220	6:13	6:22	0:09	LINE FAULT
819	17-Mar-19	BANGALORE	220	SRS PEENYA 220 - NELAMANGALA 2	SRS PEENYA 220	6:33	6:34	0:01	LOAD CHANGEOVER
820	17-Mar-19	BANGALORE	220	SRS PEENYA 220 - NELAMANGALA 3	SRS PEENYA 220	6:42	6:50	0:08	LOAD CHANGEOVER
821	17-Mar-19	BANGALORE	66	HV1	SRS PEENYA 220	5:40	5:43	0:03	LOAD CHANGEOVER
822	17-Mar-19	BANGALORE	66	SRS PEENTA 220 - DG3	WELCAST STEEL	5:40	5:43	0:03	LOAD CHANGEOVER
823	17-Mar-19	BANGALORE	220	VRISHBHAVATHI 220 - TATAGUNI (EHT)	VRISHBHAVATHI 220	11:12	11:48	0:36	MAIN SUPPLY FAILURE
824	17-Mar-19	BANGALORE	220	HV1	VRISHBHAVATHI 220	11:12	11:55	0:42	MAIN SUPPLY FAILURE
825	17-Mar-19	BANGALORE	220	HV2	VRISHBHAVATHI 220	11:12	11:50	0:37	MAIN SUPPLY FAILURE
826	17-Mar-19	BANGALORE	66	VRISHBHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	11:12	11:51	0:38	MAIN SUPPLY FAILURE
827	17-Mar-19	BANGALORE	66	AKKURMOLE - TK HALLI 220	AKKURMOLE	5:12	5:20	0:07	LINE FAULT
828	17-Mar-19	BANGALORE	66	HV2	BAGEPALLI	21:20	22:35	1:15	TRANSFORMER FAULT
829	17-Mar-19	BANGALORE	66	HV1	CHAKAVELU	1:25	2:20	0:54	TRANSFORMER FAULT
830	17-Mar-19	BANGALORE	66	HV2	CHANDAPURA	10:55	11:10	0:14	TRANSFORMER FAULT
831	17-Mar-19	BANGALORE	66	HV2	CHANDAPURA	16:07	17:08	1:01	TRANSFORMER FAULT
832	17-Mar-19	BANGALORE	66	HV2	DODDABELAVANGALA	10:41	10:50	0:09	TRANSFORMER FAULT
833	17-Mar-19	BANGALORE	220	LV2	MALUR 220	13:50	14:30	0:40	TRANSFORMER FAULT
834	17-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	20:44	21:01	0:16	LINE FAULT
835	17-Mar-19	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	13:50	14:30	0:40	MAIN SUPPLY FAILURE
836	17-Mar-19	BANGALORE	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	13:50	14:35	0:45	MAIN SUPPLY FAILURE
837	17-Mar-19	BANGALORE	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:50	14:35	0:45	MAIN SUPPLY FAILURE
838	17-Mar-19	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	11:45	11:55	0:10	LOAD CHANGEOVER
839	17-Mar-19	BANGALORE	66	JIGANI 220 - JIGANI 66	JIGANI 66	15:05	15:14	0:09	LOAD CHANGEOVER
840	17-Mar-19	BANGALORE	66	HV1	JIGANI 220	11:45	11:55	0:10	LOAD CHANGEOVER
841	17-Mar-19	BANGALORE	66	HV1	JIGANI 220	15:05	15:14	0:09	LOAD CHANGEOVER
842	17-Mar-19	BANGALORE	66	HV2	JIGANI 220	11:45	11:55	0:10	LOAD CHANGEOVER
843	17-Mar-19	BANGALORE	66	HV2	JIGANI 220	15:05	15:14	0:09	LOAD CHANGEOVER
844	17-Mar-19	BANGALORE	66	HV1	KANAKAPURA 66	18:00	18:10	0:10	LINE CLEAR AVAILED
845	17-Mar-19	GULBARGA	110	HV1	HATTI_110	21:22	21:47	0:25	TRANSFORMER FAULT
846	17-Mar-19	GULBARGA	110	HV1	SIRWAR_110	8:20	8:35	0:15	TRANSFORMER FAULT
847	17-Mar-19	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	6:36	6:43	0:07	TRANSFORMER FAULT
848	17-Mar-19	HASSAN	220	HASSN22-Shomoga	HASSAN_220	5:38	6:06	0:28	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
849	17-Mar-19	HASSAN	220	HASSN22-Shomoga	HASSAN_220	6:18	6:26	0:08	LINE CLEAR AVAILED
850	17-Mar-19	HASSAN	110	HV2	MSEZ_220	11:53	13:09	1:16	LINE CLEAR AVAILED
851	17-Mar-19	HASSAN	110	HV3	BAIKAMPADY_110	12:34	14:20	1:46	LINE CLEAR AVAILED
852	17-Mar-19	HASSAN	110	HV4	BAIKAMPADY_110	12:19	14:22	2:03	LINE CLEAR AVAILED
853	17-Mar-19	HASSAN	110	HV1	KITTADAHALLY_110	19:27	19:49	0:22	TRANSFORMER FAULT
854	17-Mar-19	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA-220	13:35	13:44	0:09	LINE FAULT
855	17-Mar-19	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLI_66	14:29	15:51	1:22	LINE FAULT
856	17-Mar-19	HASSAN	66	HV1	DODDAKADANUR_66	10:33	10:44	0:11	TRANSFORMER FAULT
857	17-Mar-19	MYSORE	66	KADAKOLA-THANDYA	THANDYA_66	9:59	17:14	7:14	NFBC ISSUED
858	17-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 2	HURA_66, HULLAHALLI_66, DOORA_66	9:16	9:22	0:05	LINE FAULT
859	17-Mar-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	9:17	9:22	0:05	LINE FAULT
860	17-Mar-19	MYSORE	66	HV2	KIRUGAVALU_66	23:03	23:10	0:06	TRANSFORMER FAULT
861	17-Mar-19	MYSORE	66	MADHUVANAHALLI-HANNUR 1	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	11:21	18:05	6:43	NFBC ISSUED
862	17-Mar-19	MYSORE	66	MADHUVANAHALLI-HANNUR 2	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	11:21	18:05	6:43	NFBC ISSUED
863	17-Mar-19	MYSORE	66	LV1	MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66 SATHEGALA_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 MADHUVANAHALLI_220	6:09	6:30	0:20	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
864	17-Mar-19	MYSORE	66	LV2	MARTAHALLI_66 DODDINADUVADI_66 HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 PGPALYA_66 SATHEGALA_66 THALAKADU_66 BGPURA_66 PARINAMIPURA_66 MADHUVANAHALLI_220	6:09	6:30	0:20	TRANSFORMER FAULT
865	17-Mar-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	11:00	16:13	5:12	NFBC ISSUED
866	17-Mar-19	MYSORE	66	MADHUVANAHALLI-DODDINADUVADI	DODDINADUVADI_66	14:20	15:49	1:29	NFBC ISSUED
867	17-Mar-19	MYSORE	66	HV1	NANJANGUDU_66	8:32	9:29	0:56	LINE CLEAR AVAILED
868	17-Mar-19	MYSORE	66	NANJANGUDU-HV2	NANJANGUDU_66	8:30	9:29	0:59	LINE CLEAR AVAILED
869	17-Mar-19	MYSORE	66	NANJANGUDU-THANDYA	THANDYA_66	10:05	17:24	7:19	NFBC ISSUED
870	17-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	6:07	23:59	17:51	LINE CLEAR AVAILED
871	17-Mar-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADICHUNCHANAGIRI_66 ADDIHALLI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 SHIVALLY_66 VADERALLI_66	7:34	7:40	0:06	LINE FAULT
872	17-Mar-19	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 2	MADHUGIRI 220kV	18:02	18:18	0:15	LINE FAULT
873	17-Mar-19	TUMKUR	220	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	5:18	19:34	14:16	LINE CLEAR AVAILED
874	17-Mar-19	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:54	13:57	0:03	MAIN SUPPLY FAILURE
875	17-Mar-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	5:18	19:35	14:17	MAIN SUPPLY FAILURE
876	17-Mar-19	TUMKUR	220	TR-2	DAVANGERE_SRS_220	15:56	18:07	2:11	LINE CLEAR AVAILED
877	17-Mar-19	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	13:25	13:55	0:30	LINE FAULT
878	17-Mar-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	7:47	18:11	10:24	LINE CLEAR AVAILED
879	17-Mar-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	6:06	6:15	0:09	LINE FAULT
880	17-Mar-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	9:02	9:10	0:08	LINE FAULT
881	17-Mar-19	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	9:02	9:10	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
882	17-Mar-19	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR_IPP_66	TATA SOLAR_IPP_66	12:41	13:18	0:36	MAIN SUPPLY FAILURE
883	17-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:31	6:46	0:14	LINE FAULT
884	17-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:57	9:10	0:13	LINE FAULT
885	17-Mar-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:04	18:18	0:13	LINE FAULT
886	17-Mar-19	TUMKUR	66	TR-1	MADHUGIRI_220	16:23	17:49	1:25	LINE CLEAR AVAILED
887	17-Mar-19	TUMKUR	66	SHYLAPURA-PR PURA	YNHOSKOTE_66, MANGALWADA_66,LINGDHALLI_66	9:11	9:37	0:25	MAIN SUPPLY FAILURE
888	17-Mar-19	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	8:02	8:49	0:47	LINE CLEAR AVAILED
889	17-Mar-19	TUMKUR	66	TR-1	SAVALANGA_66	8:02	8:49	0:47	LINE CLEAR AVAILED
890	17-Mar-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:45	16:06	6:20	LINE FAULT
891	18-Mar-19	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	15:43	15:49	0:06	LINE FAULT
892	18-Mar-19	BAGALKOT	110	AMBEWADI-NK1	HALIYAL_110	17:06	23:59	6:53	LINE CLEAR AVAILED
893	18-Mar-19	BAGALKOT	110	110/11KV,HV-2	ANAND NAGAR_110	10:44	15:29	4:45	LINE CLEAR AVAILED
894	18-Mar-19	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	22:35	23:59	1:24	LINE FAULT
895	18-Mar-19	BAGALKOT	220	BIDNAL-HUBLI3	BIDNAL_220	22:35	23:59	1:24	LINE FAULT
896	18-Mar-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	22:35	23:59	1:24	LINE FAULT
897	18-Mar-19	BAGALKOT	220	220/110KV,HV1	BIDNAL_220	22:35	23:59	1:24	TRANSFORMER FAULT
898	18-Mar-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI1	BIDNAL_220	22:35	23:59	1:24	LINE FAULT
899	18-Mar-19	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	22:35	23:59	1:24	LINE FAULT
900	18-Mar-19	BAGALKOT	110	220/110KV,LV1	BIDNAL_220	22:44	23:59	1:15	MAIN SUPPLY FAILURE
901	18-Mar-19	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	22:45	23:59	1:14	MAIN SUPPLY FAILURE
902	18-Mar-19	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	22:45	23:59	1:14	MAIN SUPPLY FAILURE
903	18-Mar-19	BAGALKOT	110	BIDNAL-GADAG	GADAG ROAD_110	22:45	23:59	1:14	MAIN SUPPLY FAILURE
904	18-Mar-19	BAGALKOT	110	BIDNAL- PH COMPOUND	PH COMPOUND_110	22:45	23:59	1:14	MAIN SUPPLY FAILURE
905	18-Mar-19	BAGALKOT	110	BIDNAL-HUBLI2	BIDNAL_220	22:44	22:58	0:14	MAIN SUPPLY FAILURE
906	18-Mar-19	BAGALKOT	110	110/11KV,HV-1&2	BIDNAL_220	22:45	22:59	0:14	MAIN SUPPLY FAILURE
907	18-Mar-19	BAGALKOT	110	BYADAGI-SUZLON	BYADAGI_110	13:44	14:28	0:44	LINE CLEAR AVAILED
908	18-Mar-19	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD	NARAGUND_110	22:59	23:12	0:13	HAND TRIPPED
909	18-Mar-19	BAGALKOT	110	GOPANKOPPA-GADAG ROAD	GADAG ROAD_110	22:59	23:00	0:01	HAND TRIPPED
910	18-Mar-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	5:28	5:39	0:11	TRANSFORMER FAULT
911	18-Mar-19	BAGALKOT	220	HAVERI-GUTTUR 2	HAVERI_220	4:41	17:05	12:24	LINE FAULT
912	18-Mar-19	BAGALKOT	220	HAVERI-GUTTUR 1	HAVERI_220	5:36	17:05	11:29	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
913	18-Mar-19	BAGALKOT	220	220/110KV,HV-1	HAVERI_220	6:38	7:27	0:49	TRANSFORMER FAULT
914	18-Mar-19	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	5:38	17:47	12:09	LINE FAULT
915	18-Mar-19	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	5:42	10:59	5:17	LINE FAULT
916	18-Mar-19	BAGALKOT	110	HAVERI-HANAGAL	HANAGAL_110	6:01	16:42	10:41	LINE FAULT
917	18-Mar-19	BAGALKOT	110	HAVERI-TILUVALI	TILUVALI_110	6:00	16:41	10:41	LINE FAULT
918	18-Mar-19	BAGALKOT	110	110/11KV, HV-1	YARGATTI_110	20:07	20:11	0:04	TRANSFORMER FAULT
919	18-Mar-19	BAGALKOT	110	110/11KV, HV-2	UGARKHUD_110	9:58	12:14	2:16	LINE CLEAR AVAILED
920	18-Mar-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	9:44	11:48	2:04	LINE FAULT
921	18-Mar-19	BAGALKOT	110	110/11KV, HV-4	HUBLI_220	16:29	17:26	0:57	LINE CLEAR AVAILED
922	18-Mar-19	BAGALKOT	110	110/11KV, HV-3	RAIBAG_110	22:02	22:08	0:06	TRANSFORMER FAULT
923	18-Mar-19	BAGALKOT	110	NARENDRA220-MRUTHYUNJAYNAGAR2	MRUTHYUNJAY NAGAR_110	11:45	13:23	1:38	LINE CLEAR AVAILED
924	18-Mar-19	BAGALKOT	110	110/11KV, HV-1	MUNDUGANUR_110	16:11	17:05	0:54	LINE CLEAR AVAILED
925	18-Mar-19	BAGALKOT	110	MAMDAPUR(B)-SHIRBUR	SHIRBUR_110	13:22	13:31	0:09	LINE CLEAR AVAILED
926	18-Mar-19	BAGALKOT	110	MAMDAPUR(B)-SHIRBUR	SHIRBUR_110	16:53	16:56	0:03	LINE CLEAR AVAILED
927	18-Mar-19	BAGALKOT	110	110/11KV, HV-2	MALGHAN(B)_110	16:03	16:19	0:16	TRANSFORMER FAULT
928	18-Mar-19	BAGALKOT	110	KARWAR220-BINAGA(EHT)	KARWAR_220	10:52	17:08	6:16	LINE CLEAR AVAILED
929	18-Mar-19	BAGALKOT	110	KIRUVATTI-UMMACHAGI	UMMACHAGI_110	22:09	23:59	1:50	LINE CLEAR AVAILED
930	18-Mar-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	13:23	13:31	0:08	HAND TRIPPED
931	18-Mar-19	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	23:01	23:59	0:58	LINE CLEAR AVAILED
932	18-Mar-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	15:52	16:07	0:15	LINE FAULT
933	18-Mar-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	16:48	17:04	0:16	LINE FAULT
934	18-Mar-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	19:25	22:09	2:44	LINE CLEAR AVAILED
935	18-Mar-19	BAGALKOT	110	AMBEWADI-KADANKOPPA	KADANKOPPA_110	0:00	19:25	19:25	LINE CLEAR AVAILED
936	18-Mar-19	BANGALORE	66	ADUGODI - HAL 2	K & C VALLEY, NAL (EHT)	13:42	13:47	0:05	LINE CLEAR AVAILED
937	18-Mar-19	BANGALORE	66	ADUGODI - HAL 2	K & C VALLEY, NAL (EHT)	11:24	11:28	0:04	LINE CLEAR AVAILED
938	18-Mar-19	BANGALORE	66	A STATION 220 - VICTORIA	VICTORIA	1:42	2:03	0:20	MAIN SUPPLY FAILURE
939	18-Mar-19	BANGALORE	220	HV1	A STATION 220	1:21	2:18	0:56	TRANSFORMER FAULT
940	18-Mar-19	BANGALORE	66	HV2	BOODIGERE	8:58	10:10	1:11	LINE CLEAR AVAILED
941	18-Mar-19	BANGALORE	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	12:32	12:37	0:04	LOAD CHANGEOVER
942	18-Mar-19	BANGALORE	220	EPIP 220 - ITPL (EHT)	EPIP 220, HSR LAYOUT 220	16:35	16:43	0:07	LINE FAULT
943	18-Mar-19	BANGALORE	220	HV1	EPIP 220	16:35	16:45	0:09	MAIN SUPPLY FAILURE
944	18-Mar-19	BANGALORE	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	16:35	16:55	0:19	MAIN SUPPLY FAILURE
945	18-Mar-19	BANGALORE	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	16:35	17:06	0:30	MAIN SUPPLY FAILURE
946	18-Mar-19	BANGALORE	66	EDC 220 - BMTC	BMTC	16:35	17:06	0:30	MAIN SUPPLY FAILURE
947	18-Mar-19	BANGALORE	66	HV1	EDC 220	16:35	17:06	0:30	MAIN SUPPLY FAILURE
948	18-Mar-19	BANGALORE	66	HV2	EDC 220	16:35	17:06	0:30	MAIN SUPPLY FAILURE
949	18-Mar-19	BANGALORE	220	HOODY 400 - HSR LAYOUT 20	HSR LAYOUT 220	16:35	17:06	0:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
950	18-Mar-19	BANGALORE	220	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	21:05	21:09	0:03	LINE FAULT
951	18-Mar-19	BANGALORE	220	SOUTH CITY - KHODAYS 220	SOUTH CITY	12:20	12:23	0:03	LOAD CHANGEOVER
952	18-Mar-19	BANGALORE	66	HSR LAYOUT 220 - S.T JOHNS	S.T JOHNS	16:35	17:06	0:30	MAIN SUPPLY FAILURE
953	18-Mar-19	BANGALORE	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	16:35	17:06	0:30	MAIN SUPPLY FAILURE
954	18-Mar-19	BANGALORE	66	HSR LAYOUT 220 - SHOBHA APARTMENTS	SHOBHA APARTMENT	16:35	17:06	0:30	MAIN SUPPLY FAILURE
955	18-Mar-19	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	13:19	13:48	0:29	MAIN SUPPLY FAILURE
956	18-Mar-19	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL PROJECTS	PRIMAL PROJECTS	13:19	13:48	0:29	MAIN SUPPLY FAILURE
957	18-Mar-19	BANGALORE	220	HV1	VIKAS TECH PARK 220	13:19	13:48	0:29	MAIN SUPPLY FAILURE
958	18-Mar-19	BANGALORE	220	HV2	VIKAS TECH PARK 220	13:19	13:49	0:30	MAIN SUPPLY FAILURE
959	18-Mar-19	BANGALORE	66	HV1	BAGEPALLI	11:35	12:03	0:28	LINE CLEAR AVAILED
960	18-Mar-19	BANGALORE	66	CHIKKABALLAPURA I/A - DB PURA 2	CHIKKABALLAPURA I/A	0:40	1:20	0:40	LINE FAULT
961	18-Mar-19	BANGALORE	66	CHIKKABALLAPURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	0:40	1:55	1:15	LINE FAULT
962	18-Mar-19	BANGALORE	66	CHIKKABALLAPURA I/A - CHIKKABALLAPURA URBAN	CHIKKABALLAPURA URBAN	0:40	1:50	1:10	LINE FAULT
963	18-Mar-19	BANGALORE	66	HV1	CHIKKABALLAPURA I/A	0:40	1:40	1:00	TRANSFORMER FAULT
964	18-Mar-19	BANGALORE	66	HV2	CHIKKABALLAPURA I/A	0:40	1:30	0:50	TRANSFORMER FAULT
965	18-Mar-19	BANGALORE	66	HV3	CHIKKABALLAPURA I/A	0:40	1:45	1:05	LINE CLEAR AVAILED
966	18-Mar-19	BANGALORE	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A	0:40	1:20	0:40	LINE CLEAR AVAILED
967	18-Mar-19	BANGALORE	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	6:20	6:27	0:06	LINE FAULT
968	18-Mar-19	BANGALORE	66	YELDUR - SRINIVASPURA	YELDUR	11:00	14:45	3:45	LINE CLEAR AVAILED
969	18-Mar-19	BANGALORE	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	15:19	16:11	0:51	LINE CLEAR AVAILED
970	18-Mar-19	BANGALORE	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	7:03	7:12	0:09	LINE FAULT
971	18-Mar-19	BANGALORE	66	HV1	KGF	11:26	12:02	0:35	LINE CLEAR AVAILED
972	18-Mar-19	BANGALORE	66	HV1	VG DODDI	16:03	16:33	0:30	LINE CLEAR AVAILED
973	18-Mar-19	BANGALORE	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:19	13:44	0:24	LINE FAULT
974	18-Mar-19	BANGALORE	66	HV1	SARJAPURA 220	13:19	13:44	0:24	MAIN SUPPLY FAILURE
975	18-Mar-19	BANGALORE	66	HV2	SARJAPURA 220	13:19	13:44	0:24	MAIN SUPPLY FAILURE
976	18-Mar-19	BANGALORE	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:19	13:44	0:24	MAIN SUPPLY FAILURE
977	18-Mar-19	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:19	13:44	0:24	MAIN SUPPLY FAILURE
978	18-Mar-19	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:19	13:53	0:33	MAIN SUPPLY FAILURE
979	18-Mar-19	GULBARGA	110	SINDHANOOR220-MUNIRABAD2	BTPS WATER WORKS, MUKUNDA_110, KAMPLI_110	2:25	2:38	0:13	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
980	18-Mar-19	GULBARGA	110	HV2	MADIYAL_110	19:00	19:20	0:20	MAIN SUPPLY FAILURE
981	18-Mar-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:34	14:07	2:33	LINE CLEAR AVAILED
982	18-Mar-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	15:31	23:59	8:28	LINE FAULT
983	18-Mar-19	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	6:21	11:32	5:11	LINE FAULT
984	18-Mar-19	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	9:44	11:01	1:17	LINE CLEAR AVAILED
985	18-Mar-19	HASSAN	220	HASSN220-CHIKMAGALUR	HASSAN_220	10:24	10:35	0:11	HAND TRIPPED
986	18-Mar-19	HASSAN	220	KADUR-DABUSET	KADUR_220	6:36	14:03	7:27	NFBC ISSUED
987	18-Mar-19	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	9:34	16:56	7:22	LINE CLEAR AVAILED
988	18-Mar-19	HASSAN	220	KAVOOR-BAJPE1	KAVOOR_220	22:39	23:59	1:20	LINE FAULT
989	18-Mar-19	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	10:24	11:32	1:08	LINE CLEAR AVAILED
990	18-Mar-19	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	6:21	11:32	5:11	LINE FAULT
991	18-Mar-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	9:33	16:59	7:26	NFBC ISSUED
992	18-Mar-19	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	22:34	23:59	1:25	LINE FAULT
993	18-Mar-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	22:34	23:25	0:51	LINE FAULT
994	18-Mar-19	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	10:19	11:37	1:18	NFBC ISSUED
995	18-Mar-19	HASSAN	110	HV2	ANAVATTI_110	15:37	16:23	0:46	TRANSFORMER FAULT
996	18-Mar-19	HASSAN	66	HASSN220-SKPURA	HASSAN_220	5:37	5:51	0:14	LINE FAULT
997	18-Mar-19	HASSAN	66	HV1	BELUR_66	0:37	17:04	16:27	TRANSFORMER FAULT
998	18-Mar-19	HASSAN	66	HV2	BELUR_66	18:08	18:13	0:05	TRANSFORMER FAULT
999	18-Mar-19	HASSAN	66	HV1	BYACHANAHALLI_66	10:14	10:19	0:05	TRANSFORMER FAULT
1000	18-Mar-19	HASSAN	66	HIREMAN-RDL	HIREMAGALUR_66	12:12	12:21	0:09	LINE FAULT
1001	18-Mar-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	21:29	21:43	0:14	LINE FAULT
1002	18-Mar-19	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	5:38	5:57	0:19	LINE FAULT
1003	18-Mar-19	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	5:38	6:05	0:27	LINE FAULT
1004	18-Mar-19	HASSAN	66	HV1	SATHENAHALLY_66	12:42	13:59	1:17	LINE CLEAR AVAILED
1005	18-Mar-19	MYSORE	66	HV1	BANNUR_66	16:08	23:59	7:50	TRANSFORMER FAULT
1006	18-Mar-19	MYSORE	66	MIRLE-KR NAGARA	MIRLE_66	6:22	8:32	2:09	LINE CLEAR AVAILED
1007	18-Mar-19	MYSORE	66	HV5	SFCSHIVA_66	12:22	23:59	11:36	LINE CLEAR AVAILED
1008	18-Mar-19	MYSORE	66	HV1	TARIPURA_66	12:12	13:35	1:22	TRANSFORMER FAULT
1009	18-Mar-19	MYSORE	66	HV1	TARIPURA_66	10:45	15:42	4:57	LINE CLEAR AVAILED
1010	18-Mar-19	TUMKUR	220	TR-3	DAVANGERE_SRS_220	10:28	19:17	8:49	LINE CLEAR AVAILED
1011	18-Mar-19	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	MRSMSG_220	13:02	13:30	0:27	LINE CLEAR AVAILED
1012	18-Mar-19	TUMKUR	110	TR-1	KBCROSS_220	15:30	15:35	0:05	HAND TRIPPED
1013	18-Mar-19	TUMKUR	66	TR-2	CHANNAGIRI_66	14:46	14:48	0:01	TRANSFORMER FAULT
1014	18-Mar-19	TUMKUR	66	TR-1	CHANNAGIRI_66	23:22	23:29	0:07	TRANSFORMER FAULT
1015	18-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	6:29	7:05	0:36	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1016	18-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:09	12:36	0:27	HAND TRIPPED
1017	18-Mar-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	22:23	22:28	0:04	HAND TRIPPED
1018	18-Mar-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	18:43	19:16	0:32	LINE CLEAR AVAILED
1019	18-Mar-19	TUMKUR	66	HIRIYUR 220KV- RKP 2	RKP1_IPP_66	18:43	19:16	0:32	LINE CLEAR AVAILED
1020	18-Mar-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	7:49	10:02	2:13	LINE FAULT
1021	18-Mar-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	11:23	11:29	0:05	LINE FAULT
1022	18-Mar-19	TUMKUR	66	TR-1	KATTIGE_66	6:30	11:02	4:32	LINE CLEAR AVAILED
1023	18-Mar-19	TUMKUR	66	TR-1	KATTIGE_66	16:06	18:44	2:38	LINE CLEAR AVAILED
1024	18-Mar-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	6:23	6:38	0:15	MAIN SUPPLY FAILURE
1025	18-Mar-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	9:50	14:14	4:24	LINE FAULT
1026	18-Mar-19	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	15:01	15:38	0:37	LINE FAULT