

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 15 to 21 FEBRUARY 2022

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1	15-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED YARAGATTI_110	9:37	12:46	3:09	LINE CLEAR AVAILED
2	15-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED YARAGATTI_110	15:24	16:04	0:40	LINE CLEAR AVAILED
3	15-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIRSI_110	12:09	12:45	0:36	LINE CLEAR AVAILED
4	15-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED RAIBAG_110	10:23	10:33	0:10	HAND TRIPPED
5	15-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED RAIBAG_110	12:57	13:52	0:55	LINE CLEAR AVAILED
6	15-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED NIDAGUNDI_110	2:02	2:11	0:09	TRANSFORMER FAULT
7	15-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TUMMINAKATTI_110	18:04	18:35	0:31	LINE CLEAR AVAILED
8	15-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TILUVALLI_110	13:54	22:13	8:19	TRANSFORMER FAULT
9	15-Feb-22	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	9:47	11:15	1:28	LINE CLEAR AVAILED
10	15-Feb-22	BAGALKOT	110	110/11KV,HV1	BISANAL_110	9:59	11:54	1:55	LINE CLEAR AVAILED
11	15-Feb-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	14:00	14:06	0:06	TRANSFORMER FAULT
12	15-Feb-22	BAGALKOT	110	110/11KV,HV1	NAVANAGAR_110	10:02	11:16	1:14	LINE CLEAR AVAILED
13	15-Feb-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	11:33	11:51	0:18	TRANSFORMER FAULT
14	15-Feb-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	14:32	14:46	0:14	HAND TRIPPED
15	15-Feb-22	BAGALKOT	110	110/11KV,HV2	NAVANAGAR_110	11:13	14:14	3:01	LINE CLEAR AVAILED
16	15-Feb-22	BAGALKOT	110	110/11KV,HV2	NAVANAGAR_110	17:19	17:32	0:13	HAND TRIPPED
17	15-Feb-22	BAGALKOT	110	110/33KV, HV2	KALABILAGI_33, TUNGAL LIS_33, & HIREPADASALAGI LIS_33 STATION NOT AFFECTED SAVALAGI_110	11:21	11:44	0:23	LINE CLEAR AVAILED
18	15-Feb-22	BAGALKOT	110	AMBEWADI-HALIYAL(NK-1)	STATION NOT AFFECTED AMBEWADI_220	8:16 (14.02.2022)	19:02 (15.02.2022)	34:46 hrs	LINE CHARGED
19	15-Feb-22	BAGALKOT	110	AMBEWADI-KAVALWADA(NK-2)	STATION NOT AFFECTED AMBEWADI_220	8:16 (14.02.2022)	19:03 (15.02.2022)	34:47 hrs	LINE CHARGED
20	15-Feb-22	BAGALKOT	110	BAGALKOT1-NAVANAGAR	NAVANAGAR_110	10:03	17:25	7:22	LINE CLEAR AVAILED
21	15-Feb-22	BAGALKOT	110	BAGALKOT2-NAVANAGAR	NAVANAGAR_110	17:19	17:25	0:06	HAND TRIPPED
22	15-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
23	15-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
24	15-Feb-22	BAGALKOT	110	KUSHTAGI 2-ILKAL	ILKAL_110	6:35	7:22	0:47	HAND TRIPPED
25	15-Feb-22	BAGALKOT	110	RANEBENNUR-BYADAGI	STATION NOT AFFECTED BYADAGI_110	11:40	12:42	1:02	HAND TRIPPED
26	15-Feb-22	BAGALKOT	110	RANEBENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	18:42 (14.02.2022)			LINE OPEN:LINE CLEAR AVAILED
27	15-Feb-22	BAGALKOT	110	TAKKALAKI-KN SOLAR SOLAR	KN SOLAR SOLAR_110 TAKKALAKI_110	14:10	14:32	0:22	HAND TRIPPED
28	15-Feb-22	BAGALKOT	110	TAKKALAKI-KN SOLAR SOLAR	KN SOLAR SOLAR_110 TAKKALAKI_110	15:38	15:48	0:10	HAND TRIPPED
29	15-Feb-22	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 TAKKALAKI_110	14:10	14:32	0:22	HAND TRIPPED
30	15-Feb-22	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 TAKKALAKI_110	15:38	15:48	0:10	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
31	15-Feb-22	BAGALKOT	220	220/110KV,HV1,LV1	BIJAPUR_110,KIADB_110 STATION NOT AFFECTED BIJAPUR_220	14:01	14:32	0:31	TRANSFORMER FAULT
32	15-Feb-22	BAGALKOT	220	220/110KV,HV1,LV1	BIJAPUR_110,KIADB_110 STATION NOT AFFECTED BIJAPUR_220	15:28	15:45	0:17	TRANSFORMER FAULT
33	15-Feb-22	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED BIJAPUR_220	13:05	18:17	5:12	LINE CLEAR AVOIDED
34	15-Feb-22	BAGALKOT	220	220/110KV,HV3,LV3	STATION NOT AFFECTED CHIKODI_220	10:25	12:50	2:25	LINE CLEAR AVOIDED
35	15-Feb-22	BAGALKOT	220	BIJAPUR-INDI2	STATION NOT AFFECTED BIJAPUR_220	12:40	19:19	6:39	LINE CLEAR AVOIDED
36	15-Feb-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVOIDED
37	15-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
38	15-Feb-22	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	10:32	15:37	5:05	LINE CLEAR AVOIDED
39	15-Feb-22	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	10:40	15:34	5:18	NFBC ISSUED
40	15-Feb-22	BAGALKOT	220	INDI-BIJAPUR2	STATION NOT AFFECTED INDI_220	12:26	19:05	6:39	NFBC ISSUED
41	15-Feb-22	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	10:16	15:34	5:18	LINE CLEAR AVOIDED
42	15-Feb-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVOIDED
43	15-Feb-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVOIDED
44	15-Feb-22	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	16:28 (12.02.2022)	14:28 (15.02.2022)	70:00 hrs	LINE CHARGED
45	15-Feb-22	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	14:16	14:26	0:10	LINE FAULT
46	15-Feb-22	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 220	BAGEPALLI	22:00	22:05	0:05	LOAD CHANGE OVER
47	15-Feb-22	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	11:45	13:12	1:26	LINE CLEAR AVOIDED
48	15-Feb-22	BENGALURU	66	GUNDAMGERE - GOWRIBIDANUR	GUNDAMGERE	8:55	9:00	0:05	LOAD CHANGE OVER
49	15-Feb-22	BENGALURU	66	HEBBAL 220 - C STATION 1 & 2	C STATION	7:59	8:24	0:25	LINE CLEAR AVOIDED
50	15-Feb-22	BENGALURU	66	HEBBAL 220 - L R BANDE	L R BANDE	7:59	8:23	0:24	LINE CLEAR AVOIDED
51	15-Feb-22	BENGALURU	66	HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	12:09	12:48	0:39	LINE CLEAR AVOIDED
52	15-Feb-22	BENGALURU	66	HV1	BANASAWADI	7:59	8:01	0:02	MAIN SUPPLY FAILURE
53	15-Feb-22	BENGALURU	66	HV1	MANYATHA TECH PARK 66	7:59	8:11	0:12	LINE CLEAR AVOIDED
54	15-Feb-22	BENGALURU	66	HV1	HOODY 220	13:03	13:35	0:32	LINE CLEAR AVOIDED
55	15-Feb-22	BENGALURU	66	HV1	JAYADEVA	14:51	15:02	0:11	LINE CLEAR AVOIDED
56	15-Feb-22	BENGALURU	66	HV1	JAYADEVA	15:37	15:49	0:12	LOAD CHANGE OVER
57	15-Feb-22	BENGALURU	66	HV1	T GOLLAHALLI 220	13:00	13:22	0:22	LINE CLEAR AVOIDED
58	15-Feb-22	BENGALURU	66	HV1	MITTEMARI 220	12:58	13:03	0:05	LOAD CHANGE OVER
59	15-Feb-22	BENGALURU	66	HV2	MANYATHA TECH PARK 66	7:59	8:11	0:12	LINE CLEAR AVOIDED
60	15-Feb-22	BENGALURU	66	HV3	BANASAWADI	8:25	8:29	0:04	MAIN SUPPLY FAILURE
61	15-Feb-22	BENGALURU	66	HV4	MANYATHA TECH PARK 66	7:59	8:11	0:12	LINE CLEAR AVOIDED
62	15-Feb-22	BENGALURU	66	II Sc - HEBBALA 220	II Sc	7:59	8:20	0:21	MAIN SUPPLY FAILURE
63	15-Feb-22	BENGALURU	66	II Sc - NRS 220	II Sc	16:52	16:55	0:03	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
64	15-Feb-22	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	10:15	15:34	5:19	LINE CLEAR AVAILED
65	15-Feb-22	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	16:31	18:14	1:43	LINE CLEAR AVAILED
66	15-Feb-22	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	CHANDRAPPA CIRCLE	6:38	7:09	0:31	LINE FAULT
67	15-Feb-22	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	6:38	7:09	0:31	LINE FAULT
68	15-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN:LINE FAULT
69	15-Feb-22	BENGALURU	66	MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66	MANYATHA TECH PARK 66	7:59	8:11	0:12	LINE CLEAR AVAILED
70	15-Feb-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	12:30	13:10	0:40	LINE CLEAR AVAILED
71	15-Feb-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	12:30	12:35	0:05	LINE CLEAR AVAILED
72	15-Feb-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	12:54	12:58	0:04	LOAD CHANGEVER
73	15-Feb-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	21:53	21:56	0:03	LOAD CHANGEVER
74	15-Feb-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	12:47	12:51	0:04	LOAD CHANGEVER
75	15-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	14:38	14:43	0:05	LOAD CHANGEVER
76	15-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	14:57	15:05	0:08	LOAD CHANGEVER
77	15-Feb-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	9:01	17:46	8:44	LOAD CURTAILMENT
78	15-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	16:05	20:29	4:24	LINE CLEAR AVAILED
79	15-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	9:46(11-2-2022)	20:30:35(15-2-2022)	106:43 hrs	LINE CHARGED
80	15-Feb-22	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	7:59	8:18	0:19	MAIN SUPPLY FAILURE
81	15-Feb-22	BENGALURU	220	HV1	MITTEMARI 220	13:13	21:53	8:40	LINE CLEAR AVAILED
82	15-Feb-22	BENGALURU	220	LV1	MITTEMARI 220	15:43	17:02	1:19	LINE CLEAR AVAILED
83	15-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
84	15-Feb-22	BENGALURU	220	MANYATHA TECH PARK 220 - HEBBALA 220	HEBBALA 220	7:59	8:15	0:16	LINE FAULT
85	15-Feb-22	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	MANYATHA TECH PARK 220	7:59	8:11	0:12	LINE FAULT
86	15-Feb-22	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 1	NO STATION AFFECTED	15:43	17:02	1:19	LINE CLEAR AVAILED
87	15-Feb-22	GULBARGA	66	HALVAGALU-NEELAGUNDA	HALVAGALU_66,HARVI_66	7:25	7:35	0:10	MAIN SUPPLY FAILURE
88	15-Feb-22	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66	9:30	18:30	9:00	LINE CLEAR AVAILED
89	15-Feb-22	GULBARGA	66	HV1	KUDLIGI_220	13:55	14:00	0:05	TRANSFORMER FAULT
90	15-Feb-22	GULBARGA	66	HV1,HV2	UCHCHANGIDURGA_66	10:15	17:45	7:30	LINE CLEAR AVAILED
91	15-Feb-22	GULBARGA	66	HV2	ITTAGI_220	23:42 (14.02.2022)	13:00 (15.02.2022)	13:18 HRS	TRANSFORMER CHARGED
92	15-Feb-22	GULBARGA	66	HV3	HALVAGALU_66	12:00	13:55	1:55	LINE CLEAR AVAILED
93	15-Feb-22	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66, HOSAHALLI_66	15:33	15:45	0:35	LINE CLEAR AVAILED
94	15-Feb-22	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66, HOSAHALLI_66	17:25	18:05	0:35	LINE CLEAR AVAILED
95	15-Feb-22	GULBARGA	66	KUDLIGI-PUNABGHATA	PUNABGHATA_66	16:05	17:30	1:25	LINE CLEAR AVAILED
96	15-Feb-22	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKANAHALLI_66 ,HAGARIBOMMANAHALLI_66,RR STEELS_IPP	13:58	14:08	0:10	LINE FAULT
97	15-Feb-22	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66	6:05	6:15	0:10	MAIN SUPPLY FAILURE
98	15-Feb-22	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	21:45	21:55	0:10	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
99	15-Feb-22	GULBARGA	66	UCHCHANGIDURGA-NEELAGUNDA	UCHCHANGIDURGA_66,BILCHOD_66	6:00	6:15	0:15	MAIN SUPPLY FAILURE
100	15-Feb-22	GULBARGA	66	UCHCHANGIDURGA-PUNABGHATA	UCHCHANGIDURGA_66,BILCHOD_66	16:00	17:30	1:30	LINE CLEAR AVAILED
101	15-Feb-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMERESHWAR_110	4:58	5:10	0:12	MAIN SUPPLY FAILURE
102	15-Feb-22	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMERESHWAR_110	21:29	21:37	0:08	MAIN SUPPLY FAILURE
103	15-Feb-22	GULBARGA	110	CHITGUPPA-HUMNABAD	CHITGUPPA_110	18:18	18:25	0:07	MAIN SUPPLY FAILURE
104	15-Feb-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	17:40	17:50	0:10	LINE FAULT
105	15-Feb-22	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	0:25	1:20	0:55	MAIN SUPPLY FAILURE
106	15-Feb-22	GULBARGA	110	GABBUR-BPSLR	GABBUR_110	19:56	22:27	2:31	LINE CLEAR AVAILED
107	15-Feb-22	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	6:50	6:56	0:06	LINE FAULT
108	15-Feb-22	GULBARGA	110	GHATARAGA-SHAHABAD	GHATARAGA_110	0:52	1:18	0:26	MAIN SUPPLY FAILURE
109	15-Feb-22	GULBARGA	110	HV2	YELBURGA_110	1:25	2:25	1:00	TRANSFORMER FAULT
110	15-Feb-22	GULBARGA	110	HV2	HATTI_110	13:19	13:28	0:09	TRANSFORMER FAULT
111	15-Feb-22	GULBARGA	110	HV3	CHIDRI_110	9:45	12:40	2:55	LINE CLEAR AVAILED
112	15-Feb-22	GULBARGA	110	KUSTAGI-ILKAL1	ILKAL_110	6:38	7:31	0:35	LINE FAULT
113	15-Feb-22	GULBARGA	110	LINGASUGUR-GURGUNTA	GURGUNTA_110,KHEL_IPP,LJVL_IPP	5:46	5:51	0:05	LINE FAULT
114	15-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	10:10	16:12	6:02	LOAD CHANGEVER
115	15-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_110	4:53	5:03	0:10	LINE FAULT
116	15-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI_110	21:28	21:37	0:09	LINE FAULT
117	15-Feb-22	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	9:10	9:22	0:12	LINE FAULT
118	15-Feb-22	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	9:28	9:32	0:04	LINE FAULT
119	15-Feb-22	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	11:14	11:19	0:05	LINE FAULT
120	15-Feb-22	GULBARGA	110	NANDOOR-SHAHBAD	NANDOOR_110	0:50	1:17	0:27	MAIN SUPPLY FAILURE
121	15-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
122	15-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
123	15-Feb-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGER A_110,SANNATHI_IPP,COREGREENSUGARS_IPP	21:59	22:06	0:07	LINE FAULT
124	15-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	5:54	6:04	0:10	LINE FAULT
125	15-Feb-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	13:58	14:05	0:07	LINE FAULT
126	15-Feb-22	GULBARGA	110	YAKATAPUR-KAMTHANA	YAKATAPUR_110	0:50	1:25	0:35	MAIN SUPPLY FAILURE
127	15-Feb-22	GULBARGA	110	YERADONA-SINDHANOOR	YERADONA_110,BENUR_110	5:50	6:05	0:15	MAIN SUPPLY FAILURE
128	15-Feb-22	GULBARGA	220	HALBARGA-HUMNABAD	HALBARGA_220	0:51	1:21	0:30	MAIN SUPPLY FAILURE
129	15-Feb-22	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	0:52	1:19	0:27	LINE FAULT
130	15-Feb-22	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	0:52	2:00	1:08	LINE FAULT
131	15-Feb-22	GULBARGA	220	HV1	SEDAM_220	0:50	1:56	1:06	TRANSFORMER FAULT
132	15-Feb-22	GULBARGA	220	HV1	KUSTAGI_220	6:38	6:45	0:35	TRANSFORMER FAULT
133	15-Feb-22	GULBARGA	220	HV1	RAICHUR_220	13:00	14:55	1:55	LINE CLEAR AVAILED
134	15-Feb-22	GULBARGA	220	HV1,HV2,LV1,LV2	KAPNOOR_220	0:55	1:27	0:32	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
135	15-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
136	15-Feb-22	GULBARGA	220	HV2	SEDAM_220	0:50	2:36	1:46	TRANSFORMER FAULT
137	15-Feb-22	GULBARGA	220	KAPNOOR-HUMNABAD1,2	KAPNOOR_220	0:50	1:20	0:30	MAIN SUPPLY FAILURE
138	15-Feb-22	GULBARGA	220	KAPNOOR-SHAHABAD	KAPNOOR_220	0:50	1:23	0:33	MAIN SUPPLY FAILURE
139	15-Feb-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	0:50	1:12	0:22	LINE FAULT
140	15-Feb-22	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	9:57	15:05	5:08	NFBC ISSUED
141	15-Feb-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	0:50	1:20	0:30	LINE FAULT
142	15-Feb-22	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	0:50	1:31	0:41	LINE FAULT
143	15-Feb-22	HASSAN	66	HV1	CRPATNA_220	10:38	14:30	3:52	LINE CLEAR AVAILED
144	15-Feb-22	HASSAN	66	HV1	SAKLESHPURA_66	8:45	19:01	10:16	TRANSFORMER FAULT
145	15-Feb-22	HASSAN	66	HV1	SINGAPURA_66	10:22	14:49	4:27	LINE CLEAR AVAILED
146	15-Feb-22	HASSAN	66	HV2	HOLALUR_66	18:42	20:33	1:51	TRANSFORMER FAULT
147	15-Feb-22	HASSAN	66	HV2	SINGAPURA_66	10:22	14:49	4:27	LINE CLEAR AVAILED
148	15-Feb-22	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	6:24	6:36	0:12	LINE FAULT
149	15-Feb-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	10:22	14:49	4:27	LINE CLEAR AVAILED
150	15-Feb-22	HASSAN	110	HV1	HEGGUNJE_220	14:19	15:41	1:22	LINE CLEAR AVAILED
151	15-Feb-22	HASSAN	110	HV1	BANTWAL_110	13:46	16:47	3:01	LINE CLEAR AVAILED
152	15-Feb-22	HASSAN	110	HV2	MANIPAL_110	10:58	13:43	2:45	LINE CLEAR AVAILED
153	15-Feb-22	HASSAN	110	HV3	BANTWAL_110	10:15	13:40	3:25	LINE CLEAR AVAILED
154	15-Feb-22	HASSAN	110	HV3	BANTWAL_110	12:15	17:36	5:21	LINE CLEAR AVAILED
155	15-Feb-22	HASSAN	110	HV3	BANTWAL_110	9:50	12:15	2:25	LINE CLEAR AVAILED
156	15-Feb-22	HASSAN	110	JOG110-AMBTR2	JOG_110	13:08 (26.01.2022)			LINE OPEN:LINE CLEAR AVAILED
157	15-Feb-22	HASSAN	110	JOG110-LPH	JOG_110	21:33	22:25	0:52	LINE CLEAR AVAILED
158	15-Feb-22	HASSAN	110	KEMAR-Manipal1	KEMAR_220	9:24	16:38	7:14	LINE CLEAR AVAILED
159	15-Feb-22	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	9:25	16:39	7:14	NFBC ISSUED
160	15-Feb-22	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:02	13:45	3:43	LINE CLEAR AVAILED
161	15-Feb-22	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	15:37	17:23	1:46	HAND TRIPPED
162	15-Feb-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	13:15	13:58	0:43	LINE CLEAR AVAILED
163	15-Feb-22	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	9:32(13.02.2022)			LINE OPEN:LINE CLEAR AVAILED
164	15-Feb-22	HASSAN	110	MSEZ-GSS31	MSEZ_220	9:17	17:31	8:14	NFBC ISSUED
165	15-Feb-22	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	11:03	13:01	1:58	NFBC ISSUED
166	15-Feb-22	HASSAN	110	SAGARA-LST4	SAGARA_110	21:50	22:15	0:25	LINE CLEAR AVAILED
167	15-Feb-22	HASSAN	220	HV1	HEGGUNJE_220	14:06	18:07	4:01	LINE CLEAR AVAILED
168	15-Feb-22	HASSAN	220	HV2	HEGGUNJE_220	10:41	13:12	2:31	LINE CLEAR AVAILED
169	15-Feb-22	HASSAN	220	HV2	HEGGUNJE_220	18:18	19:27	1:09	LINE CLEAR AVAILED
170	15-Feb-22	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	13:14	13:34	0:19	LINE CLEAR AVAILED
171	15-Feb-22	MYSURU	66	DKMAIDANA-VAJAMANGALA	NO STATIONS EFFECTED	16:23	20:46	4:22	HAND TRIPPED
172	15-Feb-22	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS EFFECTED	16:37	17:17	0:39	HAND TRIPPED
173	15-Feb-22	MYSURU	66	FTS-RAJEEVNAGARA	NO STATIONS EFFECTED	16:38	17:17	0:38	HAND TRIPPED
174	15-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
175	15-Feb-22	MYSURU	66	HV1	MADIKERI_66	8:50	13:00	4:10	HAND TRIPPED
176	15-Feb-22	MYSURU	66	HV1	CHINAKURALI_66	14:56	15:20	0:24	LINE CLEAR AVAILED
177	15-Feb-22	MYSURU	66	HV1	MAMBALLI_66	17:05	17:35	0:30	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
178	15-Feb-22	MYSURU	66	HV2	GVGUDI_66	16:19	18:59	2:40	LINE CLEAR AVAILED
179	15-Feb-22	MYSURU	66	HV2	HARVEY_66	17:00	17:38	0:38	LINE CLEAR AVAILED
180	15-Feb-22	MYSURU	66	HV2	THUMBLA_66	11:11	17:05	5:54	LINE CLEAR AVAILED
181	15-Feb-22	MYSURU	66	HV2	CHINAKURALI_66	14:56	15:20	0:24	LINE CLEAR AVAILED
182	15-Feb-22	MYSURU	66	HV3	SFCSHIVA_66	12:50	13:40	0:50	LINE CLEAR AVAILED
183	15-Feb-22	MYSURU	66	HV4	SFCSHIVA_66	16:06	16:25	0:18	LINE CLEAR AVAILED
184	15-Feb-22	MYSURU	66	HV5	SFCSHIVA_66	20:10:00 (10.2.2022)	13:12:00 (15.2.2022)	353:02 hrs	TRANSFORMER CHARGED
185	15-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
186	15-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN:LINE CLEAR AVAILED
187	15-Feb-22	MYSURU	66	MAMBALLI-YELANDUR	NO STATIONS EFFECTED	15:35	15:40	0:05	HAND TRIPPED
188	15-Feb-22	MYSURU	66	MAMBALLI-YELANDUR	NO STATIONS EFFECTED	17:05	17:35	0:30	HAND TRIPPED
189	15-Feb-22	MYSURU	66	MYSORE-BOGHADI	NO STATIONS EFFECTED	10:14	16:49	6:35	HAND TRIPPED
190	15-Feb-22	MYSURU	66	PANYADAHUNDI-KEREHALLY	NO STATIONS EFFECTED	8:15	8:20	0:05	LINE FAULT
191	15-Feb-22	MYSURU	66	PERIAPATNA-HANGUD	PONNAMPET_66,VIRAJPET_66	13:22	14:27	1:05	LINE CLEAR AVAILED
192	15-Feb-22	MYSURU	66	TUBINKERE-NAGAMANGLA2	SHIVALLY_66 HARADANAHALLI(JAK)_66,KESLAGERE_66A DICHUNCHANAGIRI_66,VADERALLI_66 BASARALU_66	13:13	13:25	0:12	LINE FAULT
193	15-Feb-22	MYSURU	220	HV2	BEGUR_220	10:02	1:02	3:00	LINE CLEAR AVAILED
194	15-Feb-22	MYSURU	220	VAJMANGALA-HOOTGALLY	NO STATIONS EFFECTED	16:41	17:51	1:10	LINE CLEAR AVAILED
195	15-Feb-22	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVANI_66	9:57	10:08	0:11	HAND TRIPPED
196	15-Feb-22	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	T G HALLI_66,HOSAPALYA_66,SOLUR_66,MAG ADI_66,V G DODDI_66	9:34	9:41	0:07	HAND TRIPPED
197	15-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	7:03	18:28	11:25	LINE CLEAR AVAILED
198	15-Feb-22	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	16:20	16:23	0:03	MAIN SUPPLY FAILURE
199	15-Feb-22	TUMKUR	66	BUKKAPATNA-SIRA	BUKKAPATNA_66	14:52	16:20	1:27	MAIN SUPPLY FAILURE
200	15-Feb-22	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	23:48	23:53	0:05	LINE FAULT
201	15-Feb-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	6:22	6:32	0:09	LINE FAULT
202	15-Feb-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	12:51	13:11	0:20	LINE FAULT
203	15-Feb-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	17:23	17:34	0:11	LINE FAULT
204	15-Feb-22	TUMKUR	66	DAVANGERE SRS- DAVANGERE 2	DAVANAGERE_66,KADAJJI_66,MELEKATTE_66	6:22	6:32	0:09	LINE FAULT
205	15-Feb-22	TUMKUR	66	DAVANGERE SRS- DAVANGERE 2	DAVANAGERE_66,KADAJJI_66,MELEKATTE_66	12:51	13:11	0:20	LINE FAULT
206	15-Feb-22	TUMKUR	66	DAVANGERE SRS- DAVANGERE 2	DAVANAGERE_66,KADAJJI_66,MELEKATTE_66	17:23	17:34	0:11	LINE FAULT
207	15-Feb-22	TUMKUR	66	HAGALWADI66-ANCHEPALYA220	HAGALWADI_66	9:55	16:00	6:05	LINE CLEAR AVAILED
208	15-Feb-22	TUMKUR	66	HINDASGHATTA66-HIRIYUR220KV	HINDASGHATTA_66	10:58	11:07	0:09	LINE FAULT
209	15-Feb-22	TUMKUR	66	HIREHALLI - DABUSPETE	HIREHALLI_66	11:50	13:15	1:25	LINE CLEAR AVAILED
210	15-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:32	9:45	0:13	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
211	15-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:04	18:15	0:11	LINE FAULT
212	15-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:20	19:21	0:01	LINE FAULT
213	15-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:31	19:43	0:12	LINE FAULT
214	15-Feb-22	TUMKUR	66	MIDIGESHI-MADHUGIRI	MEDIGESHI_66	13:05	13:20	0:14	LINE CLEAR AVAILED
215	15-Feb-22	TUMKUR	66	PAVAGADA220-SHYLAPURA66	SHYLAPURA_66	10:56	11:13	0:16	LINE FAULT
216	15-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	9:26	9:34	0:07	LINE FAULT
217	15-Feb-22	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	0:05	0:20	0:15	LINE FAULT
218	15-Feb-22	TUMKUR	66	TR-1	HARIYABBE_66	15:40	15:57	0:17	HAND TRIPPED
219	15-Feb-22	TUMKUR	66	TR-1	HAGALWADI_66	9:55	16:00	6:05	LINE CLEAR AVAILED
220	15-Feb-22	TUMKUR	66	TR-1	HIREHALLI_66	11:04	13:14	2:09	LINE CLEAR AVAILED
221	15-Feb-22	TUMKUR	66	TR-1	HIREHALLI_66	17:03	17:20	0:16	LINE CLEAR AVAILED
222	15-Feb-22	TUMKUR	66	TR-1(HV SIDE)	PAVAGADA_220	11:43	11:48	0:04	TRANSFORMER FAULT
223	15-Feb-22	TUMKUR	66	TR-2	HIREHALLI_66	11:47	13:15	1:28	LINE CLEAR AVAILED
224	15-Feb-22	TUMKUR	66	TR-2	PATTNAYAKANAHALLI_66	14:08	14:40	0:31	TRANSFORMER FAULT
225	15-Feb-22	TUMKUR	66	TR-2	THOVINAKERE_66	12:20	13:02	0:41	LINE CLEAR AVAILED
226	15-Feb-22	TUMKUR	66	TR-2(LV SIDE)	PAVAGADA_220	10:56	11:10	0:14	TRANSFORMER FAULT
227	15-Feb-22	TUMKUR	66	TR-3	HARIYABBE_66	12:04	12:16	0:12	TRANSFORMER FAULT
228	15-Feb-22	TUMKUR	220	GUTTUR 400KV- HAVERI	HAVERI_220	10:32	15:37	5:04	LINE FAULT
229	15-Feb-22	TUMKUR	220	HONNALLI 220kv- SHIMOGA 220kv	MRSMSG_220	17:43	17:45	0:02	LINE CLEAR AVAILED
230	15-Feb-22	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	10:56	11:10	0:14	TRANSFORMER FAULT
231	15-Feb-22	TUMKUR	220	TR-2(HV SIDE)	PAVAGADA_220	10:56	11:10	0:14	TRANSFORMER FAULT
1	16-Feb-22	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	10:46	13:33	2:47	LINE CLEAR AVAILED
2	16-Feb-22	BAGALKOT	110	110/11KV, HV1	RANEBENNUR_220	15:42	15:58	0:16	TRANSFORMER FAULT
3	16-Feb-22	BAGALKOT	110	110/11KV, HV2	TUMMINKATTI_110	15:02	17:38	2:36	LINE CLEAR AVAILED
4	16-Feb-22	BAGALKOT	110	110/11KV, HV2	TAKKALAKI_110	6:47	8:01	1:14	LINE CLEAR AVAILED
5	16-Feb-22	BAGALKOT	110	110/11KV, HV2	SALAHALLI_110	14:43	20:01	5:18	LINE CLEAR AVAILED
6	16-Feb-22	BAGALKOT	110	110/11KV, HV3	MUNDARGI_110	18:10	19:58	1:48	TRANSFORMER FAULT
7	16-Feb-22	BAGALKOT	110	110/11KV,HV1&2	BENAKATTI_110	9:14	12:16	3:02	TRANSFORMER FAULT
8	16-Feb-22	BAGALKOT	110	110/11KV,HV2	ANKALI_110	14:15	14:25	0:10	HAND TRIPPED
9	16-Feb-22	BAGALKOT	110	110/33KV, HV2	MURDESHWAR_110	9:00	19:51	10:51	LINE CLEAR AVAILED
10	16-Feb-22	BAGALKOT	110	110/33KV, HV3	SALAHALLI_110, HULKUND_33	8:27	11:14	2:47	LINE CLEAR AVAILED
11	16-Feb-22	BAGALKOT	110	110/33KV, HV3	MURDESHWAR_110, BHATKAL_33, KASARGOD_33	9:00	12:19	3:19	LINE CLEAR AVAILED
12	16-Feb-22	BAGALKOT	110	110/33KV, HV3	MUNAVALLY_110, HULIKATTI_33, MALLUR_33	2:51	8:35	5:44	TRANSFORMER FAULT
13	16-Feb-22	BAGALKOT	110	110/33KV,HV1	HANAGAL_110 & PALA & BASAPUR_33	10:18	14:11	3:53	LINE CLEAR AVAILED
14	16-Feb-22	BAGALKOT	110	AMBEWADI- NK1 (HALIYAL)	HALIYAL_110	10:56	11:08	0:12	HAND TRIPPED
15	16-Feb-22	BAGALKOT	110	AMBEWADI- NK2 (KAVALWADA)	KAVALWADA_110	10:56	11:09	0:13	HAND TRIPPED
16	16-Feb-22	BAGALKOT	110	BADAMI(IDLE)-HIREHAL	HIREHAL_110	14:13	14:39	0:26	HAND TRIPPED
17	16-Feb-22	BAGALKOT	110	BAGALKOT220- KERUR	KERUR_110	13:43	13:57	0:14	LINE FAULT
18	16-Feb-22	BAGALKOT	110	BAGALKOT220- KERUR	KERUR_110	14:00	18:37	4:37	LINE FAULT
19	16-Feb-22	BAGALKOT	110	BAGALKOT220-NAVANAGAR1	NAVANAGAR_110	10:01	10:09	0:08	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
20	16-Feb-22	BAGALKOT	110	BAGALKOT220-RAMDURA	STATION NOT AFFECTED BAGALKOT_220	15:49	18:38	2:49	LINE CLEAR AVAILED
21	16-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
22	16-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
23	16-Feb-22	BAGALKOT	110	HAVERI220-HANAGAL	HANAGAL_220	9:10	9:37	0:27	LINE FAULT
24	16-Feb-22	BAGALKOT	110	HIREHAL-MFR SOLAR	HIREHAHAL_110	18:44	18:50	0:06	HAND TRIPPED
25	16-Feb-22	BAGALKOT	110	HIREHAL-RON	HIREHAL_110	18:51	19:00	0:09	HAND TRIPPED
26	16-Feb-22	BAGALKOT	110	HIREHAL-RON	HIREHAL_110	19:06	19:13	0:07	HAND TRIPPED
27	16-Feb-22	BAGALKOT	110	HUBLI- SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:17	16:53	5:36	LINE CLEAR AVAILED
28	16-Feb-22	BAGALKOT	110	HUBLII- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	11:25	16:53	5:28	LINE CLEAR AVAILED
29	16-Feb-22	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	11:16	15:45	4:29	NFBC ISSUED
30	16-Feb-22	BAGALKOT	110	KADANAKOPPA-KAVALAWAD_110	KADANAKOPPA_110	22:02 (16.02.2022)			LINE OPEN:LINE FAULT
31	16-Feb-22	BAGALKOT	110	KALAGHATGI-KAVALWAD-HUBLI	KALAGHATGI-110	11:18	15:55	4:37	NFBC ISSUED
32	16-Feb-22	BAGALKOT	110	KULIGERI CROSS- MRN SUGARS	KULIGERI CROSS_110	13:42	14:03	0:21	LINE FAULT
33	16-Feb-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN:LINE CLEAR AVAILED
34	16-Feb-22	BAGALKOT	110	RON- GAMESHA	RON_110	14:13	14:15	0:02	HAND TRIPPED
35	16-Feb-22	BAGALKOT	110	RON- GAMESHA	RON_110	19:11	19:19	0:08	HAND TRIPPED
36	16-Feb-22	BAGALKOT	110	RON- HIREHAL	RON_110	19:00	19:10	0:10	LINE FAULT
37	16-Feb-22	BAGALKOT	110	RON- NAREGAL	RON_110	19:11	19:17	0:06	HAND TRIPPED
38	16-Feb-22	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	4:11	4:15	0:04	LINE FAULT
39	16-Feb-22	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110,GIRISAGAR_110,BISNAL_110,S HIRAGUPPI_110	12:14	12:18	0:04	HAND TRIPPED
40	16-Feb-22	BAGALKOT	110	VAJRAMATTI220-MANTUR(K D JUMBAGI)	STATION NOT AFFECTED K D JUMBAGI_110	10:40	15:22	4:42	LINE CLEAR AVAILED
41	16-Feb-22	BAGALKOT	110	VAJRAMATTI220-MELLIGERI	MELLIGERI_110	12:14	12:33	0:19	HAND TRIPPED
42	16-Feb-22	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI	12:14	12:32	0:18	HAND TRIPPED
43	16-Feb-22	BAGALKOT	110	VAJRAMATTI-JAMBAGI	JAMBAGI_110	10:40	15:42	5:02	LINE CLEAR AVAILED
44	16-Feb-22	BAGALKOT	110	YALLAMANAWADI- ALABAL	YALLAMANAWADI_110	4:11	4:19	0:08	LINE FAULT
45	16-Feb-22	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220	11:58	12:38	0:40	LINE CLEAR AVAILED
46	16-Feb-22	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI_220	16:38	18:01	1:23	LINE CLEAR AVAILED
47	16-Feb-22	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI_220	12:06	12:10	0:04	TRANSFORMER FAULT
48	16-Feb-22	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED VAJRAMATTI_220	12:13	12:15	0:02	TRANSFORMER FAULT
49	16-Feb-22	BAGALKOT	220	BALLIGAVI- RANEENNUR	STATION NOT AFFECTED RANEENNUR_220	10:43	11:30	0:47	HAND TRIPPED
50	16-Feb-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
51	16-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
52	16-Feb-22	BAGALKOT	220	KAKAMARI1 (RAVIURJA1)-ATHANI	STATION NOT AFFECTED ATHANI_220	6:47	20:24	13:37	NFBC ISSUED
53	16-Feb-22	BAGALKOT	220	KAKAMARI2 (RAVIURJA2)-ATHANI	STATION NOT AFFECTED ATHANI_220	6:47	20:24	13:37	NFBC ISSUED
54	16-Feb-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
55	16-Feb-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVALIED
56	16-Feb-22	BENGALURU	66	ABBIGERE - WELCASTE	ABBIGERE	23:42	23:50	0:08	LOAD CHANGEVER
57	16-Feb-22	BENGALURU	66	ALUR - NELAMANGALA 66	NO STATION AFFECTED	11:02	12:31	1:28	LINE CLEAR AVALIED
58	16-Feb-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	17:03	17:08	0:04	LOAD CHANGEVER
59	16-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA	9:05	10:00	0:55	LOAD CURTAILMENT
60	16-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	THONDEBHAVI	9:05	10:00	0:55	LOAD CURTAILMENT
61	16-Feb-22	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	10:20	10:30	0:10	LINE CLEAR AVALIED
62	16-Feb-22	BENGALURU	66	HV1	YARANDANAHALLI 220	17:20	17:25	0:05	LOAD CHANGEVER
63	16-Feb-22	BENGALURU	66	HV1	YARANDANAHALLI 220	18:16	18:26	0:10	LOAD CHANGEVER
64	16-Feb-22	BENGALURU	66	HV1	TK HALLI 220	10:29	10:36	0:07	TRANSFORMER FAULT
65	16-Feb-22	BENGALURU	66	HV1	CHAKAVELU	11:55	12:10	0:14	LINE CLEAR AVALIED
66	16-Feb-22	BENGALURU	66	HV1	CHAKAVELU	12:10	12:25	0:15	LINE CLEAR AVALIED
67	16-Feb-22	BENGALURU	66	HV1 CB	HUKUNDA	7:50	8:00	0:09	TRANSFORMER FAULT
68	16-Feb-22	BENGALURU	66	HV2	MAHALAKSHMI LAYOUT	14:35	14:40	0:05	LINE CLEAR AVALIED
69	16-Feb-22	BENGALURU	66	HV2	RR NAGAR	13:06	13:28	0:22	TRANSFORMER FAULT
70	16-Feb-22	BENGALURU	66	HV2	VIJAYANAGARA	13:01	13:06	0:05	LOAD CHANGEVER
71	16-Feb-22	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	8:19	8:52	0:33	LINE FAULT
72	16-Feb-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	11:11	13:14	2:02	LINE CLEAR AVALIED
73	16-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)	10:52(16/02/2022)	1914:27HRS	LINE CHARGED
74	16-Feb-22	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS 220	MAHALAKSHMI LAYOUT	16:10	17:10	1:00	LINE CLEAR AVALIED
75	16-Feb-22	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	6:05	6:28	0:23	LINE FAULT
76	16-Feb-22	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	14:25	14:27	0:02	LINE CLEAR AVALIED
77	16-Feb-22	BENGALURU	66	POTTERY ROAD - ITI 220	POTTERY ROAD	14:01	14:04	0:03	LINE CLEAR AVALIED
78	16-Feb-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	20:40	21:03	0:23	LINE FAULT
79	16-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	17:50	17:55	0:05	LOAD CHANGEVER
80	16-Feb-22	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	7:28	7:43	0:14	LINE FAULT
81	16-Feb-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	13:13	17:50	4:37	LOAD CURTAILMENT
82	16-Feb-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	23:57(16-2-2022)			LOAD CURTAILMENT
83	16-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
84	16-Feb-22	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66	7:20	7:25	0:05	MAIN SUPPLY FAILURE
85	16-Feb-22	GULBARGA	66	HV1	BENNEHALLI_66	16:10	16:20	0:10	TRANSFORMER FAULT
86	16-Feb-22	GULBARGA	66	HV1	PUNABGHATA_66	11:55	12:25	0:30	TRANSFORMER FAULT
87	16-Feb-22	GULBARGA	66	HV1	KUDLIGI_220	10:10	10:20	0:10	TRANSFORMER FAULT
88	16-Feb-22	GULBARGA	66	ITTAGI-HUVINHADAGALI	HUVINAHADGALI_66,HOLAGUNDI_66	18:08	18:17	0:09	LINE CLEAR AVALIED
89	16-Feb-22	GULBARGA	66	ITTAGI-HUVINHADAGALI	HUVINAHADGALI_66,HOLAGUNDI_66	11:25	11:30	0:05	LINE CLEAR AVALIED
90	16-Feb-22	GULBARGA	66	MAGALA-ITTAGGI	MAGALA_66	13:25	14:25	1:00	LINE CLEAR AVALIED
91	16-Feb-22	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66,UCHCHANGIDURGA_66	9:00	9:10	0:10	MAIN SUPPLY FAILURE
92	16-Feb-22	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI_66,YARAGUNTA_66,KUBURARAH ALI_66	10:40	10:45	0:05	LINE CLEAR AVALIED
93	16-Feb-22	GULBARGA	110	HV1	KAMALANAGAR_110	21:19	21:34	0:15	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
94	16-Feb-22	GULBARGA	110	HV1	GALAG_110	14:45	14:50	0:05	TRANSFORMER FAULT
95	16-Feb-22	GULBARGA	110	HV2	HATTI_110	8:42	8:49	0:07	TRANSFORMER FAULT
96	16-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	10:17	15:58	5:41	LOAD CHANGEOVER
97	16-Feb-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	3:00	3:10	0:10	LINE FAULT
98	16-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
99	16-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:23 (16.02.2022)			LINE OPEN:LINE CLEAR AVAILED
100	16-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	12:35	12:45	0:10	LINE FAULT
101	16-Feb-22	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	21:55	22:05	0:10	LINE FAULT
102	16-Feb-22	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	12:47	13:03	0:16	LINE FAULT
103	16-Feb-22	GULBARGA	110	YELBURGA-PARAMPUJYA	YELBURGA_110	12:48	13:08	0:20	LINE FAULT
104	16-Feb-22	GULBARGA	220	HV1	SEDAM_220	11:07	11:55	0:48	LINE CLEAR AVAILED
105	16-Feb-22	GULBARGA	220	HV1	KUSTAGI_220	12:47	13:00	0:13	TRANSFORMER FAULT
106	16-Feb-22	GULBARGA	220	HV1	ITTAGI_220	11:08	16:17	5:09	LINE CLEAR AVAILED
107	16-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
108	16-Feb-22	GULBARGA	220	HV2	ITTAGI_220	11:10	11:15	0:05	TRANSFORMER FAULT
109	16-Feb-22	GULBARGA	220	HV2	ITTAGI_220	12:56	13:00	0:04	TRANSFORMER FAULT
110	16-Feb-22	GULBARGA	220	HV2	ITTAGI_220	15:32	16:05	0:33	TRANSFORMER FAULT
111	16-Feb-22	GULBARGA	220	HV2	ITTAGI_220	16:12	19:28	3:16	TRANSFORMER FAULT
112	16-Feb-22	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	12:05	14:55	2:50	LINE CLEAR AVAILED
113	16-Feb-22	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	11:12	12:42	1:30	LINE CLEAR AVAILED
114	16-Feb-22	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	12:47	19:09	6:22	LINE FAULT
115	16-Feb-22	GULBARGA	220	RAICHUR-JURALA_IPP1 &2	RAICHUR_220	15:25	18:23	2:58	LINE CLEAR AVAILED
116	16-Feb-22	GULBARGA	400	RTPS-MUNIRABAD	MUNIRABAD_400	7:58	21:19	13:21	LINE CLEAR AVAILED
117	16-Feb-22	HASSAN	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	11:16	14:24	3:08	LINE CLEAR AVAILED
118	16-Feb-22	HASSAN	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	11:16	14:24	3:08	LINE CLEAR AVAILED
119	16-Feb-22	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	11:16	14:24	3:08	LINE CLEAR AVAILED
120	16-Feb-22	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:17	14:27	3:10	LINE CLEAR AVAILED
121	16-Feb-22	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	11:17	14:27	3:10	LINE CLEAR AVAILED
122	16-Feb-22	HASSAN	66	HV1	HNPURA_66	11:39	12:09	0:30	LINE CLEAR AVAILED
123	16-Feb-22	HASSAN	66	HV1	RAMPURA_66	11:14	12:24	1:10	LINE CLEAR AVAILED
124	16-Feb-22	HASSAN	66	HV1	CHANNARAYAPATNA_66	11:16	14:24	3:08	LINE CLEAR AVAILED
125	16-Feb-22	HASSAN	66	HV2	ARAKALGUD_66	11:49	11:55	0:06	TRANSFORMER FAULT
126	16-Feb-22	HASSAN	66	HV2	HNPURA_66	11:39	12:10	0:31	LINE CLEAR AVAILED
127	16-Feb-22	HASSAN	66	HV2	RAMPURA_66	11:45	12:24	0:39	LINE CLEAR AVAILED
128	16-Feb-22	HASSAN	66	HV2	SALAGAME_66	15:14	15:33	0:19	TRANSFORMER FAULT
129	16-Feb-22	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:16	14:25	3:09	LINE CLEAR AVAILED
130	16-Feb-22	HASSAN	66	KATTEPURA_MINIH	RAMNATHPURA_66	13:20	13:55	0:35	LINE CLEAR AVAILED
131	16-Feb-22	HASSAN	66	MATTANAV-DIDGTHL	MATTNAVILE_66	9:00	9:13	0:13	LINE FAULT
132	16-Feb-22	HASSAN	66	TAVAREC-IDLE	TAVARECHETTANAHALLY_66	20:56	21:05	0:09	LINE FAULT
133	16-Feb-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	12:25	14:25	2:00	LINE CLEAR AVAILED
134	16-Feb-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	9:17	16:41	7:24	NFBC ISSUED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
135	16-Feb-22	HASSAN	110	HV1	HIRIYADKA_66	10:48	14:52	4:04	LINE CLEAR AVAILED
136	16-Feb-22	HASSAN	110	HV2	HIRIYADKA_66	14:54	17:20	2:26	LINE CLEAR AVAILED
137	16-Feb-22	HASSAN	110	JOG-JST2	mghejog_gen	14:28	16:23	1:55	LINE CLEAR AVAILED
138	16-Feb-22	HASSAN	110	KADUR-NGNHL	KADUR_220	11:40	13:36	1:56	NFBC ISSUED
139	16-Feb-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	9:17	16:41	7:24	LINE CLEAR AVAILED
140	16-Feb-22	HASSAN	110	LV1	MSEZ_220	9:46	11:06	1:20	LINE CLEAR AVAILED
141	16-Feb-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	11:06	11:15	0:09	HAND TRIPPED
142	16-Feb-22	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	16:42	17:00	0:18	LINE CLEAR AVAILED
143	16-Feb-22	HASSAN	110	SAGARA-JST2	SAGARA_110	14:28	16:23	1:55	LINE CLEAR AVAILED
144	16-Feb-22	HASSAN	220	GERSOP-TALGUPA2	gen_gerusoppa	11:18(16.02.2022)			LINE OPEN:LINE CLEAR AVAILED
145	16-Feb-22	HASSAN	220	HV1	MSEZ_220	9:46	11:06	1:20	LINE CLEAR AVAILED
146	16-Feb-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	18:43	23:02	4:19	LINE CLEAR AVAILED
147	16-Feb-22	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	13:23(16.02.2022)			LINE OPEN:LINE CLEAR AVAILED
148	16-Feb-22	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	1:50	14:08	12:18	LINE FAULT
149	16-Feb-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:18(16.02.2022)			LINE OPEN:LINE CLEAR AVAILED
150	16-Feb-22	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	1:50	14:08	12:18	LINE FAULT
151	16-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	9:44	12:40	2:56	LINE CLEAR AVAILED
152	16-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
153	16-Feb-22	MYSURU	66	HEBBANI-SATTEGALA	NO STATIONS EFFECTED	10:46	12:02	1:16	LINE CLEAR AVAILED
154	16-Feb-22	MYSURU	66	HEBBANI-SFC 4	NO STATIONS EFFECTED	10:05	14:19	4:14	LINE CLEAR AVAILED
155	16-Feb-22	MYSURU	66	HEBBANI-SFC 5	NO STATIONS EFFECTED	10:05	14:19	4:14	LINE CLEAR AVAILED
156	16-Feb-22	MYSURU	66	HEBBANI-SFC 9	NO STATIONS EFFECTED	9:44	12:36	2:52	LINE CLEAR AVAILED
157	16-Feb-22	MYSURU	66	HEBBANI-SFC 9	NO STATIONS EFFECTED	10:47	12:32	1:45	LINE CLEAR AVAILED
158	16-Feb-22	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	10:05	14:19	4:14	LINE CLEAR AVAILED
159	16-Feb-22	MYSURU	66	HV1	SINDUVALLI_66	11:07	11:23	0:16	TRANSFORMER FAULT
160	16-Feb-22	MYSURU	66	HV1	THANDYA_66	10:38	10:41	0:02	HAND TRIPPED
161	16-Feb-22	MYSURU	66	HV1	HARADANAHALLI(JAK)_66	17:25	18:05	0:40	LINE CLEAR AVAILED
162	16-Feb-22	MYSURU	66	HV2	GVGUDI_66	8:40	10:01	1:20	LINE CLEAR AVAILED
163	16-Feb-22	MYSURU	66	HV2	KADABALLY_66	12:28	13:40	1:12	LINE CLEAR AVAILED
164	16-Feb-22	MYSURU	66	HV2	KADAKOLA_66	14:44	17:26	2:42	LINE CLEAR AVAILED
165	16-Feb-22	MYSURU	66	HV2	SFCSIVA_66	14:57	15:10	0:12	LINE CLEAR AVAILED
166	16-Feb-22	MYSURU	66	JAKKANAHALLI-NAGMANGLA	GUDDENHALLI_66 GMAILIGERE_66 BOGADHI_66 NAGAMANGALA_66	13:33	13:39	0:05	LINE FAULT
167	16-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
168	16-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN:LINE CLEAR AVAILED
169	16-Feb-22	MYSURU	66	MADHUVANAHALLI-DODDINDUVADI	NO STATIONS EFFECTED	14:10	15:31	1:20	LINE CLEAR AVAILED
170	16-Feb-22	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	11:12	13:10	1:58	LINE CLEAR AVAILED
171	16-Feb-22	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	13:21	14:08	0:47	LINE CLEAR AVAILED
172	16-Feb-22	MYSURU	66	PERIAPATNA-HANGUD	PONNAMPETE_66 VIRAJPETE_66	13:23	13:29	0:05	LINE FAULT
173	16-Feb-22	MYSURU	220	HV2	BEGUR_220	10:02:00 (15.2.2022)	21:02:00 (16.2.2022)	35:00 hrs	TRANSFORMER CHARGED
174	16-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	8:48	8:52	0:04	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
175	16-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	11:52	12:08	0:16	LINE FAULT
176	16-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	17:50	17:55	0:05	HAND TRIPPED
177	16-Feb-22	TUMKUR	66	CHITRADURGA 220KV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	0:48	8:13	7:24	LINE FAULT
178	16-Feb-22	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	11:21	11:31	0:10	LINE FAULT
179	16-Feb-22	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	12:38	13:48	1:10	LINE CLEAR AVAIED
180	16-Feb-22	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	14:36	14:52	0:15	LINE FAULT
181	16-Feb-22	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	15:07	15:15	0:07	LINE FAULT
182	16-Feb-22	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	16:39	16:54	0:15	LINE FAULT
183	16-Feb-22	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	17:29	17:45	0:15	LINE FAULT
184	16-Feb-22	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	6:15	6:27	0:11	LINE FAULT
185	16-Feb-22	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	12:11	12:38	0:26	LOAD CURTAILMENT
186	16-Feb-22	TUMKUR	66	HINDASGHATTA66-HIRIYUR220KV	HINDASGHATTA_66	8:33	8:39	0:05	MAIN SUPPLY FAILURE
187	16-Feb-22	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:45	6:47	0:01	LINE FAULT
188	16-Feb-22	TUMKUR	66	HIRIYUR 220KV- MATHOD	MATHOD_66	6:22	6:32	0:10	LINE FAULT
189	16-Feb-22	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	6:22	6:41	0:18	LINE FAULT
190	16-Feb-22	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	8:45	8:56	0:10	LINE FAULT
191	16-Feb-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	7:55	7:59	0:04	MAIN SUPPLY FAILURE
192	16-Feb-22	TUMKUR	66	HONNALLI 220KV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	13:56	14:07	0:11	LINE FAULT
193	16-Feb-22	TUMKUR	66	HONNALLI 220KV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	15:02	15:30	0:28	HAND TRIPPED
194	16-Feb-22	TUMKUR	66	HONNALLI 220KV- LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	7:03	7:13	0:09	LINE FAULT
195	16-Feb-22	TUMKUR	66	HONNALLI 220KV- LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	19:03	19:13	0:09	LINE FAULT
196	16-Feb-22	TUMKUR	66	HONNALLI 220KV- LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	23:08	23:19	0:10	LINE FAULT
197	16-Feb-22	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	17:58	18:14	0:16	MAIN SUPPLY FAILURE
198	16-Feb-22	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI	6:55	8:10	1:15	MAIN SUPPLY FAILURE
199	16-Feb-22	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI	8:49	9:05	0:16	HAND TRIPPED
200	16-Feb-22	TUMKUR	66	MATHOD-HOSADURGA	HOSADURGA_66	18:40	18:45	0:05	LINE FAULT
201	16-Feb-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	14:56	15:16	0:20	HAND TRIPPED
202	16-Feb-22	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	15:35	16:07	0:31	MAIN SUPPLY FAILURE
203	16-Feb-22	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	16:09	16:41	0:31	MAIN SUPPLY FAILURE
204	16-Feb-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	15:35	16:05	0:30	MAIN SUPPLY FAILURE
205	16-Feb-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	16:09	16:39	0:29	MAIN SUPPLY FAILURE
206	16-Feb-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	15:35	16:05	0:30	MAIN SUPPLY FAILURE
207	16-Feb-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	16:09	16:41	0:31	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
208	16-Feb-22	TUMKUR	66	THALLAK 220kV- P R PURA	MADHUGIRI_220	15:43	15:57	0:14	LINE FAULT
209	16-Feb-22	TUMKUR	66	THALLAK 220kV- P R PURA	MADHUGIRI_220	15:59	16:03	0:04	LINE FAULT
210	16-Feb-22	TUMKUR	66	TR-1	HIREHALLI_66	10:40	12:37	1:57	LINE CLEAR AVAILED
211	16-Feb-22	TUMKUR	66	TR-1	HIREHALLI_66	12:53	13:02	0:08	LINE CLEAR AVAILED
212	16-Feb-22	TUMKUR	66	TR-1	KADDAJI_66	14:19	14:25	0:06	TRANSFORMER FAULT
213	16-Feb-22	TUMKUR	66	TR-1	KADDAJI_66	18:32	18:39	0:07	TRANSFORMER FAULT
214	16-Feb-22	TUMKUR	66	TR-1	THIPPUR_66	17:57	18:00	0:02	TRANSFORMER FAULT
215	16-Feb-22	TUMKUR	66	TR-1	TURUVANUR_66	9:02	10:51	1:48	LINE CLEAR AVAILED
216	16-Feb-22	TUMKUR	66	TR-1 & 2	KDBVNP_220	17:24	18:57	1:33	LINE CLEAR AVAILED
217	16-Feb-22	TUMKUR	66	TR-2	ANTHARASANAHALLI_220	17:36	17:52	0:16	HAND TRIPPED
218	16-Feb-22	TUMKUR	66	TR-2	HIREHALLI_66	13:09	13:24	0:15	HAND TRIPPED
219	16-Feb-22	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	12:02	17:17	5:15	LINE CLEAR AVAILED
220	16-Feb-22	TUMKUR	110	HONNAVALLI 110- KADUR220(ARASEKERE)	HONNAVALLI_110	15:03	15:15	0:12	LINE FAULT
221	16-Feb-22	TUMKUR	110	HONNAVALLI 110-TIPTUR	TIPTUR_110,	15:15	15:45	0:29	LOAD CURTAILMENT
222	16-Feb-22	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	22:54	23:17	0:22	HAND TRIPPED
223	16-Feb-22	TUMKUR	110	TR-1	TURUVEKERE 110	15:32	15:52	0:20	TRANSFORMER FAULT
224	16-Feb-22	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	11:19	17:22	6:03	NFBC ISSUED
225	16-Feb-22	TUMKUR	220	TR-1	KDBVNP_220	10:11	10:16	0:05	LINE CLEAR AVAILED
226	16-Feb-22	TUMKUR	220	TR-2	ANTHRASANAHALLI 220	17:36	17:51	0:14	TRANSFORMER FAULT
227	16-Feb-22	TUMKUR	220	TR-2	KB CROSS_220	17:58	17:59	0:01	TRANSFORMER FAULT
228	16-Feb-22	TUMKUR	220	TR-2	KDBVNP_220	10:21	18:56	8:35	LINE CLEAR AVAILED
229	16-Feb-22	TUMKUR	220	TR-3	ANTHRASANAHALLI 220	17:36	17:52	0:15	TRANSFORMER FAULT
230	16-Feb-22	TUMKUR	220	TR-3	HIRIYUR_220	6:22	6:32	0:10	TRANSFORMER FAULT
231	16-Feb-22	TUMKUR	220	TR-3	HIRIYUR_220	8:45	8:54	0:08	TRANSFORMER FAULT
1	17-Feb-22	BAGALKOT	110	110/11KV, HV1	BASAVANAKATTI_110	14:10	14:29	0:19	LINE CLEAR AVAILED
2	17-Feb-22	BAGALKOT	110	110/11KV, HV1	ANKOLA_110	12:13	19:18	7:05	LINE CLEAR AVAILED
3	17-Feb-22	BAGALKOT	110	110/11KV, HV1	ANKOLA_110	19:50	20:49	0:59	LINE CLEAR AVAILED
4	17-Feb-22	BAGALKOT	110	110/11KV, HV1	GOPPANAKOPPA_110	11:31	12:13	0:42	LINE CLEAR AVAILED
5	17-Feb-22	BAGALKOT	110	110/11KV, HV1	TAKKALAKI_110	12:49	13:44	0:55	HAND TRIPPED
6	17-Feb-22	BAGALKOT	110	110/11KV, HV1	SHIGGOAN_110	10:02	17:44	7:42	LINE CLEAR AVAILED
7	17-Feb-22	BAGALKOT	110	110/11KV, HV1	MUNAVALLI_110	18:44	19:32	0:48	LINE CLEAR AVAILED
8	17-Feb-22	BAGALKOT	110	110/11KV, HV2	ANKALI_110	14:15	14:25	0:10	LINE CLEAR AVAILED
9	17-Feb-22	BAGALKOT	110	110/11KV, HV2	BASAVANAKATTI_110	14:30	14:52	0:22	LINE CLEAR AVAILED
10	17-Feb-22	BAGALKOT	110	110/11KV, HV2	MUKARTHIHAL_110	18:02	18:07	0:05	TRANSFORMER FAULT
11	17-Feb-22	BAGALKOT	110	110/11KV, HV2	SHIGGOAN_110	15:47	17:35	1:48	LINE CLEAR AVAILED
12	17-Feb-22	BAGALKOT	110	110/11KV, HV2	SALAHALLI_110	10:48	11:03	0:15	LINE CLEAR AVAILED
13	17-Feb-22	BAGALKOT	110	110/11KV, HV2	MUNAVALLI_110	17:35	18:44	1:09	LINE CLEAR AVAILED
14	17-Feb-22	BAGALKOT	110	110/33KV, HV3	SHIGGOAN_110, AMBUJA_33, SHIGGOAN_33	10:02	17:44	7:42	LINE CLEAR AVAILED
15	17-Feb-22	BAGALKOT	110	AMBEWADI- NK2 (KAVALWADA)	KAVALWADA_110	11:34	11:53	0:19	HAND TRIPPED
16	17-Feb-22	BAGALKOT	110	AMBEWADI- NK2 (KAVALWADA)	KAVALWADA_110	13:17	14:23	1:06	LINE CLEAR AVAILED
17	17-Feb-22	BAGALKOT	110	ANKOLA-ARGA	ARGA_110	19:05	19:07	0:02	HAND TRIPPED
18	17-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
19	17-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
20	17-Feb-22	BAGALKOT	110	KADANAKOPPA-KAVALAWAD_110	STATION NOT AFFECTED KADANAKOPPA_110	22:02 (16.02.2022)			LINE OPEN:LINE FAULT
21	17-Feb-22	BAGALKOT	110	KUMTA-SIRSI1KRCL(RAILWAY)	STATION NOT AFFECTED KUMTA_110	9:10	9:28	0:18	LINE FAULT
22	17-Feb-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN:LINE CLEAR AVAILED
23	17-Feb-22	BAGALKOT	110	VAJRAMATTI220-JAMBAGI	STATION NOT AFFECTED JAMBAGI_110	12:05	17:20	5:15	LINE CLEAR AVAILED
24	17-Feb-22	BAGALKOT	110	VAJRAMATTI220-JAMBAGI	STATION NOT AFFECTED VAJRAMATTI_220	12:05	17:23	5:18	LINE CLEAR AVAILED
25	17-Feb-22	BAGALKOT	220	220/110KV,HV1,LV1	VAJRAMATTI_220	16:35	18:04	1:29	LINE CLEAR AVAILED
26	17-Feb-22	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
27	17-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
28	17-Feb-22	BAGALKOT	220	KAKAMARI1-ATHANI	STATION NOT AFFECTED ATHANI_220	7:08	18:46	11:38	NFBC ISSUED
29	17-Feb-22	BAGALKOT	220	KAKAMARI2-ATHANI	STATION NOT AFFECTED ATHANI_220	7:08	18:46	11:38	NFBC ISSUED
30	17-Feb-22	BAGALKOT	220	KARWAR- KADRA1	STATION NOT AFFECTED KARWAR_220	10:01	12:16	2:15	LINE CLEAR AVAILED
31	17-Feb-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
32	17-Feb-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
33	17-Feb-22	BENGALURU	66	ABBIGERE - YELAHANKA 220	ABBIGERE	0:50	0:58	0:08	LOAD CHANGEOVER
34	17-Feb-22	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI	9:14	9:19	0:05	LOAD CHANGEOVER
35	17-Feb-22	BENGALURU	66	ATTIBELE - SARJAPUR 220	ATTIBELE	12:00	12:15	0:15	LOAD CHANGEOVER
36	17-Feb-22	BENGALURU	66	ATTIBELE - YARANDANAHALLI 220	ATTIBELE	16:15	16:20	0:05	LOAD CHANGEOVER
37	17-Feb-22	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	6:30	6:34	0:04	LOAD CHANGEOVER
38	17-Feb-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:49	11:57	0:08	LOAD CURTAILMENT
39	17-Feb-22	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	10:20	15:31	5:11	LINE CLEAR AVAILED
40	17-Feb-22	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	10:00	16:10	6:10	LINE CLEAR AVAILED
41	17-Feb-22	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	7:39	7:44	0:05	LOAD CHANGEOVER
42	17-Feb-22	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	7:36	7:40	0:04	LOAD CHANGEOVER
43	17-Feb-22	BENGALURU	66	HV1	HSR LAYOUT 220	9:17	9:23	0:06	LOAD CHANGEOVER
44	17-Feb-22	BENGALURU	66	HV1	SM MANGALA	12:05	12:37	0:31	LINE CLEAR AVAILED
45	17-Feb-22	BENGALURU	66	HV1	NANDIGANAHALLI	14:23	14:28	0:04	LINE CLEAR AVAILED
46	17-Feb-22	BENGALURU	66	HV1	NANDIGANAHALLI	13:00	13:05	0:05	LINE CLEAR AVAILED
47	17-Feb-22	BENGALURU	66	HV1	MULBAGLU	14:02	14:18	0:15	TRANSFORMER FAULT
48	17-Feb-22	BENGALURU	66	HV1	KAMASAMUDRA	14:50	16:10	1:20	LINE CLEAR AVAILED
49	17-Feb-22	BENGALURU	66	HV1	KAMASAMUDRA	12:06	12:10	0:03	LINE CLEAR AVAILED
50	17-Feb-22	BENGALURU	66	HV1	HUKUNDA	9:05	9:15	0:09	TRANSFORMER FAULT
51	17-Feb-22	BENGALURU	66	HV1	HUKUNDA	10:10	10:17	0:07	TRANSFORMER FAULT
52	17-Feb-22	BENGALURU	66	HV1	DODDABELAVANGALA	16:05	16:50	0:44	LINE CLEAR AVAILED
53	17-Feb-22	BENGALURU	66	HV1	SANKALGERE(BAIRAPATNA)	10:17	10:25	0:07	LINE CLEAR AVAILED
54	17-Feb-22	BENGALURU	66	HV2	ELECTRONIC CITY	21:14	22:18	1:04	LOAD CHANGEOVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
55	17-Feb-22	BENGALURU	66	HV2	ISRO LAYOUT	14:20	14:22	0:02	LINE CLEAR AVAILED
56	17-Feb-22	BENGALURU	66	HV3	ADUGODI	13:31	13:33	0:02	LINE CLEAR AVAILED
57	17-Feb-22	BENGALURU	66	HV3	BANASHANKARI	15:46	15:47	0:01	LINE CLEAR AVAILED
58	17-Feb-22	BENGALURU	66	HV3	ELECTRONIC CITY	0:22	5:20	4:58	TRANSFORMER FAULT
59	17-Feb-22	BENGALURU	66	HV3	EPIP 220	14:09	14:41	0:32	LINE CLEAR AVAILED
60	17-Feb-22	BENGALURU	66	HV3	EPIP 220	19:32	19:52	0:20	LINE CLEAR AVAILED
61	17-Feb-22	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)	10:52(17/02/2022)	1914:27HRS	LINE CHARGED
62	17-Feb-22	BENGALURU	66	SRINIVASPURA - DALASNUR	YELDUR	3:46	3:56	0:09	LINE FAULT
63	17-Feb-22	BENGALURU	66	SRINIVASPURA - DALASNUR	YELDUR	12:55	13:42	0:47	LINE CLEAR AVAILED
64	17-Feb-22	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	6:15	6:28	0:13	LOAD CHANGEOVER
65	17-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	14:52	15:08	0:16	LOAD CHANGEOVER
66	17-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	15:08	15:13	0:05	LOAD CHANGEOVER
67	17-Feb-22	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	10:17	16:29	6:11	LINE CLEAR AVAILED
68	17-Feb-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	10:03	22:53	12:50	LOAD CURTAILMENT
69	17-Feb-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	23:57(16-2-2022)	3:30(17-2-2022)	3:33 hrs	LINE CHARGED
70	17-Feb-22	BENGALURU	220	HV1	YARANDANAHALLI 220	14:00	14:51	0:51	TRANSFORMER FAULT
71	17-Feb-22	BENGALURU	220	HV1	YARANDANAHALLI 220	14:51	15:05	0:14	TRANSFORMER FAULT
72	17-Feb-22	BENGALURU	220	HV1	YARANDANAHALLI 220	15:08	17:10	2:02	TRANSFORMER FAULT
73	17-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
74	17-Feb-22	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	16:39	19:45	3:06	LINE FAULT
75	17-Feb-22	BENGALURU	220	SUBRAMANYAPURA 220 - SRS PEENYA 220	NO STATION AFFECTED	16:39	19:45	3:06	LINE FAULT
76	17-Feb-22	GULBARGA	66	NEELAGUNDA-HP HALLI1	HP HALLI_66	7:33	7:40	0:07	LINE FAULT
77	17-Feb-22	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHCHANGIDURGA_66	2:22	2:33	0:11	LINE FAULT
78	17-Feb-22	GULBARGA	110	HALAKUNDI-ALIPUR	HALAKUNDI_110	14:56	15:14	0:18	MAIN SUPPLY FAILURE
79	17-Feb-22	GULBARGA	110	HV1	GANDHINAGAR_110	16:37	17:02	0:25	LINE CLEAR AVAILED
80	17-Feb-22	GULBARGA	110	HV1,HV2	NALWAR_110	9:30	13:10	3:40	LINE CLEAR AVAILED
81	17-Feb-22	GULBARGA	110	HV2	GULBARGAUNIVERSITY_110	16:13	16:53	0:40	TRANSFORMER FAULT
82	17-Feb-22	GULBARGA	110	HV2	GULBARGAUNIVERSITY_110	18:05	19:30	1:25	LINE CLEAR AVAILED
83	17-Feb-22	GULBARGA	110	HV3	VALKAMDINNI_110	6:42	6:47	0:05	TRANSFORMER FAULT
84	17-Feb-22	GULBARGA	110	HV3	VALKAMDINNI_110	16:58	17:04	0:06	TRANSFORMER FAULT
85	17-Feb-22	GULBARGA	110	KEREHALLI-MUNIRABAD	KEREHALLI_110	9:45	9:50	0:05	MAIN SUPPLY FAILURE
86	17-Feb-22	GULBARGA	110	KEREHALLI-MUNIRABAD	KEREHALLI_110	11:05	11:15	0:10	MAIN SUPPLY FAILURE
87	17-Feb-22	GULBARGA	110	KEREHALLI-TALAKUTAI	KEREHALLI_110	18:37	20:38	2:01	LINE CLEAR AVAILED
88	17-Feb-22	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110	14:57	15:16	0:19	MAIN SUPPLY FAILURE
89	17-Feb-22	GULBARGA	110	KUDITINI-IDLE	TORANGALU_110	8:45	18:32	9:47	LINE CLEAR AVAILED
90	17-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	10:06	16:15	6:09	LOAD CHANGEOVER
91	17-Feb-22	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	2:41	2:50	0:09	LINE FAULT
92	17-Feb-22	GULBARGA	110	METRI-ALIPUR	METRI_110	8:45	8:50	0:05	MAIN SUPPLY FAILURE
93	17-Feb-22	GULBARGA	110	METRI-ALIPUR	METRI_110	18:23	18:33	0:10	MAIN SUPPLY FAILURE
94	17-Feb-22	GULBARGA	110	MUDDAPURA-MASKI	MASKI_110	21:20	21:26	0:06	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
95	17-Feb-22	GULBARGA	110	MUDDAPURA-SINDHANOOR	MUDDAPURA_110	0:54	1:00	0:06	MAIN SUPPLY FAILURE
96	17-Feb-22	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110,MALLAPUR_110	9:45	9:50	0:05	LINE FAULT
97	17-Feb-22	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	9:30	13:05	3:35	MAIN SUPPLY FAILURE
98	17-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR	GOOGLE_110	22:05	22:10	0:05	LINE FAULT
99	17-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
100	17-Feb-22	GULBARGA	110	SHAHABAD-RAICHUR2	NALWAR_110	9:40	13:05	3:25	LINE CLEAR AVAILED
101	17-Feb-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGER A_110,SANNATHI_IPP,COREGREENSUGARS_IPP	2:27	2:31	0:04	LINE FAULT
102	17-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:23 (16.02.2022)	9:17 (17.02.2022)	21:54 HRS	LINE CHARGED
103	17-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	12:35	18:20	5:45	LINE CLEAR AVAILED
104	17-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	2:50	3:05	0:15	LINE FAULT
105	17-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	18:05	18:15	0:10	LINE FAULT
106	17-Feb-22	GULBARGA	110	SIRIGERICROSS-KURUGOD	SIRIGERICROSS_110	8:36	19:40	11:04	LOAD CHANGEVER
107	17-Feb-22	GULBARGA	110	VALKAMDINNI-SINDHANOOR110	VALKAMDINNI_110	0:50	1:00	0:10	MAIN SUPPLY FAILURE
108	17-Feb-22	GULBARGA	220	HV 1	ALLIPUR_220	14:08	17:52	3:44	LINE CLEAR AVAILED
109	17-Feb-22	GULBARGA	220	HV 2	ALLIPUR_220	8:42	14:24	5:42	LINE CLEAR AVAILED
110	17-Feb-22	GULBARGA	220	HV 2	ALLIPUR_220	14:56	15:01	0:05	TRANSFORMER FAULT
111	17-Feb-22	GULBARGA	220	HV1	SEDAM_220	11:02	11:34	0:32	LINE CLEAR AVAILED
112	17-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
113	17-Feb-22	GULBARGA	220	KAPNOOR-HUMNABAD 2	KAPNOOR_220	13:10	19:46	6:36	LINE CLEAR AVAILED
114	17-Feb-22	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	11:34	16:34	5:00	LINE CLEAR AVAILED
115	17-Feb-22	GULBARGA	220	KUSTAGI-SULEKAL	SULEKAL_220	17:00	18:50	1:50	LINE FAULT
116	17-Feb-22	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	19:39	20:07	0:28	LINE FAULT
117	17-Feb-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	5:40	6:21	0:41	LINE FAULT
118	17-Feb-22	GULBARGA	220	SHAHABAD-SHAHAPUR	SHAHABAD_220	19:37	19:56	0:19	LINE FAULT
119	17-Feb-22	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	11:17	15:10	3:53	LINE CLEAR AVAILED
120	17-Feb-22	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	19:37	19:53	0:16	LINE FAULT
121	17-Feb-22	HASSAN	66	HV1	SINGAPURA_66	8:30	10:10	1:40	LINE CLEAR AVAILED
122	17-Feb-22	HASSAN	66	HV1	MALLAPURA_66	16:10	19:24	3:14	MAIN SUPPLY FAILURE
123	17-Feb-22	HASSAN	66	HV2	MALLAPURA_66	16:10	19:24	3:14	MAIN SUPPLY FAILURE
124	17-Feb-22	HASSAN	66	MALLAPU-SHIMOGA	MALLAPURA_66	16:10	19:24	3:14	MAIN SUPPLY FAILURE
125	17-Feb-22	HASSAN	66	MRSSHM-DVG1	MRSMG_220	7:55	11:04	3:09	LINE FAULT
126	17-Feb-22	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	18:54	19:13	0:19	LINE FAULT
127	17-Feb-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	8:15	11:25	3:10	LINE CLEAR AVAILED
128	17-Feb-22	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	13:39	14:18	0:39	HAND TRIPPED
129	17-Feb-22	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	8:15	11:25	3:10	LINE CLEAR AVAILED
130	17-Feb-22	HASSAN	110	BARANG-ANVATTI	BARANGI_110	14:05	14:15	0:10	HAND TRIPPED
131	17-Feb-22	HASSAN	110	BARANG-ANVATTI	BARANGI_110	15:55	16:20	0:25	HAND TRIPPED
132	17-Feb-22	HASSAN	110	BARANG-SHR220	BARANGI_110	9:35	11:30	1:55	NFBC ISSUED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
133	17-Feb-22	HASSAN	110	HV1	PUTTUR_110	9:00	19:22	10:22	MAIN SUPPLY FAILURE
134	17-Feb-22	HASSAN	110	HV1	GURUVAYANAKERE_110	10:23	13:39	3:16	LINE CLEAR AVAIED
135	17-Feb-22	HASSAN	110	HV1	KARAYA_110	19:13	19:37	0:24	HAND TRIPPED
136	17-Feb-22	HASSAN	110	HV1	KONAJE_110	8:56	9:00	0:04	HAND TRIPPED
137	17-Feb-22	HASSAN	110	HV1	KONAJE_110	10:53	10:56	0:03	HAND TRIPPED
138	17-Feb-22	HASSAN	110	HV1	SHIRALKOPPA_220	15:55	16:05	0:10	TRANSFORMER FAULT
139	17-Feb-22	HASSAN	110	HV2	PUTTUR_110	9:00	19:22	10:22	MAIN SUPPLY FAILURE
140	17-Feb-22	HASSAN	110	HV2	ANAVATTI_110	11:18	11:33	0:15	TRANSFORMER FAULT
141	17-Feb-22	HASSAN	110	HV2	GURUVAYANAKERE_110	11:57	14:28	2:31	LINE CLEAR AVAIED
142	17-Feb-22	HASSAN	110	HV2	KARAYA_110	19:13	19:37	0:24	HAND TRIPPED
143	17-Feb-22	HASSAN	110	HV2	KEMAR_220	2:47	7:01	4:14	TRANSFORMER FAULT
144	17-Feb-22	HASSAN	110	HV2	KONAJE_110	8:56	9:00	0:04	HAND TRIPPED
145	17-Feb-22	HASSAN	110	HV2	KONAJE_110	10:53	10:56	0:03	HAND TRIPPED
146	17-Feb-22	HASSAN	110	HV2	KONAJE_110	8:56	9:00	0:04	HAND TRIPPED
147	17-Feb-22	HASSAN	110	HV2	SHIRALKOPPA_220	15:55	16:05	0:10	TRANSFORMER FAULT
148	17-Feb-22	HASSAN	110	HV3	PUTTUR_110	9:00	19:22	10:22	MAIN SUPPLY FAILURE
149	17-Feb-22	HASSAN	110	HV3	GURUVAYANAKERE_110	13:36	16:54	3:18	LINE CLEAR AVAIED
150	17-Feb-22	HASSAN	110	HV3	KONAJE_110	10:53	10:56	0:03	HAND TRIPPED
151	17-Feb-22	HASSAN	110	HV4	PUTTUR_110	9:00	19:22	10:22	MAIN SUPPLY FAILURE
152	17-Feb-22	HASSAN	110	JOG110-LPH	JOG_110	16:09	17:55	1:46	LINE CLEAR AVAIED
153	17-Feb-22	HASSAN	110	JOG-JLT4	mghejog_gen	16:10	17:40	1:30	NFBC ISSUED
154	17-Feb-22	HASSAN	110	KEMAR-Manipal2	KEMAR_220	9:25	16:16	6:51	LINE CLEAR AVAIED
155	17-Feb-22	HASSAN	110	LPH-MGHE 1	lph_gen	16:10	18:01	1:51	NFBC ISSUED
156	17-Feb-22	HASSAN	110	LV1	SHIRALKOPPA_220	15:55	16:05	0:10	MAIN SUPPLY FAILURE
157	17-Feb-22	HASSAN	110	LV2	SHIRALKOPPA_220	15:55	16:05	0:10	MAIN SUPPLY FAILURE
158	17-Feb-22	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	9:24	16:16	6:52	NFBC ISSUED
159	17-Feb-22	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	8:54	19:24	10:30	LINE CLEAR AVAIED
160	17-Feb-22	HASSAN	110	PUTTURP-UTUR 2	PUTTUR_220	9:02	10:46	1:44	LINE CLEAR AVAIED
161	17-Feb-22	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	9:00	19:18	10:18	LINE CLEAR AVAIED
162	17-Feb-22	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	9:01	17:07	8:06	LINE CLEAR AVAIED
163	17-Feb-22	HASSAN	110	SAGARA-SORABA	SAGARA_110	15:55	16:34	0:39	LINE FAULT
164	17-Feb-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	8:20	8:30	0:10	LINE FAULT
165	17-Feb-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	9:34	14:00	4:26	LINE CLEAR AVAIED
166	17-Feb-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	15:55	16:23	0:28	MAIN SUPPLY FAILURE
167	17-Feb-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	15:55	16:00	0:05	MAIN SUPPLY FAILURE
168	17-Feb-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	15:55	16:00	0:05	MAIN SUPPLY FAILURE
169	17-Feb-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	15:55	16:05	0:10	MAIN SUPPLY FAILURE
170	17-Feb-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	15:55	16:00	0:05	MAIN SUPPLY FAILURE
171	17-Feb-22	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	11:18(16.02.2022)	13:26(17.02.2022)	26:08hrs	LINE CHARGED
172	17-Feb-22	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:37	19:10	5:33	LINE FAULT
173	17-Feb-22	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:23(16.02.2022)			LINE OPEN:LINE CLEAR AVAIED
174	17-Feb-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:18(16.02.2022)	13:26(17.02.2022)	26:08hrs	LINE CHARGED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
175	17-Feb-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:37	19:05	5:28	LINE FAULT
176	17-Feb-22	MYSURU	66	HANNUR-MADHUVANAHALLY1	NO STATIONS EFFECTED	10:16	11:57	1:40	NFBC ISSUED
177	17-Feb-22	MYSURU	66	HANNUR-MADHUVANAHALLY2	NO STATIONS EFFECTED	12:02	12:54	0:52	NFBC ISSUED
178	17-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
179	17-Feb-22	MYSURU	66	HV1	HUNSUR_66	17:44	19:04	1:19	HAND TRIPPED
180	17-Feb-22	MYSURU	66	HV1	MADIKERI_66	8:45	8:50	0:04	HAND TRIPPED
181	17-Feb-22	MYSURU	66	HV1	MANDYA_66	15:03	15:33	0:30	LINE CLEAR AVAILED
182	17-Feb-22	MYSURU	66	HV2	MADIKERI_66	8:45	8:50	0:04	HAND TRIPPED
183	17-Feb-22	MYSURU	66	HV2	MANDYA_66	13:13	15:01	1:47	LINE CLEAR AVAILED
184	17-Feb-22	MYSURU	66	HV2	SFCSIVA_66	10:48	10:53	0:04	HAND TRIPPED
185	17-Feb-22	MYSURU	66	KABHALLY-CLEAR SOLAR	NO STATIONS EFFECTED	18:25	18:39	0:13	LINE FAULT
186	17-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
187	17-Feb-22	MYSURU	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	7:29	7:36	0:07	LINE FAULT
188	17-Feb-22	MYSURU	66	KADAKOLA-NANJANGUD1	NO STATIONS EFFECTED	15:32:22 (17.2.22)			LINE OPEN:LINE CLEAR AVAILED
189	17-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN:LINE CLEAR AVAILED
190	17-Feb-22	MYSURU	66	KOLLEGALA-CRNAGARA	NO STATIONS EFFECTED	14:25	14:29	0:04	LINE FAULT
191	17-Feb-22	MYSURU	66	MADHUVANALLI-HANNUR1	NO STATIONS EFFECTED	10:16	11:57	1:40	LINE CLEAR AVAILED
192	17-Feb-22	MYSURU	66	MADHUVANALLI-HANNUR2	NO STATIONS EFFECTED	12:01	12:53	0:52	LINE CLEAR AVAILED
193	17-Feb-22	MYSURU	66	MADHUVANALLI-MAMBALLI	NO STATIONS EFFECTED	13:22	14:06	0:43	LINE CLEAR AVAILED
194	17-Feb-22	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	19:01	19:49	0:48	LINE CLEAR AVAILED
195	17-Feb-22	MYSURU	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	7:00	7:05	0:05	LINE FAULT
196	17-Feb-22	MYSURU	220	HV1	KADAKOLA_220 DOORA_66 HURA_66 HULLAHALLI_66 NANJANGUD_66 THANDYA_66 JAYAPURA_66 HAMPAPURA_66 CHANDRAWADI_66	15:28	16:03	0:34	TRANSFORMER FAULT
197	17-Feb-22	MYSURU	220	HV2	BEGUR_220	10:45	12:25	1:40	LINE CLEAR AVAILED
198	17-Feb-22	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	6:58	18:33	11:35	LINE CLEAR AVAILED
199	17-Feb-22	TUMKUR	66	BADAVANAHALLI-MADHUGIRI66	BADAVANAHALLI_66	10:14	13:39	3:24	MAIN SUPPLY FAILURE
200	17-Feb-22	TUMKUR	66	BALENAHALI66- FEFCWINDWIND IPP_66	FEFCWINDWIND_IPP_66	9:25	19:05	9:39	LINE CLEAR AVAILED
201	17-Feb-22	TUMKUR	66	BHARAMAGIRI66-MATHOD66	BHARAMAGIRI_66	21:05	22:05	1:00	LINE FAULT
202	17-Feb-22	TUMKUR	66	BHARAMAGIRI66-SRS 220KV HIRIYUR	BHARAMAGIRI_66	21:35	22:00	0:25	MAIN SUPPLY FAILURE
203	17-Feb-22	TUMKUR	66	BHARAMAGIRI66-SRS 220KV HIRIYUR	BHARAMAGIRI_66	22:45	23:00	0:15	MAIN SUPPLY FAILURE
204	17-Feb-22	TUMKUR	66	CHANNAGIRI- LINGADHALLI(CHANNAGIRI)	CHANNAGIRI_66	10:09	16:28	6:18	LINE CLEAR AVAILED
205	17-Feb-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	13:05	14:05	1:00	MAIN SUPPLY FAILURE
206	17-Feb-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	14:17	14:50	0:33	MAIN SUPPLY FAILURE
207	17-Feb-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	17:40	18:10	0:30	MAIN SUPPLY FAILURE
208	17-Feb-22	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	16:22	17:56	1:34	LINE CLEAR AVAILED
209	17-Feb-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	15:45	15:55	0:09	LINE FAULT
210	17-Feb-22	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	11:01	17:23	6:22	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
211	17-Feb-22	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	14:43	16:27	1:43	MAIN SUPPLY FAILURE
212	17-Feb-22	TUMKUR	66	MADHUGIRI 66KV- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	10:01	18:57	8:55	LINE CLEAR AVAILED
213	17-Feb-22	TUMKUR	66	PANDARAHALLI- CHITRADURGA220 1	PANDARAHALLI_66	16:23	18:00	1:37	LINE CLEAR AVAILED
214	17-Feb-22	TUMKUR	66	PANDARAHALLI- CHITRADURGA220 3	PANDARAHALLI_66	16:23	18:00	1:37	LINE CLEAR AVAILED
215	17-Feb-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	15:09	15:19	0:10	LINE FAULT
216	17-Feb-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	16:23	18:00	1:37	LINE CLEAR AVAILED
217	17-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	13:48	14:12	0:24	MAIN SUPPLY FAILURE
218	17-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	14:17	15:01	0:44	MAIN SUPPLY FAILURE
219	17-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	16:37	16:43	0:05	LINE FAULT
220	17-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	17:40	18:11	0:30	MAIN SUPPLY FAILURE
221	17-Feb-22	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	13:48	14:12	0:23	MAIN SUPPLY FAILURE
222	17-Feb-22	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	14:17	15:01	0:44	MAIN SUPPLY FAILURE
223	17-Feb-22	TUMKUR	66	PD KOTE66-AZURE POWER _IPP_66	AZURE POWER _IPP_66	17:40	18:12	0:31	MAIN SUPPLY FAILURE
224	17-Feb-22	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	13:48	15:30	1:41	MAIN SUPPLY FAILURE
225	17-Feb-22	TUMKUR	66	PD KOTE66-SOLITAIRE _IPP_66	SOLITAIRE _IPP_66	17:40	18:53	1:13	MAIN SUPPLY FAILURE
226	17-Feb-22	TUMKUR	66	SAVALANGA 66KV-HNLI220_NYMT	SAVALANGA_66	16:33	18:01	1:28	MAIN SUPPLY FAILURE
227	17-Feb-22	TUMKUR	66	SIRA66-MADHUGIRI220	SIRA_66	11:32	13:33	2:01	LINE CLEAR AVAILED
228	17-Feb-22	TUMKUR	66	SIRA66-MADHUGIRI220	SIRA_66	21:03	21:13	0:09	LINE FAULT
229	17-Feb-22	TUMKUR	66	TR-1	MADHUGIRI_66	10:01	18:57	8:55	LINE CLEAR AVAILED
230	17-Feb-22	TUMKUR	66	TR-1	CHANNAGIRI(LING)	10:08	16:28	6:19	LINE CLEAR AVAILED
231	17-Feb-22	TUMKUR	66	TR-1	DEVARAHALLI_66	11:01	17:23	6:22	MAIN SUPPLY FAILURE
232	17-Feb-22	TUMKUR	66	TR-1	CHIKKABANAGERE_66	16:22	16:36	0:14	TRANSFORMER FAULT
233	17-Feb-22	TUMKUR	66	TR-1	HONNALLI_66	17:39	19:18	1:38	LINE CLEAR AVAILED
234	17-Feb-22	TUMKUR	66	TR-1	RANGANATHAPURA_66	8:17	8:53	0:35	LINE CLEAR AVAILED
235	17-Feb-22	TUMKUR	66	TR-1	SAVALANGA_66	16:33	18:01	1:28	MAIN SUPPLY FAILURE
236	17-Feb-22	TUMKUR	66	TR-1	SANTEMVATTUR_66	9:48	9:52	0:04	TRANSFORMER FAULT
237	17-Feb-22	TUMKUR	66	TR-2	MADHUGIRI_66	10:01	18:57	8:55	LINE CLEAR AVAILED
238	17-Feb-22	TUMKUR	66	TR-2	CHANNAGIRI(LING)	10:08	16:28	6:19	LINE CLEAR AVAILED
239	17-Feb-22	TUMKUR	66	TR-2	BUKKAPATNA_66	19:36	19:46	0:09	LINE CLEAR AVAILED
240	17-Feb-22	TUMKUR	66	TR-2	HONNUDIKE_66	3:17	3:21	0:03	TRANSFORMER FAULT
241	17-Feb-22	TUMKUR	66	TR-2	LINGADAHALLY_66	15:08	15:13	0:04	TRANSFORMER FAULT
242	17-Feb-22	TUMKUR	110	K G TEMPLE-NITTUR220	KGTEMPLE_110	11:40	14:10	2:30	LINE CLEAR AVAILED
243	17-Feb-22	TUMKUR	110	K G TEMPLE-UNGRDLI(DADEHALLI)	KGTEMPLE_110	11:40	14:11	2:31	LINE CLEAR AVAILED
244	17-Feb-22	TUMKUR	110	NITTUR 220-AMMASANDRA110	AMMASANDRA_110,SAMPIGE_110	0:19	0:31	0:11	LINE CLEAR AVAILED
245	17-Feb-22	TUMKUR	110	NITTUR 220-K G TEMPLE	KGTEMPLE_110	13:50	14:04	0:13	LINE CLEAR AVAILED
246	17-Feb-22	TUMKUR	110	TR-1	KGTEMPLE_110	11:39	14:10	2:30	LINE CLEAR AVAILED
247	17-Feb-22	TUMKUR	110	TR-1	SAMPIGE_110	11:41	11:47	0:06	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
248	17-Feb-22	TUMKUR	110	TR-1	SHETTYKERE_110	12:14	12:52	0:37	HAND TRIPPED
249	17-Feb-22	TUMKUR	110	TR-1(LV SIDE)	KB CROSS_220	18:01	18:39	0:37	TRANSFORMER FAULT
250	17-Feb-22	TUMKUR	110	TR-2	KADABA_110	13:54	19:34	5:39	LINE CLEAR AVAILED
251	17-Feb-22	TUMKUR	110	TR-2	SAMPIGE_110	11:41	11:47	0:06	HAND TRIPPED
252	17-Feb-22	TUMKUR	220	KB CROSS 220KV- SHIMOGA1	KBCROSS_220	12:13	12:15	0:02	HAND TRIPPED
253	17-Feb-22	TUMKUR	220	TR-1(HV SIDE)	KB CROSS_220	18:01	18:38	0:36	TRANSFORMER FAULT
254	17-Feb-22	TUMKUR	220	TR-3(HV SIDE)	KB CROSS_220	12:10	12:25	0:15	TRANSFORMER FAULT
1	18-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED GULEDAGUDDA_110	12:04	12:47	0:43	LINE CLEAR AVAILED
2	18-Feb-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SOUDATTI_110	8:35	9:20	0:45	LINE CLEAR AVAILED
3	18-Feb-22	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED RATTIHALLI_110	16:35	17:19	0:44	LINE CLEAR AVAILED
4	18-Feb-22	BAGALKOT	110	110/11KV,HV1	INDI_220	9:15	10:25	1:10	HAND TRIPPED
5	18-Feb-22	BAGALKOT	110	110/11KV,HV2	INDI_220	9:15	10:25	1:10	HAND TRIPPED
6	18-Feb-22	BAGALKOT	110	110/33KV,HV2	SUZLON_33,CHULKI_33,UDIKERI_33,SPINNI NG MILL_33 STATION NOT AFFECTED SOUDATTI_110	9:05	9:35	0:30	LINE CLEAR AVAILED
7	18-Feb-22	BAGALKOT	110	ANNIGERI-GADAG	STATION NOT AFFECTED ANNIGERI_110	11:33	13:58	2:25	NFBC ISSUED
8	18-Feb-22	BAGALKOT	110	BAGEWADI220-UKKALI	UKKALI_110	11:03	14:10	3:07	NFBC ISSUED
9	18-Feb-22	BAGALKOT	110	BAGEWADI-UKKALI	UKKALI_110	11:03	14:10	3:07	NFBC ISSUED
10	18-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
11	18-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
12	18-Feb-22	BAGALKOT	110	HUBLI220-KALGHATAGI	STATION NOT AFFECTED KALAGHATAGI_110	12:04	16:50	4:46	LINE CLEAR AVAILED
13	18-Feb-22	BAGALKOT	110	HUBLI-SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	12:09	15:51	3:42	LINE CLEAR AVAILED
14	18-Feb-22	BAGALKOT	110	HUBLI-SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	12:09	15:51	3:42	LINE CLEAR AVAILED
15	18-Feb-22	BAGALKOT	110	HUNAGUND- KUDALASANGAM (B.BAGEWADI)	STATION NOT AFFECTED HUNAGUND_110	16:04	18:14	2:10	LINE CLEAR AVAILED
16	18-Feb-22	BAGALKOT	110	HUNAGUND-ILKAL-2	STATION NOT AFFECTED HUNAGUND_110	10:30	19:44	9:14	LINE CLEAR AVAILED
17	18-Feb-22	BAGALKOT	110	INDI220- DEVAR HIPPARAGI	DEVAR HIPPARAGI_110, ATHARGA_110, HIREMASALI_110	9:15	10:25	1:10	HAND TRIPPED
18	18-Feb-22	BAGALKOT	110	INDI220- INDI110	INDI_110	9:15	10:25	1:10	HAND TRIPPED
19	18-Feb-22	BAGALKOT	110	INDI220- LACHYAN	LACHYAN_110, HIREBEVNUR_110	9:15	10:25	1:10	HAND TRIPPED
20	18-Feb-22	BAGALKOT	110	INDI220- ZALKI1&2	ZALKI_110	9:15	10:25	1:10	HAND TRIPPED
21	18-Feb-22	BAGALKOT	110	ITNAL- MUGALHOD220(HIDKAL)	ITNAL_110	16:23	17:35	1:12	LINE CLEAR AVAILED
22	18-Feb-22	BAGALKOT	110	KADANAKOPPA-KAVALAWAD_110	STATION NOT AFFECTED KADANAKOPPA_110	22:02 (16.02.2022)			LINE OPEN:LINE FAULT
23	18-Feb-22	BAGALKOT	110	KUDALASANGAM-HUNAGUND	STATION NOT AFFECTED KUDALASANGAM_110	16:00	18:18	2:18	LINE CLEAR AVAILED
24	18-Feb-22	BAGALKOT	110	MUGALKHOD-ITNAL3	STATION NOT AFFECTED MUGALKHOD_220	16:23	17:35	1:12	LINE CLEAR AVAILED
25	18-Feb-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN:LINE CLEAR AVAILED
26	18-Feb-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
27	18-Feb-22	BAGALKOT	220	220/110KV, HV1&LV1	INDI_220	9:15	9:50	0:35	TRANSFORMER FAULT
28	18-Feb-22	BAGALKOT	220	220/110KV, HV2	INDI_220	10:00	10:10	0:10	TRANSFORMER FAULT
29	18-Feb-22	BAGALKOT	220	220/110KV, HV2&LV2	INDI_220	9:15	9:35	0:20	TRANSFORMER FAULT
30	18-Feb-22	BAGALKOT	220	220/110KV, LV1	INDI_220	10:00	10:15	0:15	TRANSFORMER FAULT
31	18-Feb-22	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
32	18-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
33	18-Feb-22	BAGALKOT	220	GHATAPRABHA-MUGALKHOD1	STATION NOT AFFECTED GHATAPRABHA_220	14:13	19:09	4:56	NFBC ISSUED
34	18-Feb-22	BAGALKOT	220	MUGALKHOD-GHATAPRABHA1	STATION NOT AFFECTED MUGALKHOD_220	14:13	19:10	4:57	LINE CLEAR AVAILED
35	18-Feb-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
36	18-Feb-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
37	18-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40(23-1-2022)			LINE OPEN:LINE FAULT
38	18-Feb-22	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	5:48	5:58	0:10	LOAD CHANGEVER
39	18-Feb-22	BENGALURU	66	HV2	SARJAPURA 220	11:22	12:37	1:15	LINE CLEAR AVAILED
40	18-Feb-22	BENGALURU	66	HV3	ELECTYRONIC CITY	10:07	22:19	12:12	LOAD CHANGEVER
41	18-Feb-22	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	6:15	6:28	0:13	LOAD CHANGEVER
42	18-Feb-22	BENGALURU	66	TG HALLI - BYADRAHALLI	TAVAREKERE	10:45	11:04	0:19	LINE FAULT
43	18-Feb-22	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	VIDHURASHWATHA, GUNDLU KOTTUR	6:20	6:30	0:10	LINE CLEAR AVAILED
44	18-Feb-22	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	VIDHURASHWATHA, GUNDLU KOTTUR	10:50	11:00	0:10	LINE CLEAR AVAILED
45	18-Feb-22	GULBARGA	66	HV1	PUNABGHATTA_66	7:15	7:20	0:05	TRANSFORMER FAULT
46	18-Feb-22	GULBARGA	66	ITTAGI-HAGRIBOMMANHALLI	UP HALLI_66,HB HALLI_66	6:15	6:22	0:07	LINE FAULT
47	18-Feb-22	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	10:05	10:20	0:15	LINE FAULT
48	18-Feb-22	GULBARGA	66	ITTAGI-KUDLIGI1	KOGALI_66, KUDLIGI_66, HANASI_66	10:15	12:55	2:40	LINE CLEAR AVAILED
49	18-Feb-22	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHCHANGIDURGA_66	15:37	15:45	0:08	LINE FAULT
50	18-Feb-22	GULBARGA	110	HV1	GANDHINAGAR_110	12:20	15:54	3:34	LINE CLEAR AVAILED
51	18-Feb-22	GULBARGA	110	HV1	MATAMARI_110	11:15	12:15	1:00	TRANSFORMER FAULT
52	18-Feb-22	GULBARGA	110	HV2	MATAMARI_110	10:32	10:36	0:04	TRANSFORMER FAULT
53	18-Feb-22	GULBARGA	110	HV3	VALKAMDINNI_110	10:10	10:20	0:10	TRANSFORMER FAULT
54	18-Feb-22	GULBARGA	110	LINGASUGUR-CHAYADEVI_IPP	LINGASUGUR_220	10:47	18:33	7:46	LINE CLEAR AVAILED
55	18-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	9:50	16:00	6:10	LOAD CHANGEVER
56	18-Feb-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	5:32	5:42	0:10	LINE FAULT
57	18-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110,MANVI_110	6:30	6:40	0:10	LINE FAULT
58	18-Feb-22	GULBARGA	110	MUNIRABAD-HAGRI	HAGRI_110,SANKLAPUR_110,RBSNS,KAMA LAPUR_110	10:51	14:50	3:59	LINE CLEAR AVAILED
59	18-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR1	GUBBUR_110	5:00	5:05	0:05	LINE FAULT
60	18-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:35	4:42	0:07	LINE FAULT
61	18-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
62	18-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	22:39 (18.02.2022)			LINE OPEN:LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
63	18-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	13:10	13:50	0:40	LINE FAULT
64	18-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
65	18-Feb-22	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	12:37	20:48	8:11	LINE CLEAR AVAILED
66	18-Feb-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	0:08	6:21	6:13	LINE FAULT
67	18-Feb-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	11:19	11:55	0:36	LINE CLEAR AVAILED
68	18-Feb-22	HASSAN	110	HGUNJE-HIRIYADKA	HGGUNJE_220	11:24	11:34	0:10	MAIN SUPPLY FAILURE
69	18-Feb-22	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	8:00	10:32	2:32	LINE FAULT
70	18-Feb-22	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	11:26	11:35	0:09	MAIN SUPPLY FAILURE
71	18-Feb-22	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	11:06	13:08	2:02	LINE CLEAR AVAILED
72	18-Feb-22	HASSAN	110	HV1	KARAYA_110	13:15	13:30	0:15	LINE CLEAR AVAILED
73	18-Feb-22	HASSAN	110	HV2	KARAYA_110	13:15	13:30	0:15	LINE CLEAR AVAILED
74	18-Feb-22	HASSAN	110	HV2	NAVUNDA_110	10:48	11:08	0:20	TRANSFORMER FAULT
75	18-Feb-22	HASSAN	110	HV3	KULASHEKARA_110	15:29	16:28	0:59	LINE CLEAR AVAILED
76	18-Feb-22	HASSAN	110	HV4	MRSMG_220	9:12	13:58	4:46	LINE CLEAR AVAILED
77	18-Feb-22	HASSAN	110	LV1	MSEZ_220	10:19	15:11	4:52	LINE CLEAR AVAILED
78	18-Feb-22	HASSAN	110	LV2	HGGUNJE_220	11:24	11:33	0:09	HAND TRIPPED
79	18-Feb-22	HASSAN	110	LV2	HGGUNJE_220	15:39	15:55	0:16	LINE CLEAR AVAILED
80	18-Feb-22	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	11:08	13:09	2:01	NFBC ISSUED
81	18-Feb-22	HASSAN	220	HV1	MSEZ_220	10:20	15:10	4:50	LINE CLEAR AVAILED
82	18-Feb-22	HASSAN	220	HV2	HGGUNJE_220	11:24	11:32	0:08	TRANSFORMER FAULT
83	18-Feb-22	HASSAN	220	HV2	HGGUNJE_220	15:38	15:54	0:16	LINE CLEAR AVAILED
84	18-Feb-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	10:18	16:54	6:36	LINE CLEAR AVAILED
85	18-Feb-22	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	13:23(16.02.2022)			LINE OPEN:LINE CLEAR AVAILED
86	18-Feb-22	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	18:30(18.02.2022)			LINE OPEN:LINE CLEAR AVAILED
87	18-Feb-22	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	15:51	18:35	2:44	NFBC ISSUED
88	18-Feb-22	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	15:51	18:35	2:44	LINE CLEAR AVAILED
89	18-Feb-22	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	10:37(18.02.2022)			LINE OPEN:LINE CLEAR AVAILED
90	18-Feb-22	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	8:53	9:02	0:09	LINE FAULT
91	18-Feb-22	HASSAN	66	HV1	SINGAPURA_66	8:10	9:53	1:43	LINE CLEAR AVAILED
92	18-Feb-22	HASSAN	66	HV2	UDAYAPURA_66	14:05	14:07	0:02	TRANSFORMER FAULT
93	18-Feb-22	HASSAN	66	LV4	MRSMG_220	9:25	12:10	2:45	LINE CLEAR AVAILED
94	18-Feb-22	HASSAN	66	MATTNAV-DIDGTHL	MATTANAVILE_66	14:08	14:25	0:17	LINE FAULT
95	18-Feb-22	MYSURU	66	ELIVALA-HOOTGALLY	NO STATIONS EFFECTED	6:14	14:49	8:35	LINE CLEAR AVAILED
96	18-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
97	18-Feb-22	MYSURU	66	HOOTAGALLY-BANNIKUPPE	NO STATIONS EFFECTED	14:51	17:35	2:44	LINE CLEAR AVAILED
98	18-Feb-22	MYSURU	66	HV1	CHIKKMANDYA_66	9:55	14:00	4:05	LINE CLEAR AVAILED
99	18-Feb-22	MYSURU	66	HV1	HANNUR_66	16:00	18:01	2:01	LINE CLEAR AVAILED
100	18-Feb-22	MYSURU	66	HV1	HULLAHALLI_66	16:31	17:16	0:45	LINE CLEAR AVAILED
101	18-Feb-22	MYSURU	66	HV1	KR PETE_66	9:59	16:22	6:23	LINE CLEAR AVAILED
102	18-Feb-22	MYSURU	66	HV2	CHIKKMANDYA_66	10:00	16:00	6:00	LINE CLEAR AVAILED
103	18-Feb-22	MYSURU	66	HV2	HAMPAPURA_66	15:19	17:45	2:26	LINE CLEAR AVAILED
104	18-Feb-22	MYSURU	66	HV2	KR PETE_66	10:00	17:42	7:42	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
105	18-Feb-22	MYSURU	66	HV3	KR PETE _66	16:25	17:39	1:14	LINE CLEAR AVAILED
106	18-Feb-22	MYSURU	66	JAKKANAHALLI- MAHADESHWARAPURA	G MALLIGERE _66 BOGADHI MANDYA _66 GUDDENAHALLI _66 NAGAMANGALA _66 JAKKANAHALLY _66	16:15	16:27	0:12	HAND TRIPPED
107	18-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
108	18-Feb-22	MYSURU	66	KADAKOLA-NANJANGUD1	NO STATIONS EFFECTED	15:32:22 (17.2.22)			LINE OPEN:LINE CLEAR AVAILED
109	18-Feb-22	MYSURU	66	KK HALLI-SHIMSHA	KADKOTHANAHALLI _66	9:20	12:30	3:10	LINE CLEAR AVAILED
110	18-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)			LINE OPEN:LINE CLEAR AVAILED
111	18-Feb-22	MYSURU	66	KM DODDI-MANDYA	KMDODDI _66 KKDODDI _66 KIADBMANDYA _66 SOMANAHALLI _66 TUMBEKERE _66 MADDUR _66	11:21	12:25	1:03	LINE CLEAR AVAILED
112	18-Feb-22	MYSURU	66	KM DODDI-MANDYA	KMDODDI _66 KKDODDI _66 KIADBMANDYA _66 SOMANAHALLI _66 TUMBEKERE _66 MADDUR _66	16:18	17:33	1:14	LINE CLEAR AVAILED
113	18-Feb-22	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	5:07	5:30	0:23	LINE FAULT
114	18-Feb-22	MYSURU	66	KR PETE 220-KR PETE1	NO STATIONS EFFECTED	12:22	17:47	5:25	LINE CLEAR AVAILED
115	18-Feb-22	MYSURU	66	KR PETE 220-KR PETE2	NO STATIONS EFFECTED	17:50	18:50	0:59	LINE CLEAR AVAILED
116	18-Feb-22	MYSURU	66	KR PETE 220-SB HALLY1	NO STATIONS EFFECTED	12:21	13:46	1:24	LINE CLEAR AVAILED
117	18-Feb-22	MYSURU	66	KR PETE 220-SB HALLY2	NO STATIONS EFFECTED	13:46	14:40	0:54	LINE CLEAR AVAILED
118	18-Feb-22	MYSURU	66	KR PETE -AKIHEBBAL1	NO STATIONS EFFECTED	17:07	17:59	0:51	LINE CLEAR AVAILED
119	18-Feb-22	MYSURU	66	KR PETE -AKIHEBBAL2	NO STATIONS EFFECTED	11:42	17:07	5:25	LINE CLEAR AVAILED
120	18-Feb-22	MYSURU	66	KR PETE -AKKIHEBBAL	AKKIHEBBAL _66	15:02	15:08	0:06	LINE FAULT
121	18-Feb-22	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	KOLLEGALA _66 PARINAMIPURA _66	3:59	4:14	0:14	LINE FAULT
122	18-Feb-22	MYSURU	66	TUBINKERE-NAGAMANGALA1	NO STATIONS EFFECTED	10:01	13:33	3:32	LINE CLEAR AVAILED
123	18-Feb-22	MYSURU	66	TUBINKERE-NAGAMANGALA2	BG NAGARA _66 ADICHUNCHANGIRI _66 VADERAHALLI _66 HARADANAHALLI _66 SHIVALLI _66 BASARALU _66 KASALGERE _66	5:36	5:44	0:08	LINE FAULT
124	18-Feb-22	MYSURU	66	TUBINKERE-NAGAMANGALA2	BG NAGARA _66 ADICHUNCHANGIRI _66 VADERAHALLI _66 HARADANAHALLI _66 SHIVALLI _66 BASARALU _66 KASALGERE _66	5:44	5:54	0:09	LINE FAULT
125	18-Feb-22	MYSURU	66	TUBINKERE-NAGAMANGALA2	BG NAGARA _66 ADICHUNCHANGIRI _66 VADERAHALLI _66 HARADANAHALLI _66 SHIVALLI _66 BASARALU _66 KASALGERE _66	6:15	8:23	2:07	HAND TRIPPED
126	18-Feb-22	MYSURU	66	TUBINKERE-NAGAMANGALA2	BG NAGARA _66 ADICHUNCHANGIRI _66 VADERAHALLI _66 HARADANAHALLI _66 SHIVALLI _66 BASARALU _66 KASALGERE _66	12:11	12:22	0:10	LINE FAULT
127	18-Feb-22	MYSURU	66	TUBINKERE-NAGAMANGALA2	BG NAGARA _66 ADICHUNCHANGIRI _66 VADERAHALLI _66 HARADANAHALLI _66 SHIVALLI _66 BASARALU _66 KASALGERE _66	14:29	15:24	0:54	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
128	18-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	11:43	14:20	2:37	LINE CLEAR AVAILED
129	18-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA	KOLALA_66, URDIGERE_66	11:43	14:20	2:37	LINE CLEAR AVAILED
130	18-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220kv- KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_66, BELADARA_66	10:18	14:20	4:01	LINE CLEAR AVAILED
131	18-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALI_66	11:12	14:20	3:07	LINE CLEAR AVAILED
132	18-Feb-22	TUMKUR	66	BRAHMASANDRA- THOVINKERE(KORA)	THOVINAKERE_66, KORA_66	10:51	11:24	0:32	HAND TRIPPED
133	18-Feb-22	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	15:51	16:08	0:16	LINE FAULT
134	18-Feb-22	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	15:10	15:15	0:05	HAND TRIPPED
135	18-Feb-22	TUMKUR	66	DODDASARANGI-ANCHEPALYA	DODDASARANGI_66	11:08	11:20	0:12	HAND TRIPPED
136	18-Feb-22	TUMKUR	66	HARIYABBE-PD KOTE	HARIYABBE_66	10:25	19:42	9:17	MAIN SUPPLY FAILURE
137	18-Feb-22	TUMKUR	66	KORA- ANTHRASANAHALLI	KORA_66	11:26	15:27	4:01	MAIN SUPPLY FAILURE
138	18-Feb-22	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	10:48	11:26	0:38	HAND TRIPPED
139	18-Feb-22	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	15:27	15:50	0:22	LINE CLEAR AVAILED
140	18-Feb-22	TUMKUR	66	MADHUGIRI 220kv- MADHUGIRI 66(OLD) 220KV	MADHUGIRI_66	9:02	18:37	9:34	LINE CLEAR AVAILED
141	18-Feb-22	TUMKUR	66	MADHUGIRI 220kv-NITRAHALLI66	NITRAHALLI_66	12:07	12:10	0:03	LINE FAULT
142	18-Feb-22	TUMKUR	66	MADHUGIRI 66kv- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	9:02	18:43	9:40	LINE CLEAR AVAILED
143	18-Feb-22	TUMKUR	66	MELKOTE-ANTHRASANAHALLI	MELKOTE_66	11:06	15:26	4:20	LINE CLEAR AVAILED
144	18-Feb-22	TUMKUR	66	PAVAGADA220-SHYLAPURA66	SHYLAPURA_66	13:46	13:50	0:03	LINE FAULT
145	18-Feb-22	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	6:42	7:22	0:40	LINE FAULT
146	18-Feb-22	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	6:42	10:50	4:07	LINE FAULT
147	18-Feb-22	TUMKUR	66	THIPPUR66-ANCHEPALYA220	THIPPUR_66	6:30	6:43	0:12	LINE FAULT
148	18-Feb-22	TUMKUR	66	THIPPUR66-YEDIYUR	THIPPUR_66	6:30	6:44	0:14	LINE FAULT
149	18-Feb-22	TUMKUR	66	TR-1	KALAMARANAHALLI_66	10:00	10:05	0:05	TRANSFORMER FAULT
150	18-Feb-22	TUMKUR	66	TR-1	KUNDUR_66	14:10	14:40	0:30	LINE CLEAR AVAILED
151	18-Feb-22	TUMKUR	66	TR-1	MADHUGIRI_66	9:02	18:43	9:40	LINE CLEAR AVAILED
152	18-Feb-22	TUMKUR	66	TR-1	RANGANATHAPURA_66	10:01	14:39	4:37	LINE CLEAR AVAILED
153	18-Feb-22	TUMKUR	66	TR-1	YEDIYUR_66	11:36	13:51	2:14	LINE CLEAR AVAILED
154	18-Feb-22	TUMKUR	66	TR-1	THIPPUR_66	12:27	12:54	0:27	LINE CLEAR AVAILED
155	18-Feb-22	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	11:07	14:20	3:12	LINE CLEAR AVAILED
156	18-Feb-22	TUMKUR	66	TR-2	BUKKAPATNA_66	16:21	17:30	1:08	LINE CLEAR AVAILED
157	18-Feb-22	TUMKUR	66	TR-2	CHANNAGIRI(LING)	18:52	19:04	0:11	LINE CLEAR AVAILED
158	18-Feb-22	TUMKUR	66	TR-2	CHANNAGIRI(LING)	22:03	22:07	0:03	TRANSFORMER FAULT
159	18-Feb-22	TUMKUR	66	TR-2	GULIGENAHALLI_66	17:54	18:52	0:57	LINE CLEAR AVAILED
160	18-Feb-22	TUMKUR	66	TR-2	HARIYABBE_66	11:55	12:39	0:44	HAND TRIPPED
161	18-Feb-22	TUMKUR	66	TR-2	KADAJI_66	22:16	22:23	0:07	TRANSFORMER FAULT
162	18-Feb-22	TUMKUR	66	TR-2	MADHUGIRI_66	9:02	18:43	9:40	LINE CLEAR AVAILED
163	18-Feb-22	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	11:11	14:20	3:08	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
164	18-Feb-22	TUMKUR	66	TR-3	HARIYABBE_66	13:06	13:12	0:05	TRANSFORMER FAULT
165	18-Feb-22	TUMKUR	66	YEDIYUR- BG NAGARA66	BGNAGARA_66	6:30	6:46	0:16	MAIN SUPPLY FAILURE
166	18-Feb-22	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_110	15:09	15:17	0:08	LINE CLEAR AVAILED
167	18-Feb-22	TUMKUR	110	NITTUR 220-SOMLAPURA110	SOMLAPURA_110	9:50	11:15	1:25	HAND TRIPPED
168	18-Feb-22	TUMKUR	110	TR-1	TURUVEKERE 110	16:32	16:41	0:09	TRANSFORMER FAULT
169	18-Feb-22	TUMKUR	110	TR-1	TURUVEKERE 110	19:59	20:14	0:15	TRANSFORMER FAULT
170	18-Feb-22	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	6:02	7:19	1:17	TRANSFORMER FAULT
171	18-Feb-22	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	11:07	14:20	3:12	LINE CLEAR AVAILED
172	18-Feb-22	TUMKUR	220	KB CROSS 220KV- NELAMANGALA	KBCROSS_220	10:15	16:07	5:52	LINE CLEAR AVAILED
173	18-Feb-22	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	10:46	17:39	6:53	LINE CLEAR AVAILED
174	18-Feb-22	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	6:02	7:19	1:17	TRANSFORMER FAULT
175	18-Feb-22	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	11:07	14:20	3:12	LINE CLEAR AVAILED
176	18-Feb-22	TUMKUR	220	TR-3	KBCROSS_220	14:19	14:23	0:04	TRANSFORMER FAULT
1	19-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TILUVALLI_110	11:06	14:46	3:40	LINE CLEAR AVAILED
2	19-Feb-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	9:05	9:36	0:31	HAND TRIPPED
3	19-Feb-22	BAGALKOT	110	110/11KV,HV2	KULIGOD_110	15:02	15:31	0:29	HAND TRIPPED
4	19-Feb-22	BAGALKOT	110	110/33KV, HV3	HALASABGI_33, NEVARGI_33 & DULAKHED_33 STATION NOT AFFECTED ZALKI_110	16:50	16:54	0:04	TRANSFORMER FAULT
5	19-Feb-22	BAGALKOT	110	110/33KV, HV3	KALKERI_33, KNNL_33 STATION NOT AFFECTED TILUVALLI_110	14:31	14:46	0:15	HAND TRIPPED
6	19-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
7	19-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
8	19-Feb-22	BAGALKOT	110	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	2:09	2:19	0:10	LINE FAULT
9	19-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
10	19-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
11	19-Feb-22	BAGALKOT	110	HAVERI-HANAGAL(TILUVALI)	STATION NOT AFFECTED HAVERI_220	10:46	12:59	2:13	LINE CLEAR AVAILED
12	19-Feb-22	BAGALKOT	110	HUBLI220- RAMANKOPPA	STATION NOT AFFECTED HUBLI_220	4:52	10:10	5:18	LINE FAULT
13	19-Feb-22	BAGALKOT	110	KADANAKOPPA-KAVALAWAD_110	STATION NOT AFFECTED KADANAKOPPA_110	22:02 (16.02.2022)	8:05 (19.02.2022)	58:03 hrs	LINE CHARGED
14	19-Feb-22	BAGALKOT	110	RAMANAKOPPA-HUBLI220	STATION NOT AFFECTED RAMANAKOPPA_110	5:18	10:20	5:02	HAND TRIPPED
15	19-Feb-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42(14.02.2022)			LINE OPEN:LINE CLEAR AVAILED
16	19-Feb-22	BAGALKOT	220	220/110KV,HV1 & LV1	STATION NOT AFFECTED BIJAPUR_220	11:03	11:10	0:07	HAND TRIPPED
17	19-Feb-22	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED HAVERI_220	11:13	12:45	1:32	LINE CLEAR AVAILED
18	19-Feb-22	BAGALKOT	220	220/110KV,HV2 & LV2	STATION NOT AFFECTED BIJAPUR_220	11:27	11:37	0:10	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
19	19-Feb-22	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED HAVERI_220	12:48	14:43	1:55	LINE CLEAR AVAILED
20	19-Feb-22	BAGALKOT	220	AMBEWADI- NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	11:21	15:44	4:23	LINE CLEAR AVAILED
21	19-Feb-22	BAGALKOT	220	BIJAPUR-BAGEWADI1	STATION NOT AFFECTED BIJAPUR_220	10:49	11:01	0:12	HAND TRIPPED
22	19-Feb-22	BAGALKOT	220	BIJAPUR-BAGEWADI2	STATION NOT AFFECTED BIJAPUR_220	11:59	12:05	0:06	HAND TRIPPED
23	19-Feb-22	BAGALKOT	220	BIJAPUR-VAISHALI1	STATION NOT AFFECTED BIJAPUR_220	11:11	11:26	0:15	HAND TRIPPED
24	19-Feb-22	BAGALKOT	220	BIJAPUR-VAISHALI2	STATION NOT AFFECTED BIJAPUR_220	11:11	11:39	0:28	HAND TRIPPED
25	19-Feb-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56(26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
26	19-Feb-22	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56(26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
27	19-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28(02.02.2022)			LINE OPEN:LINE FAULT
28	19-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28(02.02.2022)			LINE OPEN:LINE FAULT
29	19-Feb-22	BAGALKOT	220	INDI- BIJAPUR2	STATION NOT AFFECTED INDI_220	11:10	11:55	0:45	HAND TRIPPED
30	19-Feb-22	BAGALKOT	220	INDI- BIJAPUR2	INDI_220	11:55	17:00	5:05	NFBC ISSUED
31	19-Feb-22	BAGALKOT	220	KUDACHI- MAHALINGAPUR	STATION NOT AFFECTED KUDACHI_220	10:04	17:51	7:47	LINE CLEAR AVAILED
32	19-Feb-22	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	11:20	15:44	4:24	LINE CLEAR AVAILED
33	19-Feb-22	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	11:21	15:44	4:23	LINE CLEAR AVAILED
34	19-Feb-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24(09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
35	19-Feb-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24(09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
36	19-Feb-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24(09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
37	19-Feb-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24(09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
38	19-Feb-22	BENGALURU	66	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	9:04	14:31	5:27	LOAD CURTAILMENT
39	19-Feb-22	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	17:30	18:25	0:55	LINE FAULT
40	19-Feb-22	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	18:45	18:50	0:05	LOAD CHANGEVER
41	19-Feb-22	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	10:00	10:10	0:10	LOAD CHANGEVER
42	19-Feb-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	6:49	6:59	0:10	LINE FAULT
43	19-Feb-22	BENGALURU	66	HV1	BEGUR 220	17:15	17:47	0:32	LINE CLEAR AVAILED
44	19-Feb-22	BENGALURU	66	MALUR 220 - LAKKUR	NO STATION AFFECTED	15:34	17:54	2:20	LINE CLEAR AVAILED
45	19-Feb-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	19:17	19:25	0:08	LINE CLEAR AVAILED
46	19-Feb-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:34	18:09	2:35	LINE CLEAR AVAILED
47	19-Feb-22	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU, HANUMANTHANAGAR	10:12	10:16	0:04	LOAD CHANGEVER
48	19-Feb-22	BENGALURU	220	HV1	BEGUR 220	10:01	16:50	6:49	LINE CLEAR AVAILED
49	19-Feb-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1	NO STATION AFFECTED	9:40 (23-1-2022)	17:55(19-2-2022)	656:14 hrs	LINE CHARGED
50	19-Feb-22	GULBARGA	66	HV2	BENNEHALI_66	8:40	8:45	0:05	TRANSFORMER FAULT
51	19-Feb-22	GULBARGA	66	HV3	TELAGI_66	16:10	16:15	0:05	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
52	19-Feb-22	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHCHANGIDURGA_66	9:28	9:41	0:13	LINE FAULT
53	19-Feb-22	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHCHANGIDURGA_66	15:17	15:24	0:07	LINE FAULT
54	19-Feb-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	4:05	5:35	1:30	LINE FAULT
55	19-Feb-22	GULBARGA	110	GALAG-ALKOD	GALAG_110	15:40	15:55	0:15	MAIN SUPPLY FAILURE
56	19-Feb-22	GULBARGA	110	HV1,HV2,HV3	YEREGERA_110	10:43	18:05	7:22	NFBC ISSUED
57	19-Feb-22	GULBARGA	110	KANAKAGIRI-KUSHTAGI	KANAKAGIRI_110	10:45	11:05	0:20	MAIN SUPPLY FAILURE
58	19-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	9:42	15:55	6:13	LOAD CHANGEOVER
59	19-Feb-22	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	3:42	4:00	0:18	LINE FAULT
60	19-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110,MANVI_110	1:21	1:34	0:13	LINE FAULT
61	19-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110,MANVI_110	21:05	21:10	0:05	LINE FAULT
62	19-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR1	GUBBUR_110	23:58(18.02.2022)	00:05(19.02.2022)	00:07HRS	LINE CHARGED
63	19-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
64	19-Feb-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGER_A_110,SANNATHI_IPP,COREGREENSUGARS_IPP	0:28	0:31	0:03	LINE FAULT
65	19-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	22:39 (18.02.2022)	8:02 (19.02.2022)	9:23 HRS	LINE CHARGED
66	19-Feb-22	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	JAVALAGERA_110,ADAVIAMARESHWARA_110	1:45	1:55	0:10	LINE FAULT
67	19-Feb-22	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,,VALAKAMADINNI_110,	22:02	22:17	0:15	LINE FAULT
68	19-Feb-22	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	3:10	3:25	0:15	LINE FAULT
69	19-Feb-22	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	1:50	2:00	0:10	MAIN SUPPLY FAILURE
70	19-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
71	19-Feb-22	GULBARGA	220	MALLAT-LINGASUGUR	LINGASUGUR_220	10:20	16:27	6:07	NFBC ISSUED
72	19-Feb-22	GULBARGA	220	SHAHAPUR-KAPNOOR	SHAHAPUR_220	0:24	0:54	0:30	LINE FAULT
73	19-Feb-22	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLY_66	6:30	6:37	0:07	MAIN SUPPLY FAILURE
74	19-Feb-22	HASSAN	66	BELUR66-HASSAN	BELUR_66	10:06	17:07	7:01	LINE CLEAR AVAILED
75	19-Feb-22	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:07	17:15	7:08	LINE CLEAR AVAILED
76	19-Feb-22	HASSAN	66	HV1	BELUR_66	10:06	17:07	7:01	LINE CLEAR AVAILED
77	19-Feb-22	HASSAN	66	HV1	HALEBEEDU_66	13:45	14:00	0:15	TRANSFORMER FAULT
78	19-Feb-22	HASSAN	66	HV2	BALEHONNUR_66	17:30	17:44	0:14	TRANSFORMER FAULT
79	19-Feb-22	HASSAN	66	HV2	HALEBEEDU_66	10:45	11:25	0:40	LINE CLEAR AVAILED
80	19-Feb-22	HASSAN	66	HV2	HALEBEEDU_66	12:30	16:55	4:25	LINE CLEAR AVAILED
81	19-Feb-22	HASSAN	66	LV3	MRSMG_220	9:40	12:34	2:54	LINE CLEAR AVAILED
82	19-Feb-22	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILLE_66	19:01	19:16	0:15	HAND TRIPPED
83	19-Feb-22	HASSAN	110	HV1	MRSMG_220	13:42	13:51	0:09	HAND TRIPPED
84	19-Feb-22	HASSAN	110	HV2	ANANDPURA_110	15:53	16:36	0:43	TRANSFORMER FAULT
85	19-Feb-22	HASSAN	110	HV2	NAVUNDA_110	11:12	11:30	0:18	LINE CLEAR AVAILED
86	19-Feb-22	HASSAN	110	HV3	MRSMG_220	9:18	13:42	4:24	LINE CLEAR AVAILED
87	19-Feb-22	HASSAN	110	MSEZ-GSS32	MSEZ_220	10:28	16:26	5:58	LINE CLEAR AVAILED
88	19-Feb-22	HASSAN	220	MRSSHM-HONNALLI	MRSMG_220	13:23(16.02.2022)	13:25 (19.02.2022)	72:02HRS	LINE CHARGED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
89	19-Feb-22	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	13:20	15:28	2:08	LINE FAULT
90	19-Feb-22	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	18:30(18.02.2022)	13:55(19.02.2022)	19:25HRS	LINE CHARGED
91	19-Feb-22	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	10:37 (18.02.2022)	13:12 (19.02.2022)	26:14HRS	LINE CHARGED
92	19-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
93	19-Feb-22	MYSURU	66	HV1	KRPETE_220	12:39	16:27	3:48	LINE CLEAR AVAILED
94	19-Feb-22	MYSURU	66	HV1	KUNTHUR_66	14:37	14:58	0:21	LINE CLEAR AVAILED
95	19-Feb-22	MYSURU	66	HV1	HANAGODU_66	21:50	21:53	0:02	TRANSFORMER FAULT
96	19-Feb-22	MYSURU	66	HV2	KRPETE_220	10:15	12:48	2:33	LINE CLEAR AVAILED
97	19-Feb-22	MYSURU	66	HV2	HDKOTE_66	12:02	12:07	0:04	TRANSFORMER FAULT
98	19-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
99	19-Feb-22	MYSURU	66	KADAKOLA-NANJANGUD 1	NO STATIONS EFFECTED	16:33	17:01	0:27	HAND TRIPPED
100	19-Feb-22	MYSURU	66	KADAKOLA-NANJANGUD1	NO STATIONS EFFECTED	15:32:22 (17.2.22)	17:03:48 (19.02.22)	49:31HRS	LINE CHARGED
101	19-Feb-22	MYSURU	66	KADAKOLA-SARGUR2	HURA_66 DOORA_66 HULLALI_66	13:47	14:18	0:30	HAND TRIPPED
102	19-Feb-22	MYSURU	66	KKHALLI-MANDYA	NO STATIONS EFFECTED	14:20:00 (3.2.2022)	14:40 (19.02.22)	384:20HRS	LINE CHARGED
103	19-Feb-22	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	10:11	11:25	1:13	HAND TRIPPED
104	19-Feb-22	MYSURU	66	KRPETE 220-MADESWARAPURA	NO STATIONS EFFECTED	11:12	16:26	5:14	LINE CLEAR AVAILED
105	19-Feb-22	MYSURU	66	KRPET-KIKERI	KIKKERI_66	11:04	17:48	6:44	LINE CLEAR AVAILED
106	19-Feb-22	MYSURU	66	MADIKERI-SUNTHIKOPA	NO STATIONS EFFECTED	15:58	18:27	2:29	LINE CLEAR AVAILED
107	19-Feb-22	MYSURU	66	NAGAMANGALA-KR PETE	NAGAMANGALA_66	11:56	12:09	0:12	HAND TRIPPED
108	19-Feb-22	MYSURU	66	NAGAMANGALA-KR PETE	NAGAMANGALA_66	12:11	12:20	0:09	LINE CLEAR AVAILED
109	19-Feb-22	MYSURU	66	NAGAMANGALA-KR PETE	NAGAMANGALA_66	12:11	12:20	0:08	LINE CLEAR AVAILED
110	19-Feb-22	MYSURU	66	NAGAMANGALA-KR PETE	NAGAMANGALA_66	12:21	12:28	0:06	HAND TRIPPED
111	19-Feb-22	MYSURU	66	NAGAMANGALA-KR PETE	NO STATIONS EFFECTED	16:27:44(19.02.2022)			LINE OPEN:LINE CLEAR AVAILED
112	19-Feb-22	MYSURU	66	NAGAMANGALA-TUBINKERE	NAGAMANGALA_66	12:21	12:39	0:17	HAND TRIPPED
113	19-Feb-22	MYSURU	66	NAGAMANGALA-TUBINKERE	NO STATIONS EFFECTED	12:54	15:41	2:47	LINE CLEAR AVAILED
114	19-Feb-22	MYSURU	66	NAGAMANGALA-TUBINKERE	NO STATIONS EFFECTED	16:23	16:24	0:01	HAND TRIPPED
115	19-Feb-22	MYSURU	220	HV2	MADHUVANALLY_66	13:33	14:25	0:51	TRANSFORMER FAULT
116	19-Feb-22	MYSURU	220	HV2	KRPETE_220	16:39	18:08	1:29	LINE CLEAR AVAILED
117	19-Feb-22	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66,YEDAVANI_66	13:37	13:49	0:11	LINE FAULT
118	19-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	13:37	13:52	0:14	HAND TRIPPED
119	19-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA	KOLALA_66, URDIGERE_66	13:37	13:51	0:14	HAND TRIPPED
120	19-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_66, BELADARA_66	13:30	14:04	0:33	HAND TRIPPED
121	19-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAHMASANDRA_66,THOVINAKERE_66,A NKASANDRA_66	13:37	13:52	0:14	HAND TRIPPED
122	19-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALI_66	13:30	13:55	0:24	HAND TRIPPED
123	19-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	13:37	13:49	0:12	HAND TRIPPED
124	19-Feb-22	TUMKUR	66	BADAVANAHALLI-MADHUGIRI66	BADAVANAHALLI_66	18:37	19:56	1:19	MAIN SUPPLY FAILURE
125	19-Feb-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:59	14:21	0:22	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
126	19-Feb-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:41	14:56	0:15	HAND TRIPPED
127	19-Feb-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:13	21:29	0:15	LINE CLEAR AVAILED
128	19-Feb-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:59	14:45	0:46	HAND TRIPPED
129	19-Feb-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	14:29	14:45	0:16	HAND TRIPPED
130	19-Feb-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	13:59	14:56	0:57	HAND TRIPPED
131	19-Feb-22	TUMKUR	66	MADHUGIRI 66KV- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	9:03	19:53	10:50	LINE CLEAR AVAILED
132	19-Feb-22	TUMKUR	66	PAVAGADA220-SHYLAPURA66	SHYLAPURA_66	11:07	11:13	0:05	LINE FAULT
133	19-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	9:07	9:12	0:04	LINE FAULT
134	19-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	12:17	12:28	0:11	LINE FAULT
135	19-Feb-22	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	13:37	13:50	0:12	HAND TRIPPED
136	19-Feb-22	TUMKUR	66	TR-1	BADAVANAHALLI_66	11:24	19:59	8:34	MAIN SUPPLY FAILURE
137	19-Feb-22	TUMKUR	66	TR-1	BHARAMAGIRI_66	10:53	10:55	0:02	TRANSFORMER FAULT
138	19-Feb-22	TUMKUR	66	TR-1	HIRIYUR_66	10:49	17:12	6:23	LINE CLEAR AVAILED
139	19-Feb-22	TUMKUR	66	TR-1	KORATAGERE_66	4:08	15:36	11:28	LINE CLEAR AVAILED
140	19-Feb-22	TUMKUR	66	TR-1	MADHUGIRI_66	9:03	19:53	10:50	LINE CLEAR AVAILED
141	19-Feb-22	TUMKUR	66	TR-1	TUMKUR_66	11:08	16:52	5:43	LINE CLEAR AVAILED
142	19-Feb-22	TUMKUR	66	TR-1(HV SIDE)	PAVAGADA_220	8:05	8:12	0:06	TRANSFORMER FAULT
143	19-Feb-22	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	13:37	13:50	0:12	HAND TRIPPED
144	19-Feb-22	TUMKUR	66	TR-2	BADAVANAHALLI_66	19:56	19:59	0:03	MAIN SUPPLY FAILURE
145	19-Feb-22	TUMKUR	66	TR-2	BEVINAHALLI_66	8:43	9:12	0:28	LINE CLEAR AVAILED
146	19-Feb-22	TUMKUR	66	TR-2	KORATAGERE_66	15:36	18:55	3:19	MAIN SUPPLY FAILURE
147	19-Feb-22	TUMKUR	66	TR-2	MADHUGIRI_66	9:03	19:53	10:50	LINE CLEAR AVAILED
148	19-Feb-22	TUMKUR	66	TR-2	TAVAREKERE(H)	5:58	7:41	1:42	TRANSFORMER FAULT
149	19-Feb-22	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	13:15	13:20	0:05	MAIN SUPPLY FAILURE
150	19-Feb-22	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	9:35	9:40	0:05	MAIN SUPPLY FAILURE
151	19-Feb-22	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	15:15	15:25	0:10	MAIN SUPPLY FAILURE
152	19-Feb-22	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	11:07	14:20	3:12	HAND TRIPPED
153	19-Feb-22	TUMKUR	110	HONNAVALI 110- KADUR110	HONNAVALI_110	11:29	21:12	9:42	HAND TRIPPED
154	19-Feb-22	TUMKUR	110	TR-1	AMMASANDRA_110	12:01	13:27	1:26	MAIN SUPPLY FAILURE
155	19-Feb-22	TUMKUR	110	TR-1	KADABA_110	5:05	5:11	0:05	TRANSFORMER FAULT
156	19-Feb-22	TUMKUR	110	TR-2	AMMASANDRA_110	12:37	14:25	1:48	MAIN SUPPLY FAILURE
157	19-Feb-22	TUMKUR	110	TR-3	AMMASANDRA_110	12:37	14:25	1:48	MAIN SUPPLY FAILURE
158	19-Feb-22	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	13:30	13:46	0:15	HAND TRIPPED
159	19-Feb-22	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	10:47	12:09	1:22	LOAD CURTAILMENT
160	19-Feb-22	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	13:56	17:27	3:31	LOAD CURTAILMENT
161	19-Feb-22	TUMKUR	220	TR-2(HV SIDE)	PAVAGADA_220	11:08	11:14	0:05	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
162	20-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TILUVALLI_110	10:31	10:39	0:08	LINE CLEAR AVAILED
163	20-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED TARIHAL_110	6:47	7:13	0:26	TRANSFORMER FAULT
164	20-Feb-22	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	15:36	16:13	0:37	LINE CLEAR AVAILED
165	20-Feb-22	BAGALKOT	110	110/11KV,HV1	MUDALAGI_110	9:30	9:50	0:20	LINE CLEAR AVAILED
166	20-Feb-22	BAGALKOT	110	AMBEWADI- NK-1(HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	8:15	19:13	10:58	LINE CLEAR AVAILED
167	20-Feb-22	BAGALKOT	110	AMBEWADI- NK-2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:15	19:13	10:58	LINE CLEAR AVAILED
168	20-Feb-22	BAGALKOT	110	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	4:02	4:13	0:11	LINE FAULT
169	20-Feb-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42(14.02.2022)			LINE OPEN:LINE CLEAR AVAILED
170	20-Feb-22	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	11:44(20.02.2022)			LINE OPEN:LINE FAULT
171	20-Feb-22	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	13:45	17:23	3:38	LINE CLEAR AVAILED
172	20-Feb-22	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	21:43	22:15	0:32	LINE CLEAR AVAILED
173	20-Feb-22	BENGALURU	66	A STATION 220 - VICTORIA	VICTORIA	12:43	12:50	0:07	LINE CLEAR AVAILED
174	20-Feb-22	BENGALURU	66	A STATION 66 - A STATION 220	A STATION 66	12:43	12:50	0:07	LINE CLEAR AVAILED
175	20-Feb-22	BENGALURU	66	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	9:00	16:09	7:09	LOAD CURTAILMENT
176	20-Feb-22	BENGALURU	66	DEVARABISANAHALLI - HSR LAYOUT 220	DEVARABISANAHALLI	10:26	10:40	0:14	LOAD CHANGEOVER
177	20-Feb-22	BENGALURU	66	DEVARABISANAHALLI - VIKAS TECH PARK 220	DEVARABISANAHALLI	18:18	18:28	0:10	LOAD CHANGEOVER
178	20-Feb-22	BENGALURU	66	GLOBAL TECH PARK - HSR LAYOUT 220	GLOBAL TECH PARK	10:27	10:33	0:06	LOAD CHANGEOVER
179	20-Feb-22	BENGALURU	66	GLOBAL TECH PARK - VIKAS TECH PARK 220	GLOBAL TECH PARK	18:08	18:29	0:21	LOAD CHANGEOVER
180	20-Feb-22	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	16:39	16:44	0:05	LOAD CHANGEOVER
181	20-Feb-22	BENGALURU	66	GOKULA - SRS PEENYA 220 1 & 2	GOKULA, BEL (EHT), HMT (EHT)	14:13	14:33	0:20	MAIN SUPPLY FAILURE
182	20-Feb-22	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	10:30	17:20	6:50	LINE CLEAR AVAILED
183	20-Feb-22	BENGALURU	66	HOSUR RAMAPURA - NITRALLI	NITRALLI	15:25	16:09	0:44	LINE CLEAR AVAILED
184	20-Feb-22	BENGALURU	66	HV1	YARANDANAHALLI 220	12:45	13:00	0:15	LINE CLEAR AVAILED
185	20-Feb-22	BENGALURU	66	HV1	NRS 220	12:43	13:23	0:40	LINE CLEAR AVAILED
186	20-Feb-22	BENGALURU	66	HV2	HANUMANTHNAGARA	6:48	7:00	0:12	TRANSFORMER FAULT
187	20-Feb-22	BENGALURU	66	HV2	YARANDANAHALLI 220	12:45	13:00	0:15	LINE CLEAR AVAILED
188	20-Feb-22	BENGALURU	66	HV2	NRS 220	12:43	13:23	0:40	LINE CLEAR AVAILED
189	20-Feb-22	BENGALURU	66	HV2	VIJAYANAGARA	12:43	12:51	0:08	MAIN SUPPLY FAILURE
190	20-Feb-22	BENGALURU	66	HV3	YARANDANAHALLI 220	12:45	13:00	0:15	LINE CLEAR AVAILED
191	20-Feb-22	BENGALURU	66	HV3	NRS 220	12:43	13:23	0:40	LINE CLEAR AVAILED
192	20-Feb-22	BENGALURU	66	HV4	NRS 220	12:43	13:23	0:40	LINE CLEAR AVAILED
193	20-Feb-22	BENGALURU	66	HV5	NRS 220	12:43	13:23	0:40	LINE CLEAR AVAILED
194	20-Feb-22	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	16:45	16:50	0:05	LOAD CHANGEOVER
195	20-Feb-22	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	14:12	14:55	0:43	MAIN SUPPLY FAILURE
196	20-Feb-22	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	18:30	18:34	0:04	LOAD CHANGEOVER
197	20-Feb-22	BENGALURU	66	MATHIKERE -GOKULA	MATHIKERE	14:12	14:29	0:17	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
198	20-Feb-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	12:43	13:17	0:34	MAIN SUPPLY FAILURE
199	20-Feb-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	17:03	17:10	0:07	LOAD CHANGEOVER
200	20-Feb-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	8:47	8:52	0:05	MAIN SUPPLY FAILURE
201	20-Feb-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	14:12	14:44	0:32	MAIN SUPPLY FAILURE
202	20-Feb-22	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	12:43	13:25	0:42	LINE CLEAR AVAILED
203	20-Feb-22	BENGALURU	66	NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	12:43	13:25	0:42	LINE CLEAR AVAILED
204	20-Feb-22	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	14:12	14:30	0:18	MAIN SUPPLY FAILURE
205	20-Feb-22	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	19:20	19:25	0:05	LOAD CHANGEOVER
206	20-Feb-22	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	18:40	18:43	0:03	LOAD CHANGEOVER
207	20-Feb-22	BENGALURU	66	RMV - SRS PEENYA 220	RMV, TATA INSTITUTE (EHT)	14:12	14:24	0:12	MAIN SUPPLY FAILURE
208	20-Feb-22	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	17:13	17:17	0:04	LOAD CHANGEOVER
209	20-Feb-22	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALI, SRIGANDA KAVALU	14:13	14:40	0:27	LINE CLEAR AVAILED
210	20-Feb-22	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	14:13	14:43	0:30	LINE CLEAR AVAILED
211	20-Feb-22	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC	14:15	14:53	0:38	LINE CLEAR AVAILED
212	20-Feb-22	BENGALURU	66	WELCAST - SRS PEENYA 220	WELCAST	14:13	14:25	0:12	MAIN SUPPLY FAILURE
213	20-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	12:45	13:00	0:15	LINE CLEAR AVAILED
214	20-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	12:45	13:00	0:15	LINE CLEAR AVAILED
215	20-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	12:45	13:00	0:15	LINE CLEAR AVAILED
216	20-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	12:45	13:00	0:15	LINE CLEAR AVAILED
217	20-Feb-22	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU, HANUMANTHANAGAR	10:50	17:15	6:25	LINE CLEAR AVAILED
218	20-Feb-22	BENGALURU	220	A STATION 220 - A STATION 66	A STATION 220	12:43	12:50	0:07	LINE CLEAR AVAILED
219	20-Feb-22	BENGALURU	220	BRINDAVANA 220 - SRS PEENYA 220	NO STATION AFFECTED	14:15	15:25	1:10	LINE FAULT
220	20-Feb-22	BENGALURU	220	HV2	YARANDANAHALLI 220	12:45	13:00	0:15	TRANSFORMER FAULT
221	20-Feb-22	BENGALURU	220	NELAMANGALA 400 - PEENYA 2	SRS PEENYA 220	12:43	14:27	1:44	LINE FAULT
222	20-Feb-22	BENGALURU	220	NELAMANGALA 400 - PEENYA 3	NRS 220	12:43	14:28	1:45	LINE FAULT
223	20-Feb-22	BENGALURU	220	NELAMANGALA 400 - YELAHANKA 220	SRS PEENYA 220	14:13	15:38	1:25	LINE FAULT
224	20-Feb-22	BENGALURU	220	NRS 220 - NELAMANGALA 400	NRS 220	12:43	13:21	0:38	LINE CLEAR AVAILED
225	20-Feb-22	BENGALURU	220	SRS PEENYA 220 - HEBBALA 220	NO STATION AFFECTED	14:13	15:35	1:22	LINE FAULT
226	20-Feb-22	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 3 400	NO STATION AFFECTED	12:43	14:26	1:43	LINE FAULT
227	20-Feb-22	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 4 400	SRS PEENYA 220	14:13	15:25	1:12	MAIN SUPPLY FAILURE
228	20-Feb-22	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAPUR_66,MAGALA_66,SOVENHALLI_66,TUNGA BHADRA_IPP	18:36	18:43	0:07	LINE FAULT
229	20-Feb-22	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHCHANGIDURGA_66	14:21	14:33	0:12	LINE FAULT
230	20-Feb-22	GULBARGA	110	HV2	BISILAHALLI_110	12:55	13:10	0:15	TRANSFORMER FAULT
231	20-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	9:52	15:39	5:47	LOAD CHANGEOVER
232	20-Feb-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110,MANVI_110	16:20	16:30	0:10	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
233	20-Feb-22	GULBARGA	110	METRI-ALIPUR	METRI_110	7:27	8:27	1:00	MAIN SUPPLY FAILURE
234	20-Feb-22	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHIKKASUGUR_110,SHAKTHIN AGA_110	2:44	2:50	0:06	LINE FAULT
235	20-Feb-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	14:43	15:20	0:37	LOAD CURTAILMENT
236	20-Feb-22	GULBARGA	110	RAICHUR-SHAHAPUR1	GUBBUR_110	1:40	1:45	0:05	LINE FAULT
237	20-Feb-22	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	20:22	20:29	0:07	LINE FAULT
238	20-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
239	20-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:13 (20.02.2022)			LINE OPEN:LINE CLEAR AVAILED
240	20-Feb-22	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	JAVALAGERA_110,ADAVIAMARESHWARA_110	9:10	13:55	4:45	LINE CLEAR AVAILED
241	20-Feb-22	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110,MUDDAPUR_110,MASK I_110,VALAKAMADINNI_110	9:30	14:30	5:00	LINE CLEAR AVAILED
242	20-Feb-22	GULBARGA	110	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110,,VALAKAMADINNI_110,	9:30	14:30	5:00	LINE CLEAR AVAILED
243	20-Feb-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGE RA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	9:10	14:20	5:10	LINE CLEAR AVAILED
244	20-Feb-22	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	11:30	13:05	1:35	LINE FAULT
245	20-Feb-22	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	17:19	17:38	0:19	LINE FAULT
246	20-Feb-22	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	6:28	6:34	0:06	LINE FAULT
247	20-Feb-22	HASSAN	66	HV1	BANDISHETTIHALLY_66	6:30	6:37	0:07	MAIN SUPPLY FAILURE
248	20-Feb-22	HASSAN	66	HV2	BELUR_66	12:40	13:33	0:53	LINE CLEAR AVAILED
249	20-Feb-22	HASSAN	66	HV2	KIADB_66	11:56	12:45	0:49	LINE CLEAR AVAILED
250	20-Feb-22	HASSAN	66	KANDLI-HASSAN	KANDLI_66	17:19	17:41	0:22	LINE FAULT
251	20-Feb-22	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	17:19	17:41	0:22	LINE FAULT
252	20-Feb-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:50	11:18	0:28	LINE FAULT
253	20-Feb-22	HASSAN	110	BARANG-ANVATTI	BARANGI_110	18:45	18:50	0:05	HAND TRIPPED
254	20-Feb-22	HASSAN	110	BARANG-SHR220	BARANGI_110	9:39	18:45	9:06	MAIN SUPPLY FAILURE
255	20-Feb-22	HASSAN	110	HV1	NANDIKUR_110	11:53	12:00	0:07	TRANSFORMER FAULT
256	20-Feb-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:09	12:53	1:44	HAND TRIPPED
257	20-Feb-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	8:03	18:41	10:38	LINE CLEAR AVAILED
258	20-Feb-22	HASSAN	220	HASSN22-Shomoga	HASSAN_220	11:21	16:11	4:50	LINE CLEAR AVAILED
259	20-Feb-22	HASSAN	220	KEMAR-Varahi1	KEMAR_220	5:11	15:12	10:01	LINE CLEAR AVAILED
260	20-Feb-22	HASSAN	220	VARAHI-KEMAR1	varahi_gen	5:11	15:24	10:13	NFBC ISSUED
261	20-Feb-22	HASSAN	220	VARAHI-KEMAR2	varahi_gen	5:12	15:24	10:12	NFBC ISSUED
262	20-Feb-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:29	14:07	4:38	LINE CLEAR AVAILED
263	20-Feb-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
264	20-Feb-22	MYSURU	66	HV1	MADHUVANAHALLI_220	10:16	14:22	4:06	LINE CLEAR AVAILED
265	20-Feb-22	MYSURU	66	HV2	MADHUVANAHALLI_220	10:07	14:22	4:15	LINE CLEAR AVAILED
266	20-Feb-22	MYSURU	66	HV2	KUNTHUR_66	9:30	13:20	3:50	LINE CLEAR AVAILED
267	20-Feb-22	MYSURU	66	HV2	ANTHARSANTHE_66	15:30	16:00	0:30	TRANSFORMER FAULT
268	20-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
269	20-Feb-22	MYSURU	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	17:34	17:44	0:10	LINE FAULT
270	20-Feb-22	MYSURU	66	KK HALLI-MANDYA	KADKOTHANAHALLI_66	8:00	15:55	7:55	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
271	20-Feb-22	MYSURU	66	MANDYA-CHIKKA MANDYA	CHIKKMANDYA_66	9:45	14:52	5:07	LINE CLEAR AVAILED
272	20-Feb-22	MYSURU	66	MANDYA-MC 2	NO STATIONS EFFECTED	9:45	14:49	5:04	LINE CLEAR AVAILED
273	20-Feb-22	MYSURU	66	MANDYA-MC 4	MANDYA_66	9:45	14:49	5:04	LINE CLEAR AVAILED
274	20-Feb-22	MYSURU	66	NAGAMANGALA-KR PETE	NO STATIONS EFFECTED	16:27:44 (19.02.2022)			LINE OPEN:LINE CLEAR AVAILED
275	20-Feb-22	MYSURU	66	SATHEGALA-HEBBANI	SATHEGALA_66	10:00	18:07	8:07	LINE CLEAR AVAILED
276	20-Feb-22	MYSURU	220	HV2	MADHUVANAHALLI_220	15:36	16:56	1:20	LINE CLEAR AVAILED
277	20-Feb-22	MYSURU	220	MADHUVANAHALLI-WARDHA SOLAR	NO STATIONS EFFECTED	18:45	20:45	2:00	LINE CLEAR AVAILED
278	20-Feb-22	TUMKUR	66	ANCHEPALYA 220KV- HEBBUR_66	HEBBUR_66,THIMMASANDRA_66,HONNENAHALLI_66	6:40	7:03	0:22	HAND TRIPPED
279	20-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAHMASANDRA_66,THOVINAKERE_66,ANKASANDRA_66	16:23	16:46	0:23	HAND TRIPPED
280	20-Feb-22	TUMKUR	66	BADAVANAHALLI-MADHUGIRI66	BADAVANAHALLI_66	11:08	16:43	5:34	MAIN SUPPLY FAILURE
281	20-Feb-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:30	5:44	0:14	LINE FAULT
282	20-Feb-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:34	15:45	0:11	LINE FAULT
283	20-Feb-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:03	22:12	0:09	LINE FAULT
284	20-Feb-22	TUMKUR	66	MADHUGIRI 220kv- MEDIGESHI 1	MEDIGESHI_66,I D HALLI_66,KODIGENAHALLI_66,HOSKERE_66	13:09	13:37	0:28	HAND TRIPPED
285	20-Feb-22	TUMKUR	66	MADHUGIRI 220kv- MEDIGESHI 1	MEDIGESHI_66,I D HALLI_66,KODIGENAHALLI_66,HOSKERE_66	13:37	13:43	0:05	HAND TRIPPED
286	20-Feb-22	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	SIRA_66,GULIGENAHALLI_66	13:09	13:41	0:31	HAND TRIPPED
287	20-Feb-22	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	SIRA_66,GULIGENAHALLI_66	15:38	16:00	0:21	HAND TRIPPED
288	20-Feb-22	TUMKUR	66	MADHUGIRI 66KV- BADAVANAHALLI	BADAVANAHALLI_66	11:03	16:53	5:49	LINE CLEAR AVAILED
289	20-Feb-22	TUMKUR	66	MADHUGIRI 66KV- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	11:03	16:49	5:45	LINE CLEAR AVAILED
290	20-Feb-22	TUMKUR	66	MADHUGIRI 66KV- MADHUGIRI (OLD) 220KV	MADHUGIRI_66	11:03	16:49	5:45	LINE CLEAR AVAILED
291	20-Feb-22	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	11:43	12:09	0:25	LINE FAULT
292	20-Feb-22	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	15:40	15:44	0:04	LINE FAULT
293	20-Feb-22	TUMKUR	66	PAVAGADA220-PAVAGADA2	PAVAGADA_220	11:44	11:54	0:10	LINE FAULT
294	20-Feb-22	TUMKUR	66	PAVAGADA220-PAVAGADA2	PAVAGADA_220	19:53	19:55	0:02	LINE FAULT
295	20-Feb-22	TUMKUR	66	PAVAGADA220-SHYLAPURA66	SHYLAPURA_66	14:28	14:30	0:01	LINE FAULT
296	20-Feb-22	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	16:05	16:16	0:11	HAND TRIPPED
297	20-Feb-22	TUMKUR	66	TR-1		16:43	16:53	0:10	MAIN SUPPLY FAILURE
298	20-Feb-22	TUMKUR	66	TR-1	KORATAGERE_66	8:27	8:35	0:07	TRANSFORMER FAULT
299	20-Feb-22	TUMKUR	66	TR-1	MADHUGIRI_66	11:03	16:50	5:46	LINE CLEAR AVAILED
300	20-Feb-22	TUMKUR	66	TR-1	MADHUGIRI_220	13:08	13:39	0:31	HAND TRIPPED
301	20-Feb-22	TUMKUR	66	TR-1	MADHUGIRI_220	15:36	15:56	0:20	HAND TRIPPED
302	20-Feb-22	TUMKUR	66	TR-1(HV SIDE)	PAVAGADA_220	8:44	8:49	0:05	TRANSFORMER FAULT
303	20-Feb-22	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	16:25	16:45	0:20	HAND TRIPPED
304	20-Feb-22	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	11:43	11:54	0:10	TRANSFORMER FAULT
305	20-Feb-22	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	15:40	15:45	0:05	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
306	20-Feb-22	TUMKUR	66	TR-2		16:43	16:53	0:10	MAIN SUPPLY FAILURE
307	20-Feb-22	TUMKUR	66	TR-2	BRAMASANDRA_66	8:55	9:02	0:06	TRANSFORMER FAULT
308	20-Feb-22	TUMKUR	66	TR-2	MADHUGIRI_66	11:03	16:51	5:48	LINE CLEAR AVAILED
309	20-Feb-22	TUMKUR	66	TR-2	MADHUGIRI_220	13:09	13:10	0:01	HAND TRIPPED
310	20-Feb-22	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	16:25	16:45	0:20	HAND TRIPPED
311	20-Feb-22	TUMKUR	66	TR-2(LV SIDE)	PAVAGADA_220	11:43	11:55	0:11	TRANSFORMER FAULT
312	20-Feb-22	TUMKUR	66	TR-2(LV SIDE)	PAVAGADA_220	12:03	12:09	0:05	TRANSFORMER FAULT
313	20-Feb-22	TUMKUR	66	TR-2(LV SIDE)	PAVAGADA_220	15:40	15:46	0:06	TRANSFORMER FAULT
314	20-Feb-22	TUMKUR	110	HONNAVALI 110- KADUR110	HONNAVALI_110	16:53	17:02	0:08	LINE FAULT
315	20-Feb-22	TUMKUR	110	HONNAVALI 110-TIPTUR	HONNAVALI_110	16:53	17:12	0:18	LINE FAULT
316	20-Feb-22	TUMKUR	220	ANTHRASANAHALLI 220KV- SHIMOGA	ANTHRASANAHALLI_220	16:03	16:57	0:54	HAND TRIPPED
317	20-Feb-22	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	16:48	16:56	0:07	HAND TRIPPED
318	20-Feb-22	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	13:45	17:27	3:42	LINE CLEAR AVAILED
319	20-Feb-22	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	3:24	13:15	9:51	LOAD CURTAILMENT
320	20-Feb-22	TUMKUR	220	NITTUR 220-NELAMANGALA	NITTUR_220	11:54	14:43	2:49	HAND TRIPPED
321	20-Feb-22	TUMKUR	220	TR-1	MADHUGIRI_220	13:10	15:56	2:45	LINE CLEAR AVAILED
322	20-Feb-22	TUMKUR	220	TR-1	PAVAGADA_220	11:43	11:55	0:11	TRANSFORMER FAULT
323	20-Feb-22	TUMKUR	220	TR-1	PAVAGADA_220	12:00	12:05	0:05	TRANSFORMER FAULT
324	20-Feb-22	TUMKUR	220	TR-1	PAVAGADA_220	15:40	15:45	0:05	TRANSFORMER FAULT
325	20-Feb-22	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	16:16	16:47	0:30	HAND TRIPPED
326	20-Feb-22	TUMKUR	220	TR-2	PAVAGADA_220	11:43	11:55	0:11	TRANSFORMER FAULT
327	20-Feb-22	TUMKUR	220	TR-2	PAVAGADA_220	12:00	12:05	0:05	TRANSFORMER FAULT
328	20-Feb-22	TUMKUR	220	TR-2	PAVAGADA_220	15:40	15:45	0:05	TRANSFORMER FAULT
329	20-Feb-22	TUMKUR	220	TR-3	ANTHRASANAHALLI_220	16:24	16:35	0:11	HAND TRIPPED
330	21-Feb-22	BAGALKOT	110	110/11KV, HV1	CHANDKAVATTI_110	16:01	17:21	1:20	LINE CLEAR AVAILED
331	21-Feb-22	BAGALKOT	110	110/11kv, HV1	STATION NOT AFFECTED NAREGAL_110	9:36	9:42	0:06	TRANSFORMER FAULT
332	21-Feb-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NAGANUR_110	16:08	16:27	0:19	LINE CLEAR AVAILED
333	21-Feb-22	BAGALKOT	110	110/11KV,HV1	MUGALKHOD_220	9:22	9:38	0:16	TRANSFORMER FAULT
334	21-Feb-22	BAGALKOT	110	110/11KV,HV1	HUBLI_220	15:23	16:17	0:54	LINE CLEAR AVAILED
335	21-Feb-22	BAGALKOT	110	110/11KV,HV1	YARAGATTI_110	12:00	13:30	1:30	LINE CLEAR AVAILED
336	21-Feb-22	BAGALKOT	110	110/11KV,HV1	UDIKERI_110	15:50	16:20	0:30	HAND TRIPPED
337	21-Feb-22	BAGALKOT	110	110/11KV,HV2	UDIKERI_110	15:05	15:40	0:35	TRANSFORMER FAULT
338	21-Feb-22	BAGALKOT	110	AMBEWADI-HALIYAL	HALIYAL_110	8:45	19:23	10:38	LINE CLEAR AVAILED
339	21-Feb-22	BAGALKOT	110	AMBEWADI-NK-1(HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	8:26	19:23	10:57	LINE CLEAR AVAILED
340	21-Feb-22	BAGALKOT	110	AMBEWADI-NK-2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	8:26	19:18	10:52	LINE CLEAR AVAILED
341	21-Feb-22	BAGALKOT	110	GADAG220- BETAGERI	STATION NOT AFFECTED GADAG_220	15:42 (14.12.2021)			LINE OPEN:LINE CLEAR AVAILED
342	21-Feb-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN:LINE CLEAR AVAILED
343	21-Feb-22	BAGALKOT	110	HAVERI220- BASAVANAKATTI	BASAVANKATTI_110	14:25	14:48	0:23	LINE FAULT
344	21-Feb-22	BAGALKOT	110	HOSAHONNATTI- GUTTAL	HOSAHONNATTI_110	23:08	23:24	0:16	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
345	21-Feb-22	BAGALKOT	110	MAMADAPUR(B)-BELGAUM SOLAR	BELGAUM SOLAR_110 STATION NOT AFFECTED MAMADAPUR(B)_110	18:16	19:20	1:04	LINE CLEAR AVAILED
346	21-Feb-22	BAGALKOT	110	RANEENNUR-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEENNUR_220	18:42 (14.02.2022)			LINE OPEN:LINE CLEAR AVAILED
347	21-Feb-22	BAGALKOT	110	RANEENNUR-HONNATTI	HONNATTI_110	23:08	23:18	0:10	LINE FAULT
348	21-Feb-22	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	STATION NOT AFFECTED CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN:LINE CLEAR AVAILED
349	21-Feb-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	12:28 (02.02.2022)			LINE OPEN:LINE FAULT
350	21-Feb-22	BAGALKOT	220	HAVERI- GUTTUR1	STATION NOT AFFECTED HAVERI_220	20:31 (21.02.2022)			LINE OPEN:LINE CLEAR AVAILED
351	21-Feb-22	BAGALKOT	220	HAVERI- GUTTUR2	STATION NOT AFFECTED HAVERI_220	10:52	18:18	7:26	LINE CLEAR AVAILED
352	21-Feb-22	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	11:44 (20.02.2022)	18:20 (21.02.2022)	30:36 hrs	LINE CHARGED
353	21-Feb-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
354	21-Feb-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:24 (09.02.2022)			LINE OPEN:LINE CLEAR AVAILED
355	21-Feb-22	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	16:08	16:11	0:03	LOAD CHANGEOR
356	21-Feb-22	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	12:28	12:34	0:06	MAIN SUPPLY FAILURE
357	21-Feb-22	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	18:29	18:50	0:21	MAIN SUPPLY FAILURE
358	21-Feb-22	BENGALURU	66	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	8:57	10:19	1:22	LOAD CURTAILMENT
359	21-Feb-22	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	16:18	16:24	0:06	MAIN SUPPLY FAILURE
360	21-Feb-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	16:18	16:28	0:10	MAIN SUPPLY FAILURE
361	21-Feb-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	16:18	16:28	0:10	MAIN SUPPLY FAILURE
362	21-Feb-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	22:26	22:30	0:04	LOAD CHANGEOR
363	21-Feb-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	22:26	22:28	0:02	LOAD CHANGEOR
364	21-Feb-22	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	18:49	18:53	0:04	LOAD CHANGEOR
365	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	13:02	13:07	0:05	MAIN SUPPLY FAILURE
366	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	13:50	14:18	0:28	MAIN SUPPLY FAILURE
367	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	13:02	13:07	0:05	MAIN SUPPLY FAILURE
368	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	13:50	14:18	0:28	MAIN SUPPLY FAILURE
369	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADOSANAHALLI	13:02	13:07	0:05	MAIN SUPPLY FAILURE
370	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADOSANAHALLI	13:50	14:18	0:28	MAIN SUPPLY FAILURE
371	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR	13:02	13:07	0:05	MAIN SUPPLY FAILURE
372	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR	13:50	14:18	0:28	MAIN SUPPLY FAILURE
373	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	13:02	13:07	0:05	MAIN SUPPLY FAILURE
374	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	13:50	14:18	0:28	MAIN SUPPLY FAILURE
375	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA, NITRALLI	13:02	13:07	0:05	MAIN SUPPLY FAILURE
376	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	13:50	14:18	0:28	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
377	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	NO STATION AFFECTED	13:02	13:07	0:05	MAIN SUPPLY FAILURE
378	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	NO STATION AFFECTED	13:50	14:18	0:28	MAIN SUPPLY FAILURE
379	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	13:02	13:07	0:05	MAIN SUPPLY FAILURE
380	21-Feb-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	13:50	14:18	0:28	MAIN SUPPLY FAILURE
381	21-Feb-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	10:22	11:45	1:23	LINE CLEAR AVAILED
382	21-Feb-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	12:45	12:53	0:08	LINE FAULT
383	21-Feb-22	BENGALURU	66	HV1	EPIP 220	11:18	12:10	0:52	LINE CLEAR AVAILED
384	21-Feb-22	BENGALURU	66	HV1	EPIP 220	12:20	13:09	0:49	LINE CLEAR AVAILED
385	21-Feb-22	BENGALURU	66	HV1	SARJAPURA 220	12:31	12:42	0:11	LOAD CHANGEOVER
386	21-Feb-22	BENGALURU	66	HV2	BTM 4TH PHASE	12:42	12:47	0:05	TRANSFORMER FAULT
387	21-Feb-22	BENGALURU	66	HV2	SARJAPURA 220	10:56	11:59	1:03	LINE CLEAR AVAILED
388	21-Feb-22	BENGALURU	66	HV2	SARJAPURA 220	12:21	12:30	0:09	LOAD CHANGEOVER
389	21-Feb-22	BENGALURU	66	HV2	MULBAGLU	15:06	16:40	1:34	LINE CLEAR AVAILED
390	21-Feb-22	BENGALURU	66	HV3	EPIP 220	5:09	5:37	0:28	LINE CLEAR AVAILED
391	21-Feb-22	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	16:09	16:22	0:13	LOAD CHANGEOVER
392	21-Feb-22	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	12:28	13:03	0:35	MAIN SUPPLY FAILURE
393	21-Feb-22	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	18:30	18:56	0:26	MAIN SUPPLY FAILURE
394	21-Feb-22	BENGALURU	66	KIADB DB PURA 220 - APPEAREL PARK	APPEAREL PARK	13:02	13:07	0:05	MAIN SUPPLY FAILURE
395	21-Feb-22	BENGALURU	66	KIADB DB PURA 220 - APPEAREL PARK	APPEAREL PARK	13:50	14:21	0:31	MAIN SUPPLY FAILURE
396	21-Feb-22	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT)	HIMAT SINGHA FACTORY (EHT)	13:02	13:07	0:05	MAIN SUPPLY FAILURE
397	21-Feb-22	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT)	HIMAT SINGHA FACTORY (EHT)	13:50	14:21	0:31	MAIN SUPPLY FAILURE
398	21-Feb-22	BENGALURU	66	KIADB DB PURA 220 - INDO MM (EHT)	INDO MM (EHT)	13:02	13:07	0:05	MAIN SUPPLY FAILURE
399	21-Feb-22	BENGALURU	66	KIADB DB PURA 220 - INDO MM (EHT)	INDO MM (EHT)	13:50	14:21	0:31	MAIN SUPPLY FAILURE
400	21-Feb-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	8:57	9:03	0:06	LINE FAULT
401	21-Feb-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	13:02	13:10	0:08	MAIN SUPPLY FAILURE
402	21-Feb-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	13:50	14:21	0:31	MAIN SUPPLY FAILURE
403	21-Feb-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	13:02	13:10	0:08	MAIN SUPPLY FAILURE
404	21-Feb-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	13:50	14:21	0:31	MAIN SUPPLY FAILURE
405	21-Feb-22	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	13:02	13:10	0:08	MAIN SUPPLY FAILURE
406	21-Feb-22	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	13:50	14:21	0:31	MAIN SUPPLY FAILURE
407	21-Feb-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	13:02	13:10	0:08	MAIN SUPPLY FAILURE
408	21-Feb-22	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	13:50	14:21	0:31	MAIN SUPPLY FAILURE
409	21-Feb-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	13:02	13:11	0:09	MAIN SUPPLY FAILURE
410	21-Feb-22	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	13:50	14:21	0:31	MAIN SUPPLY FAILURE
411	21-Feb-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	13:02	13:11	0:09	MAIN SUPPLY FAILURE
412	21-Feb-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	13:50	14:21	0:31	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
413	21-Feb-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	13:02	13:11	0:09	MAIN SUPPLY FAILURE
414	21-Feb-22	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	13:50	14:21	0:31	MAIN SUPPLY FAILURE
415	21-Feb-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	17:12	17:23	0:11	LOAD CHANGEOVER
416	21-Feb-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	15:44	16:15	0:31	MAIN SUPPLY FAILURE
417	21-Feb-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:31	12:40	0:09	LOAD CHANGEOVER
418	21-Feb-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:50	10:55	0:05	LOAD CHANGEOVER
419	21-Feb-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:00	12:30	0:30	LOAD CHANGEOVER
420	21-Feb-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:50	10:55	0:05	LOAD CHANGEOVER
421	21-Feb-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:00	12:29	0:29	LOAD CHANGEOVER
422	21-Feb-22	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI, GURUVINAPURA	10:01	10:16	0:15	LINE FAULT
423	21-Feb-22	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	11:00	12:42	1:42	LINE FAULT
424	21-Feb-22	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	15:44	16:15	0:31	LINE FAULT
425	21-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	12:18	13:26	1:08	LINE FAULT
426	21-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	15:09	16:41	1:32	LINE FAULT
427	21-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	16:54	17:19	0:25	LINE FAULT
428	21-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	17:35	18:35	1:00	LINE FAULT
429	21-Feb-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	18:35	20:34	1:59	LINE CLEAR AVAILED
430	21-Feb-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE	13:04	13:54	0:50	LINE FAULT
431	21-Feb-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	13:06	14:20	1:14	LINE CLEAR AVAILED
432	21-Feb-22	BENGALURU	66	VRISHABHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	12:28	13:07	0:39	LINE CLEAR AVAILED
433	21-Feb-22	BENGALURU	66	VRISHABHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	18:29	18:51	0:22	LINE CLEAR AVAILED
434	21-Feb-22	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	REMCO	12:28	12:58	0:30	LINE CLEAR AVAILED
435	21-Feb-22	BENGALURU	66	VRISHABHAVATHI 220 - REMCO	REMCO	18:29	18:58	0:29	LINE CLEAR AVAILED
436	21-Feb-22	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	12:28	13:15	0:47	LINE CLEAR AVAILED
437	21-Feb-22	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	18:29	18:56	0:27	LINE CLEAR AVAILED
438	21-Feb-22	BENGALURU	66	WELCASTE STEEL - ABBIGERE	WELCASTE STEEL	0:10	0:14	0:04	LOAD CHANGEOVER
439	21-Feb-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	17:05	17:10	0:05	LOAD CHANGEOVER
440	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	KIADB DB PURA 220	13:02	13:07	0:05	MAIN SUPPLY FAILURE
441	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	KIADB DB PURA 220	13:50	14:18	0:28	MAIN SUPPLY FAILURE
442	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	13:02	13:07	0:05	MAIN SUPPLY FAILURE
443	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	13:50	14:18	0:28	MAIN SUPPLY FAILURE
444	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	13:02	13:07	0:05	MAIN SUPPLY FAILURE
445	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	13:50	14:18	0:28	MAIN SUPPLY FAILURE
446	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	13:02	13:07	0:05	MAIN SUPPLY FAILURE
447	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 1	GOWRIBIDANUR 220	13:50	14:18	0:28	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
448	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	13:02	13:07	0:05	MAIN SUPPLY FAILURE
449	21-Feb-22	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	GOWRIBIDANUR 220	13:50	14:18	0:28	MAIN SUPPLY FAILURE
450	21-Feb-22	BENGALURU	220	HV1	SARIAPURA 220	10:56	12:28	1:32	LINE CLEAR AVAILED
451	21-Feb-22	BENGALURU	220	HV2	SARIAPURA 220	10:56	12:28	1:32	LINE CLEAR AVAILED
452	21-Feb-22	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI 220	VRISHABHAVATHI 220	12:28	12:50	0:22	LINE FAULT
453	21-Feb-22	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220	VRISHABHAVATHI 220	12:28	12:47	0:19	MAIN SUPPLY FAILURE
454	21-Feb-22	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220	VRISHABHAVATHI 220	18:29	18:46	0:17	MAIN SUPPLY FAILURE
455	21-Feb-22	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP,BHALKI SUGAR_IPP	18:05	18:08	0:03	LINE FAULT
456	21-Feb-22	GULBARGA	110	HV2	DEODURGA_110	3:12	3:19	0:07	TRANSFORMER FAULT
457	21-Feb-22	GULBARGA	110	HV2	KAVITAL_110	15:05	17:37	2:32	TRANSFORMER FAULT
458	21-Feb-22	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	20:35	20:40	0:05	LINE FAULT
459	21-Feb-22	GULBARGA	110	LV1	HUMNABAD_220	9:36	15:57	6:21	LOAD CHANGEOVER
460	21-Feb-22	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAMDINNI_110	13:02	13:22	0:20	LINE FAULT
461	21-Feb-22	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	5:45	5:50	0:05	LINE FAULT
462	21-Feb-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN:LINE CLEAR AVAILED
463	21-Feb-22	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	21:13 (20.02.2022)	5:44 (21.02.2022)	8:31 HRS	LINE CHARGED
464	21-Feb-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	14:30	14:40	0:10	LINE FAULT
465	21-Feb-22	GULBARGA	110	YERADONA-BENUR	BENUR_110	21:15	21:20	0:05	LINE FAULT
466	21-Feb-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
467	21-Feb-22	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	9:10	19:05	9:55	LINE CLEAR AVAILED
468	21-Feb-22	GULBARGA	220	LINGAPUR-GANGAVATHI2	GANGAVATHI_220	10:54	13:24	2:30	LINE CLEAR AVAILED
469	21-Feb-22	GULBARGA	220	MALLAT-RTPS	MALLAT_220	0:31	0:57	0:26	LINE FAULT
470	21-Feb-22	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	11:25	12:46	1:21	LINE CLEAR AVAILED
471	21-Feb-22	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	7:42	13:54	6:12	LINE FAULT
472	21-Feb-22	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	10:06	17:38	7:32	LINE CLEAR AVAILED
473	21-Feb-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	8:30	8:35	0:05	LINE FAULT
474	21-Feb-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	9:40	12:26	2:46	LINE CLEAR AVAILED
475	21-Feb-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	20:38	20:44	0:06	LINE FAULT
476	21-Feb-22	HASSAN	66	HV1	DODDAHALLY_66	10:14	10:37	0:23	LINE CLEAR AVAILED
477	21-Feb-22	HASSAN	66	HV1	DODDAHALLY_66	20:44	20:48	0:04	MAIN SUPPLY FAILURE
478	21-Feb-22	HASSAN	66	HV1	SINGAPURA_66	10:31	18:29	7:58	NFBC ISSUED
479	21-Feb-22	HASSAN	66	HV1	YESLUR_66	11:10	11:18	0:08	MAIN SUPPLY FAILURE
480	21-Feb-22	HASSAN	66	HV2	HALEBEEDU_66	14:56	16:54	1:58	LINE CLEAR AVAILED
481	21-Feb-22	HASSAN	66	HV2	KANDLI_66	9:55 (21.02.2022)			TRANSFORMER OPEN:LINE CLEAR AVAILED
482	21-Feb-22	HASSAN	66	HV2	BASAVAGHATTA_66	12:05	12:38	0:33	LINE CLEAR AVAILED
483	21-Feb-22	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	7:42	14:20	6:38	LINE FAULT
484	21-Feb-22	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	8:30	8:35	0:05	MAIN SUPPLY FAILURE
485	21-Feb-22	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	8:37	12:35	3:58	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
486	21-Feb-22	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	9:30	17:25	7:55	LINE CLEAR AVAILED
487	21-Feb-22	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	8:30	8:40	0:10	LINE FAULT
488	21-Feb-22	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	9:30	17:25	7:55	LINE CLEAR AVAILED
489	21-Feb-22	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	10:06	17:40	7:34	NFBC ISSUED
490	21-Feb-22	HASSAN	110	HULICA-HSNGD	HULICAL_110	10:40	18:55	8:15	LINE CLEAR AVAILED
491	21-Feb-22	HASSAN	110	HULICA-KVR	HULICAL_110	10:40 (21.02.2022)			LINE OPEN:LINE CLEAR AVAILED
492	21-Feb-22	HASSAN	110	HV1	NITTUR_110	19:06	19:12	0:06	TRANSFORMER FAULT
493	21-Feb-22	HASSAN	110	HV1	HULICAL_110	10:40	18:55	8:15	LINE CLEAR AVAILED
494	21-Feb-22	HASSAN	110	HV1	SAGARA_110	10:18	11:05	0:47	TRANSFORMER FAULT
495	21-Feb-22	HASSAN	110	KADUR-NERELEKERE	KADUR_220	13:50	14:05	0:15	HAND TRIPPED
496	21-Feb-22	HASSAN	110	KADUR-NGNHL	KADUR_220	13:50	14:05	0:15	HAND TRIPPED
497	21-Feb-22	HASSAN	110	LV1	KADUR_220	13:52	14:03	0:11	LINE CLEAR AVAILED
498	21-Feb-22	HASSAN	220	HGUNJE-LINE3	HEGGUNJE_220	11:31	13:42	2:11	NFBC ISSUED
499	21-Feb-22	HASSAN	220	HV1	KADUR_220	13:52	14:03	0:11	LINE CLEAR AVAILED
500	21-Feb-22	HASSAN	220	KEMAR-BAIPE2	KEMAR_220	10:14	15:19	5:05	NFBC ISSUED
501	21-Feb-22	HASSAN	220	KEMAR-HEGGUNJE	KEMAR_220	11:30	13:42	2:12	LINE CLEAR AVAILED
502	21-Feb-22	HASSAN	220	KEMAR-Varahi1	KEMAR_220	14:21	15:57	1:36	LINE CLEAR AVAILED
503	21-Feb-22	HASSAN	220	KEMAR-VARAH12	KEMAR_220	16:04	17:42	1:38	LINE CLEAR AVAILED
504	21-Feb-22	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:36	14:46	4:10	LINE CLEAR AVAILED
505	21-Feb-22	HASSAN	220	VARAH1-KEMAR1	varahi_gen	13:54	15:57	2:03	NFBC ISSUED
506	21-Feb-22	HASSAN	220	VARAH1-KEMAR2	varahi_gen	16:05	17:42	1:37	NFBC ISSUED
507	21-Feb-22	MYSURU	66	BANNIMANTAPA-FTS	NO STATIONS EFFECTED	10:46	11:13	0:26	HAND TRIPPED
508	21-Feb-22	MYSURU	66	BANNIMANTAPA-VIJAYANAGARA	BANNIMANTAP_66	10:46	11:13	0:26	HAND TRIPPED
509	21-Feb-22	MYSURU	66	CR NAGARA-HONGANURU	HONGANOORU_66	18:41	18:45	0:04	LINE FAULT
510	21-Feb-22	MYSURU	66	HEBBANI-MADHUVANALLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN:LINE CLEAR AVAILED
511	21-Feb-22	MYSURU	66	HEBBANI-MEGHALAPURA	BGPURA_66CHIDRAVALLI_66THUMBLA_66 VYASRAJPURA_66GARGESHWARI_66	13:05	13:59	0:54	LINE FAULT
512	21-Feb-22	MYSURU	66	HEBBANI-SATTEGALA	NO STATIONS EFFECTED	13:05	14:04	0:59	LINE FAULT
513	21-Feb-22	MYSURU	66	HEBBANI-SFC 1	NO STATIONS EFFECTED	11:51	14:16	2:25	LINE CLEAR AVAILED
514	21-Feb-22	MYSURU	66	HEBBANI-SFC 2	NO STATIONS EFFECTED	11:51	13:05	1:14	LINE CLEAR AVAILED
515	21-Feb-22	MYSURU	66	HEBBANI-SFC 2	NO STATIONS EFFECTED	13:05:00 (21.02.2022)			LINE OPEN:LINE FAULT
516	21-Feb-22	MYSURU	66	HEBBANI-SFC 4	NO STATIONS EFFECTED	13:05	15:24	2:19	LINE FAULT
517	21-Feb-22	MYSURU	66	HEBBANI-SFC 5	NO STATIONS EFFECTED	13:05	15:24	2:19	LINE FAULT
518	21-Feb-22	MYSURU	66	HEBBANI-SFC 6	NO STATIONS EFFECTED	13:05	14:05	1:00	LINE FAULT
519	21-Feb-22	MYSURU	66	HEBBANI-SFC 7	NO STATIONS EFFECTED	13:05	14:05	1:00	LINE FAULT
520	21-Feb-22	MYSURU	66	HEBBANI-SFC 8	NO STATIONS EFFECTED	13:05	14:10	1:05	LINE FAULT
521	21-Feb-22	MYSURU	66	HEBBANI-SFC 9	NO STATIONS EFFECTED	13:05	14:01	0:56	LINE FAULT
522	21-Feb-22	MYSURU	66	HEBBANI-SHIMSHA	NO STATIONS EFFECTED	13:05	14:14	1:09	LINE FAULT
523	21-Feb-22	MYSURU	66	HEBBANI-VADAKEPURA	NO STATIONS EFFECTED	12:44	15:17	2:33	LINE CLEAR AVAILED
524	21-Feb-22	MYSURU	66	HOOTAGALLI-FTS 1	NO STATIONS EFFECTED	9:32	18:04	8:32	LINE CLEAR AVAILED
525	21-Feb-22	MYSURU	66	HOOTAGALLI-FTS 2	NO STATIONS EFFECTED	9:32	18:04	8:32	LINE CLEAR AVAILED
526	21-Feb-22	MYSURU	66	HV1	SOMANAHALLI_66	8:53	8:58	0:05	TRANSFORMER FAULT
527	21-Feb-22	MYSURU	66	HV1	HARIYALDAMMATAMPLE_66	10:30	15:30	5:00	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
528	21-Feb-22	MYSURU	66	HV1	CHANDALLI_66	11:05	11:10	0:05	TRANSFORMER FAULT
529	21-Feb-22	MYSURU	66	HV1	HUNSUR_66	12:50	13:50	1:00	LINE CLEAR AVAILED
530	21-Feb-22	MYSURU	66	HV1	PERIYAPATNA_66	15:44	16:18	0:34	LINE CLEAR AVAILED
531	21-Feb-22	MYSURU	66	HV2	HUNSUR_66	14:25	14:40	0:15	LINE CLEAR AVAILED
532	21-Feb-22	MYSURU	66	HV2	PERIYAPATNA_66	15:44	16:20	0:35	LINE CLEAR AVAILED
533	21-Feb-22	MYSURU	66	KADAKOLA -DEVNOOR NANJANGUDU	NO STATIONS EFFECTED	16:38:00 (9/1/2022)			LINE OPEN:LINE CLEAR AVAILED
534	21-Feb-22	MYSURU	66	MADHUVANALLY-MAMBALLI	NO STATIONS EFFECTED	10:24	10:32	0:08	LINE FAULT
535	21-Feb-22	MYSURU	66	NAGAMANGALA-KR PETE	NO STATIONS EFFECTED	16:27:44 (19.02.2022)	13:05:00 (21.02.2022)	44:37 hrs	LINE CHARGED
536	21-Feb-22	MYSURU	66	SUNTIKOPPA-MADIKERI	NO STATIONS EFFECTED	11:24	11:38	0:14	HAND TRIPPED
537	21-Feb-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 JAKKANAHALLY_66	11:20	13:03	1:43	LINE CLEAR AVAILED
538	21-Feb-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	HARADANAHALLI(JAK)_66 SHIVALLY _66BASARALU_66KESLAGERE_66	13:10	14:25	1:15	LINE CLEAR AVAILED
539	21-Feb-22	MYSURU	66	TUBINAKERE-PANDAVAPURA	DODDABYADARAHALLI_66PANDAVAPURA_ 66BANANGADI_66BELAGOLA_66	10:10	10:18	0:08	LINE FAULT
540	21-Feb-22	MYSURU	220	HV1	NO STATIONS EFFECTED	13:05	14:09	1:04	TRANSFORMER FAULT
541	21-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	6:45	6:52	0:07	LINE FAULT
542	21-Feb-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	7:07	18:57	11:50	LINE CLEAR AVAILED
543	21-Feb-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	14:27	14:37	0:10	LOAD CURTAILMENT
544	21-Feb-22	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	13:00	13:10	0:10	LOAD CURTAILMENT
545	21-Feb-22	TUMKUR	66	CHITRADURGA 66kv- DAVANAGERE2	CHITRADURGA_66	11:40	12:12	0:32	HAND TRIPPED
546	21-Feb-22	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	8:02	8:04	0:02	LINE FAULT
547	21-Feb-22	TUMKUR	66	HINDASGHATTA66-HIRIYUR220KV	HINDASGHATTA_66	17:08	17:13	0:04	LOAD CURTAILMENT
548	21-Feb-22	TUMKUR	66	MADHUGIRI 220kv- KORATAGERE 1	KORATAGERE_66	5:04	5:14	0:10	LINE FAULT
549	21-Feb-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	18:00	18:31	0:31	NFBC ISSUED
550	21-Feb-22	TUMKUR	66	PKOTE-AZURE SOLAR	PKOTE_66	13:03	14:44	1:40	MAIN SUPPLY FAILURE
551	21-Feb-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	10:04	10:25	0:21	LOAD CURTAILMENT
552	21-Feb-22	TUMKUR	66	PKOTE-CLEAR SOLAR	CLEAR SOLAR	13:03	14:43	1:40	MAIN SUPPLY FAILURE
553	21-Feb-22	TUMKUR	66	PKOTE-SALOTOR SOLAR	SOLITAIRE SOLAR	13:03	14:44	1:40	MAIN SUPPLY FAILURE
554	21-Feb-22	TUMKUR	66	THALLAK 220kv- P R PURA	MADHUGIRI_220	15:16	15:22	0:06	LINE FAULT
555	21-Feb-22	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR_IPP_66	MYLANAHALLI_66, DYAVARANAHALLI_66	15:45	16:58	1:13	LINE CLEAR AVAILED
556	21-Feb-22	TUMKUR	66	TR-1	HANAGAL_66	13:03	14:56	1:53	LINE CLEAR AVAILED
557	21-Feb-22	TUMKUR	66	TR-1	MADHUGIRI_66	10:42	11:42	1:00	LINE CLEAR AVAILED
558	21-Feb-22	TUMKUR	66	TR-1	MADADKERE_66	14:52	15:36	0:43	LINE CLEAR AVAILED
559	21-Feb-22	TUMKUR	66	TR-1	MAVINAKATTE_66	11:26	11:31	0:04	TRANSFORMER FAULT
560	21-Feb-22	TUMKUR	66	TR-1	MAVINAKATTE_66	15:50	16:01	0:11	TRANSFORMER FAULT
561	21-Feb-22	TUMKUR	66	TR-1(HV-1)	PAVAGADA_220	20:59	21:07	0:08	TRANSFORMER FAULT
562	21-Feb-22	TUMKUR	66	TR-2	BRAMASANDRA_66	16:44	18:28	1:44	LINE CLEAR AVAILED
563	21-Feb-22	TUMKUR	66	TR-2	HARIYABBE_66	11:02	11:09	0:06	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
564	21-Feb-22	TUMKUR	66	TR-2	KADAJJI_66	15:55	16:00	0:04	TRANSFORMER FAULT
565	21-Feb-22	TUMKUR	66	TR-2	MADHUGIRI_66	17:31	18:43	1:12	LINE CLEAR AVAILED
566	21-Feb-22	TUMKUR	66	TR-2	MADADKERE_66	15:13	15:43	0:30	LINE CLEAR AVAILED
567	21-Feb-22	TUMKUR	220	MADHUGIRI 220kV- GOWRIBIDANUR220	MADHUGIRI_220	13:02	14:26	1:23	LINE FAULT
568	21-Feb-22	TUMKUR	220	PAVAGADA220-PAVAGADA2	PAVAGADA_220	13:02	13:15	0:13	LINE FAULT
569	21-Feb-22	TUMKUR	220	TR-1(HV & LV)	PAVAGADA_220	13:02	13:15	0:13	TRANSFORMER FAULT
570	21-Feb-22	TUMKUR	220	TR-2(HV&LV)	PAVAGADA_220	13:02	13:15	0:13	TRANSFORMER FAULT