

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 18.02.2020 TO 24.02.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	18-Feb-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI 2	BAGALKOT_220	23:39	23:59	0:20	LINE FAULT
2	18-Feb-2020	BAGALKOT	110	BETAGERI-NAREGALL	NAREGALL_110	15:16	18:42	3:26	LINE CLEAR AVAILED
3	18-Feb-2020	BAGALKOT	110	110/11KV,HV-1&2	GADAG_110	10:03	17:20	7:17	LINE CLEAR AVAILED
4	18-Feb-2020	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	12:23	13:03	0:40	LINE CLEAR AVAILED
5	18-Feb-2020	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	13:04	13:40	0:36	LINE CLEAR AVAILED
6	18-Feb-2020	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	13:44	14:04	0:20	LINE CLEAR AVAILED
7	18-Feb-2020	BAGALKOT	220	BIDNAL-HIREBENDIGERI 1	BIDNAL_220	18:22	19:07	0:45	LINE CLEAR AVAILED
8	18-Feb-2020	BAGALKOT	220	BIDNAL-HIREBENDIGERI 2	BIDNAL_220	17:34	18:21	0:47	LINE CLEAR AVAILED
9	18-Feb-2020	BAGALKOT	110	110/11KV,HV 1	HALIYAL_110	2:01	9:05	7:04	TRANSFORMER FAULT
10	18-Feb-2020	BAGALKOT	110	11/33KV,HV2 &3	HANAGALL_110 & 33KV LAXMIPUR,BELAGALL PET,BOMMANALLI, AKKIALUR	11:35	11:44	0:09	TRANSFORMER FAULT
11	18-Feb-2020	BAGALKOT	110	110/11V,HV 2	HIDIKAL DAM_110	12:14	12:31	0:17	LINE CLEAR AVAILED
12	18-Feb-2020	BAGALKOT	110	110/33KV, HV3	ZALKI_110, HORTI_33	14:29	14:51	0:22	LINE CLEAR AVAILED
13	18-Feb-2020	BAGALKOT	110	110/33KV, HV3	UGARKHUD_110, MANGASULI_33, SHEDBAL_33	13:45	13:48	0:03	LINE CLEAR AVAILED
14	18-Feb-2020	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	15:52	16:04	0:12	LINE CLEAR AVAILED
15	18-Feb-2020	BAGALKOT	110	HUBLI-KADANKOPPA	KADANKOPPA_110	9:54	17:12	7:18	LINE CLEAR AVAILED
16	18-Feb-2020	BAGALKOT	110	NAREGAL-RON	RON_110	11:21	18:43	7:22	LINE CLEAR AVAILED
17	18-Feb-2020	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	14:54	18:53	3:59	LINE CLEAR AVAILED
18	18-Feb-2020	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	12:31	20:17	7:46	LINE CLEAR AVAILED
19	18-Feb-2020	BAGALKOT	110	UAS(NARENDRA2)- MRUTHYUNJAY NAGAR	MRYUNTHJAYANAGAR_110	15:26	16:40	1:14	LINE CLEAR AVAILED
20	18-Feb-2020	BAGALKOT	110	110/33KV, HV1	KUMATA_110, HONNAVAR_33, ANKOLA_33	16:04	16:49	0:45	LINE CLEAR AVAILED
21	18-Feb-2020	BAGALKOT	220	MAHALINGAPUR - ATHANI	MAHALINGAPUR_220	4:15	4:35	0:20	LINE FAULT
22	18-Feb-2020	BAGALKOT	110	110/33KV, HV2	KADANKOPPA_110, DUMMAWAD_33, KALGHATAGI_33, YPR_33	9:51	17:25	7:34	LINE CLEAR AVAILED
23	18-Feb-2020	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33	9:38	9:41	0:03	TRANSFORMER FAULT
24	18-Feb-2020	BAGALKOT	110	110/11KV, HV1	HIREKERUR_110	10:11	11:40	1:29	LINE CLEAR AVAILED
25	18-Feb-2020	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	11:25	11:46	0:21	LINE CLEAR AVAILED
26	18-Feb-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	0:00	0:30	0:30	MAIN SUPPLY FAILURE
27	18-Feb-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	0:00	0:30	0:30	MAIN SUPPLY FAILURE
28	18-Feb-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	0:00	0:30	0:30	MAIN SUPPLY FAILURE
29	18-Feb-2020	BENGALURU	220	KOLAR 220 - MALUR 220	MALUR 220	0:00	0:25	0:25	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
30	18-Feb-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	0:00	0:25	0:25	MAIN SUPPLY FAILURE
31	18-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	0:00	0:25	0:25	MAIN SUPPLY FAILURE
32	18-Feb-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	0:00	0:25	0:25	MAIN SUPPLY FAILURE
33	18-Feb-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	0:00	0:25	0:25	MAIN SUPPLY FAILURE
34	18-Feb-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	0:00	0:25	0:25	MAIN SUPPLY FAILURE
35	18-Feb-2020	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	0:00	0:25	0:25	MAIN SUPPLY FAILURE
36	18-Feb-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	0:00	0:35	0:35	MAIN SUPPLY FAILURE
37	18-Feb-2020	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	0:00	0:35	0:35	MAIN SUPPLY FAILURE
38	18-Feb-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	0:00	0:35	0:35	MAIN SUPPLY FAILURE
39	18-Feb-2020	BENGALURU	220	HV1	VIKAS TECH PARK 220	0:00	0:35	0:35	MAIN SUPPLY FAILURE
40	18-Feb-2020	BENGALURU	220	HV2	VIKAS TECH PARK 220	0:00	0:35	0:35	MAIN SUPPLY FAILURE
41	18-Feb-2020	BENGALURU	66	HV2	WELCAST STEEL	12:22	12:29	0:06	LINE CLEAR AVAILED
42	18-Feb-2020	BENGALURU	66	MELUR - VIJAYAPURA	MELUR	21:30	21:35	0:05	HAND TRIPPED
43	18-Feb-2020	BENGALURU	66	HV2	M GOLAHALLI	17:14	17:21	0:06	TRANSFORMER FAULT
44	18-Feb-2020	BENGALURU	66	HV2	MANCHENAHALLY	13:18	13:31	0:12	TRANSFORMER FAULT
45	18-Feb-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	18:16	19:03	0:46	LINE FAULT
46	18-Feb-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	22:14	23:26	1:12	LINE CLEAR AVAILED
47	18-Feb-2020	BENGALURU	66	HAL 220 - HOODY 1	HAL 220, EDC 220	18:40	19:38	0:58	LINE FAULT
48	18-Feb-2020	BENGALURU	66	HAL 220 - HOODY 1	HAL 220, EDC 220	19:38	23:25	3:47	LINE FAULT
49	18-Feb-2020	BENGALURU	66	HOODY 220 - ITI	ITI	0:02	0:11	0:09	LINE FAULT
50	18-Feb-2020	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD	0:02	0:12	0:10	LINE FAULT
51	18-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	7:15	7:24	0:09	LINE FAULT
52	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	18:12	18:18	0:06	LINE CLEAR AVAILED
53	18-Feb-2020	BENGALURU	66	HV1	HANUMANTHNAGAR	12:51	14:24	1:32	LINE CLEAR AVAILED
54	18-Feb-2020	BENGALURU	66	HV2	HANUMANTHNAGAR	12:53	14:24	1:31	LINE CLEAR AVAILED
55	18-Feb-2020	BENGALURU	66	HV1	HSR LAYOUT 220	13:35	14:29	0:54	LINE CLEAR AVAILED
56	18-Feb-2020	BENGALURU	66	HV2	NRS 220	16:19	16:24	0:05	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
57	18-Feb-2020	BENGALURU	220	HV1	CHINTAMANI 220	0:00	0:25	0:25	MAIN SUPPLY FAILURE
58	18-Feb-2020	BENGALURU	220	HV2	CHINTAMANI 220	0:00	0:25	0:25	MAIN SUPPLY FAILURE
59	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	0:00	0:27	0:27	MAIN SUPPLY FAILURE
60	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	0:00	0:27	0:27	MAIN SUPPLY FAILURE
61	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	0:00	0:27	0:27	MAIN SUPPLY FAILURE
62	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66	0:00	0:27	0:27	MAIN SUPPLY FAILURE
63	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	0:00	0:27	0:27	MAIN SUPPLY FAILURE
64	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	0:00	0:27	0:27	MAIN SUPPLY FAILURE
65	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	0:00	0:27	0:27	MAIN SUPPLY FAILURE
66	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	0:00	0:27	0:27	MAIN SUPPLY FAILURE
67	18-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	0:00	0:27	0:27	MAIN SUPPLY FAILURE
68	18-Feb-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	0:00	0:26	0:26	MAIN SUPPLY FAILURE
69	18-Feb-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	0:00	0:26	0:26	MAIN SUPPLY FAILURE
70	18-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	0:00	14:39	14:39	MAIN SUPPLY FAILURE
71	18-Feb-2020	BENGALURU	66	HV2	KODIHALLI	11:09	18:53	7:44	LINE CLEAR AVAILED
72	18-Feb-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	0:00	0:26	0:26	MAIN SUPPLY FAILURE
73	18-Feb-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	0:00	0:26	0:26	MAIN SUPPLY FAILURE
74	18-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	0:00	0:29	0:29	MAIN SUPPLY FAILURE
75	18-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	0:00	0:25	0:25	MAIN SUPPLY FAILURE
76	18-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	0:00	0:25	0:25	MAIN SUPPLY FAILURE
77	18-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	0:00	0:25	0:25	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
78	18-Feb-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220	0:00	0:30	0:30	MAIN SUPPLY FAILURE
79	18-Feb-2020	GULBARGA	110	KUSHTAGI-SUZLONWIND2_IPP	KUSHTAGI_220	12:15	17:10	4:55	LINE CLEAR AVAILED
80	18-Feb-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	ACMESOLAR_IPP	11:40	11:55	0:15	LINE FAULT
81	18-Feb-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	ACMESOLAR_IPP	12:18	12:30	0:12	LINE FAULT
82	18-Feb-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	ACMESOLAR_IPP	13:16	13:26	0:10	LINE FAULT
83	18-Feb-2020	GULBARGA	110	HV2	DEODURGA_110	12:50	12:55	0:05	TRANSFORMER FAULT
84	18-Feb-2020	GULBARGA	110	HV2	HATTI_110	8:02	8:06	0:04	TRANSFORMER FAULT
85	18-Feb-2020	GULBARGA	110	HALBARGA-KOLHAR 1&2	KOLHAR_110,JANAWADA_110,NSS K_IPP	10:50	16:04	5:14	LINE CLEAR AVAILED
86	18-Feb-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	3:40	3:58	0:18	LINE FAULT
87	18-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGAR_IPP, ASKI_110	4:49	4:55	0:06	LINE FAULT
88	18-Feb-2020	GULBARGA	110	HV1	KAVITAL_110	21:35	21:44	0:09	TRANSFORMER FAULT
89	18-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	21:36	21:46	0:10	LINE FAULT
90	18-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	13:40	23:59	10:19	LINE CLEAR AVAILED
91	18-Feb-2020	GULBARGA	220	SEDAM-HUMNABAD2	SEDAM_220	12:42	16:22	3:40	LINE CLEAR AVAILED
92	18-Feb-2020	GULBARGA	110	SINDHANOOR-PGLR_WIND(NIRLOOTI_IPP)	SINDHANOOR_220	4:50	5:00	0:10	LINE FAULT
93	18-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110, ASKI_110, HUNSGI_110	20:32	20:38	0:06	LINE FAULT
94	18-Feb-2020	GULBARGA	110	HV2	MANVI_110	11:53	12:15	0:22	TRANSFORMER FAULT
95	18-Feb-2020	GULBARGA	110	HV2	MANVI_110	13:13	13:23	0:10	TRANSFORMER FAULT
96	18-Feb-2020	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	13:16	16:16	3:00	LINE CLEAR AVAILED
97	18-Feb-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	20:27	20:48	0:21	LINE FAULT
98	18-Feb-2020	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	14:56	15:30	0:34	LINE FAULT
99	18-Feb-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:59	17:03	2:04	LINE FAULT
100	18-Feb-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	10:06	10:32	0:26	HAND TRIPPED
101	18-Feb-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	10:04	10:32	0:28	LINE CLEAR AVAILED
102	18-Feb-2020	HASSAN	110	HV2	ANANDAPURA_110	9:52	10:43	0:51	LINE CLEAR AVAILED
103	18-Feb-2020	HASSAN	110	HV3	BANTWAL_110	10:16	12:27	2:11	LINE CLEAR AVAILED
104	18-Feb-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	11:02	13:28	2:26	LINE CLEAR AVAILED
105	18-Feb-2020	HASSAN	110	HV1	KONAJE_110	9:31	13:54	4:23	LINE CLEAR AVAILED
106	18-Feb-2020	HASSAN	110	HV1	KONAJE_110	14:07	17:11	3:04	LINE CLEAR AVAILED
107	18-Feb-2020	HASSAN	110	SHIVAPU-NERLEKERE	SHIVPURA_110	14:07	14:56	0:49	LINE CLEAR AVAILED
108	18-Feb-2020	HASSAN	66	HV1	ALDUR_66	21:33	21:57	0:24	TRANSFORMER FAULT
109	18-Feb-2020	HASSAN	66	ALDUR-LINGADAHALLI	bhadra_gen	10:12	10:20	0:08	LINE FAULT
110	18-Feb-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	14:08	14:23	0:15	LINE FAULT
111	18-Feb-2020	HASSAN	66	HV1	HNPURA_66	9:38	17:36	7:58	LINE CLEAR AVAILED
112	18-Feb-2020	HASSAN	66	HV2	MATTNAVILE_66	13:29	13:48	0:19	LINE CLEAR AVAILED
113	18-Feb-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	13:24	13:33	0:09	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
114	18-Feb-2020	MYSORE	66	HV1	DODDARAYAPET_66	16:25	17:50	1:25	LINE CLEAR AVAILED
115	18-Feb-2020	MYSORE	66	HV2	DODDARAYAPET_66	16:38	17:50	1:11	LINE CLEAR AVAILED
116	18-Feb-2020	MYSORE	66	MADIKERI-SUNTIKOPPA	SUNTIKOPPA	12:33	18:29	5:56	NFBC ISSUED
117	18-Feb-2020	MYSORE	66	SANTHESARGURU-B-MATTGERE	B MATKERE_66 SANTHESARAGUR_66	11:35	17:50	6:15	LINE CLEAR AVAILED
118	18-Feb-2020	MYSORE	66	HV2	YELANDUR_66	13:17	16:24	3:06	LINE CLEAR AVAILED
119	18-Feb-2020	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	9:57	10:02	0:05	LINE FAULT
120	18-Feb-2020	MYSORE	66	KADAKOLA-DK MAIDANA	DKMAIDANA_66	18:39	18:43	0:04	LINE FAULT
121	18-Feb-2020	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	7:15	7:37	0:21	LOAD CURTAILMENT
122	18-Feb-2020	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	7:15	7:37	0:21	LOAD CURTAILMENT
123	18-Feb-2020	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	7:15	7:59	0:43	LOAD CURTAILMENT
124	18-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	9:32	9:41	0:08	TRANSFORMER FAULT
125	18-Feb-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	9:02	9:22	0:20	LINE FAULT
126	18-Feb-2020	TUMKUR	66	DASUDI-M/S CLEAN SOLAR	M/S CLEAN SOLAR_IPP_66	7:34	7:39	0:05	LINE FAULT
127	18-Feb-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	15:03	15:16	0:12	MAIN SUPPLY FAILURE
128	18-Feb-2020	TUMKUR	66	HANAGAL_66	TR-1	11:06	11:38	0:31	LINE CLEAR AVAILED
129	18-Feb-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	13:42	14:14	0:32	HAND TRIPPED
130	18-Feb-2020	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	12:57	14:07	1:09	LINE CLEAR AVAILED
131	18-Feb-2020	TUMKUR	66	TR-1	IDHALLY_66	12:57	14:03	1:05	LINE CLEAR AVAILED
132	18-Feb-2020	TUMKUR	66	TR-2	IDHALLY_66	11:59	14:04	2:05	LINE CLEAR AVAILED
133	18-Feb-2020	TUMKUR	66	TR-1	PAVAGADA_220	14:39	16:04	1:25	LINE CLEAR AVAILED
134	18-Feb-2020	TUMKUR	66	TR-2	TAVAREKERE(H)_66	0:09	0:14	0:05	TRANSFORMER FAULT
135	18-Feb-2020	TUMKUR	66	TR-1	TYAVANAGI_66	11:14	12:22	1:08	LINE CLEAR AVAILED
136	19-Feb-2020	BAGALKOT	110	ANKOLA-ARGA(L1)	ANKOLA_110	3:05	12:50	9:45	LINE FAULT
137	19-Feb-2020	BAGALKOT	110	110/33KV ,HV 2	ANKOLA_110 &33KV MASTIKATTA&SEA BIRD	10:02	18:40	8:38	LINE CLEAR AVAILED
138	19-Feb-2020	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	6:44	12:04	5:20	LINE FAULT
139	19-Feb-2020	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	9:36	9:45	0:09	TRANSFORMER FAULT
140	19-Feb-2020	BAGALKOT	110	110/33KV, HV3	SANKESHWAR_110, KANAGALA_33, HEBBAL_33	11:40	12:18	0:38	LINE CLEAR AVAILED
141	19-Feb-2020	BAGALKOT	110	RANEENNUR- AREMALLAPUR (HONNATTI)	HONNATTI_110	6:30	6:41	0:11	LINE FAULT
142	19-Feb-2020	BAGALKOT	110	HUBLI-TARIHAL2	TARIHAL_110	18:12	22:20	4:08	LINE FAULT
143	19-Feb-2020	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	2:20	3:03	0:43	TRANSFORMER FAULT
144	19-Feb-2020	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	15:55	16:20	0:25	LINE CLEAR AVAILED
145	19-Feb-2020	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	16:26	16:46	0:20	LINE CLEAR AVAILED
146	19-Feb-2020	BAGALKOT	110	HUKKERI-HATTARGI	HATTARGI_110	19:14	19:18	0:04	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
147	19-Feb-2020	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	12:17	12:19	0:02	HAND TRIPPED
148	19-Feb-2020	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	13:25	13:45	0:20	LINE FAULT
149	19-Feb-2020	BAGALKOT	110	CHIKKODI220-SANKESHWAR	SANKESHWAR_110	18:49	19:12	0:23	LINE FAULT
150	19-Feb-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:42	11:03	0:21	LINE CLEAR AVAILED
151	19-Feb-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:55	13:05	0:10	LINE CLEAR AVAILED
152	19-Feb-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:30	14:42	0:12	LINE CLEAR AVAILED
153	19-Feb-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:14	13:31	0:16	LINE CLEAR AVAILED
154	19-Feb-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:46	14:58	0:12	LINE CLEAR AVAILED
155	19-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:06	12:11	0:05	LINE FAULT
156	19-Feb-2020	BENGALURU	66	HV1	KODIHALLI	8:26	9:45	1:19	LINE CLEAR AVAILED
157	19-Feb-2020	BENGALURU	66	HV2	KODIHALLI	8:26	9:45	1:19	LINE CLEAR AVAILED
158	19-Feb-2020	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI, BIJJAHALLI	9:50	11:45	1:55	LINE CLEAR AVAILED
159	19-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	10:30	11:35	1:05	LOAD CURTAILMENT
160	19-Feb-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	10:30	11:30	1:00	LOAD CURTAILMENT
161	19-Feb-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	11:56	13:32	1:36	LOAD CURTAILMENT
162	19-Feb-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	13:13	15:30	2:17	LOAD CURTAILMENT
163	19-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	13:13	14:00	0:47	LOAD CURTAILMENT
164	19-Feb-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	16:15	17:46	1:31	LOAD CURTAILMENT
165	19-Feb-2020	BENGALURU	220	HV1	KOLAR 220	17:35	17:45	0:10	TRANSFORMER FAULT
166	19-Feb-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	TAMAKA, MALLASANDRA, DRDO (EHT), DALSNUR	17:36	17:46	0:10	MAIN SUPPLY FAILURE
167	19-Feb-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	17:36	19:10	1:34	MAIN SUPPLY FAILURE
168	19-Feb-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	17:36	17:46	0:10	MAIN SUPPLY FAILURE
169	19-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	17:36	17:46	0:10	MAIN SUPPLY FAILURE
170	19-Feb-2020	BENGALURU	66	HV2	KOLAR 220	17:36	17:46	0:10	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
171	19-Feb-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	19:15	19:20	0:05	LOAD CURTAILMENT
172	19-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	22:10	22:20	0:10	LOAD CURTAILMENT
173	19-Feb-2020	BENGALURU	66	SRS PEENYA 220 - ALUR	ALUR, NELAMANGALA 66	14:02	14:23	0:21	LINE FAULT
174	19-Feb-2020	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	14:02	14:47	0:45	MAIN SUPPLY FAILURE
175	19-Feb-2020	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	17:20	17:27	0:07	LOAD CHANGE OVER
176	19-Feb-2020	BENGALURU	66	MALLASANDRA - TAMAKA	MALLASANDRA, YELDUR, DALASNUR	11:15	11:45	0:30	LOAD CURTAILMENT
177	19-Feb-2020	BENGALURU	66	MALLASANDRA - TAMAKA	MALLASANDRA, YELDUR, DALASNUR	15:30	19:00	3:30	LOAD CURTAILMENT
178	19-Feb-2020	BENGALURU	66	MALLASANDRA - TAMAKA	MALLASANDRA, YELDUR, DALASNUR	19:05	19:20	0:15	LOAD CURTAILMENT
179	19-Feb-2020	BENGALURU	66	HV3	A STATION 66	22:00	23:59	1:59	LINE CLEAR AVAILED
180	19-Feb-2020	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	11:08	11:45	0:37	LINE CLEAR AVAILED
181	19-Feb-2020	BENGALURU	66	HV1	CHELUR	15:15	18:00	2:45	LINE CLEAR AVAILED
182	19-Feb-2020	BENGALURU	66	CHELUR - YENNIGADALE	CHELUR	16:30	18:00	1:30	LINE CLEAR AVAILED
183	19-Feb-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	17:51	18:04	0:13	LINE FAULT
184	19-Feb-2020	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	7:38	7:50	0:12	LINE FAULT
185	19-Feb-2020	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - NAGANATHPURA 220	ELECTRONIC CITY PH-2 SEC-2 , BIOCON(EHT)	18:05	18:34	0:29	LINE FAULT
186	19-Feb-2020	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	18:05	18:34	0:29	LINE FAULT
187	19-Feb-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	19:18	19:38	0:20	LINE FAULT
188	19-Feb-2020	GULBARGA	220	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	9:45	13:53	4:08	LINE CLEAR AVAILED
189	19-Feb-2020	GULBARGA	220	SHAHBAD-KAPNOOR	KAPNOOR_220	8:45	14:20	5:35	LINE CLEAR AVAILED
190	19-Feb-2020	GULBARGA	220	KAPNOOR-SHAHABAD	KAPNOOR_220	8:17	8:40	0:23	LINE CLEAR AVAILED
191	19-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	2:26	2:36	0:10	LINE FAULT
192	19-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	5:16	5:50	0:34	LINE FAULT
193	19-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110	6:01	6:03	0:02	LINE FAULT
194	19-Feb-2020	GULBARGA	110	SEDAM-VICATASAGAR CEMENTS_IPP	VICATASAGAR CEMENTS_IPP	6:40	6:51	0:11	LINE FAULT
195	19-Feb-2020	GULBARGA	110	GABBUR -BP SOLAR	BPSOLAR_IPP	6:10	6:12	0:02	LINE FAULT
196	19-Feb-2020	GULBARGA	110	HV2	HATTI_110	9:41	10:10	0:29	HAND TRIPPED
197	19-Feb-2020	GULBARGA	110	HV2	KAMPLI_GLB_110	7:25	8:08	0:43	TRANSFORMER FAULT
198	19-Feb-2020	GULBARGA	110	ALIPUR-BELLARYNORTH	BELLARYNORTH_110,SOMASAMU DRA_110,MOKA_110,PDHALLI_110 ,BISHALLI_110	11:42	11:54	0:12	LINE FAULT
199	19-Feb-2020	GULBARGA	110	HV1	GULBARGAUNIVERSITY_110	23:05	23:19	0:14	TRANSFORMER FAULT
200	19-Feb-2020	GULBARGA	220	KUSHTAGI-LINGAPUR	KUSTAGI_220	14:50	18:19	3:29	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
201	19-Feb-2020	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	13:13	13:30	0:17	LINE FAULT
202	19-Feb-2020	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	13:50	13:58	0:08	LINE FAULT
203	19-Feb-2020	GULBARGA	220	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	19:50	20:48	0:58	LINE CLEAR AVAILED
204	19-Feb-2020	GULBARGA	220	KUSHTAGI-SUZLONWIND2_IPP	KUSHTAGI_220	9:40	21:22	11:42	LINE CLEAR AVAILED
205	19-Feb-2020	GULBARGA	110	MARAGUTTI-CLNSLR	MARGUTTI_110	18:45	19:50	1:05	LINE CLEAR AVAILED
206	19-Feb-2020	GULBARGA	110	RAJESHWAR-WARDHA	RAJESHWAR_110	18:58	20:26	1:28	LINE CLEAR AVAILED
207	19-Feb-2020	GULBARGA	220	SHAHBAD-SHAHAPUR	SHAHABAD_220	14:32	20:59	6:27	LINE CLEAR AVAILED
208	19-Feb-2020	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	15:55	16:15	0:20	TRANSFORMER FAULT
209	19-Feb-2020	HASSAN	110	HV2	ANANDPURA_110	10:18	10:50	0:32	LINE CLEAR AVAILED
210	19-Feb-2020	HASSAN	110	HV1	GANDASI_110	11:22	11:25	0:03	HAND TRIPPED
211	19-Feb-2020	HASSAN	110	HV2	GANDAS	11:22	11:25	0:03	HAND TRIPPED
212	19-Feb-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	9:01	18:16	9:15	NFBC ISSUED
213	19-Feb-2020	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	19:00	19:06	0:06	LINE FAULT
214	19-Feb-2020	HASSAN	66	HV2	MATTANAVILE_66	12:12	12:15	0:03	TRANSFORMER FAULT
215	19-Feb-2020	HASSAN	66	HV2	RAMESHWARNAGARA_66	9:30	9:43	0:13	HAND TRIPPED
216	19-Feb-2020	HASSAN	66	HV2	RAMESHWARNAGARA_66	12:31	12:39	0:08	HAND TRIPPED
217	19-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	9:00	18:16	9:16	LINE CLEAR AVAILED
218	19-Feb-2020	MYSORE	66	BG PURA-CHANDALLY	CHANDALLI_66	9:28	15:00	5:32	NFBC ISSUED
219	19-Feb-2020	MYSORE	66	HV1	PANDAVAPURA_66	10:04	10:35	0:31	LINE CLEAR AVAILED
220	19-Feb-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	9:45	9:49	0:04	LINE FAULT
221	19-Feb-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	16:14	16:20	0:06	LINE FAULT
222	19-Feb-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	16:41	16:46	0:05	LINE FAULT
223	19-Feb-2020	MYSORE	66	KR PETE 220- MAHADESHWARAPURA	MADESWARAPURA_66 JAKKANAHALLY_66 G MALLIGERE_66 GUDDENAHALLI_66 BOGADHI MANDYA_66 NAGAMANGALA_66	13:00	13:05	0:05	LINE FAULT
224	19-Feb-2020	MYSORE	66	KUSHALANAGARA-MYSORE 1	MIRLE_66 KRNAGARA_66	8:30	8:40	0:10	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
225	19-Feb-2020	MYSORE	66	KUSHALANAGARA-BETTADAPURA	BETTADHAPURA_66 RAVANDUR_66 KITTUR_66 CHUNCHUNKATTE_66	8:30	8:40	0:10	LINE FAULT
226	19-Feb-2020	MYSORE	66	KADAKOLA-DK MAIDANA	DKMAIDANA_66	3:15	3:21	0:06	LINE FAULT
227	19-Feb-2020	MYSORE	66	CH KATTE-KR NAGARA	CHUNCHUNKATTE_66	14:30	18:50	4:20	LINE CLEAR AVAILED
228	19-Feb-2020	MYSORE	66	KR NAGARA-BILIKERE	BILIKERE_66 GVGUDI_66 DMG_HALLI_66	10:40	17:15	6:35	LINE CLEAR AVAILED
229	19-Feb-2020	TUMKUR	110	TR-3	GUBBI_110	12:26	13:49	1:23	LINE CLEAR AVAILED
230	19-Feb-2020	TUMKUR	110	TR-2	KADEHALLI_110	3:05	3:27	0:22	TRANSFORMER FAULT
231	19-Feb-2020	TUMKUR	110	TR-2	SAMPIGE_110	19:21	19:51	0:30	TRANSFORMER FAULT
232	19-Feb-2020	TUMKUR	110	TR-2	SAMPIGE_110	21:46	22:17	0:31	TRANSFORMER FAULT
233	19-Feb-2020	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	15:08	15:55	0:47	LOAD CURTAILMENT
234	19-Feb-2020	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	12:11	12:12	0:01	MAIN SUPPLY FAILURE
235	19-Feb-2020	TUMKUR	66		BADAVANAHALLI_66	16:10	17:55	1:44	LINE CLEAR AVAILED
236	19-Feb-2020	TUMKUR	66	TR-2	BRAHMASANDRA_66	14:25	16:53	2:28	LINE CLEAR AVAILED
237	19-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	8:39	8:49	0:09	TRANSFORMER FAULT
238	19-Feb-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:30	12:09	1:38	LINE FAULT
239	19-Feb-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	17:28	17:40	0:12	LINE FAULT
240	19-Feb-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	DAVANGERE_SRS_220	12:34	12:42	0:08	LINE FAULT
241	19-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:36	9:28	0:51	LINE FAULT
242	19-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:47	11:17	0:29	LINE FAULT
243	19-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:31	10:35	0:04	LINE FAULT
244	19-Feb-2020	TUMKUR	66	TR-1	HANGLA_66	10:13	10:28	0:15	LINE CLEAR AVAILED
245	19-Feb-2020	TUMKUR	66	TR-1	HIRIYUR_66	9:52	19:39	9:47	LINE CLEAR AVAILED
246	19-Feb-2020	TUMKUR	66	TR-1	KUNDUR_66	0:25	0:32	0:06	LINE CLEAR AVAILED
247	19-Feb-2020	TUMKUR	66	TR-1	KUNDUR_66	11:23	11:41	0:17	LINE CLEAR AVAILED
248	19-Feb-2020	TUMKUR	66	TR-1	LINGADAHALLY_66	15:30	15:42	0:11	TRANSFORMER FAULT
249	19-Feb-2020	TUMKUR	66	TR-2	LINGADAHALLY_66	15:30	15:42	0:12	TRANSFORMER FAULT
250	20-Feb-2020	BAGALKOT	110	110/11KV,HV 1	BETAGERI_110	16:30	17:48	1:18	TRANSFORMER FAULT
251	20-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	11:19	13:36	2:17	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
252	20-Feb-2020	BAGALKOT	220	AMBEWADI-NAGJHARI 1	AMBEWADI_220	11:24	13:34	2:10	LINE CLEAR AVAILED
253	20-Feb-2020	BAGALKOT	220	AMBEWADI-NAGJHARI 2	AMBEWADI_220	13:41	16:38	2:57	LINE CLEAR AVAILED
254	20-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	13:39	16:38	2:59	LINE CLEAR AVAILED
255	20-Feb-2020	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	17:02	17:36	0:34	HAND TRIPPED
256	20-Feb-2020	BAGALKOT	220	220/110KV,HV2&LV2	AMBEWADI_220	17:30	20:12	2:42	LINE CLEAR AVAILED
257	20-Feb-2020	BAGALKOT	110	CHIKKODI-NIPPANI	NIPPANI_110	5:18	5:30	0:12	LINE FAULT
258	20-Feb-2020	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	1:45	7:28	5:43	LINE FAULT
259	20-Feb-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	17:32	23:59	6:27	LINE FAULT
260	20-Feb-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110&33KV KARADI,MYTRA SOLAR,AMINAGAD	12:21	16:42	4:21	TRANSFORMER FAULT
261	20-Feb-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, ALSANGI_33, DHULKED_33, NEVARGI_33	11:39	11:45	0:06	TRANSFORMER FAULT
262	20-Feb-2020	BAGALKOT	110	110/33KV, HV3	UGARKHUD_110, SHEDBAL_33	10:19	11:03	0:44	LINE CLEAR AVAILED
263	20-Feb-2020	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	5:40	5:51	0:11	TRANSFORMER FAULT
264	20-Feb-2020	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	4:03	4:13	0:10	LINE FAULT
265	20-Feb-2020	BAGALKOT	110	110/11KV,HV1&HV2	MUNDUGANUR_110	11:22	11:39	0:17	LINE CLEAR AVAILED
266	20-Feb-2020	BAGALKOT	110	MAREGUDDI-MUNDUGANUR	MUNDUGANUR_110	11:22	11:39	0:17	LINE CLEAR AVAILED
267	20-Feb-2020	BAGALKOT	110	110/33KV, HV2	MATTIHAL_110, KOLAR W/S_33, NTPC_33	9:08	12:51	3:43	LINE CLEAR AVAILED
268	20-Feb-2020	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR_33	16:19	17:05	0:46	LINE CLEAR AVAILED
269	20-Feb-2020	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	10:07	10:17	0:10	TRANSFORMER FAULT
270	20-Feb-2020	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	9:51	17:06	7:15	LINE CLEAR AVAILED
271	20-Feb-2020	BAGALKOT	110	110/33KV, HV2	JAMKHANDI_110, HIPPARGI_33	17:44	18:04	0:20	TRANSFORMER FAULT
272	20-Feb-2020	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	6:35	6:43	0:08	LOAD CHANGE OVER
273	20-Feb-2020	BENGALURU	66	WELCAST STEEL - YELAHANKA 220	WELCAST STEEL	13:12	13:17	0:05	LOAD CHANGE OVER
274	20-Feb-2020	BENGALURU	66	HV2	MUDIYANUR	17:05	17:20	0:15	LINE CLEAR AVAILED
275	20-Feb-2020	BENGALURU	66	HV1	MUDIYANUR	16:40	16:50	0:10	TRANSFORMER FAULT
276	20-Feb-2020	BENGALURU	66	HV2	MUDIYANUR	15:25	16:00	0:35	LINE CLEAR AVAILED
277	20-Feb-2020	BENGALURU	66	MITTEMARI 220 - SADLI	DIBURALLI, JILLUPALYA, SADLI	14:23	15:13	0:50	LINE CLEAR AVAILED
278	20-Feb-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	18:36	18:44	0:08	LINE FAULT
279	20-Feb-2020	BENGALURU	66	HV2	MAGADI	14:55	16:08	1:13	LINE CLEAR AVAILED
280	20-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	9:05	9:25	0:20	LOAD CURTAILMENT
281	20-Feb-2020	BENGALURU	220	HV3	KOLAR	10:15	15:28	5:13	LINE CLEAR AVAILED
282	20-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:15	15:28	5:13	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
283	20-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	10:15	10:25	0:10	LINE CLEAR AVAILED
284	20-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:15	10:25	0:10	LINE CLEAR AVAILED
285	20-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	15:10	15:33	0:23	LINE CLEAR AVAILED
286	20-Feb-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	10:44	10:55	0:11	LINE CLEAR AVAILED
287	20-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	15:20	15:32	0:12	LINE CLEAR AVAILED
288	20-Feb-2020	BENGALURU	66	HV2	KANAKAPURA	12:15	12:25	0:10	TRANSFORMER FAULT
289	20-Feb-2020	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	10:25	13:25	3:00	LINE CLEAR AVAILED
290	20-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	10:34	10:37	0:03	LINE CLEAR AVAILED
291	20-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	18:23	18:25	0:02	LINE CLEAR AVAILED
292	20-Feb-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:27	18:31	0:04	LINE CLEAR AVAILED
293	20-Feb-2020	BENGALURU	66	VIDHURASHWATHA - BAGEPALLI 2	GUNDLU KOTTUR, BAGEPALLI	6:20	6:30	0:10	LINE FAULT
294	20-Feb-2020	BENGALURU	66	BAGEPALLI - BAGEPALLI 2	BAGEPALLI	10:00	10:05	0:05	LOAD CHANGE OVER
295	20-Feb-2020	BENGALURU	66	NELAMANGALA 66 - SRS PEENYA 220	NELAMANGALA 66	6:28	6:33	0:05	LOAD CHANGE OVER
296	20-Feb-2020	BENGALURU	66	NELAMANGALA 66 - SRS PEENYA 220	NELAMANGALA 66	6:28	6:33	0:05	LOAD CHANGE OVER
297	20-Feb-2020	BENGALURU	66	HV1	NELAMANGALA 66	6:28	6:33	0:05	LOAD CHANGE OVER
298	20-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPETE 220	NELAMANGALA 66	13:00	13:02	0:02	LOAD CHANGE OVER
299	20-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPETE 220	NELAMANGALA 66	13:00	13:02	0:02	LOAD CHANGE OVER
300	20-Feb-2020	BENGALURU	66	HV1	NELAMANGALA 66	13:00	13:02	0:02	LOAD CHANGE OVER
301	20-Feb-2020	BENGALURU	66	HV1	VIJAYAPURA	7:49	7:55	0:05	LINE CLEAR AVAILED
302	20-Feb-2020	BENGALURU	66	HV1	AMARJYOTHI	7:52	7:58	0:06	LOAD CHANGE OVER
303	20-Feb-2020	BENGALURU	220	EDC 220 - NIMHANS 220	EDC 220	12:59	13:51	0:52	MAIN SUPPLY FAILURE
304	20-Feb-2020	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	12:59	13:51	0:52	MAIN SUPPLY FAILURE
305	20-Feb-2020	BENGALURU	66	EDC 220 - BMTC	BMTC	12:59	13:51	0:52	MAIN SUPPLY FAILURE
306	20-Feb-2020	BENGALURU	66	EDC 220 - B STATION	B STATION	12:59	13:51	0:52	MAIN SUPPLY FAILURE
307	20-Feb-2020	BENGALURU	66	HV1	ELITE PROMENEDE	11:05	14:35	3:30	LINE CLEAR AVAILED
308	20-Feb-2020	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	16:10	16:34	0:24	LINE FAULT
309	20-Feb-2020	BENGALURU	220	HOODY 400 - ITPL	EPIP 220,ITPL 220	0:30	1:10	0:40	LINE FAULT
310	20-Feb-2020	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	0:30	1:14	0:44	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
311	20-Feb-2020	BENGALURU	220	EPIP 220 - ITPL(EHT) 220	EPIP 220	0:30	1:10	0:40	MAIN SUPPLY FAILURE
312	20-Feb-2020	BENGALURU	220	HOODY 400 - HSR	HSR 220,NIMHANS 220	12:59	13:39	0:40	LINE FAULT
313	20-Feb-2020	BENGALURU	220	HSR 220 - KORAMANGALA 220	KORAMANGALA 220	12:59	13:47	0:48	MAIN SUPPLY FAILURE
314	20-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	12:59	13:45	0:46	MAIN SUPPLY FAILURE
315	20-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1 & 2	ADUGODI, BOSCH (EHT)	12:59	13:45	0:46	MAIN SUPPLY FAILURE
316	20-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - KORAMANGALA	KORAMANGALA	12:59	13:45	0:46	MAIN SUPPLY FAILURE
317	20-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	12:59	13:45	0:46	MAIN SUPPLY FAILURE
318	20-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	12:59	13:45	0:46	MAIN SUPPLY FAILURE
319	20-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	12:59	13:45	0:46	MAIN SUPPLY FAILURE
320	20-Feb-2020	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI, EXORA	17:25	17:40	0:15	LOAD CHANGE OVER
321	20-Feb-2020	BENGALURU	66	HV1	KUMBALAGODU	17:45	18:04	0:19	TRANSFORMER FAULT
322	20-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	12:59	14:16	1:17	MAIN SUPPLY FAILURE
323	20-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE	12:59	14:16	1:17	MAIN SUPPLY FAILURE
324	20-Feb-2020	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	7:00	7:05	0:05	LOAD CHANGE OVER
325	20-Feb-2020	BENGALURU	66	HV2	PLATINUM CITY	13:00	14:10	1:10	LINE CLEAR AVAILED
326	20-Feb-2020	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	14:10	14:15	0:05	LOAD CHANGE OVER
327	20-Feb-2020	BENGALURU	66	POTTERY ROAD - ITI	POTTERY ROAD	0:31	1:15	0:44	MAIN SUPPLY FAILURE
328	20-Feb-2020	BENGALURU	66	POTTERY ROAD - HEBBAL 220	POTTERY ROAD	2:35	2:40	0:05	LOAD CHANGE OVER
329	20-Feb-2020	BENGALURU	66	HV1	RAJANUKUNTE	11:39	12:07	0:28	LINE CLEAR AVAILED
330	20-Feb-2020	BENGALURU	66	HV2	RAJANUKUNTE	11:39	12:07	0:28	LINE CLEAR AVAILED
331	20-Feb-2020	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	7:35	7:40	0:05	LOAD CHANGE OVER
332	20-Feb-2020	BENGALURU	66	HV2	REMCO	7:32	7:34	0:02	LOAD CHANGE OVER
333	20-Feb-2020	BENGALURU	66	SHAMARAJU TECH PARK - EPIP 220	SHAMARAJU TECH PARK	0:30	1:13	0:43	MAIN SUPPLY FAILURE
334	20-Feb-2020	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	NO RELAY OPERATED	18:18	18:35	0:17	LINE FAULT
335	20-Feb-2020	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	NO RELAY OPERATED	18:18	18:40	0:22	LINE FAULT
336	20-Feb-2020	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	6:45	7:23	0:38	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
337	20-Feb-2020	BENGALURU	220	HV2	YARANDANAHALLI 220	6:45	7:15	0:30	TRANSFORMER FAULT
338	20-Feb-2020	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	13:44	13:55	0:11	LINE FAULT
339	20-Feb-2020	GULBARGA	110	ITTAGI-KOGALI	KOGALI_66	10:25	10:45	0:20	MAIN SUPPLY FAILURE
340	20-Feb-2020	GULBARGA	110	HV2	MANVI_110	13:28	13:34	0:06	TRANSFORMER FAULT
341	20-Feb-2020	GULBARGA	110	HV2	MANVI_110	16:02	16:07	0:05	TRANSFORMER FAULT
342	20-Feb-2020	GULBARGA	110	HV2	HATTI_110	18:00	18:30	0:30	HAND TRIPPED
343	20-Feb-2020	GULBARGA	66	BETAGERE-KESHAVCEMENT	KESHAVCEMENT_IPP	4:00	4:10	0:10	LINE FAULT
344	20-Feb-2020	GULBARGA	66	BETAGERE-KESHAVCEMENT	KESHAVCEMENT_IPP	4:50	5:05	0:15	LINE FAULT
345	20-Feb-2020	GULBARGA	66	ITTAGI-HUVINAHDGALI	HUVINSHDAGALI_66,HOLAGUNDI_66	10:10	18:20	8:10	LINE CLEAR AVAILED
346	20-Feb-2020	GULBARGA	66	KOGALI-ASTROSOLAR_IPP	ASTROSOLAR_IPP	10:35	10:45	0:10	MAIN SUPPLY FAILURE
347	20-Feb-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	16:04	16:37	0:33	HAND TRIPPED
348	20-Feb-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:06	11:11	0:05	LINE FAULT
349	20-Feb-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	16:03	16:38	0:35	HAND TRIPPED
350	20-Feb-2020	HASSAN	110	HV1	SHIVPURA_110	11:58	13:08	1:10	LINE CLEAR AVAILED
351	20-Feb-2020	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	11:09	11:58	0:49	LINE CLEAR AVAILED
352	20-Feb-2020	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	9:44	12:34	2:50	NFBC ISSUED
353	20-Feb-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	9:01	17:17	8:16	NFBC ISSUED
354	20-Feb-2020	HASSAN	66	HV2	KANDLI_66	11:27	11:38	0:11	LINE CLEAR AVAILED
355	20-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	9:00	17:08	8:08	LINE CLEAR AVAILED
356	20-Feb-2020	MYSORE	66	KUSHALANAGARA 220-MYSORE 1	BILIKERE_66 BHERYA_66 DMG_HALLI_66 GVGUDI_66 MIRLE_66 KRNAGARA_66	12:31	12:46	0:15	LINE FAULT
357	20-Feb-2020	MYSORE	66	CHUNCHANKATTE-RAVANDUR	CHUNCHUNKATTE_66	11:40	13:05	1:25	LINE CLEAR AVAILED
358	20-Feb-2020	TUMKUR	220	TR-3	HIRIYUR_220	6:37	7:10	0:33	TRANSFORMER FAULT
359	20-Feb-2020	TUMKUR	220	TR-3	HIRIYUR_220	14:17	14:43	0:25	TRANSFORMER FAULT
360	20-Feb-2020	TUMKUR	220	TR-1	KBCROSS_220	15:41	18:27	2:45	LINE CLEAR AVAILED
361	20-Feb-2020	TUMKUR	220	TR-1&TR-2	MADHUGIRI_220	11:25	13:01	1:35	LINE CLEAR AVAILED
362	20-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	22:05	22:21	0:16	LINE FAULT
363	20-Feb-2020	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	11:31	12:42	1:11	LINE CLEAR AVAILED
364	20-Feb-2020	TUMKUR	110	TR-1	KBCROSS_220	15:41	18:30	2:49	LINE CLEAR AVAILED
365	20-Feb-2020	TUMKUR	66	BHAKTHARA HALLI -ANCHEPALYA	BHAKTHARAHALLI_66	16:32	16:54	0:22	LINE CLEAR AVAILED
366	20-Feb-2020	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	16:31	16:56	0:24	LINE CLEAR AVAILED
367	20-Feb-2020	TUMKUR	66	TR-1	CHELURU_66	6:30	7:18	0:47	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
368	20-Feb-2020	TUMKUR	66	TR-1	CHELURU_66	10:33	18:44	8:10	LINE CLEAR AVAILED
369	20-Feb-2020	TUMKUR	66	DAVANGERE SRS- GUTTUR66	DAVANGERE_SRS_220	18:48	19:14	0:25	LINE FAULT
370	20-Feb-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:56	10:05	0:09	LINE FAULT
371	20-Feb-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:59	17:08	0:08	LINE FAULT
372	20-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:03	12:06	0:02	LINE FAULT
373	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	6:37	7:17	0:40	HAND TRIPPED
374	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	14:19	14:45	0:25	HAND TRIPPED
375	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	7:02	7:21	0:18	HAND TRIPPED
376	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	14:18	14:46	0:27	HAND TRIPPED
377	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	5:55	8:27	2:32	LINE CLEAR AVAILED
378	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	14:20	14:47	0:27	HAND TRIPPED
379	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	7:03	7:14	0:10	HAND TRIPPED
380	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	14:19	15:26	1:06	LINE CLEAR AVAILED
381	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV- RKP 2	RKP1_IPP_66	7:03	7:14	0:10	HAND TRIPPED
382	20-Feb-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	14:17	15:08	0:50	HAND TRIPPED
383	20-Feb-2020	TUMKUR	66	HIRIYURkV 220kV- SUZLON 2	SUZLON1_IPP_66	15:01	15:09	0:08	HAND TRIPPED
384	20-Feb-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAG UNDA_66	3:12	3:19	0:06	LINE FAULT
385	20-Feb-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAG UNDA_66	7:22	8:22	1:00	LINE CLEAR AVAILED
386	20-Feb-2020	TUMKUR	66	TR-2	KOLALA_66	13:45	14:22	0:37	LINE CLEAR AVAILED
387	20-Feb-2020	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	13:01	13:05	0:03	LINE CLEAR AVAILED
388	20-Feb-2020	TUMKUR	66	TR-2(LV SIDE)	MADHUGIRI_220	11:25	13:01	1:35	LINE CLEAR AVAILED
389	20-Feb-2020	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	13:01	13:03	0:01	LINE CLEAR AVAILED
390	20-Feb-2020	TUMKUR	66	TR-2	MATHOD_66	18:07	18:14	0:07	TRANSFORMER FAULT
391	20-Feb-2020	TUMKUR	66	TR-2	TELAGI_66	13:12	13:36	0:23	LINE CLEAR AVAILED
392	21-Feb-2020	BAGALKOT	110	110/11KV,HV 1	GULEDGUDD_110	18:44	19:24	0:40	TRANSFORMER FAULT
393	21-Feb-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	0:00	10:03	10:03	LINE CLEAR AVAILED
394	21-Feb-2020	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	10:40	10:57	0:17	TRANSFORMER FAULT
395	21-Feb-2020	BAGALKOT	110	HUBLI-KALGHATAGI	KALGHATAGI_110	5:53	23:59	18:06	LINE CLEAR AVAILED
396	21-Feb-2020	BENGALURU	66	VOLVO - HOSKOTE 220	VOLVO	16:09	16:23	0:13	LINE CLEAR AVAILED
397	21-Feb-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI, SOMNATHPURA	16:05	16:10	0:05	LINE FAULT
398	21-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:09	12:18	0:09	LINE FAULT
399	21-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:18	12:30	0:12	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
400	21-Feb-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:24	9:39	0:15	LOAD CURTAILMENT
401	21-Feb-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	14:00	14:16	0:16	LINE FAULT
402	21-Feb-2020	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	7:10	8:05	0:55	LINE CLEAR AVAILED
403	21-Feb-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	7:10	8:05	0:55	LINE CLEAR AVAILED
404	21-Feb-2020	BENGALURU	220	HV2	CHINTAMANI 220	11:02	11:22	0:20	LINE CLEAR AVAILED
405	21-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	11:32	11:35	0:03	LINE CLEAR AVAILED
406	21-Feb-2020	BENGALURU	66	BRINDAVANA - SRS PEENYA	BRINDAVANA,NELAKADRENAHALLI	16:55	17:30	0:35	LINE CLEAR AVAILED
407	21-Feb-2020	BENGALURU	66	BRINDAVANA - SRS PEENYA	BRINDAVANA,NELAKADRENAHALLI	17:30	18:05	0:35	LINE FAULT
408	21-Feb-2020	BENGALURU	66	HV1	BRINDAVANA	18:40	18:55	0:15	LINE CLEAR AVAILED
409	21-Feb-2020	BENGALURU	66	HV2	BRINDAVANA	18:40	18:55	0:15	LINE CLEAR AVAILED
410	21-Feb-2020	BENGALURU	66	HV3	BRINDAVANA	18:40	18:55	0:15	LINE CLEAR AVAILED
411	21-Feb-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO,KADUBISANAHALLI	7:40	8:25	0:45	LINE FAULT
412	21-Feb-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO	8:25	10:26	2:01	LINE FAULT
413	21-Feb-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	13:56	14:16	0:20	LINE FAULT
414	21-Feb-2020	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI	7:45	9:00	1:15	MAIN SUPPLY FAILURE
415	21-Feb-2020	BENGALURU	66	KORAMANGALA 220 - HAL 2	K & C VALLEY,KORAMANGALA,LEELA VENTURE	10:20	10:55	0:35	LINE FAULT
416	21-Feb-2020	BENGALURU	220	HV1	MANYATHA TECH PARK 220	10:59	11:05	0:06	LOAD CHANGE OVER
417	21-Feb-2020	BENGALURU	220	HV1	MANYATHA TECH PARK 220	17:22	17:31	0:09	LOAD CHANGE OVER
418	21-Feb-2020	BENGALURU	66	MANYATH TECH PARK 220 - MANYATH TECH PARK 66	MANYATH TECH PARK 66	10:55	11:05	0:10	LOAD CHANGE OVER
419	21-Feb-2020	BENGALURU	66	MANYATH TECH PARK 220 - MANYATH TECH PARK 66	MANYATH TECH PARK 66	17:12	17:31	0:19	LOAD CHANGE OVER
420	21-Feb-2020	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	9:40	9:45	0:05	LOAD CHANGE OVER
421	21-Feb-2020	BENGALURU	66	HV2	REMCO	10:37	10:38	0:01	LOAD CHANGE OVER
422	21-Feb-2020	BENGALURU	66	HV1	T K HALLI 220	10:30	10:44	0:14	LINE CLEAR AVAILED
423	21-Feb-2020	BENGALURU	66	HV2	T K HALLI 220	10:00	10:30	0:30	LINE CLEAR AVAILED
424	21-Feb-2020	GULBARGA	220	LINGAPUR-JVSL-1	JVSL 1_IPP	9:55	16:45	6:50	NFBC ISSUED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
425	21-Feb-2020	GULBARGA	110	MALLAT-MANVI	MANVI_110	0:05	0:16	0:11	MAIN SUPPLY FAILURE
426	21-Feb-2020	GULBARGA	110	HV2	DEODURGA_110	7:55	9:50	1:55	TRANSFORMER FAULT
427	21-Feb-2020	GULBARGA	110	HV2	DEODURGA_110	12:20	12:30	0:10	TRANSFORMER FAULT
428	21-Feb-2020	GULBARGA	110	MALLAT-MANVI	MANVI_110	22:35	22:46	0:11	MAIN SUPPLY FAILURE
429	21-Feb-2020	GULBARGA	66	KUDALIGI-CJHALLI	CJHALLI_66	10:25	10:40	0:15	MAIN SUPPLY FAILURE
430	21-Feb-2020	GULBARGA	66	HV2	CJHALLI_66	11:10	11:15	0:05	TRANSFORMER FAULT
431	21-Feb-2020	GULBARGA	66	HV1	HANSI_66	11:22	11:30	0:08	TRANSFORMER FAULT
432	21-Feb-2020	HASSAN	220	MRSSHM-VARAH1	MRS MG_220	15:34	20:43	5:09	LINE FAULT
433	21-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRS MG_220	19:28	23:59	4:31	LINE CLEAR AVAILED
434	21-Feb-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	18:17	23:59	5:42	LINE FAULT
435	21-Feb-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	15:34	20:46	5:12	LINE FAULT
436	21-Feb-2020	HASSAN	110	JOG110-LPH	JOG_110	9:00	23:59	14:59	LINE CLEAR AVAILED
437	21-Feb-2020	HASSAN	110	SAGARA-ALKLA	SAGARA_110	18:17	18:47	0:30	LINE FAULT
438	21-Feb-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	15:44	16:09	0:25	LINE FAULT
439	21-Feb-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	18:59	19:29	0:30	LINE FAULT
440	21-Feb-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:23	10:27	0:04	LINE FAULT
441	21-Feb-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:13	12:16	0:03	LINE FAULT
442	21-Feb-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	10:53	11:25	0:32	LINE FAULT
443	21-Feb-2020	HASSAN	66	HV1	HIRISAVE_66	8:09	10:32	2:23	TRANSFORMER FAULT
444	21-Feb-2020	HASSAN	66	HV1	MAGGE_66	8:48	9:02	0:14	TRANSFORMER FAULT
445	21-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	8:59	9:02	0:03	TRANSFORMER FAULT
446	21-Feb-2020	MYSORE	66	KADAKOLA-SARGUR-1	ANTHARSANTHE_66, B MATKERE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66, SANTHESARAGUR_66	7:47	7:56	0:09	LINE FAULT
447	21-Feb-2020	MYSORE	66	KADAKOLA-SARGUR-2	CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66	7:47	7:56	0:09	LINE FAULT
448	21-Feb-2020	MYSORE	66	KADAKOLA-SARGUR-1	ANTHARSANTHE_66, B MATKERE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66, SANTHESARAGUR_66	8:39	8:45	0:06	LINE FAULT
449	21-Feb-2020	MYSORE	66	KADAKOLA-SARGUR-2	CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66	8:39	8:45	0:06	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
450	21-Feb-2020	MYSORE	66	KADAKOLA-SARGUR-1	ANTHARSANTHE_66, B MATKERE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66, SANTHESARAGUR_66	9:45	9:51	0:06	LINE FAULT
451	21-Feb-2020	MYSORE	66	KADAKOLA-SARGUR-2	CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66	9:45	9:51	0:06	LINE FAULT
452	21-Feb-2020	MYSORE	66	KADAKOLA-SARGUR-1	ANTHARSANTHE_66, B MATKERE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66, SANTHESARAGUR_66	10:41	11:00	0:19	LINE FAULT
453	21-Feb-2020	MYSORE	66	KADAKOLA-SARGUR-2	CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66	10:41	11:00	0:19	LINE FAULT
454	21-Feb-2020	MYSORE	66	HV1	ARAKERE_66	10:03	10:08	0:04	TRANSFORMER FAULT
455	21-Feb-2020	MYSORE	66	CR NAGARA-PANYADAHUNDI	DEVANOORNGUDU_66, HEMMARGALA_66, KARYA_66, PANDYADAHUNDI_66, SUTTUR_66	17:17	18:01	0:44	LINE FAULT
456	21-Feb-2020	TUMKUR	110	TR-1	TURUVEKERE_110	7:47	8:01	0:14	TRANSFORMER FAULT
457	21-Feb-2020	TUMKUR	66	TR-2	BENKIKERE_66	6:03	6:27	0:24	TRANSFORMER FAULT
458	21-Feb-2020	TUMKUR	66	TR-1	CHANNAGIRI_66	16:04	16:10	0:05	TRANSFORMER FAULT
459	21-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	19:27	19:32	0:04	TRANSFORMER FAULT
460	21-Feb-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	2:29	2:30	0:01	MAIN SUPPLY FAILURE
461	21-Feb-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	18:39	18:47	0:08	MAIN SUPPLY FAILURE
462	21-Feb-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	2:29	2:30	0:01	MAIN SUPPLY FAILURE
463	21-Feb-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	18:39	18:47	0:08	MAIN SUPPLY FAILURE
464	21-Feb-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	15:26	15:31	0:04	LINE FAULT
465	21-Feb-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:05	14:14	0:09	LINE FAULT
466	21-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:13	15:17	0:04	LINE FAULT
467	21-Feb-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:38	18:48	0:09	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
468	21-Feb-2020	TUMKUR	66	MADHUGIRI 220kV-KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	3:49	4:04	0:15	LINE FAULT
469	21-Feb-2020	TUMKUR	66	TR-2	TAVAREKERE(C)_66	18:50	18:53	0:03	TRANSFORMER FAULT
470	21-Feb-2020	TUMKUR	66	TR-2	TELAGI_66	13:04	15:04	2:00	LINE CLEAR AVAILED
471	22-Feb-2020	BAGALKOT	220	220/110KV,HV2&LV 2	AMBEWADI_220	11:38	13:48	2:10	LINE CLEAR AVAILED
472	22-Feb-2020	BAGALKOT	220	220/110KV,HV1&LV 1	AMBEWADI_220	14:56	16:10	1:14	LINE CLEAR AVAILED
473	22-Feb-2020	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	17:00	18:13	1:13	LINE CLEAR AVAILED
474	22-Feb-2020	BAGALKOT	110	BIDNAL-GADAG ROAD	GADAG ROAD_110 GOPANAKOPPA	10:01	16:39	6:38	LINE CLEAR AVAILED
475	22-Feb-2020	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	12:54	13:48	0:54	LINE FAULT
476	22-Feb-2020	BAGALKOT	110	SAVALAGI-TODALBAGI	TODALBAGI_110	8:38	8:50	0:12	HAND TRIPPED
477	22-Feb-2020	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	8:49	8:56	0:07	TRANSFORMER FAULT
478	22-Feb-2020	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	1:34	2:10	0:36	LINE FAULT
479	22-Feb-2020	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	14:25	18:05	3:40	LINE FAULT
480	22-Feb-2020	BAGALKOT	110	110/11KV, HV2	PG HUSHYAL_110	11:02	11:24	0:22	LINE CLEAR AVAILED
481	22-Feb-2020	BAGALKOT	110	110/11KV, HV3	MUDALGI_110	11:21	12:28	1:07	LINE CLEAR AVAILED
482	22-Feb-2020	BAGALKOT	110	HUBLI-KALGHATAGI	KALGHATAGI_110	0:00	7:28	7:28	LINE CLEAR AVAILED
483	22-Feb-2020	BAGALKOT	220	KADRA2-KARWAR	KARWAR_220	9:24	16:44	7:20	LINE CLEAR AVAILED
484	22-Feb-2020	BAGALKOT	110	110/33KV, HV2	HIREKERUR_110, KODA_33, CHIKKERUR_33	10:14	10:27	0:13	TRANSFORMER FAULT
485	22-Feb-2020	BAGALKOT	110	110/33KV, HV2	HANGAL_110, BELAGALPET_33	9:40	9:45	0:05	TRANSFORMER FAULT
486	22-Feb-2020	BAGALKOT	220	DHONI1&2-GADAG	GADAG_220	0:00	12:48	12:48	LINE CLEAR AVAILED
487	22-Feb-2020	BENGALURU	66	HV2	VOLVO	11:00	11:30	0:30	LINE CLEAR AVAILED
488	22-Feb-2020	BENGALURU	66	HV2	VOLVO	12:50	13:05	0:15	LINE CLEAR AVAILED
489	22-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	12:25	12:30	0:05	LINE FAULT
490	22-Feb-2020	BENGALURU	66	DODDABELAVANGALA - DB PURA 220	DODDABELAVANGALA	17:00	17:15	0:15	LINE CLEAR AVAILED
491	22-Feb-2020	BENGALURU	220	HV2	CHINTAMANI 220	6:10	6:50	0:40	LINE CLEAR AVAILED
492	22-Feb-2020	BENGALURU	220	HV1	CHINTAMANI 220	18:40	19:06	0:26	LINE CLEAR AVAILED
493	22-Feb-2020	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	21:47	22:35	0:48	LINE FAULT
494	22-Feb-2020	BENGALURU	66	HV1	ANEKAL	21:47	22:42	0:55	TRANSFORMER FAULT
495	22-Feb-2020	BENGALURU	220	HV1	KIADB DB PURA 220	11:57	14:24	2:26	LINE CLEAR AVAILED
496	22-Feb-2020	BENGALURU	66	HV2	ELECTRONIC CITY	12:39	12:45	0:06	LINE CLEAR AVAILED
497	22-Feb-2020	BENGALURU	66	HV3	ELECTRONIC CITY	1:01	1:15	0:14	TRANSFORMER FAULT
498	22-Feb-2020	BENGALURU	66	HV3	ELECTRONIC CITY	14:39	14:51	0:12	TRANSFORMER FAULT
499	22-Feb-2020	BENGALURU	66	HV3	ELECTRONIC CITY	20:34	20:42	0:08	TRANSFORMER FAULT
500	22-Feb-2020	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	11:10	11:16	0:06	LOAD CHANGE OVER
501	22-Feb-2020	BENGALURU	220	EPIP 220 - HOODY 220	EPIP 220	16:36	16:38	0:02	LOAD CHANGE OVER
502	22-Feb-2020	BENGALURU	66	HV3	HEBBAL 220	18:03	20:59	2:56	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
503	22-Feb-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	11:12	11:22	0:10	LOAD CHANGE OVER
504	22-Feb-2020	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	19:09	19:13	0:04	LOAD CHANGE OVER
505	22-Feb-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	11:10	11:15	0:05	LOAD CHANGE OVER
506	22-Feb-2020	GULBARGA	110	KAPNOOR-ALAND KADAGANCHI	ALAND KADAGANCHI_IPP	6:21	6:30	0:09	LINE FAULT
507	22-Feb-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI	NIRLOOTI_IPP	18:20	18:35	0:15	LINE FAULT
508	22-Feb-2020	GULBARGA	66	KOGALI-ASTROSOLAR_IPP	ASTROSOLAR_IPP	13:00	13:45	0:45	HAND TRIPPED
509	22-Feb-2020	GULBARGA	66	KUDALIGI-CJHALLI	CJHALLI_66	13:05	13:20	0:15	MAIN SUPPLY FAILURE
510	22-Feb-2020	GULBARGA	66	BENAVEKAL-SLRYS SOLAR	SLRYS SOLAR_IPP	13:10	13:45	0:35	HAND TRIPPED
511	22-Feb-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	9:10	9:16	0:06	HAND TRIPPED
512	22-Feb-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	16:40	20:05	3:25	LINE CLEAR AVAILED
513	22-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	11:21	17:42	6:21	LINE CLEAR AVAILED
514	22-Feb-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	11:21	17:42	6:21	LINE CLEAR AVAILED
515	22-Feb-2020	HASSAN	110	HV1	HIRENALLUR_110	13:10	13:58	0:48	LINE CLEAR AVAILED
516	22-Feb-2020	HASSAN	110	SAGARA-ALKLA	SAGARA_110	7:18	7:54	0:36	LINE CLEAR AVAILED
517	22-Feb-2020	HASSAN	110	SAGARA-ALKLA	SAGARA_110	9:46	18:01	8:15	LINE CLEAR AVAILED
518	22-Feb-2020	HASSAN	110	HV2	SORABA_110	7:48	7:51	0:03	TRANSFORMER FAULT
519	22-Feb-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	9:01	17:08	8:07	NFBC ISSUED
520	22-Feb-2020	HASSAN	66	HV1	KANDLI_66	17:01	17:24	0:23	TRANSFORMER FAULT
521	22-Feb-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	18:37	18:43	0:06	LINE FAULT
522	22-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	9:00	17:07	8:07	LINE CLEAR AVAILED
523	22-Feb-2020	HASSAN	66	HV2	UDAYAPURA_66	7:26	7:36	0:10	TRANSFORMER FAULT
524	22-Feb-2020	MYSORE	66	HV2	SATHEGALA_66	16:53	17:18	0:25	LINE CLEAR AVAILED
525	22-Feb-2020	TUMKUR	220	HIRIYUR220-MADHUGIRI	HIRIYUR_220	17:01	17:16	0:15	LINE FAULT
526	22-Feb-2020	TUMKUR	66	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	9:36	9:52	0:16	LINE FAULT
527	22-Feb-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	2:08	2:13	0:05	TRANSFORMER FAULT
528	22-Feb-2020	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	19:29	19:36	0:07	LINE FAULT
529	22-Feb-2020	TUMKUR	66	TR-2	AVAREGERE_66	19:29	19:36	0:07	TRANSFORMER FAULT
530	22-Feb-2020	TUMKUR	66	TR-3	AVAREGERE_66	19:29	19:36	0:07	TRANSFORMER FAULT
531	22-Feb-2020	TUMKUR	66	TR-3	AVAREGERE_66	21:16	21:39	0:22	LINE CLEAR AVAILED
532	22-Feb-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	22:52	23:06	0:14	LINE FAULT
533	22-Feb-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	13:29	15:18	1:48	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
534	22-Feb-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	19:03	19:23	0:20	HAND TRIPPED
535	22-Feb-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	18:58	19:04	0:06	MAIN SUPPLY FAILURE
536	22-Feb-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	18:58	19:04	0:06	MAIN SUPPLY FAILURE
537	22-Feb-2020	TUMKUR	66	TR-1	HIRIYUR_66	15:41	18:42	3:00	LINE CLEAR AVAILED
538	22-Feb-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	17:47	17:58	0:11	HAND TRIPPED
539	22-Feb-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	11:20	11:29	0:08	LINE FAULT
540	22-Feb-2020	TUMKUR	66	TR-2	HOSADURGA_66	12:27	12:35	0:07	TRANSFORMER FAULT
541	23-Feb-2020	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	10:56	17:41	6:45	LINE CLEAR AVAILED
542	23-Feb-2020	BAGALKOT	220	NARENDRA1-AMBEWADI	AMBEWADI_220	10:56	17:41	6:45	LINE CLEAR AVAILED
543	23-Feb-2020	BAGALKOT	110	110/11KV,HV1	DAVALESHWARA_110	9:29	12:01	2:32	LINE CLEAR AVAILED
544	23-Feb-2020	BAGALKOT	110	110/33KV,HV2	GANESHGUDI_110	17:55	18:42	0:47	LINE CLEAR AVAILED
545	23-Feb-2020	BAGALKOT	110	110/33KV,HV1	KADANAKOPPA_110	3:25	3:32	0:07	TRANSFORMER FAULT
546	23-Feb-2020	BAGALKOT	110	110/33KV,HV2	HANGAL_110	23:48	23:53	0:05	TRANSFORMER FAULT
547	23-Feb-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,DHULKED_33,NEVARGI _33,HALASANGI_33	13:01	13:22	0:21	LINE CLEAR AVAILED
548	23-Feb-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,DHULKED_33,NEVARGI _33,HALASANGI_33	14:16	14:20	0:04	TRANSFORMER FAULT
549	23-Feb-2020	BAGALKOT	220	KUDUCHI-GHATAPRABHA	KUDUCHI_220	3:43	4:27	0:44	LINE FAULT
550	23-Feb-2020	BAGALKOT	110	KUDUCHI-TERDAL	TERDAL_110	3:55	4:35	0:40	LINE FAULT
551	23-Feb-2020	BAGALKOT	220	220/110KV,HV1,LV1	KUDUCHI_220	3:56	4:17	0:21	TRANSFORMER FAULT
552	23-Feb-2020	BENGALURU	66	YELAHANKA 220 - LINE 6	SOLDEVANAHALLI	7:14	8:31	1:17	LINE FAULT
553	23-Feb-2020	BENGALURU	66	HV2	VOLVO	14:05	14:20	0:15	TRANSFORMER FAULT
554	23-Feb-2020	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	7:03	7:17	0:14	LINE FAULT
555	23-Feb-2020	BENGALURU	66	JIGANI - SOMANAHALLI 220	JIGANI, BG ROAD,	12:09	12:20	0:11	MAIN SUPPLY FAILURE
556	23-Feb-2020	BENGALURU	66	JIGANI - JIGANI 220	JIGANI, BG ROAD,	15:30	15:38	0:08	LOAD CHANGE OVER
557	23-Feb-2020	BENGALURU	66	HV2	DOMMASANDRA	14:39	14:45	0:06	LINE CLEAR AVAILED
558	23-Feb-2020	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	7:18	7:21	0:03	LINE CLEAR AVAILED
559	23-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	7:22	7:32	0:10	LINE CLEAR AVAILED
560	23-Feb-2020	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	18:22	18:30	0:08	LINE CLEAR AVAILED
561	23-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	18:30	18:33	0:03	LINE CLEAR AVAILED
562	23-Feb-2020	BENGALURU	66	HV2	CB PURA URBAN	14:55	15:15	0:20	TRANSFORMER FAULT
563	23-Feb-2020	BENGALURU	66	NELAMANGALA 66 - SRS PEENYA 220	NELAMANGALA 66	7:38	7:43	0:05	LOAD CHANGE OVER

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
564	23-Feb-2020	BENGALURU	66	NELAMANGALA 66 - SRS PEENYA 220	NELAMANGALA 66	7:38	7:43	0:05	LOAD CHANGE OVER
565	23-Feb-2020	BENGALURU	66	HV1	NELAMANGALA 66	7:38	7:43	0:05	LOAD CHANGE OVER
566	23-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPETE 220	NELAMANGALA 66	14:36	14:39	0:03	LOAD CHANGE OVER
567	23-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPETE 220	NELAMANGALA 66	14:36	14:39	0:03	LOAD CHANGE OVER
568	23-Feb-2020	BENGALURU	66	HV1	NELAMANGALA 66	14:36	14:39	0:03	LOAD CHANGE OVER
569	23-Feb-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	10:08	18:13	8:05	LINE CLEAR AVAILED
570	23-Feb-2020	BENGALURU	66	DODALAHALLI - TK HALLI 220	DODALAHALLI	14:25	16:00	1:35	LINE CLEAR AVAILED
571	23-Feb-2020	BENGALURU	66	DODALAHALLI - TK HALLI 220	DODALAHALLI	16:00	18:10	2:10	LINE FAULT
572	23-Feb-2020	BENGALURU	66	B G ROAD - JIGANI 220	B G ROAD	15:30	15:50	0:20	LOAD CHANGE OVER
573	23-Feb-2020	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	17:54	18:00	0:06	LOAD CHANGE OVER
574	23-Feb-2020	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI, EXORA	13:00	13:10	0:10	LOAD CHANGE OVER
575	23-Feb-2020	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYA PURA 220	PADMANABHANAGARA	22:05	22:11	0:06	LOAD CHANGE OVER
576	23-Feb-2020	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	22:45	22:50	0:05	LOAD CHANGE OVER
577	23-Feb-2020	BENGALURU	66	SOLDEVANAHALLI - YELAHANKA 220	SOLDEVANAHALLI	7:15	7:38	0:23	MAIN SUPPLY FAILURE
578	23-Feb-2020	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	8:35	8:55	0:20	LOAD CHANGE OVER
579	23-Feb-2020	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	17:50	17:55	0:05	LOAD CHANGE OVER
580	23-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,AS KI_110,UGAR SUGAR_IPP	3:25	3:32	0:07	LINE FAULT
581	23-Feb-2020	GULBARGA	110	HV1	LINGASUGUR_220,CHAYADEVI_IPP ,KAREPOWER_IPP,MUDGOL_110	5:40	5:48	0:08	TRANSFORMER FAULT
582	23-Feb-2020	GULBARGA	110	HV2	LINGASUGUR_220,CHAYADEVI_IPP ,KAREPOWER_IPP,MUDGOL_110	5:40	6:05	0:25	TRANSFORMER FAULT
583	23-Feb-2020	GULBARGA	110	HV2	MANVI_110	16:02	16:07	0:05	TRANSFORMER FAULT
584	23-Feb-2020	GULBARGA	110	HV2	MANVI_110	16:11	16:13	0:02	TRANSFORMER FAULT
585	23-Feb-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	17:47	18:02	0:15	LINE FAULT
586	23-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,AS KI_110,UGAR SUGAR_IPP	21:52	21:56	0:04	LINE FAULT
587	23-Feb-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	8:33	10:23	1:50	LINE CLEAR AVAILED
588	23-Feb-2020	HASSAN	220	HV1	KADUR_220	10:25	10:50	0:25	TRANSFORMER FAULT
589	23-Feb-2020	HASSAN	220	HV2	KADUR_220	10:25	10:50	0:25	TRANSFORMER FAULT
590	23-Feb-2020	HASSAN	110	LV1	KADUR_220	10:25	10:50	0:25	TRANSFORMER FAULT
591	23-Feb-2020	HASSAN	110	LV2	KADUR_220	10:25	10:50	0:25	TRANSFORMER FAULT
592	23-Feb-2020	HASSAN	220	HV1	KAVOOR_220	12:00	13:22	1:22	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
593	23-Feb-2020	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	12:00	13:46	1:46	LINE CLEAR AVAILED
594	23-Feb-2020	HASSAN	110	LV1	KAVOOR_220	12:00	13:22	1:22	LINE CLEAR AVAILED
595	23-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRS MG_220	0:00	16:00	16:00	LINE CLEAR AVAILED
596	23-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRS MG_220	16:07	23:59	7:52	LINE FAULT
597	23-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRS MG_220	10:25	14:58	4:33	LINE CLEAR AVAILED
598	23-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRS MG_220	17:44	20:37	2:53	LINE CLEAR AVAILED
599	23-Feb-2020	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	0:00	16:04	16:04	LINE FAULT
600	23-Feb-2020	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	16:07	23:59	7:52	LINE FAULT
601	23-Feb-2020	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	10:25	20:40	10:15	LINE CLEAR AVAILED
602	23-Feb-2020	HASSAN	110	HV1	JAVAGAL_110	8:51	9:05	0:14	TRANSFORMER FAULT
603	23-Feb-2020	HASSAN	110	HV1	KONAJE_110	13:47	13:56	0:09	HAND TRIPPED
604	23-Feb-2020	HASSAN	110	HV2	KONAJE_110	13:47	13:56	0:09	HAND TRIPPED
605	23-Feb-2020	HASSAN	110	HV3	KONAJE_110	13:47	13:55	0:08	HAND TRIPPED
606	23-Feb-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	9:03	13:21	4:18	NFBC ISSUED
607	23-Feb-2020	HASSAN	110	HV1	MOODABIDRE_110	8:07	8:13	0:06	TRANSFORMER FAULT
608	23-Feb-2020	HASSAN	110	SAGARA-ALKLA	SAGARA_110	9:30	15:14	5:44	LINE CLEAR AVAILED
609	23-Feb-2020	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	8:30	8:41	0:11	LINE FAULT
610	23-Feb-2020	MYSORE	66	HV1	ARAKERE_66	10:05	10:22	0:16	TRANSFORMER FAULT
611	23-Feb-2020	MYSORE	66	HV1	DUNDANAHALLI_66	2:40	2:48	0:08	TRANSFORMER FAULT
612	23-Feb-2020	MYSORE	66	HV1	DUNDANAHALLI_66	3:02	3:09	0:06	TRANSFORMER FAULT
613	23-Feb-2020	MYSORE	66	HV1	DUNDANAHALLI_66	6:58	7:04	0:05	TRANSFORMER FAULT
614	23-Feb-2020	MYSORE	66	HAMPAPURA-BASARALU	BASARALU_66, BESAGARAHALLI_66, KOPPA_66	17:42	19:41	1:58	LINE FAULT
615	23-Feb-2020	MYSORE	66	HV2	HULLAHALLI_66	14:10	23:59	9:49	LINE CLEAR AVAILED
616	23-Feb-2020	MYSORE	66	KADAKOLA-SARGUR 2	CHANDRAVADI_66, DOORA_66, HULLAHALLI_66, HURA_66	6:24	6:27	0:03	LINE FAULT
617	23-Feb-2020	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, B MATKERE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66, SANTHESARAGUR_66	6:24	6:27	0:03	LINE FAULT
618	23-Feb-2020	MYSORE	66	KADAKOLA-SARGUR 1	ANTHARSANTHE_66, B MATKERE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66, SANTHESARAGUR_66	6:30	6:33	0:03	LINE FAULT
619	23-Feb-2020	TUMKUR	220	TR-1	CHITRADURGA_220	19:44	19:52	0:08	TRANSFORMER FAULT
620	23-Feb-2020	TUMKUR	110	TR-1	TURUVEKERE_110	7:15	7:28	0:12	TRANSFORMER FAULT
621	23-Feb-2020	TUMKUR	110	TR-1	TURUVEKERE_110	13:35	19:42	6:07	TRANSFORMER FAULT
622	23-Feb-2020	TUMKUR	66	TR-1	CHITRADURGA_220	19:44	19:52	0:08	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
623	23-Feb-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	14:00	14:10	0:09	LINE FAULT
624	23-Feb-2020	TUMKUR	66	TR-1	MATHOD_66	10:14	14:40	4:25	LINE CLEAR AVAILED
625	23-Feb-2020	TUMKUR	66	TR-2	MATHOD_66	13:25	14:40	1:15	LINE CLEAR AVAILED
626	23-Feb-2020	TUMKUR	66	TR-1	TYAVANAGI_66	21:09	21:11	0:01	TRANSFORMER FAULT
627	23-Feb-2020	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	13:17	13:34	0:16	HAND TRIPPED
628	24-Feb-2020	BAGALKOT	220	220/110KV,HV 1 & LV 1	BELGAUM_220	0:00	14:17	14:17	LINE CLEAR AVAILED
629	24-Feb-2020	BAGALKOT	110	110/11KV,HV 1	BABALESHWAR_110	12:36	14:31	1:55	LINE CLEAR AVAILED
630	24-Feb-2020	BAGALKOT	110	110/33KV,HV 3	GHATAPRABHA_110& 33KV KULLOLLI,GOKAK MILL	5:49	6:53	1:04	LINE CLEAR AVAILED
631	24-Feb-2020	BAGALKOT	110	110/11KV,HV 4	GHATAPRABHA_110	7:50	7:59	0:09	TRANSFORMER FAULT
632	24-Feb-2020	BAGALKOT	110	110/11KV,HV 1	HALIYAL_110	12:36	14:59	2:23	LINE CLEAR AVAILED
633	24-Feb-2020	BAGALKOT	110	110/33KV,HV 2	HANAGAL_110	8:22	8:29	0:07	TRANSFORMER FAULT
634	24-Feb-2020	BAGALKOT	220	CHIKKODI-MUDASINGI	CHIKKODI_220	9:59	23:59	14:00	NFBC ISSUED
635	24-Feb-2020	BAGALKOT	220	HAVERI-GUTTUR	HAVERI_220	14:30	18:42	4:12	LINE FAULT
636	24-Feb-2020	BAGALKOT	110	HAVERI-HANAGAL	HANAGAL_110	22:04	22:16	0:12	LINE FAULT
637	24-Feb-2020	BAGALKOT	110	JAMAKHANDI- PRABHULIGESHWAR SUGARS	JAMAKHANDI_110	12:04	12:49	0:45	HAND TRIPPED
638	24-Feb-2020	BAGALKOT	110	110/11KV,HV3	MUDALAGI_110	14:09	14:12	0:03	LINE CLEAR AVAILED
639	24-Feb-2020	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	15:22	15:31	0:09	TRANSFORMER FAULT
640	24-Feb-2020	BAGALKOT	110	MANALI SUGARS-MALGHAN(S)	MALGHAN(S)_110	7:05	7:12	0:07	HAND TRIPPED
641	24-Feb-2020	BAGALKOT	220	HUBLI-NAGJAHARI3	HUBLI_220	14:23	18:03	3:40	LINE FAULT
642	24-Feb-2020	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	13:04	23:59	10:55	LINE CLEAR AVAILED
643	24-Feb-2020	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	16:16	18:46	2:30	LINE CLEAR AVAILED
644	24-Feb-2020	BAGALKOT	220	220/110KV, HV1&LV1	SIRSI_220, SIRSI_110	19:23	19:27	0:04	TRANSFORMER FAULT
645	24-Feb-2020	BAGALKOT	220	KADRA1-KARWAR	KARWAR_220	18:13	18:59	0:46	LINE FAULT
646	24-Feb-2020	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	18:13	23:59	5:46	LINE FAULT
647	24-Feb-2020	BAGALKOT	110	110/33KV, HV1	KADANKOPPA_110, DUMMAWAD_33, KALGHATAGI_33	11:02	11:05	0:03	HAND TRIPPED
648	24-Feb-2020	BENGALURU	66	A STATION 220 - A STATION 1	A STATION 66	5:38	5:49	0:11	LINE CLEAR AVAILED
649	24-Feb-2020	BENGALURU	66	A STATION 220 - A STATION 2	A STATION 66	5:38	5:49	0:10	LINE CLEAR AVAILED
650	24-Feb-2020	BENGALURU	66	BRINDAVANA - SRS PEENYA 220	BRINDAVANA	12:10	12:56	0:46	LOAD CHANGE OVER
651	24-Feb-2020	BENGALURU	66	BRINDAVANA - SRS PEENYA 220	BRINDAVANA	13:30	13:40	0:10	LOAD CHANGE OVER
652	24-Feb-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	18:28	18:31	0:03	LINE CLEAR AVAILED
653	24-Feb-2020	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	18:23	18:27	0:03	LINE CLEAR AVAILED
654	24-Feb-2020	BENGALURU	66	DALASANUR - SRINIVASPURA	YELDUR	9:41	10:10	0:29	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
655	24-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	8:27	8:33	0:05	LINE FAULT
656	24-Feb-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	8:41	8:50	0:09	LINE FAULT
657	24-Feb-2020	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	11:34	11:45	0:10	LINE CLEAR AVAILED
658	24-Feb-2020	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	16:08	16:26	0:17	MAIN SUPPLY FAILURE
659	24-Feb-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	16:08	16:26	0:17	MAIN SUPPLY FAILURE
660	24-Feb-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	16:08	16:26	0:17	MAIN SUPPLY FAILURE
661	24-Feb-2020	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	16:08	16:22	0:14	LINE FAULT
662	24-Feb-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	16:08	16:26	0:17	MAIN SUPPLY FAILURE
663	24-Feb-2020	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	16:08	16:25	0:17	MAIN SUPPLY FAILURE
664	24-Feb-2020	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	16:09	16:25	0:16	MAIN SUPPLY FAILURE
665	24-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	9:05	23:59	14:54	LOAD CURTAILMENT
666	24-Feb-2020	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	13:55	14:19	0:24	LINE FAULT
667	24-Feb-2020	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	12:25	12:30	0:05	LOAD CHANGE OVER
668	24-Feb-2020	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	14:30	14:35	0:05	LOAD CHANGE OVER
669	24-Feb-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR	9:13	9:42	0:28	LOAD CURTAILMENT
670	24-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	12:22	12:25	0:03	LOAD CHANGE OVER
671	24-Feb-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	14:30	14:34	0:03	LINE CLEAR AVAILED
672	24-Feb-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:10	16:27	0:16	LOAD CURTAILMENT
673	24-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:10	16:27	0:16	LOAD CURTAILMENT
674	24-Feb-2020	BENGALURU	66	HV1	BOODIGERE	10:37	12:17	1:40	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
675	24-Feb-2020	BENGALURU	66	HV2	BOODIGERE	10:37	13:29	2:52	LINE CLEAR AVAILED
676	24-Feb-2020	BENGALURU	66	HV1	CHAKAVELU	9:10	9:11	0:01	LINE CLEAR AVAILED
677	24-Feb-2020	BENGALURU	66	HV2	CHANNAPATNA	14:11	14:13	0:01	LINE CLEAR AVAILED
678	24-Feb-2020	BENGALURU	66	HV2	ISRO LAYOUT	15:25	15:36	0:11	LINE CLEAR AVAILED
679	24-Feb-2020	BENGALURU	66	HV2	Y HUNSENHALLI	17:27	17:37	0:10	LINE CLEAR AVAILED
680	24-Feb-2020	BENGALURU	66	HV1	SURYANAGAR	16:44	17:03	0:19	LINE CLEAR AVAILED
681	24-Feb-2020	BENGALURU	66	HV1	TK HALLI 220	16:17	16:52	0:35	LINE CLEAR AVAILED
682	24-Feb-2020	BENGALURU	66	HV1	ANDERSONPET	16:01	16:23	0:21	LINE CLEAR AVAILED
683	24-Feb-2020	BENGALURU	66	HV1	NALAKADRINAHALLI	12:45	13:59	1:14	TRANSFORMER FAULT
684	24-Feb-2020	GULBARGA	110	GABUR-BPSLR	GABUR_110	5:39	5:45	0:06	LINE FAULT
685	24-Feb-2020	GULBARGA	110	HV1	KEMBHAVI_110	6:30	14:25	7:55	LINE CLEAR AVAILED
686	24-Feb-2020	GULBARGA	110	HV1	KEMBHAVI_110	19:25	19:30	0:05	TRANSFORMER FAULT
687	24-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,AS KI_110,UGAR SUGAR_IPP	23:35	23:50	0:15	LINE FAULT
688	24-Feb-2020	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	12:15	12:25	0:10	LINE CLEAR AVAILED
689	24-Feb-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	12:19	12:35	0:16	LINE CLEAR AVAILED
690	24-Feb-2020	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	17:35	17:45	0:10	HAND TRIPPED
691	24-Feb-2020	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	11:12	13:16	2:04	LINE CLEAR AVAILED
692	24-Feb-2020	HASSAN	220	MRSSHM-KBCRS	MRS MG_220	12:19	16:44	4:25	LINE CLEAR AVAILED
693	24-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRS MG_220	0:00	12:05	12:05	LINE FAULT
694	24-Feb-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	11:12	13:23	2:11	NFBC ISSUED
695	24-Feb-2020	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	0:00	12:05	12:05	LINE FAULT
696	24-Feb-2020	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	16:20	19:30	3:10	LINE CLEAR AVAILED
697	24-Feb-2020	HASSAN	110	JOG110-LPH	JOG_110	23:58	23:59	0:01	LINE CLEAR AVAILED
698	24-Feb-2020	HASSAN	110	KADUR-YGTI	KADUR_220	6:30	7:46	1:16	LINE FAULT
699	24-Feb-2020	HASSAN	110	HV1	KALLUSADARAHALLY_110	11:12	11:22	0:10	LINE CLEAR AVAILED
700	24-Feb-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	13:43	13:48	0:05	MAIN SUPPLY FAILURE
701	24-Feb-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	12:08	12:19	0:11	LINE CLEAR AVAILED
702	24-Feb-2020	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	10:15	10:28	0:13	LINE FAULT
703	24-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	13:43	13:46	0:03	HAND TRIPPED
704	24-Feb-2020	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	12:09	12:25	0:16	NFBC ISSUED
705	24-Feb-2020	MYSORE	66	KUSHALNAGARA -MYSORE1	MIRLE STATION INTERRUPTED	3:40	3:46	0:06	LINE FAULT
706	24-Feb-2020	MYSORE	66	TUBINKERE-M-2	CHIKKA_MANDYA_66 HADLI_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MANDYA_66 MALAVALLI_66	11:00	11:03	0:03	HAND TRIPPED
707	24-Feb-2020	MYSORE	66	TUBINKERE-ARAKERE	TARIPURA_66 ARAKERE_66 GAMANAHALLY_66	7:03	7:08	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
708	24-Feb-2020	MYSORE	66	TUBINKERE-M-4	CHIKKA_MANDYA_66 HADLI_66 HAMPAPURA_66 KADKOTHANAHALLI_66 MANDYA_66 MALAVALLI_66	11:00	11:03	0:03	HAND TRIPPED
709	24-Feb-2020	MYSORE	220	HV1	TUBINAKERE_220	11:02	18:22	7:20	LINE CLEAR AVAILED
710	24-Feb-2020	MYSORE	66	HV1	TUBINAKERE_220	11:00	11:06	0:06	HAND TRIPPED
711	24-Feb-2020	TUMKUR	110	TR-1	KALLUR_110	19:00	20:53	1:53	TRANSFORMER FAULT
712	24-Feb-2020	TUMKUR	66	BRAHMASANDRA- THOVINKERE	THOVINAKERE_66, KORA_66	15:15	19:35	4:19	LINE CLEAR AVAILED
713	24-Feb-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	17:51	18:00	0:09	MAIN SUPPLY FAILURE
714	24-Feb-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	17:51	18:00	0:09	MAIN SUPPLY FAILURE
715	24-Feb-2020	TUMKUR	66	TR-1	HANAGAL_66	13:37	17:51	4:13	LINE CLEAR AVAILED
716	24-Feb-2020	TUMKUR	66	TR-1	HIRIYUR_66	15:15	18:17	3:02	LINE CLEAR AVAILED
717	24-Feb-2020	TUMKUR	66	TR-2	HOSADURGA_66	17:18	17:23	0:05	TRANSFORMER FAULT
718	24-Feb-2020	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	16:07	18:25	2:18	LINE CLEAR AVAILED
719	24-Feb-2020	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	16:06	18:25	2:18	LINE CLEAR AVAILED
720	24-Feb-2020	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	15:15	19:23	4:08	LINE CLEAR AVAILED
721	24-Feb-2020	TUMKUR	66	TR-1	MATHOD_66	18:00	18:20	0:19	LINE CLEAR AVAILED
722	24-Feb-2020	TUMKUR	66	TR-2	PANDARAHALLI_66	15:27	15:28	0:01	LINE CLEAR AVAILED
723	24-Feb-2020	TUMKUR	66	TR-2	THOVINAKERE_66	15:15	19:24	4:09	LINE CLEAR AVAILED
724	24-Feb-2020	TUMKUR	66	THOVINAKERE-KORA	THOVINAKERE_66	15:15	19:24	4:09	LINE CLEAR AVAILED