

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 25.02.2020 TO 2.03.2020

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	25-Feb-2020	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	21:10	21:22	0:12	LINE FAULT
2	25-Feb-2020	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	15:05	19:20	4:15	LINE CLEAR AVAILED
3	25-Feb-2020	BAGALKOT	220	ALAMATTI2-BAGALKOT	BAGALKOT_220	10:52	11:39	0:47	LINE FAULT
4	25-Feb-2020	BAGALKOT	220	220/110KV,HV1&LV1	BELGAUM_220	11:56	12:58	1:02	LINE CLEAR AVAILED
5	25-Feb-2020	BAGALKOT	110	BELGAUM220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	12:35	12:58	0:23	HAND TRIPPED
6	25-Feb-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	9:44	23:59	14:15	LINE CLEAR AVAILED
7	25-Feb-2020	BAGALKOT	110	HIDIKALDAM-ANKALAGI	ANKALAGI_110	13:31	23:59	10:28	LINE CLEAR AVAILED
8	25-Feb-2020	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	0:00	13:16	13:16	LINE CLEAR AVAILED
9	25-Feb-2020	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	13:21	13:25	0:04	HAND TRIPPED
10	25-Feb-2020	BAGALKOT	110	KARWAR220-BINAGA (SOLARIS)	BINAGA_110	11:17	13:29	2:12	LINE CLEAR AVAILED
11	25-Feb-2020	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	0:00	12:16	12:16	LINE CLEAR AVAILED
12	25-Feb-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HORTI_33KV	14:51	14:56	0:05	TRANSFORMER FAULT
13	25-Feb-2020	BAGALKOT	110	JAMKHANDI SUGAR-TODALBAGI	TODALBAGI_110	2:30	2:49	0:19	LINE FAULT
14	25-Feb-2020	BAGALKOT	110	JAMKHANDI SUGAR-TODALBAGI	TODALBAGI_110	21:10	21:29	0:19	LINE FAULT
15	25-Feb-2020	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	7:11	7:30	0:19	TRANSFORMER FAULT
16	25-Feb-2020	BAGALKOT	110	RANEENNUR-RATTIHALLI(TUMMINAKATTI)	TUMMINAKATTI_110	22:09	22:27	0:18	LOAD CURTAILMENT
17	25-Feb-2020	BAGALKOT	110	RANEENNUR-(AREMALLAPUR)HONNATTI	HONNATTI_110	22:09	22:26	0:17	LOAD CURTAILMENT
18	25-Feb-2020	BAGALKOT	220	CHIKKODI-MUDASHINGI	CHIKKODI_220	0:00	20:38	20:38	LINE CLEAR AVAILED
19	25-Feb-2020	BAGALKOT	110	CHIKKODI-SADALAGA	SADALAGA_110	4:11	4:50	0:39	LINE FAULT
20	25-Feb-2020	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	13:33	15:41	2:08	LINE CLEAR AVAILED
21	25-Feb-2020	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	12:22	12:27	0:05	TRANSFORMER FAULT
22	25-Feb-2020	BAGALKOT	110	SIRSI1&2-KUMTA	KUMTA_110	14:33	23:59	9:26	LINE CLEAR AVAILED
23	25-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY, BTM 4TH PHASE	12:18	12:33	0:15	LINE CLEAR AVAILED
24	25-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	12:00	12:13	0:13	LINE CLEAR AVAILED
25	25-Feb-2020	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	ISKON, SUBRAMANYAPURA 66	17:05	17:15	0:10	LOAD CHANGE OVER
26	25-Feb-2020	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	HSR LAYOUT 220	12:01	12:20	0:18	LINE FAULT
27	25-Feb-2020	BENGALURU	220	HSR LAYOUT 220 - EPIP 220	HSR LAYOUT 220	13:13	14:51	1:38	LINE FAULT
28	25-Feb-2020	BENGALURU	220	HSR LAYOUT 220 - KORMANGALA 220	KORMANGALA 220	12:01	12:21	0:19	MAIN SUPPLY FAILURE
29	25-Feb-2020	BENGALURU	66	BRINDAVANA - NELAKADRINAHALLI	NELAKADRINAHALLI	16:20	16:26	0:06	LINE CLEAR AVAILED
30	25-Feb-2020	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	12:01	12:37	0:35	MAIN SUPPLY FAILURE
31	25-Feb-2020	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	13:13	14:27	1:14	MAIN SUPPLY FAILURE
32	25-Feb-2020	BENGALURU	66	EDC 220 - BMTC	BMTC	12:01	12:36	0:35	MAIN SUPPLY FAILURE
33	25-Feb-2020	BENGALURU	66	EDC 220 - BMTC	BMTC	13:13	14:30	1:17	MAIN SUPPLY FAILURE
34	25-Feb-2020	BENGALURU	66	EDC 220 - B STATION	B STATION	12:01	12:42	0:40	MAIN SUPPLY FAILURE
35	25-Feb-2020	BENGALURU	66	EDC 220 - B STATION	B STATION	13:13	14:54	1:41	MAIN SUPPLY FAILURE
36	25-Feb-2020	BENGALURU	220	EDC 220 - NIMHANS 220	NIMHANS 220	12:01	12:33	0:32	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
37	25-Feb-2020	BENGALURU	220	EDC 220 - NIMHANS 220	NIMHANS 220	13:13	14:26	1:13	MAIN SUPPLY FAILURE
38	25-Feb-2020	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	HSR LAYOUT 220	13:13	14:15	1:02	LINE FAULT
39	25-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	12:01	12:23	0:22	MAIN SUPPLY FAILURE
40	25-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	ADUGODI, BOSCH (EHT)	13:13	14:22	1:09	MAIN SUPPLY FAILURE
41	25-Feb-2020	BENGALURU	220	NIMHANS 220 - HSR LAYOUT 220	NIMHANS 220	12:01	12:32	0:30	LINE FAULT
42	25-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	12:01	12:33	0:32	MAIN SUPPLY FAILURE
43	25-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	13:13	14:22	1:09	MAIN SUPPLY FAILURE
44	25-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	12:01	12:34	0:33	MAIN SUPPLY FAILURE
45	25-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	13:13	14:55	1:42	MAIN SUPPLY FAILURE
46	25-Feb-2020	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	12:11	12:36	0:25	LINE CLEAR AVAILED
47	25-Feb-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	8:21	9:29	1:07	LINE CLEAR AVAILED
48	25-Feb-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	16:31	17:30	0:59	LINE CLEAR AVAILED
49	25-Feb-2020	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	14:44	15:01	0:17	LINE CLEAR AVAILED
50	25-Feb-2020	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA	14:44	15:01	0:17	LINE CLEAR AVAILED
51	25-Feb-2020	BENGALURU	66	MALUR 220 - MASTHI	MAASTHI, DEVANGONDHI, LAKKUR	19:05	19:10	0:05	LINE FAULT
52	25-Feb-2020	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	15:10	15:22	0:12	LOAD CHANGE OVER
53	25-Feb-2020	BENGALURU	220	HV1	EDC 220	12:01	12:34	0:32	MAIN SUPPLY FAILURE
54	25-Feb-2020	BENGALURU	220	HV1	EDC 220	13:13	14:27	1:14	MAIN SUPPLY FAILURE
55	25-Feb-2020	BENGALURU	220	HV2	EDC 220	12:01	12:34	0:32	MAIN SUPPLY FAILURE
56	25-Feb-2020	BENGALURU	220	HV2	EDC 220	13:13	14:27	1:14	MAIN SUPPLY FAILURE
57	25-Feb-2020	BENGALURU	220	HV1	NIMHANS 220	12:01	12:32	0:31	MAIN SUPPLY FAILURE
58	25-Feb-2020	BENGALURU	220	HV1	NIMHANS 220	13:13	14:22	1:09	MAIN SUPPLY FAILURE
59	25-Feb-2020	BENGALURU	220	HV2	NIMHANS 220	12:01	12:34	0:33	MAIN SUPPLY FAILURE
60	25-Feb-2020	BENGALURU	220	HV2	NIMHANS 220	13:13	14:22	1:09	MAIN SUPPLY FAILURE
61	25-Feb-2020	BENGALURU	66	HV1	DOMMASANDRA	10:11	10:15	0:03	LINE CLEAR AVAILED
62	25-Feb-2020	BENGALURU	66	HV2	DOMMASANDRA	10:11	10:15	0:03	LINE CLEAR AVAILED
63	25-Feb-2020	GULBARGA	110	HV2	MANTHAL_110	8:40	8:50	0:10	LINE CLEAR AVAILED
64	25-Feb-2020	GULBARGA	110	HV2	DEODURGA_110	11:35	11:45	0:10	TRANSFORMER FAULT
65	25-Feb-2020	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	11:57	12:10	0:13	LINE FAULT
66	25-Feb-2020	GULBARGA	110	RAICHUR-SHAHAPUR1	GABUR_110,DEODURGA_110	12:03	12:21	0:18	LINE FAULT
67	25-Feb-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	12:12	12:16	0:04	LINE CLEAR AVAILED
68	25-Feb-2020	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	13:05	18:34	5:29	LINE CLEAR AVAILED
69	25-Feb-2020	GULBARGA	110	RAICHUR-SHAHAPUR1	GABUR_110,DEODURGA_110	13:26	17:16	3:50	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
70	25-Feb-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	11:55	17:00	5:05	LINE FAULT
71	25-Feb-2020	GULBARGA	110	HV1	MANVI_110	14:32	14:45	0:13	TRANSFORMER FAULT
72	25-Feb-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGAR_IPP,CHOW DAPUR_110	15:05	16:08	1:03	LINE CLEAR AVAILED
73	25-Feb-2020	GULBARGA	110	HV1	KAVITAL_110	16:25	16:30	0:05	TRANSFORMER FAULT
74	25-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_ 110,UGAR SUGAR_IPP	19:25	19:35	0:10	LINE FAULT
75	25-Feb-2020	GULBARGA	110	HV2	SHAKTHINAGAR_110	22:22	23:59	1:37	LINE CLEAR AVAILED
76	25-Feb-2020	GULBARGA	66	HV1 & HV2	TAMBRAHALLI_66	6:55	7:20	0:25	LINE CLEAR AVAILED
77	25-Feb-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	10:14	15:12	4:58	LINE CLEAR AVAILED
78	25-Feb-2020	HASSAN	110	HV1	HALADY_110	11:48	13:01	1:13	LINE CLEAR AVAILED
79	25-Feb-2020	HASSAN	110	HV1	KALLUSADARAHALLY_110	18:22	18:24	0:02	HAND TRIPPED
80	25-Feb-2020	HASSAN	110	KEMAR-Manipal1	KEMAR_220	10:48	12:50	2:02	LINE CLEAR AVAILED
81	25-Feb-2020	HASSAN	110	KEMAR-Manipal1	KEMAR_220	15:04	15:06	0:02	HAND TRIPPED
82	25-Feb-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	10:48	12:52	2:04	LINE CLEAR AVAILED
83	25-Feb-2020	HASSAN	110	HV2	KUNDAPURA_110	9:31	18:23	8:52	LINE CLEAR AVAILED
84	25-Feb-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	10:08	15:20	5:12	LINE CLEAR AVAILED
85	25-Feb-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:15	15:58	5:43	LINE CLEAR AVAILED
86	25-Feb-2020	HASSAN	110	HV1	MANIPAL_110	10:15	15:12	4:57	LINE CLEAR AVAILED
87	25-Feb-2020	HASSAN	110	HV2	MANIPAL_110	10:15	15:06	4:51	LINE CLEAR AVAILED
88	25-Feb-2020	HASSAN	110	HV3	MANIPAL_110	10:10	15:20	5:10	LINE CLEAR AVAILED
89	25-Feb-2020	HASSAN	110	HV4	MANIPAL_110	10:06	15:14	5:08	LINE CLEAR AVAILED
90	25-Feb-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	10:15	15:05	4:50	LINE CLEAR AVAILED
91	25-Feb-2020	HASSAN	110	HV2	SORABA_110	11:30	16:06	4:36	LINE CLEAR AVAILED
92	25-Feb-2020	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	22:01	22:27	0:26	LINE FAULT
93	25-Feb-2020	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	22:47	23:01	0:14	LINE FAULT
94	25-Feb-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	17:38	17:48	0:10	LINE FAULT
95	25-Feb-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:55	13:10	3:15	NFBC ISSUED
96	25-Feb-2020	HASSAN	66	HV2	CHIKMAGALUR_66	12:10	12:25	0:15	LINE CLEAR AVAILED
97	25-Feb-2020	HASSAN	66	HV1	KANDLI_66	9:27	9:32	0:05	TRANSFORMER FAULT
98	25-Feb-2020	HASSAN	66	HV1	KANDLI_66	14:28	14:30	0:02	TRANSFORMER FAULT
99	25-Feb-2020	HASSAN	66	HV1	SOMANAHALLI_66	14:03	16:00	1:57	LINE CLEAR AVAILED
100	25-Feb-2020	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	17:04	17:10	0:06	HAND TRIPPED
101	25-Feb-2020	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	17:37	17:45	0:08	LINE FAULT
102	25-Feb-2020	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	22:01	22:36	0:35	LINE FAULT
103	25-Feb-2020	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	22:36	22:46	0:10	LINE FAULT
104	25-Feb-2020	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	22:47	23:59	1:12	LINE FAULT
105	25-Feb-2020	MYSORE	66	HV1	BOMMALAPURA_66	12:08	14:21	2:13	LINE CLEAR AVAILED
106	25-Feb-2020	MYSORE	66	HV2	BOMMALAPURA_66	15:12	16:34	1:21	LINE CLEAR AVAILED
107	25-Feb-2020	MYSORE	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66	17:04	17:12	0:08	HAND TRIPPED
108	25-Feb-2020	MYSORE	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66	18:02	18:07	0:04	LINE FAULT
109	25-Feb-2020	MYSORE	66	HV1	FTS_66	14:10	14:26	0:15	HAND TRIPPED
110	25-Feb-2020	MYSORE	66	HV2	FTS_66	8:50	21:11	12:20	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
111	25-Feb-2020	MYSORE	66	HV2	FTS_66	21:11	21:23	0:12	TRANSFORMER FAULT
112	25-Feb-2020	MYSORE	66	HV2	HULLAHALLI_66	11:42	12:50	1:07	LINE CLEAR AVAILED
113	25-Feb-2020	MYSORE	66	HV2	KRPET_66	13:05	14:02	0:57	LINE CLEAR AVAILED
114	25-Feb-2020	MYSORE	66	SINDUVALLI-KADAKOLA	SINDHUVALLI_66	10:03	17:45	7:42	LINE CLEAR AVAILED
115	25-Feb-2020	MYSORE	66	TUBINKERE-NAGAMANGLA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66	16:53	16:59	0:05	LINE FAULT
116	25-Feb-2020	MYSORE	66	TUBINKERE-NAGAMANGLA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66	17:08	17:17	0:08	LINE FAULT
117	25-Feb-2020	MYSORE	66	TUBINKERE-NAGAMANGLA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66	17:35	17:49	0:13	LINE FAULT
118	25-Feb-2020	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	11:05	11:51	0:46	HAND TRIPPED
119	25-Feb-2020	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	11:05	11:51	0:46	HAND TRIPPED
120	25-Feb-2020	TUMKUR	220	TR-1	PAVAGADA_220	14:22	14:26	0:04	LINE CLEAR AVAILED
121	25-Feb-2020	TUMKUR	220	MADHUGIRI 220kV- GOWRIBIDANUR220	MADHUGIRI 220kV	11:14	12:46	1:32	LINE CLEAR AVAILED
122	25-Feb-2020	TUMKUR	110	TR-1	DODDAGUNI_110	21:04	21:24	0:20	TRANSFORMER FAULT
123	25-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	11:49	11:58	0:08	HAND TRIPPED
124	25-Feb-2020	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	13:12	13:18	0:05	LINE FAULT
125	25-Feb-2020	TUMKUR	110	TR-1	KALLUR_110	8:59	15:21	6:21	TRANSFORMER FAULT
126	25-Feb-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	10:03	11:50	1:47	MAIN SUPPLY FAILURE
127	25-Feb-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	10:03	11:55	1:52	MAIN SUPPLY FAILURE
128	25-Feb-2020	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	12:35	12:40	0:05	LINE FAULT
129	25-Feb-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	13:37	13:47	0:10	LINE FAULT
130	25-Feb-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	11:30	11:31	0:00	MAIN SUPPLY FAILURE
131	25-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	7:30	7:35	0:04	TRANSFORMER FAULT
132	25-Feb-2020	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	16:39	18:17	1:37	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
133	25-Feb-2020	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	16:40	18:17	1:36	LINE CLEAR AVAILED
134	25-Feb-2020	TUMKUR	66	TR-1	CHITRADURGA_66	18:38	18:49	0:11	TRANSFORMER FAULT
135	25-Feb-2020	TUMKUR	66	TR-1	CHITRADURGA_66	22:14	22:29	0:15	TRANSFORMER FAULT
136	25-Feb-2020	TUMKUR	66	TR-2	CHITRADURGA_66	10:59	15:20	4:21	MAIN SUPPLY FAILURE
137	25-Feb-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	11:06	11:48	0:42	MAIN SUPPLY FAILURE
138	25-Feb-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	11:06	11:48	0:42	MAIN SUPPLY FAILURE
139	25-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	4:11	4:35	0:24	LINE FAULT
140	25-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:03	10:17	0:14	LINE FAULT
141	25-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:38	14:47	1:08	LINE FAULT
142	25-Feb-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:54	20:04	0:09	LINE FAULT
143	25-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:51	12:58	0:06	LINE FAULT
144	25-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:21	16:27	0:06	LINE FAULT
145	25-Feb-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	11:42	11:52	0:09	TRANSFORMER FAULT
146	25-Feb-2020	TUMKUR	66	HARIHARA-DAVANGERE SRS	HARIHAR_66	13:59	14:05	0:05	MAIN SUPPLY FAILURE
147	25-Feb-2020	TUMKUR	66	TR-1	HARIHAR_66	11:14	12:25	1:11	LINE CLEAR AVAILED
148	25-Feb-2020	TUMKUR	66	TR-1 & TR-2	HARIHAR_66	13:59	14:06	0:06	MAIN SUPPLY FAILURE
149	25-Feb-2020	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	13:33	13:44	0:10	LINE FAULT
150	25-Feb-2020	TUMKUR	66	TR-1	NAGASAMUDRA_66	10:54	16:18	5:23	LINE CLEAR AVAILED
151	25-Feb-2020	TUMKUR	66	TR-2	KORATAGERE_66	12:35	14:27	1:52	LINE CLEAR AVAILED
152	25-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	9:58	10:14	0:16	LINE FAULT
153	25-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	13:57	14:09	0:12	LINE FAULT
154	25-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	16:31	18:42	2:10	LINE CLEAR AVAILED
155	25-Feb-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	14:46	14:50	0:03	TRANSFORMER FAULT
156	25-Feb-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	21:39	21:51	0:11	TRANSFORMER FAULT
157	25-Feb-2020	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,LING DHALLI_66,MANGALWADA_66	21:47	22:35	0:48	LINE CLEAR AVAILED
158	25-Feb-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	21:37	22:39	1:02	LINE CLEAR AVAILED
159	25-Feb-2020	TUMKUR	66	TR-1	SHYLAPURA_66	11:26	11:38	0:11	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
160	25-Feb-2020	TUMKUR	66	TR-2	SHYLAPURA_66	21:37	22:39	1:02	LINE CLEAR AVAILED
161	25-Feb-2020	TUMKUR	66	TR-1	SHYLAPURA_66	21:37	22:39	1:02	LINE CLEAR AVAILED
162	26-Feb-2020	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	10:16	15:56	5:40	LINE CLEAR AVAILED
163	26-Feb-2020	BAGALKOT	110	110/11KV,HV2	ACHANUR_110	12:05	15:50	3:45	LINE CLEAR AVAILED
164	26-Feb-2020	BAGALKOT	110	BAGEWADI220-MAMADAPUR2	MAMADAPUR_110	21:59	22:08	0:09	LINE FAULT
165	26-Feb-2020	BAGALKOT	110	110/11KV,HV1	BILAGI_110	15:35	16:30	0:55	LINE CLEAR AVAILED
166	26-Feb-2020	BAGALKOT	220	220/110KV,HV2&LV2	GADAG_220	11:52	18:48	6:56	LINE CLEAR AVAILED
167	26-Feb-2020	BAGALKOT	110	110/33KV,HV2	GULEDAGUDDA_110	11:00	17:57	6:57	TRANSFORMER FAULT
168	26-Feb-2020	BAGALKOT	110	110/33KV,HV2	HANAGAL_110,LAXMIPUR_33,AKKIH ALUR_33,BOMMANAHALLI_33,BELAG ALAPETE_33	8:55	8:59	0:04	TRANSFORMER FAULT
169	26-Feb-2020	BAGALKOT	110	110/33KV,HV2	HANAGAL_110,LAXMIPUR_33,AKKIH ALUR_33,BOMMANAHALLI_33,BELAG ALAPETE_33	9:32	9:35	0:03	TRANSFORMER FAULT
170	26-Feb-2020	BAGALKOT	110	SIRSI-KIRUVATTI	KIRUVATTI_110	4:45	4:55	0:10	MAIN SUPPLY FAILURE
171	26-Feb-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HORTI_33	7:43	7:48	0:05	TRANSFORMER FAULT
172	26-Feb-2020	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HORTI_33	15:09	15:13	0:04	TRANSFORMER FAULT
173	26-Feb-2020	BAGALKOT	110	UGAR SUGAR-UGARKHUD	UGARKHUD_110	17:19	17:21	0:02	LINE CLEAR AVAILED
174	26-Feb-2020	BAGALKOT	110	UGAR KHUD-KAGAWAD	KAGAWAD_110	17:19	17:35	0:16	LINE CLEAR AVAILED
175	26-Feb-2020	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	4:29	4:40	0:11	LINE FAULT
176	26-Feb-2020	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	7:01	7:04	0:03	TRANSFORMER FAULT
177	26-Feb-2020	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)_110	10:05	16:58	6:53	LINE CLEAR AVAILED
178	26-Feb-2020	BAGALKOT	110	110/11KV,HV2	MUKARTIHAL_110	18:35	18:57	0:22	LINE CLEAR AVAILED
179	26-Feb-2020	BAGALKOT	110	110/11KV,HV1	KUMTA_110	10:02	17:38	7:36	LINE CLEAR AVAILED
180	26-Feb-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:00	15:04	2:03	LINE CLEAR AVAILED
181	26-Feb-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	11:47	12:11	0:23	LINE CLEAR AVAILED
182	26-Feb-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	16:19	16:51	0:32	LOAD CURTAILMENT
183	26-Feb-2020	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU, SOMENAHALLI, SADLI, JULUPALYA	6:25	6:31	0:06	LINE FAULT
184	26-Feb-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	14:47	14:51	0:04	LINE FAULT
185	26-Feb-2020	BENGALURU	66	HV2	BMTC	8:02	8:04	0:02	LINE CLEAR AVAILED
186	26-Feb-2020	BENGALURU	66	HV2	BMTC	18:25	18:46	0:21	LINE CLEAR AVAILED
187	26-Feb-2020	BENGALURU	66	HV2	BRIGADE METRO POLIS	11:23	11:56	0:33	LINE CLEAR AVAILED
188	26-Feb-2020	BENGALURU	66	HV1	PADMANBHANAGAR	14:12	14:17	0:04	LINE CLEAR AVAILED
189	26-Feb-2020	BENGALURU	66	HV1	Y HUNSENHALLI	19:08	21:31	2:22	TRANSFORMER FAULT
190	26-Feb-2020	GULBARGA	220	ALIPUR-NEELGUNDA	ALIPUR_220	3:54	4:15	0:21	LINE FAULT
191	26-Feb-2020	GULBARGA	220	HV1 & HV2	MALLAT_220	11:40	13:20	1:40	LINE CLEAR AVAILED
192	26-Feb-2020	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	13:35	19:54	6:19	LINE CLEAR AVAILED
193	26-Feb-2020	GULBARGA	220	HV2	HUMNABAD_220	14:20	14:25	0:05	TRANSFORMER FAULT
194	26-Feb-2020	GULBARGA	220	HV2	ALLIPUR_220	20:50	21:02	0:12	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
195	26-Feb-2020	GULBARGA	110	HV2	SHAKTHINAGAR_110	0:00	15:39	15:39	LINE CLEAR AVAILED
196	26-Feb-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	0:00	16:10	16:10	LINE CLEAR AVAILED
197	26-Feb-2020	GULBARGA	110	ALLIPUR-KUDITINI	KUDITINI_110	9:50	18:25	8:35	LINE CLEAR AVAILED
198	26-Feb-2020	GULBARGA	110	HV1	KEMBHAVI_110	10:00	10:10	0:10	TRANSFORMER FAULT
199	26-Feb-2020	GULBARGA	110	SHAHAPUR-RAICHUR2	GOOGLE_110	10:02	15:49	5:47	NFBC ISSUED
200	26-Feb-2020	GULBARGA	110	CHITAGUPPA-ACMESOLAR	CHITAGUPPA_110,NIRNA_110	11:45	11:56	0:11	LINE FAULT
201	26-Feb-2020	GULBARGA	110	HV1	KEMBHAVI_110	13:42	13:45	0:03	TRANSFORMER FAULT
202	26-Feb-2020	GULBARGA	110	SHAHAPUR-RAICHUR1	GABUR_110,DEODURGA_110	14:06	15:48	1:42	LINE CLEAR AVAILED
203	26-Feb-2020	GULBARGA	110	HV1	KEMBHAVI_110	14:40	14:45	0:05	TRANSFORMER FAULT
204	26-Feb-2020	GULBARGA	110	SEDAM-VICATSAGAR	VICATSAGAR_1IPP	18:50	19:05	0:15	LINE FAULT
205	26-Feb-2020	GULBARGA	110	MALLAT-BYAGAWAT	BYAGAWAT_110	20:02	20:12	0:10	LINE FAULT
206	26-Feb-2020	GULBARGA	110	ALLIPUR-MUNIRBAD	TORANGALLU_110,KUDITINI_110,KU RUGOD_110,AGRAWAL_1PP,SHATHV AHANA_1PP,SUZLON_1PP,KAMALAPU R_110,MATRI_110,RANS FACTORY	20:50	21:33	0:43	LINE FAULT
207	26-Feb-2020	GULBARGA	110	ALLIPUR-ALLIPUR SOUTH	ALLIPUR SOUTH_110	20:55	21:05	0:10	LINE CLEAR AVAILED
208	26-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_ 110,UGAR SUGAR_1PP	21:34	21:50	0:16	LINE FAULT
209	26-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110,ASKI_ 110,UGAR SUGAR_1PP	21:51	22:38	0:47	LINE CLEAR AVAILED
210	26-Feb-2020	GULBARGA	66	ITTAGI-HIREHADAGALI	HIREHADAGALI_66,SOVENHALLI_66, MAGALA_66, GIRIYAPURA_66,MYLAR_66	2:16	2:25	0:09	LINE FAULT
211	26-Feb-2020	HASSAN	220	ARSK2-SHMG	ARSK2	14:48	16:42	1:54	LINE FAULT
212	26-Feb-2020	HASSAN	220	MRSSHM-ARASIKERE	MRSMSG_220	14:48	16:45	1:57	LINE FAULT
213	26-Feb-2020	HASSAN	220	MRSSHM-SHANTHIGRAMA	MRSMSG_220	3:50	11:14	7:24	LINE FAULT
214	26-Feb-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	13:04	16:17	3:13	LINE CLEAR AVAILED
215	26-Feb-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	9:13	18:07	8:54	LINE CLEAR AVAILED
216	26-Feb-2020	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	9:13	18:07	8:54	LINE CLEAR AVAILED
217	26-Feb-2020	HASSAN	110	HV1	ANANDAPURA_110	11:49	16:28	4:39	LINE CLEAR AVAILED
218	26-Feb-2020	HASSAN	110	JOG110-LPH	JOG_110	9:04	10:56	1:52	LINE CLEAR AVAILED
219	26-Feb-2020	HASSAN	110	KADUR-AJAMPURA	KADUR_220	5:53	8:44	2:51	LINE FAULT
220	26-Feb-2020	HASSAN	110	KADUR-TNGL	KADUR_220	14:21	14:27	0:06	LINE CLEAR AVAILED
221	26-Feb-2020	HASSAN	110	HV2	NERALAKERE_110	10:00	13:32	3:32	LINE CLEAR AVAILED
222	26-Feb-2020	HASSAN	66	HASSN22-MALLALI	HASSAN_220	12:29	12:48	0:19	LINE CLEAR AVAILED
223	26-Feb-2020	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	12:27	12:50	0:23	LINE CLEAR AVAILED
224	26-Feb-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	20:16	20:30	0:14	LINE FAULT
225	26-Feb-2020	HASSAN	66	AREHALI-SAKLESPUR	AREHALLI_HSN_66	11:25	13:28	2:03	LINE CLEAR AVAILED
226	26-Feb-2020	HASSAN	66	CHKMA-L1-ALDUR	CHIKMAGALUR_66	17:05	17:22	0:17	LINE FAULT
227	26-Feb-2020	HASSAN	66	HIREMAN-RDL	HIREMANGALUR_66	10:15	16:55	6:40	LINE CLEAR AVAILED
228	26-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHPUA_66	13:09	13:18	0:09	HAND TRIPPED
229	26-Feb-2020	HASSAN	66	HV2	SHANTHIGRAMMA_66	12:01	12:40	0:39	LINE CLEAR AVAILED
230	26-Feb-2020	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	18:08	18:12	0:04	HAND TRIPPED
231	26-Feb-2020	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	18:08	18:13	0:05	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
232	26-Feb-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	16:49	18:06	1:17	LINE FAULT
233	26-Feb-2020	HASSAN	66	KIAD H-RAMESWARNAGAR	KIADB_66	0:00	14:48	14:48	LINE FAULT
234	26-Feb-2020	HASSAN	66	KIAD H-RAMESWARNAGAR	KIADB_66	14:58	15:09	0:11	HAND TRIPPED
235	26-Feb-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	11:52	11:58	0:06	LINE FAULT
236	26-Feb-2020	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66 CHANDRAVADI_66	11:52	11:58	0:06	LINE FAULT
237	26-Feb-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	12:30	12:33	0:03	LINE FAULT
238	26-Feb-2020	MYSORE	66	KADAKOLA-SARGUR 2	HURA_66, HULLAHALLI_66, DOORA_66 CHANDRAVADI_66	12:30	12:33	0:03	LINE FAULT
239	26-Feb-2020	MYSORE	66	TUBINKERE-ARAKERE	TARIPURA_66 GAMANAHALLY_66 ARAKERE_66	2:49	2:56	0:07	LINE FAULT
240	26-Feb-2020	MYSORE	66	TUBINKERE-MC2	MANDYA_66 CHIKKA_MANDYA_66 BASARALU_66 KOPPA_66 BESAGARAHALLI_66 HAMPAPURA_66	8:21	8:33	0:12	LINE FAULT
241	26-Feb-2020	MYSORE	66	TUBINKERE-MC4	KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	8:21	8:33	0:12	LINE FAULT
242	26-Feb-2020	MYSORE	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	16:11	16:12	0:01	HAND TRIPPED
243	26-Feb-2020	MYSORE	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	18:09	18:10	0:01	HAND TRIPPED
244	26-Feb-2020	TUMKUR	220	HIRIYUR220-MADHUGIRI	HIRIYUR_220	15:10	18:00	2:50	LINE FAULT
245	26-Feb-2020	TUMKUR	220	MADHUGIRI 220kV-GOWRIBIDANUR220	MADHUGIRI 220kV	16:16	16:44	0:27	HAND TRIPPED
246	26-Feb-2020	TUMKUR	110	TR-1	KALLUR_110	14:17	14:20	0:02	LINE CLEAR AVAILED
247	26-Feb-2020	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	10:25	10:35	0:09	LINE FAULT
248	26-Feb-2020	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	9:09	10:54	1:44	LINE CLEAR AVAILED
249	26-Feb-2020	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	15:38	16:55	1:17	LINE CLEAR AVAILED
250	26-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	2:02	3:49	1:46	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
251	26-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:17	8:27	0:10	LINE FAULT
252	26-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:01	9:22	0:20	LINE FAULT
253	26-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:15	13:25	0:09	LINE FAULT
254	26-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:49	14:57	0:07	LINE FAULT
255	26-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	13:08	13:25	0:16	LINE FAULT
256	26-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:06	15:21	0:15	LINE FAULT
257	26-Feb-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	4:24	6:58	2:34	LINE FAULT
258	26-Feb-2020	TUMKUR	66	TR-1	GARAGA_66	6:32	6:49	0:16	TRANSFORMER FAULT
259	26-Feb-2020	TUMKUR	66	HANAGAL- THALLAK	HANAGAL_66	21:20	21:37	0:16	LINE FAULT
260	26-Feb-2020	TUMKUR	66	TR-1&TR-2	HANAGAL_66	21:31	21:40	0:09	HAND TRIPPED
261	26-Feb-2020	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	21:31	21:47	0:16	HAND TRIPPED
262	26-Feb-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:19	18:36	0:16	LINE FAULT
263	26-Feb-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	18:28	18:33	0:04	HAND TRIPPED
264	26-Feb-2020	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	5:04	8:14	3:10	LINE CLEAR AVAILED
265	26-Feb-2020	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	18:30	18:34	0:04	HAND TRIPPED
266	26-Feb-2020	TUMKUR	66	TR-1	KORATAGERE_66	7:19	9:25	2:06	LINE CLEAR AVAILED
267	26-Feb-2020	TUMKUR	66	TR-2	KORATAGERE_66	7:09	7:27	0:17	LINE CLEAR AVAILED
268	26-Feb-2020	TUMKUR	66	TR-1	MATHOD_66	11:01	11:27	0:26	TRANSFORMER FAULT
269	26-Feb-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGID URGA_66,JAGALUR_66,PALLAGATTE_ 66	13:02	13:56	0:54	LINE CLEAR AVAILED
270	26-Feb-2020	TUMKUR	66	TR-1	NEELAGUNDA_220	9:45	9:54	0:08	TRANSFORMER FAULT
271	26-Feb-2020	TUMKUR	66	TR-1	PAVAGADA_220	11:33	12:04	0:30	MAIN SUPPLY FAILURE
272	26-Feb-2020	TUMKUR	66		PAVAGADA_220	13:31	14:31	0:59	MAIN SUPPLY FAILURE
273	27-Feb-2020	BAGALKOT	110	AMBEWADI220-NK2	KAVALWADA_110	9:55	17:35	7:40	LINE CLEAR AVAILED
274	27-Feb-2020	BAGALKOT	110	AMBEWADI220-NK1	HALIYAL_110	10:04	17:35	7:31	LINE CLEAR AVAILED
275	27-Feb-2020	BAGALKOT	110	AMBEWADI220-NK2	KAVALWADA_110	19:16	19:25	0:09	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
276	27-Feb-2020	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	12:08	13:42	1:34	LINE CLEAR AVAILED
277	27-Feb-2020	BAGALKOT	110	110/11KV,HV2	ACHANUR_110	13:42	14:30	0:48	LINE CLEAR AVAILED
278	27-Feb-2020	BAGALKOT	110	110/11KV,HV1	ANAND NAGAR_110	12:20	13:15	0:55	LINE CLEAR AVAILED
279	27-Feb-2020	BAGALKOT	110	ARGA-ANKOLA	ANKOLA_110	19:41	21:29	1:48	LINE CLEAR AVAILED
280	27-Feb-2020	BAGALKOT	110	EILS(SOLAR)-DAMBAL	DAMBAL_110	18:40	23:59	5:19	LINE FAULT
281	27-Feb-2020	BAGALKOT	220	220/110KV,HV1&LV1	GADAG_220	8:30	12:20	3:50	LINE CLEAR AVAILED
282	27-Feb-2020	BAGALKOT	220	220/110KV,HV3&LV3	GADAG_220	10:44	14:10	3:26	LINE CLEAR AVAILED
283	27-Feb-2020	BAGALKOT	110	110/33KV,HV1&HV2	HANGAL_110,BELAGALPET_33,LAXMI PUR_33,BASAPUR_33,PALA_33,BOM MANAHALLI_33	7:27	7:46	0:19	TRANSFORMER FAULT
284	27-Feb-2020	BAGALKOT	110	110/33KV,HV1&HV2	HANGAL_110,BELAGALPET_33,LAXMI PUR_33,BASAPUR_33,PALA_33,BOM MANAHALLI_33	10:01	10:14	0:13	TRANSFORMER FAULT
285	27-Feb-2020	BAGALKOT	220	KAVATAGI LIS-VAJRAMATTI	VAJRAMATTI_220	12:06	16:54	4:48	LINE CLEAR AVAILED
286	27-Feb-2020	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	5:58	6:05	0:07	LINE FAULT
287	27-Feb-2020	BAGALKOT	110	110/11KV,HV1	TODALBAGI_110	3:33	3:38	0:05	TRANSFORMER FAULT
288	27-Feb-2020	BAGALKOT	110	KUDUCHI-TERDAL	TERDAL_110	11:42	23:59	12:17	LINE CLEAR AVAILED
289	27-Feb-2020	BAGALKOT	220	220/110KV,HV2,LV3	HUBLI_220	10:21	12:12	1:51	LINE CLEAR AVAILED
290	27-Feb-2020	BAGALKOT	110	220/110KV,LV3	HUBLI_220	12:13	23:59	11:46	LINE CLEAR AVAILED
291	27-Feb-2020	BAGALKOT	110	SAVANUR-RAMANAKOPPA	RAMANAKOPPA_110,SHIGGOAN_110 ,MUNDAGOD_110	0:30	1:05	0:35	HAND TRIPPED
292	27-Feb-2020	BAGALKOT	110	SAVANUR-RAMANAKOPPA	RAMANAKOPPA_110,SHIGGOAN_110 ,MUNDAGOD_110	1:50	6:35	4:45	LINE CLEAR AVAILED
293	27-Feb-2020	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	0:30	1:05	0:35	HAND TRIPPED
294	27-Feb-2020	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	1:50	6:35	4:45	LINE CLEAR AVAILED
295	27-Feb-2020	BAGALKOT	110	110/11KV,HV1	SAVANUR_110	0:30	1:05	0:35	HAND TRIPPED
296	27-Feb-2020	BAGALKOT	110	110/11KV,HV1	SAVANUR_110	1:50	6:45	4:55	LINE CLEAR AVAILED
297	27-Feb-2020	BAGALKOT	110	110/33KV,HV1	SAVANUR_110,BANKAPUR_33,HATTI MATTUR_33	0:30	1:05	0:35	HAND TRIPPED
298	27-Feb-2020	BAGALKOT	110	110/33KV,HV1	SAVANUR_110,BANKAPUR_33,HATTI MATTUR_33	1:50	6:45	4:55	LINE CLEAR AVAILED
299	27-Feb-2020	BAGALKOT	110	110/33KV.HV2	SAVANUR_110,HULAGUR_33,GUDIGE RI_33,HESARUR_33	0:30	1:05	0:35	HAND TRIPPED
300	27-Feb-2020	BAGALKOT	110	110/33KV.HV2	SAVANUR_110,HULAGUR_33,GUDIGE RI_33,HESARUR_33	1:50	6:45	4:55	LINE CLEAR AVAILED
301	27-Feb-2020	BAGALKOT	110	110/11KV,HV2	SAVALAGI_110	14:05	14:30	0:25	TRANSFORMER FAULT
302	27-Feb-2020	BAGALKOT	110	110/11KV,HV2	SAVALAGI_110	11:08	12:11	1:03	LINE CLEAR AVAILED
303	27-Feb-2020	BAGALKOT	110	SIRSI1&2-KUMTA	KUMTA_110	0:00	19:31	19:31	LINE CLEAR AVAILED
304	27-Feb-2020	BAGALKOT	110	110/11KV,HV1	KUMTA_110	19:20	20:54	1:34	TRANSFORMER FAULT
305	27-Feb-2020	BAGALKOT	110	110/33KV.HV3	KUMTA_110,MARAKAL_33KV,GOKAR NA_33KV	19:15	19:46	0:31	TRANSFORMER FAULT
306	27-Feb-2020	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	17:32	19:32	2:00	LINE CLEAR AVAILED
307	27-Feb-2020	BAGALKOT	110	110/11KV,HV1	KAGAWAD_110	11:37	14:25	2:48	LINE CLEAR AVAILED
308	27-Feb-2020	BAGALKOT	110	ILKAL1-HUNGUND	HUNGUND_110	15:45	16:15	0:30	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
309	27-Feb-2020	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220,TERDAL_110,R ABAKAVI_110,ITNAL_110,HIDIKAL_11 0	14:46	15:04	0:18	TRANSFORMER FAULT
310	27-Feb-2020	BAGALKOT	110	MAHALINGAPUR220-TERDAL	TERDAL_110	18:32	19:35	1:03	LINE CLEAR AVAILED
311	27-Feb-2020	BENGALURU	66	A STATION 220 - A STATION 1	A STATION 66	15:17	15:20	0:03	MAIN SUPPLY FAILURE
312	27-Feb-2020	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	14:58	15:29	0:30	MAIN SUPPLY FAILURE
313	27-Feb-2020	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	14:58	15:36	0:38	MAIN SUPPLY FAILURE
314	27-Feb-2020	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	14:58	15:33	0:35	MAIN SUPPLY FAILURE
315	27-Feb-2020	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	14:58	15:33	0:35	MAIN SUPPLY FAILURE
316	27-Feb-2020	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	14:58	15:31	0:32	MAIN SUPPLY FAILURE
317	27-Feb-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:58	15:33	0:35	MAIN SUPPLY FAILURE
318	27-Feb-2020	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:58	15:34	0:35	MAIN SUPPLY FAILURE
319	27-Feb-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	9:56	10:06	0:09	LINE CLEAR AVAILED
320	27-Feb-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:58	15:43	0:45	MAIN SUPPLY FAILURE
321	27-Feb-2020	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	21:35	21:39	0:04	LOAD CHANGE OVER
322	27-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	15:18	15:59	0:40	MAIN SUPPLY FAILURE
323	27-Feb-2020	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	15:18	15:56	0:37	MAIN SUPPLY FAILURE
324	27-Feb-2020	BENGALURU	220	NIMHANS 220 - HSR LAYOUT 220	NIMHANS 220	15:17	15:54	0:36	LINE FAULT
325	27-Feb-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	5:54	6:03	0:09	LINE FAULT
326	27-Feb-2020	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:58	15:27	0:29	LINE FAULT
327	27-Feb-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	12:24	13:18	0:54	LINE FAULT
328	27-Feb-2020	BENGALURU	220	EDC 220 - NIMHANS 220	NIMHANS 220	15:17	15:55	0:38	MAIN SUPPLY FAILURE
329	27-Feb-2020	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN	15:17	15:59	0:42	MAIN SUPPLY FAILURE
330	27-Feb-2020	BENGALURU	66	EDC 220 - B STATION	B STATION	15:17	15:59	0:41	MAIN SUPPLY FAILURE
331	27-Feb-2020	BENGALURU	66	HV1	VIJAYAPURA	18:36	19:50	1:13	TRANSFORMER FAULT
332	27-Feb-2020	BENGALURU	66	HV1	VIKAS TECH PARK 220	14:58	15:29	0:31	MAIN SUPPLY FAILURE
333	27-Feb-2020	BENGALURU	66	HV2	VIKAS TECH PARK 220	14:58	15:29	0:31	MAIN SUPPLY FAILURE
334	27-Feb-2020	BENGALURU	220	HV1	VIKAS TECH PARK 220	14:58	14:59	0:01	MAIN SUPPLY FAILURE
335	27-Feb-2020	BENGALURU	220	HV2	VIKAS TECH PARK 220	14:58	15:31	0:33	MAIN SUPPLY FAILURE
336	27-Feb-2020	BENGALURU	66	HV2	REMCO	13:09	14:40	1:31	LINE CLEAR AVAILED
337	27-Feb-2020	BENGALURU	220	HV1	NIMHANS 220	15:18	15:54	0:36	MAIN SUPPLY FAILURE
338	27-Feb-2020	BENGALURU	220	HV2	NIMHANS 220	15:18	15:54	0:36	MAIN SUPPLY FAILURE
339	27-Feb-2020	BENGALURU	66	HV2	NIMHANS 220	15:18	16:05	0:47	MAIN SUPPLY FAILURE
340	27-Feb-2020	BENGALURU	220	HV1	EDC 220	15:17	16:00	0:42	MAIN SUPPLY FAILURE
341	27-Feb-2020	BENGALURU	220	HV2	EDC 220	15:58	15:58	0:00	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
342	27-Feb-2020	BENGALURU	66	HV2	EDC 220	15:18	16:00	0:41	MAIN SUPPLY FAILURE
343	27-Feb-2020	BENGALURU	66	HV2	EDC 220	15:18	15:58	0:40	MAIN SUPPLY FAILURE
344	27-Feb-2020	BENGALURU	66	HV1	BOODIGERE	22:33	22:42	0:09	TRANSFORMER FAULT
345	27-Feb-2020	BENGALURU	66	HV2	ANDERSONPET	19:10	19:11	0:01	TRANSFORMER FAULT
346	27-Feb-2020	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	14:51	14:57	0:06	TRANSFORMER FAULT
347	27-Feb-2020	BENGALURU	66	HV2	NIMHANS 220	13:10	13:28	0:18	LINE CLEAR AVOIDED
348	27-Feb-2020	BENGALURU	66	HV2	NIMHANS 220	13:37	13:41	0:04	LINE CLEAR AVOIDED
349	27-Feb-2020	GULBARGA	400	RTPS-GD HALLI	GDHALLI_440	9:49	18:43	8:54	LINE CLEAR AVOIDED
350	27-Feb-2020	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	12:38	13:48	1:10	LINE CLEAR AVOIDED
351	27-Feb-2020	GULBARGA	220	HV1 & HV2	ITTAGI_220	14:00	14:15	0:15	LINE CLEAR AVOIDED
352	27-Feb-2020	GULBARGA	220	HV1	LINGASUGUR_220	14:42	14:47	0:05	TRANSFORMER FAULT
353	27-Feb-2020	GULBARGA	220	HV2	LINGASUGUR_220	14:42	14:47	0:05	TRANSFORMER FAULT
354	27-Feb-2020	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	5:05	5:15	0:10	LINE FAULT
355	27-Feb-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,HUNASIGI_110, ASKI_110	5:12	5:20	0:08	LINE FAULT
356	27-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASIGI_110, ASKI_110,UGAR SUGAR_IPP	5:12	5:20	0:08	LINE FAULT
357	27-Feb-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_IPP	5:15	5:25	0:10	LINE FAULT
358	27-Feb-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	6:58	7:10	0:12	LINE FAULT
359	27-Feb-2020	GULBARGA	110	HV1	TAMBRAHALLI_66+F384	7:20	8:16	0:56	LINE CLEAR AVOIDED
360	27-Feb-2020	GULBARGA	110	HV2	KEMBHAVI_110	8:34	9:19	0:45	LINE CLEAR AVOIDED
361	27-Feb-2020	GULBARGA	110	HV1	DEODURGA_110	12:30	12:45	0:15	LINE CLEAR AVOIDED
362	27-Feb-2020	GULBARGA	110	HV2	DEODURGA_110	13:11	13:22	0:11	LINE CLEAR AVOIDED
363	27-Feb-2020	GULBARGA	110	HV3	LADHA_110	16:20	16:30	0:10	TRANSFORMER FAULT
364	27-Feb-2020	GULBARGA	110	SHAHAPUR-WARADA SOLAR	SHAHAPUR_220	18:40	18:50	0:10	LINE FAULT
365	27-Feb-2020	GULBARGA	66	ITTAGI-HIREHADAGALI1&2	HIREHADAGALI_66,SOVENHALLI_66, MAGALA_66, GIRIYAPURA_66,MYLAR_66	10:40	17:23	6:43	LINE CLEAR AVOIDED
366	27-Feb-2020	GULBARGA	66	ITTAGI-KUDLIGI1&2	KOGALI_66,KUDLIGI_66,HANASI_66,C JHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BANVEKAL_66,CHORNOOR_66	11:20	14:55	3:35	LINE CLEAR AVOIDED
367	27-Feb-2020	GULBARGA	66	MUNIRABAD-MSD	HANASI_66	18:54	18:59	0:05	LINE FAULT
368	27-Feb-2020	HASSAN	110	HV2	BAIKAM	10:57	11:25	0:28	HAND TRIPPED
369	27-Feb-2020	HASSAN	110	HV2	BAIKAM	14:39	16:17	1:38	LINE CLEAR AVOIDED
370	27-Feb-2020	HASSAN	110	HV2	HOSNGD	9:20	15:40	6:20	LINE CLEAR AVOIDED
371	27-Feb-2020	HASSAN	110	HV2	KUNDAP	11:09	11:30	0:21	LINE CLEAR AVOIDED
372	27-Feb-2020	HASSAN	110	MRSSHM-MPM	MRSMSG_220	9:38	12:22	2:44	LINE CLEAR AVOIDED
373	27-Feb-2020	HASSAN	66	HV1	MAGGE_66	6:44	7:06	0:22	TRANSFORMER FAULT
374	27-Feb-2020	MYSORE	66	BANNUR-SFC	BANNUR_66	10:30	17:50	7:19	LINE CLEAR AVOIDED
375	27-Feb-2020	MYSORE	66	BANNUR-VAJAMANGALA	BANNUR_66	10:30	17:50	7:19	LINE CLEAR AVOIDED
376	27-Feb-2020	MYSORE	66	HV1	BOGADHI_66	9:55	16:14	6:18	LINE CLEAR AVOIDED
377	27-Feb-2020	MYSORE	66	KABBHALLY-CHAMARAJNAGARA	HARVEY_66 KABBHALLY_66	6:18	6:38	0:19	LINE FAULT
378	27-Feb-2020	MYSORE	66	NANJANAGUDU-BEGUR	SINDHUVALLI_66	0:39	0:49	0:10	LINE FAULT
379	27-Feb-2020	MYSORE	66	HV2	PANDAVAPURA_66	11:58	12:42	0:43	LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
380	27-Feb-2020	MYSORE	66	HV2	PANDAVAPURA_66	15:59	16:31	0:31	LINE CLEAR AVAILED
381	27-Feb-2020	MYSORE	66	SINDUVALLI-KADAKOLA	SINDHUVALLI_66	12:01	13:50	1:49	NFBC ISSUED
382	27-Feb-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	15:02	15:19	0:16	HAND TRIPPED
383	27-Feb-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	6:17	8:32	2:14	TRANSFORMER FAULT
384	27-Feb-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	7:21	7:26	0:05	TRANSFORMER FAULT
385	27-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:06	9:13	0:07	LINE FAULT
386	27-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:39	14:01	0:21	LINE FAULT
387	27-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:04	15:41	0:36	LINE FAULT
388	27-Feb-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	11:41	11:50	0:08	HAND TRIPPED
389	27-Feb-2020	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	16:35	17:01	0:26	HAND TRIPPED
390	27-Feb-2020	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	11:41	16:55	5:13	LINE CLEAR AVAILED
391	27-Feb-2020	TUMKUR	66	DYAVARANAHALLI-THALLAK	DYAVARANAHALLI_66	11:23	11:41	0:18	LINE CLEAR AVAILED
392	27-Feb-2020	TUMKUR	66	TR-2	HINDASGHATTA_66	16:55	17:53	0:58	LINE CLEAR AVAILED
393	27-Feb-2020	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	17:53	17:58	0:04	HAND TRIPPED
394	27-Feb-2020	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	18:00	18:05	0:05	HAND TRIPPED
395	27-Feb-2020	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:39	14:52	0:13	LINE FAULT
396	27-Feb-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	10:35	10:45	0:10	LINE FAULT
397	27-Feb-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	8:47	9:01	0:14	LINE FAULT
398	27-Feb-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	1:27	1:33	0:06	LINE FAULT
399	27-Feb-2020	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	22:08	22:14	0:05	MAIN SUPPLY FAILURE
400	27-Feb-2020	TUMKUR	66	TR-2	MADHUGIRI_66	10:18	18:52	8:33	LINE CLEAR AVAILED
401	27-Feb-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66,JAGALUR_66,PALLAGATTE_66	13:45	14:31	0:46	LINE CLEAR AVAILED
402	27-Feb-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66,JAGALUR_66,PALLAGATTE_66	15:03	15:21	0:17	LINE FAULT
403	27-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	4:01	4:18	0:17	LINE FAULT
404	27-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	13:00	13:05	0:04	LINE FAULT
405	27-Feb-2020	TUMKUR	66	TR-2	RAMPURA_66	10:10	14:25	4:14	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
406	27-Feb-2020	TUMKUR	66	TR-2	RAMPURA_66	15:21	16:52	1:31	LINE CLEAR AVAILED
407	27-Feb-2020	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	12:08	14:03	1:54	LINE CLEAR AVAILED
408	28-Feb-2020	BAGALKOT	110	110/11KV,HV2	ANANDNAGAR_110	11:10	11:58	0:48	LINE CLEAR AVAILED
409	28-Feb-2020	BAGALKOT	110	110/11KV,HV1	BILAGI_110	17:54	18:03	1:48	TRANSFORMER FAULT
410	28-Feb-2020	BAGALKOT	110	EILS(SOLAR)-DAMBAL	DAMBAL_110	0:00	9:01	2:48	LINE CLEAR AVAILED
411	28-Feb-2020	BAGALKOT	110	110/33KV,HV1&HV2	HANGAL_110,BELAGALPET_33,LAXMI PUR_33,BASAPUR_33,PALA_33,BOM MANAHALLI_33	9:10	9:22	3:48	TRANSFORMER FAULT
412	28-Feb-2020	BAGALKOT	110	110/33KV,HV1	JAMAKHANDI_110	15:03	17:38	4:48	LINE CLEAR AVAILED
413	28-Feb-2020	BAGALKOT	220	RAVIURJA1&2-ATHANI	ATHANI_220	9:17	23:59	5:48	LINE CLEAR AVAILED
414	28-Feb-2020	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	12:53	12:56	6:48	TRANSFORMER FAULT
415	28-Feb-2020	BAGALKOT	110	10/11KV, HV2	SAVANUR_110	16:32	17:00	7:48	TRANSFORMER FAULT
416	28-Feb-2020	BAGALKOT	110	GHATAPRABHA220-PG HUNSHYAL	PG HUSHYAL_110	12:51	13:12	8:48	LINE FAULT
417	28-Feb-2020	BAGALKOT	110	PG HUNSHYAL-MUDALGI	MUDALGI_110	13:12	13:15	9:48	LINE CLEAR AVAILED
418	28-Feb-2020	BAGALKOT	110	110/11KV, HV2	NIDAGUNDI_110	13:41	15:39	10:48	TRANSFORMER FAULT
419	28-Feb-2020	BAGALKOT	110	NARENDRA-BELUR1	BELUR_110	11:06	12:29	11:48	LINE CLEAR AVAILED
420	28-Feb-2020	BAGALKOT	110	NARENDRA-BELUR2	BELUR_110	12:53	15:04	12:48	LINE CLEAR AVAILED
421	28-Feb-2020	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220	13:07	13:47	13:48	TRANSFORMER FAULT
422	28-Feb-2020	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	13:07	13:50	14:48	LINE FAULT
423	28-Feb-2020	BAGALKOT	110	MAHALINGAPUR-RABKAVI	RABAKAVI_110	13:22	13:49	15:48	LINE CLEAR AVAILED
424	28-Feb-2020	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	13:23	13:54	16:48	LINE CLEAR AVAILED
425	28-Feb-2020	BAGALKOT	110	SIRSI-KUMTA1	KUMTA_110	18:26	23:59	17:48	LINE FAULT
426	28-Feb-2020	BENGALURU	66	ADUGODI - HSR 1 & 2	ADUGODI, BOSCH (EHT)	16:36	16:46	18:48	LOAD CHANGE OVER
427	28-Feb-2020	BENGALURU	66	HV2	NRS 66	12:06	12:10	19:48	LINE CLEAR AVAILED
428	28-Feb-2020	BENGALURU	66	HV2	ANEKAL	18:16	18:50	20:48	LINE CLEAR AVAILED
429	28-Feb-2020	BENGALURU	66	CHANDRAPPA CIRCLE - KUMBALGODU	CHANDRAPPA CIRCLE	0:34	0:40	21:48	LINE FAULT
430	28-Feb-2020	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	3:18	3:50	22:48	LINE FAULT
431	28-Feb-2020	BENGALURU	66	HV2	DOMMASANDRA	10:20	16:47	23:48	LINE CLEAR AVAILED
432	28-Feb-2020	BENGALURU	66	HV1	VIJAYAPURA	16:26	17:15	0:48	LINE CLEAR AVAILED
433	28-Feb-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	9:05	9:30	1:48	LOAD CURTAILMENT
434	28-Feb-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR	9:39	10:03	2:48	LOAD CURTAILMENT
435	28-Feb-2020	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR	15:16	15:41	3:48	LOAD CURTAILMENT
436	28-Feb-2020	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	12:55	13:00	4:48	LINE FAULT
437	28-Feb-2020	GULBARGA	220	HV1	MALLAT_220	11:12	23:59	5:48	LINE CLEAR AVAILED
438	28-Feb-2020	GULBARGA	220	HV1	SHAHAPUR_220	11:48	15:02	6:48	LINE CLEAR AVAILED
439	28-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110	0:43	0:50	7:48	LINE FAULT
440	28-Feb-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,ASKI_110,HUNSAGI_110	1:05	1:15	8:48	LINE FAULT
441	28-Feb-2020	GULBARGA	110	HV2	HATTI_110	9:05	9:12	9:48	TRANSFORMER FAULT
442	28-Feb-2020	GULBARGA	110	HUMNABAD220-HUMNABAD110	HUMNABAD_110	12:14	12:22	10:48	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
443	28-Feb-2020	GULBARGA	110	HV4	KUSTAGI_220	12:34	13:37	11:48	TRANSFORMER FAULT
444	28-Feb-2020	GULBARGA	110	HV1	KUSTAGI_220	12:34	13:38	12:48	TRANSFORMER FAULT
445	28-Feb-2020	GULBARGA	110	HV1	KURKUNTA_110	16:45	18:00	13:48	TRANSFORMER FAULT
446	28-Feb-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,ASKI_110,HUNSAGI_110	18:40	18:50	14:48	LINE FAULT
447	28-Feb-2020	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	10:10	15:41	15:48	LINE CLEAR AVAILED
448	28-Feb-2020	HASSAN	110	HV2	GURUVAYANAKERE_110	11:54	13:05	16:48	LINE CLEAR AVAILED
449	28-Feb-2020	HASSAN	110	HV2	HOSANGADI_110	8:55	18:14	17:48	LINE CLEAR AVAILED
450	28-Feb-2020	HASSAN	110	KADUR-YGTI	KADUR_220	10:15	16:44	18:48	LINE CLEAR AVAILED
451	28-Feb-2020	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	8:01	17:29	19:48	LINE CLEAR AVAILED
452	28-Feb-2020	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	8:01	17:30	20:48	LINE CLEAR AVAILED
453	28-Feb-2020	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	8:00	17:30	21:48	NFBC ISSUED
454	28-Feb-2020	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	8:00	17:30	22:48	NFBC ISSUED
455	28-Feb-2020	HASSAN	110	HV2	SAGARA_110	11:14	12:11	23:48	LINE CLEAR AVAILED
456	28-Feb-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	4:50	4:55	0:48	LINE FAULT
457	28-Feb-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	8:56	9:14	1:48	LINE FAULT
458	28-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	13:55	14:07	2:48	LINE FAULT
459	28-Feb-2020	HASSAN	66	SAKALE-HASSAN1	SAKLESHPURA_66	8:56	10:17	3:48	LINE FAULT
460	28-Feb-2020	HASSAN	66	SOMNHL-HN PURA	SOMANAHALLI_66	11:47	12:30	4:48	MAIN SUPPLY FAILURE
461	28-Feb-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	13:26	14:10	5:48	LINE FAULT
462	28-Feb-2020	MYSORE	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	16:16	16:48	6:48	LINE CLEAR AVAILED
463	28-Feb-2020	MYSORE	66	CR NAGARA-BADANGUPPE-2	BADANGUPPE_66	12:24	16:57	7:48	LINE CLEAR AVAILED
464	28-Feb-2020	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66	6:30	6:35	9:48	LINE FAULT
465	28-Feb-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	11:50	13:49	10:47	LINE CLEAR AVAILED
466	28-Feb-2020	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR_	ADAN SOLAR_IPP_66	18:01	18:12	11:48	LINE FAULT
467	28-Feb-2020	TUMKUR	110	TR-1	MAYASANDRA_110	16:26	17:19	12:48	LINE CLEAR AVAILED
468	28-Feb-2020	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	14:57	15:05	13:47	LINE CLEAR AVAILED
469	28-Feb-2020	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	7:22	7:53	14:48	LINE FAULT
470	28-Feb-2020	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	CHITRADURGA_66	7:22	7:54	15:48	LINE FAULT
471	28-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	7:36	8:04	16:47	LINE FAULT
472	28-Feb-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:04	9:17	17:48	LINE FAULT
473	28-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	9:04	9:12	18:48	LINE FAULT
474	28-Feb-2020	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:01	14:05	19:47	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
475	28-Feb-2020	TUMKUR	66	TR-1	HARAPPANAHALLI_66	15:11	15:33	20:48	TRANSFORMER FAULT
476	28-Feb-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	8:38	12:06	21:48	LINE CLEAR AVAILED
477	28-Feb-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:33	14:39	22:47	LINE FAULT
478	28-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	4:23	4:43	23:48	LINE FAULT
479	28-Feb-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	3:16	3:20	0:48	LINE CLEAR AVAILED
480	28-Feb-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	7:39	8:09	1:47	MAIN SUPPLY FAILURE
481	29-Feb-2020	BAGALKOT	220	AMBEWADI-PONDA 2	AMBEWADI_220	10:13	19:40	2:48	LINE CLEAR AVAILED
482	29-Feb-2020	BAGALKOT	220	AMBEWADI-NAGJHARI 1	AMBEWADI_220	10:41	19:23	3:48	LINE CLEAR AVAILED
483	29-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA 1	AMBEWADI_220	10:47	19:29	4:47	LINE CLEAR AVAILED
484	29-Feb-2020	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	11:07	19:29	5:48	LINE CLEAR AVAILED
485	29-Feb-2020	BAGALKOT	220	220/110KV,HV1&LV1,HV2&LV2	AMBEWADI_220	10:48	19:42	6:48	LINE CLEAR AVAILED
486	29-Feb-2020	BAGALKOT	110	110/11 KV HV 2	AMBEWADI_220	11:35	12:00	7:47	TRANSFORMER FAULT
487	29-Feb-2020	BAGALKOT	110	AMBEWADI-NK2	KAVALWAD_110	12:44	12:49	8:48	LINE CLEAR AVAILED
488	29-Feb-2020	BAGALKOT	110	110/11KV,HV2	BABALESHWAR+110	13:10	19:06	9:48	LINE CLEAR AVAILED
489	29-Feb-2020	BAGALKOT	110	110/11KV,HV 1	GOPPANAKOPPA_110	18:18	18:31	10:47	LINE CLEAR AVAILED
490	29-Feb-2020	BAGALKOT	110	110/11KV,HV 2	GOPPANAKOPPA_110	17:57	18:11	11:48	LINE CLEAR AVAILED
491	29-Feb-2020	BAGALKOT	110	110/11KV,HV 2	HIDIKAL_110	16:16	16:45	12:48	LINE CLEAR AVAILED
492	29-Feb-2020	BAGALKOT	110	SHIROLKOPPA-HIREKERUR	HIREKERUR_110	4:55	5:25	13:47	LINE FAULT
493	29-Feb-2020	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	4:07	13:39	14:48	LINE FAULT
494	29-Feb-2020	BAGALKOT	220	GUTTUR1-HAVERI	HAVERI_220	10:18	12:01	15:48	LINE CLEAR AVAILED
495	29-Feb-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	8:17	14:21	16:47	LINE CLEAR AVAILED
496	29-Feb-2020	BAGALKOT	110	RAIBAG 1&2-ITNAL	ITNAL_110	12:25	14:01	17:48	LINE CLEAR AVAILED
497	29-Feb-2020	BAGALKOT	110	110/33KV,HV 2	KIRUVATTI_110,YELLAPUR_33	12:15	13:14	18:48	LINE CLEAR AVAILED
498	29-Feb-2020	BAGALKOT	110	KAVALWADA-KADANKOPPA	KADANKOPPA_110	20:03	23:59	19:47	LINE CLEAR AVAILED
499	29-Feb-2020	BAGALKOT	110	110/11KV. HV1	VAJRAMATTI_110	12:05	15:07	20:48	LINE CLEAR AVAILED
500	29-Feb-2020	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	12:05	12:26	21:48	LINE CLEAR AVAILED
501	29-Feb-2020	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_110	12:04	15:05	22:47	LINE CLEAR AVAILED
502	29-Feb-2020	BAGALKOT	110	SOUDATTI220-NARAGUND(RAMDURGA1)	RAMDURGA_110	11:52	21:13	23:48	LINE CLEAR AVAILED
503	29-Feb-2020	BAGALKOT	220	HUBLI2-SIRSI	SIRSI_220	15:08	15:55	0:48	LINE CLEAR AVAILED
504	29-Feb-2020	BAGALKOT	220	SHARAVATHY2-SIRSI	SIRSI_220	15:08	15:54	1:47	LINE CLEAR AVAILED
505	29-Feb-2020	BAGALKOT	110	SIRSI-KUMATA2	SIRSI_110	10:01	13:02	2:48	LINE CLEAR AVAILED
506	29-Feb-2020	BAGALKOT	110	SIRSI-KUMATA1	SIRSI_110	0:00	12:58	3:47	LINE CLEAR AVAILED
507	29-Feb-2020	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	17:02	17:20	4:47	LOAD CHANGE OVER
508	29-Feb-2020	BENGALURU	66	HV2	AREHALLI	11:47	11:48	5:48	LINE CLEAR AVAILED
509	29-Feb-2020	BENGALURU	220	HV2	HSR 220	9:25	9:33	6:47	LINE CLEAR AVAILED
510	29-Feb-2020	BENGALURU	220	HV2	HSR 220	14:27	14:30	7:47	LINE CLEAR AVAILED
511	29-Feb-2020	BENGALURU	66	HV1	JAYADEVA	9:24	10:01	8:48	LINE CLEAR AVAILED
512	29-Feb-2020	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI	10:40	15:50	9:47	LINE CLEAR AVAILED
513	29-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	9:25	9:42	10:47	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
514	29-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	14:27	14:30	11:48	LINE CLEAR AVOIDED
515	29-Feb-2020	BENGALURU	66	HV1	BAGHMANE WORLD TECH PARK	11:14	11:22	12:47	LINE CLEAR AVOIDED
516	29-Feb-2020	BENGALURU	66	HV1	BANGARPETE	13:19	13:29	13:47	LINE CLEAR AVOIDED
517	29-Feb-2020	BENGALURU	66	HV1	D CROSS	13:28	15:05	14:48	LINE CLEAR AVOIDED
518	29-Feb-2020	BENGALURU	220	HV3	SRS PEENYA	13:25	13:55	15:47	TRANSFORMER FAULT
519	29-Feb-2020	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYADRAHALLI, TAVAREKERE, KODIGENAHALLI	13:25	14:54	16:47	LINE FAULT
520	29-Feb-2020	BENGALURU	66	HV2	C STATION	20:58	22:10	17:48	TRANSFORMER FAULT
521	29-Feb-2020	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	10:02	10:26	18:47	LINE FAULT
522	29-Feb-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	17:44	18:34	19:47	LINE FAULT
523	29-Feb-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	18:34	18:45	20:48	LINE FAULT
524	29-Feb-2020	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT, KADUBISANAHALLI, CESSNO PARK	18:58	19:43	21:47	LINE FAULT
525	29-Feb-2020	BENGALURU	66	HV1	JAYADEVA	5:08	7:53	22:47	TRANSFORMER FAULT
526	29-Feb-2020	BENGALURU	66	HV1	DODDABELAVANGALA	10:19	17:19	23:48	LINE CLEAR AVOIDED
527	29-Feb-2020	BENGALURU	66	HV2	DOMMASANDRA	10:12	12:19	0:47	LINE CLEAR AVOIDED
528	29-Feb-2020	BENGALURU	66	HV1	HOSOR RAMAPURA	13:38	14:11	1:47	LINE CLEAR AVOIDED
529	29-Feb-2020	BENGALURU	66	HV1	KEMBODI	15:40	15:51	2:48	LINE CLEAR AVOIDED
530	29-Feb-2020	BENGALURU	66	HV1	KONDASPURA	10:38	15:53	3:47	LINE CLEAR AVOIDED
531	29-Feb-2020	BENGALURU	66	HV2	KONDASPURA	10:38	15:53	4:47	LINE CLEAR AVOIDED
532	29-Feb-2020	BENGALURU	66	HV1	VTG DODDI	14:05	14:25	5:48	LINE CLEAR AVOIDED
533	29-Feb-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	13:52	14:08	7:47	LINE FAULT
534	29-Feb-2020	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	12:04	12:09	8:48	LINE FAULT
535	29-Feb-2020	GULBARGA	220	HV1	MALLAT_220	0:00	17:07	9:47	LINE CLEAR AVOIDED
536	29-Feb-2020	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	2:28	2:32	10:47	LINE FAULT
537	29-Feb-2020	GULBARGA	110	HV2	HATTI_110	9:21	9:29	11:48	TRANSFORMER FAULT
538	29-Feb-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110, ASKI_110, HUNSAGI_110	7:00	7:10	12:47	LINE FAULT
539	29-Feb-2020	GULBARGA	110	HV2	DEODURGA_110	9:39	9:56	13:47	TRANSFORMER FAULT
540	29-Feb-2020	GULBARGA	110	CHINCHOLI-RNWWIND_IPP	CHINCHOLI_110	19:28	21:12	14:48	LINE CLEAR AVOIDED
541	29-Feb-2020	GULBARGA	110	SHAHABAD-JEEWARGI	JEEWARGI_110	23:00	23:10	15:47	LINE FAULT
542	29-Feb-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KBJNL_IPP	20:07	20:14	16:47	LINE FAULT
543	29-Feb-2020	HASSAN	220	ARSK2-HSN	ARSK2	7:52	23:59	17:48	NFBC ISSUED
544	29-Feb-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	8:03	23:59	18:47	NFBC ISSUED
545	29-Feb-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	21:56	23:59	19:47	LINE FAULT
546	29-Feb-2020	HASSAN	220	VARAHI-SHMG3	varahi_gen	21:52	23:59	20:48	LINE FAULT
547	29-Feb-2020	HASSAN	110	HV4	MRSMSG_220	10:10	10:15	21:47	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
548	29-Feb-2020	HASSAN	110	HV4	MRSMSG_220	12:45	15:53	22:47	LINE CLEAR AVAILED
549	29-Feb-2020	HASSAN	110	HV3	MRSMSG_220	9:10	12:40	23:48	LINE CLEAR AVAILED
550	29-Feb-2020	HASSAN	110	HV2	MRSMSG_220	10:12	10:14	0:47	TRANSFORMER FAULT
551	29-Feb-2020	HASSAN	110	HV1	MRSMSG_220	10:12	10:16	1:47	TRANSFORMER FAULT
552	29-Feb-2020	HASSAN	110	MRSSHM-SS2	MRSMSG_220	12:05	14:44	2:48	LINE CLEAR AVAILED
553	29-Feb-2020	HASSAN	110	HV2	BAIKAMPADI_110	12:45	13:43	3:47	LINE CLEAR AVAILED
554	29-Feb-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	21:50	21:56	4:47	LINE FAULT
555	29-Feb-2020	HASSAN	110	HV2	HOSANGADI_110	8:01	11:55	5:48	LINE CLEAR AVAILED
556	29-Feb-2020	HASSAN	110	JOG110-AMBTR2	JOG_110	0:00	16:35	6:47	LINE CLEAR AVAILED
557	29-Feb-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	10:10	10:22	7:47	LINE CLEAR AVAILED
558	29-Feb-2020	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	10:10	10:22	8:48	LINE CLEAR AVAILED
559	29-Feb-2020	HASSAN	66	MRSSHM-OHOLUR	MRSMSG_220	6:19	6:27	9:47	LINE FAULT
560	29-Feb-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	6:38	9:58	10:47	LINE CLEAR AVAILED
561	29-Feb-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	10:10	10:22	11:48	LINE CLEAR AVAILED
562	29-Feb-2020	HASSAN	66	LV1	MRSMSG_220	10:12	10:16	12:47	TRANSFORMER FAULT
563	29-Feb-2020	HASSAN	66	LV2	MRSMSG_220	10:12	10:15	13:47	TRANSFORMER FAULT
564	29-Feb-2020	HASSAN	66	LV3	MRSMSG_220	9:10	12:40	14:48	LINE CLEAR AVAILED
565	29-Feb-2020	HASSAN	66	LV4	MRSMSG_220	10:12	10:15	15:47	TRANSFORMER FAULT
566	29-Feb-2020	HASSAN	66	LV4	MRSMSG_220	12:45	15:53	16:47	LINE CLEAR AVAILED
567	29-Feb-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	7:05	7:29	17:48	LINE FAULT
568	29-Feb-2020	HASSAN	66	HV1	DODDAKADANUR_66	7:05	7:24	18:47	MAIN SUPPLY FAILURE
569	29-Feb-2020	HASSAN	66	HV1	HANBALU_66	9:01	17:52	19:47	MAIN SUPPLY FAILURE
570	29-Feb-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	9:01	17:53	20:48	MAIN SUPPLY FAILURE
571	29-Feb-2020	HASSAN	66	HASSN66-HASSAN	HASSAN_66	10:22	10:25	21:47	MAIN SUPPLY FAILURE
572	29-Feb-2020	HASSAN	66	HASSN66-HASSAN	HASSAN_66	12:58	13:00	22:47	MAIN SUPPLY FAILURE
573	29-Feb-2020	HASSAN	66	HASSN66-HASSAN	HASSAN_66	13:58	16:20	23:48	MAIN SUPPLY FAILURE
574	29-Feb-2020	HASSAN	66	HASSN66-HASSAN	HASSAN_66	16:30	16:54	0:47	MAIN SUPPLY FAILURE
575	29-Feb-2020	HASSAN	66	HASSN66-HASSAN	HASSAN_66	17:05	17:45	1:47	MAIN SUPPLY FAILURE
576	29-Feb-2020	HASSAN	66	HASSN66-HASSAN	HASSAN_66	18:30	18:35	2:48	MAIN SUPPLY FAILURE
577	29-Feb-2020	HASSAN	66	HV1	KANDLI_66	3:00	3:10	3:47	TRANSFORMER FAULT
578	29-Feb-2020	HASSAN	66	HV1	MAGGE_66	16:23	16:34	4:47	TRANSFORMER FAULT
579	29-Feb-2020	HASSAN	66	HV1	MOSALEHOSAHALLI_66	12:02	13:06	5:47	NFBC ISSUED
580	29-Feb-2020	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	12:02	13:06	6:47	NFBC ISSUED
581	29-Feb-2020	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	9:00	17:52	7:47	LINE CLEAR AVAILED
582	29-Feb-2020	HASSAN	66	HV1	SHRAVANABELAGOLA_66	17:55	18:01	8:47	TRANSFORMER FAULT
583	29-Feb-2020	MYSORE	66	HV1	DUNDANAHALLI_66	11:25	13:29	9:47	LINE CLEAR AVAILED
584	29-Feb-2020	MYSORE	66	HV1	DUNDANAHALLI_66	14:05	14:07	10:47	LINE CLEAR AVAILED
585	29-Feb-2020	MYSORE	66	KHB STATION-HOOTAGALLY	KHBCOLONY_66	10:54	12:21	12:47	NFBC ISSUED
586	29-Feb-2020	MYSORE	66	KR PETE-AKKIHEBBAL1	AKKIHEBBAL_66	15:12	15:25	13:47	LINE FAULT
587	29-Feb-2020	MYSORE	66	KR PETE-AKKIHEBBAL2	AKKIHEBBAL_66	15:12	15:25	14:47	LINE FAULT
588	29-Feb-2020	MYSORE	66	MADHUVANALLI-MAMBALLI	MAMBALLI_66	17:44	17:49	15:47	LINE FAULT
589	29-Feb-2020	MYSORE	66	HV1	PANDAVAPURA_66	12:19	12:54	17:47	LINE CLEAR AVAILED
590	29-Feb-2020	MYSORE	66	HV1	SHIVALLY_66	9:45	13:19	18:47	LINE CLEAR AVAILED
591	29-Feb-2020	MYSORE	66	HV2	SHIVALLY_66	9:47	11:14	19:47	LINE CLEAR AVAILED
592	29-Feb-2020	MYSORE	66	SHIVALLI-TUBINKERE	SHIVALLY_66	9:47	11:13	20:47	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
593	29-Feb-2020	MYSORE	66	TUBINKERE-NAGAMANGLA1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	16:39	16:47	21:47	LINE FAULT
594	29-Feb-2020	MYSORE	66	TUBINKERE-NAGAMANGLA1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	17:04	20:41	22:47	LINE FAULT
595	29-Feb-2020	TUMKUR	110	TR-1	TURUVEKERE_110	0:24	0:34	23:47	TRANSFORMER FAULT
596	29-Feb-2020	TUMKUR	110	TR-1	AMMASANDRA_110	15:20	15:56	0:47	LINE CLEAR AVAILED
597	29-Feb-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	15:58	16:07	1:47	TRANSFORMER FAULT
598	29-Feb-2020	TUMKUR	66	BALENAHALLI-CHALKERE	BALENAHALLI_66	6:39	16:56	2:47	LINE CLEAR AVAILED
599	29-Feb-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	NANDIGUDI_66	13:44	13:57	3:47	LINE FAULT
600	29-Feb-2020	TUMKUR	66	TR-2	BELLAVI_66	11:08	13:12	4:47	LINE CLEAR AVAILED
601	29-Feb-2020	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:08	12:30	5:47	LINE CLEAR AVAILED
602	29-Feb-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	15:26	15:35	6:47	LINE CLEAR AVAILED
603	29-Feb-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	18:43	18:50	7:47	LINE CLEAR AVAILED
604	29-Feb-2020	TUMKUR	66	TR--1	DEVARAHALLI_66	15:26	15:35	8:47	LINE CLEAR AVAILED
605	29-Feb-2020	TUMKUR	66	TR--1	DEVARAHALLI_66	18:43	18:50	9:47	LINE CLEAR AVAILED
606	29-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:22	9:54	10:47	LINE FAULT
607	29-Feb-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:36	14:44	11:47	LINE FAULT
608	29-Feb-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:06	22:15	12:47	LINE FAULT
609	29-Feb-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	8:08	9:09	13:47	MAIN SUPPLY FAILURE
610	29-Feb-2020	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:43	18:51	14:47	LINE CLEAR AVAILED
611	29-Feb-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	17:29	17:44	15:47	LINE CLEAR AVAILED
612	29-Feb-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	18:03	18:11	16:47	LINE CLEAR AVAILED
613	29-Feb-2020	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	14:14	15:06	17:47	LINE CLEAR AVAILED
614	29-Feb-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:07	0:14	18:47	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
615	29-Feb-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:24	13:56	19:47	LINE FAULT
616	29-Feb-2020	TUMKUR	66	NEELAGUNDA 220kV-HARAPPANAHALLI 1	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	6:23	6:35	20:47	LINE FAULT
617	29-Feb-2020	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	6:23	6:35	21:47	LINE FAULT
618	29-Feb-2020	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	7:22	8:34	22:47	LINE CLEAR AVAILED
619	29-Feb-2020	TUMKUR	66	NEELAGUNDA 220kV-PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHANGIDURGA_66, JAGALUR_66, PALLAGATTE_66	20:54	21:04	23:47	LINE FAULT
620	29-Feb-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66, HARAPPANAHALLI_66, HALUVAGALU_66, TELAGI_66	7:18	8:29	0:47	LINE CLEAR AVAILED
621	29-Feb-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66, HARAPPANAHALLI_66, HALUVAGALU_66, TELAGI_66	17:31	18:21	1:47	LINE CLEAR AVAILED
622	29-Feb-2020	TUMKUR	66	TR-1	SHYLAPURA_66	11:42	12:36	2:47	MAIN SUPPLY FAILURE
623	29-Feb-2020	TUMKUR	66	TR-2	SHYLAPURA_66	11:42	12:36	3:47	MAIN SUPPLY FAILURE
624	29-Feb-2020	TUMKUR	66	SHYLAPURA-PAVAGADA 220KV	SHYLAPURA_66	11:42	12:36	4:47	MAIN SUPPLY FAILURE
625	29-Feb-2020	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	6:38	11:39	5:47	LINE FAULT
626	1-Mar-2020	BAGALKOT	110	110/11 KV HV 2	AMBEWADI_220	1:26	1:35	6:47	TRANSFORMER FAULT
627	1-Mar-2020	BAGALKOT	110	BGALKOT 220-BAGALKOT 2	BAGALKOT_110	6:50	7:07	7:47	LINE FAULT
628	1-Mar-2020	BAGALKOT	110	110/11KV,HV 1	BAGALKOT_110	8:25	9:51	8:47	LINE CLEAR AVAILED
629	1-Mar-2020	BAGALKOT	110	DAMBAL-GADAG 2	DAMBAL_110	20:23	23:59	9:47	LINE FAULT
630	1-Mar-2020	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	16:51	17:01	10:47	LINE FAULT
631	1-Mar-2020	BAGALKOT	110	110/11KV,HV 1	HANGAL_110, BOMMANALLI_33, BELA GALPET_33	13:32	13:40	11:47	TRANSFORMER FAULT
632	1-Mar-2020	BAGALKOT	110	110/11KV,HV 2	HIDIKAL_110	12:05	12:08	12:47	TRANSFORMER FAULT
633	1-Mar-2020	BAGALKOT	110	110/11KV,HV 2	HIDIKAL_110	12:09	12:38	13:47	TRANSFORMER FAULT
634	1-Mar-2020	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	13:30	14:14	14:47	LINE CLEAR AVAILED
635	1-Mar-2020	BAGALKOT	110	ISLAMPUR-HIDIKAL DAM	HIDIKAL DAM_110	14:14	23:59	15:47	LINE CLEAR AVAILED
636	1-Mar-2020	BAGALKOT	110	SHIROLKOPPA-HIREKERUR	HIREKERUR_110	15:01	16:04	16:47	LINE CLEAR AVAILED
637	1-Mar-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	6:55	17:17	17:47	LINE CLEAR AVAILED
638	1-Mar-2020	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	21:31	23:59	18:47	LINE CLEAR AVAILED
639	1-Mar-2020	BAGALKOT	110	GAMESH-KULIGOD	KULIGOD_110	10:20	10:22	19:47	LINE CLEAR AVAILED
640	1-Mar-2020	BAGALKOT	110	MUDALAGI-KULIGOD	KULIGOD_110	9:40	10:15	20:47	LINE FAULT
641	1-Mar-2020	BAGALKOT	110	110/33KV,HV 4	LAKKAMANAHALLI_110, ALNAVAR_33	5:35	5:44	21:47	TRANSFORMER FAULT
642	1-Mar-2020	BAGALKOT	110	110/33KV,HV 4	LAKKAMANAHALLI_110, ALNAVAR_33	20:00	20:11	22:47	TRANSFORMER FAULT
643	1-Mar-2020	BAGALKOT	110	110/11KV,HV 2	MALGHAN(B)_110	5:03	5:05	23:47	TRANSFORMER FAULT
644	1-Mar-2020	BAGALKOT	110	110/11KV,HV 2	MALGHAN(B)_110	9:25	9:27	0:48	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
645	1-Mar-2020	BAGALKOT	110	110/11KV,HV 2	MALGHAN(B)_110	11:01	11:03	1:48	TRANSFORMER FAULT
646	1-Mar-2020	BAGALKOT	110	110/11KV,HV 2	MALGHAN(B)_110	22:06	22:09	2:47	TRANSFORMER FAULT
647	1-Mar-2020	BAGALKOT	110	UDYAMBAG-MACHE	MACHE_110	11:33	12:07	3:48	LINE CLEAR AVAILED
648	1-Mar-2020	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YADWAD_33, VANTAGOD_33	7:19	7:33	4:48	TRANSFORMER FAULT
649	1-Mar-2020	BAGALKOT	220	HUBLI-SIRSI1&2	HUBLI_220	0:00	21:13	5:47	LINE CLEAR AVAILED
650	1-Mar-2020	BAGALKOT	220	SHARAVATHY1&2-SIRSI	SIRSI_220	14:31	19:06	6:48	LINE CLEAR AVAILED
651	1-Mar-2020	BAGALKOT	110	ESALE 1-SIRSI	SIRSI_110	14:06	14:27	7:48	LINE CLEAR AVAILED
652	1-Mar-2020	BAGALKOT	110	RANEENNUR220-HONNATTI	HONNATTI_110	7:44	8:01	8:47	LINE CLEAR AVAILED
653	1-Mar-2020	BAGALKOT	110	RANEENNUR220-TUMMINAKATTI	TUMMINAKATTI_110	9:09	9:25	9:48	LINE CLEAR AVAILED
654	1-Mar-2020	BAGALKOT	220	SHIRALKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	0:00	7:34	10:48	LINE CLEAR AVAILED
655	1-Mar-2020	BAGALKOT	220	SHIRALKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	9:21	15:13	11:47	LINE CLEAR AVAILED
656	1-Mar-2020	BAGALKOT	220	SHIRALKOPPA(BALLIGAVI)- RANEENNUR	RANEENNUR_220	15:46	23:59	12:48	LINE CLEAR AVAILED
657	1-Mar-2020	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	0:00	14:57	13:48	LINE CLEAR AVAILED
658	1-Mar-2020	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	12:51	14:01	14:47	TRANSFORMER FAULT
659	1-Mar-2020	BAGALKOT	110	110/11KV,HV2	NIDAGUNDI_110	14:01	14:13	15:48	LINE CLEAR AVAILED
660	1-Mar-2020	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	5:02	5:03	16:48	LINE CLEAR AVAILED
661	1-Mar-2020	BAGALKOT	110	110/33KV,HV1	YARAGATTI_110	19:15	19:45	17:47	TRANSFORMER FAULT
662	1-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	18:17	18:53	18:48	LINE FAULT
663	1-Mar-2020	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	18:17	22:25	19:48	MAIN SUPPLY FAILURE
664	1-Mar-2020	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI 66, JIGANI LINK ROAD	22:25	22:30	20:47	LOAD CHANGE OVER
665	1-Mar-2020	BENGALURU	66	HV1	BAIRAKURU	21:02	21:52	21:48	TRANSFORMER FAULT
666	1-Mar-2020	BENGALURU	66	HV1	BAIRAKURU	21:57	22:14	22:48	TRANSFORMER FAULT
667	1-Mar-2020	BENGALURU	66	HV1	CB PURA I/A	17:20	17:37	23:47	TRANSFORMER FAULT
668	1-Mar-2020	BENGALURU	66	HV2	HONNIGANAHALLI	14:08	18:13	0:48	TRANSFORMER FAULT
669	1-Mar-2020	BENGALURU	66	HV2	HONNIGANAHALLI	18:13	18:50	1:48	TRANSFORMER FAULT
670	1-Mar-2020	BENGALURU	66	HV1	THAYALUR	18:41	18:49	2:47	TRANSFORMER FAULT
671	1-Mar-2020	BENGALURU	66	YELAHANKA 220 - LINE4	SAHAKARINAGAR, RAILWAYS (EHT)	7:03	8:38	4:48	LINE FAULT
672	1-Mar-2020	BENGALURU	66	SIDLAGATTA - CHINTAMANI 220	SIDLAGATTA, MELUR	8:52	9:10	5:47	LINE CLEAR AVAILED
673	1-Mar-2020	BENGALURU	66	AMAR JYOTHI - HAL 220	AMAR JYOTHI,LEELA VENTURE	9:50	10:12	6:48	LOAD CHANGE OVER
674	1-Mar-2020	BENGALURU	66	AMAR JYOTHI - KORAMANGALA	AMAR JYOTHI,LEELA VENTURE	18:05	18:10	7:48	LOAD CHANGE OVER
675	1-Mar-2020	BENGALURU	220	A STATION 220 - NRS 220	A STATION 220	6:45	16:57	8:47	LINE CLEAR AVAILED
676	1-Mar-2020	BENGALURU	66	A STATION 66 - NRS 220	A STATION 66	7:49	9:35	9:48	LINE CLEAR AVAILED
677	1-Mar-2020	BENGALURU	66	EDC 220 - B STATION	B STATION	9:52	16:02	10:48	LINE CLEAR AVAILED
678	1-Mar-2020	BENGALURU	66	ELITE PROMENEDE - ARMY WELFARE	ELITE PROMENEDE	19:55	20:04	11:47	LOAD CHANGE OVER
679	1-Mar-2020	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	22:50	22:54	12:48	LOAD CHANGE OVER
680	1-Mar-2020	BENGALURU	220	HAL 220 - HOODY 1	HAL 220	10:00	17:52	13:48	LINE CLEAR AVAILED
681	1-Mar-2020	BENGALURU	220	HAL 220 - HOODY 2	HAL 220	10:00	17:52	14:47	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
682	1-Mar-2020	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	10:00	18:02	15:48	LINE CLEAR AVAILED
683	1-Mar-2020	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	10:00	18:02	16:48	LINE CLEAR AVAILED
684	1-Mar-2020	BENGALURU	66	HAL 220 - HAL (EHT)	HAL (EHT)	10:00	18:02	17:47	LINE CLEAR AVAILED
685	1-Mar-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	10:00	18:02	18:48	LINE CLEAR AVAILED
686	1-Mar-2020	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:30	10:35	19:48	LOAD CHANGE OVER
687	1-Mar-2020	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	19:44	19:47	20:47	LOAD CHANGE OVER
688	1-Mar-2020	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	4:16	5:37	21:48	LINE FAULT
689	1-Mar-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	20:00	20:12	22:48	LOAD CHANGE OVER
690	1-Mar-2020	BENGALURU	66	RBI - ELITE PROMENEDE	RBI	22:50	23:00	23:47	LOAD CHANGE OVER
691	1-Mar-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	20:01	20:10	0:48	LOAD CHANGE OVER
692	1-Mar-2020	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	23:12	23:20	1:48	LOAD CHANGE OVER
693	1-Mar-2020	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	T K HALLI 220	13:58	17:48	2:47	MAIN SUPPLY FAILURE
694	1-Mar-2020	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	13:58	17:48	3:48	MAIN SUPPLY FAILURE
695	1-Mar-2020	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	T K HALLI 220	13:58	17:48	4:48	MAIN SUPPLY FAILURE
696	1-Mar-2020	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	13:58	17:48	5:47	MAIN SUPPLY FAILURE
697	1-Mar-2020	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR	13:58	17:48	6:48	MAIN SUPPLY FAILURE
698	1-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	13:58	17:48	7:48	MAIN SUPPLY FAILURE
699	1-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	13:58	17:48	8:47	MAIN SUPPLY FAILURE
700	1-Mar-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	13:58	17:48	9:48	MAIN SUPPLY FAILURE
701	1-Mar-2020	GULBARGA	220	BMMISPAT_LINGAPUR	LINGAPUR_220	21:55	23:59	10:48	LINE FAULT
702	1-Mar-2020	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,M ANTHAL_110	21:44	22:05	11:47	LINE FAULT
703	1-Mar-2020	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,M ANTHAL_110	22:18	23:59	12:48	LINE CLEAR AVAILED
704	1-Mar-2020	GULBARGA	110	HUMNABAD-ALAND	ALAND_110	10:55	12:15	13:48	NFBC ISSUED
705	1-Mar-2020	GULBARGA	110	HUMNABAD-ALAND	ALAND_110	14:40	16:30	14:47	NFBC ISSUED
706	1-Mar-2020	GULBARGA	110	HV2	DEODURGA_110	10:00	10:10	15:48	TRANSFORMER FAULT
707	1-Mar-2020	GULBARGA	110	HV2	HATTI_110	23:11	23:22	16:48	MAIN SUPPLY FAILURE
708	1-Mar-2020	GULBARGA	110	HV2	HATTI_110	23:40	23:45	17:47	TRANSFORMER FAULT
709	1-Mar-2020	GULBARGA	110	HV3	HAGARIBOMMANAHALLI_110	14:10	15:45	18:48	LINE CLEAR AVAILED
710	1-Mar-2020	GULBARGA	110	HV2	HAGARIBOMMANAHALLI_110		21:50	19:48	TRANSFORMER FAULT
711	1-Mar-2020	GULBARGA	110	KUSHTAGI-INR_SOLAR_IPP	KUSHTAGI_220	18:35	23:59	20:47	LINE CLEAR AVAILED
712	1-Mar-2020	GULBARGA	220	HV1	KUSHTAGI_220	21:09	21:45	21:48	TRANSFORMER FAULT
713	1-Mar-2020	GULBARGA	220	KUSHTAGI-LINGSUGUR	KUSHTAGI_220	23:09	23:43	22:48	LINE FAULT
714	1-Mar-2020	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	21:09	21:50	23:47	LINE FAULT
715	1-Mar-2020	GULBARGA	110	HV1	LADHA_110	15:30	16:20	0:48	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
716	1-Mar-2020	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	21:57	22:23	1:48	LINE FAULT
717	1-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110	5:53	6:04	2:47	LINE FAULT
718	1-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110	6:27	6:34	3:48	LINE FAULT
719	1-Mar-2020	GULBARGA	110	TELKKALKOTE-ABMN_SLR	TEKKALKOTE_110	18:46	20:14	4:48	LINE CLEAR AVAILED
720	1-Mar-2020	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110,NSSK SUGAR FACTORY_IPP	6:10	6:15	5:47	LINE FAULT
721	1-Mar-2020	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	6:10	6:25	6:48	LINE FAULT
722	1-Mar-2020	GULBARGA	400	BTPS-HIRIYUR1	HIRIYUR_400	13:37	23:59	7:48	LINE FAULT
723	1-Mar-2020	GULBARGA	110	SINDHANOOR220-SINDHANOOR	SINDHANOOR_110	12:24	12:44	8:47	LINE FAULT
724	1-Mar-2020	GULBARGA	110	SINDHANOOR220-SUZLON1	SINDHANOOR_220	16:21	18:13	9:48	LINE FAULT
725	1-Mar-2020	GULBARGA	66	MORAGERE-TBHALLI	TAMBRAHALLI_66,HAMPASAGAR_66	21:40	23:59	10:48	LINE FAULT
726	1-Mar-2020	GULBARGA	66	HV1	MORAGERE_66	21:45	22:05	11:47	TRANSFORMER FAULT
727	1-Mar-2020	GULBARGA	110	HUMNABAD220-HUMNABAD2	ALAND_110,KADAGANCHI_110	8:30	16:37	12:48	LINE FAULT
728	1-Mar-2020	HASSAN	400	HASSAN4-NLM400	HASSAN_400	13:57	15:55	13:48	LINE FAULT
729	1-Mar-2020	HASSAN	400	HASSAN4-NLM400	HASSAN_400	16:02	16:11	14:47	LINE FAULT
730	1-Mar-2020	HASSAN	400	HASSAN4-TLGP400	HASSAN_400	14:08	15:37	15:48	LINE FAULT
731	1-Mar-2020	HASSAN	400	HASSAN4-TLGP400	HASSAN_400	15:37	17:43	16:48	LINE FAULT
732	1-Mar-2020	HASSAN	400	HASSAN4-UPCL1	HASSAN_400	14:08	18:37	17:47	LINE FAULT
733	1-Mar-2020	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	13:57	15:37	18:48	LINE FAULT
734	1-Mar-2020	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	15:37	17:43	19:48	LINE FAULT
735	1-Mar-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:57	14:47	20:47	LINE FAULT
736	1-Mar-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	14:08	18:37	21:48	LINE FAULT
737	1-Mar-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	14:08	16:02	22:48	LINE FAULT
738	1-Mar-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:03	17:26	23:47	LINE FAULT
739	1-Mar-2020	HASSAN	220	HASSAN4-C R PATNA	HASSAN_400	14:02	16:29	0:48	LINE CLEAR AVAILED
740	1-Mar-2020	HASSAN	220	HASSAN4-CHMLR	HASSAN_400	14:08	17:48	1:48	LINE CLEAR AVAILED
741	1-Mar-2020	HASSAN	220	HASSAN4-GOPALPURA	HASSAN_400	14:08	17:34	2:47	LINE CLEAR AVAILED
742	1-Mar-2020	HASSAN	220	LV1	HASSAN_400	14:08	17:00	3:48	LINE CLEAR AVAILED
743	1-Mar-2020	HASSAN	220	LV2	HASSAN_400	14:08	15:51	4:48	LINE CLEAR AVAILED
744	1-Mar-2020	HASSAN	220	HASSAN4-SHIMOGA1	HASSAN_400	14:08	15:47	5:47	LINE CLEAR AVAILED
745	1-Mar-2020	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	13:57	15:26	6:48	LINE CLEAR AVAILED
746	1-Mar-2020	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	13:57	15:28	7:48	LINE CLEAR AVAILED
747	1-Mar-2020	HASSAN	220	TALAGU-STRP1	TALAGUPPA_400	13:57	15:29	8:47	LINE CLEAR AVAILED
748	1-Mar-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:57	16:28	9:48	LINE CLEAR AVAILED
749	1-Mar-2020	HASSAN	220	UPCL-KEMAR1	upcl_gen	14:08	15:50	10:47	LINE FAULT
750	1-Mar-2020	HASSAN	220	UPCL-KEMAR2	upcl_gen	14:11	16:20	11:47	LINE CLEAR AVAILED
751	1-Mar-2020	HASSAN	220	UPCL-STNAUX1	upcl_gen	14:08	15:51	12:48	LINE CLEAR AVAILED
752	1-Mar-2020	HASSAN	220	UPCL-STNAUX2	upcl_gen	14:08	15:51	13:47	LINE CLEAR AVAILED
753	1-Mar-2020	HASSAN	220	HASSN22-NITTUR	HASSN_220	14:02	17:48	14:47	MAIN SUPPLY FAILURE
754	1-Mar-2020	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	13:57	15:07	15:48	MAIN SUPPLY FAILURE
755	1-Mar-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	13:57	14:31	16:47	LINE FAULT
756	1-Mar-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:00	15:03	17:47	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
757	1-Mar-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:00	14:13	18:48	LINE CLEAR AVAILED
758	1-Mar-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:21	14:33	19:47	LINE FAULT
759	1-Mar-2020	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	14:34	16:26	20:47	LINE FAULT
760	1-Mar-2020	HASSAN	220	KAVOOR-KULSHK1	KAVOOR_220	14:00	16:25	21:48	MAIN SUPPLY FAILURE
761	1-Mar-2020	HASSAN	220	KAVOOR-KULSHK2	KAVOOR_220	14:00	16:25	22:47	MAIN SUPPLY FAILURE
762	1-Mar-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	14:00	16:10	23:47	MAIN SUPPLY FAILURE
763	1-Mar-2020	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	14:00	16:37	0:48	MAIN SUPPLY FAILURE
764	1-Mar-2020	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	14:00	16:37	1:47	MAIN SUPPLY FAILURE
765	1-Mar-2020	HASSAN	220	HV1	KEMAR_220	13:57	15:59	2:47	MAIN SUPPLY FAILURE
766	1-Mar-2020	HASSAN	220	HV2	KEMAR_220	13:57	15:40	3:48	MAIN SUPPLY FAILURE
767	1-Mar-2020	HASSAN	220	HV2	KEMAR_220	15:40	17:04	4:47	TRANSFORMER FAULT
768	1-Mar-2020	HASSAN	220	HV3	KEMAR_220	13:57	15:36	5:47	MAIN SUPPLY FAILURE
769	1-Mar-2020	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	13:57	16:30	6:48	MAIN SUPPLY FAILURE
770	1-Mar-2020	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	13:57	16:31	7:47	MAIN SUPPLY FAILURE
771	1-Mar-2020	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	13:57	15:47	8:47	MAIN SUPPLY FAILURE
772	1-Mar-2020	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	13:57	15:47	9:48	MAIN SUPPLY FAILURE
773	1-Mar-2020	HASSAN	220	KEMAR-UPCL1	KEMAR_220	13:57	15:49	10:47	MAIN SUPPLY FAILURE
774	1-Mar-2020	HASSAN	220	KEMAR-UPCL2	KEMAR_220	13:57	16:19	11:47	MAIN SUPPLY FAILURE
775	1-Mar-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	13:57	16:36	12:48	MAIN SUPPLY FAILURE
776	1-Mar-2020	HASSAN	220	KEMAR-Varahi2	KEMAR_220	13:57	16:11	13:47	MAIN SUPPLY FAILURE
777	1-Mar-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	13:57	15:35	14:47	MAIN SUPPLY FAILURE
778	1-Mar-2020	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	13:57	16:38	15:48	MAIN SUPPLY FAILURE
779	1-Mar-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	13:57	16:37	16:47	MAIN SUPPLY FAILURE
780	1-Mar-2020	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	13:57	16:31	17:47	MAIN SUPPLY FAILURE
781	1-Mar-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	13:57	16:31	18:48	MAIN SUPPLY FAILURE
782	1-Mar-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	13:57	14:29	19:47	LINE FAULT
783	1-Mar-2020	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:41	17:56	20:47	LINE FAULT
784	1-Mar-2020	HASSAN	220	MRSSHM-DAVANGERE	MRSMSG_220	13:58	15:01	21:48	MAIN SUPPLY FAILURE
785	1-Mar-2020	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	13:58	14:47	22:47	MAIN SUPPLY FAILURE
786	1-Mar-2020	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:58	15:01	23:47	MAIN SUPPLY FAILURE
787	1-Mar-2020	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	17:37	23:59	0:48	LINE CLEAR AVAILED
788	1-Mar-2020	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	13:58	14:47	1:47	MAIN SUPPLY FAILURE
789	1-Mar-2020	HASSAN	220	HV1	MRSMSG_220	13:58	14:43	2:47	MAIN SUPPLY FAILURE
790	1-Mar-2020	HASSAN	220	HV2	MRSMSG_220	13:58	14:46	3:48	MAIN SUPPLY FAILURE
791	1-Mar-2020	HASSAN	220	HV3	MRSMSG_220	13:58	15:04	4:47	MAIN SUPPLY FAILURE
792	1-Mar-2020	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	13:58	14:47	5:47	MAIN SUPPLY FAILURE
793	1-Mar-2020	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	13:58	15:15	6:48	MAIN SUPPLY FAILURE
794	1-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:58	15:02	7:47	MAIN SUPPLY FAILURE
795	1-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:58	14:37	8:47	MAIN SUPPLY FAILURE
796	1-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	13:58	15:13	9:48	MAIN SUPPLY FAILURE
797	1-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	13:58	15:14	10:47	MAIN SUPPLY FAILURE
798	1-Mar-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	13:58	15:14	11:47	MAIN SUPPLY FAILURE
799	1-Mar-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	13:58	14:30	12:48	MAIN SUPPLY FAILURE
800	1-Mar-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	0:00	12:03	13:47	LINE FAULT
801	1-Mar-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	13:58	16:01	14:47	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
802	1-Mar-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	0:00	7:33	15:48	LINE FAULT
803	1-Mar-2020	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	13:57	15:47	16:47	MAIN SUPPLY FAILURE
804	1-Mar-2020	HASSAN	220	SHRAVTY-SHIMOGA 2	sharavathy_gen	13:57	15:20	17:47	MAIN SUPPLY FAILURE
805	1-Mar-2020	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	13:57	15:14	18:48	MAIN SUPPLY FAILURE
806	1-Mar-2020	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	13:57	15:44	19:47	MAIN SUPPLY FAILURE
807	1-Mar-2020	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	13:57	19:05	20:47	MAIN SUPPLY FAILURE
808	1-Mar-2020	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	13:57	19:05	21:48	MAIN SUPPLY FAILURE
809	1-Mar-2020	HASSAN	220	SHRAVTY-TALAGUPPA 3	sharavathy_gen	13:57	15:29	22:47	MAIN SUPPLY FAILURE
810	1-Mar-2020	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	13:57	15:28	23:47	MAIN SUPPLY FAILURE
811	1-Mar-2020	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	13:57	15:27	0:48	MAIN SUPPLY FAILURE
812	1-Mar-2020	HASSAN	220	VARAH1-KEMAR1	varahi_gen	13:57	16:36	1:47	MAIN SUPPLY FAILURE
813	1-Mar-2020	HASSAN	220	VARAH1-KEMAR2	varahi_gen	13:57	16:14	2:47	MAIN SUPPLY FAILURE
814	1-Mar-2020	HASSAN	220	VARAH1-KEMAR3	varahi_gen	13:57	15:35	3:48	MAIN SUPPLY FAILURE
815	1-Mar-2020	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	13:57	16:05	4:47	MAIN SUPPLY FAILURE
816	1-Mar-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	23:57	23:59	5:47	LINE FAULT
817	1-Mar-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	0:00	12:03	6:48	LINE FAULT
818	1-Mar-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	0:00	7:29	7:47	LINE FAULT
819	1-Mar-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:57	15:10	8:47	MAIN SUPPLY FAILURE
820	1-Mar-2020	HASSAN	220	HV1	GOPALAPURA_220	14:08	17:42	9:48	MAIN SUPPLY FAILURE
821	1-Mar-2020	HASSAN	220	HV2	GOPALAPURA_220	14:08	17:44	10:47	MAIN SUPPLY FAILURE
822	1-Mar-2020	HASSAN	220	SHRLKP-SHARAVATHI	SHIRALKOPPA_220	13:56	15:44	11:47	MAIN SUPPLY FAILURE
823	1-Mar-2020	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	13:57	15:19	12:48	MAIN SUPPLY FAILURE
824	1-Mar-2020	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	13:57	15:25	13:47	MAIN SUPPLY FAILURE
825	1-Mar-2020	HASSAN	110	HV1	ARASIKERE_220	13:57	15:11	14:47	MAIN SUPPLY FAILURE
826	1-Mar-2020	HASSAN	110	KADUR-AJAMPURA	KADUR_220	13:57	15:24	15:48	MAIN SUPPLY FAILURE
827	1-Mar-2020	HASSAN	110	HV2	KADUR_220	13:57	15:24	16:47	MAIN SUPPLY FAILURE
828	1-Mar-2020	HASSAN	110	KADUR-NERELEKERE	KADUR_220	13:57	15:24	17:47	MAIN SUPPLY FAILURE
829	1-Mar-2020	HASSAN	110	KADUR-NGNHL	KADUR_220	13:57	15:24	18:48	MAIN SUPPLY FAILURE
830	1-Mar-2020	HASSAN	110	KADUR-TNGL	KADUR_220	13:57	15:24	19:47	MAIN SUPPLY FAILURE
831	1-Mar-2020	HASSAN	110	KADUR-YGTI	KADUR_220	13:57	15:24	20:47	MAIN SUPPLY FAILURE
832	1-Mar-2020	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	14:00	16:25	21:48	MAIN SUPPLY FAILURE
833	1-Mar-2020	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	14:00	16:25	22:47	MAIN SUPPLY FAILURE
834	1-Mar-2020	HASSAN	110	HV1	KAVOOR_220	14:00	16:10	23:47	MAIN SUPPLY FAILURE
835	1-Mar-2020	HASSAN	110	HV2	KAVOOR_220	14:00	17:10	0:48	MAIN SUPPLY FAILURE
836	1-Mar-2020	HASSAN	110	HV3	KAVOOR_220	14:00	18:10	1:47	MAIN SUPPLY FAILURE
837	1-Mar-2020	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	13:57	16:44	2:47	MAIN SUPPLY FAILURE
838	1-Mar-2020	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	13:57	16:44	3:48	MAIN SUPPLY FAILURE
839	1-Mar-2020	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	13:57	15:42	4:47	MAIN SUPPLY FAILURE
840	1-Mar-2020	HASSAN	110	HV1	KEMAR_220	13:57	15:43	5:47	MAIN SUPPLY FAILURE
841	1-Mar-2020	HASSAN	110	HV2	KEMAR_220	15:40	17:04	6:48	TRANSFORMER FAULT
842	1-Mar-2020	HASSAN	110	HV2	KEMAR_220	13:57	15:40	7:47	MAIN SUPPLY FAILURE
843	1-Mar-2020	HASSAN	110	LV1	KEMAR_220	13:57	15:59	8:47	MAIN SUPPLY FAILURE
844	1-Mar-2020	HASSAN	110	LV2	KEMAR_220	13:57	17:05	9:48	MAIN SUPPLY FAILURE
845	1-Mar-2020	HASSAN	110	LV3	KEMAR_220	13:57	15:36	10:47	MAIN SUPPLY FAILURE
846	1-Mar-2020	HASSAN	110	KEMAR-Manipal1	KEMAR_220	13:57	16:54	11:47	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
847	1-Mar-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	13:57	16:55	12:48	MAIN SUPPLY FAILURE
848	1-Mar-2020	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	13:57	16:41	13:47	MAIN SUPPLY FAILURE
849	1-Mar-2020	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	13:57	16:42	14:47	MAIN SUPPLY FAILURE
850	1-Mar-2020	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	13:58	15:21	15:48	MAIN SUPPLY FAILURE
851	1-Mar-2020	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	13:58	15:21	16:47	MAIN SUPPLY FAILURE
852	1-Mar-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	13:58	15:16	17:47	MAIN SUPPLY FAILURE
853	1-Mar-2020	HASSAN	110	HV1	MRSMSG_220	13:58	14:55	18:48	MAIN SUPPLY FAILURE
854	1-Mar-2020	HASSAN	110	HV2	MRSMSG_220	13:58	14:45	19:47	MAIN SUPPLY FAILURE
855	1-Mar-2020	HASSAN	110	HV3	MRSMSG_220	13:58	14:54	20:47	MAIN SUPPLY FAILURE
856	1-Mar-2020	HASSAN	110	HV4	MRSMSG_220	13:58	14:53	21:48	MAIN SUPPLY FAILURE
857	1-Mar-2020	HASSAN	110	HV5	MRSMSG_220	13:58	14:47	22:47	MAIN SUPPLY FAILURE
858	1-Mar-2020	HASSAN	110	LV1	MRSMSG_220	13:58	14:44	23:47	MAIN SUPPLY FAILURE
859	1-Mar-2020	HASSAN	110	LV2	MRSMSG_220	13:58	14:47	0:48	MAIN SUPPLY FAILURE
860	1-Mar-2020	HASSAN	110	LV3	MRSMSG_220	13:58	15:07	1:47	MAIN SUPPLY FAILURE
861	1-Mar-2020	HASSAN	110	MRSSHM-MPM	MRSMSG_220	13:58	15:16	2:47	MAIN SUPPLY FAILURE
862	1-Mar-2020	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	13:58	15:17	3:48	MAIN SUPPLY FAILURE
863	1-Mar-2020	HASSAN	110	MRSSHM-SS1	MRSMSG_220	13:58	15:04	4:47	MAIN SUPPLY FAILURE
864	1-Mar-2020	HASSAN	110	MRSSHM-SS2	MRSMSG_220	13:58	15:04	5:47	MAIN SUPPLY FAILURE
865	1-Mar-2020	HASSAN	110	MSEZ-GSS31	MSEZ_220	13:57	16:00	6:48	MAIN SUPPLY FAILURE
866	1-Mar-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	13:57	16:48	7:47	MAIN SUPPLY FAILURE
867	1-Mar-2020	HASSAN	110	HV	PUTTUR_220	13:57	15:48	8:47	MAIN SUPPLY FAILURE
868	1-Mar-2020	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	13:57	15:51	9:48	MAIN SUPPLY FAILURE
869	1-Mar-2020	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	13:57	15:59	10:47	MAIN SUPPLY FAILURE
870	1-Mar-2020	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	13:57	16:12	11:47	MAIN SUPPLY FAILURE
871	1-Mar-2020	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	14:01	17:01	12:48	MAIN SUPPLY FAILURE
872	1-Mar-2020	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	13:58	15:46	13:47	MAIN SUPPLY FAILURE
873	1-Mar-2020	HASSAN	110	HALADY1-HOSANGADI	HALADY_110	15:46	15:53	14:47	LINE CLEAR AVAILED
874	1-Mar-2020	HASSAN	110	HV3	ALKOLA_110	14:08	15:09	15:48	MAIN SUPPLY FAILURE
875	1-Mar-2020	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	13:58	15:15	16:47	MAIN SUPPLY FAILURE
876	1-Mar-2020	HASSAN	110	HV1	ANANDAPURA_110	14:10	15:20	17:47	TRANSFORMER FAULT
877	1-Mar-2020	HASSAN	110	HV2	ANANDAPURA_110	14:10	15:35	18:48	TRANSFORMER FAULT
878	1-Mar-2020	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	12:15	14:50	19:47	NFBC ISSUED
879	1-Mar-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	14:00	15:50	20:47	MAIN SUPPLY FAILURE
880	1-Mar-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	16:20	16:35	21:48	LINE CLEAR AVAILED
881	1-Mar-2020	HASSAN	110	HV1	ANAVATTI_110	14:00	15:50	22:47	MAIN SUPPLY FAILURE
882	1-Mar-2020	HASSAN	110	HV1	ANAVATTI_110	16:20	16:35	23:47	LINE CLEAR AVAILED
883	1-Mar-2020	HASSAN	110	HV1	ANAVATTI_110	14:00	15:50	0:48	MAIN SUPPLY FAILURE
884	1-Mar-2020	HASSAN	110	HV2	ANAVATTI_110	16:20	16:35	1:47	LINE CLEAR AVAILED
885	1-Mar-2020	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	14:00	15:50	2:47	MAIN SUPPLY FAILURE
886	1-Mar-2020	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	16:20	16:35	3:48	LINE CLEAR AVAILED
887	1-Mar-2020	HASSAN	110	BAIKAM-KAVOOR	BAIKAMPADI_110	13:57	16:07	4:47	MAIN SUPPLY FAILURE
888	1-Mar-2020	HASSAN	110	HV1	BAIKAMPADI_110	13:57	16:07	5:47	MAIN SUPPLY FAILURE
889	1-Mar-2020	HASSAN	110	HV2	BAIKAMPADI_110	13:57	16:07	6:48	MAIN SUPPLY FAILURE
890	1-Mar-2020	HASSAN	110	HV3	BAIKAMPADI_110	13:57	16:07	7:47	MAIN SUPPLY FAILURE
891	1-Mar-2020	HASSAN	110	HV4	BAIKAMPADI_110	13:57	16:07	8:47	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
892	1-Mar-2020	HASSAN	110	HV5	BAIKAMPADI_110	13:57	16:07	9:48	MAIN SUPPLY FAILURE
893	1-Mar-2020	HASSAN	110	ESSUR-SHRLKP	ESSUR_110	13:58	15:51	10:47	MAIN SUPPLY FAILURE
894	1-Mar-2020	HASSAN	110	HV1	ESSUR_110	13:58	15:51	11:47	MAIN SUPPLY FAILURE
895	1-Mar-2020	HASSAN	110	HV2	ESSUR_110	13:58	15:51	12:48	MAIN SUPPLY FAILURE
896	1-Mar-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	13:55	15:30	13:47	MAIN SUPPLY FAILURE
897	1-Mar-2020	HASSAN	110	HV1	GERUMARA_110	14:10	14:46	14:47	TRANSFORMER FAULT
898	1-Mar-2020	HASSAN	110	HV1	GERUMARA_110	14:00	14:10	15:48	MAIN SUPPLY FAILURE
899	1-Mar-2020	HASSAN	110	HV2	GERUMARA_110	14:10	15:10	16:47	TRANSFORMER FAULT
900	1-Mar-2020	HASSAN	110	HV2	GERUMARA_110	14:00	14:10	17:47	MAIN SUPPLY FAILURE
901	1-Mar-2020	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	13:57	16:43	18:48	MAIN SUPPLY FAILURE
902	1-Mar-2020	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	13:57	15:51	19:47	MAIN SUPPLY FAILURE
903	1-Mar-2020	HASSAN	110	GURUVA-SLPWR	GURUVAYANAKERE_110	13:58	17:13	20:47	MAIN SUPPLY FAILURE
904	1-Mar-2020	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	13:58	15:45	21:48	MAIN SUPPLY FAILURE
905	1-Mar-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	13:58	15:47	22:47	MAIN SUPPLY FAILURE
906	1-Mar-2020	HASSAN	110	HV1	JOG_110	13:55	18:05	23:47	MAIN SUPPLY FAILURE
907	1-Mar-2020	HASSAN	110	HV2	JOG_110	13:55	19:25	0:48	MAIN SUPPLY FAILURE
908	1-Mar-2020	HASSAN	110	HV1	KALLUSADARAHALLY_110	14:08	16:08	1:47	MAIN SUPPLY FAILURE
909	1-Mar-2020	HASSAN	110	HV2	KONAJE_110	13:57	16:23	2:47	MAIN SUPPLY FAILURE
910	1-Mar-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	13:58	18:44	3:48	MAIN SUPPLY FAILURE
911	1-Mar-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	14:01	17:00	4:47	MAIN SUPPLY FAILURE
912	1-Mar-2020	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	14:01	17:10	5:47	MAIN SUPPLY FAILURE
913	1-Mar-2020	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	14:01	16:50	6:48	MAIN SUPPLY FAILURE
914	1-Mar-2020	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	14:01	16:50	7:47	MAIN SUPPLY FAILURE
915	1-Mar-2020	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	13:56	15:50	8:47	MAIN SUPPLY FAILURE
916	1-Mar-2020	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	13:56	15:50	9:48	MAIN SUPPLY FAILURE
917	1-Mar-2020	HASSAN	110	HV2	SAGARA_110	14:00	15:45	10:47	MAIN SUPPLY FAILURE
918	1-Mar-2020	HASSAN	110	HV1	SAGARA_110	14:00	15:20	11:47	MAIN SUPPLY FAILURE
919	1-Mar-2020	HASSAN	110	HV3	SAGARA_110	14:00	15:20	12:48	MAIN SUPPLY FAILURE
920	1-Mar-2020	HASSAN	110	SAGARA-IDLE	SAGARA_110	14:00	15:05	13:47	MAIN SUPPLY FAILURE
921	1-Mar-2020	HASSAN	110	SAGARA-LST4	SAGARA_110	14:00	15:25	14:47	MAIN SUPPLY FAILURE
922	1-Mar-2020	HASSAN	110	SAGARA-SORABA	SAGARA_110	14:00	16:00	15:48	MAIN SUPPLY FAILURE
923	1-Mar-2020	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:58	15:48	16:47	MAIN SUPPLY FAILURE
924	1-Mar-2020	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:58	15:56	17:47	MAIN SUPPLY FAILURE
925	1-Mar-2020	HASSAN	110	SHRLKP-BARANGI	SHIRALKOPPA_220	13:58	15:54	18:48	MAIN SUPPLY FAILURE
926	1-Mar-2020	HASSAN	110	HV1	SHIRALKOPPA_220	13:58	14:46	19:47	MAIN SUPPLY FAILURE
927	1-Mar-2020	HASSAN	110	HV2	SHIRALKOPPA_220	13:58	14:46	20:47	MAIN SUPPLY FAILURE
928	1-Mar-2020	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:58	15:50	21:48	MAIN SUPPLY FAILURE
929	1-Mar-2020	HASSAN	66	HASSN22-ARAKALGUD	HASSN_220	14:02	17:51	22:47	MAIN SUPPLY FAILURE
930	1-Mar-2020	HASSAN	66	HASSN22-BELUR	HASSN_220	8:53	9:05	23:47	LINE FAULT
931	1-Mar-2020	HASSAN	66	HASSN22-BELUR	HASSN_220	10:35	13:06	0:48	LINE CLEAR AVAILED
932	1-Mar-2020	HASSAN	66	HASSN22-BELUR	HASSN_220	14:02	18:56	1:47	MAIN SUPPLY FAILURE
933	1-Mar-2020	HASSAN	66	HASSN22-CHIKAMAGLUR2	HASSN_220	14:03	16:54	2:47	MAIN SUPPLY FAILURE
934	1-Mar-2020	HASSAN	66	HASSN22-HN PURA	HASSN_220	14:02	18:47	3:48	MAIN SUPPLY FAILURE
935	1-Mar-2020	HASSAN	66	HASSN22-HSN66	HASSN_220	14:02	16:28	4:47	MAIN SUPPLY FAILURE
936	1-Mar-2020	HASSAN	66	HASSN22-HSN66	HASSN_220	16:30	17:46	5:47	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
937	1-Mar-2020	HASSAN	66	HASSN22-MALLALI	HASSN_220	10:28	13:06	6:48	LINE CLEAR AVAILED
938	1-Mar-2020	HASSAN	66	HASSN22-MALLALI	HASSN_220	14:02	18:47	7:47	MAIN SUPPLY FAILURE
939	1-Mar-2020	HASSAN	66	HASSN22-R R NAGAR	HASSN_220	10:19	13:38	8:47	LINE CLEAR AVAILED
940	1-Mar-2020	HASSAN	66	HASSN22-R R NAGAR	HASSN_220	14:02	17:02	9:48	MAIN SUPPLY FAILURE
941	1-Mar-2020	HASSAN	66	HASSN22-R R NAGAR	HASSN_220	17:02	17:49	10:47	MAIN SUPPLY FAILURE
942	1-Mar-2020	HASSAN	66	HASSN22-SKPURA	HASSN_220	14:02	18:09	11:47	MAIN SUPPLY FAILURE
943	1-Mar-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSN_220	10:36	10:44	12:48	LINE CLEAR AVAILED
944	1-Mar-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSN_220	12:50	12:56	13:47	LINE CLEAR AVAILED
945	1-Mar-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSN_220	14:02	16:23	14:47	MAIN SUPPLY FAILURE
946	1-Mar-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSN_220	16:30	18:07	15:48	MAIN SUPPLY FAILURE
947	1-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	13:58	14:55	16:47	MAIN SUPPLY FAILURE
948	1-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	14:55	15:19	17:47	LINE FAULT
949	1-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	15:19	17:34	18:48	LINE FAULT
950	1-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	17:34	23:59	19:47	LINE FAULT
951	1-Mar-2020	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	13:58	14:55	20:47	MAIN SUPPLY FAILURE
952	1-Mar-2020	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	13:58	14:55	21:48	MAIN SUPPLY FAILURE
953	1-Mar-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	13:58	14:55	22:47	MAIN SUPPLY FAILURE
954	1-Mar-2020	HASSAN	66	LV1	MRSMSG_220	13:58	14:55	23:47	MAIN SUPPLY FAILURE
955	1-Mar-2020	HASSAN	66	LV2	MRSMSG_220	13:58	14:55	0:48	MAIN SUPPLY FAILURE
956	1-Mar-2020	HASSAN	66	LV3	MRSMSG_220	13:58	14:54	1:47	MAIN SUPPLY FAILURE
957	1-Mar-2020	HASSAN	66	LV4	MRSMSG_220	13:58	14:54	2:47	MAIN SUPPLY FAILURE
958	1-Mar-2020	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	14:00	18:30	3:48	MAIN SUPPLY FAILURE
959	1-Mar-2020	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	13:05	17:34	4:47	MAIN SUPPLY FAILURE
960	1-Mar-2020	HASSAN	66	HV1	BANDISHETTYHALLI_66	13:58	17:34	5:47	MAIN SUPPLY FAILURE
961	1-Mar-2020	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	13:58	17:34	6:48	MAIN SUPPLY FAILURE
962	1-Mar-2020	HASSAN	66	BANDIDH-HNPURA	BANDISHETTYHALLI_66	13:58	17:34	7:47	MAIN SUPPLY FAILURE
963	1-Mar-2020	HASSAN	66	BANDIDH-HNPURA	BANDISHETTYHALLI_66	6:25	6:35	8:47	MAIN SUPPLY FAILURE
964	1-Mar-2020	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	13:58	15:00	9:48	MAIN SUPPLY FAILURE
965	1-Mar-2020	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	13:58	23:59	10:47	MAIN SUPPLY FAILURE
966	1-Mar-2020	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	13:58	16:00	11:47	MAIN SUPPLY FAILURE
967	1-Mar-2020	HASSAN	66	CHIKMA-L1-ALDUR	CHIKMAGALUR_66	13:56	15:02	12:48	MAIN SUPPLY FAILURE
968	1-Mar-2020	HASSAN	66	HV1	DODDAKADANUR_66	13:55	17:25	13:47	MAIN SUPPLY FAILURE
969	1-Mar-2020	HASSAN	66	HALEBE-HASSAN	HALEBEEDU_66	13:57	16:10	14:47	MAIN SUPPLY FAILURE
970	1-Mar-2020	HASSAN	66	HV1	HALEBEEDU_66	13:57	16:10	15:48	MAIN SUPPLY FAILURE
971	1-Mar-2020	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	9:00	16:51	16:47	MAIN SUPPLY FAILURE
972	1-Mar-2020	HASSAN	66	KANDLI-HASSAN	KANDLI_66	14:00	15:50	17:47	MAIN SUPPLY FAILURE
973	1-Mar-2020	HASSAN	66	KANDLI-HASSAN	KANDLI_66	15:55	16:35	18:48	MAIN SUPPLY FAILURE
974	1-Mar-2020	HASSAN	66	KANDLI-HASSAN	KANDLI_66	17:05	18:10	19:47	MAIN SUPPLY FAILURE
975	1-Mar-2020	HASSAN	66	MAGGE-KANDLI	MAGGE_66	14:00	16:45	20:47	MAIN SUPPLY FAILURE
976	1-Mar-2020	HASSAN	66	MAGGE-KANDLI	MAGGE_66	17:10	18:05	21:48	MAIN SUPPLY FAILURE
977	1-Mar-2020	HASSAN	66	HV1	MAGGE_66	14:00	16:45	22:47	MAIN SUPPLY FAILURE
978	1-Mar-2020	HASSAN	66	HV1	MAGGE_66	17:10	18:05	23:47	MAIN SUPPLY FAILURE
979	1-Mar-2020	HASSAN	66	HV2	MAGGE_66	14:00	16:45	0:48	MAIN SUPPLY FAILURE
980	1-Mar-2020	HASSAN	66	HV2	MAGGE_66	17:10	18:05	1:47	MAIN SUPPLY FAILURE
981	1-Mar-2020	HASSAN	66	HV1	MATTNIVILE_66	14:00	17:00	2:47	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
982	1-Mar-2020	HASSAN	66	MATTNAV-CRPATNA	MATTNAVILE_66	14:00	17:00	3:48	MAIN SUPPLY FAILURE
983	1-Mar-2020	HASSAN	66	HV1	MOSALEHOSAHALLI_66	13:55	17:35	4:47	MAIN SUPPLY FAILURE
984	1-Mar-2020	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	13:55	17:35	5:47	MAIN SUPPLY FAILURE
985	1-Mar-2020	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	10:20	10:30	6:48	LINE CLEAR AVAILED
986	1-Mar-2020	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	13:25	13:40	7:47	LINE CLEAR AVAILED
987	1-Mar-2020	HASSAN	66	RMWNGR-HASSAN	RAMESHWARNAGAR_66	13:57	17:45	8:47	MAIN SUPPLY FAILURE
988	1-Mar-2020	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	8:59	16:51	9:48	LINE CLEAR AVAILED
989	1-Mar-2020	HASSAN	66	HV1	SHRAVANABELAGOLA_66	14:00	16:50	10:47	MAIN SUPPLY FAILURE
990	1-Mar-2020	HASSAN	66	HV2	SHRAVANABELAGOLA_66	14:00	16:50	11:47	MAIN SUPPLY FAILURE
991	1-Mar-2020	HASSAN	66	SBELAG-CRPATNA	SHRAVANABELAGOLA_66	14:00	16:50	12:48	MAIN SUPPLY FAILURE
992	1-Mar-2020	HASSAN	66	HV2	SHANTHIGRAMMA_66	13:55	17:30	13:47	MAIN SUPPLY FAILURE
993	1-Mar-2020	HASSAN	66	SHANTHI-UDAYPURA	SHANTHIGRAMMA_66	13:55	17:30	14:47	MAIN SUPPLY FAILURE
994	1-Mar-2020	HASSAN	66	HV1	SINGAPURA_66	13:57	17:31	15:48	MAIN SUPPLY FAILURE
995	1-Mar-2020	HASSAN	66	SINGAP-HNPURA	SINGAPURA_66	13:57	17:31	16:47	MAIN SUPPLY FAILURE
996	1-Mar-2020	HASSAN	66	HV2	SINGAPURA_66	13:57	17:31	17:47	MAIN SUPPLY FAILURE
997	1-Mar-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	8:53	9:00	18:48	LINE FAULT
998	1-Mar-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	10:35	13:00	19:47	MAIN SUPPLY FAILURE
999	1-Mar-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	13:55	16:25	20:47	MAIN SUPPLY FAILURE
1000	1-Mar-2020	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	16:30	18:05	21:48	MAIN SUPPLY FAILURE
1001	1-Mar-2020	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	14:04	16:50	22:47	MAIN SUPPLY FAILURE
1002	1-Mar-2020	HASSAN	66	HV1	CHANNARAYAPATNA_66	14:04	16:39	23:47	MAIN SUPPLY FAILURE
1003	1-Mar-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	14:04	16:39	0:48	MAIN SUPPLY FAILURE
1004	1-Mar-2020	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	14:04	16:46	1:47	MAIN SUPPLY FAILURE
1005	1-Mar-2020	HASSAN	66	KIADB H-HASAN I\C	KIADB_66	14:00	17:45	2:47	MAIN SUPPLY FAILURE
1006	1-Mar-2020	HASSAN	66	KIADB H-HASAN I\C	KIADB_66	13:25	13:44	3:48	LINE CLEAR AVAILED
1007	1-Mar-2020	HASSAN	66	KIADB H-HASAN I\C	KIADB_66	10:15	10:35	4:47	MAIN SUPPLY FAILURE
1008	1-Mar-2020	MYSORE	220	CR NAGARA-MADHUVANALLI 1	CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66, TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66, BEGUR_66, HARVEY_66, YELANDUR_66 , BHARGI_66, SINDHUVALLI_66 HEMMARGALA_66 PANDYADAHUNDI_66, BADANAGUPPE_66	13:57	17:11	6:48	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1009	1-Mar-2020	MYSORE	220	CR NAGARA-MADHUVANALLI 2	CHANDAKAVADI_66, DODDARAYAPET_66, HONNALLY_MYS_66, ATTIGULIPURA_66 TERAKANAMBE_66, GUNDULPET_66, BOMMALAPURA_66, HANGLA_66, KABHALLY_66. BEGUR_66, HARVEY_66, YELANDUR_66 , BHARGI_66, SINDHUVALLI_66 HEMMARGALA_66 PANDYADAHUNDI_66, BADANAGUPPE_66	13:57	17:11	7:47	MAIN SUPPLY FAILURE
1010	1-Mar-2020	MYSORE	66	HV2	DKMAIDANA_66	18:21	18:31	8:47	TRANSFORMER FAULT
1011	1-Mar-2020	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	3:09	9:48	10:47	LINE FAULT
1012	1-Mar-2020	MYSORE	220	HV1	HOOTAGALLY_220	14:05	16:59	11:47	MAIN SUPPLY FAILURE
1013	1-Mar-2020	MYSORE	220	HV2	HOOTAGALLY_220	14:05	17:00	12:48	MAIN SUPPLY FAILURE
1014	1-Mar-2020	MYSORE	220	HV3	HOOTAGALLY_220	14:04	17:03	13:47	MAIN SUPPLY FAILURE
1015	1-Mar-2020	MYSORE	220	KADAKOLA-CR NAGARA 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66, THANDYA_66 SINDHUVALLI_66 NANJANGUDU_66 KADAKOLA_220	14:02	17:00	14:47	MAIN SUPPLY FAILURE
1016	1-Mar-2020	MYSORE	220	KADAKOLA-CR NAGARA 2	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66, THANDYA_66 SINDHUVALLI_66 NANJANGUDU_66 KADAKOLA_220	14:02	17:01	15:48	MAIN SUPPLY FAILURE
1017	1-Mar-2020	MYSORE	66	KR PETE 220-BOOKANKERE	SHEELUNERE_66, GANJIGERE_66, BOOKANAKERE_66, BANANGADI_66 CHINAKURALI_66	10:37	10:44	18:48	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1018	1-Mar-2020	MYSORE	220	KR PETE 220-CR PATNA	AKKIHEBBAL_66, ANEGOLAL_66, KIKKERI_66, KRISHNAPURA_66, KRPET_220, KRPET_66, SANTHEBACHALLI_66, BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66, SHEELUNERE_66, GANJIGERE_66, BOOKANAKERE_66, BANANGADI_66 CHINAKURALI_66	13:59	16:36	19:47	MAIN SUPPLY FAILURE
1019	1-Mar-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	19:12	19:19	20:47	LINE FAULT
1020	1-Mar-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	21:50	22:04	21:48	LINE FAULT
1021	1-Mar-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	22:21	22:45	22:47	LINE FAULT
1022	1-Mar-2020	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66	23:22	23:59	23:47	LINE FAULT
1023	1-Mar-2020	MYSORE	220	HV1	KUSHALNAGARA 220-	13:58	16:59	1:47	MAIN SUPPLY FAILURE
1024	1-Mar-2020	MYSORE	220	HV2	KUSHALNAGARA 220-	13:58	16:59	2:47	MAIN SUPPLY FAILURE
1025	1-Mar-2020	MYSORE	66	MADHUVANAHALLI-DODDINADUVADI	DODDINADUVADI_66 KOTTANUR_66	13:57	17:28	5:47	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1026	1-Mar-2020	MYSORE	66	MADHUVANAHALLI-KUNTHUR	KUNTHUR_66 JANNUR_66 TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 GARGESHWARI_66 VYASRAJPURA_66	13:57	17:28	6:48	MAIN SUPPLY FAILURE
1027	1-Mar-2020	MYSORE	66	MADHUVANAHALLI-HANNUR1	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	13:57	17:30	7:47	MAIN SUPPLY FAILURE
1028	1-Mar-2020	MYSORE	66	MADHUVANAHALLI-HANNUR2	HANNUR_66 BANDALLI_66 COWDALLI_66 RAMAPURA_MYS_66 MARTAHALLI_66	13:57	17:30	8:47	MAIN SUPPLY FAILURE
1029	1-Mar-2020	MYSORE	66	MADHUVANAHALLI-KOLLEGALA1	SATHEGALA_66 KOLLEGALA_66 PARINAMIPURA_66 THALAKADU_66 BGPURA_66 CHANDALLI_66	13:57	17:28	9:48	MAIN SUPPLY FAILURE
1030	1-Mar-2020	MYSORE	66	MADHUVANAHALLI-PGPALYA	PGPALYA_66	13:57	17:28	10:47	MAIN SUPPLY FAILURE
1031	1-Mar-2020	MYSORE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	13:57	17:39	12:48	MAIN SUPPLY FAILURE
1032	1-Mar-2020	MYSORE	220	TUBINKERE-BASTIPURA	TUBINAKERE_220	13:50	17:08	13:47	MAIN SUPPLY FAILURE
1033	1-Mar-2020	MYSORE	220	TUBINKERE-HUYGONAHALLI	TUBINAKERE_220	13:50	17:16	14:47	MAIN SUPPLY FAILURE
1034	1-Mar-2020	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66, TARIPURA_66	13:57	17:32	15:48	MAIN SUPPLY FAILURE
1035	1-Mar-2020	MYSORE	66	TUBINKERE-G UKKADA	GARUDANAUKADDA_66, SRIRANGAPATNA_66	13:57	17:32	16:47	MAIN SUPPLY FAILURE
1036	1-Mar-2020	MYSORE	66	TUBINKERE-MANDYA 2	BASARALU_66, BESAGARAHALLI_66, CHIKKA_MANDYA_66, HADLI_66, HAMPAPURA_66, KADKOTHANAHALLI_66, KOPPA_66, MALAVALLI_66, MANDYA_66	13:50	0:00	17:47	MAIN SUPPLY FAILURE
1037	1-Mar-2020	MYSORE	66	TUBINKERE-MANDYA 4	BASARALU_66, BESAGARAHALLI_66, CHIKKA_MANDYA_66, HADLI_66, HAMPAPURA_66, KADKOTHANAHALLI_66, KOPPA_66, MALAVALLI_66, MANDYA_66	13:50	17:35	18:48	MAIN SUPPLY FAILURE
1038	1-Mar-2020	MYSORE	66	TUBINKERE-NAGMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66 KESLAGERE_66	13:57	17:17	19:47	MAIN SUPPLY FAILURE
1039	1-Mar-2020	MYSORE	66	TUBINKERE-NAGMANGALA 2	SHIVALLY_66	13:57	17:32	20:47	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1040	1-Mar-2020	MYSORE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66, PANDAVAPURA_66	13:57	17:24	21:48	MAIN SUPPLY FAILURE
1041	1-Mar-2020	MYSORE	220	VAJMANGALA-HOOTAGALLI	VAJAMANGALA_220 DEVANOORMYS_66 FTS_66 MEGALAPURA_66 BANNUR_66 KIRUGAVALU_66 BGPURA_66 JYOTHINAGARA_66 BANNIMANTAP_66 THUMLA_66 RAJEEVNAGARA_66 DKMAIDANA_66 MALIYURU_66 VADKEPURA_66	14:13	17:00	22:47	MAIN SUPPLY FAILURE
1042	1-Mar-2020	TUMKUR	220	TR-1	KBCROSS_220	14:08	14:43	23:47	MAIN SUPPLY FAILURE
1043	1-Mar-2020	TUMKUR	220	TR-2	KBCROSS_220	14:08	15:21	0:48	MAIN SUPPLY FAILURE
1044	1-Mar-2020	TUMKUR	110	TR-1	BANDIHALLI_110	14:08	15:30	1:47	MAIN SUPPLY FAILURE
1045	1-Mar-2020	TUMKUR	110	TR-2	BANDIHALLI_110	14:08	15:30	2:47	MAIN SUPPLY FAILURE
1046	1-Mar-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	14:08	15:30	3:48	MAIN SUPPLY FAILURE
1047	1-Mar-2020	TUMKUR	110	TR-1	HALKURKE_110	14:08	15:28	4:47	MAIN SUPPLY FAILURE
1048	1-Mar-2020	TUMKUR	110	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	13:57	15:18	5:47	LINE CLEAR AVAILED
1049	1-Mar-2020	TUMKUR	110	TR-1	KBCROSS_220	7:13	8:01	6:48	LINE CLEAR AVAILED
1050	1-Mar-2020	TUMKUR	110	TR-1	KBCROSS_220	13:57	15:40	7:47	LINE CLEAR AVAILED
1051	1-Mar-2020	TUMKUR	110	TR-2	KBCROSS_220	14:08	15:01	8:47	LINE CLEAR AVAILED
1052	1-Mar-2020	TUMKUR	110	TR-1(LV1 SIDE)	KBCROSS_220	14:08	15:16	9:48	LINE CLEAR AVAILED
1053	1-Mar-2020	TUMKUR	110	TR-2(LV2)	KBCROSS_220	14:08	15:25	10:47	LINE CLEAR AVAILED
1054	1-Mar-2020	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	13:57	15:27	11:47	LINE CLEAR AVAILED
1055	1-Mar-2020	TUMKUR	66	BHAKTHARA HALLI -ANCHEPALYA	BHAKTHARAHALLI_66	15:59	16:50	12:48	LINE CLEAR AVAILED
1056	1-Mar-2020	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	15:58	16:51	13:47	LINE CLEAR AVAILED
1057	1-Mar-2020	TUMKUR	66	TR-2	CHELURU_66	12:44	12:51	14:47	LINE CLEAR AVAILED
1058	1-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	16:53	17:40	15:48	LINE CLEAR AVAILED
1059	1-Mar-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	18:13	18:24	16:47	LINE CLEAR AVAILED
1060	1-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	16:53	17:40	17:47	LINE CLEAR AVAILED
1061	1-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	18:13	18:24	18:48	LINE CLEAR AVAILED
1062	1-Mar-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:48	20:58	19:47	LINE FAULT
1063	1-Mar-2020	TUMKUR	66	TR-1	HALUVAGALU_66	6:56	7:48	20:47	MAIN SUPPLY FAILURE
1064	1-Mar-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	7:20	9:22	21:48	LINE CLEAR AVAILED
1065	1-Mar-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	18:24	18:34	22:47	LINE FAULT
1066	1-Mar-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:53	17:40	23:47	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1067	1-Mar-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	15:11	16:17	0:48	LINE CLEAR AVAILED
1068	1-Mar-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	17:06	17:41	1:47	LINE CLEAR AVAILED
1069	1-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	5:24	5:29	2:47	LINE FAULT
1070	1-Mar-2020	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:05	12:40	3:48	LINE CLEAR AVAILED
1071	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kv-HARAPPANAHALLI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJIHALLI_66	5:34	7:22	4:47	LOAD CURTAILMENT
1072	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kv-HULUVAGALU	HALUVAGALU_66	5:20	7:25	5:47	LOAD CURTAILMENT
1073	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kv-HULUVAGALU	HALUVAGALU_66	17:42	18:56	6:48	LOAD CURTAILMENT
1074	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kv-PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66,JAGALUR_66,PALLAGATTE_66	4:11	5:20	7:47	LOAD CURTAILMENT
1075	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kv-PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66,JAGALUR_66,PALLAGATTE_66	22:03	22:21	8:47	LOAD CURTAILMENT
1076	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kv-PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66,JAGALUR_66,PALLAGATTE_66	23:43	23:57	9:48	LOAD CURTAILMENT
1077	1-Mar-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	5:35	6:03	10:47	LOAD CURTAILMENT
1078	1-Mar-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	16:49	17:42	11:47	LOAD CURTAILMENT
1079	1-Mar-2020	TUMKUR	66	UCHANGIDURGA-I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	6:03	7:27	12:48	LINE CLEAR AVAILED
1080	1-Mar-2020	TUMKUR	66	UCHANGIDURGA-I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	17:41	18:28	13:47	LINE CLEAR AVAILED
1081	1-Mar-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	7:20	9:22	14:47	LINE CLEAR AVAILED
1082	1-Mar-2020	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	18:24	18:34	15:48	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1083	1-Mar-2020	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:53	17:40	16:47	LINE CLEAR AVAILED
1084	1-Mar-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	15:11	16:17	17:47	LINE CLEAR AVAILED
1085	1-Mar-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	17:06	17:41	18:48	LINE CLEAR AVAILED
1086	1-Mar-2020	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUN DA_66	5:24	5:29	19:47	LINE FAULT
1087	1-Mar-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:05	12:40	20:47	LINE CLEAR AVAILED
1088	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kV- HARAPPANAHALLI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJIHALLI_66	5:34	7:22	21:48	LOAD CURTAILMENT
1089	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	5:20	7:25	22:47	LOAD CURTAILMENT
1090	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	17:42	18:56	23:47	LOAD CURTAILMENT
1091	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGID URGA_66,JAGALUR_66,PALLAGATTE_ 66	4:11	5:20	0:48	LOAD CURTAILMENT
1092	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGID URGA_66,JAGALUR_66,PALLAGATTE_ 66	22:03	22:21	1:47	LOAD CURTAILMENT
1093	1-Mar-2020	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGID URGA_66,JAGALUR_66,PALLAGATTE_ 66	23:43	23:57	2:47	LOAD CURTAILMENT
1094	1-Mar-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAPPANAH ALLI_66,HALUVAGALU_66,TELAGI_66	5:35	6:03	3:48	LOAD CURTAILMENT
1095	1-Mar-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66,HARAPPANAH ALLI_66,HALUVAGALU_66,TELAGI_66	16:49	17:42	4:47	LOAD CURTAILMENT
1096	1-Mar-2020	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	6:03	7:27	5:47	LINE CLEAR AVAILED
1097	1-Mar-2020	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANG(NEELAGUNDA)	UCHCHANGIDURGA_66	17:41	18:28	6:48	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1098	2-Mar-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGER_110	7:40	23:59	7:47	LINE CLEAR AVAILED
1099	2-Mar-2020	BAGALKOT	110	DAMBAL-GADAG 2	DAMBAL_110	0:00	10:10	8:47	LINE CLEAR AVAILED
1100	2-Mar-2020	BAGALKOT	110	DAMBAL-SUZLON 2	DAMBAL_110	8:41	10:30	9:48	LINE CLEAR AVAILED
1101	2-Mar-2020	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	8:41	11:00	10:47	LINE CLEAR AVAILED
1102	2-Mar-2020	BAGALKOT	110	110/11KV,HV 1	DAMBAL_110	8:41	10:25	11:47	LINE CLEAR AVAILED
1103	2-Mar-2020	BAGALKOT	110	GADAG-DAMBAL L2	DAMBAL_110	8:42	11:43	12:48	LINE CLEAR AVAILED
1104	2-Mar-2020	BAGALKOT	110	SIRSI(AMBEWADI)-KIRUVATTI	KIRUVATTI_110	1:27	23:59	13:47	LINE CLEAR AVAILED
1105	2-Mar-2020	BAGALKOT	110	L1 & L2 NARENDRA-MRUTHYUNJAYANAGAR	MRUTHYUNJAYANAGAR_110	11:25	15:02	14:47	NFBC ISSUED
1106	2-Mar-2020	BAGALKOT	110	MUNDARAGI-VIJAYANAGAR SUGAR	MUNDARAGI_110	8:41	10:13	15:48	LINE CLEAR AVAILED
1107	2-Mar-2020	BAGALKOT	110	SANKESHWAR-HUKKERI	HUKKERI_110	11:36	11:43	16:47	LINE CLEAR AVAILED
1108	2-Mar-2020	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	12:04	14:15	17:47	LINE CLEAR AVAILED
1109	2-Mar-2020	BAGALKOT	110	110/11KV, HV1	YELPARAHATTI_110	11:35	12:42	18:48	LINE CLEAR AVAILED
1110	2-Mar-2020	BAGALKOT	110	110/11KV, HV1&HV2	YARAGATTI_110	7:19	14:34	19:47	LINE CLEAR AVAILED
1111	2-Mar-2020	BAGALKOT	110	110/33KV, HV3	YARAGATTI_110, SHIVAPURA_33	7:19	14:34	20:47	LINE CLEAR AVAILED
1112	2-Mar-2020	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	10:37	16:40	21:48	LINE CLEAR AVAILED
1113	2-Mar-2020	BAGALKOT	110	VAJRAMATTI220-KATARKI	KATARKI_110	10:37	16:12	22:47	LINE CLEAR AVAILED
1114	2-Mar-2020	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	VAJRAMATTI_220	5:23	7:06	23:47	LINE FAULT
1115	2-Mar-2020	BAGALKOT	110	SOUDATTI220-YARGATTI	YARAGATTI_110	7:13	14:32	0:48	LINE FAULT
1116	2-Mar-2020	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	11:23	12:41	1:47	LINE CLEAR AVAILED
1117	2-Mar-2020	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	12:44	13:05	2:47	LINE CLEAR AVAILED
1118	2-Mar-2020	BENGALURU	66	KADUGODI - ARMY WELFARE ORGANIZATION	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	8:20	8:50	3:48	LINE FAULT
1119	2-Mar-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	5:28	5:37	4:47	LINE FAULT
1120	2-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	9:46	10:09	5:47	LOAD CURTAILMENT
1121	2-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	14:10	14:25	6:48	LOAD CURTAILMENT
1122	2-Mar-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	15:20	15:30	7:47	LOAD CURTAILMENT
1123	2-Mar-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:05	15:25	8:47	LOAD CURTAILMENT
1124	2-Mar-2020	BENGALURU	66	HV1	BANASHANKARI	8:09	8:13	9:48	TRANSFORMER FAULT
1125	2-Mar-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	14:23	14:27	10:47	LINE FAULT
1126	2-Mar-2020	BENGALURU	66	HV2	MAHALAKSHMI LAYOUT	10:59	11:05	11:47	LINE CLEAR AVAILED
1127	2-Mar-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66, ISKON	7:15	7:33	12:48	LINE FAULT
1128	2-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:26	11:38	13:47	LINE FAULT
1129	2-Mar-2020	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:26	11:38	14:47	LINE FAULT
1130	2-Mar-2020	GULBARGA	66	ITTAGGI-TBHALLI	TAMBRAHALLI_66,HAMPASAGAR_66, MORAGERE_66	18:06	18:35	15:48	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1131	2-Mar-2020	GULBARGA	66	ITTAGGI-KUDLIGI1,2	KUDLIGI_66,KOGALI_66,CHORNOOR_66,HOSAHALLI_66,CJHALLI_66,BANVE KAL_66,GUDEKOTE_66	20:30	20:51	16:47	LINE CLEAR AVAILED
1132	2-Mar-2020	GULBARGA	220	ITTAGGI-NEELAGUNDA	ITTAGI_220	17:05	17:35	17:47	LINE CLEAR AVAILED
1133	2-Mar-2020	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,M ANTHAL_110	0:00	15:45	18:48	LINE FAULT
1134	2-Mar-2020	GULBARGA	110	HV2	MADIYAL_110	16:57	17:59	19:47	LINE CLEAR AVAILED
1135	2-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	1:35	1:40	20:47	LINE FAULT
1136	2-Mar-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	3:26	3:32	21:48	LINE FAULT
1137	2-Mar-2020	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM-220	13:31	13:32	22:47	LINE FAULT
1138	2-Mar-2020	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110,SAI DAPUR_110,CORE GREEN SUGAR_IPP,SANNATHI_IPP	23:46	23:54	23:47	LINE FAULT
1139	2-Mar-2020	GULBARGA	110	HALBARGA-CHIDRI1	CHIDRI_110	19:04	19:12	0:48	LINE FAULT
1140	2-Mar-2020	GULBARGA	220	BMMISPAT-ITTAGGI	ITTAGI_220	16:35	18:19	1:47	LINE FAULT
1141	2-Mar-2020	HASSAN	400	HASSAN4-NLM400	SHANTHIGRAMA_400	11:06	17:16	2:47	LINE CLEAR AVAILED
1142	2-Mar-2020	HASSAN	400	HASSAN4-TLGP400	SHANTHIGRAMA_400	10:57	17:13	3:48	LINE CLEAR AVAILED
1143	2-Mar-2020	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	10:57	17:13	4:47	NFBC ISSUED
1144	2-Mar-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	15:44	18:59	5:47	LINE FAULT
1145	2-Mar-2020	HASSAN	220	VARAHI-SHMG3	varahi_gen	15:44	19:00	6:48	LINE FAULT
1146	2-Mar-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	17:38	18:47	7:47	LINE CLEAR AVAILED
1147	2-Mar-2020	HASSAN	110	HV2	BAIKAMPADY_110	10:10	17:01	8:47	LINE CLEAR AVAILED
1148	2-Mar-2020	HASSAN	110	HV2	BARANGI_110	9:18	17:28	9:48	TRANSFORMER FAULT
1149	2-Mar-2020	HASSAN	110	HV1	JAVAGAL_110	15:56	16:01	10:47	LINE CLEAR AVAILED
1150	2-Mar-2020	HASSAN	110	HV1	MOODABIDRE_110	5:49	6:04	11:47	TRANSFORMER FAULT
1151	2-Mar-2020	HASSAN	110	HV2	NANDIKUR_110	14:59	15:05	12:48	LINE CLEAR AVAILED
1152	2-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	10:50	13:11	13:47	LINE FAULT
1153	2-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	13:15	13:21	14:47	LINE CLEAR AVAILED
1154	2-Mar-2020	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	15:53	23:59	15:48	NFBC ISSUED
1155	2-Mar-2020	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	11:11	11:43	16:47	LINE FAULT
1156	2-Mar-2020	HASSAN	66	HASSN22-BELUR	HASSAN_220	12:52	14:01	17:47	LINE CLEAR AVAILED
1157	2-Mar-2020	HASSAN	66	LV1	HASSAN_220	12:32	12:35	18:48	LINE CLEAR AVAILED
1158	2-Mar-2020	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	12:52	13:59	19:47	LINE CLEAR AVAILED
1159	2-Mar-2020	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	11:43	11:53	20:47	MAIN SUPPLY FAILURE
1160	2-Mar-2020	HASSAN	66	BHADRA-SHMG1	bhadra_gen	0:00	13:24	21:48	MAIN SUPPLY FAILURE
1161	2-Mar-2020	HASSAN	66	BHADRA-SHMG1	bhadra_gen	15:53	23:59	22:47	LINE CLEAR AVAILED
1162	2-Mar-2020	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	16:13	16:53	23:47	LINE CLEAR AVAILED
1163	2-Mar-2020	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	12:40	14:04	0:48	LINE CLEAR AVAILED
1164	2-Mar-2020	HASSAN	66	HV1	HALLYMYSORE_66	5:00	5:10	1:47	TRANSFORMER FAULT
1165	2-Mar-2020	MYSORE	66	BOOKANAKERE-CHINKURLI	BANANGADI_66 CHINAKURALI_66	2:41	3:04	2:47	LINE FAULT
1166	2-Mar-2020	MYSORE	66	HUNSUR-HANAGUDU	HANAGODU_66	16:37	16:45	4:47	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1167	2-Mar-2020	MYSORE	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBKERE_66	11:25	11:57	5:47	LINE FAULT
1168	2-Mar-2020	MYSORE	66	HV1	SATHEGALA_66	13:13	13:17	6:48	TRANSFORMER FAULT
1169	2-Mar-2020	MYSORE	66	HV5	SFCSHIVA_66	5:52	23:59	7:47	LINE CLEAR AVAILED
1170	2-Mar-2020	MYSORE	66	HV2	TERAKANAMBE_66	14:35	15:11	12:48	TRANSFORMER FAULT
1171	2-Mar-2020	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 KESLAGERE_66	10:17	10:24	13:47	LINE CLEAR AVAILED
1172	2-Mar-2020	MYSORE	66	NAGAMANGALA-JAKKANALLY	BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	10:20	12:25	14:47	LINE CLEAR AVAILED
1173	2-Mar-2020	TUMKUR	220	NEELAGUNDA- ITTAGI	NEELAGUNDA_220	17:01	17:23	15:48	LINE CLEAR AVAILED
1174	2-Mar-2020	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	9:30	9:39	16:47	LINE CLEAR AVAILED
1175	2-Mar-2020	TUMKUR	66	TR-2	AVAREGERE_66	13:37	14:23	17:47	LINE CLEAR AVAILED
1176	2-Mar-2020	TUMKUR	66	TR-1	BANUVALLI_66	9:53	12:43	18:48	LINE CLEAR AVAILED
1177	2-Mar-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	10:58	11:56	19:47	TRANSFORMER FAULT
1178	2-Mar-2020	TUMKUR	66	TR-2	HARAPPANAHALLI_66	10:56	13:39	20:47	LINE CLEAR AVAILED
1179	2-Mar-2020	TUMKUR	66	TR-1	HIRIYUR_66	17:31	17:42	21:48	TRANSFORMER FAULT
1180	2-Mar-2020	TUMKUR	66	TR-1	KALAMARANAHALLI_66	10:08	10:17	22:47	LINE CLEAR AVAILED
1181	2-Mar-2020	TUMKUR	66	TR-1	KUNDUR_66	1:58	2:27	23:47	TRANSFORMER FAULT
1182	2-Mar-2020	TUMKUR	66	TR-1	LINGADAHALLY_66	9:02	9:27	0:48	TRANSFORMER FAULT
1183	2-Mar-2020	TUMKUR	66	NEELAGUNDA- TELAGI	PUNABHAGHATTA_66, HARAPPANAH ALLI_66, HALUVAGALU_66, TELAGI_66	0:32	0:58	1:47	LINE FAULT
1184	2-Mar-2020	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	15:34	16:35	2:47	LINE CLEAR AVAILED
1185	2-Mar-2020	TUMKUR	66	RANGENAHALLI- P R PURA	RANGENAHALLI_66	21:34	21:42	3:48	LINE CLEAR AVAILED
1186	2-Mar-2020	TUMKUR	66	TR-1	SASALUHALLA_66	18:03	18:29	4:47	LINE CLEAR AVAILED
1187	2-Mar-2020	TUMKUR	66	TR-2	TELAGI_66	16:35	16:48	5:47	TRANSFORMER FAULT